

Appendix H:
Data Summary Report for
Storm and Sanitary Drain
Systems

SP-012

Attachment 8

**Data
Summary Report**

1. Introduction

Samples were collected from Ford Nuclear Reactor (FNR) storm drain and sanitary sewer lines during 2007 as part of the Decommissioning Phase Characterization. These samples were collected from drain traps and cleanouts of both systems. This report describes the samples and presents the results. It also provides background information on the storm drains and their present configuration following Decommissioning dismantlement activities.

2. System Description

The FNR storm sewer (storm drains) received water from FNR roof drains and from several drains originating inside the FNR. Storm sewer piping exits the FNR at three locations on the Beam Port Floor. These connect to a storm sewer line that runs around the perimeter of the building below grade and connects to a campus main N-S line located just west of the FNR. During FNR operation, the Cold Sump in the Basement received water from floor drains and overflow from the Hot Sump. The FNR process flow diagram shows a connection from the Cold Sump to the storm sewer [Smith 1955].

There are four roof drains that enter the FNR storm sewer system. Two drains on the main roof connect to a line on the Pool Floor ceiling (Room 3101A) which drops to the Beam Port Floor. This line exits the FNR to the external sanitary sewer at the SW corner of the Beam Port Floor. A single drain originates on the FNR Roof above the Third Floor, north of the Cooling Tower. It drops to the ceiling of Room 3104, then to the North Vertical Pipe Chase. This vertical line joins the Cooling Tower Sump Overflow drain inside the pipe chase and then exits the FNR to the external storm sewer at the north side of the building just above the Beam Port Floor elevation. A single drain originates on the FNR Roof above the third floor east of the Cooling Tower. It enters the FNR building in the ceiling of Room 3102 and then drops to the Beam Port Floor through the East Vertical Pipe Chase and exits the FNR to the external storm sewer at the SE corner. A former Secondary System emergency blowdown drain connected to the storm sewer through a 10 inch drain connection located on the east side of the Beam Port Floor. This connection is currently capped with a blank flange. A schematic of the FNR storm sewer connections is shown in Exhibit 1.

There were two paths for FNR waste water to the Ann Arbor sanitary sewer system:

- a. During FNR operation, waste water from the Reactor Pool and floor drains (via the Hot Sump) was routed to three retention tanks in the PML. The water from the PML Retention Tanks was filtered and processed through ion exchange columns and released to the sanitary sewer piping in the PML Basement Piping Tunnel. This waste water was monitored and then released to an Ann Arbor sanitary sewer system main south of the PML.
- b. The sanitary sewer that directly serviced the FNR received waste water from janitor sinks, toilets, showers and lavatories in the FNR. These connect to a sewer line which exits the building near the SE corner of the Beam Port Floor. The line then runs north and west outside the building (below grade) and connects to the N-S sewer trunk line at a man-hole located just west of the FNR.

The sanitary sewer release path from the FNR through the PML (Path a., described above) was investigated in the 2003 FNR Characterization Survey and found to be not impacted by FNR licensed radioactive materials [Ch2 2004]. The PML sanitary sewer was removed from the scope of the FNR Decommissioning. All the remaining connections to the FNR sanitary sewer (Path b.) originated in the 2nd Floor Restrooms and Janitor's Closet. Drains from lavatories, toilets and a urinal (a total of six) connected to a horizontal header in the East Pipe Chase which transitioned to a vertical line which dropped to the sanitary sewer connection on the east wall next to the Beam Port Floor Janitor closet. All the drain piping that connected the 2nd floor restroom lavatories, urinals and commodes to the sanitary sewer has been removed in 2007. The floor, shower and 2nd floor Janitor's closet drains remain.

Two floor drains and one capped drain from Room 2111 drained to a common 4 in. line located in the Beam Port Floor overhead just south of the North Stairwell. This line connects to the vertical drain from the FNR roof in the North Pipe Tunnel. The Room 2111 floor drain piping was removed during decommissioning and no characterization was performed.

Most piping for roof drains and sanitary drains within the FNR is carbon steel. Both the roof drain and sanitary drains transition to cast iron sewer piping (4 and 6 in.) prior to exiting the FNR.

3. System History and Previous Characterization

From the start of operations in 1957 until 1991, liquid effluents from the FNR were routinely released through the PML sanitary sewer via the retention tanks in the PML.¹ During the 2003 FNR Characterization survey, the sanitary sewer system was investigated. Samples were collected from five locations in the sanitary sewer. They were:

- drain line at exit from the PML
- Manhole outside PML where sewer joins main campus trunk line
- Manhole midway between campus and municipal treatment facility
- Manhole near municipal treatment facility
- Manhole upstream of PML sewer outlet connection

The 2004 Characterization Survey Report stated that "none of the sanitary system samples contained positive concentrations of radionuclides; this indicates that the system is not impacted by licensed operations". The storm drain system and the sanitary sewer system within the FNR were not investigated.

The Historical Site Assessment (HSA) report did not address the sanitary sewer or storm sewer systems inside the FNR or the respective sewer lines immediately downstream of the FNR.

¹ University of Michigan, *Ford Nuclear Reactor Decommissioning Plan*, Rev 1, 2006. § 2.1.2.3 describes the historical operation of the retention tanks in the PML and the PML sanitary sewer as the liquid effluent release path from FNR operations.

4. Sampling Basis

Selection of sampling locations considers potential contamination sources and waste water travel paths in the FNR storm and sanitary drain piping. Sources and potential pathways are:

Storm Sewer System: Potential sources for release of contaminated waste water from FNR operations to the storm sewer system were:

- Basement and Beam Port Floor flood events involving reactor pool water
- overflow from the Hot Sump to the Cold Sump
- waste water from floor drains in the HVAC equipment room (Rm 2111).

Other sources of water from the FNR to the storm drain system are the roof drains; Cooling Tower Sump overflow and secondary system blowdown, but these water sources have a low contamination probability.

Sanitary Sewer System: Potential sources of contaminated waste water to the FNR sanitary sewer system include the 2nd floor janitor closet drain, restroom floor and shower drains, lavatories and toilets in the FNR.

The approach to characterization of FNR storm and sanitary systems is to collect samples of material; sediment and corrosion-scale from clean-outs where storm and sanitary sewer lines exit the FNR. Non-destructive means are used to gain access – the goal is to maintain the roof drains and the main sanitary lines functional.

5. Description of Samples

Six sample locations for the storm drains and five sample locations for sanitary drains were identified and samples were collected from all but one location. The proposed sample location at the North Pipe Chase exit to the storm sewer, the pipe cleanout was "frozen" (corroded) in place, so this location was not sampled. Table 1 lists the samples that were collected. As seen in the table. Most sampling locations yielded only a small amount of material – this limits the analytical sensitivity or minimum detectable activity concentrations that can be achieved.

The samples were shipped to a vendor laboratory for analysis. The analyses requested were: tritium, C-14 and gamma spectroscopy.

Ford Nuclear Reactor Decommissioning Project - Characterization Data Summary Report
 SP-012, Storm Drains and Sanitary Sewer

Table 1, Storm Drain and Sanitary Sewer Characterization Samples

| Sample Location -Description | Sample Date | FNRDP Sample ID | Sample Description | Eberline Work Order |
|---|-------------|------------------|--|---------------------|
| Storm Drain - Main FNR Roof Drain clean-out where line exits the FNR at the SW corner of Beam Port Floor (STM DRN-01A) | 10/10/07 | CH-2007-10-10-01 | Sludge in 20 ml vial | 07-10110 |
| Storm Drain - Emergency drain connection, E side of Beam Port Floor (STM DRN-03A) | 10/10/07 | CH-2007-10-10-03 | Dry scale and rust in 20 ml vial | 07-10110 |
| Storm Drain - East Roof Drain line clean-out, Beam Port Floor SE corner where line exits FNR to Storm Drain (adjacent to Janitor's Closet (STM DRN-04A) | 11/06/07 | CH-2007-11-06-01 | Dry residue-scrappings in 20 ml vial | 07-11061 |
| Storm Drain - Manhole west of FNR just west of Storage Ports (STM DRN-05A) | 10/16/07 | CH-2007-10-16-01 | Sludge in 20 ml vial | 07-10110 |
| Storm Drain - Manhole west of FNR just west of Storage Ports (STM DRN-05B) | 10/16/07 | CH-2007-10-16-02 | Sludge in 20 ml vial | 07-10110 |
| Sanitary Drain - Sanitary drain line clean-out, Beam Port Floor SE corner where the line exits the FNR to the Sanitary Sewer (adjacent to Janitor's Closet) (SAN DRN-01A) | 11/6/07 | CH-2007-11-06-02 | Dry dark brown scale-scrappings in 20 ml vial | 07-11061 |
| Sanitary Drain - Second Floor Janitor's closet Floor Drain trap in ceiling on Beam Port Floor. (SAN DRN-02A) | 10/11/07 | CH-2007-10-10-06 | Sludge-scrappings ~ 10 ml in 20 ml vial | 07-10110 |
| Sanitary Drain - Women's 2 nd Floor Restroom shower drain trap on Beam Port Floor Janitor's Closet ceiling (SAN DRN-03A) | 10/10/07 | CH-2007-10-10-05 | Dry scale-rust in 20 ml vial | 07-10110 |
| Sanitary Drain - Men's 2 nd Floor Restroom shower drain trap on Beam Port Floor ceiling (SAN DRN-04A) | 10/10/07 | CH-2007-10-10-07 | Water and sediment in 20 ml vial | 07-10110 |
| Sanitary Drain - Manhole west of FNR just west of Storage Ports (SAN DRN-05A) | 10/17/07 | CH-2007-10-17-05 | ~ ½ gallon of clear liquid (water) in 1 gal. container | 07-10112 |

6. Sample Results

The vendor laboratory reported radionuclide concentrations below MDA for all radionuclides in six of the ten samples. Results above MDA were reported in three storm drain samples and in two sanitary sewer samples. Tables 2 and 3 identify the samples and radionuclides reported as “detected” in the storm drain and sanitary sewer samples, respectively. Each sample result reported as > MDA is discussed below.

Table 2, Storm Drain Sample Screening - Results > MDA

| Sample Location | Sample ID | Sample Date | Analyte | pCi/g | | |
|--|-------------------|-------------|-------------|----------|--------------------|--------------------|
| | | | | Result | CSU ⁽¹⁾ | MDA ⁽²⁾ |
| Main Roof Drain Cleanout SW BP Floor Bldg Exit ⁽³⁾ | CH-2007-10-10-01 | 10/10/2007 | Uranium-235 | 4.14E+00 | 2.06E+00 | 2.14E+00 |
| Emergency Storm Drain Connection BP Floor, E Side ⁽⁴⁾ | CH-2007-10-10-03 | 10/10/2007 | Cobalt-60 | 2.15E+00 | 3.40E-01 | 1.06E+00 |
| East Roof Drain Cleanout SE BP Floor Bldg Exit ⁽⁵⁾ | CH-2007-11-06-01A | 11/6/2007 | Carbon-14 | 1.42E+00 | 3.82E-01 | 1.23E+00 |
| East Roof Drain Cleanout SE BP Floor Bldg Exit ⁽⁵⁾ | CH-2007-11-06-01A | 11/6/2007 | Cesium-137 | 6.83E+00 | 1.59E+00 | 2.60E+00 |
| East Roof Drain Cleanout SE BP Floor Bldg Exit ⁽⁵⁾ | CH-2007-11-06-01A | 11/6/2007 | Tritium | 6.22E+00 | 1.34E+00 | 4.23E+00 |

Table 2 Notes:

1. CSU is combined standard uncertainty, at the one-sigma level.
2. MDA is minimum detectable activity concentration.
3. The vendor laboratory report interpreted that sample CH-2007-10-10-01 demonstrated slightly positive results for U-235 (by gamma spectroscopy) [Eberline Work Order Report 07-10110, 11/6/07].
4. The vendor laboratory report interpreted that sample CH-2007-10-10-03 demonstrated slightly positive results for Co-60 [Eberline Work Order Report 07-10110, 11/6/07].
5. The vendor laboratory report interpreted that sample CH-2007-11-06-01A demonstrated slightly positive results for C-14, Cs-137 and tritium [Eberline Work Order Report 07-11061, 11/30/07].

The sample from the main roof drain connection to the storm sewer (CH-2007-10-10-01) reported a U-235 concentration of 4.14 pCi/g. This sample also reported 0.5 pCi/g for the “duplicate” analysis; within the two-sigma error band of 4.14 ± 4 pCi/g. This sample result was obtained by gamma spectroscopy, which has relatively poor detection sensitivity for U-235 at environmental levels.² Further, a sample upstream in the roof drain catch basin did not show detectable U-235 (see Characterization Package SP-017). It is concluded that this result is not a true “detect”.

² Personal communication, Mike McDougal, Laboratory Manager, Eberline Services, Oak Ridge, TN., 11/12/07.

Ford Nuclear Reactor Decommissioning Project - Characterization Data Summary Report
 SP-012, Storm Drains and Sanitary Sewer

The reported value for C-14 (1.42 ± 0.8 pCi/g) in the East Roof Drain cleanout sample is considered to be a non-detect. It is only slightly > MDA and the MDA is well within the two-sigma uncertainty band. The tritium result from this sample (6.22 ± 2.7 pCi/g) is also judged to be a non-detect – the MDA value is within the sample result uncertainty band. The result reported for Co-60 (2.15 ± 0.7 pCi/g) in the emergency storm drain sample from the connection to the storm sewer (Sample No. CH-2007-10-10-03) is considered to be a true detect. Similarly, the reported result for Cs-137 in the East Roof Drain cleanout at the storm drain exit (6.83 ± 3.2 pCi/g) is considered to be a true detect.

Table 3, Sanitary Sewer Sample Screening - Results > MDA

| Sample Location | Sample ID | Sample Date | Analyte | pCi/g | | |
|--|-------------------|-------------|-----------|----------|--------------------|--------------------|
| | | | | Result | CSU ⁽¹⁾ | MDA ⁽²⁾ |
| Women's 2 nd Floor Rest Room Shower Drain Trap ⁽³⁾ | CH-2007-10-10-05 | 10/10/2007 | Cobalt-60 | 2.08E+00 | 3.63E-01 | 1.03E+00 |
| Sanitary Drain Cleanout SE BP Floor Bldg Exit ⁽⁴⁾ | CH-2007-11-06-02A | 11/6/2007 | Carbon-14 | 9.02E+00 | 3.64E-01 | 9.37E-01 |
| Sanitary Drain Cleanout SE BP Floor Bldg Exit ⁽⁴⁾ | CH-2007-11-06-02A | 11/6/2007 | Tritium | 7.73E+00 | 1.28E+00 | 3.94E+00 |

Table 3 Notes:

1. CSU is combined standard uncertainty, at the one-sigma level.
2. MDA is minimum detectable activity concentration.
3. The vendor laboratory report interpreted that sample CH-2007-10-10-05 demonstrated slightly positive results for Co-60 [Eberline Work Order Report 07-10110, 11/6/07].
4. The vendor laboratory report interpreted that sample CH-2007-11-06-02A demonstrated slightly positive results for C-14 and tritium [Eberline Work Order Report 07-11061 11/30/07].

The sanitary sewer sample results reported to be > MDA are considered to be true detects. The lower limits of the error bands are above the MDA for all these results. No DCGLs have been established for licensed radioactive material in FNR storm and sanitary drains. For reference, the NRC default screening level DCGLs for surface soil are shown in Table 4. It is seen that all the sample positive results are below the soil DCGLs. It is noted that no FNR licensed radionuclides were detected in samples collected from the storm and sanitary sewer mains immediately downstream of the FNR.

Table 4, NRC Screening Level DCGLs for Surface Soil

| Radionuclide | DCGL (pCi/g) |
|--------------|--------------|
| C-14 | 12 |
| tritium | 110 |
| Co-60 | 3.8 |
| Cs-137 | 11 |

7. References

Eberline Services/Oak Ridge Laboratory, University of Michigan FNR D&D, Standard Level IV Report of Analysis, Work Order No. 07-10112-R, October 31, 2007

Eberline Services/Oak Ridge Laboratory, University of Michigan FNR D&D, Standard Level IV Report of Analysis, Work Order No. 07-10110-R, November 6, 2007

Eberline Services/Oak Ridge Laboratory, University of Michigan FNR D&D, Standard Level IV Report of Analysis, Work Order No. 07-11061-R, November 30, 2007

Smith, Hinchmann and Grylls, Inc. University of Michigan Reactor Building, Process Flow Diagram, Drawing M-1, 1/24/1955.

University of Michigan, *Historical Site Assessment for the Ford Nuclear Reactor* [CH2MHill, January 2003],


University of Michigan, Ford Nuclear Reactor, Report of the 2003 FNR Characterization Survey [CH2MHill, June 2004].

University of Michigan, *Ford Nuclear Reactor Decommissioning Plan*, Rev 1, 2006.

Ford Nuclear Reactor Decommissioning Project - Characterization Data Summary Report
SP-012, Storm Drains and Sanitary Sewer

Exhibit 1

FNR STORM SEWER CONNECTIONS AS OF 12/9/97



●

●

Appendix I: Final Disposition of the Storage Ports

●



Ford Nuclear Reactor Facility Final Disposition of the Storage Ports

February 24, 2012



Table of Contents

| | |
|--|----|
| Executive Summary | 3 |
| Description of the Storage Ports Construction and Use | 5 |
| Characterization of the Storage Ports | 8 |
| <i>Characterization of Storage Port Internal Contamination</i> | 9 |
| <i>Determination of DCGLs for the Neutron Activated Soil around Storage Port 1</i> | 10 |
| <i>Characterization of Neutron Activated Soil around Storage Port 1</i> | 13 |
| <i>Characterization of Neutron Activated Concrete around Storage Port No. 1</i> | 15 |
| Storage Port and Contaminated Soil Removal Activity | 17 |
| <i>Removal of Storage Port Vent Lines</i> | 18 |
| <i>Removal of Storage Ports and Concrete Support Wall</i> | 19 |
| Final Status Confirmation Surveys | 20 |
| <i>Free Release Survey of Sections of Storage Ports Remaining in the FNR Wall</i> | 22 |
| <i>Soil and Concrete Survey and Analysis around Storage Port No. 1</i> | 23 |
| <i>Final Status Survey Conclusion</i> | 25 |
| NRC Confirmation Surveys | 25 |
| Appendices | 27 |

List of Appendices

- A Pre-Removal Internal Characterization of the Storage Ports
- B Analytical Data for Activated Soil Characterization around Storage Port No. 1
- C Pre-Excavation Soil Analysis around Storage Port No. 1
- D Analysis of Concrete Support Wall around Storage Port No. 1 Eberline Analytical
- E Storage Port Vent Lines Survey Data Sheet
- F Radiological Survey and Swipe Analysis for Storage Port Ends Remaining in FNR Wall
- G Radiological Survey Report of Excavation Zone Former Storage Port No. 1 Location
- H Analytical Data for Final Status Survey of Soil Located Behind the Section of Support Wall Removed
- I Analytical Data for Final Status Survey of Soil Located Behind the Section of Support Wall Removed
- J Analytical Results from Eberline Analytical for Final Status Survey of the Soil under the Former Storage Port No. 1
- K ORISE Confirmation Samples Collected by NRC



Executive Summary

Fifty storage ports extended through the west wall of the first floor of the reactor and were designed for and used to store beam port plugs, collimators or other equipment from the beam ports. The storage ports were also used to store items with elevated dose readings. The storage ports consisted of forty-two 6" and eight 8" schedule 40 carbon steel pipes that extended 8'-10" into the soil; terminating into an 8" thick concrete wall providing structural support for the pipes ends. The storage ports were arranged in three levels.

Of specific interest was Storage Port No. 1 that was used to store two large Pu²³⁸Be sources from approximately November 1971 to February 2003 when they were relocated to another U-M facility in preparation for decommissioning the reactor facility. These Pu²³⁸Be sources were capable of producing approximately $1.7E+8$ neutrons sec⁻¹ which would be spread in all directions. The other ports were used for storing materials that would not produce a neutron flux capable of activating surrounding soil materials. Therefor the primary areas of concern during the remediation efforts were from:

- Contaminated surfaces and debris inside the storage ports from reactor equipment
- Activated soils surrounding Storage Port No. 1
- Concrete surfaces that may have been within the radius of influence from the Pu²³⁸Be sources in Storage Port No. 1 and become partially activated

During November/December 2008 excavation activity was undertaken to expose the storage ports to facilitate their removal. Activities involved:

- Installation of sheet piling to establish the northern, western and southern limits of the approximately 10' by 52' excavation.
- Excavation from the ground surface down to the bottom of the east/west running storage port pipes at a depth of approximately 13'. All excavated soil from storage ports 4 through 50 was stockpiled for re-use in backfilling the excavation zone. Soil from around storage ports 1 through 3 was removed for disposal.
- The seventeen one inch vent lines and 50 six and eight inch storage ports were cut and removed in a controlled manner.
- The concrete support wall around Storage Port Nos. 1 through 3 was cut and removed from the excavation for disposal.

With the excavation completed and the storage ports all removed, the project moved into a final status survey mode to confirm the ability to backfill and close the site. This involved radiological surveys of the excavation zone where the Pu²³⁸Be sources had been stored in Storage Port No. 1, confirmation soil samples of the area under the former Storage Port No. 1 and to the west of the area where the concrete support wall had been removed, and confirmation of the remaining concrete support wall. In addition, all of the storage port ends remaining in the wall into the FNR facility were surveyed for free release to allow them to remain in place.

The surveys and analytical work performed on remaining soil and the concrete support wall have not identified contamination remaining in the excavation associated with the operation of the storage ports, in particular Storage Port No. 1 that had been used to house high level neutron sources in the form of Pu²³⁸Be. The final status survey supports the conclusion that all remedial



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

activity has been adequately completed to comply with the Default Screening Values of Table 6.91 in NUREG 5512.

On Monday, March 25, 2009 the NRC visited the FNR facility to conduct confirmatory sampling of the storage port soil and concrete for their independent analysis. The NRC radiological analyses of the soil concurred with the analyses conducted by the FNR staff and Eberline Analytical. The excavation was subsequently backfilled.

Description of the Storage Ports Construction and Use

Fifty storage ports extended through the west wall of the first floor of the reactor and were designed for and used to store beam port plugs, collimators or other equipment from the beam ports. The storage ports were also used to store items with elevated dose readings. The storage ports consisted of forty-two 6" and eight 8" schedule 40 (1/4" wall thickness) carbon steel pipes that extended 8'-10" into the soil; terminating into an 8" thick, 10'-9" tall concrete wall providing structural support for the pipes ends. The storage ports were arranged in three levels with the top and bottom levels aligned vertically and the middle level staggered horizontally between adjacent pairs. The configuration resulted in 17 storage ports in the top row, 17 storage ports in the middle row, and 16 storage ports in the bottom row. The storage ports are numbered one through fifty going from south to north and top to bottom (see Figure 1).




Figure 1, Storage Ports numbering system starting with no. 1 to the south and ending with no. 50 to the north

Each storage port had a 1/2" vent line attached near the end of the pipe to provide for air passage into or out of the storage port as the tight fitting beam port plugs, collimators or other equipment were inserted or withdrawn. With the exception of the storage ports at the north and south ends, the vents lines from three storage ports (one each from the top, middle, and bottom rows) were connected to a common vent line using "Y" fittings, and increasing from 1/2 inch pipe at the lowest storage port to 1 inch pipe at the upper storage port (see Figures 2 and 3). The common vent line then turned horizontal and ran parallel to and 3'-6" above the upper storage port to return through the west wall of the reactor building for connection to the Stack 2 exhaust system. The north and south end upper and lower storage ports were connected to common vent lines and run into the west wall of the facility in a similar manner.




Figure 2, Typical Vent Line Layout for the Storage Ports




Figure 3, Storage Ports under Construction – view from NW looking toward SE

The entire installation of storage ports was buried along the west wall of the reactor building, running south to north 48°. The vent lines were located approximately 7'-10" below ground surface, the top row of storage ports were located approximately 10'-2" below ground surface, and the bottom row of storage ports were located approximately 12'-10" below ground surface. (See Figures 4 through 7)



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

was Storage Port No. 1 that was used to store two large Pu²³⁸Be sources from approximately November 1971 to February 2003 when they were relocated to another U-M facility in preparation for decommissioning the reactor facility. These Pu²³⁸Be sources were capable of producing approximately $1.7E+8$ neutrons sec^{-1} (from the paper work provided by Monsanto with the sources) which would be spread 4π from the source in all directions such that at 8 cm from the source, neutron flux in air would be approximately $6E+5$ neutrons $\text{cm}^2 \text{sec}^{-1}$. The other ports were used for storing materials that would not produce a neutron flux capable of activating surrounding soil materials. Therefor the primary areas of concern during the remediation efforts were from:

- Contaminated surfaces and debris inside the storage ports from reactor equipment
- Activated soils surrounding Storage Port No. 1
- Concrete surfaces that may have been within the radius of influence from the Pu²³⁸Be sources in Storage Port No. 1 and become partially activated

Characterization of Storage Port Internal Contamination

To determine internal contamination of the ports, survey work was performed using one minute static gamma measurements at approximately 9" intervals from the entrance to the back of each of the storage ports using a Ludlum 44-10 2" by 2" NaI detector (serial no. 24815). The detector was placed in a 6" or 8" cradle specifically constructed to center the NaI detector in each 6" or 8" storage port. The detector was then connected using a 20' R-59 cable to a Ludlum 2221 Scaler Ratemeter (serial no. 218602). The gross count measurements for each storage port are summarized in Table 1 below with additional data and plots of gross gamma counts as a function of position for each storage port provided in Appendix A (separate binder).

From these measurements, the following observations were made:

- Storage Port No. 1: The activation of the carbon steel wall of by the Pu²³⁸Be sources yielded a peak activity approximately 2' in from the end of the storage port. This agreed with operational knowledge that the Pu²³⁸Be sources were stored approximately one to two feet from the end of the storage port. Removable activity was found at one survey point.
- Storage Port No. 10: The high gamma measurement at the end indicated that there was a piece of activated metal stored at the very end of the storage port and that piece of metal potentially had a high specific activity. Subsequent visual inspection by camera did not identify a source of the elevated measurements. Removable activity was found at three survey points.
- Storage Port No. 48: The high gamma measurement 1' from the end indicated that there may be a piece of activated metal that required removal. Subsequent visual inspection by camera did not identify a source of the elevated measurements. Removable activity was found at three survey points.
- Storage Port No. 12, 13, 26, 29-49: Removable activity was found at various survey points.



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Table 1, Storage Port pre-removal survey results summary

| Port Number | Highest Gross CPM During Scan | Highest Smear in dpm/100cm ² | Port Number | Highest Gross CPM During Scan | Highest Smear in dpm/100cm ² |
|-------------|-------------------------------|---|-------------|-------------------------------|---|
| Port 1 | 2400 @ 8 ft | 121 | Port 26 | 1200 @ 7 ft | 45 |
| Port 2 | 600 @ 10 ft | <MDA | Port 27 | 300-350 | <MDA |
| Port 3 | 300-350 | <MDA | Port 28 | 300-350 | <MDA |
| Port 4 | 300-350 | <MDA | Port 29 | 1000 @ 6.5 ft | 33 |
| Port 5 | 586 @ 5 ft | <MDA | Port 30 | 300-350 | 1220 |
| Port 6 | 800 @ 5.5 ft | <MDA | Port 31 | 300-350 | 37 |
| Port 7 | 300-350 | <MDA | Port 32 | 1300 @ 10 ft | 205 |
| Port 8 | 300-350 | <MDA | Port 33 | 1400 @ 5 ft | 71 |
| Port 9 | 300-350 | <MDA | Port 34 | 300-350 | 5.80 α only |
| Port 10 | 52,000 @ 9 ft | 96 | Port 35 | 3000 @ 8 ft | 83 |
| Port 11 | 300-350 | <MDA | Port 36 | 3000 @ 8 ft | 343 |
| Port 12 | 400-450 | 73 | Port 37 | 300-350 | 31 |
| Port 13 | 1000 @ 5 ft | 1078 | Port 38 | 600 @ 7 ft | 60 |
| Port 14 | 300-350 | <MDA | Port 39 | 300-350 | 140 |
| Port 15 | 300-350 | <MDA | Port 40 | 370 @ 10 ft | 31 |
| Port 16 | 300-350 | <MDA | Port 41 | 1700 @ 6 ft, 600 @ 9 ft | 79 |
| Port 17 | 400-450 | <MDA | Port 42 | 500-600 all | 92 |
| Port 18 | 300-350 | <MDA | Port 43 | 4300 @ 6ft | 73 |
| Port 19 | 300-350 | <MDA | Port 44 | 300-350 | 22 |
| Port 20 | 1000 4-10 ft | <MDA | Port 45 | 1100 @ 9 ft | 690 |
| Port 21 | 300-350 | <MDA | Port 46 | 300-500 all | 119 |
| Port 22 | 300-350 | <MDA | Port 47 | 300-350 | 25 |
| Port 23 | 300-350 | <MDA | Port 48 | 1300-9200 @ 10 ft | 217 |
| Port 24 | 300-350 | <MDA | Port 49 | 5000 @ 10 ft | 58 |
| Port 25 | 300-350 | <MDA | Port 50 | 400-700 all | <MDA |

No feasible method could be identified that would allow characterization of the small diameter vent lines in order to leave them in place. Based on the need to remove the vent lines and the three storage ports with elevated measurements, it was determined the most expeditious route was to remove all storage ports for disposal

Determination of DCGLs for the Neutron Activated Soil around Storage Port 1

Soil samples were collected north of the storage port area in November 2008 to determine a background concentration for the isotopes of concern in the soil near Storage Port No. 1 that may have become activated due to proximity to the Pu²³⁸Be sources. Using a 2 inch diameter dual tube direct push soil sampler, three samples were collected from a depth of 8 feet to 12 feet below the surface (the approximate depth of the storage ports) at a point north of Storage Port No. 50. The soil samples were collected in acetate liners and processed following ASTM (2005) C 999, *Soil Sample Preparation for the Determination of Radionuclides*. The material from the three acetate tubes was dried for two days at 110 degrees C until reaching a constant weight. The sample material from the three samples was combined into one sample, UM2008-11-06-01. The sample was split then into two portions using an ELLE sample splitter and 186 grams of sample material from the first split was sent to Oregon State University for determination of the content of the soil using Instrumental Neutron Activation Analysis (INAA) (refer to the



following site for information:

http://serc.carleton.edu/research_education/geochemsheets/techniques/INAA.html).

The purpose of the Oregon State University analyses was two-fold: first to determine the elemental composition of the soil, and second to give an indication of what radio-isotopes might stand out given exposure to a higher neutron flux rate. In addition it was suspected that certain other elements of possible concern may be present in the soil at levels not detected by the Oregon State University analyses; in particular, tin, molybdenum, and certain of the rare earth elements (REE). Gerhard Erdtmann, Neutron Activation Tables, 1976 was consulted based on the Oregon State University results and the suspect elements to determine what additional radioisotopes might have been produced by neutron activation of the soil. Only those radio-isotopes with a half-life greater than 100 days and absorption cross section of milli-barns or larger were considered in the analysis as others would be present at levels approximately 10E-9 pCi/g or lower.

It was necessary to make reasonable assumptions about the suspect elements concentrations in the soil in order to calculate an estimated activity for their neutron activation products. Since it is known that the REE elements, with the exceptions of europium and cerium, behave geochemically in a predictable way¹, their behavior can be used to estimate the concentration of REEs of interest based on those that were detected in the Oregon State University analyses and the commonly accepted REE pattern in the upper continental crust (UCC) as reported by Taylor and McLennan².

Based on this analysis, the elemental concentration of metal with activation potential and the subsequent significant activation radionuclides and their estimated concentrations are listed in Table 2.

Table 2, Metals in soil with activation potential from Storage Port 1 Activity

| Natural Element | Concentration | Activation Radionuclide | Target isotope % abundance | Activation Cross Section (barn) | Half Life (d-days, a-years) |
|--------------------------------|---------------|-------------------------|----------------------------|---------------------------------|-----------------------------|
| Activation by Thermal Neutrons | | | | | |
| Iron | 15325 µg/g | Fe-55 | 5.8 | 2.25 | 2.7 a |
| Europium | 0.60 µg/g | Eu-152 | 47.8 | 5900 | 12.4 a |
| | | Eu-154 | 52.2 | 390 | 8.5 a |
| Cobalt | 5.0µg/g | Co-60 | 100 | 37.2 | 5.272 a |
| Cesium | 0.92 µg/g | Cs-134 | 100 | 29 | 2.06 a |
| Barium | 292 µg/g | Ba-133 | 0.095 | 8.5 | 10.4 a |
| Cerium | 26 µg/g | La-137 | 0.193 | 7.25 | 60,000 a |
| | | Ce-139 | 0.26 | 1.1 | 137.5 d |
| Chromium | 5.0 µg/g | None ² | - | - | - |
| Antimony | 0.53 µg/g | None ² | - | - | - |
| Hafnium | 0.0044 µg/g | None ² | - | - | - |

¹ Cornell University, Geol. 655 Isotope Geochemistry, Lecture 7, Spring 2003, GEOCHRONOLOGY III, THE SM-ND SYSTEM

² Taylor and McLennan, The Continental Crust: its Composition and Evolution, Blackwell Scientific Publications, 1985, Table 2.15 Chemical composition of the upper continental crust, p.46



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

| Natural Element | Concentration | Activation Radionuclide | Target isotope % abundance | Activation Cross Section (barn) | Half Life (d-days, a-years) |
|-----------------------------|---------------|-------------------------|----------------------------|---------------------------------|-----------------------------|
| Neodymium | 13 µg/g | Sm-151 | 5.62 | 1.2 | 93 a |
| Nickel | 12 µg/g | Ni-59 | 67.88 | 4.6 | 75,000 a |
| | | Ni-63 | 3.66 | 14.2 | 100 a |
| Rubidium | 42 µg/g | None ² | - | - | - |
| Scandium | 4.7 µg/g | None ² | - | - | - |
| Strontium | 202 µg/g | None ² | - | - | - |
| Tantalum | 310 µg/g | Ta-182 | 99.998 | 21 | 115 d |
| Terbium | 349 µg/g | None ² | - | - | - |
| Zinc | 48 µg/g | Zn-65 | 48.9 | 0.78 | 243.7 d |
| Zirconium | 160 µg/g | Zr-93 | 17.11 | 260 x 10 ⁻³ | 1.5 x 10 ⁶ a |
| Tin | 5.5 µg/g | Sn-113 | 0.96 | 1.15 | 115.1 d |
| | | Sn-119m | 24.03 | 16 x 10 ⁻³ | 245 d |
| | | Sn-121m | 32.85 | 1 x 10 ⁻³ | 50 a |
| | | Sn-123 | 4.72 | 180 x 10 ⁻³ | 129.2 d |
| Samarium | 4.5 µg/g | Sm-145 | 3.1 | 0.7 | 340 d |
| | | Sm-151 | 7.4 | 102 | 93 a |
| | | Eu-155 | 22.8 | 5.5 | 4.96 a |
| Gadolinium | 3.8 µg/g | Gd-153 | 0.2 | 1100 | 241.5 d |
| Lutetium | 0.32 µg/g | Lu-177m | 2.6 | 7 | 161 d |
| Activation by Fast Neutrons | | | | | |
| Iron | 15325 µg/g | Mn-54 | 5.8 | 82.5 X 10 ⁻³ | 312.5 d |
| Barium | 292 µg/g | Cs-134 | 2.42 | | |
| Hafnium | 0.0044 µg/g | La-137 | 0.17 | 2.2 x 10 ⁻³ | 1.37 a |
| Nickel | 12 µg/g | Co-60 | | 4.4 x 10 ⁻³ | 5.272 a |
| Terbium | 349 µg/g | Tb-158 | 100 | 3.2 x 10 ⁻³ | 150 a |
| Molybdenum | 1.5 µg/g | Tc-99 | 23.78 | 130 x 10 ⁻³ | 2.15 x 10 ⁵ a |
| Tin | 5.5 µg/g | Sb-125 | 5.8 | 134 x 10 ⁻³ | 2.77 a |

² No activation product with a half-life of greater than 100 day or an absorption cross section smaller than millibarn.

The concentration of activity formed in the soil from a given element by activation of the neutrons from the Pu²³⁸Be source is described by the activation equation:

$$C_{pCi/g} = C_{\mu g/g} * \frac{0.6023 * a_{\%}}{1 \times 10^6 * MW_{g/mole}} (\phi * \sigma_{a-barns}) * \left(1 - 2^{-\frac{t_{irradiation}}{T_{1/2}}} \right)_{Buildup} * \left(2^{-\frac{t_{decay}}{T_{1/2}}} \right)_{Decay}$$

Where:

- $C_{\mu g/g}$ is the concentration of the element in the soil surrounding the storage port
- $a_{\%}$ is the abundance of the isotope of the radionuclide to be measured
- MW is the atomic weight of the element
- ϕ is the neutron flux from the Pu²³⁸Be source
- σ_a is the cross section for the corresponding reaction
- $t_{irradiation}$ is the length of time the soil was exposed to neutrons from the Pu²³⁸Be source
- t_{decay} is the length of time after the irradiation the soil decayed before being excavated
- $T_{1/2}$ is the half-life of the activation product



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

1,000 grams of sample material from the first split was placed into a 500 ml wide mouth Nalgene bottle and analyzed using the U-M high purity germanium (HPGe) detector. The HPGe was calibrated using a 2.09 g cm⁻³ epoxy, 500 ml Nalgene, multi-nuclide standard (Am-241 – 60 keV through Y-99 1836 keV). This sample analysis allows a determination of the isotopic concentration of the above nuclides to less than 25% of the concentration (pCi g⁻¹) that is equivalent to 25 mrem yr⁻¹ for various radio nuclides listed in Table 6.91 of NUREG 5512 Vol 3 (1999), *Residual Radioactive Contamination from Decommissioning – Parameter Analysis*. This sample serves as background for the analyses of the soil around Storage Port No. 1; results are shown in Tables 3 and 4. Analytical reports are available in Appendix B (separate binder).

Table 3, Nuclides of Concern in soil surrounding Storage Port No. 1

| | Concentration (pCi g ⁻¹) equivalent to 25 mrem yr ⁻¹ | EPA Consultation Trigger (pCi g ⁻¹) for Residual Soil Contamination | Typical MDA (pCi g ⁻¹) for 50,000 second analysis |
|--------|---|--|---|
| Mn-54 | 13.9 | 69 | 3 x 10 ⁻² |
| Fe-55 | 9,350 | 269,000 | N/A |
| Co-60 | 3.68 | 4 | 3 x 10 ⁻² |
| Ba-133 | | | 5 x 10 ⁻² |
| Cs-134 | 5.36 | 16 | 3 x 10 ⁻² |
| Eu-152 | 8.66 | 4 | 5 x 10 ⁻² |
| Eu-154 | 8.0 | 5 | 5 x 10 ⁻² |

Table 4, Background soil analysis (sample no. UM2008-11-06-01) for Storage Port Area

| Identified Radionuclide | Measured Concentration (pCi g ⁻¹) | Minimum Detectable Activity (pCi g ⁻¹) | Default Screening Values (pCi/ g ⁻¹) |
|----------------------------|--|--|---|
| Mn-54 | Not Identified | 1.77 x 10 ⁻² | 13.9 |
| Fe-55 | Not Identified | Not Detectable | 9,350 |
| Co-60 | Not Identified | 1.76 x 10 ⁻² | 3.68 |
| Ba-133 | Not Identified | 2.73 x 10 ⁻² | |
| Cs-134 | Not Identified | 1.90 x 10 ⁻² | 5.36 |
| Eu-152 | Not Identified | 2.88 x 10 ⁻² | 8.66 |
| Eu-154 | Not Identified | 2.05 x 10 ⁻² | 8.0 |

Characterization of Neutron Activated Soil around Storage Port 1

In September 2008 three soil samples were collected along Storage Port No. 1, approximately 1.5' from the end of the pipe where the Pu²³⁸Be sources had been stored. The purpose of these samples was to compare them to the radio-isotopes of concern identified in Tables 3 and 4 to determine if the soil had activation products that exceeded the Default Screening Values, requiring removal.

Using a 2 inch diameter dual tube direct push soil sampler, three sample tubes were collected at the two locations along Storage Port No. 1 from a depth of 8 feet to 12 feet below the surface. The soil from the third set of tubes (the approximate depth of the storage ports) was collected for analysis. The sample material from the two geo-probes was identified as sample numbers UM2008-11-20-01 and UM2008-11-20-02. In addition, a 6" hole was hand dug directly over and down to Storage Port No. 1 where sample number UM2008-12-18-01 was collected. All samples were processed following ASTM (2005) C 999, *Soil Sample Preparation for the*



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Determination of Radionuclides. The material was dried for two days at 110 degrees C until reaching a constant weight. 1,000 grams of sample material from each was placed into 500 ml wide mouth Nalgene bottles and analyzed using the U-M high purity germanium (HPGe) detector calibrated using a 2.09 g cm⁻³ epoxy, 500 ml Nalgene, multi-nuclide standard (Am-241 – 60 keV through Y-99 1836 keV). Results shown in Table 5 indicate soil activation products from the Pu²³⁸Be source material that had been stored in the Storage Port No. 1. Analytical reports are in Appendix C (separate binder).

Table 5, Pre-excavation soil samples collected at Storage Port No. 1

| Identified Radionuclide | Measured Concentration (pCi g ⁻¹) ³ | Minimum Detectable Activity (pCi g ⁻¹) | Default Screening Values – Table 3 (pCi/ g ⁻¹) |
|---|--|--|--|
| Sample No. UM2008-11-20-02: Dual Tube sample 1.5' from end of Storage Port No. 1, along south side of port, depth at 8' to -11' [calculated unity factor of 0.03] | | | |
| Mn-54 | 1.31 x 10 ⁻² | 1.30 x 10 ⁻² | 13.9 |
| Fe-55 | 1.6 | - | 9,350 |
| Co-60 | 2.52 x 10 ⁻² | 2.34 x 10 ⁻² | 3.68 |
| Ba-133 | Not Identified | 3.06 x 10 ⁻² | |
| Cs-134 | Not Identified | 2.14 x 10 ⁻² | 5.36 |
| Eu-152 | 0.257 | 4.08 x 10 ⁻² | 8.66 |
| Eu-154 | Not Identified | 2.63 x 10 ⁻² | 8.0 |
| Sample No. UM2008-11-20-01: Dual Tube sample 1.5' from end of Storage Port No. 1, along center line of port, depth at 8' to -12' [calculated unity factor of 0.04] | | | |
| Mn-54 | Not Identified | 1.96 x 10 ⁻² | 13.9 |
| Fe-55 | 1.6 | - | 9,350 |
| Co-60 | 2.42 x 10 ⁻² | 2.05 x 10 ⁻² | 3.68 |
| Ba-133 | Not Identified | 3.02 x 10 ⁻² | |
| Cs-134 | Not Identified | 2.11 x 10 ⁻² | 5.36 |
| Eu-152 | 0.194 | 3.78 x 10 ⁻² | 8.66 |
| Eu-154 | Not Identified | 2.53 x 10 ⁻² | 8.0 |
| Sample No. UM2008-12-18-01: Hand dug soil from within 6 inches of Storage Port No. 1 – [calculated unity factor of 0.37] | | | |
| Mn-54 | <MDA | 2.2 x 10 ⁻² | 13.9 |
| Fe-55 | 2.9 | - | 9,350 |
| Co-60 | 0.462 | 2.61 x 10 ⁻² | 3.68 |
| Ba-133 | Not Identified | 3.19 x 10 ⁻² | |
| Cs-134 | 2.77 x 10 ⁻² | 1.59 x 10 ⁻² | 5.36 |
| Eu-152 | 2.08 | 6.37 x 10 ⁻² | 8.66 |
| Eu-154 | < MDA | 5.35 x 10 ⁻² | 8.00 |

Because the radionuclides are in a mixture, a sum-of-fractions calculation was performed on the samples to determine if the 25 mrem/yr equivalent had been exceeded in the soil. As shown in Table 5, the calculated unity factors ranged from 0.03 to 0.37. The samples indicate some activation of soil particles surrounding Storage Port No. 1 but not to the extent the soil exceeds the Default Screening Values of Table 6.91 in NUREG 5512.

Because the default screening values are based on an assumption that there is at least a 1 meter separation between the activated soil and groundwater, a determination was made that the separation does exist. Based on data collected from a monitoring well located approximately

³ Fe-55 Estimated by activation calculation bases upon measured Cu-152 and Co-60 concentrations

200' south of the storage port location, the groundwater zone was 25' (7.7 m) below the depth of Storage Port No. 1.




Figure 8, Depth to Groundwater Determination

Characterization of Neutron Activated Concrete around Storage Port No. 1

Samples of the concrete from the wall supporting the west end of Storage Port No. 1 were collected to analyze for isotopes that may have been activated by the storage of the Pu^{238}Be sources approximately 1.5' from the end of the storage port. Two samples from the wall were collected after the storage port had been removed. The first was a circular pattern 12" diameter from the centerline of the storage port (UM2009-02-26-01) and the second was a circular pattern 18" diameter from the centerline (UM2009-03-04091). In each sample collection, a clean, 1" rotor-hammer bit was used to drill a series of holes approximately 7" deep in a circular pattern around the centerline of the storage port (see Figure 9).




Figure 9, Concrete sampling around Storage Port 1 to check for activation products

Fines from the drilling operation were collected in a clean “Minute Man Vacuum” purchased specifically for the project. The fines were collected in a paper filter bag from which they were removed for analysis. A total of approximately 1.5 gallons of material were collected for each set of sample drill holes. The samples were submitted to Eberline Analytical for characterization and the results are shown in Table 6. Analytical data sheets are in Attachment D.

Table 6, Characterization of concrete around Storage Port No. 1 end cap (Analysis performed by Eberline)

| Identified Radionuclide | Measured Concentration (pCi g ⁻¹) | Minimum Detectable Activity (pCi g ⁻¹) | Default Screening Values – Table 3 (pCi/ g ⁻¹) |
|--|---|--|--|
| Sample No. UM2009-02-26-01: Concrete wall 12” from centerline of Storage Port No. 1 [calculated unity factor of 0.37] | | | |
| Mn-54 | <MDA | 1.74 x 10 ⁻¹ | 13.9 |
| Fe-55 | 1.48 | 11.4 | 9,350 |
| Co-60 | 2.75 x 10 ⁻¹ | 9.66 x 10 ⁻² | 3.68 |
| Ag-108m | 1.32 x 10 ⁻² | 9.07 x 10 ⁻² | |



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

| Identified Radionuclide | Measured Concentration (pCi g ⁻¹) | Minimum Detectable Activity (pCi g ⁻¹) | Default Screening Values – Table 3 (pCi/ g ⁻¹) |
|---|---|--|--|
| Ba-133 | 6.89 x 10 ⁻² | 1.02 x 10 ⁻¹ | |
| Cs-134 | 9.35 x 10 ⁻³ | 1.05 x 10 ⁻¹ | 5.36 |
| Eu-152 | 1.73 | 3.94 x 10 ⁻¹ | 8.66 |
| Eu-154 | 7.48 x 10 ⁻² | 2.88 x 10 ⁻¹ | 8.0 |
| Eu-155 | 3.23 x 10 ⁻¹ | 2.09 x 10 ⁻¹ | 282 |
| Sample No. UM2009-03-04-01: Concrete wall 18" from centerline of Storage Port No. 1 [calculated unity factor of 0.1] | | | |
| Mn-54 | 2.33 x 10 ⁻² | 1.43 x 10 ⁻¹ | 13.9 |
| Fe-55 | <MDA | 10.5 | 9,350 |
| Co-60 | 8.9 x 10 ⁻² | 8.18 x 10 ⁻² | 3.68 |
| Ag-108m | 1.28 x 10 ⁻² | 6.94 x 10 ⁻² | |
| Ba-133 | <MDA | 7.56 x 10 ⁻² | |
| Cs-134 | 3.59 x 10 ⁻² | 8.61 x 10 ⁻² | 5.36 |
| Eu-152 | 4.94 x 10 ⁻¹ | 6.03 x 10 ⁻¹ | 8.66 |
| Eu-154 | 4.89 x 10 ⁻² | 2.18 x 10 ⁻¹ | 8.0 |
| Eu-155 | 8.28 x 10 ⁻² | 1.76 x 10 ⁻¹ | 282 |

Results of the analysis indicate some activation of the concrete from the Pu²³⁸Be neutron source but at levels below the Default Screening Values. Because the radionuclides are in a mixture, a sum-of-fractions calculation was performed on the samples to determine if the 25 mrem/yr equivalent had been exceeded in the concrete. Calculated sample unity factors were 0.37 and 0.1. The samples indicate some activation of concrete particles surrounding Storage Port No. 1 but not to the extent the concrete exceeds the Default Screening Values of Table 6.91 in NUREG 5512. A decision was made to cut the concrete section of the wall from around Storage Port No. 1 for disposal.

Storage Port and Contaminated Soil Removal Activity

During November/December 2008 excavation activity was undertaken to expose the storage ports to facilitate their removal. Activities involved:

- Installation of sheet piling to establish the northern, western and southern limits of the approximately 10' by 52' excavation (the eastern limit of the excavation was established by the western wall of the building) as shown on figure 10.
- Excavation from the ground surface down to the bottom of the east/west running storage port pipes at a depth of approximately 13'. All excavated soil from storage ports 4 through 50 was stockpiled for re-use in backfilling the excavation zone. Soil from around storage ports 1 through 3 was removed for disposal.
- The seventeen one inch vent lines and 50 six and eight inch storage ports were cut and removed in a controlled manner.
- The concrete support wall around Storage Port Nos. 1 through 3 was cut and removed from the excavation for disposal.




Figure 10, Storage Port excavation zone

Removal of Storage Port Vent Lines

Seventeen 1" vent lines running from the west ends of the storage ports, in an easterly direction back to and through the wall of the FNR facility were removed on December 10, 2008 using a band saw. A cardboard tray was placed under each cut line to contain pipe shavings from the band saw operation. The shavings were placed in a radioactive materials slurry/piping drum for proper disposal.

Following the cutting operation the pipes were wipe sampled at each end, and then taped to seal the openings. The pipes were then placed in the FNR radioactive material area inside FNR and eventually sent for proper disposal. All wipe samples measured below L_c levels. The cardboard tray was checked using a frisker probe Model 44-142, serial no. PR249243, and wipe samples collected and analyzed on a Tenelec Series 5, serial no. 2161, measured below L_c levels. Refer to Appendix E for the survey data sheet.




Figure 11, Cutting vent lines from the storage ports

Removal of Storage Ports and Concrete Support Wall

In December 2008 all 50 storage ports were uncovered, cut, and removed from the excavation zone. The storage ports were moved inside the FNR building for processing and ultimately disposed as low level radioactive waste in a controlled manner. As anticipated from the preliminary soil sampling activities, the soil immediately surrounding Storage Port No. 1 exhibited low-level soil activation from the Pu²³⁸Be sources that had been stored in the storage port. The soil and concrete in a cube approximately 40-inches on a side or approximately 37 cubic feet was removed in a controlled manner and disposed as radioactive waste.




Figure 11, Cutting Storage Ports wall section removed




Figure 12, Concrete support

Final Status Confirmation Surveys

With the excavation completed and the storage ports all removed, the project moved into a final status survey mode to confirm the ability to backfill and close the site. This involved radiological surveys of the excavation zone where the Pu^{238}Be sources had been stored in Storage Port No. 1, confirmation soil samples of the area under the former Storage Port No. 1 and to the west of the area where the concrete support wall had been removed, and confirmation of the remaining concrete support wall. In addition, all of the storage port ends remaining in the wall into the FNR facility were surveyed for free release to allow them to remain in place. The NRC then made a site visit and collected samples of the soil and concrete to confirm the analysis in order to allow backfilling of the excavation. Figure 13 identifies the sample locations.




Figure 13, Final Status Survey sample locations for Storage Port No. 1




Figure 14, Storage port excavation ready for final survey work

Free Release Survey of Sections of Storage Ports Remaining in the FNR Wall

To determine the ability to free-release and leave in the wall the remaining sections of storage ports that could not be removed, survey work was performed using one minute static gamma measurements at two locations on each pipe end. The survey was performed using a Ludlum 44-1 NaI detector, serial no. PR249243, on January 9, 2009. Swipe samples were also collected and analyzed for alpha and beta using a Tenelec S5-XLB, serial no. 2161. The measurements for each storage port are summarized in Table 7 below with survey data sheets provided in Appendix F (separate binder).

The survey results indicate the pipe ends can all be free-released and left in the wall of the FNR. The ends were plugged and capped to prevent soil infiltration to the FNR facility during backfill of the excavation.



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Table 7, Final Status Survey of Storage Port pipe-ends remaining in FNR wall

| Port Number | Highest Gross CPM During Scan | Highest Smear in dpm/100cm ² | Port Number | Highest Gross CPM During Scan | Highest Smear in dpm/100cm ² |
|-------------|-------------------------------|---|-------------|-------------------------------|---|
| Port 1 | <MDA | <MDA | Port 26 | <MDA | <MDA |
| Port 2 | <MDA | <MDA | Port 27 | <MDA | <MDA |
| Port 3 | <MDA | <MDA | Port 28 | <MDA | <MDA |
| Port 4 | <MDA | <MDA | Port 29 | <MDA | <MDA |
| Port 5 | <MDA | <MDA | Port 30 | <MDA | <MDA |
| Port 6 | <MDA | <MDA | Port 31 | <MDA | <MDA |
| Port 7 | <MDA | <MDA | Port 32 | <MDA | <MDA |
| Port 8 | <MDA | <MDA | Port 33 | <MDA | <MDA |
| Port 9 | <MDA | <MDA | Port 34 | <MDA | <MDA |
| Port 10 | <MDA | <MDA | Port 35 | <MDA | <MDA |
| Port 11 | <MDA | <MDA | Port 36 | <MDA | <MDA |
| Port 12 | <MDA | <MDA | Port 37 | <MDA | <MDA |
| Port 13 | <MDA | <MDA | Port 38 | <MDA | <MDA |
| Port 14 | <MDA | <MDA | Port 39 | <MDA | <MDA |
| Port 15 | <MDA | <MDA | Port 40 | <MDA | <MDA |
| Port 16 | <MDA | <MDA | Port 41 | <MDA | <MDA |
| Port 17 | <MDA | <MDA | Port 42 | <MDA | <MDA |
| Port 18 | <MDA | <MDA | Port 43 | <MDA | <MDA |
| Port 19 | <MDA | <MDA | Port 44 | <MDA | <MDA |
| Port 20 | <MDA | <MDA | Port 45 | <MDA | <MDA |
| Port 21 | <MDA | <MDA | Port 46 | <MDA | <MDA |
| Port 22 | <MDA | <MDA | Port 47 | <MDA | <MDA |
| Port 23 | <MDA | <MDA | Port 48 | <MDA | <MDA |
| Port 24 | <MDA | <MDA | Port 49 | <MDA | <MDA |
| Port 25 | <MDA | <MDA | Port 50 | <MDA | <MDA |

Soil and Concrete Survey and Analysis around Storage Port No. 1

On April 13, 2009 a survey of the soil and concrete support wall around the former location of Storage Port No. 1 was conducted using a Ludlum Model 19 MicroR Meter, serial no. 101763. All measurements were at or below the background levels as determined through measurements at the north end of the excavation zone. Appendix G (separate binder) is the Radiological Survey Report for this effort.

Following removal of the section of concrete support wall from the south end, up through Storage Port No. 3 including the concrete around Storage Port No. 1, a sample of the cut edge of the remaining concrete was collected and analyzed to determine residual activation products. The sample was collected using a diamond grinder with a new diamond wheel to grind the concrete surface. Dust from the grinding was collected in a clean Minuteman vacuum designated specifically for sample collection. The sample was processed and analyzed using the U-M high purity germanium (HPGe) detector calibrated using a 2.09 g cm⁻³ epoxy, 500 ml Nalgene, multi-nuclide standard (Am-241 – 60 keV through Y-99 1836 keV). The samples are compared to the activation products identified in the concrete prior to removal. Table 8 below provides results of that analysis and the analytical data is in Appendix H (separate binder).



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Table 8, Final Status Survey Characterization of concrete support wall remaining in the excavation zone

| Identified Radionuclide | Pre-Removal Measured Concentration (pCi g ⁻¹) | Post-Removal Measured Concentration (pCi g ⁻¹) | Minimum Detectable Activity (pCi g ⁻¹) | Default Screening Values – Table 3 (pCi/ g ⁻¹) |
|--|---|--|--|--|
| Sample No. UM2009-04-24-01: Edge of remaining concrete wall at centerline of removed Storage Port No. 1 | | | | |
| Mn-54 | <MDA | <MDA | 3.72 x 10 ⁻¹ | 13.9 |
| Fe-55 | 1.48 | <MDA | 11.4 | 9,350 |
| Co-60 | 2.75 x 10 ⁻¹ | <MDA | 5.84 x 10 ⁻² | 3.68 |
| Ag-108m | 1.32 x 10 ⁻² | <MDA | 2.9 x 10 ⁻² | |
| Ba-133 | 6.89 x 10 ⁻² | <MDA | 7.88 x 10 ⁻¹ | |
| Cs-134 | 9.35 x 10 ⁻³ | <MDA | 1.05 x 10 ⁻¹ | 5.36 |
| Eu-152 | 1.73 | 8.58 x 10 ⁻² | 7.26 x 10 ⁻² | 8.66 |
| Eu-154 | 7.48 x 10 ⁻² | <MDA | 5.83 x 10 ⁻² | 8.0 |
| Eu-155 | 3.23 x 10 ⁻¹ | ND | ND | 282 |

Following removal of the support wall section for Storage Port No. 1 the soil behind the wall was analyzed to determine if the soil was impacted by the neutron flux from the former Pu²³⁸Be sources stored in the vicinity. The soil sample was collected using a clean flat scoop using ASTM D5633 (2004) methodology. The sample was processed following ASTM (2005) C 999, *Soil Sample Preparation for the Determination of Radionuclides*. The material was dried for two days at 110 degrees C until reaching a constant weight. 1,000 grams of sample material from each was placed into 500 ml wide mouth Nalgene bottles and analyzed using the U-M high purity germanium (HPGe) detector calibrated using a 2.09 g cm⁻³ epoxy, 500 ml Nalgene, multi-nuclide standard (Am-241 – 60 keV through Y-99 1836 keV). Table 9 below provides results of that analysis and the analytical data is in Appendix I (separate binder).

Table 9, Final Status Survey soil sample from behind support wall for Storage Port No. 1

| Identified Radionuclide | Measured Concentration (pCi g ⁻¹) ⁴ | Minimum Detectable Activity (pCi g ⁻¹) | Default Screening Values – Table 3 (pCi/ g ⁻¹) |
|---|--|--|--|
| Sample No. UM2009-03-25-02: Soil from behind support wall for Storage Port No. 1 | | | |
| Mn-54 | <MDA | 2.4 x 10 ⁻¹ | 13.9 |
| Fe-55 | <MDA | - | 9,350 |
| Co-60 | <MDA | 3.7 x 10 ⁻² | 3.68 |
| Ba-133 | <MDA | 5.36 x 10 ⁻² | |
| Cs-134 | <MDA | 5.23 x 10 ⁻² | 5.36 |
| Eu-152 | <MDA | 5.29 x 10 ⁻² | 8.66 |
| Eu-154 | <MDA | 4.4 x 10 ⁻² | 8.0 |

The only original soil remaining from around Storage Port No. 1 was the bottom of the excavation, approximately 20” below the former storage port, and the south wall of the excavation approximately 22” from the former storage port. The soil from the top, north, and east sides was removed. Soil samples were collected from these locations using a clean flat scoop. The samples were processed and sent to Eberline Analytical for final status survey determination of final closure of the excavation. Figure 13 above shows the sample locations and orientation with the former storage port. Table 10 below provides results of that analysis and the analytical data is in Appendix J (separate binder).

⁴ Fe-55 Estimated by activation calculation bases upon measured Cu-152 and Co-60 concentrations



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Table 10, Final Status Survey Soil samples from around the former Storage Port No. 1 (Eberline Analytical)

| Identified Radionuclide | Measured Concentration (pCi g ⁻¹) ⁵ | Minimum Detectable Activity (pCi g ⁻¹) | Default Screening Values – Table 3 (pCi/ g ⁻¹) |
|--|--|--|--|
| Sample No. UM2009-02-06-02: Soil on floor of excavation directly under former Pu²³⁸Be source in Storage Port No. 1 [calculated unity factor of 0.08] | | | |
| Mn-54 | <MDA | 5.36 x 10 ⁻² | 13.9 |
| Fe-55 | <MDA | 3.87 | 9,350 |
| Co-60 | 7.64 x 10 ⁻² | 6.51 x 10 ⁻² | 3.68 |
| Ba-133 | Not Identified | Not Identified | |
| Cs-134 | <MDA | 5.38 x 10 ⁻² | 5.36 |
| Eu-152 | 5.1 x 10 ⁻¹ | 3.58 x 10 ⁻¹ | 8.66 |
| Eu-154 | <MDA | 1.77 x 10 ⁻¹ | 8.0 |
| Sample No. UM2009-02-06-04: Soil on south wall of excavation directly adjacent to former Pu²³⁸Be source in Storage Port No. 1 | | | |
| Mn-54 | <MDA | 1.11 x 10 ⁻¹ | 13.9 |
| Fe-55 | <MDA | 4.16 | 9,350 |
| Co-60 | <MDA | 1.58 x 10 ⁻¹ | 3.68 |
| Ba-133 | Not Identified | Not Identified | |
| Cs-134 | <MDA | 1.00 x 10 ⁻¹ | 5.36 |
| Eu-152 | <MDA | 1.00 | 8.66 |
| Eu-154 | <MDA | 2.99 x 10 ⁻¹ | 8.0 |

Because the radionuclides are in a mixture, a sum-of-fractions calculation was performed on the samples to determine if the 25 mrem/yr equivalent had been exceeded in the soil. As shown in Table 10, the calculated unity factor for the soil under the former Pu²³⁸Be sources was 0.08, indicating the remaining soils in the excavation do not exceed the Default Screening Values of Table 6.91 in NUREG 5512.

Final Status Survey Conclusion

The surveys and analytical work performed on remaining soil and the concrete support wall have not identified contamination remaining in the excavation associated with the operation of the storage ports, in particular Storage Port No. 1 that had been used to house high level neutron sources in the form of Pu²³⁸Be. The final status survey supports the conclusion that all remedial activity has been adequately completed to comply with the Default Screening Values of Table 6.91 in NUREG 5512.

NRC Confirmation Surveys

On December 11, 2008, the decommissioning branch of the NRC conducted an inspection of activities at the FNR facility. The NRC inspection team consisted of Senior Health Physicist Bill Snell and staff Health Physicist Jeremy Tapp. The purpose of the inspection was to determine whether the decommissioning activities were conducted safely and in accordance with NRC requirements. Specifically, the two inspectors evaluated decommissioning activities and radioactive waste management. The primary activity observed during the inspection was the removal of the underground storage ports and associated vent lines. The inspectors determined that the University of Michigan was effectively completing decontamination and dismantlement

⁵ Fe-55 Estimated by activation calculation bases upon measured Cu-152 and Co-60 concentrations



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

activities along with adequate calibration of survey equipment and completion of associated documentation. In an NRC inspection report dated December 23, 2008, the NRC noted that no radiological concerns were identified during facility tours and observations of work in progress.

On Monday, March 25, 2009 the NRC visited the FNR facility to conduct confirmatory sampling of the storage port soil and concrete for their independent analysis. The NRC radiological analyses of the soil concurred with the analyses conducted by the FNR staff and Eberline Analytical. The excavation was subsequently backfilled. Table 11 below provides results of the NRC confirmation sampling and the data sheets are provided in Appendix K (separate binder).

Table 11, NRC confirmation sampling/analytical through ORISE

| Identified Radionuclide | Measured Concentration (pCi g ⁻¹) ⁶ | Minimum Detectable Concentration (pCi g ⁻¹) | Default Screening Values – Table 3 (pCi/ g ⁻¹) |
|---|--|---|--|
| Sample No. UOM-09-1-01: Soil sample from area of former Storage Port No. 1 | | | |
| Fe-55 | 0.03 | 2.4 | 9,350 |
| Co-60 | 0.03 | 0.03 | 3.68 |
| Eu-152 | 0.02 | 0.03 | 8.66 |
| Sample No. UOM-09-1-02: Soil sample from area of former Storage Port No. 1 | | | |
| Fe-55 | 0.07 | 2.4 | 9,350 |
| Co-60 | 0.01 | 0.03 | 3.68 |
| Eu-152 | 0.06 | 0.04 | 8.66 |
| Sample No. UOM-09-1-03: Concrete support wall sample | | | |
| Fe-55 | 0.07 | 2.3 | 9,350 |
| Co-60 | 0.04 | 0.05 | 3.68 |
| Eu-152 | 0.08 | 0.06 | 8.66 |

⁶ Fe-55 Estimated by activation calculation bases upon measured Cu-152 and Co-60 concentrations



Appendices

- A Pre-Removal Internal Characterization of the Storage Ports
- B Analytical Data for Activated Soil Characterization around Storage Port No. 1
- C Pre-Excavation Soil Analysis around Storage Port No. 1
- D Analysis of Concrete Support Wall around Storage Port No. 1 Eberline Analytical
- E Storage Port Vent Lines Survey Data Sheet
- F Radiological Survey and Swipe Analysis for Storage Port Ends Remaining in FNR Wall
- G Radiological Survey Report of Excavation Zone Former Storage Port No. 1 Location
- H Analytical Data for Final Status Survey of Soil Located Behind the Section of Support Wall Removed
- I Analytical Data for Final Status Survey of Soil Located Behind the Section of Support Wall Removed
- J Analytical Results from Eberline Analytical for Final Status Survey of the Soil under the Former Storage Port No. 1
- K ORISE Confirmation Samples Collected by NRC



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Appendix A Pre-Removal Internal Characterization of the Storage Ports

Ford Nuclear Reactor Decommissioning Project
Storage Port Characterization Surveys

The following surveys were performed using a Ludlum 2221 meter (Serial No. 218602) and a 2" x 2" NaI probe (Ludlum 4410; Serial No. 242815)
Removable activity surveys (disc smears) were also performed at each point whenever practical. Removable activity smears were counted on a L-2929 counter.

Survey Method: The NaI probe was placed onto a circular jig (see attached photos). The jig ensured the probe remained centered within the storage port. The jig was attached to a string. The jig/probe was inserted into the storage port and measurements were taken at one foot (1-ft.) increments.

Survey point #1 represents the first measurement as the probe breaks the plane of the storage point. The August, 2006 measurements have elevated counts at the first port due to high exposure rates from staged radioactive materials on the Beam Port Floor (BPF).

Since exposure rates were elevated by radioactive materials in the areas surrounding the Storage Ports, corresponding graphs do not plot Pt. #1 for the August, 2006 characterization surveys. Although the May, 2007 survey data show less elevated exposure rates for Pt. #1, statistics also exclude Pt. #1 to be consistent with the August, 2006 survey statistics.

Gross Gamma (cpm) vs Depth into Storage Port


| Port | Position (feet into port) | | | | | | | | | | | | | Average. (excluding Pt. #1) | Stand. Dev. (excluding Pt. #1) | Survey Date | Survey Log No. | Removable Activity Detected? |
|------|---------------------------|------|------|------|------|------|------|------|------|-------|-------|-------|-------|-----------------------------------|--------------------------------------|-------------|-------------------|------------------------------------|
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | | | | | |
| 1 | 4649 | 4904 | 4897 | 4886 | 5098 | 5064 | 5130 | 5578 | 8986 | 20081 | 20581 | 14651 | 11696 | 9296 | 6053 | 5/17/2007 | 2007-0997 | Y |
| 2 | 5249 | 4754 | 4847 | 4785 | 4708 | 4761 | 4463 | 4666 | 4977 | 5377 | 5702 | 5549 | 5027 | 4968 | 381 | 5/17/2007 | 2007-0998 | N |
| 3 | 20700 | 6768 | 5732 | 5219 | 5209 | 5004 | 5131 | 5311 | 5953 | 7366 | 8065 | 6968 | 6348 | 6090 | 1010 | 8/21/2006 | 2006-0383 | N |
| 4 | 21232 | 5890 | 5433 | 5251 | 5113 | 5040 | 4985 | 5015 | 5273 | 5386 | 5711 | 5335 | 5172 | 5300 | 277 | 8/21/2006 | 2006-0384 | N |
| 5 | 17429 | 5261 | 5204 | 5126 | 5116 | 5247 | 5292 | 5030 | 5342 | 5147 | 5013 | 5027 | 5042 | 5154 | 114 | 8/30/2006 | 2006-0470 | N |
| 6 | 16368 | 6776 | 5596 | 5248 | 5273 | 4920 | 5057 | 5081 | 5241 | 5471 | 5535 | 5332 | 5124 | 5388 | 481 | 8/29/2006 | 2006-0467 | not surveyed |
| 7 | 21008 | 6206 | 5550 | 5353 | 5169 | 5250 | 5156 | 5081 | 5323 | 5287 | 5359 | 5488 | 5121 | 5362 | 302 | 8/29/2006 | 2006-0468 | not surveyed |
| 8 | 19735 | 5734 | 5510 | 5317 | 5106 | 5017 | 5175 | 5321 | 5267 | 5451 | 5850 | 5350 | 5041 | 5345 | 269 | 8/29/2006 | 2006-0469 | not surveyed |
| 9 | 21066 | 6005 | 5901 | 5728 | 5350 | 5532 | 5517 | 5623 | 5879 | 6255 | 6368 | 6103 | 5512 | 5814 | 324 | 8/30/2006 | 2006-0471 | not surveyed |
| 10 | 6868 | 5706 | 8363 | 5822 | 5272 | 5303 | 5244 | 5688 | 6783 | 10533 | 15106 | 23606 | 71422 | 14071 | 18877 | 5/17/2007 | 2007-0999 | Y |
| 11 | 21228 | 5926 | 5541 | 5553 | 5298 | 5070 | 5234 | 5221 | 5336 | 5866 | 5662 | 5599 | 5206 | 5459 | 274 | 8/30/2006 | 2006-0473 | not surveyed |
| 12 | 20019 | 5935 | 5814 | 5579 | 5722 | 5766 | 5827 | 6013 | 6331 | 6913 | 7324 | 7434 | 7991 | 6387 | 814 | 8/30/2006 | 2006-0472 | not surveyed |
| 13 | 22436 | 7342 | 6583 | 5894 | 6130 | 6616 | 6540 | 6414 | 6017 | 5719 | 5729 | 5825 | 5382 | 6183 | 537 | 8/30/2006 | 2006-0474 | not surveyed |
| 14 | 24569 | 5605 | 5567 | 5311 | 5203 | 5137 | 5557 | 5354 | 5354 | 5369 | 5427 | 5281 | 5002 | 5347 | 180 | 8/30/2006 | 2006-0475 | not surveyed |
| 15 | 16088 | 5469 | 5376 | 5439 | 5384 | 5129 | 5150 | 4984 | 5238 | 5027 | 5064 | 5032 | 5264 | 5213 | 173 | 8/30/2006 | 2006-0476 | not surveyed |
| 16 | 27251 | 5631 | 5241 | 5199 | 5288 | 5328 | 5252 | 5131 | 5202 | 5126 | 5213 | 5108 | 5352 | 5256 | 141 | 8/30/2006 | 2006-0477 | not surveyed |
| 17 | 27156 | 5722 | 5599 | 5461 | 5635 | 5359 | 5597 | 5569 | 6064 | 6361 | 6056 | 5883 | 6507 | 5818 | 361 | 8/30/2006 | 2006-0478 | not surveyed |
| 18 | 27724 | 5711 | 5410 | 5075 | 5125 | 5149 | 5068 | 5014 | 5047 | 5168 | 5156 | 5236 | 5281 | 5203 | 194 | 8/30/2006 | 2006-0479 | not surveyed |
| 19 | 32823 | 5451 | 5040 | 5152 | 5208 | 5039 | 5114 | 5118 | 5198 | 5107 | 5126 | 5110 | 5090 | 5146 | 109 | 8/31/2006 | 2006-0492 | not surveyed |
| 20 | 35160 | 5613 | 5039 | 4942 | 5290 | 5594 | 5732 | 5677 | 5559 | 5670 | 5710 | 5802 | 5795 | 5535 | 288 | 8/31/2006 | 2006-0493 | not surveyed |
| 21 | 33633 | 5609 | 4980 | 5094 | 5078 | 4869 | 5140 | 5089 | 5056 | 5159 | 5207 | 5263 | 5069 | 5134 | 181 | 8/31/2006 | 2006-0494 | not surveyed |
| 22 | 42950 | 5855 | 4988 | 4777 | 4817 | 4866 | 4981 | 5039 | 5047 | 5051 | 5067 | 5125 | 5182 | 5066 | 276 | 8/31/2006 | 2006-0495 | not surveyed |
| 23 | 43985 | 5299 | 4628 | 4557 | 4923 | 4677 | 4794 | 4834 | 4931 | 5041 | 5219 | 5258 | 5202 | 4947 | 258 | 8/31/2006 | 2006-0496 | not surveyed |
| 24 | 42749 | 7809 | 5631 | 5108 | 5058 | 5062 | 4958 | 4979 | 5076 | 5152 | 5112 | 5181 | 5057 | 5349 | 794 | 8/31/2006 | 2006-0497 | not surveyed |
| 25 | 6050 | 5636 | 4482 | 4547 | 4649 | 4395 | 4617 | 4555 | 4689 | 4759 | 4813 | 4923 | 4822 | 4741 | 321 | 5/17/2007 | 2007-1000 | N |
| 26 | 4879 | 4485 | 4486 | 4623 | 4830 | 5097 | 5378 | 5218 | 5730 | 6219 | 5809 | 5395 | 5399 | 5222 | 547 | 5/17/2007 | 2007-1001 | N |
| 27 | 5198 | 4708 | 4758 | 4636 | 4599 | 4539 | 4617 | 4818 | 4881 | 4844 | 4897 | 4960 | 4983 | 4770 | 149 | 5/17/2007 | 2007-1002 | N |

Ford Nuclear Reactor Decommissioning Project
Storage Port Characterization Surveys

Gross Gamma (cpm) vs Depth into Storage Port


| Port | Position (feet into port) | | | | | | | | | | | | | Average (excluding Pt. #1) | Stand. Dev. (excluding Pt. #1) | Survey Date | Survey Log No. | Removable Activity Detected? |
|------|---------------------------|------|------|------|------|------|------|------|------|------|------|------|------|----------------------------------|--------------------------------------|-------------|-------------------|------------------------------------|
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | | | | | |
| 28 | 5634 | 4848 | 4729 | 4488 | 4667 | 4536 | 4668 | 4960 | 4792 | 4768 | 4737 | 4790 | 4717 | 4725 | 128 | 5/17/2007 | 2007-1003 | N |
| 29 | 5702 | 4769 | 4720 | 4909 | 4794 | 4843 | 4998 | 4923 | 5057 | 5099 | 5209 | 5239 | 5466 | 5002 | 222 | 5/17/2007 | 2007-1004 | N |
| 30 | 5235 | 4747 | 4888 | 4738 | 4542 | 4627 | 4758 | 4763 | 4735 | 4902 | 5000 | 4891 | 4819 | 4784 | 126 | 5/17/2007 | 2007-1005 | N |
| 31 | 5383 | 5146 | 5213 | 4957 | 5011 | 5294 | 5526 | 5205 | 5246 | 5516 | 5476 | 5295 | 5240 | 5260 | 180 | 5/17/2007 | 2007-1006 | N |
| 32 | 5100 | 4644 | 4894 | 5101 | 4879 | 5142 | 5072 | 5426 | 5814 | 6372 | 6237 | 5689 | 5298 | 5381 | 545 | 5/17/2007 | 2007-1007 | N |
| 33 | 5524 | 4912 | 4794 | 4850 | 5129 | 5867 | 5327 | 5174 | 5221 | 5037 | 4984 | 4780 | 4654 | 5061 | 324 | 5/17/2007 | 2007-1008 | N |
| 34 | 6153 | 5020 | 4815 | 4905 | 4995 | 5004 | 5179 | 5275 | 5418 | 5500 | 5140 | 5088 | 4760 | 5092 | 226 | 5/17/2007 | 2007-1009 | N |
| 35 | 6332 | 5654 | 6958 | 6524 | 6566 | 7129 | 6802 | 6271 | 6426 | 6068 | 5468 | 5610 | 5141 | 6218 | 633 | 5/17/2007 | 2007-1010 | N |
| 36 | 6538 | 4834 | 4702 | 5125 | 5401 | 5247 | 5654 | 5398 | 5583 | 5773 | 5783 | 5248 | 5091 | 5320 | 348 | 5/17/2007 | 2007-1011 | Y |
| 37 | 6381 | 4722 | 4712 | 4640 | 4808 | 4798 | 5006 | 4981 | 5220 | 5224 | 5321 | 5316 | 5121 | 4989 | 249 | 5/18/2007 | 2007-1025 | N |
| 38 | 7396 | 4902 | 4813 | 4693 | 5036 | 5248 | 5362 | 5425 | 5450 | 5497 | 5443 | 5508 | 5308 | 5224 | 288 | 5/18/2007 | 2007-1024 | N |
| 39 | 6253 | 5825 | 5247 | 5254 | 5135 | 5262 | 5271 | 5291 | 5259 | 5540 | 5413 | 5339 | 4924 | 5313 | 218 | 5/18/2007 | 2007-1023 | N |
| 40 | 7462 | 4784 | 4955 | 4999 | 4969 | 4977 | 5708 | 5549 | 5525 | 5328 | 5186 | 5005 | 4949 | 5161 | 296 | 5/18/2007 | 2007-1022 | N |
| 41 | 8923 | 5190 | 5170 | 5034 | 5439 | 5390 | 5625 | 5525 | 5708 | 5536 | 5525 | 5252 | 5093 | 5374 | 221 | 5/18/2007 | 2007-1021 | N |
| 42 | 8539 | 5476 | 5303 | 5134 | 5092 | 5280 | 5355 | 5326 | 5208 | 5365 | 5365 | 5103 | 4941 | 5246 | 152 | 5/18/2007 | 2007-1020 | N |
| 43 | 7128 | 5153 | 5044 | 4921 | 4934 | 5049 | 5015 | 5038 | 4954 | 4981 | 5344 | 4984 | 4708 | 5010 | 149 | 5/21/2007 | 2007-1037 | Y |
| 44 | 8479 | 5381 | 4910 | 4585 | 4730 | 4725 | 4736 | 4791 | 5023 | 4890 | 4927 | 4917 | 4621 | 4853 | 212 | 5/21/2007 | 2007-1038 | N |
| 45 | 7727 | 5420 | 5466 | 5179 | 5024 | 5031 | 5162 | 5249 | 4938 | 5212 | 5027 | 5012 | 4729 | 5121 | 206 | 5/21/2007 | 2007-1039 | Y |
| 46 | 11016 | 7470 | 6062 | 5392 | 5233 | 5319 | 5390 | 5451 | 4949 | 5092 | 5071 | 4936 | 4716 | 5423 | 729 | 5/21/2007 | 2007-1040 | Y |
| 47 | 8747 | 4933 | 4404 | 4731 | 4707 | 4824 | 4947 | 5091 | 4973 | 5031 | 4965 | 5102 | 4764 | 4873 | 199 | 5/21/2007 | 2007-1041 | Y |
| 48 | 7889 | 5782 | 5474 | 5893 | 6407 | 5874 | 5759 | 5942 | 6312 | 6553 | 6945 | 9954 | 7384 | 6523 | 1211 | 5/21/2007 | 2007-1042 | Y |
| 49 | 11190 | 5707 | 5309 | 5186 | 5274 | 5072 | 5199 | 5479 | 6491 | 6490 | 6109 | 7789 | 5993 | 5842 | 793 | 5/21/2007 | 2007-1043 | Y |
| 50 | 7208 | 5017 | 4607 | 4605 | 4616 | 4550 | 4742 | 4786 | 4883 | 4985 | 5000 | 5034 | 4848 | 4806 | 181 | 5/21/2007 | 2007-1044 | Y |

FNR Storage Port #1: Nal Gross Gamma vs Depth




Surveyed: 5-17-2007

FNR Storage Port #2: NaI Gross Gamma vs Depth




Surveyed: 5-17-2007


FNR Storage Port #3: NaI Gross Gamma vs Depth




FNR Storage Port #4: NaI Gross Gamma vs Depth




FNR Storage Port #5: NaI Gross Gamma vs Depth




FNR Storage Port #6: NaI Gross Gamma vs Depth




FNR Storage Port #7: NaI Gross Gamma vs Depth




FNR Storage Port #8: NaI Gross Gamma vs Depth



FNR Storage Port #9: NaI Gross Gamma vs Depth




FNR Storage Port #10: NaI Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #11: NaI Gross Gamma vs Depth




FNR Storage Port #12: NaI Gross Gamma vs Depth




Surveyed: 08-30-2006

FNR Storage Port #13: NaI Gross Gamma vs Depth




Surveyed: 08-30-2006

FNR Storage Port #14: NaI Gross Gamma vs Depth




Surveyed: 08-30-2006


FNR Storage Port #15: NaI Gross Gamma vs Depth




FNR Storage Port #16: NaI Gross Gamma vs Depth



FNR Storage Port #17: NaI Gross Gamma vs Depth




FNR Storage Port #18: NaI Gross Gamma vs Depth




Surveyed: 08-30-2006


FNR Storage Port #19: NaI Gross Gamma vs Depth




FNR Storage Port #20: Nal Gross Gamma vs Depth




FNR Storage Port #21: NaI Gross Gamma vs Depth




FNR Storage Port #22: NaI Gross Gamma vs Depth



FNR Storage Port #23: NaI Gross Gamma vs Depth




FNR Storage Port #24: NaI Gross Gamma vs Depth




Surveyed: 08-31-2006

FNR Storage Port #25: NaI Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #26: NaI Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #27: NaI Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #28: Nal Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #29: NaI Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #30: NaI Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #31: NaI Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #32: NaI Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #33: NaI Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #34: NaI Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #35: NaI Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #36: NaI Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #37: Nal Gross Gamma vs Depth




Surveyed: 05-18-2007

FNR Storage Port #38: NaI Gross Gamma vs Depth




Surveyed: 05-17-2007

FNR Storage Port #39: NaI Gross Gamma vs Depth




Surveyed: 05-18-2007

FNR Storage Port #40: NaI Gross Gamma vs Depth




Surveyed: 05-18-2007

FNR Storage Port #41: NaI Gross Gamma vs Depth




Surveyed: 05-18-2007

FNR Storage Port #42: NaI Gross Gamma vs Depth




Surveyed: 05-18-2007

FNR Storage Port #43: Nal Gross Gamma vs Depth




Surveyed: 05-21-2007

FNR Storage Port #44: NaI Gross Gamma vs Depth




Surveyed: 05-21-2007

FNR Storage Port #45: NaI Gross Gamma vs Depth




Surveyed: 05-21-2007

FNR Storage Port #46: NaI Gross Gamma vs Depth




Surveyed: 05-21-2007

FNR Storage Port #47: Nal Gross Gamma vs Depth




Surveyed: 05-21-2007

FNR Storage Port #48: NaI Gross Gamma vs Depth




Surveyed: 05-21-2007

FNR Storage Port #49: NaI Gross Gamma vs Depth



Surveyed: 05-21-2007

FNR Storage Port #50: NaI Gross Gamma vs Depth



Surveyed: 05-21-2007



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Appendix B

Analytical Data for Activated Soil Characterization around Storage Port No. 1

***** G A M M A § E C T R U M A N A L Y I S *****

Filename: C:\Soil\2008-11-06-01\2008-11-06-01N_100000_2008Nov10.CNF

Report Generated On : 12/17/2008 6:07:55 PM

Sample Title : Soil Background - Storage Port Fill
Sample Description : 500 ml nalgene
Sample Identification : UM-2008-11-06-01
Sample Type : soil
Sample Geometry : 500 ml Nalgene

Peak Locate Threshold : 3.00
Peak Locate Range (in channels) : 1 - 8192
Peak Area Range (in channels) : 5 - 8192
Identification Energy Tolerance : 1.000 keV

Sample Size : 1.000E+003 g

Sample Taken On : 9/1/2008 11:45:00 PM
Acquisition Started : 11/10/2008 9:07:01 AM

Live Time : 100000.0 seconds
Real Time : 100100.3 seconds

Dead Time : 0.10 %

Energy Calibration Used Done On : 12/17/2008

 *** N U C L I D E M D A R E P O R T ***

Detector Name: HPGE
 Sample Geometry: 500 ml Nalgene
 Sample Title: Soil Background - Storage Port Fill
 Nuclide Library Used: C:\GENIE2K\CAMFILES\Libraries\Soil_DCGL_

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | |
|--------|--------------|--------------|-------------|-------------------|----------------------|-------------------|--------------|
| + | Pb x-ray | 72.80 | 61.00 | 1.7312E-008 | 1.73E-008 | -6.8954E-009 | |
| | | 75.00* | 100.00 | 1.8854E-008 | | 4.9930E-008 | |
| | | 84.90* | 36.00 | 2.1462E-008 | | 1.8456E-008 | |
| | | 87.60* | 10.00 | 9.0358E-008 | | 2.1696E-007 | |
| | BE-7 | 477.59 | 10.42 | 2.8147E-007 | 2.81E-007 | 2.8645E-008 | |
| + | K-40 | 1460.75* | 10.67 | 2.0949E-007 | 2.09E-007 | 8.9679E-006 | |
| | | MN-54 | 834.83 | 99.98 | 1.7669E-008 | 1.77E-008 | -4.3999E-009 |
| | | CO-60 | 1173.24 | 99.90 | 2.0256E-008 | 1.76E-008 | 8.3258E-009 |
| | | | 1332.50 | 99.98 | 1.7643E-008 | | 1.5454E-008 |
| | | ZN-65 | 511.00 | 2.83 | 7.5535E-007 | 5.71E-008 | -7.9533E-008 |
| | | | 1115.55 | 50.70 | 5.7140E-008 | | -4.0718E-009 |
| | | NB-94x | 702.62 | 97.90 | 1.4098E-008 | 1.41E-008 | 3.1511E-009 |
| | | | 871.09 | 99.90 | 1.4750E-008 | | 5.3043E-009 |
| | | AG-108m | 79.13 | 6.60 | 1.6780E-007 | 1.30E-008 | 1.6613E-008 |
| | | | 433.94 | 90.50 | 1.3046E-008 | | 8.7054E-009 |
| | | | 614.28 | 89.80 | 2.5348E-008 | | 2.2054E-010 |
| | | | 722.94 | 90.80 | 1.6153E-008 | | 4.0493E-009 |
| + | CD-109 | 88.03* | 3.61 | 2.7407E-007 | 2.74E-007 | 6.5808E-007 | |
| | | AG-110m | 446.81 | 3.75 | 3.6686E-007 | 1.64E-008 | 1.5427E-007 |
| | | | 620.36 | 2.81 | 5.4534E-007 | | -1.1882E-007 |
| | | | 657.76 | 94.60 | 1.6445E-008 | | 6.0295E-010 |
| | | | 677.62 | 10.35 | 1.4631E-007 | | -6.8294E-008 |
| | | | 687.02 | 6.44 | 2.4955E-007 | | 4.0062E-008 |
| | | | 706.68 | 16.44 | 1.0337E-007 | | 8.7489E-008 |
| | | | 744.28 | 4.73 | 3.6893E-007 | | 1.4310E-007 |
| | | | 763.94 | 22.29 | 8.8737E-008 | | 1.8806E-008 |
| | | | 818.03 | 7.34 | 2.3929E-007 | | 6.7159E-009 |
| | | | 884.68 | 72.70 | 2.4825E-008 | | -2.5776E-010 |
| | | | 937.49 | 34.36 | 5.7360E-008 | | -8.6489E-009 |
| | | | 1384.30 | 24.28 | 8.1767E-008 | | 4.3171E-008 |
| | | | 1475.79 | 3.99 | 3.6941E-007 | | 1.1523E-007 |
| | | | 1505.04 | 13.04 | 1.3429E-007 | | -8.3139E-008 |
| | | | 1562.30 | 1.03 | 1.4606E-006 | | 4.8391E-007 |
| SB-125 | 176.33 | 6.79 | 1.5043E-007 | 4.02E-008 | -7.9700E-008 | | |
| | 380.43 | 1.52 | 7.5359E-007 | | 3.8838E-008 | | |
| | 427.89 | 29.40 | 4.0236E-008 | | -1.7034E-008 | | |
| | 463.38 | 10.45 | 1.2215E-007 | | 1.6248E-007 | | |
| | 600.56 | 17.78 | 7.5604E-008 | | 6.5278E-008 | | |
| | 606.64 | 5.02 | 5.0997E-007 | | -5.8991E-008 | | |
| | 635.90 | 11.32 | 1.1386E-007 | | 2.8665E-010 | | |
| | 671.41 | 1.80 | 7.5226E-007 | | -1.3293E-007 | | |
| BA-133 | 53.16 | 2.20 | 3.7734E-007 | 2.73E-008 | 1.7622E-007 | | |

| Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|--------------|--------------|-------------|-------------------|----------------------|-------------------|-------------|--------------|
| BA-133 | 79.62 | 2.62 | 4.2479E-007 | 2.73E-008 | -1.9400E-009 | | |
| | 81.00 | 34.10 | 2.7340E-008 | | -1.1400E-008 | | |
| | 160.61 | 0.64 | 1.4401E-006 | | 7.0942E-007 | | |
| | 223.23 | 0.45 | 2.2985E-006 | | 7.5210E-007 | | |
| | 276.40 | 7.16 | 1.4778E-007 | | 3.9165E-008 | | |
| | 302.85 | 18.33 | 5.7083E-008 | | 3.8433E-010 | | |
| | 356.02 | 62.05 | 2.8064E-008 | | -2.7673E-008 | | |
| | 383.85 | 8.94 | 1.2801E-007 | | 6.5646E-008 | | |
| CS-134 | 475.35 | 1.46 | 8.5311E-007 | 1.90E-008 | -2.8470E-007 | | |
| | 563.23 | 8.38 | 1.5525E-007 | | -7.4280E-011 | | |
| | 569.32 | 15.43 | 8.5974E-008 | | 8.6071E-009 | | |
| | 604.70 | 97.60 | 2.0763E-008 | | -3.0739E-009 | | |
| | 795.84 | 85.40 | 1.9032E-008 | | 2.3069E-008 | | |
| | 801.93 | 8.73 | 1.7546E-007 | | -7.2547E-008 | | |
| | 1038.57 | 1.00 | 1.8112E-006 | | -4.1042E-007 | | |
| | 1167.94 | 1.80 | 1.1535E-006 | | 1.0394E-006 | | |
| | 1365.15 | 3.04 | 4.9918E-007 | | 3.8692E-007 | | |
| | CS-137 | 661.66 | 85.21 | | 1.6079E-008 | 1.61E-008 | 7.4697E-009 |
| EU-152x | | 121.78 | 28.40 | 2.8786E-008 | 2.88E-008 | 1.0174E-009 | |
| | 244.70 | 7.49 | 1.5999E-007 | 2.0757E-009 | | | |
| | 344.28 | 26.60 | 4.1085E-008 | -6.0935E-009 | | | |
| | 411.11 | 2.23 | 5.2242E-007 | -1.2062E-007 | | | |
| | 443.98 | 2.78 | 4.1100E-007 | -1.3841E-007 | | | |
| | 778.90 | 12.96 | 1.1246E-007 | -8.9233E-009 | | | |
| | 867.39 | 4.15 | 3.6246E-007 | 5.2208E-008 | | | |
| | 964.13 | 14.34 | 1.3505E-007 | -3.9789E-008 | | | |
| | 1085.91 | 9.92 | 1.7523E-007 | -9.4027E-009 | | | |
| | 1089.70 | 1.71 | 1.0295E-006 | 3.0797E-007 | | | |
| | 1112.12 | 13.55 | 1.3612E-007 | 1.8966E-008 | | | |
| | 1212.95 | 1.40 | 1.5750E-006 | -7.2865E-007 | | | |
| | 1299.12 | 1.63 | 1.0407E-006 | 1.3197E-007 | | | |
| | 1408.01 | 20.87 | 7.8480E-008 | 1.0402E-007 | | | |
| | EU-154 | 123.07 | 40.40 | 2.0536E-008 | | 2.05E-008 | 1.1116E-009 |
| | | 188.25 | 0.23 | 4.9960E-006 | | | -9.2005E-007 |
| 247.93 | | 6.83 | 1.4678E-007 | -9.6790E-009 | | | |
| 401.30 | | 0.19 | 6.0017E-006 | -9.1079E-007 | | | |
| 444.39 | | 0.55 | 2.0762E-006 | -1.0161E-006 | | | |
| 478.26 | | 0.21 | 5.7388E-006 | 9.3377E-007 | | | |
| 557.56 | | 0.25 | 4.7266E-006 | -2.3068E-006 | | | |
| 582.00 | | 0.89 | 1.9537E-006 | 1.0025E-005 | | | |
| 591.76 | | 4.91 | 2.4453E-007 | -2.3015E-007 | | | |
| 625.22 | | 0.32 | 3.9055E-006 | -1.6843E-006 | | | |
| 676.59 | | 0.14 | 9.2642E-006 | -4.9429E-006 | | | |
| 692.42 | | 1.78 | 7.6497E-007 | -5.9129E-008 | | | |
| 715.76 | | 0.17 | 7.7322E-006 | -5.2589E-006 | | | |
| 722.30 | | 20.00 | 7.0082E-008 | -2.3892E-008 | | | |
| 756.86 | | 4.50 | 3.2676E-007 | -7.5369E-009 | | | |
| 815.55 | | 0.50 | 2.8984E-006 | -1.7062E-006 | | | |
| 845.39 | | 0.58 | 2.5718E-006 | -1.4378E-006 | | | |
| 850.64 | 0.23 | 6.3928E-006 | -2.7820E-006 | | | | |
| 873.20 | 12.09 | 1.2349E-007 | 2.7098E-008 | | | | |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|---|--------------|--------------|-----------|-------------------|----------------------|-------------------|-----------|--------------|
| | EU-154 | 892.73 | 0.50 | 3.0741E-006 | 2.05E-008 | -1.2778E-007 | | |
| | | 904.05 | 0.85 | 1.8100E-006 | | 1.5800E-007 | | |
| | | 996.30 | 10.34 | 1.5704E-007 | | -1.1905E-008 | | |
| | | 1004.76 | 17.90 | 9.7292E-008 | | 1.2028E-007 | | |
| | | 1128.40 | 0.29 | 6.3588E-006 | | -3.5137E-006 | | |
| | | 1140.90 | 0.22 | 8.5255E-006 | | -6.8257E-007 | | |
| | | 1241.60 | 0.13 | 1.9085E-005 | | -9.0839E-006 | | |
| | | 1246.60 | 0.80 | 2.5117E-006 | | -3.5308E-006 | | |
| | | 1274.51 | 34.40 | 5.2824E-008 | | -6.9981E-008 | | |
| | | 1494.08 | 0.71 | 1.8543E-006 | | -7.9253E-007 | | |
| | | 1596.45 | 1.80 | 7.7621E-007 | | -7.5055E-008 | | |
| + | | TL-208B | 72.80 | 2.02 | | 5.2279E-007 | 1.79E-008 | -2.0823E-007 |
| | | | 74.97* | 3.41 | | 5.5290E-007 | | 1.4642E-006 |
| | | | 84.90* | 1.51 | | 5.1168E-007 | | 4.4002E-007 |
| | 277.36* | | 6.31 | 1.2898E-007 | 7.9916E-008 | | | |
| | 510.77* | | 22.60 | 1.1666E-007 | 1.3365E-007 | | | |
| | 583.19* | | 84.50 | 1.8279E-008 | 7.9848E-008 | | | |
| | 763.13 | | 1.81 | 8.7109E-007 | -5.9783E-008 | | | |
| | 860.56* | | 12.42 | 1.5089E-007 | 1.1443E-007 | | | |
| | 2614.53* | | 99.16 | 1.7922E-008 | 9.1687E-008 | | | |
| + | Pb-210 | | 46.52* | 4.05 | 2.3910E-007 | 2.39E-007 | | 3.8653E-007 |
| + | PB-212B | | 74.81* | 10.50 | 1.7956E-007 | 4.76E-008 | | 4.7552E-007 |
| | | | 77.11* | 17.60 | 1.0722E-007 | | | 4.5689E-007 |
| | | | 87.30* | 7.90 | 1.1438E-007 | | | 2.7463E-007 |
| | | | 238.63* | 43.60 | 4.7555E-008 | | | 2.6027E-007 |
| | | 300.09* | 3.34 | 3.1207E-007 | 1.3451E-007 | | | |
| + | BI-214B | 609.31* | 44.80 | 4.8603E-008 | 4.86E-008 | 3.8037E-007 | | |
| | | 665.45* | 1.29 | 9.2101E-007 | | 6.6909E-007 | | |
| | | 768.36* | 4.80 | 4.0987E-007 | | 4.5556E-007 | | |
| | | 806.17* | 1.12 | 1.5595E-006 | | 8.4699E-007 | | |
| | | 934.06* | 3.03 | 7.4092E-007 | | 1.6421E-007 | | |
| | | 1120.29* | 14.80 | 1.9382E-007 | | 4.3643E-007 | | |
| | | 1155.19 | 1.64 | 1.2132E-006 | | 1.3175E-006 | | |
| | | 1238.11* | 5.86 | 4.2833E-007 | | 5.5968E-007 | | |
| | | 1280.96 | 1.44 | 1.3007E-006 | | 1.7046E-006 | | |
| | | 1377.67* | 3.92 | 4.2373E-007 | | 3.7318E-007 | | |
| | | 1401.50* | 1.55 | 9.1760E-007 | | 4.8399E-007 | | |
| | | 1407.98* | 2.80 | 5.3286E-007 | | 3.7594E-007 | | |
| | | 1509.23* | 2.12 | 7.7084E-007 | | 5.5296E-007 | | |
| | | 1661.28 | 1.14 | 1.0383E-006 | | -3.6302E-007 | | |
| | | 1729.59* | 2.88 | 6.1080E-007 | | 3.8151E-007 | | |
| | | 1764.49* | 15.36 | 1.4213E-007 | | 3.7158E-007 | | |
| | | 1847.42* | 2.04 | 9.1315E-007 | | 8.0059E-007 | | |
| | | 2118.55 | 1.14 | 1.1561E-006 | | -2.1082E-007 | | |
| | | 2204.21* | 4.86 | 2.8591E-007 | | 7.3993E-007 | | |
| | | 2447.86* | 1.50 | 1.2947E-006 | | 4.2322E-007 | | |
| + | PB-214B | 53.23* | 1.11 | 7.0559E-007 | 4.57E-008 | 3.5720E-007 | | |
| | | 74.81* | 5.90 | 3.1956E-007 | | 8.4626E-007 | | |
| | | 77.11* | 9.90 | 1.9061E-007 | | 8.1226E-007 | | |
| | | 87.30* | 4.41 | 2.0489E-007 | | 4.9197E-007 | | |
| | | 241.98* | 7.50 | 2.8262E-007 | | 4.6078E-007 | | |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | | |
|--------|--------------|--------------|--------------|-------------------|----------------------|-------------------|-------------|-----------|--------------|
| + | PB-214B | 295.21* | 18.50 | 7.9660E-008 | 4.57E-008 | 4.0375E-007 | | | |
| | | 351.92* | 35.80 | 4.5726E-008 | | 3.9887E-007 | | | |
| + | RA-226 | 186.10* | 3.50 | 3.6333E-007 | 3.63E-007 | 6.8903E-007 | | | |
| + | AC-228B | 12.95 | 15.10 | 1.6557E-006 | 7.09E-008 | -1.1996E-005 | | | |
| | | 16.15 | 20.00 | 4.4331E-007 | | -2.6600E-006 | | | |
| | | 19.11 | 4.60 | 9.2538E-007 | | -1.5923E-006 | | | |
| | | 89.96* | 3.40 | 3.9161E-007 | | 3.8590E-007 | | | |
| | | 93.35* | 5.60 | 2.5957E-007 | | 4.6363E-007 | | | |
| | | 99.55* | 1.30 | 5.4002E-007 | | 4.6691E-007 | | | |
| | | 105.36 | 2.00 | 4.0651E-007 | | 4.7495E-008 | | | |
| | | 129.03* | 2.90 | 2.6337E-007 | | 1.4655E-007 | | | |
| | | 209.39* | 4.10 | 2.1806E-007 | | 2.7152E-007 | | | |
| | | 270.26* | 3.80 | 3.4606E-007 | | 2.4428E-007 | | | |
| | | 328.07* | 3.50 | 2.7746E-007 | | 2.2795E-007 | | | |
| | | 338.42* | 12.40 | 8.4379E-008 | | 2.9111E-007 | | | |
| | | 409.62* | 2.20 | 6.2330E-007 | | 2.0545E-007 | | | |
| | | 463.10* | 4.60 | 2.6564E-007 | | 3.5236E-007 | | | |
| | | 562.65 | 1.01 | 1.2141E-006 | | -2.1701E-007 | | | |
| | | 755.28 | 1.32 | 1.1028E-006 | | 9.0669E-008 | | | |
| | | 772.28 | 1.09 | 1.5442E-006 | | 6.3911E-008 | | | |
| | | 794.79* | 4.60 | 2.8188E-007 | | 2.2660E-007 | | | |
| | | 835.60 | 1.71 | 8.9855E-007 | | -1.2797E-007 | | | |
| | | 911.16* | 29.00 | 7.0879E-008 | | 2.2971E-007 | | | |
| | | 964.64* | 5.80 | 2.4653E-007 | | 1.9612E-007 | | | |
| | | 968.97* | 17.40 | 8.4908E-008 | | 2.6778E-007 | | | |
| | | 1459.19 | 1.06 | 5.6817E-006 | | 9.3381E-005 | | | |
| | | 1496.00 | 1.05 | 1.2553E-006 | | 4.6106E-007 | | | |
| | | 1588.23 | 3.60 | 4.3444E-007 | | -7.8049E-008 | | | |
| | | 1630.47 | 1.95 | 6.5277E-007 | | 4.6825E-007 | | | |
| | | PA-234B | | 63.00 | | 3.20 | 2.8589E-007 | 3.50E-008 | -8.4035E-008 |
| | | | | 94.67 | | 14.30 | 6.6056E-008 | | -1.1601E-008 |
| | | | | 98.44 | | 23.00 | 3.4991E-008 | | 3.4064E-009 |
| | | | | 99.70 | | 4.80 | 1.6839E-007 | | 3.4916E-008 |
| 111.00 | 10.80 | | | 7.6730E-008 | 3.6766E-008 | | | | |
| 125.40 | 1.00 | | | 8.4102E-007 | -4.4674E-007 | | | | |
| 131.20 | 20.00 | | | 4.3648E-008 | 5.8143E-009 | | | | |
| 152.70 | 6.70 | | | 1.3965E-007 | -3.4542E-008 | | | | |
| 186.00 | 2.00 | | | 5.8159E-007 | 2.3512E-006 | | | | |
| 200.90 | 1.00 | | | 1.0212E-006 | 1.5893E-007 | | | | |
| 202.90 | 1.20 | | | 8.5387E-007 | 8.1785E-008 | | | | |
| 226.40 | 5.90 | | | 1.7491E-007 | -1.0841E-007 | | | | |
| 227.20 | 5.50 | | | 1.8848E-007 | -8.1392E-008 | | | | |
| 248.90 | 2.80 | | | 3.5761E-007 | -6.9412E-008 | | | | |
| 272.10 | 1.00 | | | 1.1039E-006 | -3.5589E-007 | | | | |
| 293.70 | 3.90 | | | 3.6928E-007 | -1.2072E-007 | | | | |
| 369.80 | 2.90 | | | 3.8494E-007 | 1.9626E-007 | | | | |
| 372.40 | 1.30 | | | 8.4695E-007 | -1.2731E-007 | | | | |
| 458.80 | 1.50 | 7.9411E-007 | -2.9967E-008 | | | | | | |
| 506.80 | 1.60 | 1.0030E-006 | -2.6117E-007 | | | | | | |
| 513.70 | 1.30 | 1.3535E-006 | 5.0962E-008 | | | | | | |
| 565.90 | 1.40 | 9.0435E-007 | 5.7709E-007 | | | | | | |

| Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|--------------|--------------|-----------|-------------------|----------------------|-------------------|
| PA-234B | 568.70 | 3.30 | 3.8179E-007 | 3.50E-008 | -2.5676E-008 |
| | 569.50 | 10.00 | 1.2613E-007 | | 1.2628E-008 |
| | 574.00 | 2.00 | 6.2872E-007 | | -2.1914E-007 |
| | 664.80 | 1.30 | 1.0724E-006 | | 1.3361E-006 |
| | 666.70 | 1.60 | 8.6195E-007 | | 3.0313E-007 |
| | 669.90 | 1.40 | 9.4827E-007 | | -1.6473E-007 |
| | 692.70 | 1.50 | 9.0478E-007 | | -4.1787E-008 |
| | 699.00 | 4.60 | 2.9748E-007 | | -2.1391E-007 |
| | 706.10 | 3.10 | 4.5650E-007 | | 5.3844E-007 |
| | 733.00 | 9.00 | 1.6937E-007 | | 2.1644E-009 |
| | 738.00 | 1.00 | 1.4768E-006 | | -2.6685E-007 |
| | 742.81 | 2.40 | 6.0690E-007 | | 9.7801E-008 |
| | 755.60 | 1.40 | 1.0416E-006 | | -6.7296E-009 |
| | 780.70 | 1.10 | 1.3520E-006 | | -4.6143E-008 |
| | 786.27 | 1.40 | 1.0551E-006 | | -8.3617E-007 |
| | 793.60 | 1.50 | 1.0392E-006 | | 1.5215E-006 |
| | 796.30 | 3.80 | 4.0829E-007 | | 6.5897E-007 |
| | 805.80 | 3.30 | 4.4124E-007 | | 2.9526E-007 |
| | 819.60 | 2.60 | 5.6820E-007 | | 4.5623E-008 |
| | 826.30 | 4.00 | 3.8135E-007 | | 3.2153E-007 |
| | 831.60 | 5.50 | 2.7817E-007 | | 1.3670E-007 |
| | 876.40 | 4.00 | 3.6869E-007 | | -4.3722E-008 |
| | 880.50 | 4.00 | 3.6424E-007 | | -3.0321E-007 |
| | 880.51 | 9.00 | 1.6188E-007 | | -1.3476E-007 |
| | 883.24 | 15.00 | 9.9918E-008 | | 3.3205E-008 |
| | 899.00 | 4.10 | 3.7150E-007 | | -5.0801E-009 |
| | 925.00 | 2.90 | 5.2849E-007 | | 7.4763E-008 |
| | 926.00 | 11.00 | 1.3835E-007 | | -3.0267E-008 |
| | 927.10 | 11.00 | 1.3780E-007 | | -9.0792E-008 |
| | 946.00 | 12.00 | 1.3229E-007 | | 7.5176E-008 |
| | 949.00 | 8.00 | 1.9753E-007 | | 1.6926E-007 |
| | 978.80 | 1.40 | 1.0857E-006 | | -1.3248E-007 |
| | 980.50 | 2.00 | 7.6961E-007 | | 2.4922E-007 |
| | 980.50 | 3.00 | 5.1307E-007 | | 1.6615E-007 |
| | 984.00 | 1.90 | 8.2918E-007 | | 6.9079E-008 |
| | 1353.30 | 1.70 | 8.8483E-007 | | -2.4300E-007 |
| | 1394.10 | 3.00 | 4.5838E-007 | | 2.5716E-008 |
| | 1452.70 | 1.00 | 1.8093E-006 | | -2.5344E-007 |
| | 1668.50 | 1.20 | 9.4669E-007 | | -7.4170E-007 |
| | 1694.60 | 1.20 | 1.0156E-006 | | -4.8341E-007 |
| | + TH-234 | 63.29* | 4.50 | | 1.7585E-006 |
| | 92.38 | 2.60 | 2.8420E-006 | 1.5332E-005 | |
| | 92.80* | 2.60 | 4.1278E-006 | 7.3727E-006 | |
| + U-235 | 72.70 | 0.11 | 9.4758E-006 | 2.21E-008 | -3.7742E-006 |
| | 89.95* | 2.80 | 4.6931E-007 | | 4.6246E-007 |
| | 93.35* | 4.50 | 3.1880E-007 | | 5.6941E-007 |
| | 94.00 | 0.40 | 2.3388E-006 | | -3.4545E-007 |
| | 105.00 | 2.10 | 3.8144E-007 | | 7.7268E-008 |
| | 109.16 | 1.50 | 5.3782E-007 | | -3.4139E-007 |
| | 140.76 | 0.22 | 4.1492E-006 | | -7.6042E-007 |
| | 143.76* | 10.90 | 8.9113E-008 | | 3.5441E-008 |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-----------|-------------------|----------------------|-------------------|
| + | U-235 | 163.33 | 5.00 | 1.8444E-007 | 2.21E-008 | 6.4852E-009 |
| | | 182.61 | 0.40 | 2.6956E-006 | | -4.0257E-006 |
| | | 185.71* | 57.50 | 2.2114E-008 | | 4.1937E-008 |
| | | 194.94 | 0.59 | 1.6992E-006 | | 3.3220E-008 |
| | | 202.11 | 1.00 | 1.0055E-006 | | -5.1415E-007 |
| | | 205.31 | 5.00 | 2.0423E-007 | | -1.1028E-008 |
| | | 279.50 | 0.27 | 3.7867E-006 | | 3.2493E-006 |

+ = Nuclide identified during the nuclide identification

* = Energy line found in the spectrum

> = MDA value not calculated

@ = Half-life too short to be able to perform the decay correction



**Ford Nuclear Reactor
Storage Ports - Final Disposition**

Revision: 00

Appendix C

Pre-Excavation Soil Analysis around Storage Port No. 1

***** G A M M A S E C T R U M A N A L Y I S *****

Filename: C:\Soil\2008-12-18-01\2008-12-18-01N_100000_2009Jan2.CNF

Report Generated On : 1/5/2009 3:47:54 PM

Sample Title : Soil Immediately in vicinity of Storage
Sample Description : 500 ml Nalgene
Sample Identification : 2008-12-18-01N
Sample Type : Soil 2.0 g/cc
Sample Geometry : 500 ml Nalgene

Peak Locate Threshold : 3.00
Peak Locate Range (in channels) : 8 - 8192
Peak Area Range (in channels) : 8 - 8192
Identification Energy Tolerance : 1.000 keV

Sample Size : 1.000E+003 g

Sample Taken On : 12/18/2008 11:55:00 AM
Acquisition Started : 1/2/2009 10:37:40 PM

Live Time : 100000.0 seconds
Real Time : 100007.8 seconds

Dead Time : 0.01 %

Energy Calibration Used Done On : 12/18/2008
Efficiency Calibration Used Done On : 12/17/2008
Efficiency ID :

 *** N U C L I D E M D A R E P O R T ***

Detector Name: HPGE
 Sample Geometry: 500 ml Nalgene
 Sample Title: Soil Immediately in vicinity of Storage
 Nuclide Library Used: C:\GENIE2K\CAMFILES\Libraries\Soil_DCGL_

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-----------|-------------------|----------------------|-------------------|
| + | Pb x-ray | 72.80 | 61.00 | 2.2790E-008 | 1.99E-008 | -7.3552E-009 |
| | | 75.00* | 100.00 | 1.9939E-008 | | 6.2027E-008 |
| | | 84.90* | 36.00 | 9.9714E-008 | | 7.8783E-008 |
| | | 87.60* | 10.00 | 3.5953E-007 | | 4.7002E-007 |
| | BE-7 | 477.59 | 10.42 | 1.9989E-007 | 2.00E-007 | 9.2997E-008 |
| + | K-40 | 1460.75* | 10.67 | 2.1220E-007 | 2.12E-007 | 1.1019E-005 |
| + | MN-54 | 834.83* | 99.98 | 2.2026E-008 | 2.20E-008 | 1.5932E-008 |
| + | CO-60 | 1173.24* | 99.90 | 4.0304E-008 | 2.61E-008 | 4.6182E-007 |
| | | 1332.50* | 99.98 | 2.6145E-008 | | 4.4833E-007 |
| | ZN-65 | 511.00 | 2.83 | 8.2718E-007 | 8.26E-008 | 4.6003E-006 |
| | | 1115.55 | 50.70 | 8.2641E-008 | | 6.7304E-007 |
| | NB-94x | 702.62 | 97.90 | 2.0800E-008 | 2.08E-008 | 1.3779E-008 |
| | | 871.09 | 99.90 | 2.8204E-008 | | 1.4854E-008 |
| | AG-108m | 79.13 | 6.60 | 2.1680E-007 | 1.77E-008 | -3.3509E-007 |
| | | 433.94 | 90.50 | 1.7691E-008 | | -1.0709E-008 |
| | | 614.28 | 89.80 | 2.8847E-008 | | -2.9331E-008 |
| | | 722.94 | 90.80 | 2.5222E-008 | | 1.1850E-008 |
| + | CD-109 | 88.03* | 3.61 | 1.0163E-006 | 1.02E-006 | 1.3286E-006 |
| | AG-110m | 446.81 | 3.75 | 5.1169E-007 | 2.15E-008 | -1.0785E-007 |
| | | 620.36 | 2.81 | 7.0796E-007 | | -3.5764E-007 |
| | | 657.76 | 94.60 | 2.1492E-008 | | -2.0575E-008 |
| | | 677.62 | 10.35 | 2.0031E-007 | | 1.2930E-007 |
| | | 687.02 | 6.44 | 3.3201E-007 | | 1.1237E-007 |
| | | 706.68 | 16.44 | 1.2912E-007 | | -3.6883E-008 |
| | | 744.28 | 4.73 | 4.8487E-007 | | 1.3469E-007 |
| | | 763.94 | 22.29 | 1.1253E-007 | | -6.3800E-008 |
| | | 818.03 | 7.34 | 3.2259E-007 | | -2.2853E-008 |
| | | 884.68 | 72.70 | 3.4213E-008 | | 7.6985E-009 |
| | | 937.49 | 34.36 | 7.4316E-008 | | -7.5817E-009 |
| | | 1384.30 | 24.28 | 7.4132E-008 | | -4.2231E-008 |
| | | 1475.79 | 3.99 | 3.4329E-007 | | -1.9457E-007 |
| | | 1505.04 | 13.04 | 1.1881E-007 | | -1.5693E-008 |
| | | 1562.30 | 1.03 | 1.2901E-006 | | -6.2532E-007 |
| | SB-125 | 176.33 | 6.79 | 2.1164E-007 | 5.53E-008 | -3.4249E-008 |
| | | 380.43 | 1.52 | 1.0219E-006 | | -7.0704E-007 |
| | | 427.89 | 29.40 | 5.5274E-008 | | -1.8866E-008 |
| | | 463.38 | 10.45 | 1.6231E-007 | | 5.8298E-008 |
| | | 600.56 | 17.78 | 1.1099E-007 | | 4.1788E-010 |
| | | 606.64 | 5.02 | 5.7244E-007 | | -2.3331E-008 |
| | | 635.90 | 11.32 | 1.6916E-007 | | 3.2118E-008 |
| | | 671.41 | 1.80 | 1.1021E-006 | | -1.0918E-006 |
| | BA-133 | 53.16 | 2.20 | 4.9756E-007 | 3.19E-008 | 1.0735E-007 |

| Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|--------------|--------------|-----------|-------------------|----------------------|-------------------|-------------|--------------|
| BA-133 | 79.62 | 2.62 | 5.4466E-007 | 3.19E-008 | -8.4640E-007 | | |
| | 81.00 | 34.10 | 3.8162E-008 | | -1.6450E-007 | | |
| | 160.61 | 0.64 | 2.1384E-006 | | 2.8297E-006 | | |
| | 223.23 | 0.45 | 3.3399E-006 | | 1.1284E-006 | | |
| | 276.40 | 7.16 | 2.0579E-007 | | 5.2598E-008 | | |
| | 302.85 | 18.33 | 8.0133E-008 | | -1.6931E-008 | | |
| | 356.02 | 62.05 | 3.1866E-008 | | -1.0333E-007 | | |
| | 383.85 | 8.94 | 1.7541E-007 | | -4.4408E-009 | | |
| | + CS-134 | 475.35 | 1.46 | | 1.1640E-006 | 1.59E-008 | 2.7777E-008 |
| | | 563.23* | 8.38 | | 1.5977E-007 | | 5.5290E-008 |
| | | 569.32 | 15.43 | | 1.2439E-007 | | -3.5171E-008 |
| | | 604.70* | 97.60 | | 1.5930E-008 | | 1.9392E-008 |
| | | 795.84* | 85.40 | | 2.0223E-008 | | 2.7770E-008 |
| 801.93 | | 8.73 | 2.5819E-007 | -2.2145E-007 | | | |
| 1038.57 | | 1.00 | 2.3764E-006 | -2.9657E-006 | | | |
| 1167.94 | | 1.80 | 2.3336E-006 | 4.2343E-007 | | | |
| 1365.15 | | 3.04 | 5.3262E-007 | 2.1101E-007 | | | |
| CS-137 | | 661.66 | 85.21 | 2.3295E-008 | 2.33E-008 | | 6.7507E-009 |
| | + EU-152x | 121.78* | 28.40 | 6.3672E-008 | 6.37E-008 | 1.9663E-006 | |
| 244.70* | | 7.49 | 4.6185E-007 | 1.9143E-006 | | | |
| 344.28* | | 26.60 | 7.0919E-008 | 1.8879E-006 | | | |
| 411.11* | | 2.23 | 7.8608E-007 | 2.1749E-006 | | | |
| 443.98* | | 2.78 | 7.1092E-007 | 2.2104E-006 | | | |
| 778.90* | | 12.96 | 1.7189E-007 | 2.0531E-006 | | | |
| 867.39* | | 4.15 | 6.1539E-007 | 1.8145E-006 | | | |
| 964.13* | | 14.34 | 2.9108E-007 | 2.0566E-006 | | | |
| 1085.91* | | 9.92 | 4.6298E-007 | 2.0919E-006 | | | |
| 1089.70* | | 1.71 | 2.7021E-006 | 2.6391E-006 | | | |
| 1112.12* | | 13.55 | 2.4919E-007 | 2.0369E-006 | | | |
| 1212.95* | | 1.40 | 1.7558E-006 | 2.2261E-006 | | | |
| 1299.12* | | 1.63 | 1.1766E-006 | 1.9564E-006 | | | |
| 1408.01* | | 20.87 | 9.5893E-008 | 2.0823E-006 | | | |
| EU-154 | | 123.07 | 40.40 | 5.3508E-008 | | 5.35E-008 | -4.5774E-009 |
| | | 188.25 | 0.23 | 6.7518E-006 | | | -3.6636E-006 |
| | | 247.93 | 6.83 | 2.6435E-007 | | | 1.4184E-006 |
| | 401.30 | 0.19 | 8.3321E-006 | 3.1884E-006 | | | |
| | 444.39 | 0.55 | 3.3662E-006 | 1.1169E-005 | | | |
| | 478.26 | 0.21 | 8.1163E-006 | 5.2896E-006 | | | |
| | 557.56 | 0.25 | 7.2431E-006 | -5.1831E-006 | | | |
| | 582.00 | 0.89 | 2.6094E-006 | 9.6606E-006 | | | |
| | 591.76 | 4.91 | 3.8831E-007 | -2.7262E-007 | | | |
| | 625.22 | 0.32 | 5.9727E-006 | -2.9648E-008 | | | |
| | 676.59 | 0.14 | 1.4582E-005 | -2.2096E-006 | | | |
| | 692.42 | 1.78 | 1.1787E-006 | -5.1231E-008 | | | |
| | 715.76 | 0.17 | 1.2112E-005 | 2.6098E-006 | | | |
| | 722.30 | 20.00 | 1.1154E-007 | 4.5687E-008 | | | |
| | 756.86 | 4.50 | 5.1234E-007 | 2.6612E-007 | | | |
| | 815.55 | 0.50 | 4.5640E-006 | 3.6749E-007 | | | |
| | 845.39 | 0.58 | 4.0517E-006 | 2.2147E-006 | | | |
| | 850.64 | 0.23 | 9.9898E-006 | -5.8306E-006 | | | |
| | 873.20 | 12.09 | 2.2458E-007 | -2.9083E-008 | | | |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|---|--------------|--------------|-------------|-------------------|----------------------|-------------------|-----------|--------------|
| | EU-154 | 892.73 | 0.50 | 4.8349E-006 | 5.35E-008 | 1.8677E-006 | | |
| | | 904.05 | 0.85 | 2.8602E-006 | | -4.8653E-007 | | |
| | | 996.30 | 10.34 | 2.3656E-007 | | 2.5683E-008 | | |
| | | 1004.76 | 17.90 | 1.4756E-007 | | 2.3828E-007 | | |
| | | 1128.40 | 0.29 | 8.5146E-006 | | -9.5004E-006 | | |
| | | 1140.90 | 0.22 | 1.1294E-005 | | -7.9772E-006 | | |
| | | 1241.60 | 0.13 | 2.0896E-005 | | -1.4188E-005 | | |
| | | 1246.60 | 0.80 | 2.9608E-006 | | -1.9684E-006 | | |
| | | 1274.51 | 34.40 | 7.0414E-008 | | 1.3229E-007 | | |
| | | 1494.08 | 0.71 | 1.9605E-006 | | -3.3617E-007 | | |
| | | 1596.45 | 1.80 | 8.8063E-007 | | -4.5685E-008 | | |
| + | | TL-208B | 72.80 | 2.02 | | 6.8822E-007 | 2.61E-008 | -2.2211E-007 |
| | | | 74.97* | 3.41 | | 5.8472E-007 | | 1.8190E-006 |
| | | | 84.90* | 1.51 | | 2.3773E-006 | | 1.8783E-006 |
| | 277.36* | | 6.31 | 1.6686E-007 | 7.3518E-008 | | | |
| | 510.77* | | 22.60 | 1.3009E-007 | 9.1441E-008 | | | |
| | 583.19* | | 84.50 | 2.6114E-008 | 9.9847E-008 | | | |
| | 763.13 | | 1.81 | 1.3183E-006 | -8.4216E-007 | | | |
| | 860.56* | | 12.42 | 1.4468E-007 | 1.3066E-007 | | | |
| | 2614.53 | | 99.16 | 2.8487E-008 | 1.2778E-007 | | | |
| + | Pb-210 | | 46.52* | 4.05 | 3.8975E-007 | 3.90E-007 | | 1.4607E-006 |
| + | PB-212B | 74.81* | 10.50 | 1.8989E-007 | 7.93E-008 | 5.9073E-007 | | |
| | | 77.11* | 17.60 | 1.1208E-007 | | 5.2798E-007 | | |
| | | 87.30* | 7.90 | 4.5511E-007 | | 5.9496E-007 | | |
| | | 238.63* | 43.60 | 7.9280E-008 | | 3.4815E-007 | | |
| | | 300.09* | 3.34 | 4.0858E-007 | | 4.0355E-007 | | |
| + | BI-214B | 609.31* | 44.80 | 4.6571E-008 | 4.66E-008 | 5.4444E-007 | | |
| | | 665.45 | 1.29 | 1.5492E-006 | | 8.1125E-007 | | |
| | | 768.36* | 4.80 | 3.8640E-007 | | 6.2775E-007 | | |
| | | 806.17 | 1.12 | 2.0246E-006 | | 6.5388E-007 | | |
| | | 934.06* | 3.03 | 8.5674E-007 | | 5.0205E-007 | | |
| | | 1120.29* | 14.80 | 1.9604E-007 | | 5.6662E-007 | | |
| | | 1155.19* | 1.64 | 1.2889E-006 | | 1.3812E-006 | | |
| | | 1238.11* | 5.86 | 3.8957E-007 | | 7.3543E-007 | | |
| | | 1280.96 | 1.44 | 1.6059E-006 | | 1.1556E-006 | | |
| | | 1377.67* | 3.92 | 4.0913E-007 | | 7.3397E-007 | | |
| | | 1401.50* | 1.55 | 1.0090E-006 | | 5.2258E-007 | | |
| | | 1407.98* | 2.80 | 7.1529E-007 | | 1.5532E-005 | | |
| | | 1509.23* | 2.12 | 8.4472E-007 | | 1.0995E-006 | | |
| | | 1661.28* | 1.14 | 1.2716E-006 | | 6.1785E-007 | | |
| | | 1729.59* | 2.88 | 3.5610E-007 | | 6.0672E-007 | | |
| | | 1764.49* | 15.36 | 9.8206E-008 | | 5.9582E-007 | | |
| | | 1847.42* | 2.04 | 6.6568E-007 | | 5.6918E-007 | | |
| | | 2118.55 | 1.14 | 1.2111E-006 | | -9.1058E-009 | | |
| | | 2204.21* | 4.86 | 4.7675E-007 | | 6.7652E-007 | | |
| | 2447.86* | 1.50 | 5.3151E-007 | 5.2608E-007 | | | | |
| + | PB-214B | 53.23* | 1.11 | 7.3322E-007 | 5.09E-008 | 5.4642E-007 | | |
| | | 74.81* | 5.90 | 3.3795E-007 | | 1.0513E-006 | | |
| | | 77.11* | 9.90 | 1.9926E-007 | | 9.3863E-007 | | |
| | | 87.30* | 4.41 | 8.1527E-007 | | 1.0658E-006 | | |
| | | 241.98* | 7.50 | 4.5906E-007 | | 7.3976E-007 | | |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-------------|-------------------|----------------------|-------------------|
| + | PB-214B | 295.21* | 18.50 | 8.8721E-008 | 5.09E-008 | 6.4590E-007 |
| | | 351.92* | 35.80 | 5.0880E-008 | | 5.8294E-007 |
| + | RA-226 | 186.10* | 3.50 | 4.6241E-007 | 4.62E-007 | 9.7896E-007 |
| + | AC-228B | 12.95 | 15.10 | 1.0284E-006 | 9.54E-008 | -9.3529E-009 |
| | | 16.15 | 20.00 | 4.1228E-007 | | 7.2653E-008 |
| | | 19.11 | 4.60 | 1.0510E-006 | | -3.8324E-007 |
| | | 89.96* | 3.40 | 1.0702E-006 | | 7.7066E-007 |
| | | 93.35* | 5.60 | 6.5366E-007 | | 4.2049E-007 |
| | | 99.55 | 1.30 | 9.7011E-007 | | 6.8496E-007 |
| | | 105.36 | 2.00 | 6.2999E-007 | | 6.9668E-008 |
| | | 129.03* | 2.90 | 3.6627E-007 | | 2.8412E-007 |
| | | 209.39* | 4.10 | 2.8160E-007 | | 2.0020E-007 |
| | | 270.26* | 3.80 | 4.8039E-007 | | 6.3653E-007 |
| | | 328.07* | 3.50 | 4.6898E-007 | | 4.9838E-007 |
| | | 338.42* | 12.40 | 1.2720E-007 | | 2.2411E-007 |
| | | 409.62 | 2.20 | 8.1479E-007 | | 2.1817E-006 |
| | | 463.10* | 4.60 | 2.7360E-007 | | 3.9123E-007 |
| | | 562.65* | 1.01 | 1.3107E-006 | | 4.5359E-007 |
| | | 755.28 | 1.32 | 1.7386E-006 | | 9.1203E-007 |
| | | 772.28 | 1.09 | 2.2972E-006 | | -1.9324E-007 |
| | | 794.79* | 4.60 | 3.7124E-007 | | 5.0978E-007 |
| | | 835.60* | 1.71 | 1.2464E-006 | | 9.0152E-007 |
| | | 911.16* | 29.00 | 9.5369E-008 | | 3.3640E-007 |
| | | 964.64* | 5.80 | 7.2023E-007 | | 5.0887E-006 |
| | | 968.97* | 17.40 | 2.4479E-007 | | 4.0219E-007 |
| | | 1459.19 | 1.06 | 6.2056E-006 | | 1.1293E-004 |
| | | 1496.00 | 1.05 | 1.3325E-006 | | 6.5624E-007 |
| | | 1588.23 | 3.60 | 4.6012E-007 | | 3.2593E-007 |
| | | 1630.47 | 1.95 | 6.6862E-007 | | -4.2890E-007 |
| | | PA-234B | 63.00 | 3.20 | | 3.6937E-007 |
| | 94.67 | | 14.30 | 9.4719E-008 | -6.7474E-008 | |
| | 98.44 | | 23.00 | 5.4760E-008 | -1.8959E-008 | |
| | 99.70 | | 4.80 | 2.6241E-007 | 1.5368E-007 | |
| | 111.00 | | 10.80 | 1.1953E-007 | 3.4364E-008 | |
| | 125.40 | | 1.00 | 1.5861E-006 | -1.8845E-006 | |
| | 131.20 | | 20.00 | 6.0649E-008 | -1.0088E-008 | |
| | 152.70 | | 6.70 | 2.0276E-007 | 2.6111E-007 | |
| | 186.00 | | 2.00 | 7.8496E-007 | 2.8385E-006 | |
| | 200.90 | | 1.00 | 1.4599E-006 | -8.8002E-007 | |
| | 202.90 | | 1.20 | 1.2187E-006 | -7.0006E-007 | |
| | 226.40 | | 5.90 | 2.5304E-007 | 2.9514E-008 | |
| | 227.20 | | 5.50 | 2.6979E-007 | -1.4786E-007 | |
| | 248.90 | | 2.80 | 5.8582E-007 | -2.4409E-006 | |
| | 272.10 | | 1.00 | 1.4953E-006 | -8.5579E-007 | |
| | 293.70 | 3.90 | 4.5665E-007 | -2.2556E-007 | | |
| | 369.80 | 2.90 | 5.5821E-007 | 6.8400E-007 | | |
| | 372.40 | 1.30 | 1.2208E-006 | -5.9671E-007 | | |
| | 458.80 | 1.50 | 1.1212E-006 | -1.5552E-006 | | |
| | 506.80 | 1.60 | 1.3293E-006 | -9.2358E-008 | | |
| | 513.70 | 1.30 | 1.7102E-006 | -1.0790E-006 | | |
| | 565.90 | 1.40 | 1.3769E-006 | 2.9473E-007 | | |

| Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|--------------|--------------|-------------|-------------------|----------------------|-------------------|
| PA-234B | 568.70 | 3.30 | 5.8083E-007 | 5.48E-008 | -2.0564E-007 |
| | 569.50 | 10.00 | 1.8983E-007 | | -5.3675E-008 |
| | 574.00 | 2.00 | 9.5072E-007 | | -1.8218E-007 |
| | 664.80 | 1.30 | 1.5363E-006 | | 6.3837E-007 |
| | 666.70 | 1.60 | 1.2578E-006 | | 7.7283E-007 |
| | 669.90 | 1.40 | 1.4171E-006 | | -6.3550E-007 |
| | 692.70 | 1.50 | 1.3933E-006 | | 1.2949E-007 |
| | 699.00 | 4.60 | 4.4232E-007 | | -6.6417E-008 |
| | 706.10 | 3.10 | 6.5587E-007 | | -2.3926E-007 |
| | 733.00 | 9.00 | 2.5459E-007 | | 1.2239E-007 |
| | 738.00 | 1.00 | 2.1906E-006 | | -6.3777E-007 |
| | 742.81 | 2.40 | 9.1527E-007 | | -1.8839E-007 |
| | 755.60 | 1.40 | 1.6382E-006 | | 4.1169E-007 |
| | 780.70 | 1.10 | 2.9876E-006 | | 2.2651E-005 |
| | 786.27 | 1.40 | 1.6805E-006 | | -5.5459E-006 |
| | 793.60 | 1.50 | 1.5487E-006 | | 2.6658E-006 |
| | 796.30 | 3.80 | 6.0802E-007 | | 3.9786E-007 |
| | 805.80 | 3.30 | 6.8495E-007 | | 1.4754E-007 |
| | 819.60 | 2.60 | 8.6663E-007 | | -3.1580E-007 |
| | 826.30 | 4.00 | 5.7048E-007 | | 2.9071E-007 |
| | 831.60 | 5.50 | 4.2067E-007 | | 7.3590E-008 |
| | 876.40 | 4.00 | 6.1878E-007 | | 1.5853E-007 |
| | 880.50 | 4.00 | 5.9431E-007 | | -1.8105E-007 |
| | 880.51 | 9.00 | 2.6414E-007 | | -8.0469E-008 |
| | 883.24 | 15.00 | 1.5919E-007 | | 9.3824E-008 |
| | 899.00 | 4.10 | 5.8677E-007 | | -1.8587E-007 |
| | 925.00 | 2.90 | 8.3614E-007 | | 2.6960E-007 |
| | 926.00 | 11.00 | 2.1969E-007 | | -5.9510E-008 |
| | 927.10 | 11.00 | 2.1890E-007 | | 6.8320E-009 |
| | 946.00 | 12.00 | 1.9941E-007 | | 1.3339E-007 |
| | 949.00 | 8.00 | 2.9850E-007 | | -9.1904E-008 |
| | 978.80 | 1.40 | 1.6283E-006 | | -1.1024E-007 |
| | 980.50 | 2.00 | 1.1374E-006 | | -2.4057E-007 |
| | 980.50 | 3.00 | 7.5825E-007 | | -1.6038E-007 |
| 984.00 | 1.90 | 1.1918E-006 | -7.6146E-007 | | |
| 1353.30 | 1.70 | 9.5839E-007 | -5.1743E-007 | | |
| 1394.10 | 3.00 | 5.1917E-007 | -2.5184E-008 | | |
| 1452.70 | 1.00 | 2.3612E-006 | -1.5479E-006 | | |
| 1668.50 | 1.20 | 1.0105E-006 | 3.1367E-007 | | |
| 1694.60 | 1.20 | 9.6053E-007 | -2.6350E-007 | | |
| + TH-234 | 63.29* | 4.50 | 4.5348E-007 | 4.53E-007 | 5.4959E-007 |
| | 92.38 | 2.60 | 8.4581E-007 | | 2.8175E-006 |
| | 92.80* | 2.60 | 2.2256E-006 | | 1.4317E-006 |
| + U-235 | 72.70 | 0.11 | 1.2603E-005 | 2.81E-008 | -4.0673E-006 |
| | 89.95* | 2.80 | 1.2957E-006 | | 9.3307E-007 |
| | 93.35* | 4.50 | 8.1106E-007 | | 5.2175E-007 |
| | 94.00 | 0.40 | 3.3771E-006 | | -1.7096E-006 |
| | 105.00 | 2.10 | 5.9784E-007 | | 1.6501E-007 |
| | 109.16 | 1.50 | 8.4920E-007 | | -7.0172E-007 |
| | 140.76 | 0.22 | 5.8894E-006 | | -2.5483E-006 |
| | 143.76* | 10.90 | 1.1233E-007 | | 2.4408E-008 |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-----------|-------------------|----------------------|-------------------|
| + | U-235 | 163.33 | 5.00 | 2.7595E-007 | 2.81E-008 | 3.0782E-007 |
| | | 182.61 | 0.40 | 3.7883E-006 | | -3.1668E-006 |
| | | 185.71* | 57.50 | 2.8146E-008 | | 5.9587E-008 |
| | | 194.94 | 0.59 | 2.4691E-006 | | 1.3618E-006 |
| | | 202.11 | 1.00 | 1.4597E-006 | | -6.4174E-007 |
| | | 205.31 | 5.00 | 2.9598E-007 | | -1.5979E-007 |
| | | 279.50 | 0.27 | 5.4954E-006 | | 1.3447E-006 |

+ = Nuclide identified during the nuclide identification

* = Energy line found in the spectrum

> = MDA value not calculated

@ = Half-life too short to be able to perform the decay correction

Filename: C:\Soil\2008-11-20-01\2008-11-20-01N_100000_2008November28.CN

Report Generated On : 12/17/2008 8:02:02 PM

Sample Title : 2008-11-20-01-Nalgene
Sample Description : 500 ml Nalgene
Sample Identification : 208-11-20-01
Sample Type : 500 ml Nalgene
Sample Geometry : 500 ml Nalgene

Peak Locate Threshold : 3.00
Peak Locate Range (in channels) : 1 - 8192
Peak Area Range (in channels) : 14 - 8192
Identification Energy Tolerance : 1.000 keV

Sample Size : 1.000E+003 g

Sample Taken On : 9/19/2008 8:45:00 AM
Acquisition Started : 11/28/2008 9:26:59 AM

Live Time : 100000.0 seconds
Real Time : 100005.3 seconds

Dead Time : 0.01 %

Energy Calibration Used Done On : 12/17/2008
Efficiency Calibration Used Done On : 12/17/2008
Efficiency ID :

 ***** N U C L I D E M D A R E P O R T *****

Detector Name: HPGE
 Sample Geometry: 500 ml Nalgene
 Sample Title: 2008-11-20-01-Nalgene
 Nuclide Library Used: C:\GENIE2K\CAMFILES\Libraries\Soil_DCGL_

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-----------|-------------------|----------------------|-------------------|
| + | Pb x-ray | 72.80 | 61.00 | 1.9507E-008 | 1.95E-008 | -1.1788E-008 |
| | | 75.00* | 100.00 | 2.5030E-008 | | 5.8326E-008 |
| | | 84.90* | 36.00 | 2.1262E-008 | | 4.2712E-008 |
| | | 87.60* | 10.00 | 9.6304E-008 | | 2.8112E-007 |
| | BE-7 | 477.59 | 10.42 | 2.9187E-007 | 2.92E-007 | -5.3608E-008 |
| + | K-40 | 1460.75* | 10.67 | 2.1724E-007 | 2.17E-007 | 1.0665E-005 |
| | MN-54 | 834.83 | 99.98 | 1.9611E-008 | 1.96E-008 | 1.1128E-008 |
| + | CO-60 | 1173.24* | 99.90 | 2.7008E-008 | 2.05E-008 | 1.9877E-008 |
| | | 1332.50* | 99.98 | 2.0547E-008 | | 2.4214E-008 |
| | ZN-65 | 511.00 | 2.83 | 8.0625E-007 | 6.39E-008 | 5.0777E-006 |
| | | 1115.55 | 50.70 | 6.3872E-008 | | 2.4557E-007 |
| | NB-94x | 702.62 | 97.90 | 1.5116E-008 | 1.51E-008 | 5.1081E-009 |
| | | 871.09 | 99.90 | 1.6684E-008 | | 1.3197E-008 |
| | AG-108m | 79.13 | 6.60 | 1.8470E-007 | 1.39E-008 | 3.2637E-007 |
| | | 433.94 | 90.50 | 1.3925E-008 | | 8.7007E-009 |
| | | 614.28 | 89.80 | 2.7449E-008 | | -1.5479E-008 |
| | | 722.94 | 90.80 | 1.7939E-008 | | 3.8441E-009 |
| + | CD-109 | 88.03* | 3.61 | 2.9235E-007 | 2.92E-007 | 8.5340E-007 |
| | AG-110m | 446.81 | 3.75 | 3.9862E-007 | 1.79E-008 | 1.1423E-007 |
| | | 620.36 | 2.81 | 6.0346E-007 | | -3.2289E-008 |
| | | 657.76 | 94.60 | 1.7878E-008 | | -2.0951E-009 |
| | | 677.62 | 10.35 | 1.6847E-007 | | -6.2273E-008 |
| | | 687.02 | 6.44 | 2.6959E-007 | | -3.0201E-008 |
| | | 706.68 | 16.44 | 1.0788E-007 | | 5.4925E-008 |
| | | 744.28 | 4.73 | 3.9769E-007 | | 2.0204E-007 |
| | | 763.94 | 22.29 | 9.8240E-008 | | -8.1510E-008 |
| | | 818.03 | 7.34 | 2.6493E-007 | | 1.0330E-007 |
| | | 884.68 | 72.70 | 2.6939E-008 | | 8.0247E-009 |
| | | 937.49 | 34.36 | 6.3323E-008 | | 2.2241E-008 |
| | | 1384.30 | 24.28 | 9.1513E-008 | | -2.1218E-008 |
| | | 1475.79 | 3.99 | 3.7431E-007 | | -2.4713E-007 |
| | | 1505.04 | 13.04 | 1.4862E-007 | | 5.4234E-009 |
| | | 1562.30 | 1.03 | 1.5068E-006 | | 1.2057E-006 |
| | SB-125 | 176.33 | 6.79 | 1.6836E-007 | 4.44E-008 | -3.6817E-008 |
| | | 380.43 | 1.52 | 8.3286E-007 | | 6.4043E-009 |
| | | 427.89 | 29.40 | 4.4422E-008 | | -8.8267E-009 |
| | | 463.38 | 10.45 | 1.3023E-007 | | 1.3505E-007 |
| | | 600.56 | 17.78 | 8.2433E-008 | | 1.4410E-008 |
| | | 606.64 | 5.02 | 5.5368E-007 | | -1.3854E-007 |
| | | 635.90 | 11.32 | 1.2411E-007 | | -6.6792E-008 |
| | | 671.41 | 1.80 | 8.3897E-007 | | 1.6433E-007 |
| | BA-133 | 53.16 | 2.20 | 4.1784E-007 | 3.02E-008 | 4.6551E-007 |

| Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|--------------|--------------|-------------|--------------------|----------------------|-------------------|--------------|--------------|
| BA-133 | 79.62 | 2.62 | 4.6780E-007 | 3.02E-008 | 1.1162E-006 | | |
| | 81.00 | 34.10 | 3.0161E-008 | | -4.2266E-007 | | |
| | 160.61 | 0.64 | 1.6256E-006 | | 2.8150E-007 | | |
| | 223.23 | 0.45 | 2.5148E-006 | | -1.9541E-006 | | |
| | 276.40 | 7.16 | 1.6088E-007 | | -2.6087E-008 | | |
| | 302.85 | 18.33 | 6.3475E-008 | | -1.3120E-008 | | |
| | 356.02 | 62.05 | 3.0221E-008 | | -2.1460E-008 | | |
| | 383.85 | 8.94 | 1.3845E-007 | | -3.6701E-008 | | |
| | CS-134 | 475.35 | 1.46 | | 8.8912E-007 | 2.11E-008 | 1.4056E-007 |
| | | 563.23 | 8.38 | | 1.7097E-007 | | -8.6160E-008 |
| 569.32 | | 15.43 | 9.3636E-008 | -7.3711E-009 | | | |
| 604.70 | | 97.60 | 2.2582E-008 | -7.9836E-009 | | | |
| 795.84 | | 85.40 | 2.1078E-008 | <u>1.7273E-008</u> | | | |
| 801.93 | | 8.73 | 1.9847E-007 | -1.1229E-007 | | | |
| 1038.57 | | 1.00 | 1.9187E-006 | -1.0387E-006 | | | |
| 1167.94 | | 1.80 | 1.3183E-006 | 3.3212E-007 | | | |
| 1365.15 | | 3.04 | 5.5730E-007 | 5.1356E-008 | | | |
| CS-137 | | 661.66 | 85.21 | 1.6851E-008 | 1.69E-008 | | -8.8619E-009 |
| | 121.78* | 28.40 | 3.7810E-008 | 3.78E-008 | 1.1047E-007 | | |
| 244.70* | 7.49 | 1.1806E-007 | 4.9216E-008 | | | | |
| 344.28* | 26.60 | 4.2745E-008 | 9.9522E-008 | | | | |
| 411.11 | 2.23 | 5.8722E-007 | 3.2492E-007 | | | | |
| 443.98 | 2.78 | 4.4942E-007 | 6.5840E-008 | | | | |
| 778.90* | 12.96 | 1.0771E-007 | 1.0168E-007 | | | | |
| 867.39 | 4.15 | 4.0912E-007 | -1.0085E-007 | | | | |
| 964.13* | 14.34 | 2.0822E-007 | 2.5714E-007 | | | | |
| 1085.91 | 9.92 | 2.0233E-007 | 9.2358E-008 | | | | |
| 1089.70 | 1.71 | 1.1737E-006 | 2.9125E-007 | | | | |
| 1112.12* | 13.55 | 2.1184E-007 | 1.2403E-007 | | | | |
| 1212.95 | 1.40 | 1.6550E-006 | 4.2269E-007 | | | | |
| 1299.12 | 1.63 | 1.1314E-006 | 2.6851E-007 | | | | |
| 1408.01* | 20.87 | 6.5551E-008 | <u>1.9388E-007</u> | | | | |
| EU-154 | 123.07 | 40.40 | 2.5252E-008 | | 2.53E-008 | -1.4260E-009 | |
| | 188.25 | 0.23 | 5.5681E-006 | | | -1.5640E-005 | |
| | 247.93 | 6.83 | 1.6584E-007 | 5.0769E-008 | | | |
| | 401.30 | 0.19 | 6.6345E-006 | 2.3022E-006 | | | |
| | 444.39 | 0.55 | 2.2641E-006 | 1.5647E-007 | | | |
| | 478.26 | 0.21 | 5.9116E-006 | -5.7596E-007 | | | |
| | 557.56 | 0.25 | 5.3097E-006 | -3.0550E-006 | | | |
| | 582.00 | 0.89 | 2.2019E-006 | 1.3428E-005 | | | |
| | 591.76 | 4.91 | 2.8125E-007 | -1.0302E-007 | | | |
| | 625.22 | 0.32 | 4.3906E-006 | -4.5490E-006 | | | |
| | 676.59 | 0.14 | 1.0620E-005 | -7.7876E-006 | | | |
| | 692.42 | 1.78 | 8.3313E-007 | 4.6020E-008 | | | |
| | 715.76 | 0.17 | 8.7511E-006 | 4.0263E-006 | | | |
| | 722.30 | 20.00 | 7.8827E-008 | 2.5177E-008 | | | |
| | 756.86 | 4.50 | 3.5812E-007 | 2.9098E-009 | | | |
| | 815.55 | 0.50 | 3.1869E-006 | -3.3612E-007 | | | |
| | 845.39 | 0.58 | 2.8545E-006 | -3.7930E-007 | | | |
| | 850.64 | 0.23 | 6.9718E-006 | -9.2890E-006 | | | |
| | 873.20 | 12.09 | 1.3957E-007 | 1.6585E-008 | | | |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|---|--------------|--------------|-------------|-------------------|----------------------|-------------------|-----------|--------------|
| | EU-154 | 892.73 | 0.50 | 3.2917E-006 | 2.53E-008 | -9.0941E-007 | | |
| | | 904.05 | 0.85 | 2.0472E-006 | | 5.2964E-007 | | |
| | | 996.30 | 10.34 | 1.7569E-007 | | -3.8026E-008 | | |
| | | 1004.76 | 17.90 | 1.0729E-007 | | -1.3880E-008 | | |
| | | 1128.40 | 0.29 | 6.9146E-006 | | -1.8266E-006 | | |
| | | 1140.90 | 0.22 | 9.2528E-006 | | -1.7067E-006 | | |
| | | 1241.60 | 0.13 | 2.0273E-005 | | 4.0159E-005 | | |
| | | 1246.60 | 0.80 | 2.7411E-006 | | -2.2812E-006 | | |
| | | 1274.51 | 34.40 | 5.8399E-008 | | 1.0686E-008 | | |
| | | 1494.08 | 0.71 | 1.9753E-006 | | -6.5782E-007 | | |
| | | 1596.45 | 1.80 | 8.4962E-007 | | -2.8908E-007 | | |
| + | | TL-208B | 72.80 | 2.02 | | 5.8907E-007 | 1.99E-008 | -3.5598E-007 |
| | | | 74.97* | 3.41 | | 7.3401E-007 | | 1.7104E-006 |
| | 84.90* | | 1.51 | 5.0692E-007 | 1.0183E-006 | | | |
| | 277.36* | | 6.31 | 1.6163E-007 | 2.0963E-007 | | | |
| | 510.77* | | 22.60 | 1.2084E-007 | 1.4063E-007 | | | |
| | 583.19* | | 84.50 | 2.0727E-008 | 1.2109E-007 | | | |
| | 763.13 | | 1.81 | 9.7589E-007 | -8.3550E-007 | | | |
| | 860.56* | | 12.42 | 1.3708E-007 | 1.5753E-007 | | | |
| | 2614.53* | | 99.16 | 1.9892E-008 | 1.0345E-007 | | | |
| + | Pb-210 | | 46.52* | 4.05 | 3.0358E-007 | 3.04E-007 | | 6.3411E-007 |
| + | PB-212B | 74.81* | 10.50 | 2.3838E-007 | 4.62E-008 | 5.5548E-007 | | |
| | | 77.11* | 17.60 | 1.4218E-007 | | 5.3836E-007 | | |
| | | 87.30* | 7.90 | 1.2190E-007 | | 3.5585E-007 | | |
| | | 238.63* | 43.60 | 4.6238E-008 | | 3.3362E-007 | | |
| | | 300.09* | 3.34 | 2.8958E-007 | | 3.8694E-007 | | |
| + | BI-214B | 609.31* | 44.80 | 4.2857E-008 | 4.29E-008 | 5.9788E-007 | | |
| | | 665.45* | 1.29 | 9.8018E-007 | | 6.9112E-007 | | |
| | | 768.36* | 4.80 | 3.1441E-007 | | 5.8983E-007 | | |
| | | 806.17 | 1.12 | 1.4330E-006 | | -1.7565E-007 | | |
| | | 934.06* | 3.03 | 5.8323E-007 | | 7.9035E-007 | | |
| | | 1120.29* | 14.80 | 1.5241E-007 | | 6.6197E-007 | | |
| | | 1155.19* | 1.64 | 1.1806E-006 | | 8.1112E-007 | | |
| | | 1238.11* | 5.86 | 3.6751E-007 | | 7.0365E-007 | | |
| | | 1280.96* | 1.44 | 1.6815E-006 | | 8.0497E-007 | | |
| | | 1377.67* | 3.92 | 7.8218E-007 | | 1.0423E-006 | | |
| | | 1401.50 | 1.55 | 1.1505E-006 | | -7.3310E-007 | | |
| | | 1407.98* | 2.80 | 4.9029E-007 | | 1.4501E-006 | | |
| | | 1509.23* | 2.12 | 1.0308E-006 | | 1.6538E-007 | | |
| | | 1661.28* | 1.14 | 1.2923E-006 | | 1.1331E-006 | | |
| | | 1729.59* | 2.88 | 3.7642E-007 | | 7.2990E-007 | | |
| | | 1764.49* | 15.36 | 1.2965E-007 | | 6.8308E-007 | | |
| | | 1847.42* | 2.04 | 4.8305E-007 | | 1.3387E-006 | | |
| | | 2118.55* | 1.14 | 1.3079E-006 | | 4.8343E-007 | | |
| | | 2204.21* | 4.86 | 3.2401E-007 | | 9.9062E-007 | | |
| | 2447.86* | 1.50 | 7.2595E-007 | 1.4171E-006 | | | | |
| + | PB-214B | 53.23* | 1.11 | 6.9333E-007 | 4.47E-008 | 6.0276E-007 | | |
| | | 74.81* | 5.90 | 4.2423E-007 | | 9.8857E-007 | | |
| | | 77.11* | 9.90 | 2.5276E-007 | | 9.5708E-007 | | |
| | | 87.30* | 4.41 | 2.1838E-007 | | 6.3746E-007 | | |
| | | 241.98* | 7.50 | 2.6946E-007 | | 7.3934E-007 | | |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|---|--------------|--------------|-------------|-------------------|----------------------|-------------------|-----------|--------------|
| + | PB-214B | 295.21* | 18.50 | 7.7561E-008 | 4.47E-008 | 6.1113E-007 | | |
| | | 351.92* | 35.80 | 4.4676E-008 | | 6.0289E-007 | | |
| + | RA-226 | 186.10* | 3.50 | 3.6694E-007 | 3.67E-007 | 1.2533E-006 | | |
| + | AC-228B | 12.95* | 15.10 | 8.0507E-007 | 7.67E-008 | 4.3442E-007 | | |
| | | 16.15 | 20.00 | 3.4020E-007 | | -6.2293E-008 | | |
| | | 19.11 | 4.60 | 8.6488E-007 | | 1.3943E-007 | | |
| | | 89.96* | 3.40 | 1.9819E-007 | | 5.1562E-007 | | |
| | | 93.35* | 5.60 | 2.1872E-007 | | 4.6177E-007 | | |
| | | 99.55* | 1.30 | 6.5781E-007 | | 3.9880E-007 | | |
| | | 105.36* | 2.00 | 3.1788E-007 | | 2.0236E-007 | | |
| | | 129.03* | 2.90 | 3.2153E-007 | | 2.9308E-007 | | |
| | | 209.39* | 4.10 | 2.3730E-007 | | 4.2225E-007 | | |
| | | 270.26* | 3.80 | 3.2268E-007 | | 5.7734E-007 | | |
| | | 328.07* | 3.50 | 3.0666E-007 | | 2.7969E-007 | | |
| | | 338.42* | 12.40 | 1.0797E-007 | | 2.8263E-007 | | |
| | | 409.62* | 2.20 | 5.1529E-007 | | 2.6377E-007 | | |
| | | 463.10* | 4.60 | 2.6449E-007 | | 4.1318E-007 | | |
| | | 562.65 | 1.01 | 1.3577E-006 | | 1.3747E-007 | | |
| | | 755.28* | 1.32 | 1.3977E-006 | | 7.0994E-007 | | |
| | | 772.28 | 1.09 | 1.6902E-006 | | -1.5779E-007 | | |
| | | 794.79* | 4.60 | 3.1624E-007 | | 3.4805E-007 | | |
| | | 835.60 | 1.71 | 9.9980E-007 | | 1.0275E-006 | | |
| | | 911.16* | 29.00 | 7.6685E-008 | | 3.2727E-007 | | |
| | | 964.64* | 5.80 | 5.1660E-007 | | 6.3796E-007 | | |
| | | 968.97* | 17.40 | 1.8138E-007 | | 3.4843E-007 | | |
| | | 1459.19 | 1.06 | 6.1602E-006 | | 1.0870E-004 | | |
| | | 1496.00 | 1.05 | 1.3443E-006 | | -5.2200E-007 | | |
| | | 1588.23* | 3.60 | 3.0148E-007 | | 4.0019E-007 | | |
| | | 1630.47* | 1.95 | 6.5202E-007 | | 1.3895E-007 | | |
| | | PA-234B | 63.00 | 3.20 | | 3.1476E-007 | 3.99E-008 | -1.3943E-007 |
| | | | 94.67 | 14.30 | | 7.2975E-008 | | -9.3142E-009 |
| | | | 98.44 | 23.00 | | 3.9881E-008 | | 2.1110E-008 |
| | | | 99.70 | 4.80 | | 1.9088E-007 | | 1.9327E-007 |
| | 111.00 | | 10.80 | 8.5952E-008 | 2.9189E-008 | | | |
| | 125.40 | | 1.00 | 9.6376E-007 | -5.7600E-007 | | | |
| | 131.20 | | 20.00 | 4.8884E-008 | -1.8954E-008 | | | |
| | 152.70 | | 6.70 | 1.5819E-007 | 2.8734E-008 | | | |
| | 186.00 | | 2.00 | 6.4333E-007 | 2.8236E-006 | | | |
| | 200.90 | | 1.00 | 1.1440E-006 | -5.0799E-007 | | | |
| | 202.90 | | 1.20 | 9.5428E-007 | 5.8837E-008 | | | |
| | 226.40 | | 5.90 | 1.9453E-007 | -2.2644E-008 | | | |
| | 227.20 | | 5.50 | 2.0971E-007 | 6.4071E-008 | | | |
| | 248.90 | | 2.80 | 4.0017E-007 | 1.6924E-007 | | | |
| | 272.10 | | 1.00 | 1.2014E-006 | -1.8479E-007 | | | |
| | 293.70 | | 3.90 | 3.9988E-007 | 4.7164E-008 | | | |
| | 369.80 | | 2.90 | 4.0940E-007 | -6.1541E-008 | | | |
| | 372.40 | | 1.30 | 9.2200E-007 | 2.4178E-007 | | | |
| | 458.80 | 1.50 | 8.4807E-007 | -1.8687E-007 | | | | |
| | 506.80 | 1.60 | 1.0870E-006 | 6.4392E-008 | | | | |
| | 513.70 | 1.30 | 1.4540E-006 | -1.2781E-007 | | | | |
| | 565.90 | 1.40 | 9.8645E-007 | 2.1464E-007 | | | | |

| Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|--------------|--------------|-------------|-------------------|----------------------|-------------------|
| PA-234B | 568.70 | 3.30 | 4.1447E-007 | 3.99E-008 | -3.0886E-007 |
| | 569.50 | 10.00 | 1.3731E-007 | | -1.0809E-008 |
| | 574.00 | 2.00 | 6.8905E-007 | | -4.1730E-007 |
| | 664.80 | 1.30 | 1.1409E-006 | | 6.2704E-007 |
| | 666.70 | 1.60 | 9.2665E-007 | | 1.2331E-007 |
| | 669.90 | 1.40 | 1.0651E-006 | | 1.3819E-007 |
| | 692.70 | 1.50 | 9.8682E-007 | | 1.0637E-007 |
| | 699.00 | 4.60 | 3.2873E-007 | | 1.7670E-007 |
| | 706.10 | 3.10 | 4.7590E-007 | | 2.0801E-007 |
| | 733.00 | 9.00 | 1.8609E-007 | | -1.7127E-007 |
| | 738.00 | 1.00 | 1.5698E-006 | | 4.5560E-007 |
| | 742.81 | 2.40 | 6.5164E-007 | | -1.2292E-007 |
| | 755.60 | 1.40 | 1.1407E-006 | | -8.5827E-008 |
| | 780.70 | 1.10 | 1.5705E-006 | | 1.1282E-006 |
| | 786.27 | 1.40 | 1.2091E-006 | | 9.3691E-007 |
| | 793.60 | 1.50 | 1.1518E-006 | | 8.5026E-007 |
| | 796.30 | 3.80 | 4.4993E-007 | | 2.6752E-007 |
| | 805.80 | 3.30 | 4.8573E-007 | | -1.3166E-007 |
| | 819.60 | 2.60 | 6.2647E-007 | | 1.4057E-008 |
| | 826.30 | 4.00 | 4.0474E-007 | | 2.1854E-008 |
| | 831.60 | 5.50 | 3.0061E-007 | | 3.2026E-009 |
| | 876.40 | 4.00 | 4.1302E-007 | | -2.6478E-009 |
| | 880.50 | 4.00 | 4.0555E-007 | | -9.4975E-008 |
| | 880.51 | 9.00 | 1.8025E-007 | | -4.2211E-008 |
| | 883.24 | 15.00 | 1.0787E-007 | | 5.2396E-008 |
| | 899.00 | 4.10 | 4.2108E-007 | | 2.6449E-007 |
| | 925.00 | 2.90 | 5.8504E-007 | | -2.4454E-008 |
| | 926.00 | 11.00 | 1.5346E-007 | | -4.0452E-008 |
| | 927.10 | 11.00 | 1.5337E-007 | | -4.0489E-008 |
| | 946.00 | 12.00 | 1.4576E-007 | | -1.9021E-008 |
| | 949.00 | 8.00 | 2.2334E-007 | | 5.1564E-008 |
| | 978.80 | 1.40 | 1.2359E-006 | | 2.5749E-007 |
| | 980.50 | 2.00 | 8.6001E-007 | | -1.0936E-007 |
| 980.50 | 3.00 | 5.7334E-007 | -7.2908E-008 | | |
| 984.00 | 1.90 | 9.0444E-007 | -1.8261E-007 | | |
| 1353.30 | 1.70 | 9.4914E-007 | -3.5773E-007 | | |
| 1394.10 | 3.00 | 5.0216E-007 | -6.7873E-007 | | |
| 1452.70 | 1.00 | 1.8495E-006 | -1.8362E-007 | | |
| 1668.50 | 1.20 | 1.0676E-006 | 2.1472E-007 | | |
| 1694.60 | 1.20 | 1.0206E-006 | -2.4406E-007 | | |
| + TH-234 | 63.29* | 4.50 | 1.8596E-006 | 1.86E-006 | 1.9361E-006 |
| | 92.38 | 2.60 | 3.1727E-006 | | 1.5315E-005 |
| | 92.80* | 2.60 | 3.5422E-006 | | 7.4782E-006 |
| + U-235 | 72.70 | 0.11 | 1.0676E-005 | 2.23E-008 | -6.4515E-006 |
| | 89.95* | 2.80 | 2.3748E-007 | | 6.1785E-007 |
| | 93.35* | 4.50 | 2.6860E-007 | | 5.6706E-007 |
| | 94.00* | 0.40 | 2.7204E-006 | | 9.7656E-007 |
| | 105.00 | 2.10 | 4.2494E-007 | | -1.7311E-007 |
| | 109.16 | 1.50 | 6.0659E-007 | | -1.1882E-008 |
| | 140.76 | 0.22 | 4.6037E-006 | | -1.0799E-006 |
| | 143.76* | 10.90 | 8.8770E-008 | 2.5756E-008 | |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-----------|-------------------|----------------------|-------------------|
| + | U-235 | 163.33 | 5.00 | 2.0827E-007 | 2.23E-008 | 1.1497E-007 |
| | | 182.61 | 0.40 | 2.9829E-006 | | -1.8655E-006 |
| | | 185.71* | 57.50 | 2.2334E-008 | | 7.6280E-008 |
| | | 194.94 | 0.59 | 1.9023E-006 | | 4.9723E-007 |
| | | 202.11 | 1.00 | 1.1279E-006 | | -6.2595E-007 |
| | | 205.31 | 5.00 | 2.2681E-007 | | -1.4373E-007 |
| | | 279.50 | 0.27 | 4.1731E-006 | | 5.8468E-007 |

+ = Nuclide identified during the nuclide identification

* = Energy line found in the spectrum

> = MDA value not calculated

@ = Half-life too short to be able to perform the decay correction

***** GAMMA S E C T R U M A N A L Y : S *****

Filename: HPGE

Report Generated On : 12/18/2008 9:37:24 AM

Sample Title : 2008-11-20-02N_2008Dec16
Sample Description : 500 ml Nalgene
Sample Identification : 2008-11-20-02
Sample Type : 500 ml Nalgene
Sample Geometry : 500 ml Nalgene

Peak Locate Threshold : 3.00
Peak Locate Range (in channels) : 8 - 8192
Peak Area Range (in channels) : 8 - 8192
Identification Energy Tolerance : 1.000 keV

Sample Size : 1.000E+003 g

Sample Taken On : 9/19/2008 9:45:00 AM
Acquisition Started : 12/16/2008 7:47:05 PM

Live Time : 100000.0 seconds
Real Time : 100005.5 seconds

Dead Time : 0.01 %

 ** N U C L I D E M D A R E P O R T **

Detector Name: HPGE
 Sample Geometry: 500 ml Nalgene
 Sample Title: 2008-11-20-02N_2008Dec16
 Nuclide Library Used: C:\GENIE2K\CAMFILES\Libraries\Soil_DCGL_

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-----------|-------------------|----------------------|-------------------|
| + | Pb x-ray | 72.80 | 61.00 | 1.9771E-008 | 1.70E-008 | -8.6747E-009 |
| | | 75.00* | 100.00 | 1.7035E-008 | | 5.9513E-008 |
| | | 84.90* | 36.00 | 7.6710E-008 | | 3.7817E-008 |
| | | 87.60* | 10.00 | 2.7870E-007 | | 3.0898E-007 |
| | BE-7 | 477.59 | 10.42 | 3.8459E-007 | 3.85E-007 | 6.1627E-008 |
| + | K-40 | 1460.75* | 10.67 | 2.0511E-007 | 2.05E-007 | 1.0819E-005 |
| + | MN-54 | 834.83* | 99.98 | 1.3015E-008 | 1.30E-008 | 1.3105E-008 |
| + | CO-60 | 1173.24* | 99.90 | 2.5642E-008 | 2.34E-008 | 2.5243E-008 |
| | | 1332.50* | 99.98 | 2.3358E-008 | | 3.8339E-008 |
| | ZN-65 | 511.00 | 2.83 | 8.5220E-007 | 6.76E-008 | 5.2298E-006 |
| | | 1115.55 | 50.70 | 6.7579E-008 | | 4.7919E-008 |
| | NB-94x | 702.62 | 97.90 | 1.5128E-008 | 1.51E-008 | -5.2693E-009 |
| | | 871.09 | 99.90 | 1.7004E-008 | | 2.0479E-008 |
| | AG-108m | 79.13 | 6.60 | 1.8821E-007 | 1.41E-008 | -2.1692E-007 |
| | | 433.94 | 90.50 | 1.4120E-008 | | -3.2291E-009 |
| | | 614.28 | 89.80 | 2.7175E-008 | | -3.4055E-009 |
| | | 722.94 | 90.80 | 1.8051E-008 | | 5.5084E-011 |
| + | CD-109 | 88.03* | 3.61 | 8.6664E-007 | 8.67E-007 | 9.6082E-007 |
| | AG-110m | 446.81 | 3.75 | 4.2884E-007 | 1.94E-008 | 2.4598E-007 |
| | | 620.36 | 2.81 | 6.1394E-007 | | -3.2693E-007 |
| | | 657.76 | 94.60 | 1.9351E-008 | | -6.3456E-009 |
| | | 677.62 | 10.35 | 1.7154E-007 | | 1.5469E-008 |
| | | 687.02 | 6.44 | 2.8142E-007 | | -2.5619E-008 |
| | | 706.68 | 16.44 | 1.1544E-007 | | 5.1336E-008 |
| | | 744.28 | 4.73 | 4.3196E-007 | | 3.2756E-007 |
| | | 763.94 | 22.29 | 1.0525E-007 | | -6.7215E-008 |
| | | 818.03 | 7.34 | 2.8249E-007 | | -7.4947E-008 |
| | | 884.68 | 72.70 | 2.9505E-008 | | 3.4660E-008 |
| | | 937.49 | 34.36 | 6.8598E-008 | | 6.5659E-008 |
| | | 1384.30 | 24.28 | 9.5936E-008 | | -1.3727E-008 |
| | | 1475.79 | 3.99 | 4.1688E-007 | | -1.1341E-007 |
| | | 1505.04 | 13.04 | 1.5747E-007 | | -3.8006E-009 |
| | | 1562.30 | 1.03 | 1.5491E-006 | | -4.7912E-008 |
| | SB-125 | 176.33 | 6.79 | 1.7348E-007 | 4.47E-008 | -4.1221E-008 |
| | | 380.43 | 1.52 | 8.6771E-007 | | 4.5805E-007 |
| | | 427.89 | 29.40 | 4.4716E-008 | | -1.3415E-008 |
| | | 463.38 | 10.45 | 1.3349E-007 | | 7.2608E-008 |
| | | 600.56 | 17.78 | 8.2960E-008 | | 1.8588E-008 |
| | | 606.64 | 5.02 | 5.6297E-007 | | -3.1577E-008 |
| | | 635.90 | 11.32 | 1.2756E-007 | | -6.6065E-008 |
| | | 671.41 | 1.80 | 8.4704E-007 | | -8.4606E-007 |
| | BA-133 | 53.16 | 2.20 | 4.1852E-007 | 3.06E-008 | 7.5555E-009 |

| Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|--------------|--------------|-------------|-------------------|----------------------|-------------------|--------------|--------------|
| BA-133 | 79.62 | 2.62 | 4.7747E-007 | 3.06E-008 | -8.0979E-007 | | |
| | 81.00 | 34.10 | 3.1095E-008 | | -6.2254E-008 | | |
| | 160.61 | 0.64 | 1.6661E-006 | | 4.0547E-007 | | |
| | 223.23 | 0.45 | 2.6022E-006 | | -5.3629E-008 | | |
| | 276.40 | 7.16 | 1.6340E-007 | | 6.7523E-008 | | |
| | 302.85 | 18.33 | 6.4449E-008 | | -2.6511E-008 | | |
| | 356.02 | 62.05 | 3.0553E-008 | | -3.2892E-009 | | |
| | 383.85 | 8.94 | 1.4087E-007 | | -7.9324E-008 | | |
| | CS-134 | 475.35 | 1.46 | | 9.3177E-007 | 2.14E-008 | -5.0733E-007 |
| | | 563.23 | 8.38 | | 1.7768E-007 | | 1.0518E-007 |
| 569.32 | | 15.43 | 9.7569E-008 | 5.3462E-008 | | | |
| 604.70 | | 97.60 | 2.3175E-008 | -1.6525E-009 | | | |
| 795.84 | | 85.40 | 2.1356E-008 | 2.0855E-008 | | | |
| 801.93 | | 8.73 | 2.0733E-007 | -2.6268E-008 | | | |
| 1038.57 | | 1.00 | 2.0034E-006 | 1.4765E-007 | | | |
| 1167.94 | | 1.80 | 1.3827E-006 | 4.2514E-007 | | | |
| 1365.15 | | 3.04 | 5.3616E-007 | 7.3781E-008 | | | |
| CS-137 | | 661.66 | 85.21 | 1.7767E-008 | 1.78E-008 | | 1.4619E-008 |
| | 121.78* | 28.40 | 4.6101E-008 | 4.08E-008 | 1.4464E-007 | | |
| + EU-152x | 244.70* | 7.49 | 1.0767E-007 | | 8.3944E-008 | | |
| | 344.28* | 26.60 | 4.0780E-008 | | 1.2562E-007 | | |
| | 411.11* | 2.23 | 5.2569E-007 | | 2.5166E-007 | | |
| | 443.98 | 2.78 | 4.5722E-007 | | -2.5908E-007 | | |
| | 778.90* | 12.96 | 9.8501E-008 | | 1.3014E-007 | | |
| | 867.39 | 4.15 | 4.0891E-007 | | 8.9574E-008 | | |
| | 964.13* | 14.34 | 2.3266E-007 | | 2.9035E-007 | | |
| | 1085.91* | 9.92 | 1.4649E-007 | | 1.8209E-007 | | |
| | 1089.70 | 1.71 | 1.1904E-006 | | 8.3829E-007 | | |
| | 1112.12* | 13.55 | 1.2694E-007 | | 1.3322E-007 | | |
| | 1212.95 | 1.40 | 1.6795E-006 | | -4.2966E-007 | | |
| | 1299.12 | 1.63 | 1.1335E-006 | | 3.2769E-007 | | |
| | 1408.01* | 20.87 | 7.7087E-008 | | 2.5664E-007 | | |
| | EU-154 | 123.07 | 40.40 | 2.6289E-008 | 2.63E-008 | -8.4530E-009 | |
| | | 188.25 | 0.23 | 5.6072E-006 | | -2.2803E-006 | |
| | | 247.93 | 6.83 | 1.6781E-007 | | -3.5039E-008 | |
| | | 401.30 | 0.19 | 6.7091E-006 | | 9.8740E-007 | |
| 444.39 | | 0.55 | 2.3206E-006 | -1.6490E-006 | | | |
| 478.26 | | 0.21 | 6.1364E-006 | 2.3715E-006 | | | |
| 557.56 | | 0.25 | 5.3843E-006 | -5.9162E-006 | | | |
| 582.00 | | 0.89 | 2.2155E-006 | 1.2670E-005 | | | |
| 591.76 | | 4.91 | 2.8105E-007 | -1.7564E-007 | | | |
| 625.22 | | 0.32 | 4.3548E-006 | 8.2460E-007 | | | |
| 676.59 | | 0.14 | 1.0440E-005 | -9.4933E-008 | | | |
| 692.42 | | 1.78 | 8.4264E-007 | 5.2719E-007 | | | |
| 715.76 | | 0.17 | 8.7491E-006 | -3.9570E-006 | | | |
| 722.30 | | 20.00 | 7.9877E-008 | -1.5282E-009 | | | |
| 756.86 | | 4.50 | 3.5858E-007 | -2.1530E-007 | | | |
| 815.55 | | 0.50 | 3.3010E-006 | -7.1129E-007 | | | |
| 845.39 | | 0.58 | 2.8982E-006 | -2.2735E-006 | | | |
| 850.64 | 0.23 | 7.2629E-006 | -1.9087E-006 | | | | |
| 873.20 | 12.09 | 1.4097E-007 | -9.2267E-010 | | | | |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|---|--------------|--------------|-------------|-------------------|----------------------|-------------------|-----------|--------------|
| | EU-154 | 892.73 | 0.50 | 3.4459E-006 | 2.63E-008 | -9.0880E-007 | | |
| | | 904.05 | 0.85 | 2.1205E-006 | | -5.4565E-007 | | |
| | | 996.30 | 10.34 | 1.7581E-007 | | 9.2446E-008 | | |
| | | 1004.76 | 17.90 | 1.0626E-007 | | 9.7160E-009 | | |
| | | 1128.40 | 0.29 | 6.9690E-006 | | 2.4773E-006 | | |
| | | 1140.90 | 0.22 | 9.3566E-006 | | -5.5021E-006 | | |
| | | 1241.60 | 0.13 | 2.0231E-005 | | -7.4913E-006 | | |
| | | 1246.60 | 0.80 | 2.7278E-006 | | -1.0292E-006 | | |
| | | 1274.51 | 34.40 | 5.6790E-008 | | -4.8507E-008 | | |
| | | 1494.08 | 0.71 | 1.9773E-006 | | -4.5929E-007 | | |
| | | 1596.45 | 1.80 | 8.3011E-007 | | -7.6348E-007 | | |
| + | | TL-208B | 72.80 | 2.02 | | 5.9703E-007 | 1.94E-008 | -2.6196E-007 |
| | | | 74.97* | 3.41 | | 4.9956E-007 | | 1.7453E-006 |
| | | | 84.90* | 1.51 | | 1.8288E-006 | | 9.0161E-007 |
| | 277.36 | | 6.31 | 1.8668E-007 | 8.6203E-008 | | | |
| | 510.77* | | 22.60 | 1.2357E-007 | 2.0574E-007 | | | |
| | 583.19* | | 84.50 | 2.2918E-008 | 1.0971E-007 | | | |
| | 763.13 | | 1.81 | 1.0010E-006 | -8.0631E-007 | | | |
| | 860.56* | | 12.42 | 1.4830E-007 | 1.1172E-007 | | | |
| | 2614.53* | | 99.16 | 1.9417E-008 | 1.0530E-007 | | | |
| + | Pb-210 | | 46.52* | 4.05 | 3.1938E-007 | 3.19E-007 | | 5.6445E-007 |
| + | PB-212B | 74.81* | 10.50 | 1.6224E-007 | 4.68E-008 | 5.6679E-007 | | |
| | | 77.11* | 17.60 | 9.6064E-008 | | 5.4901E-007 | | |
| | | 87.30* | 7.90 | 3.5278E-007 | | 3.9112E-007 | | |
| | | 238.63* | 43.60 | 4.6835E-008 | | 3.5217E-007 | | |
| | | 300.09* | 3.34 | 2.5827E-007 | | 4.3141E-007 | | |
| + | BI-214B | 609.31* | 44.80 | 4.8205E-008 | 4.82E-008 | 6.0001E-007 | | |
| | | 665.45 | 1.29 | 1.1884E-006 | | 9.1470E-007 | | |
| | | 768.36* | 4.80 | 4.4949E-007 | | 4.8782E-007 | | |
| | | 806.17* | 1.12 | 1.2558E-006 | | 7.6897E-007 | | |
| | | 934.06* | 3.03 | 5.4109E-007 | | 6.6708E-007 | | |
| | | 1120.29* | 14.80 | 2.3865E-007 | | 6.9791E-007 | | |
| | | 1155.19 | 1.64 | 1.3133E-006 | | -6.4333E-007 | | |
| | | 1238.11* | 5.86 | 4.4230E-007 | | 5.7377E-007 | | |
| | | 1280.96 | 1.44 | 1.4246E-006 | | 7.5732E-007 | | |
| | | 1377.67* | 3.92 | 4.5776E-007 | | 7.7039E-007 | | |
| | | 1401.50* | 1.55 | 8.3668E-007 | | 8.7994E-007 | | |
| | | 1407.98* | 2.80 | 5.7710E-007 | | 1.9213E-006 | | |
| | | 1509.23* | 2.12 | 1.0154E-006 | | 1.2189E-006 | | |
| | | 1661.28 | 1.14 | 1.1431E-006 | | 2.9841E-008 | | |
| | | 1729.59* | 2.88 | 6.1631E-007 | | 9.5715E-007 | | |
| | | 1764.49* | 15.36 | 1.7542E-007 | | 6.8580E-007 | | |
| | | 1847.42* | 2.04 | 5.7644E-007 | | 9.2342E-007 | | |
| | | 2118.55 | 1.14 | 1.1962E-006 | | 7.0094E-007 | | |
| | | 2204.21* | 4.86 | 2.7413E-007 | | 6.8161E-007 | | |
| | 2447.86 | 1.50 | 9.2179E-007 | 2.9824E-007 | | | | |
| + | PB-214B | 53.23* | 1.11 | 7.8030E-007 | 5.00E-008 | 5.1161E-007 | | |
| | | 74.81* | 5.90 | 2.8873E-007 | | 1.0087E-006 | | |
| | | 77.11* | 9.90 | 1.7078E-007 | | 9.7603E-007 | | |
| | | 87.30* | 4.41 | 6.3197E-007 | | 7.0065E-007 | | |
| | | 241.98* | 7.50 | 2.7650E-007 | | 7.5057E-007 | | |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-------------|-------------------|----------------------|-------------------|
| + | PB-214B | 295.21* | 18.50 | 8.2709E-008 | 5.00E-008 | 6.2956E-007 |
| | | 351.92* | 35.80 | 5.0034E-008 | | 6.4621E-007 |
| + | RA-226 | 186.10* | 3.50 | 4.2818E-007 | 4.28E-007 | 8.3083E-007 |
| + | AC-228B | 12.95 | 15.10 | 1.0109E-006 | 6.09E-008 | -2.0875E-006 |
| | | 16.15 | 20.00 | 3.7554E-007 | | 3.9494E-008 |
| | | 19.11 | 4.60 | 9.0977E-007 | | -2.0883E-007 |
| | | 89.96* | 3.40 | 8.0925E-007 | | 5.2632E-007 |
| | | 93.35* | 5.60 | 5.0886E-007 | | 3.8076E-007 |
| | | 99.55 | 1.30 | 7.1038E-007 | | -1.6147E-007 |
| | | 105.36* | 2.00 | 4.4940E-007 | | 2.6570E-007 |
| | | 129.03* | 2.90 | 2.9300E-007 | | 3.0412E-007 |
| | | 209.39* | 4.10 | 2.4257E-007 | | 4.2862E-007 |
| | | 270.26* | 3.80 | 3.4880E-007 | | 6.3227E-007 |
| | | 328.07* | 3.50 | 3.7750E-007 | | 5.3944E-007 |
| | | 338.42* | 12.40 | 1.2303E-007 | | 3.6875E-007 |
| | | 409.62* | 2.20 | 5.4166E-007 | | 4.9087E-007 |
| | | 463.10* | 4.60 | 3.3399E-007 | | 5.3332E-007 |
| | | 562.65* | 1.01 | 1.0648E-006 | | 2.8323E-007 |
| | | 755.28 | 1.32 | 1.2170E-006 | | 5.2264E-007 |
| | | 772.28 | 1.09 | 1.7317E-006 | | -8.5947E-007 |
| | | 794.79* | 4.60 | 4.8564E-007 | | 4.1544E-007 |
| | | 835.60* | 1.71 | 6.3503E-007 | | 6.3941E-007 |
| | | 911.16* | 29.00 | 6.0947E-008 | | 3.2663E-007 |
| | | 964.64* | 5.80 | 5.7777E-007 | | 7.2103E-007 |
| | | 968.97* | 17.40 | 1.9729E-007 | | 3.6263E-007 |
| | | 1459.19 | 1.06 | 6.2360E-006 | | 1.1114E-004 |
| | | 1496.00 | 1.05 | 1.3450E-006 | | 3.8894E-009 |
| | | 1588.23* | 3.60 | 3.1427E-007 | | 3.1969E-007 |
| | | 1630.47 | 1.95 | 6.6328E-007 | | -6.5222E-007 |
| | | PA-234B | 63.00 | 3.20 | | 3.1930E-007 |
| | 94.67 | | 14.30 | 7.4421E-008 | -5.9071E-008 | |
| | 98.44 | | 23.00 | 4.0335E-008 | -3.3875E-008 | |
| | 99.70 | | 4.80 | 1.9264E-007 | -2.0025E-008 | |
| | 111.00 | | 10.80 | 8.7144E-008 | 1.3006E-008 | |
| | 125.40 | | 1.00 | 9.9209E-007 | -1.1251E-006 | |
| | 131.20 | | 20.00 | 4.9283E-008 | 3.1355E-009 | |
| | 152.70 | | 6.70 | 1.6122E-007 | 9.9171E-008 | |
| | 186.00 | | 2.00 | 6.5039E-007 | 3.0795E-006 | |
| | 200.90 | | 1.00 | 1.1711E-006 | -5.7985E-007 | |
| | 202.90 | | 1.20 | 9.7608E-007 | 4.1131E-007 | |
| | 226.40 | | 5.90 | 1.9900E-007 | -3.8803E-008 | |
| | 227.20 | | 5.50 | 2.1435E-007 | -2.0708E-008 | |
| | 248.90 | | 2.80 | 4.0345E-007 | -1.9161E-007 | |
| | 272.10 | | 1.00 | 1.2216E-006 | -2.4644E-007 | |
| | 293.70 | | 3.90 | 4.1064E-007 | -3.6712E-008 | |
| | 369.80 | | 2.90 | 4.2418E-007 | 6.6356E-008 | |
| | 372.40 | 1.30 | 9.4794E-007 | -2.2619E-007 | | |
| | 458.80 | 1.50 | 8.9522E-007 | 1.1678E-007 | | |
| | 506.80 | 1.60 | 1.0811E-006 | -2.5258E-008 | | |
| | 513.70 | 1.30 | 1.4649E-006 | -9.4003E-008 | | |
| | 565.90 | 1.40 | 1.0159E-006 | 2.9432E-007 | | |

| Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|--------------|--------------|-------------|-------------------|----------------------|-------------------|
| PA-234B | 568.70 | 3.30 | 4.2519E-007 | 4.03E-008 | 2.0013E-007 |
| | 569.50 | 10.00 | 1.4117E-007 | | 7.7352E-008 |
| | 574.00 | 2.00 | 7.0874E-007 | | -7.7288E-009 |
| | 664.80 | 1.30 | 1.1788E-006 | | 9.3773E-007 |
| | 666.70 | 1.60 | 9.6063E-007 | | 1.0111E-006 |
| | 669.90 | 1.40 | 1.0680E-006 | | 2.0256E-007 |
| | 692.70 | 1.50 | 1.0047E-006 | | 8.5147E-007 |
| | 699.00 | 4.60 | 3.3092E-007 | | 2.0942E-008 |
| | 706.10 | 3.10 | 4.8836E-007 | | 2.0943E-007 |
| | 733.00 | 9.00 | 1.9137E-007 | | -1.0508E-007 |
| | 738.00 | 1.00 | 1.6096E-006 | | -6.8019E-007 |
| | 742.81 | 2.40 | 6.7675E-007 | | 1.0238E-007 |
| | 755.60 | 1.40 | 1.1497E-006 | | 5.0565E-007 |
| | 780.70 | 1.10 | 1.6728E-006 | | 1.5689E-006 |
| | 786.27 | 1.40 | 1.2676E-006 | | 9.1301E-007 |
| | 793.60 | 1.50 | 1.1498E-006 | | -3.5347E-007 |
| | 796.30 | 3.80 | 4.4995E-007 | | 3.1342E-007 |
| | 805.80 | 3.30 | 5.1877E-007 | | 3.5842E-007 |
| | 819.60 | 2.60 | 6.3198E-007 | | -1.9968E-007 |
| | 826.30 | 4.00 | 4.0872E-007 | | -1.5979E-007 |
| | 831.60 | 5.50 | 3.0206E-007 | | -5.2989E-008 |
| | 876.40 | 4.00 | 4.2382E-007 | | -1.3958E-007 |
| | 880.50 | 4.00 | 4.2285E-007 | | 6.0178E-008 |
| | 880.51 | 9.00 | 1.8793E-007 | | 2.6746E-008 |
| | 883.24 | 15.00 | 1.1120E-007 | | -8.6320E-008 |
| | 899.00 | 4.10 | 4.3127E-007 | | 8.7464E-008 |
| | 925.00 | 2.90 | 5.9652E-007 | | -3.8424E-008 |
| | 926.00 | 11.00 | 1.5680E-007 | | -4.1726E-008 |
| | 927.10 | 11.00 | 1.5482E-007 | | -1.1219E-007 |
| | 946.00 | 12.00 | 1.4904E-007 | | -2.9778E-008 |
| | 949.00 | 8.00 | 2.2381E-007 | | -7.4685E-008 |
| | 978.80 | 1.40 | 1.2364E-006 | | 6.9376E-007 |
| | 980.50 | 2.00 | 8.7779E-007 | | 7.7073E-007 |
| 980.50 | 3.00 | 5.8519E-007 | 5.1382E-007 | | |
| 984.00 | 1.90 | 9.1474E-007 | -7.1859E-007 | | |
| 1353.30 | 1.70 | 9.3560E-007 | -1.6114E-007 | | |
| 1394.10 | 3.00 | 4.9737E-007 | -4.4321E-007 | | |
| 1452.70 | 1.00 | 2.0321E-006 | -4.9964E-007 | | |
| 1668.50 | 1.20 | 1.0436E-006 | -1.7203E-009 | | |
| 1694.60 | 1.20 | 1.0459E-006 | 1.0262E-007 | | |
| + TH-234 | 63.29* | 4.50 | 3.0689E-006 | 3.07E-006 | 3.0594E-006 |
| | 92.38 | 2.60 | 5.4557E-006 | | 2.7366E-005 |
| | 92.80* | 2.60 | 1.3936E-005 | | 1.0428E-005 |
| + U-235 | 72.70 | 0.11 | 1.0782E-005 | 2.61E-008 | -4.7310E-006 |
| | 89.95* | 2.80 | 9.6631E-007 | | 6.2847E-007 |
| | 93.35* | 4.50 | 6.2271E-007 | | 4.6594E-007 |
| | 94.00 | 0.40 | 2.6213E-006 | | -1.3384E-006 |
| | 105.00* | 2.10 | 4.2087E-007 | | 2.4884E-007 |
| | 109.16 | 1.50 | 6.1658E-007 | | 1.8173E-008 |
| | 140.76 | 0.22 | 4.6861E-006 | | -4.9986E-007 |
| | 143.76 | 10.90 | 9.5719E-008 | | 2.1991E-008 |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-----------|-------------------|----------------------|-------------------|
| + | U-235 | 163.33 | 5.00 | 2.1145E-007 | 2.61E-008 | 1.7451E-007 |
| | | 182.61 | 0.40 | 3.0207E-006 | | -1.4635E-006 |
| | | 185.71* | 57.50 | 2.6060E-008 | | 5.0567E-008 |
| | | 194.94 | 0.59 | 1.9468E-006 | | 2.0713E-006 |
| | | 202.11 | 1.00 | 1.1528E-006 | | -6.5152E-008 |
| | | 205.31 | 5.00 | 2.3340E-007 | | -6.6598E-008 |
| | | 279.50 | 0.27 | 4.2900E-006 | | 6.4679E-007 |

+ = Nuclide identified during the nuclide identification

* = Energy line found in the spectrum

> = MDA value not calculated

@ = Half-life too short to be able to perform the decay correction



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Appendix D

Analysis of Concrete Support Wall around Storage Port No. 1

Eberline Analytical

UNIVERSITY OF MICHIGAN

Concrete Material

**STANDARD LEVEL IV
REPORT OF ANALYSIS**

WORK ORDER #10-02134-OR

April 19, 2010

**EBERLINE ANALYTICAL/OAK RIDGE LABORATORY
OAK RIDGE, TN**

| Eberline Analytical Final Report of Analysis | | | Report To: | | | | | | Work Order Details: | | | | | |
|---|-------------|------------------|---|--------------|---------------|----------|-------------|----------------------|---|----------|----------|----------|--------------|--|
| | | | Mark L. Driscoll Univ of MI, Occupational Safety & Env Heal 1239 Kepke Drive Ann Arbor, MI 48109 | | | | | | SDG: 10-02134 Purchase Order: 5000002634 Analysis Category: ENVIRONMENTAL Sample Matrix: SO | | | | | |
| Lab ID | Sample Type | Client ID | Sample Date | Receipt Date | Analysis Date | Batch ID | Analyte | Method | Result | CU | CSU | MDA | Report Units | |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 1.45E+03 | 4.05E+01 | | | pCi/g | |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 1.44E+03 | 1.42E+01 | 1.44E+01 | 5.68E+00 | pCi/g | |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 4.03E+00 | 3.30E+00 | 3.30E+00 | 5.51E+00 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 4.10E-01 | 6.64E-01 | 6.64E-01 | 1.12E+00 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 0.00E+00 | 5.95E-01 | 5.95E-01 | 1.02E+00 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 0.00E+00 | 6.46E-01 | 6.46E-01 | 1.10E+00 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 3.97E-01 | 6.43E-01 | 6.43E-01 | 1.09E+00 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 1.67E+00 | 6.99E-01 | 6.99E-01 | 1.14E+00 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 3.56E+00 | 7.01E-01 | 7.01E-01 | 1.08E+00 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 5.31E+00 | 7.52E-01 | 7.52E-01 | 1.12E+00 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 0.00E+00 | 6.25E-01 | 6.25E-01 | 1.07E+00 | pCi/g | |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-Cl-B Modified | 3.91E+02 | 8.60E+00 | | | pCi/g | |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-Cl-B Modified | 3.90E+02 | 6.29E+00 | 6.29E+00 | 6.54E-01 | pCi/g | |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-Cl-B Modified | 2.81E-01 | 8.54E-02 | 8.54E-02 | 1.18E-01 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-Cl-B Modified | 4.32E-02 | 6.35E-02 | 6.35E-02 | 1.08E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-Cl-B Modified | -8.86E-03 | 5.80E-02 | 5.80E-02 | 1.05E-01 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-Cl-B Modified | -3.25E-02 | 6.24E-02 | 6.24E-02 | 1.16E-01 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-Cl-B Modified | 2.82E-02 | 5.25E-02 | 5.25E-02 | 9.11E-02 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-Cl-B Modified | -2.81E-02 | 5.98E-02 | 5.98E-02 | 1.11E-01 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-Cl-B Modified | 2.67E-02 | 5.58E-02 | 5.58E-02 | 9.71E-02 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-Cl-B Modified | 2.40E-02 | 5.92E-02 | 5.92E-02 | 1.03E-01 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-Cl-B Modified | 2.00E-02 | 6.38E-02 | 6.38E-02 | 1.17E-01 | pCi/g | |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 3.50E+02 | 1.26E+01 | | | pCi/g | |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 3.24E+02 | 4.24E+00 | 3.62E+01 | 2.06E+00 | pCi/g | |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.58E+00 | 1.24E+00 | 1.25E+00 | 2.06E+00 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.88E+00 | 1.31E+00 | 1.32E+00 | 2.18E+00 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.85E+00 | 1.29E+00 | 1.30E+00 | 2.14E+00 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.64E+00 | 1.28E+00 | 1.29E+00 | 2.13E+00 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.57E+00 | 1.23E+00 | 1.24E+00 | 2.04E+00 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.67E+00 | 1.30E+00 | 1.32E+00 | 2.17E+00 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.67E+00 | 1.31E+00 | 1.32E+00 | 2.17E+00 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.70E+00 | 1.33E+00 | 1.34E+00 | 2.21E+00 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 0.00E+00 | 1.23E+00 | 1.23E+00 | 2.11E+00 | pCi/g | |

CU=Counting Uncertainty; CSU=Combined Standard Uncertainty (2-sigma); MDA=Minimal Detected Activity; LCS=Laboratory Control Sample; MBL=Blank; DUP=Duplicate; TRG=Normal Sample; DO=Duplicate Original

03
13
12



EBERLINE ANALYTICAL CORPORATION

601 SCARBORO ROAD OAK RIDGE, TN 37830 865/481-0683 FAX 865/483-4621

| Eberline Analytical Final Report of Analysis | | | Report To: | | | | | Work Order Details: | | | | | |
|---|-------------|------------------|---|--------------|---------------|----------|---------------|----------------------|---------------|----------|----------|----------|--------------|
| | | | Mark L. Driscoll Univ of MI, Occupational Safety & Env Health 1239 Kepke Drive Ann Arbor, MI 48109 | | | | | SDG: | 10-02134 | | | | |
| | | | | | | | | Purchase Order: | 5000002634 | | | | |
| | | | | | | | | Analysis Category: | ENVIRONMENTAL | | | | |
| | | | | | | | | Sample Matrix: | SO | | | | |
| Lab ID | Sample Type | Client ID | Sample Date | Receipt Date | Analysis Date | Batch ID | Analyte | Method | Result | CU | CSU | MDA | Report Units |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Americium-241 | LANL ER-130 Modified | 3.66E+03 | 1.14E+02 | | | pCi/g |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Cobalt-57 | LANL ER-130 Modified | 1.14E+03 | 3.42E+01 | | | pCi/g |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Americium-241 | LANL ER-130 Modified | 3.59E+03 | 3.03E+02 | 3.03E+02 | 5.09E+00 | pCi/g |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Cobalt-57 | LANL ER-130 Modified | 1.23E+03 | 1.98E+02 | 1.98E+02 | 4.11E+00 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | -1.45E+00 | 6.43E+00 | 6.43E+00 | 1.07E+01 | pCi/g |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | -6.74E+00 | 1.10E+01 | 1.10E+01 | 1.11E+01 | pCi/g |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | 1.48E+00 | 6.62E+00 | 6.62E+00 | 1.14E+01 | pCi/g |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | -6.82E+00 | 1.12E+01 | 1.12E+01 | 1.05E+01 | pCi/g |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | 2.27E+00 | 5.08E+00 | 5.08E+00 | 7.72E+00 | pCi/g |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | 2.74E+00 | 5.64E+00 | 5.64E+00 | 8.17E+00 | pCi/g |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | -5.07E+00 | 9.54E+00 | 9.54E+00 | 1.17E+01 | pCi/g |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | 4.61E+00 | 8.08E+00 | 8.08E+00 | 1.04E+01 | pCi/g |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | -6.66E+00 | 1.02E+01 | 1.02E+01 | 9.03E+00 | pCi/g |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 1.34E+02 | 3.81E+00 | | | pCi/g |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | 8.08E+01 | 2.26E+00 | | | pCi/g |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 1.39E+02 | 1.08E+01 | 1.08E+01 | 7.52E-01 | pCi/g |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | 8.50E+01 | 8.03E+00 | 8.03E+00 | 6.77E-01 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | -9.39E-03 | 1.46E-02 | 1.46E-02 | 2.28E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | 9.54E-03 | 1.60E-02 | 1.60E-02 | 3.25E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 1.05E-02 | 1.81E-02 | 1.81E-02 | 3.58E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 3.08E-03 | 1.34E-02 | 1.34E-02 | 2.86E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | -2.25E-03 | 1.54E-02 | 1.54E-02 | 2.53E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | -3.45E-03 | 1.77E-02 | 1.77E-02 | 3.26E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 8.88E-02 | 9.91E-02 | 9.91E-02 | 2.46E-01 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 4.03E-02 | 4.83E-02 | 4.83E-02 | 1.06E-01 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 1.43E-02 | 2.80E-02 | 2.80E-02 | 4.92E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | 1.75E-03 | 1.32E-02 | 1.32E-02 | 2.63E-02 | pCi/g |

CU=Counting Uncertainty;CSU=Combined Standard Uncertainty (2-sigma);MDA=Minimal Detected Activity;LCS=Laboratory Control Sample; MBL=Blank; DUP=Duplicate; TRG=Normal Sample; DO=Duplicate Original



EBERLINE ANALYTICAL CORPORATION

601 SCARBORO ROAD OAK F... TN 37830 865/481-0683 FAX 865/483-4621

| Eberline Analytical Final Report of Analysis | | | Report To: | | | | | Work Order Details: | | | | | | |
|---|-------------|------------------|---|--------------|---------------|----------|--------------|----------------------|---------------|----------|----------|----------|--------------|--|
| | | | Mark L. Driscoll Univ of MI, Occupational Safety & Env Health 1239 Kepke Drive Ann Arbor, MI 48109 | | | | | SDG: | 10-02134 | | | | | |
| | | | | | | | | Purchase Order: | 5000002634 | | | | | |
| | | | | | | | | Analysis Category: | ENVIRONMENTAL | | | | | |
| | | | | | | | | Sample Matrix: | SO | | | | | |
| Lab ID | Sample Type | Client ID | Sample Date | Receipt Date | Analysis Date | Batch ID | Analyte | Method | Result | CU | CSU | MDA | Report Units | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | 2.81E-04 | 4.70E-02 | 4.70E-02 | 8.39E-02 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | 7.75E-02 | 1.15E-01 | 1.15E-01 | 2.10E-01 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 2.46E-02 | 5.98E-02 | 5.98E-02 | 9.94E-02 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 3.00E-01 | 7.99E-02 | 7.99E-02 | 1.18E-01 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | -7.18E-03 | 6.34E-02 | 6.34E-02 | 9.98E-02 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | 2.71E-02 | 4.74E-02 | 4.74E-02 | 8.95E-02 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 1.49E+00 | 6.15E-01 | 6.15E-01 | 1.13E+00 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 1.12E-01 | 1.42E-01 | 1.42E-01 | 2.84E-01 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 2.71E-01 | 1.37E-01 | 1.37E-01 | 2.08E-01 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | -1.94E-03 | 9.94E-02 | 9.94E-02 | 1.77E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | 1.32E-02 | 5.55E-02 | 5.55E-02 | 9.07E-02 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | -3.77E-02 | 1.13E-01 | 1.13E-01 | 1.96E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 6.89E-02 | 5.83E-02 | 5.83E-02 | 1.02E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 2.75E-01 | 6.71E-02 | 6.71E-02 | 9.66E-02 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | 9.35E-03 | 6.48E-02 | 6.48E-02 | 1.05E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | -6.31E-03 | 4.54E-02 | 4.54E-02 | 8.07E-02 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 1.73E+00 | 3.41E-01 | 3.41E-01 | 3.94E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 7.48E-02 | 1.51E-01 | 1.51E-01 | 2.88E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 3.23E-01 | 1.38E-01 | 1.38E-01 | 2.09E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | -6.45E-02 | 1.05E-01 | 1.05E-01 | 1.74E-01 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | 1.28E-02 | 4.08E-02 | 4.08E-02 | 6.94E-02 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | -1.76E-02 | 7.96E-02 | 7.96E-02 | 1.44E-01 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | -3.55E-02 | 5.39E-02 | 5.39E-02 | 7.56E-02 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 8.90E-02 | 4.67E-02 | 4.67E-02 | 8.18E-02 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | 3.59E-02 | 3.36E-02 | 3.36E-02 | 8.61E-02 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | -1.53E-02 | 3.55E-02 | 3.55E-02 | 6.30E-02 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 4.94E-01 | 3.76E-01 | 3.76E-01 | 6.03E-01 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 4.89E-02 | 1.12E-01 | 1.12E-01 | 2.18E-01 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 8.28E-02 | 1.25E-01 | 1.25E-01 | 1.76E-01 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | 2.33E-02 | 7.58E-02 | 7.58E-02 | 1.43E-01 | pCi/g | |

CU=Counting Uncertainty;CSU=Combined Standard Uncertainty (2-sigma);MDA=Minimal Detected Activity;LCS=Laboratory Control Sample; MBL=Blank; DUP=Duplicate; TRG=Normal Sample; DO=Duplicate Original

5025



EBERLINE ANALYTICAL CORPORATION

601 SCARBORO ROAD OAK RIDGE, TN 37830 865/481-0683 FAX 865/483-4621

| Eberline Analytical Final Report of Analysis | | | Report To: | | | | | Work Order Details: | | | | | | |
|---|-------------|------------------|---|--------------|---------------|----------|--------------|----------------------|----------------------------|----------------------------------|----------|-------------------|--------------|--|
| | | | Mark L. Driscoll Univ of MI, Occupational Safety & Env Health 1239 Kepke Drive Ann Arbor, MI 48109 | | | | | SDG: 10-02134 | Purchase Order: 5000002634 | Analysis Category: ENVIRONMENTAL | | Sample Matrix: SO | | |
| Lab ID | Sample Type | Client ID | Sample Date | Receipt Date | Analysis Date | Batch ID | Analyte | Method | Result | CU | CSU | MDA | Report Units | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | 1.17E-02 | 2.33E-02 | 2.33E-02 | 4.64E-02 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | -3.76E-02 | 4.23E-02 | 4.23E-02 | 6.80E-02 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 5.82E-02 | 3.06E-02 | 3.06E-02 | 6.01E-02 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 4.05E-02 | 2.22E-02 | 2.22E-02 | 5.00E-02 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | -4.30E-04 | 3.24E-02 | 3.24E-02 | 5.28E-02 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | 5.68E-03 | 2.21E-02 | 2.21E-02 | 4.24E-02 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 2.49E-02 | 1.58E-01 | 1.58E-01 | 3.16E-01 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 1.31E-02 | 4.70E-02 | 4.70E-02 | 1.04E-01 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | -2.76E-02 | 4.57E-02 | 4.57E-02 | 6.55E-02 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | 6.45E-03 | 3.73E-02 | 3.73E-02 | 7.17E-02 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | 3.04E-01 | 4.45E-02 | 4.45E-02 | 7.69E-02 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | 1.76E-03 | 6.67E-02 | 6.67E-02 | 1.24E-01 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 6.06E-01 | 1.07E-01 | 1.07E-01 | 8.59E-02 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 5.51E-01 | 8.02E-02 | 8.02E-02 | 5.98E-02 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | 7.58E-03 | 4.75E-02 | 4.75E-02 | 7.97E-02 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | -2.32E-02 | 3.75E-02 | 3.75E-02 | 6.53E-02 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 2.24E-01 | 2.83E-01 | 2.83E-01 | 5.49E-01 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | -6.17E-02 | 1.16E-01 | 1.16E-01 | 1.96E-01 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 1.26E-01 | 1.07E-01 | 1.07E-01 | 1.44E-01 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | -3.33E-02 | 7.11E-02 | 7.11E-02 | 1.23E-01 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | 1.35E-01 | 5.13E-02 | 5.13E-02 | 1.12E-01 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | 3.74E-02 | 1.15E-01 | 1.15E-01 | 1.94E-01 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 4.79E-02 | 7.47E-02 | 7.47E-02 | 1.27E-01 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 4.31E-01 | 1.04E-01 | 1.04E-01 | 1.40E-01 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | -3.52E-02 | 8.00E-02 | 8.00E-02 | 1.21E-01 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | 2.41E-01 | 1.17E-01 | 1.17E-01 | 1.07E-01 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 7.59E-01 | 4.04E-01 | 4.04E-01 | 9.14E-01 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 2.27E-01 | 2.67E-01 | 2.67E-01 | 3.55E-01 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 1.05E-01 | 1.59E-01 | 1.59E-01 | 2.45E-01 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | 3.67E-02 | 1.04E-01 | 1.04E-01 | 1.92E-01 | pCi/g | |

ADU

CU=Counting Uncertainty; CSU=Combined Standard Uncertainty (2-sigma); MDA=Minimal Detected Activity; LCS=Laboratory Control Sample; MBL=Blank; DUP=Duplicate; TRG=Normal Sample; DO=Duplicate Original

EBC
INC
CT



EBERLINE ANALYTICAL CORPORATION

601 SCARBORO ROAD OAK RIDGE, TN 37830 865/481-0683 FAX 865/483-4621

| Eberline Analytical Final Report of Analysis | | | Report To: | | | | | Work Order Details: | | | | | |
|---|-------------|------------------|--|--------------|---------------|----------|--------------|----------------------|---------------------------|----------|----------|----------------------------------|--------------|
| | | | Mark L. Driscoll Univ of MI, Occupational Safety & Env Hea 1239 Kepke Drive Ann Arbor, MI 48109 | | | | | SDG: 10-02134 | Purchase Order: 500002634 | | | Analysis Category: ENVIRONMENTAL | |
| Lab ID | Sample Type | Client ID | Sample Date | Receipt Date | Analysis Date | Batch ID | Analyte | Method | Result | CU | CSU | MDA | Report Units |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Silver-106m | LANL ER-130 Modified | 3.58E-01 | 6.57E-02 | 6.57E-02 | 1.32E-01 | pCi/g |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | 2.02E-01 | 1.52E-01 | 1.52E-01 | 2.67E-01 | pCi/g |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 1.83E-02 | 9.37E-02 | 9.37E-02 | 1.43E-01 | pCi/g |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 4.21E+00 | 3.62E-01 | 3.62E-01 | 1.31E-01 | pCi/g |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | 7.26E-02 | 4.03E-02 | 4.03E-02 | 1.31E-01 | pCi/g |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | 1.77E+00 | 3.08E-01 | 3.08E-01 | 1.17E-01 | pCi/g |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 3.52E-01 | 3.64E-01 | 3.64E-01 | 7.19E-01 | pCi/g |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 6.88E-02 | 1.84E-01 | 1.84E-01 | 3.45E-01 | pCi/g |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 1.80E-01 | 1.76E-01 | 1.76E-01 | 2.87E-01 | pCi/g |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | 3.65E-03 | 1.35E-01 | 1.35E-01 | 2.38E-01 | pCi/g |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Silver-106m | LANL ER-130 Modified | -1.49E-02 | 4.39E-02 | 4.39E-02 | 7.69E-02 | pCi/g |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | -3.03E-02 | 3.89E-02 | 3.89E-02 | 6.49E-02 | pCi/g |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | -6.26E-03 | 5.88E-02 | 5.88E-02 | 9.42E-02 | pCi/g |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | -2.42E-02 | 4.78E-02 | 4.78E-02 | 8.14E-02 | pCi/g |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | -3.16E-02 | 4.67E-02 | 4.67E-02 | 6.92E-02 | pCi/g |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | -5.83E-03 | 4.03E-02 | 4.03E-02 | 7.27E-02 | pCi/g |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 1.80E-01 | 2.59E-01 | 2.59E-01 | 5.37E-01 | pCi/g |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | -1.98E-02 | 1.23E-01 | 1.23E-01 | 2.22E-01 | pCi/g |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 4.15E-02 | 1.46E-01 | 1.46E-01 | 1.91E-01 | pCi/g |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | -1.18E-02 | 4.69E-02 | 4.69E-02 | 8.26E-02 | pCi/g |

CU=Counting Uncertainty;CSU=Combined Standard Uncertainty (2-sigma);MDA=Minimal Detected Activity;LCS=Laboratory Control Sample; MBL=Blank; DUP=Duplicate; TRG=Normal Sample; DO=Duplicate Original



EBERLINE ANALYTICAL CORPORATION

601 SCARBORO ROAD OAK RIDGE, TN 37830 865/481-0683 FAX 865/483-4621

UNIVERSITY OF MICHIGAN

Concrete Material

**STANDARD LEVEL IV
REPORT OF ANALYSIS**

WORK ORDER #10-02134-OR

April 19, 2010

**EBERLINE ANALYTICAL/OAK RIDGE LABORATORY
OAK RIDGE, TN**

| Eberline Analytical Final Report of Analysis | | | Report To | | | | | Work Order Details | | | | | | |
|---|-------------|------------------|---|--------------|---------------|----------|-------------|----------------------|----------------------------|----------------------------------|----------|----------|--------------|-------------------|
| | | | Mark L. Driscoll Univ of MI, Occupational Safety & Env Health 1239 Kepke Drive Ann Arbor, MI 48109 | | | | | SDG: 10-02134 | Purchase Order: 5000002634 | Analysis Category: ENVIRONMENTAL | | | | Sample Matrix: SO |
| Lab ID | Sample Type | Client ID | Sample Date | Receipt Date | Analysis Date | Batch ID | Analyte | Method | Result | CU | CSU | MDA | Report Units | |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 1.45E+03 | 4.05E+01 | | | pCi/g | |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 1.44E+03 | 1.42E+01 | 1.44E+01 | 5.66E+00 | pCi/g | |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 4.03E+00 | 3.30E+00 | 3.30E+00 | 5.51E+00 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 4.10E-01 | 6.64E-01 | 6.64E-01 | 1.12E+00 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 0.00E+00 | 5.95E-01 | 5.95E-01 | 1.02E+00 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 0.00E+00 | 6.46E-01 | 6.46E-01 | 1.10E+00 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 3.97E-01 | 6.43E-01 | 6.43E-01 | 1.09E+00 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 1.67E+00 | 6.99E-01 | 6.99E-01 | 1.14E+00 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 3.56E+00 | 7.01E-01 | 7.01E-01 | 1.08E+00 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 5.31E+00 | 7.52E-01 | 7.52E-01 | 1.12E+00 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/18/2010 | 10-02134 | Carbon-14 | EPA 520.0 Modified | 0.00E+00 | 6.25E-01 | 6.25E-01 | 1.07E+00 | pCi/g | |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-CI-B Modified | 3.91E+02 | 8.60E+00 | | | pCi/g | |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-CI-B Modified | 3.90E+02 | 6.29E+00 | 6.29E+00 | 6.54E-01 | pCi/g | |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-CI-B Modified | 2.81E-01 | 8.54E-02 | 8.54E-02 | 1.18E-01 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-CI-B Modified | 4.32E-02 | 6.35E-02 | 6.35E-02 | 1.08E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-CI-B Modified | -6.86E-03 | 5.80E-02 | 5.80E-02 | 1.05E-01 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-CI-B Modified | -3.25E-02 | 6.24E-02 | 6.24E-02 | 1.16E-01 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-CI-B Modified | 2.82E-02 | 5.25E-02 | 5.25E-02 | 9.11E-02 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-CI-B Modified | -2.81E-02 | 5.98E-02 | 5.98E-02 | 1.11E-01 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-CI-B Modified | 2.67E-02 | 5.58E-02 | 5.58E-02 | 9.71E-02 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-CI-B Modified | 2.40E-02 | 5.92E-02 | 5.92E-02 | 1.03E-01 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Chlorine-36 | 4500-CI-B Modified | -2.00E-02 | 6.38E-02 | 6.38E-02 | 1.17E-01 | pCi/g | |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 3.50E+02 | 1.26E+01 | | | pCi/g | |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 3.24E+02 | 4.24E+00 | 3.62E+01 | 2.06E+00 | pCi/g | |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.58E+00 | 1.24E+00 | 1.25E+00 | 2.06E+00 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.68E+00 | 1.31E+00 | 1.32E+00 | 2.18E+00 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.65E+00 | 1.29E+00 | 1.30E+00 | 2.14E+00 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.64E+00 | 1.28E+00 | 1.29E+00 | 2.13E+00 | pCi/g | |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.57E+00 | 1.23E+00 | 1.24E+00 | 2.04E+00 | pCi/g | |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.67E+00 | 1.30E+00 | 1.32E+00 | 2.17E+00 | pCi/g | |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.67E+00 | 1.31E+00 | 1.32E+00 | 2.17E+00 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 1.70E+00 | 1.33E+00 | 1.34E+00 | 2.21E+00 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/19/2010 | 10-02134 | Tritium | LANL ER-210 Modified | 0.00E+00 | 1.23E+00 | 1.23E+00 | 2.11E+00 | pCi/g | |

CU=Counting Uncertainty;CSU=Combined Standard Uncertainty (2-sigma);MDA=Minimal Detected Activity;LCS=Laboratory Control Sample; MBL=Blank; DUP=Duplicate; TRG=Normal Sample; DO=Duplicate Original

0022



EBERLINE ANALYTICAL CORPORATION

601 SCARBORO ROAD OAK RIDGE, TN 37830 865/481-0683 FAX 865/483-4621

| Eberline Analytical Final Report of Analysis | | | Report To: | | | | | Work Order Details: | | | | | |
|---|-------------|------------------|--|--------------|---------------|----------|---------------|----------------------|----------------------------|----------|----------|----------------------------------|--------------|
| | | | Mark L. Driscoll Univ of MI, Occupational Safety & Env Hea 1239 Kepke Drive Ann Arbor, MI 48109 | | | | | SDG: 10-02134 | Purchase Order: 5000002634 | | | Analysis Category: ENVIRONMENTAL | |
| Lab ID | Sample Type | Client ID | Sample Date | Receipt Date | Analysis Date | Batch ID | Analyte | Method | Result | CU | CSU | MDA | Report Units |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Americium-241 | LANL ER-130 Modified | 3.66E+03 | 1.14E+02 | | | pCi/g |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Cobalt-57 | LANL ER-130 Modified | 1.14E+03 | 3.42E+01 | | | pCi/g |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Americium-241 | LANL ER-130 Modified | 3.59E+03 | 3.03E+02 | 3.03E+02 | 5.09E+00 | pCi/g |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Cobalt-57 | LANL ER-130 Modified | 1.23E+03 | 1.98E+02 | 1.98E+02 | 4.11E+00 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | -1.45E+00 | 6.43E+00 | 6.43E+00 | 1.07E+01 | pCi/g |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | -6.74E+00 | 1.10E+01 | 1.10E+01 | 1.11E+01 | pCi/g |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | 1.48E+00 | 6.62E+00 | 6.62E+00 | 1.14E+01 | pCi/g |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | -8.82E+00 | 1.12E+01 | 1.12E+01 | 1.05E+01 | pCi/g |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | 2.27E+00 | 5.08E+00 | 5.08E+00 | 7.72E+00 | pCi/g |
| 10-02134-07 | TRG | UM-2009-08-10-01 | 08/22/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | 2.74E+00 | 5.64E+00 | 5.64E+00 | 8.17E+00 | pCi/g |
| 10-02134-08 | TRG | UM-2009-08-12-01 | 08/24/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | -5.07E+00 | 9.54E+00 | 9.54E+00 | 1.17E+01 | pCi/g |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | 4.61E+00 | 8.08E+00 | 8.08E+00 | 1.04E+01 | pCi/g |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/15/2010 | 10-02134 | Iron-55 | LANL ER-130 Modified | -6.66E+00 | 1.02E+01 | 1.02E+01 | 9.03E+00 | pCi/g |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 1.34E+02 | 3.81E+00 | | | pCi/g |
| 10-02134-01 | LCS | KNOWN | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | 8.08E+01 | 2.26E+00 | | | pCi/g |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 1.39E+02 | 1.08E+01 | 1.08E+01 | 7.52E-01 | pCi/g |
| 10-02134-01 | LCS | SPIKE | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | 8.50E+01 | 8.03E+00 | 8.03E+00 | 6.77E-01 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | -9.39E-03 | 1.46E-02 | 1.46E-02 | 2.28E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | 9.54E-03 | 1.60E-02 | 1.60E-02 | 3.25E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 1.05E-02 | 1.81E-02 | 1.81E-02 | 3.58E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 3.08E-03 | 1.34E-02 | 1.34E-02 | 2.86E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | -2.25E-03 | 1.54E-02 | 1.54E-02 | 2.53E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | -3.45E-03 | 1.77E-02 | 1.77E-02 | 3.26E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 8.88E-02 | 9.91E-02 | 9.91E-02 | 2.46E-01 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 4.03E-02 | 4.83E-02 | 4.83E-02 | 1.06E-01 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 1.43E-02 | 2.80E-02 | 2.80E-02 | 4.92E-02 | pCi/g |
| 10-02134-02 | MBL | BLANK | 02/24/10 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | 1.75E-03 | 1.32E-02 | 1.32E-02 | 2.63E-02 | pCi/g |

COPY

CU=Counting Uncertainty;CSU=Combined Standard Uncertainty (2-sigma);MDA=Minimal Detected Activity;LCS=Laboratory Control Sample; MBL=Blank; DUP=Duplicate; TRG=Normal Sample; DO=Duplicate Original



EBERLINE
SERVICES

EBERLINE ANALYTICAL CORPORATION

601 SCARBORO ROAD OAK RIDGE, TN 37830 865/481-0683 Fax 865/483-4621

| Eberline Analytical Final Report of Analysis | | | Report To: | | | | | Work Order Details: | | | | | | |
|---|-------------|------------------|---|--------------|---------------|----------|--------------|----------------------|---------------|----------|----------|----------|--------------|--|
| | | | Mark L. Driscoll Univ of MI, Occupational Safety & Env Health 1239 Kepke Drive Ann Arbor, MI 48109 | | | | | SDG: | 10-02134 | | | | | |
| | | | | | | | | Purchase Order: | 5000002634 | | | | | |
| | | | | | | | | Analysis Category: | ENVIRONMENTAL | | | | | |
| | | | | | | | | Sample Matrix: | SO | | | | | |
| Lab ID | Sample Type | Client ID | Sample Date | Receipt Date | Analysis Date | Batch ID | Analyte | Method | Result | CU | CSU | MDA | Report Units | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | 2.81E-04 | 4.70E-02 | 4.70E-02 | 8.39E-02 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | 7.75E-02 | 1.15E-01 | 1.15E-01 | 2.19E-01 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 2.46E-02 | 5.98E-02 | 5.98E-02 | 9.94E-02 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 3.00E-01 | 7.99E-02 | 7.99E-02 | 1.18E-01 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | -7.18E-03 | 6.34E-02 | 6.34E-02 | 9.98E-02 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | 2.71E-02 | 4.74E-02 | 4.74E-02 | 8.95E-02 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 1.49E+00 | 6.15E-01 | 6.15E-01 | 1.13E+00 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 1.12E-01 | 1.42E-01 | 1.42E-01 | 2.84E-01 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 2.71E-01 | 1.37E-01 | 1.37E-01 | 2.08E-01 | pCi/g | |
| 10-02134-03 | DUP | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | -1.94E-03 | 9.94E-02 | 9.94E-02 | 1.77E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | 1.32E-02 | 5.55E-02 | 5.55E-02 | 9.07E-02 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | -3.77E-02 | 1.13E-01 | 1.13E-01 | 1.96E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 6.89E-02 | 5.83E-02 | 5.83E-02 | 1.02E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 2.75E-01 | 6.71E-02 | 6.71E-02 | 9.66E-02 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | 9.35E-03 | 6.48E-02 | 6.48E-02 | 1.05E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | -6.31E-03 | 4.54E-02 | 4.54E-02 | 8.07E-02 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 1.73E+00 | 3.41E-01 | 3.41E-01 | 3.94E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 7.48E-02 | 1.51E-01 | 1.51E-01 | 2.88E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 3.23E-01 | 1.38E-01 | 1.38E-01 | 2.09E-01 | pCi/g | |
| 10-02134-04 | DO | UM-2009-02-26-01 | 02/26/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | -6.45E-02 | 1.05E-01 | 1.05E-01 | 1.74E-01 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | 1.28E-02 | 4.08E-02 | 4.08E-02 | 8.94E-02 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | -1.76E-02 | 7.96E-02 | 7.96E-02 | 1.44E-01 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | -3.55E-02 | 5.39E-02 | 5.39E-02 | 7.56E-02 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 8.90E-02 | 4.67E-02 | 4.67E-02 | 8.18E-02 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | 3.59E-02 | 3.36E-02 | 3.36E-02 | 8.61E-02 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | -1.53E-02 | 3.55E-02 | 3.55E-02 | 6.30E-02 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 4.94E-01 | 3.76E-01 | 3.76E-01 | 6.03E-01 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 4.89E-02 | 1.12E-01 | 1.12E-01 | 2.18E-01 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 8.28E-02 | 1.25E-01 | 1.25E-01 | 1.76E-01 | pCi/g | |
| 10-02134-05 | TRG | UM-2009-03-04-01 | 03/06/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | 2.33E-02 | 7.58E-02 | 7.58E-02 | 1.43E-01 | pCi/g | |

CU=Counting Uncertainty;CSU=Combined Standard Uncertainty (2-sigma);MDA=Minimal Detected Activity;LCS=Laboratory Control Sample; MBL=Blank; DUP=Duplicate; TRG=Normal Sample; DO=Duplicate Original



EBERLINE ANALYTICAL CORPORATION

601 SCARBORO ROAD OAK RIDGE, TN 37830 865/481-0683 FAX 865/483-4621

| Eberline Analytical Final Report of Analysis | | | Report To: | | | | | Work Order Details: | | | | | |
|---|-------------|------------------|---|--------------|---------------|----------|--------------|----------------------|---------------|----------|----------|----------|--------------|
| | | | Mark L. Driscoll Univ of MI, Occupational Safety & Env Health 1239 Kepke Drive Ann Arbor, MI 48109 | | | | | SDG: | 10-02134 | | | | |
| | | | | | | | | Purchase Order: | 5000002634 | | | | |
| | | | | | | | | Analysis Category: | ENVIRONMENTAL | | | | |
| | | | | | | | | Sample Matrix: | SO | | | | |
| Lab ID | Sample Type | Client ID | Sample Date | Receipt Date | Analysis Date | Batch ID | Analyte | Method | Result | CU | CSU | MDA | Report Units |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | 1.17E-02 | 2.33E-02 | 2.33E-02 | 4.64E-02 | pCi/g |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | -3.76E-02 | 4.23E-02 | 4.23E-02 | 6.80E-02 | pCi/g |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 5.82E-02 | 3.06E-02 | 3.06E-02 | 6.01E-02 | pCi/g |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 4.05E-02 | 2.22E-02 | 2.22E-02 | 5.00E-02 | pCi/g |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | -4.30E-04 | 3.24E-02 | 3.24E-02 | 5.28E-02 | pCi/g |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | 5.68E-03 | 2.21E-02 | 2.21E-02 | 4.24E-02 | pCi/g |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 2.49E-02 | 1.58E-01 | 1.58E-01 | 3.16E-01 | pCi/g |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 1.31E-02 | 4.70E-02 | 4.70E-02 | 1.04E-01 | pCi/g |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | -2.76E-02 | 4.57E-02 | 4.57E-02 | 6.55E-02 | pCi/g |
| 10-02134-06 | TRG | UM-2009-06-08-01 | 06/29/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | 6.45E-03 | 3.73E-02 | 3.73E-02 | 7.17E-02 | pCi/g |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | 3.04E-01 | 4.45E-02 | 4.45E-02 | 7.69E-02 | pCi/g |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | 1.76E-03 | 6.67E-02 | 6.67E-02 | 1.24E-01 | pCi/g |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 8.06E-01 | 1.07E-01 | 1.07E-01 | 8.59E-02 | pCi/g |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 5.51E-01 | 8.02E-02 | 8.02E-02 | 5.98E-02 | pCi/g |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | 7.58E-03 | 4.75E-02 | 4.75E-02 | 7.97E-02 | pCi/g |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | -2.32E-02 | 3.75E-02 | 3.75E-02 | 6.53E-02 | pCi/g |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 2.24E-01 | 2.83E-01 | 2.83E-01 | 5.49E-01 | pCi/g |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | -6.17E-02 | 1.16E-01 | 1.16E-01 | 1.96E-01 | pCi/g |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 1.26E-01 | 1.07E-01 | 1.07E-01 | 1.44E-01 | pCi/g |
| 10-02134-07 | TRG | UM-2009-06-10-01 | 06/22/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | -3.33E-02 | 7.11E-02 | 7.11E-02 | 1.23E-01 | pCi/g |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | 1.35E-01 | 5.13E-02 | 5.13E-02 | 1.12E-01 | pCi/g |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | 3.74E-02 | 1.15E-01 | 1.15E-01 | 1.94E-01 | pCi/g |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 4.79E-02 | 7.47E-02 | 7.47E-02 | 1.27E-01 | pCi/g |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 4.31E-01 | 1.04E-01 | 1.04E-01 | 1.40E-01 | pCi/g |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | -3.52E-02 | 8.00E-02 | 8.00E-02 | 1.21E-01 | pCi/g |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | 2.41E-01 | 1.17E-01 | 1.17E-01 | 1.07E-01 | pCi/g |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 7.59E-01 | 4.04E-01 | 4.04E-01 | 9.14E-01 | pCi/g |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 2.27E-01 | 2.67E-01 | 2.67E-01 | 3.55E-01 | pCi/g |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 1.05E-01 | 1.59E-01 | 1.59E-01 | 2.45E-01 | pCi/g |
| 10-02134-08 | TRG | UM-2009-06-12-01 | 06/24/09 00:00 | 2/24/2010 | 3/4/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | 3.67E-02 | 1.04E-01 | 1.04E-01 | 1.92E-01 | pCi/g |

CU=Counting Uncertainty;CSU=Combined Standard Uncertainty (2-sigma);MDA=Minimal Detected Activity;LCS=Laboratory Control Sample; MBL=Blank; DUP=Duplicate; TRG=Normal Sample; DO=Duplicate Original

000000



EBERLINE
SERVICES

EBERLINE ANALYTICAL CORPORATION

601 SCARBORO ROAD OAK RIDGE, TN 37830 865/481-0683 Fax 865/483-4621

| Eberline Analytical Final Report of Analysis | | | Report To: | | | | | Work Order Details: | | | | | | |
|---|-------------|------------------|---|--------------|---------------|----------|--------------|--|-----------|----------|----------|----------|--------------|--|
| | | | Mark L. Driscoll Univ of MI, Occupational Safety & Env Health 1239 Kepke Drive Ann Arbor, MI 48109 | | | | | SDG: 10-02134 Purchase Order: 5000002634 Analysis Category: ENVIRONMENTAL Sample Matrix: SO | | | | | | |
| Lab ID | Sample Type | Client ID | Sample Date | Receipt Date | Analysis Date | Batch ID | Analyte | Method | Result | CU | CSU | MDA | Report Units | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | 3.58E-01 | 6.57E-02 | 6.57E-02 | 1.32E-01 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | 2.02E-01 | 1.52E-01 | 1.52E-01 | 2.67E-01 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | 1.83E-02 | 9.37E-02 | 9.37E-02 | 1.43E-01 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | 4.21E+00 | 3.62E-01 | 3.62E-01 | 1.31E-01 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | 7.26E-02 | 4.03E-02 | 4.03E-02 | 1.31E-01 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | 1.77E+00 | 3.08E-01 | 3.08E-01 | 1.17E-01 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 3.52E-01 | 3.64E-01 | 3.64E-01 | 7.19E-01 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | 6.98E-02 | 1.84E-01 | 1.84E-01 | 3.45E-01 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 1.80E-01 | 1.76E-01 | 1.76E-01 | 2.67E-01 | pCi/g | |
| 10-02134-09 | TRG | UM-2009-06-19-01 | 06/25/09 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | 3.65E-03 | 1.35E-01 | 1.35E-01 | 2.38E-01 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Silver-108m | LANL ER-130 Modified | -1.49E-02 | 4.39E-02 | 4.39E-02 | 7.69E-02 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Silver-110m | LANL ER-130 Modified | -3.03E-02 | 3.89E-02 | 3.89E-02 | 6.49E-02 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Barium-133 | LANL ER-130 Modified | -8.26E-03 | 5.88E-02 | 5.88E-02 | 9.42E-02 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Cobalt-60 | LANL ER-130 Modified | -2.42E-02 | 4.78E-02 | 4.78E-02 | 8.14E-02 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Cesium-134 | LANL ER-130 Modified | -3.16E-02 | 4.67E-02 | 4.67E-02 | 6.92E-02 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Cesium-137 | LANL ER-130 Modified | -5.63E-03 | 4.03E-02 | 4.03E-02 | 7.27E-02 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Europium-152 | LANL ER-130 Modified | 1.80E-01 | 2.59E-01 | 2.59E-01 | 5.37E-01 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Europium-154 | LANL ER-130 Modified | -1.98E-02 | 1.23E-01 | 1.23E-01 | 2.22E-01 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Europium-155 | LANL ER-130 Modified | 4.15E-02 | 1.46E-01 | 1.46E-01 | 1.91E-01 | pCi/g | |
| 10-02134-10 | TRG | UM-2010-01-29-01 | 01/29/10 00:00 | 2/24/2010 | 3/5/2010 | 10-02134 | Manganese-54 | LANL ER-130 Modified | -1.18E-02 | 4.69E-02 | 4.69E-02 | 8.26E-02 | pCi/g | |

CU=Counting Uncertainty;CSU=Combined Standard Uncertainty (2-sigma);MDA=Minimal Detected Activity;LCS=Laboratory Control Sample; MBL=Blank; DUP=Duplicate; TRG=Normal Sample; DO=Duplicate Original



EBERLINE ANALYTICAL CORPORATION

601 SCARBORO ROAD OAK RIDGE, TN 37830 865/481-0683 FAX 865/483-4621



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Appendix E Storage Port Vent Lines Survey Data Sheet

Cutting of Storage Port Bleed-off Lines

Survey NO.: NA

DATE: 10-Dec-08 LOCATION: O/S, West of FNR above Storage Ports TIME: 15:30

Smear Information dpm Frisking Probe Model # 44-142 Serial # 240718

ϵ_i 38 ϵ_a 0.25 Frisking Probe Efficiency 0.095

1 Min BKG: 1. 335 2. 355 3. 342

Avg. BKG: 344

L_C Gross CPM: 394

L_C Net CPM: 50

L_D Gross CPM: 417

L_D Net CPM: 73

Note: Removed Storage Port Bleed-off Lines using a bandsaw. Bleed-off lines were 1" in diameter. Pipes were Large Area Wiped internally at each end after cut. (4) Lines were cut in total, starting with the north most pipe. All Large Area Wipes were $<L_C$. Pipe ends were then taped. All (4) now loose pipes were then placed in the FNR radioactive material area inside the FNR.

During cutting activities, a cardboard tray was used to collect any pipe shavings from cutting the pipes with the bandsaw. Shavings were disposed of as radioactive materials and placed in a radioactive materials slurry/piping drum. Frisk and wipes done for the cardboard tray were all $<L_C$. Large Area Wipe of the bandsaw was $<L_C$.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|---|-----------------|------------------------------|------------------|---|-----------|
| L-2221 / 44-142 | 218579 / 240714 | 8-Mar-09 | 0.095 | 344 | 773 |
| | | | $d=1.38$ $p=0.5$ | t(sec) 2 | 2087 |
| Frisker Detector HV = 1150 Vdc (240714) | | Threshold Voltage = 350 mVdc | | Detector cable type/length = $\approx 59/6ft$ | |

Print/Signature of Surveyor: Jerry Shrimelley Date: 10-Dec-08

Comments: _____

Review By: [Signature] Date: 2/21/2012



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Appendix F Radiological Survey and Swipe Analysis for Storage Port Ends Remaining in FNR Wall

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 1 TIME: 16:25
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 32 30 3. 27

Avg. BKG: 30

L_C Gross CPM: 57

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 37 | 7 | <MDA |
| 2 Static 2 | 38 | 8 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 30 | 188 |
| | | | d=1.38 p=0.5 | t (sec) 3 | 377 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinde / Guy [Signature] Date: 09-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 2 TIME: 16:00
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 32 28 3. 38

Avg. BKG: 33

L_C Gross CPM: 54 L_C Net CPM: 21

L_D Gross CPM: N/A L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 24 | 0 | <MDA |
| 2 | | | |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 33 | 196 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 395 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shimek Date: 09-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 3 TIME: 15:45
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 38 31 3. 29

Avg. BKG: 33

L_C Gross CPM: 54

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 32 | 0 | <MDA |
| 2 Static 2 | 34 | 1 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 33 | 196 |
| | | | d=1.38 p=0.5 | t(sec) 3 | 395 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shimek Jerry Shimek Date: 09-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port #4 TIME: 15:15
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 32 26 3. 37

Avg. BKG: 32

L_C Gross CPM: 53 L_C Net CPM: 21

L_D Gross CPM: N/A L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 51 | 19 | <MDA |
| 2 Static 2 | 50 | 18 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary. Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 32 | 193 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 389 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinkel / Guy Shindel Date: 09-Jan-09

Comments: _____

Review By: ASL Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 5 TIME: 15:00

Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243

ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 3.

Avg. BKG:

L_C Gross CPM:

L_C Net CPM:

L_D Gross CPM:

L_D Net CPM:

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 | 41 | 13 | <MDA |
| 2 | 42 | 14 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|---------------------|---|--------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 28 | 183 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 366 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | β = 17.41 α = 17.25 | β = 1.33 α = 0.00 | β = 23.00 α = 5.23 |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shreck / Guy Shreck Date: 09-Jan-09

Comments: _____

Review By: [Signature] Date: 2/28/13

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 6 TIME: 14:30
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 3.

Avg. BKG:

L_C Gross CPM: L_C Net CPM:

L_D Gross CPM: L_D Net CPM:

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 25 | 0 | <MDA |
| 2 Static 2 | 39 | 9 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 90 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|---------------------|---|--------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 30 | 189 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 379 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | β = 17.41 α = 17.25 | β = 1.33 α = 0.00 | β = 23.00 α = 5.23 |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinek / Jerry Shant Date: 09-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 7 TIME: 14:15
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 35 29 3. 38

Avg. BKG: 34

L_C Gross CPM: 55

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 | 28 | 0 | <MDA |
| 2 | 31 | 0 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 34 | 199 |
| | | | $d'=1.38$ $p=0.5$ | t (sec) 3 | 403 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shimek / Jerry Shimek Date: 09-Jan-09

Comments: _____

Review By: A. J. [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 8 TIME: 13:50
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 37 30 3. 27

Avg. BKG: 31

L_C Gross CPM: 52

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 37 | 0 | <MDA |
| 2 Static 2 | 51 | 20 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 75 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 31 | 192 |
| | | | d=1.38 p=0.5 | t(sec) 3 | 387 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shmek Date: 09-Jan-09

Comments: _____

Review By: Adel Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 9 TIME: 13:30
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 26 26 3. 28

Avg. BKG: 27

L_C Gross CPM: 48

L_C Net CPM: 27

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 | 43 | 16 | <MDA |
| 2 | 46 | 19 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 65 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 27 | 179 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 357 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinek Dewey Shant Date: 09-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 10 TIME: 13:00

Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243

ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 28 30 3. 26

Avg. BKG: 28

L_C Gross CPM: 49

L_C Net CPM: 27

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 38 | 10 | <MDA |
| 2 Static 2 | 47 | 19 | <MDA |
| 3 Static 3 | 40 | 12 | <MDA |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Refer to initial port survey report for pre-decon contamination results. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|---------------------|---|--------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 28 | 183 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 366 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | β = 17.41 α = 17.25 | β = 1.33 α = 0.00 | β = 23.00 α = 5.23 |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Slinick Guy Abbott Date: 09-Jan-09

Comments: _____

Review By: Abbott Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 11 TIME: 11:30
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 30 29 3. 31

Avg. BKG: 30

L_C Gross CPM: 57

L_C Net CPM: 27

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 33 | 3 | <MDA |
| 2 Static 2 | 46 | 16 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 30 | 189 |
| | | | d'=1.38 p=0.5 | t(sec) 3 | 379 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinde / Jerry Shinde Date: 09-Jan-09

Comments: _____

Review By: AKH Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 12 TIME: 10:45
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_s 50.5 ϵ_b 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 35 30 3. 35

Avg. BKG: 33
 L_C Gross CPM: 54 L_C Net CPM: 21
 L_D Gross CPM: N/A L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 42 | 9 | <MDA |
| 2 Static 2 | 30 | 0 | <MDA |
| 3 Static 3 | 38 | 0 | <MDA |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 68 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 33 | 197 |
| | | | d'=1.38 p=0.5 | t(sec) 3 | 399 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shink / Doug Struts Date: 09-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 13 TIME: 10:00
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 40 41 3. 32

Avg. BKG: 38

L_C Gross CPM: 59

L_C Net CPM: 27

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 54 | 16 | <MDA |
| 2 Static 2 | 45 | 7 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Refer to initial port survey report for pre-decon contamination results. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 38 | 208 |
| | | | d=1.38 p=0.5 | t(sec) 3 | 424 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shreck Date: 09-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 14 TIME: 9:45

Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243

ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 27 35 3. 27

Avg. BKG: 30

L_C Gross CPM: 57 L_C Net CPM: 27

L_D Gross CPM: N/A L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 38 | 8 | <MDA |
| 2 Static 2 | 33 | 3 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 30 | 188 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 377 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinek Date: 09-Jan-09

Comments: _____

Review By: A. Hill Date: 3/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 15 TIME: 9:25
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 30 28 3. 37

Avg. BKG: 32

L_C Gross CPM: 53

L_C Net CPM: 27

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 23 | 0 | <MDA |
| 2 Static 2 | 18 | 0 | <MDA |
| 3 Static 3 | 39 | 7 | <MDA |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 32 | 193 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 389 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinek / Guy Shurt Date: 09-Jan-09

Comments: _____

Review By: A. J. H. L. Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 16 TIME: 9:00
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 3.

Avg. BKG:

L_C Gross CPM:

L_C Net CPM:

L_D Gross CPM:

L_D Net CPM:

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 40 | 3 | <MDA |
| 2 Static 2 | 32 | 0 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 37 | 208 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 422 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jeary Shreck Date: 09-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 17 TIME: 8:45
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 3.

Avg. BKG:

L_C Gross CPM:

L_C Net CPM:

L_D Gross CPM:

L_D Net CPM:

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 | 37 | 2 | <MDA |
| 2 | 50 | 15 | <MDA |
| 3 | 41 | 6 | <MDA |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 35 | 201 |
| | | | d=1.38 p=0.5 | t(sec) 3 | 407 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shimel / Jerry Shimel Date: 09-Jan-09

Comments: _____

Review By: AKA Date: 2/22/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 18 TIME: 8:25
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_e 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 35 41 3. 36

Avg. BKG: 37

L_C Gross CPM: 58

L_C Net CPM: 27

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 38 | 1 | <MDA |
| 2 Static 2 | 50 | 13 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 37 | 208 |
| | | | d=1.38 p=0.5 | t(sec) 3 | 422 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shink Date: 09-Jan-09

Comments: _____

Review By: AKAL Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 9-Jan-09 LOCATION: Port # 19 TIME: 8:10
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 37 38 3. 25

Avg. BKG: 33

L_C Gross CPM: 54

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 | 32 | 0 | <MDA |
| 2 | 35 | 2 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 33 | 197 |
| | | | $d'=1.38$ $p=0.5$ | t (sec) 3 | 399 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinde / Jerry Shinde Date: 09-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 20 TIME: 14:15

Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243

ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 40 28 3. 33

Avg. BKG: 34

L_C Gross CPM: 55

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 39 | 5 | <MDA |
| 2 Static 2 | 35 | 1 | <MDA |
| 3 Static 3 | 52 | 18 | <MDA |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 60 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 34 | 198 |
| | | | $d'=1.38$ $p=0.5$ | t (sec) 3 | 401 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shindler Guy Date: 08-Jan-09

Comments: _____

Review By: AAH Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 21 TIME: 14:00
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 26 34 3. 31

Avg. BKG: 30

L_C Gross CPM: 51 L_C Net CPM: 21

L_D Gross CPM: N/A L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 37 | 7 | <MDA |
| 2 Static 2 | 33 | 3 | <MDA |
| 3 Static 3 | 24 | 0 | <MDA |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 30 | 189 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 381 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shrock / Jerry Shrock Date: 08-Jan-09

Comments: _____

Review By: AL Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 22 TIME: 13:35

Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243

ϵ_s 50.5 ϵ_e 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 28 28 3. 31

Avg. BKG: 29

L_C Gross CPM: 50 L_C Net CPM: 21

L_D Gross CPM: N/A L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 36 | 7 | <MDA |
| 2 Static 2 | 36 | 0 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 29 | 186 |
| | | | $d'=1.38$ $\rho=0.5$ | t (sec) 3 | 372 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinkel Guy Shit Date: 08-Jan-09

Comments: _____

Review By: AKH Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 23 TIME: 13:10
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_a 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 32 43 3. 37

Avg. BKG: 37

L_C Gross CPM: 58 L_C Net CPM: 21

L_D Gross CPM: N/A L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 42 | 5 | <MDA |
| 2 | | | |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary. Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 37 | 208 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 422 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shimek / Guy [Signature] Date: 08-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 24 TIME: 13:00
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 31 44 3. 35

Avg. BKG: 37

L_C Gross CPM: 58

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 36 | 0 | <MDA |
| 2 Static 2 | 22 | 0 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 37 | 206 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 419 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shimet / Jerry Shimet Date: 08-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 25 TIME: 12:45
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 3.

Avg. BKG:

L_C Gross CPM:

L_C Net CPM:

L_D Gross CPM:

L_D Net CPM:

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 50 | 19 | <MDA |
| 2 Static 2 | 43 | 12 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 31 | 191 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 385 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shimetz / Jerry Smith Date: 08-Jan-09

Comments: _____

Review By: AKH Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 26 TIME: 11:00

Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243

ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 31 44 3 39

Avg. BKG: 38

L_C Gross CPM: 59

L_C Net CPM: 27

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 55 | 17 | <MDA |
| 2 Static 2 | 53 | 15 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|--------------------------------|---|-------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 38 | 209 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 426 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41 \alpha = 17.25$ | $\beta = 1.33 \alpha = 0.00$ | $\beta = 23.00 \alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shimek Date: 08-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 27 TIME: 10:25
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 3.

Avg. BKG:

L_C Gross CPM:

L_C Net CPM:

L_D Gross CPM:

L_D Net CPM:

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 29 | 0 | <MDA |
| 2 | | | |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary. Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 36 | 205 |
| | | | $d=1.38$ $p=0.5$ | t (sec) 3 | 417 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Tempshnick / Guy Shita Date: 08-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 28 TIME: 10:00
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243

ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 29 31 3. 29

Avg. BKG: 30

L_C Gross CPM: 57

L_C Net CPM: 27

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 40 | 10 | <MDA |
| 2 Static 2 | 33 | 3 | <MDA |
| 3 Static 3 | 31 | 1 | <MDA |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 60 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 30 | 188 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 377 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shimick / Guy [Signature] Date: 08-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 29 TIME: 9:45
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_b 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 3.

Avg. BKG:

L_C Gross CPM:

L_C Net CPM:

L_D Gross CPM:

L_D Net CPM:

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 44 | 8 | <MDA |
| 2 Static 2 | 40 | 4 | <MDA |
| 3 Static 3 | 25 | 0 | <MDA |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary.
 Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 36 | 205 |
| | | | d'=1.38 p=0.5 | 1 (sec) 3 | 417 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinn / Guy Shinn Date: 08-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 30 TIME: 9:20
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 38 28 3. 36

Avg. BKG: 34

L_C Gross CPM: 55

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 33 | 9 | <MDA |
| 2 | | | |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No Decon Necessary. Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 34 | 199 |
| | | | d=1.38 p=0.5 | t (sec) 3 | 403 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Terry Shreck / Guy Shred Date: 08-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 31 TIME: 9:00
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 26 38 3. 39

Avg. BKG: 34

L_C Gross CPM: 55

L_C Net CPM: 27

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 38 | 4 | <MDA |
| 2 Static 2 | 40 | 6 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 80 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|--------------------------------|---|-------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 34 | 200 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 405 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41 \alpha = 17.25$ | $\beta = 1.33 \alpha = 0.00$ | $\beta = 23.00 \alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinn / Guy White Date: 08-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 32 TIME: 8:45
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 29 33 3. 31

Avg. BKG: 31

L_C Gross CPM: 52

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 47 | 16 | <MDA |
| 2 Static 2 | 49 | 18 | <MDA |
| 3 Static 3 | 44 | 13 | <MDA |
| 4 Static 4 | 47 | 16 | <MDA |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 61 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|--------------------------------|---|-------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 31 | 191 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 385 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41 \alpha = 17.25$ | $\beta = 1.33 \alpha = 0.00$ | $\beta = 23.00 \alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jeremy Shivek / Guy Shivek Date: 08-Jan-09

Comments: _____

Review By: [Signature] Date: 2/25/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 33 TIME: 8:25
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 3.

Avg. BKG:

L_C Gross CPM:

L_C Net CPM:

L_D Gross CPM:

L_D Net CPM:

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 50 | 15 | <MDA |
| 2 Static 2 | 39 | 4 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 63 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 35 | 201 |
| | | | $d'=1.38$ $p=0.5$ | t (sec) 3 | 407 |
| Tenelec Series S | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shihel / Jerry Shihel Date: 08-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 8-Jan-09 LOCATION: Port # 34 TIME: 8:10
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 36 28 3. 24

Avg. BKG: 29

L_C Gross CPM: 50

L_C Net CPM: 27

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 44 | 15 | <MDA |
| 2 Static 2 | 30 | 1 | <MDA |
| 3 Static 3 | 36 | 7 | <MDA |
| 4 Static 4 | 27 | 0 | <MDA |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 58 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 29 | 187 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 374 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinek / Jerry Shinek Date: 08-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 7-Jan-09 LOCATION: Port # 35 TIME: 11:30

Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243

ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 32 33 3. 34

Avg. BKG: 33

L_C Gross CPM: 54

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 48 | 15 | <MDA |
| 2 Static 2 | 45 | 12 | <MDA |
| 3 Static 3 | 34 | 1 | <MDA |
| 4 Static 4 | 32 | 0 | <MDA |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Refer to initial port survey report for pre-decon contamination results. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 33 | 197 |
| | | | $d'=1.38$ $p=0.5$ | $t(\text{sec})$ 3 | 397 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shink / Jerry Shink Date: 07-Jan-09

Comments: _____

Review By: AKH Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 7-Jan-09 LOCATION: Port # 36 TIME: 11:15
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 27 33 3. 37

Avg. BKG: 32

L_C Gross CPM: 53 L_C Net CPM: 27

L_D Gross CPM: N/A L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 50 | 18 | <MDA |
| 2 Static 2 | 37 | 5 | <MDA |
| 3 Static 3 | 33 | 1 | <MDA |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port.
 Smear taken was <MDA. No Decon Necessary. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 32 | 195 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 393 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerome Shimek / Guy Shimek Date: 07-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 7-Jan-09 LOCATION: Port # 37 TIME: 11:00
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 32 38 3. 29

Avg. BKG: 33

L_C Gross CPM: 54

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 39 | 6 | <MDA |
| 2 Static 2 | 44 | 11 | <MDA |
| 3 Static 3 | 37 | 4 | <MDA |
| 4 Static 4 | 26 | 0 | <MDA |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port.
 Smear taken was <MDA. No Decon Necessary. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 33 | 197 |
| | | | d'=1.38 p=0.5 | t(sec) 3 | 397 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shuck / Gary White Date: 07-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 7-Jan-09 LOCATION: Port # 38 TIME: 10:50
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243

ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 30 34 3. 29

Avg. BKG: 31

L_c Gross CPM: 52

L_c Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 50 | 19 | <MDA |
| 2 Static 2 | 39 | 8 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Refer to initial port survey report for pre-decon contamination results. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 31 | 191 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 385 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinkel / Jerry Shinkel Date: 07-Jan-09

Comments: _____

Review By: [Signature] Date: 2/22/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 7-Jan-09 LOCATION: Port # 39 TIME: 10:30
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 27 22 3. 36

Avg. BKG: 28

L_C Gross CPM: 49

L_C Net CPM: 27

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 43 | 15 | <MDA |
| 2 Static 2 | 36 | 8 | <MDA |
| 3 Static 3 | 33 | 5 | <MDA |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Refer to initial port survey report for pre-decon contamination results. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 28 | 184 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 368 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinkel / Guy Shindel Date: 07-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 7-Jan-09 LOCATION: Port # 40 TIME: 10:15
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 34 34 3. 27

Avg. BKG: 32

L_C Gross CPM: 53 L_C Net CPM: 21

L_D Gross CPM: N/A L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 43 | 11 | <MDA |
| 2 Static 2 | 39 | 7 | <MDA |
| 3 Static 3 | 33 | 1 | <MDA |
| 4 Static 4 | 37 | 5 | <MDA |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port.
 Smear taken was <MDA. No Decon Necessary. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|---------------------|---|--------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 32 | 193 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 389 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | β = 17.41 α = 17.25 | β = 1.33 α = 0.00 | β = 23.00 α = 5.23 |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinnick / Jerry Shinnick Date: 07-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 7-Jan-09 LOCATION: Port # 41 TIME: 10:00
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 25 32 3. 23

Avg. BKG: 27

L_C Gross CPM: 48

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 37 | 10 | <MDA |
| 2 Static 2 | 31 | 4 | <MDA |
| 3 Static 3 | 33 | 6 | <MDA |
| 4 Static 4 | 36 | 9 | <MDA |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 77 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 27 | 179 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 357 |
| Tenclec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Terry Shindel / Jerry Shindel Date: 07-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 6-Jan-09 LOCATION: Port # 42 TIME: 15:00
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 34 37 3. 31

Avg. BKG: 34

L_C Gross CPM: 55

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 36 | 2 | <MDA |
| 2 Static 2 | 42 | 8 | <MDA |
| 3 Static 3 | 31 | 0 | <MDA |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 77 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 34 | 199 |
| | | | d=1.38 p=0.5 | t(sec) 3 | 403 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shroeder / Jerry White Date: 06-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 6-Jan-09 LOCATION: Port # 43 TIME: 14:45

Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243

ϵ_i 50.5 ϵ_a 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 3.

Avg. BKG:

L_C Gross CPM:

L_C Net CPM:

L_D Gross CPM:

L_D Net CPM:

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 38 | 11 | <MDA |
| 2 Static 2 | 44 | 17 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts of the O/S portion end of each port. No decon necessary. Smear taken was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 27 | 181 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 361 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shimick / Jerry Shimick Date: 06-Jan-09

Comments: _____

Review By: ASL Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 6-Jan-09 LOCATION: Port # 44 TIME: 14:25
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243

ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 3.

Avg. BKG:

L_C Gross CPM:

L_C Net CPM:

L_D Gross CPM:

L_D Net CPM:

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 34 | 5 | <MDA |
| 2 Static 2 | 38 | 9 | <MDA |
| 3 Static 3 | 34 | 5 | <MDA |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 74 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 29 | 185 |
| | | | d=1.38 p=0.5 | t(sec) 3 | 370 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Sh. mek Guyer Date: 06-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 23-Dec-08 LOCATION: Port # 45 TIME: 14:00
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 3.

Avg. BKG:

L_C Gross CPM:

L_C Net CPM:

L_D Gross CPM:

L_D Net CPM:

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 48 | 10 | <MDA |
| 2 Static 2 | 46 | 8 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Refer to initial port survey report for pre-decon contamination results. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|--------------------------------|---|-------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 38 | 208 |
| | | | d'=1.38 p=0.5 | t(sec) 3 | 424 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41 \alpha = 17.25$ | $\beta = 1.33 \alpha = 0.00$ | $\beta = 23.00 \alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shirek / Guy Shirek Date: 23-Dec-08

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 23-Dec-08 LOCATION: Port # 46 TIME: 13:45
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625
 1 Min BKG: 1. 34 40 3. 42

Avg. BKG: 39
 L_C Gross CPM: 60 L_C Net CPM: 21
 L_D Gross CPM: N/A L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 33 | 0 | <MDA |
| 2 Static 2 | 29 | 0 | <MDA |
| 3 Static 3 | 35 | 0 | <MDA |
| 4 Static 4 | 49 | 10 | <MDA |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Refer to initial port survey report for pre-decon contamination results. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 39 | 211 |
| | | | d'=1.38 p=0.5 | t(sec) 3 | 430 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shick / Jerry Shick Date: 23-Dec-08

Comments: _____

Review By: AShick Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 6-Jan-09 LOCATION: Port # 47 TIME: 14:00
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 3.

Avg. BKG:

L_C Gross CPM:

L_C Net CPM:

L_D Gross CPM:

L_D Net CPM:

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 44 | 16 | <MDA |
| 2 Static 2 | 34 | 6 | <MDA |
| 3 Static 3 | 37 | 9 | <MDA |
| 4 Static 4 | 41 | 13 | <MDA |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Up to 100 cpm gross pre-decon. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 28 | 182 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 364 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shinde / Gary [Signature] Date: 06-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 6-Jan-09 LOCATION: Port # 48 TIME: 13:45
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_1 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 33 29 3. 36

Avg. BKG: 33

L_C Gross CPM: 54

L_C Net CPM: 27

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 39 | 6 | <MDA |
| 2 Static 2 | 48 | 15 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Refer to initial port survey report for pre-decon contamination results. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 33 | 196 |
| | | | d=1.38 p=0.5 | t(sec) 3 | 395 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Shimek / Guy Sh... Date: 06-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 6-Jan-09 LOCATION: Port # 49 TIME: 13:25
 Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243
 ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 31 27 3. 29

Avg. BKG: 29

L_C Gross CPM: 50

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 41 | 12 | <MDA |
| 2 Static 2 | 46 | 17 | <MDA |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Refer to initial port survey report for pre-decon contamination results. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------------------|---------------|---|--------------------------------|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 29 | 186 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 372 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | | |

Print/Signature of Surveyor: Jerry Shinde / Guy Shinde Date: 06-Jan-09

Comments: _____

Review By: [Signature] Date: 2/23/12

Storage Port Exterior Survey Report

Survey NO.: NA

DATE: 23-Dec-08 LOCATION: Port # 50 TIME: 13:30

Smear Information dpm Frisking Probe Model # 44-1 Serial # PR249243

ϵ_i 50.5 ϵ_s 0.25 Frisking Probe Efficiency 0.12625

1 Min BKG: 1. 34 33 3. 42

Avg. BKG: 36

L_C Gross CPM: 57

L_C Net CPM: 21

L_D Gross CPM: N/A

L_D Net CPM: N/A

| Static Count No. | CPM (Gross) | CPM (Net) | DPM |
|------------------|-------------|-----------|------|
| 1 Static 1 | 45 | 9 | <MDA |
| 2 Static 2 | 50 | 14 | <MDA |
| 3 Static 3 | 39 | 3 | <MDA |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |

*NOTE: All counts are 1 minute static counts post-decon of the O/S portion end of each port. Refer to initial port survey report for pre-decon contamination results. Smear taken post-decon was <MDA. Port end is free released up to plane of wall.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|--|-----------------|-----------------------------|----------------------------------|---|---------------------------------|
| L-2221 / 44-1 | 218597 / 249243 | 9-Dec-09 | 0.502 | 36 | 205 |
| | | | d'=1.38 p=0.5 | t (sec) 3 | 417 |
| Tenelec Series 5 | 2161 | 28-Jul-09 | $\beta = 17.41$ $\alpha = 17.25$ | $\beta = 1.33$ $\alpha = 0.00$ | $\beta = 23.00$ $\alpha = 5.23$ |
| Frisker Detector HV = 700 Vdc (249243) | | Threshold Voltage = 50 mVdc | | Detector cable type/length = 59 / 6 ft. | |

Print/Signature of Surveyor: Jerry Strimick / Guy [Signature] Date: 23-Dec-08

Comments: _____

Review By: [Signature] Date: 2/22/12

Sample Report

| | | | |
|------------|-----------------------|------------------|---------------------|
| Batch ID: | Smears - 200901121728 | Count Date: | 1/12/2009 5:28:10PM |
| Group: | B | Count Minutes: | 3.00 |
| Device: | S5-XLB | Count Mode: | Simultaneous |
| Batch Key: | 233 | Operating Volts: | 1440 |
| Selected | Swipe/Smear | | |

Efficiency (%)

Alpha: 17.25 ± 0.12
Beta: 17.41 ± 0.05

| Sample ID | Sample Type | Alpha (dpm) | Unc | Alpha MDA (dpm) | Beta (dpm) | Unc | Beta MDA (dpm) |
|--------------------------|-------------|-------------------|--------|--------------------|---------------|--------|-------------------|
| Unloaded Swipe | LCS | 7.73 | 3.86 | 5.23 | -1.91 | 5.07 | 23.00 |
| Tc-99 Eberline Standard | LCS | 27.05 | 7.23 | 5.23 | 14558.19 | 172.37 | 23.00 |
| th-230 Eberline Standard | LCS | 13851.28 | 189.21 | 5.23 | 2812.46 | 74.04 | 23.00 |
| 20090112173951-B1 | Unknown | 0.00 | 0.00 | 5.23 | -1.91 | 5.07 | 23.00 |
| 20090112174311-B2 | Unknown | 0.00 | 0.00 | 5.23 | 3.83 | 6.05 | 23.00 |
| 20090112174621-B3 | Unknown | 0.00 | 0.00 | 5.23 | 0.00 | 5.42 | 23.00 |
| 20090112174941-B4 | Unknown | 0.00 | 0.00 | 5.23 | 1.91 | 5.74 | 23.00 |
| 20090112175301-B5 | Unknown | 1.93 | 1.93 | 5.23 | -1.91 | 5.07 | 23.00 |
| 20090112175611-B6 | Unknown | 0.00 | 0.00 | 5.23 | 0.00 | 5.42 | 23.00 |
| 20090112175931-B7 | Unknown | 1.93 | 1.93 | 5.23 | 1.91 | 5.74 | 23.00 |
| 20090112180251-B8 | Unknown | 3.86 | 2.73 | 5.23 | 5.74 | 6.35 | 23.00 |
| 20090112180611-B9 | Unknown | 1.93 | 1.93 | 5.23 | 7.66 | 6.63 | 23.00 |
| 20090112180921-B10 | Unknown | 0.00 | 0.00 | 5.23 | 3.83 | 6.05 | 23.00 |
| 20090112181241-B11 | Unknown | 3.86 | 2.73 | 5.23 | 0.00 | 5.42 | 23.00 |
| 20090112181601-B12 | Unknown | 0.00 | 0.00 | 5.23 | -1.91 | 5.07 | 23.00 |
| 20090112181911-B13 | Unknown | 0.00 | 0.00 | 5.23 | -5.74 | 4.28 | 23.00 |
| 20090112182231-B14 | Unknown | 0.00 | 0.00 | 5.23 | -5.74 | 4.28 | 23.00 |
| 20090112182551-B15 | Unknown | 0.00 | 0.00 | 5.23 | 5.74 | 6.35 | 23.00 |
| 20090112182911-B16 | Unknown | 0.00 | 0.00 | 5.23 | 5.74 | 6.35 | 23.00 |
| 20090112183221-B17 | Unknown | 0.00 | 0.00 | 5.23 | -3.83 | 4.69 | 23.00 |
| 20090112183541-B18 | Unknown | 0.00 | 0.00 | 5.23 | 0.00 | 5.42 | 23.00 |
| 20090112183901-B19 | Unknown | 0.00 | 0.00 | 5.23 | 7.66 | 6.63 | 23.00 |
| 20090112184211-B20 | Unknown | 0.00 | 0.00 | 5.23 | -3.83 | 4.69 | 23.00 |
| 20090112184531-B21 | Unknown | 0.00 | 0.00 | 5.23 | -1.91 | 5.07 | 23.00 |
| 20090112184851-B22 | Unknown | 0.00 | 0.00 | 5.23 | 1.91 | 5.74 | 23.00 |
| 20090112185211-B23 | Unknown | 0.00 | 0.00 | 5.23 | 9.57 | 6.90 | 23.00 |
| 20090112185521-B24 | Unknown | 0.00 | 0.00 | 5.23 | 11.49 | 7.16 | 23.00 |
| 20090112185841-B25 | Unknown | 0.00 | 0.00 | 5.23 | 15.32 | 7.66 | 23.00 |
| Unloaded Swipe | Background | Alpha (cpm): 0.00 | | Beta (cpm): 1.33 | | | |
| Unloaded Swipe | LCS | 1.93 | 1.93 | 5.23 | 1.91 | 5.74 | 23.00 |

Reviewed by: *AK/lyc* 2/23/12

Background Report

Batch ID: Smears - 200901121728
Group: B
Device: S5-XLB
Batch Key: 233
Selected: Swipe/Smear

Count Date: 1/12/2009 5:28:10PM
Count Minutes: 3.00
Count Mode: Simultaneous
Operating Volts: 1440

Background (cpm)

Alpha Rate: 0.00 ± 0.00

Beta Rate: 1.33 ± 0.67

| Sample ID | <u>Alpha</u> <u>(cpm)</u> | <u>Unc</u> | <u>Beta</u> <u>(cpm)</u> | <u>Unc</u> | <u>Guard</u> <u>(cpm)</u> |
|------------------------|------------------------------|------------|-----------------------------|------------|------------------------------|
| 20090112172810-B141 | 1.33 | 0.67 | 1.00 | 0.58 | 217.67 |
| 20090112173311-B149 | 4.67 | 1.25 | 2,536.00 | 29.07 | 205.67 |
| 20090112173631-B150 | 2,389.67 | 28.22 | 491.00 | 12.79 | 213.33 |
| 20090112173951-B1 | 0.00 | 0.00 | 1.00 | 0.58 | 197.00 |
| 20090112174311-B2 | 0.00 | 0.00 | 2.00 | 0.82 | 222.67 |
| 20090112174621-B3 | 0.00 | 0.00 | 1.33 | 0.67 | 213.67 |
| 20090112174941-B4 | 0.00 | 0.00 | 1.67 | 0.75 | 210.67 |
| 20090112175301-B5 | 0.33 | 0.33 | 1.00 | 0.58 | 217.33 |
| 20090112175611-B6 | 0.00 | 0.00 | 1.33 | 0.67 | 213.00 |
| 20090112175931-B7 | 0.33 | 0.33 | 1.67 | 0.75 | 213.67 |
| 20090112180251-B8 | 0.67 | 0.47 | 2.33 | 0.88 | 216.33 |
| 20090112180611-B9 | 0.33 | 0.33 | 2.67 | 0.94 | 206.00 |
| 20090112180921-B10 | 0.00 | 0.00 | 2.00 | 0.82 | 217.00 |
| 20090112181241-B11 | 0.67 | 0.47 | 1.33 | 0.67 | 200.00 |
| 20090112181601-B12 | 0.00 | 0.00 | 1.00 | 0.58 | 209.67 |
| 20090112181911-B13 | 0.00 | 0.00 | 0.33 | 0.33 | 226.33 |
| 20090112182231-B14 | 0.00 | 0.00 | 0.33 | 0.33 | 209.67 |
| 20090112182551-B15 | 0.00 | 0.00 | 2.33 | 0.88 | 218.67 |
| 20090112182911-B16 | 0.00 | 0.00 | 2.33 | 0.88 | 229.33 |
| 20090112183221-B17 | 0.00 | 0.00 | 0.67 | 0.47 | 197.33 |
| 20090112183541-B18 | 0.00 | 0.00 | 1.33 | 0.67 | 221.00 |
| 20090112183901-B19 | 0.00 | 0.00 | 2.67 | 0.94 | 207.33 |
| 20090112184211-B20 | 0.00 | 0.00 | 0.67 | 0.47 | 218.00 |
| 20090112184531-B21 | 0.00 | 0.00 | 1.00 | 0.58 | 214.67 |
| 20090112184851-B22 | 0.00 | 0.00 | 1.67 | 0.75 | 194.00 |
| 20090112185211-B23 | 0.00 | 0.00 | 3.00 | 1.00 | 209.00 |
| 20090112185521-B24 | 0.00 | 0.00 | 3.33 | 1.05 | 210.67 |
| 20090112185841-B25 | 0.00 | 0.00 | 4.00 | 1.15 | 219.00 |
| 20090112190201-B143 | 0.00 | 0.00 | 1.33 | 0.67 | 202.67 |
| 20090112190511-B147 | 0.33 | 0.33 | 1.67 | 0.75 | 216.00 |
| Guard Avg Rate: | | | | | 212.24 |

Reviewed by:  2/23/12

Procedure: Smears

Preselected Report: >>

Reporting Units: dpm

Is Active
Count Mode
Alpha
• Simultaneous

Alpha then Beta

Preselected Group & Device:
None None

Sample Count Delay
0.1 minutes (0 to 9,999 minutes)

Background Subtraction
Disable Enable
Previous Stored Method Blank

Discriminator Selection
Alpha/Beta ROI:
Tc-99 3.5% 0.8%

Beta Lower: 0.25
Beta Upper: 42.30
Alpha Lower: 72.50

Count Repetitions
Sample: 1 (1 - 99)

Batch: (1 - 10)

Spillover Correction
Disable Enable

Sample Activity
Disable Enable

Alpha Cal. Standard: Am-241 47 mm Fi

Beta Cal. Standard: Tc-99 47 mm Fil

Presets:
Count Time: 3 minutes
Alpha: 0 counts
Beta: 0 counts

Weak Sample Reject
Disable Enable

Initial Test Time:

Min Count Rate:

Geometry Selection
Geometry: Swipe/Smear

New

Save As

Print

Key 233
Group B

O/S Storage Ports 1-50

AS 1-12-09



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Appendix G Radiological Survey Report of Excavation Zone Former Storage Port No. 1 Location


Radiological Survey Report

DATE: 4/13/09 LOCATION: SW Corner of Storage Port Pit SURVEY NO.: 2009-0041 TIME: 1300

Smear Information N/A

Survey Map

| No. | Beta/Gamma | Alpha (20%) |
|-----|------------|-------------|
| 1 | | |
| 2 | | |
| 3 | | |
| 4 | | |
| 5 | | |
| 6 | | |
| 7 | | |
| 8 | | |
| 9 | | |
| 10 | | |
| 11 | | |
| 12 | | |
| 13 | | |
| 14 | | |
| 15 | | |
| 16 | | |
| 17 | | |
| 18 | | |
| 19 | | |
| 20 | | |



Legend: * = Contact; #/# = Contact Reading / General Area; # = General Area; ⊙ = Smear location; Δ = Air Sample.
 Note: Readings in mrem/hr unless noted otherwise.

| Instrument | Serial Number | Cal. Due Date | Efficiency | Background (CPM) | MDA (DPM) |
|-----------------------|---------------|---------------------|------------|-------------------------|-----------|
| Model 19 | 101763 | 25 Jul 09 | NA | NA | NA |
| Frisker Detector HV = | Vdc | Threshold Voltage = | mVdc | Detector cable length = | ft. |

Print/Signature of Surveyor: Shannon M. Weger / Shannon M. Weger Date: 4/16/09

Comments: represents readings taken at one Meter ^{SW 4/15/09} high up and one Meter out.
 BKG was taken at NW corner

Review By: [Signature] Date: 2/23/12

Ludlum Model 19 Micro R Meter



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Appendix H

Analytical Data for Final Status Survey of Concrete Support Wall Remaining in Excavation

***** GAMMA SPECTRUM ANALYSIS *****

Filename: C:\GENIE2K\CAMFILES\Det 264\StoragePortExcavation\UM-2009-04-

Report Generated On : 2/16/2012 5:13:27 PM
Sample Title : UM-2009-04-24-01
Sample Description : Concrete ground from north cut f
Sample Identification : 2009-04-24-01
Sample Type : concrete
Sample Geometry : 500 ml Nalgene
Peak Locate Threshold : 3.00
Peak Locate Range (in channels) : 39 - 8192
Peak Area Range (in channels) : 47 - 8192
Identification Energy Tolerance : 0.750 FWHM
Sample Size : 6.000E+002 g
Sample Taken On : 2/24/2009 3:00:00 PM
Acquisition Started : 2/7/2012 4:05:55 PM
Live Time : 50000.0 seconds
Real Time : 50005.0 seconds
Dead Time : 0.01 %

Energy Calibration Used Done On : 2/16/2012
Efficiency Calibration Used Done On : 2/5/2012
Efficiency ID : 500ml 2.0 g/cc

Eu-152 8.1E-2 pCi/g MDA 7.3E-2 pCi/g
± 29
N. J. [Signature] 2/16/12

 ***** N U C L I D E M D A R E P O R T *****

Detector Name: HPGE
 Sample Geometry: 500 ml Nalgene
 Sample Title: UM-2009-04-24-01
 Nuclide Library Used: C:\GENIE2K\CAMFILES\Libraries\Soil_DCGL_

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-----------|-------------------|----------------------|-------------------|
| | BE-7 | 477.60 | 10.52 | 3.0238E-001 | 3.02E-001 | 2.8237E-002 |
| + | K-40 | 1460.83* | 10.67 | 3.2978E-007 | 3.30E-007 | 7.4985E-006 |
| | MN-54 | 834.85 | 99.98 | 3.7205E-007 | 3.72E-007 | 1.0129E-007 |
| + | CO-60 | 1173.24* | 99.97 | 5.8372E-008 | 5.84E-008 | 4.3962E-009 |
| | | 1332.50* | 99.99 | 5.9717E-008 | | 5.6344E-008 |
| | ZN-65 | 1115.55 | 50.60 | 2.2101E-006 | 2.21E-006 | -1.3088E-007 |
| | NB-94x | 702.62 | 97.90 | 3.0977E-008 | 3.10E-008 | -1.7010E-008 |
| | | 871.09 | 99.90 | 3.3103E-008 | | 2.8596E-008 |
| | AG-108m | 21.10 | 59.10 | 2.9021E-007 | 2.90E-008 | -4.2206E-008 |
| | | 23.80 | 9.60 | 1.1000E-006 | | 3.7623E-008 |
| | | 79.13 | 8.76 | 3.0715E-007 | | -1.2767E-007 |
| | | 433.94 | 90.50 | 2.9036E-008 | | 1.1123E-008 |
| | | 614.28 | 89.87 | 5.8451E-008 | | -8.9361E-009 |
| | | 722.91 | 90.80 | 3.8072E-008 | | -5.5848E-009 |
| | CD-109 | 22.10 | 85.20 | 8.2472E-007 | 8.25E-007 | -3.6121E-007 |
| | | 25.02 | 16.81 | 2.6144E-006 | | -7.5823E-007 |
| | | 88.03 | 3.61 | 3.1183E-006 | | 2.8567E-007 |
| | AG-110m | 446.81 | 3.72 | 1.2919E-005 | 6.13E-007 | 5.8616E-006 |
| | | 620.36 | 2.79 | 1.9121E-005 | | -1.4550E-005 |
| | | 657.76 | 94.00 | 6.1270E-007 | | 2.0481E-007 |
| | | 677.62 | 10.28 | 5.5135E-006 | | -2.1508E-006 |
| | | 687.02 | 6.39 | 9.3357E-006 | | 6.0910E-006 |
| | | 706.68 | 16.33 | 3.7046E-006 | | 2.9949E-006 |
| | | 744.28 | 4.70 | 1.2706E-005 | | 6.6709E-006 |
| | | 763.94 | 22.14 | 3.1887E-006 | | -2.2700E-006 |
| | | 818.03 | 7.34 | 8.5823E-006 | | 2.4817E-006 |
| | | 884.68 | 72.70 | 8.7968E-007 | | 1.0407E-007 |
| | | 937.49 | 34.36 | 2.1135E-006 | | 1.6964E-006 |
| | | 1384.30 | 24.28 | 2.8403E-006 | | -2.8642E-007 |
| | | 1475.79 | 3.99 | 1.4517E-005 | | -1.3200E-006 |
| | | 1505.04 | 13.04 | 5.2799E-006 | | -4.0265E-007 |
| | | 1562.30 | 1.03 | 5.7636E-005 | | 2.3703E-005 |
| | SB-125 | 176.33 | 6.79 | 6.3825E-007 | 1.86E-007 | -2.0701E-007 |
| | | 380.43 | 1.52 | 3.3788E-006 | | -2.3257E-006 |
| | | 427.89 | 29.40 | 1.8592E-007 | | -8.1883E-008 |
| | | 463.38 | 10.45 | 5.4579E-007 | | 7.4082E-007 |
| | | 600.56 | 17.78 | 3.4983E-007 | | 1.2418E-008 |
| | | 606.64 | 5.02 | 2.4829E-006 | | -7.2793E-008 |
| | | 635.90 | 11.32 | 5.0898E-007 | | -3.8281E-009 |
| | | 671.41 | 1.80 | 3.2759E-006 | | -3.0495E-006 |
| | BA-133 | 53.16 | 2.20 | 1.1860E-006 | 7.88E-008 | 6.1883E-007 |
| | | 79.62 | 2.62 | 1.2292E-006 | | -5.1558E-007 |

| Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|--------------|--------------|-------------|-------------------|----------------------|-------------------|-----------|--------------|
| BA-133 | 81.00 | 34.10 | 7.8831E-008 | 7.88E-008 | -3.9516E-008 | | |
| | 160.61 | 0.64 | 3.7204E-006 | | -8.9237E-008 | | |
| | 223.23 | 0.45 | 6.0509E-006 | | 1.0282E-006 | | |
| | 276.40 | 7.16 | 3.8953E-007 | | 1.5544E-007 | | |
| | 302.85 | 18.33 | 1.6075E-007 | | 1.3201E-007 | | |
| | 356.02 | 62.05 | 7.9624E-008 | | -1.2952E-008 | | |
| | 383.85 | 8.94 | 3.3550E-007 | | -2.7235E-007 | | |
| | CS-134 | 475.35 | 1.46 | | 4.4711E-006 | 1.05E-007 | 2.5662E-006 |
| | | 563.23 | 8.38 | | 8.9872E-007 | | 1.4368E-007 |
| | | 569.32 | 15.43 | | 4.7562E-007 | | 5.6590E-008 |
| 604.70 | | 97.60 | 1.4184E-007 | -1.8281E-008 | | | |
| 795.84 | | 85.40 | 1.0511E-007 | 6.5436E-008 | | | |
| 801.93 | | 8.73 | 9.7931E-007 | 4.3651E-007 | | | |
| 1038.57 | | 1.00 | 9.2355E-006 | -1.4515E-006 | | | |
| 1167.94 | | 1.80 | 6.2161E-006 | -1.7210E-006 | | | |
| 1365.15 | | 3.04 | 2.8191E-006 | 6.4870E-007 | | | |
| CS-137 | | 661.66 | 85.21 | 3.8032E-008 | 3.80E-008 | | 1.9934E-008 |
| CE-139 | 165.85 | 79.89 | 2.6052E-008 | 2.61E-008 | -3.2693E-010 | | |
| + EU-152x | 121.78* | 28.40 | 7.2633E-008 | 7.26E-008 | 8.5815E-008 | | |
| | 244.70* | 7.49 | 3.0332E-007 | | 5.1063E-008 | | |
| | 344.28* | 26.60 | 8.2604E-008 | | 8.2042E-008 | | |
| | 411.11 | 2.23 | 1.3423E-006 | | 3.7311E-007 | | |
| | 443.98 | 2.78 | 9.9661E-007 | | -2.2806E-007 | | |
| | 778.90 | 12.96 | 2.7508E-007 | | -8.2245E-009 | | |
| | 867.39 | 4.15 | 9.3557E-007 | | 1.0848E-007 | | |
| | 964.13 | 14.34 | 3.6014E-007 | | 5.9676E-008 | | |
| | 1085.91 | 9.92 | 4.3500E-007 | | 1.4024E-007 | | |
| | 1089.70 | 1.71 | 2.5341E-006 | | 3.7245E-007 | | |
| | 1112.12 | 13.55 | 3.2576E-007 | | -1.9859E-009 | | |
| | 1212.95 | 1.40 | 3.3727E-006 | | 1.6737E-006 | | |
| | 1299.12 | 1.63 | 2.5226E-006 | | 9.1149E-008 | | |
| | 1408.01* | 20.87 | 1.1873E-007 | | 2.4679E-007 | | |
| | EU-154 | 123.07 | 40.40 | | 5.8266E-008 | 5.83E-008 | 5.8094E-008 |
| | | 188.25 | 0.23 | | 1.4017E-005 | | -5.0999E-006 |
| | | 247.93 | 6.83 | | 4.1119E-007 | | 2.7898E-008 |
| | | 401.30 | 0.19 | | 1.6072E-005 | | -9.9571E-006 |
| | | 444.39 | 0.55 | | 5.4894E-006 | | -2.0581E-006 |
| | | 478.26 | 0.21 | | 1.4817E-005 | | -2.0735E-006 |
| 557.56 | | 0.25 | 1.3557E-005 | 4.0431E-006 | | | |
| 582.00 | | 0.89 | 5.4581E-006 | 1.6515E-005 | | | |
| 591.76 | | 4.91 | 6.9397E-007 | -3.1158E-007 | | | |
| 625.22 | | 0.32 | 1.0818E-005 | 3.8836E-007 | | | |
| 676.59 | | 0.14 | 2.6160E-005 | -1.5677E-005 | | | |
| 692.42 | | 1.78 | 2.0895E-006 | -1.1498E-006 | | | |
| 715.76 | | 0.17 | 2.2879E-005 | -1.0072E-005 | | | |
| 722.30 | | 20.00 | 2.1599E-007 | -2.0578E-009 | | | |
| 756.86 | | 4.50 | 8.6176E-007 | -6.7063E-008 | | | |
| 815.55 | | 0.50 | 7.9101E-006 | -3.3062E-006 | | | |
| 845.39 | | 0.58 | 6.6414E-006 | -1.9085E-007 | | | |
| 850.64 | 0.23 | 1.7313E-005 | 1.3369E-005 | | | | |
| 873.20 | 12.09 | 3.4367E-007 | 1.3553E-007 | | | | |

| Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|--------------|--------------|-----------|-------------------|----------------------|-------------------|-----------|-------------|
| EU-154 | 892.73 | 0.50 | 8.4607E-006 | 5.83E-008 | 2.9852E-006 | | |
| | 904.05 | 0.85 | 4.9222E-006 | | -3.8438E-006 | | |
| | 996.30 | 10.34 | 4.3746E-007 | | -1.1993E-007 | | |
| | 1004.76 | 17.90 | 2.5585E-007 | | 4.1773E-008 | | |
| | 1128.40 | 0.29 | 1.5780E-005 | | -8.1276E-006 | | |
| | 1140.90 | 0.22 | 2.0837E-005 | | -8.9336E-006 | | |
| | 1241.60 | 0.13 | 4.8046E-005 | | -7.9671E-006 | | |
| | 1246.60 | 0.80 | 5.9038E-006 | | -4.7195E-006 | | |
| | 1274.51 | 34.40 | 1.2941E-007 | | -7.3095E-008 | | |
| | 1494.08 | 0.71 | 5.7687E-006 | | 4.4402E-007 | | |
| | 1596.45 | 1.80 | 2.3964E-006 | | -4.1291E-007 | | |
| | + TL-208B | 72.80 | 2.02 | | 1.5742E-006 | 5.50E-008 | 8.0762E-008 |
| | | 74.97* | 3.41 | | 1.2160E-006 | | 3.4242E-006 |
| | | 84.90 | 1.51 | | 1.8101E-006 | | 1.0951E-006 |
| | | 277.36 | 6.31 | | 4.4674E-007 | | 2.8983E-007 |
| 510.77* | | 22.60 | 3.0421E-007 | 3.9585E-007 | | | |
| 583.19* | | 84.50 | 5.5003E-008 | 1.4500E-007 | | | |
| 763.13 | | 1.81 | 2.3043E-006 | -2.1353E-006 | | | |
| 860.56* | | 12.42 | 4.0579E-007 | 1.6762E-007 | | | |
| 2614.53 | | 99.16 | 8.3734E-008 | 2.3516E-007 | | | |
| + Pb-210 | | 46.52* | 4.05 | 7.6428E-007 | 7.64E-007 | | 1.2997E-006 |
| | | 74.81* | 10.50 | 3.9491E-007 | | | 1.1121E-006 |
| + PB-212B | | 77.11* | 17.60 | 2.3351E-007 | 1.54E-007 | | 1.0611E-006 |
| | | 87.30* | 7.90 | 2.9624E-007 | | | 5.9477E-007 |
| | | 238.63* | 43.60 | 1.5368E-007 | | | 4.9668E-007 |
| | | 300.09* | 3.34 | 6.3681E-007 | | | 5.1091E-007 |
| | 609.31* | 44.80 | 1.1250E-007 | 1.1332E-006 | | | |
| + BI-214B | 665.45 | 1.29 | 2.8436E-006 | 1.12E-007 | 1.8892E-006 | | |
| | 768.36* | 4.80 | 7.6886E-007 | | 7.2145E-007 | | |
| | 806.17 | 1.12 | 3.5813E-006 | | 4.3837E-006 | | |
| | 934.06* | 3.03 | 1.4667E-006 | | 7.5853E-007 | | |
| | 1120.29* | 14.80 | 4.2775E-007 | | 1.0248E-006 | | |
| | 1155.19 | 1.64 | 2.9536E-006 | | 1.5538E-006 | | |
| | 1238.11* | 5.86 | 8.0533E-007 | | 1.5287E-006 | | |
| | 1280.96* | 1.44 | 3.0451E-006 | | 3.1718E-006 | | |
| | 1377.67* | 3.92 | 2.0322E-006 | | 1.3195E-006 | | |
| | 1401.50* | 1.55 | 2.6183E-006 | | 1.2498E-006 | | |
| | 1407.98* | 2.80 | 9.3357E-007 | | 1.9406E-006 | | |
| | 1509.23 | 2.12 | 2.1046E-006 | | 1.1105E-006 | | |
| | 1661.28 | 1.14 | 3.0500E-006 | | -9.8201E-008 | | |
| | 1729.59* | 2.88 | 1.7145E-006 | | 9.7237E-007 | | |
| | 1764.49* | 15.36 | 2.9063E-007 | | 1.2331E-006 | | |
| | 1847.42* | 2.04 | 1.0027E-006 | | 1.7854E-006 | | |
| | 2118.55* | 1.14 | 1.4220E-006 | | 2.9866E-006 | | |
| | 2204.21 | 4.86 | 1.0202E-006 | | 1.2169E-006 | | |
| | 2447.86 | 1.50 | 2.9615E-006 | | 2.8941E-006 | | |
| | + PB-214B | 53.23* | 1.11 | | 2.3899E-006 | 1.31E-007 | 6.1958E-007 |
| 74.81* | | 5.90 | 7.0280E-007 | 1.9791E-006 | | | |
| 77.11* | | 9.90 | 4.1513E-007 | 1.8864E-006 | | | |
| 87.30* | | 4.41 | 5.3069E-007 | 1.0655E-006 | | | |
| 241.98* | | 7.50 | 8.7664E-007 | 1.5907E-006 | | | |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|---|--------------|--------------|-------------|-------------------|----------------------|-------------------|-----------|--------------|
| + | PB-214B | 295.21* | 18.50 | 2.0020E-007 | 1.31E-007 | 1.2695E-006 | | |
| | | 351.92* | 35.80 | 1.3081E-007 | | 1.1792E-006 | | |
| + | RA-226 | 186.10* | 3.50 | 7.1912E-007 | 7.19E-007 | 1.6436E-006 | | |
| + | AC-228B | 12.95 | 15.10 | 2.0842E-007 | 1.96E-007 | 0.0000E+000 | | |
| | | 16.15 | 20.00 | 2.5069E-006 | | 7.6400E-006 | | |
| | | 19.11 | 4.60 | 7.0440E-006 | | 3.4197E-005 | | |
| | | 89.96* | 3.40 | 1.1582E-006 | | 6.2816E-007 | | |
| | | 93.35* | 5.60 | 7.6131E-007 | | 1.0898E-006 | | |
| | | 99.55 | 1.30 | 1.6663E-006 | | -1.8988E-007 | | |
| | | 105.36 | 2.00 | 1.0916E-006 | | -5.6032E-007 | | |
| | | 129.03* | 2.90 | 5.9468E-007 | | 5.3074E-007 | | |
| | | 209.39* | 4.10 | 6.9177E-007 | | 5.6981E-007 | | |
| | | 270.26* | 3.80 | 9.7025E-007 | | 1.7062E-006 | | |
| | | 328.07* | 3.50 | 9.0526E-007 | | 7.9729E-007 | | |
| | | 338.42* | 12.40 | 2.5904E-007 | | 5.8412E-007 | | |
| | | 409.62 | 2.20 | 1.4270E-006 | | 2.3282E-007 | | |
| | | 463.10* | 4.60 | 7.3494E-007 | | 8.7265E-007 | | |
| | | 562.65 | 1.01 | 3.3551E-006 | | -1.2755E-006 | | |
| | | 755.28 | 1.32 | 2.8325E-006 | | 6.5265E-008 | | |
| | | 772.28 | 1.09 | 3.9958E-006 | | -1.2434E-006 | | |
| | | 794.79* | 4.60 | 9.0227E-007 | | 1.4130E-006 | | |
| | | 835.60 | 1.71 | 2.4360E-006 | | 1.0529E-006 | | |
| | | 911.16* | 29.00 | 1.9637E-007 | | 4.4613E-007 | | |
| | | 964.64 | 5.80 | 9.5092E-007 | | 3.0068E-007 | | |
| | | 968.97* | 17.40 | 3.0238E-007 | | 3.7422E-007 | | |
| | | 1459.19 | 1.06 | 1.2019E-005 | | 9.4817E-005 | | |
| | | 1496.00 | 1.05 | 3.7125E-006 | | -2.3071E-006 | | |
| | | 1588.23 | 3.60 | 1.2495E-006 | | 8.5727E-007 | | |
| | | 1630.47 | 1.95 | 1.8751E-006 | | 2.8073E-007 | | |
| | | PA-234B | 63.00 | 3.20 | | 8.7030E-007 | 9.45E-008 | 1.1614E-006 |
| | | | 94.67 | 14.30 | | 1.8379E-007 | | -6.6375E-008 |
| | | | 98.44 | 23.00 | | 9.4517E-008 | | 1.7385E-008 |
| | | | 99.70 | 4.80 | | 4.5318E-007 | | 1.4763E-007 |
| | 111.00 | | 10.80 | 2.0783E-007 | -1.4722E-008 | | | |
| | 125.40 | | 1.00 | 2.2601E-006 | -5.3145E-007 | | | |
| | 131.20 | | 20.00 | 1.1753E-007 | 5.1874E-008 | | | |
| | 152.70 | | 6.70 | 3.5868E-007 | 1.1431E-007 | | | |
| | 186.00 | | 2.00 | 1.5645E-006 | 4.7542E-006 | | | |
| | 200.90 | | 1.00 | 2.6639E-006 | -3.0975E-008 | | | |
| | 202.90 | | 1.20 | 2.2191E-006 | -3.1264E-007 | | | |
| | 226.40 | | 5.90 | 4.6867E-007 | 6.1141E-008 | | | |
| | 227.20 | | 5.50 | 5.0196E-007 | -2.4374E-007 | | | |
| | 248.90 | | 2.80 | 9.5020E-007 | -7.9629E-008 | | | |
| | 272.10 | | 1.00 | 3.0663E-006 | -4.2847E-007 | | | |
| | 293.70 | 3.90 | 1.0713E-006 | 1.7151E-009 | | | | |
| | 369.80 | 2.90 | 9.9836E-007 | -4.6059E-007 | | | | |
| | 372.40 | 1.30 | 2.2495E-006 | -2.7169E-007 | | | | |
| | 458.80 | 1.50 | 2.0759E-006 | 1.7249E-007 | | | | |
| | 506.80 | 1.60 | 3.0191E-006 | -2.0448E-006 | | | | |
| | 513.70 | 1.30 | 3.9086E-006 | -2.1919E-007 | | | | |
| | 565.90 | 1.40 | 2.4542E-006 | 1.2850E-006 | | | | |

| Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|--------------|--------------|-------------|-------------------|----------------------|-------------------|
| PA-234B | 568.70 | 3.30 | 1.0152E-006 | 9.45E-008 | 2.8251E-007 |
| | 569.50 | 10.00 | 3.3214E-007 | | 6.1554E-008 |
| | 574.00 | 2.00 | 1.6077E-006 | | -1.2991E-006 |
| | 664.80 | 1.30 | 2.8518E-006 | | 1.7045E-006 |
| | 666.70 | 1.60 | 2.2316E-006 | | -7.2171E-007 |
| | 669.90 | 1.40 | 2.5222E-006 | | 1.1666E-006 |
| | 692.70 | 1.50 | 2.4138E-006 | | -1.6946E-007 |
| | 699.00 | 4.60 | 8.1634E-007 | | 4.0541E-007 |
| | 706.10 | 3.10 | 1.1946E-006 | | 3.1546E-007 |
| | 733.00 | 9.00 | 4.2152E-007 | | 1.3331E-007 |
| | 738.00 | 1.00 | 3.5663E-006 | | 3.1910E-008 |
| | 742.81 | 2.40 | 1.5084E-006 | | -4.0973E-007 |
| | 755.60 | 1.40 | 2.6643E-006 | | 3.2781E-007 |
| | 780.70 | 1.10 | 3.6079E-006 | | 1.6533E-006 |
| | 786.27 | 1.40 | 2.7699E-006 | | -7.4167E-007 |
| | 793.60 | 1.50 | 2.7595E-006 | | 3.7125E-006 |
| | 796.30 | 3.80 | 1.0711E-006 | | 6.2056E-008 |
| | 805.80 | 3.30 | 1.2055E-006 | | 1.1891E-006 |
| | 819.60 | 2.60 | 1.5065E-006 | | -1.3913E-007 |
| | 826.30 | 4.00 | 9.8258E-007 | | 2.1059E-007 |
| | 831.60 | 5.50 | 7.3214E-007 | | -1.6540E-007 |
| | 876.40 | 4.00 | 9.6031E-007 | | -5.7628E-007 |
| | 880.50 | 4.00 | 9.4959E-007 | | -3.6541E-008 |
| | 880.51 | 9.00 | 4.2204E-007 | | -1.6241E-008 |
| | 883.24 | 15.00 | 2.5255E-007 | | -3.6833E-008 |
| | 899.00 | 4.10 | 1.0078E-006 | | 2.6378E-007 |
| | 925.00 | 2.90 | 1.4239E-006 | | 6.0873E-007 |
| | 926.00 | 11.00 | 3.7798E-007 | | 9.0370E-008 |
| | 927.10 | 11.00 | 3.7718E-007 | | -4.6172E-007 |
| | 946.00 | 12.00 | 3.4466E-007 | | -4.9891E-008 |
| | 949.00 | 8.00 | 5.2387E-007 | | -4.0844E-008 |
| | 978.80 | 1.40 | 2.9640E-006 | | 5.8799E-007 |
| | 980.50 | 2.00 | 2.0775E-006 | | 4.2875E-007 |
| 980.50 | 3.00 | 1.3850E-006 | 2.8583E-007 | | |
| 984.00 | 1.90 | 2.2035E-006 | -7.0030E-007 | | |
| 1353.30 | 1.70 | 2.1771E-006 | -7.1542E-007 | | |
| 1394.10 | 3.00 | 1.2357E-006 | -5.5449E-007 | | |
| 1452.70 | 1.00 | 4.6547E-006 | -5.0377E-006 | | |
| 1668.50 | 1.20 | 2.9992E-006 | 5.2892E-007 | | |
| 1694.60 | 1.20 | 2.6785E-006 | 1.5344E-006 | | |
| TH-234 | 63.29 | 4.50 | 1.4863E+007 | 1.49E+007 | 2.0735E+007 |
| | 92.38 | 2.60 | 2.5777E+007 | | 1.1490E+008 |
| | 92.80 | 2.60 | 2.5596E+007 | | 1.0897E+008 |
| + U-235 | 72.70 | 0.11 | 2.3570E-005 | 4.37E-008 | 1.2092E-006 |
| | 89.95* | 2.80 | 1.1461E-006 | | 6.2164E-007 |
| | 93.35* | 4.50 | 7.7212E-007 | | 1.1053E-006 |
| | 94.00 | 0.40 | 5.4278E-006 | | -5.4716E-007 |
| | 105.00 | 2.10 | 8.4662E-007 | | -2.4922E-007 |
| | 109.16 | 1.50 | 1.2132E-006 | | -1.4208E-007 |
| | 140.76 | 0.22 | 8.6649E-006 | | -6.3840E-007 |
| | 143.76* | 10.90 | 2.3775E-007 | | 1.6431E-007 |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-----------|-------------------|----------------------|-------------------|
| + | U-235 | 163.33 | 5.00 | 4.1311E-007 | 4.37E-008 | 7.1838E-008 |
| | | 182.61 | 0.40 | 6.0901E-006 | | 1.5608E-007 |
| | | 185.71* | 57.50 | 4.3717E-008 | | 9.9919E-008 |
| | | 194.94 | 0.59 | 3.6157E-006 | | -6.0892E-007 |
| | | 202.11 | 1.00 | 2.1629E-006 | | -4.7616E-007 |
| | | 205.31* | 5.00 | 4.7894E-007 | | 1.7975E-007 |
| | | 279.50 | 0.27 | 8.4534E-006 | | -2.4896E-006 |

+ = Nuclide identified during the nuclide identification

* = Energy line found in the spectrum

> = MDA value not calculated

@ = Half-life too short to be able to perform the decay correction



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Appendix I

Analytical Data for Final Status Survey of Soil Located Behind the Section of Support Wall Removed

***** GAMMA S E C T R U M A N A L Y I S *****

Filename: C:\GENIE2K\CAMFILES\Det 264\StoragePortExcavation\UM-2009-03-

Report Generated On : 2/16/2012 4:18:35 PM

Sample Title : UM-2009-03-25-02
Sample Description : Soil sample from behind West sup
Sample Identification : 2009-03-25-02
Sample Type : soil
Sample Geometry : 500 ml Nalgene

Peak Locate Threshold : 3.00
Peak Locate Range (in channels) : 39 - 8192
Peak Area Range (in channels) : 47 - 8192
Identification Energy Tolerance : 0.750 FWHM

Sample Size : 1.000E+003 g
Sample Taken On : 3/25/2009 3:00:00 PM
Acquisition Started : 2/8/2012 7:31:14 PM
Live Time : 50000.0 seconds
Real Time : 50005.3 seconds
Dead Time : 0.01 %

Energy Calibration Used Done On : 2/8/2012
Efficiency Calibration Used Done On : 2/5/2012
Efficiency ID : 500ml 2.0 g/cc

*Eu-152 5.22E-2 pCi/s; MDA 5.29 pCi/s
± 1.65*

Asy [Signature] 2/16/12

 ***** N U C L I D E M D A R E P O R T *****

Detector Name: HPGE
 Sample Geometry: 500 ml Nalgene
 Sample Title: UM-2009-03-25-02
 Nuclide Library Used: C:\GENIE2K\CAMFILES\Libraries\Soil_DCGL_

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-----------|-------------------|----------------------|-------------------|
| | BE-7 | 477.60 | 10.52 | 1.6456E-001 | 1.65E-001 | 1.0882E-001 |
| + | K-40 | 1460.83* | 10.67 | 3.1760E-007 | 3.18E-007 | 1.0858E-005 |
| | MN-54 | 834.85 | 99.98 | 2.4037E-007 | 2.40E-007 | 1.6465E-008 |
| | CO-60 | 1173.24 | 99.97 | 4.4321E-008 | 3.70E-008 | 3.1633E-008 |
| | | 1332.50 | 99.99 | 3.6979E-008 | | 1.8919E-008 |
| | ZN-65 | 1115.55 | 50.60 | 1.4069E-006 | 1.41E-006 | 5.2555E-007 |
| | NB-94x | 702.62 | 97.90 | 2.2608E-008 | 2.26E-008 | -1.0627E-008 |
| | | 871.09 | 99.90 | 2.3648E-008 | | 1.8787E-008 |
| | AG-108m | 21.10 | 59.10 | 1.9731E-007 | 1.96E-008 | 3.4438E-009 |
| | | 23.80 | 9.60 | 7.7467E-007 | | -4.7816E-007 |
| | | 79.13 | 8.76 | 2.1390E-007 | | -3.5145E-008 |
| | | 433.94 | 90.50 | 1.9616E-008 | | 7.2955E-009 |
| | | 614.28 | 89.87 | 3.6118E-008 | | 5.4458E-009 |
| | | 722.91 | 90.80 | 2.6608E-008 | | -1.9056E-008 |
| | CD-109 | 22.10 | 85.20 | 5.4719E-007 | 5.47E-007 | -1.4555E-007 |
| | | 25.02 | 16.81 | 1.7679E-006 | | -4.7782E-007 |
| | | 88.03 | 3.61 | 2.1691E-006 | | 2.0459E-006 |
| | AG-110m | 446.81 | 3.72 | 8.5387E-006 | 3.82E-007 | -6.4813E-007 |
| | | 620.36 | 2.79 | 1.2880E-005 | | -1.1860E-005 |
| | | 657.76 | 94.00 | 3.8215E-007 | | -1.8735E-007 |
| | | 677.62 | 10.28 | 3.6133E-006 | | -3.3784E-007 |
| | | 687.02 | 6.39 | 6.2502E-006 | | 2.8184E-007 |
| | | 706.68 | 16.33 | 2.4534E-006 | | 4.2788E-007 |
| | | 744.28 | 4.70 | 8.4115E-006 | | 3.3779E-006 |
| | | 763.94 | 22.14 | 2.0195E-006 | | -9.1750E-007 |
| | | 818.03 | 7.34 | 5.2690E-006 | | -1.7553E-006 |
| | | 884.68 | 72.70 | 5.8287E-007 | | 5.0385E-008 |
| | | 937.49 | 34.36 | 1.3261E-006 | | -2.8503E-007 |
| | | 1384.30 | 24.28 | 1.8113E-006 | | -1.0060E-006 |
| | | 1475.79 | 3.99 | 8.2625E-006 | | 1.0959E-006 |
| | | 1505.04 | 13.04 | 3.0801E-006 | | 3.0956E-007 |
| | | 1562.30 | 1.03 | 2.9368E-005 | | 1.5026E-005 |
| | SB-125 | 176.33 | 6.79 | 4.5856E-007 | 1.23E-007 | -2.2914E-008 |
| | | 380.43 | 1.52 | 2.3359E-006 | | 1.3939E-006 |
| | | 427.89 | 29.40 | 1.2257E-007 | | 3.1802E-008 |
| | | 463.38 | 10.45 | 3.7626E-007 | | 5.0984E-007 |
| | | 600.56 | 17.78 | 2.3678E-007 | | 1.3155E-007 |
| | | 606.64 | 5.02 | 1.5158E-006 | | 1.0431E-005 |
| | | 635.90 | 11.32 | 3.6155E-007 | | 3.3139E-007 |
| | | 671.41 | 1.80 | 2.2683E-006 | | 2.4419E-007 |
| | BA-133 | 53.16 | 2.20 | 8.9274E-007 | 5.36E-008 | 2.6670E-007 |
| | | 79.62 | 2.62 | 8.5178E-007 | | -1.4123E-007 |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-----------|-------------------|----------------------|-------------------|
| | BA-133 | 81.00 | 34.10 | 5.7807E-008 | 5.36E-008 | -1.0824E-008 |
| | | 160.61 | 0.64 | 2.8696E-006 | | 4.2189E-006 |
| | | 223.23 | 0.45 | 4.3390E-006 | | -3.3091E-006 |
| | | 276.40 | 7.16 | 2.7894E-007 | | 8.5359E-009 |
| | | 302.85 | 18.33 | 1.1607E-007 | | 1.1813E-008 |
| | | 356.02 | 62.05 | 5.3555E-008 | | -1.6372E-007 |
| | | 383.85 | 8.94 | 2.2898E-007 | | -2.0086E-007 |
| + | CS-134 | 475.35 | 1.46 | 3.3991E-006 | 5.23E-008 | -3.9913E-007 |
| | | 563.23 | 8.38 | 6.0952E-007 | | -7.2275E-008 |
| | | 569.32 | 15.43 | 3.3739E-007 | | 1.6637E-007 |
| | | 604.70* | 97.60 | 5.5194E-008 | | 1.4989E-008 |
| | | 795.84* | 85.40 | 5.2280E-008 | | 4.4372E-008 |
| | | 801.93 | 8.73 | 7.0044E-007 | | -5.4224E-007 |
| | | 1038.57 | 1.00 | 6.7490E-006 | | -7.9711E-007 |
| | | 1167.94 | 1.80 | 4.2469E-006 | | -2.6214E-006 |
| | | 1365.15* | 3.04 | 1.4234E-006 | | 3.1159E-007 |
| | CS-137 | 661.66 | 85.21 | 2.5861E-008 | 2.59E-008 | -1.3351E-008 |
| | CE-139 | 165.85 | 79.89 | 1.8967E-008 | 1.90E-008 | 3.7266E-009 |
| + | EU-152x | 121.78* | 28.40 | 5.2888E-008 | 5.29E-008 | 5.2165E-008 |
| | | 244.70 | 7.49 | 2.8808E-007 | | -1.9642E-007 |
| | | 344.28* | 26.60 | 5.7823E-008 | | 4.0024E-008 |
| | | 411.11 | 2.23 | 9.6437E-007 | | 5.5213E-007 |
| | | 443.98 | 2.78 | 7.2525E-007 | | -1.6170E-007 |
| | | 778.90 | 12.96 | 2.0089E-007 | | 5.8606E-009 |
| | | 867.39 | 4.15 | 6.4664E-007 | | -7.0299E-008 |
| | | 964.13* | 14.34 | 3.2956E-007 | | 1.9433E-007 |
| | | 1085.91 | 9.92 | 3.1585E-007 | | -1.5211E-007 |
| | | 1089.70 | 1.71 | 1.8703E-006 | | -9.4496E-008 |
| | | 1112.12 | 13.55 | 2.4456E-007 | | -3.2794E-008 |
| | | 1212.95 | 1.40 | 2.7002E-006 | | 1.3933E-006 |
| | | 1299.12 | 1.63 | 1.9402E-006 | | 1.0649E-006 |
| | | 1408.01* | 20.87 | 9.5035E-008 | | 1.6590E-007 |
| | EU-154 | 123.07 | 40.40 | 4.4047E-008 | 4.40E-008 | 4.0526E-008 |
| | | 188.25 | 0.23 | 9.7103E-006 | | -2.0107E-006 |
| | | 247.93 | 6.83 | 2.9200E-007 | | -4.8052E-007 |
| | | 401.30 | 0.19 | 1.1678E-005 | | -2.6578E-006 |
| | | 444.39 | 0.55 | 3.9730E-006 | | -1.4680E-006 |
| | | 478.26 | 0.21 | 1.1576E-005 | | 6.5170E-006 |
| | | 557.56 | 0.25 | 9.3724E-006 | | -6.5241E-006 |
| | | 582.00 | 0.89 | 3.9237E-006 | | 1.5521E-005 |
| | | 591.76 | 4.91 | 4.8753E-007 | | -3.0548E-007 |
| | | 625.22 | 0.32 | 7.7846E-006 | | -5.2081E-008 |
| | | 676.59 | 0.14 | 1.8846E-005 | | 1.4567E-005 |
| | | 692.42 | 1.78 | 1.5915E-006 | | 8.4011E-007 |
| | | 715.76 | 0.17 | 1.5699E-005 | | 3.3660E-006 |
| | | 722.30 | 20.00 | 1.4674E-007 | | -1.0853E-007 |
| | | 756.86 | 4.50 | 6.0252E-007 | | -1.1843E-008 |
| | | 815.55 | 0.50 | 5.3237E-006 | | 1.3015E-006 |
| | | 845.39 | 0.58 | 4.9127E-006 | | 1.1991E-006 |
| | | 850.64 | 0.23 | 1.2719E-005 | | 6.1022E-006 |
| | | 873.20 | 12.09 | 2.4410E-007 | | -8.9822E-008 |

| Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|--------------|--------------|-----------|-------------------|----------------------|-------------------|-----------|--------------|
| EU-154 | 892.73 | 0.50 | 5.9369E-006 | 4.40E-008 | -3.9812E-006 | | |
| | 904.05 | 0.85 | 3.6303E-006 | | 7.5720E-007 | | |
| | 996.30 | 10.34 | 3.1409E-007 | | -5.2863E-008 | | |
| | 1004.76 | 17.90 | 1.8011E-007 | | 1.1868E-007 | | |
| | 1128.40 | 0.29 | 1.2238E-005 | | 2.5642E-006 | | |
| | 1140.90 | 0.22 | 1.6436E-005 | | -6.5126E-006 | | |
| | 1241.60 | 0.13 | 3.6399E-005 | | -1.0478E-005 | | |
| | 1246.60 | 0.80 | 5.0657E-006 | | -5.5569E-006 | | |
| | 1274.51 | 34.40 | 1.0241E-007 | | -1.8171E-008 | | |
| | 1494.08 | 0.71 | 3.4519E-006 | | -5.1743E-007 | | |
| | 1596.45 | 1.80 | 1.6311E-006 | | -5.4889E-007 | | |
| | + TL-208B | 72.80 | 2.02 | | 1.1090E-006 | 2.87E-008 | -1.6946E-007 |
| | | 74.97* | 3.41 | | 8.6269E-007 | | 1.9967E-006 |
| | | 84.90 | 1.51 | | 1.2944E-006 | | 1.7831E-006 |
| | | 277.36 | 6.31 | | 3.1700E-007 | | 2.8927E-008 |
| 510.77* | | 22.60 | 1.6905E-007 | 2.4420E-007 | | | |
| 583.19* | | 84.50 | 3.3663E-008 | 1.3488E-007 | | | |
| 763.13 | | 1.81 | 1.5876E-006 | -8.4405E-007 | | | |
| 860.56* | | 12.42 | 2.1580E-007 | 3.5145E-007 | | | |
| 2614.53* | | 99.16 | 2.8733E-008 | 1.3636E-007 | | | |
| + Pb-210 | | 46.52* | 4.05 | 5.5777E-007 | 5.58E-007 | | 9.9170E-007 |
| | | + PB-212B | 74.81* | 10.50 | | | 2.8017E-007 |
| 77.11* | | | 17.60 | 1.6617E-007 | 6.6986E-007 | | |
| 87.30* | | | 7.90 | 1.9957E-007 | 4.1504E-007 | | |
| 238.63* | | | 43.60 | 7.9198E-008 | 4.1724E-007 | | |
| 300.09* | | | 3.34 | 5.9844E-007 | 3.9201E-007 | | |
| + BI-214B | 609.31* | 44.80 | 7.1392E-008 | 7.14E-008 | 6.7005E-007 | | |
| | 665.45* | 1.29 | 2.4325E-006 | | 8.3065E-007 | | |
| | 768.36* | 4.80 | 5.9498E-007 | | 6.7654E-007 | | |
| | 806.17* | 1.12 | 2.3089E-006 | | 1.7023E-006 | | |
| | 934.06* | 3.03 | 9.9556E-007 | | 9.9021E-007 | | |
| | 1120.29* | 14.80 | 3.2186E-007 | | 7.7439E-007 | | |
| | 1155.19 | 1.64 | 2.2033E-006 | | -1.0795E-006 | | |
| | 1238.11* | 5.86 | 7.0030E-007 | | 1.0434E-006 | | |
| | 1280.96 | 1.44 | 2.3370E-006 | | -3.8142E-007 | | |
| | 1377.67 | 3.92 | 7.6579E-007 | | -2.7056E-007 | | |
| | 1401.50 | 1.55 | 1.9213E-006 | | -3.1845E-007 | | |
| | 1407.98* | 2.80 | 7.4626E-007 | | 1.3027E-006 | | |
| | 1509.23* | 2.12 | 1.1704E-006 | | 8.6018E-007 | | |
| | 1661.28* | 1.14 | 2.2138E-006 | | -8.2237E-008 | | |
| | 1729.59* | 2.88 | 7.8428E-007 | | 1.1796E-006 | | |
| | 1764.49* | 15.36 | 2.5293E-007 | | 6.2268E-007 | | |
| | 1847.42* | 2.04 | 1.1579E-006 | | 1.1147E-006 | | |
| | 2118.55* | 1.14 | 1.7155E-006 | | 1.2161E-006 | | |
| | 2204.21* | 4.86 | 4.3741E-007 | | 1.2394E-006 | | |
| | 2447.86 | 1.50 | 1.6636E-006 | | 9.5891E-007 | | |
| + PB-214B | 53.23* | 1.11 | 1.4791E-006 | 6.88E-008 | 7.4841E-007 | | |
| | 74.81* | 5.90 | 4.9861E-007 | | 1.1540E-006 | | |
| | 77.11* | 9.90 | 2.9541E-007 | | 1.1909E-006 | | |
| | 87.30* | 4.41 | 3.5750E-007 | | 7.4349E-007 | | |
| | 241.98* | 7.50 | 4.3887E-007 | | 9.9044E-007 | | |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) | | |
|---|--------------|--------------|-------------|-------------------|----------------------|-------------------|-----------|--------------|
| + | PB-214B | 295.21* | 18.50 | 1.4388E-007 | 6.88E-008 | 7.0992E-007 | | |
| | | 351.92* | 35.80 | 6.8828E-008 | | 6.9362E-007 | | |
| + | RA-226 | 186.10* | 3.50 | 5.8424E-007 | 5.84E-007 | 1.1772E-006 | | |
| + | AC-228B | 12.95 | 15.10 | 1.2439E-007 | 1.24E-007 | 0.0000E+000 | | |
| | | 16.15 | 20.00 | 1.6790E-006 | | 5.9664E-006 | | |
| | | 19.11 | 4.60 | 4.7754E-006 | | 2.8416E-005 | | |
| | | 89.96* | 3.40 | 4.7443E-007 | | 2.8156E-007 | | |
| | | 93.35* | 5.60 | 3.1238E-007 | | 4.1891E-007 | | |
| | | 99.55 | 1.30 | 1.2654E-006 | | 6.1971E-008 | | |
| | | 105.36 | 2.00 | 8.0505E-007 | | -6.4090E-007 | | |
| | | 129.03* | 2.90 | 5.1759E-007 | | 1.9787E-007 | | |
| | | 209.39* | 4.10 | 3.8404E-007 | | 3.4966E-007 | | |
| | | 270.26* | 3.80 | 4.4207E-007 | | 4.2689E-007 | | |
| | | 328.07* | 3.50 | 5.0172E-007 | | 2.9218E-007 | | |
| | | 338.42* | 12.40 | 2.0369E-007 | | 3.5388E-007 | | |
| | | 409.62 | 2.20 | 1.0431E-006 | | 4.9016E-007 | | |
| | | 463.10* | 4.60 | 4.3969E-007 | | 4.9870E-007 | | |
| | | 562.65 | 1.01 | 2.3373E-006 | | -4.8701E-008 | | |
| | | 755.28 | 1.32 | 1.9926E-006 | | 3.4770E-007 | | |
| | | 772.28 | 1.09 | 2.7787E-006 | | -1.6951E-006 | | |
| | | 794.79* | 4.60 | 4.5063E-007 | | 3.8247E-007 | | |
| | | 835.60 | 1.71 | 1.6578E-006 | | -1.5997E-007 | | |
| | | 911.16* | 29.00 | 1.2384E-007 | | 3.6938E-007 | | |
| | | 964.64* | 5.80 | 8.5840E-007 | | 5.0618E-007 | | |
| | | 968.97* | 17.40 | 2.9849E-007 | | 4.1136E-007 | | |
| | | 1459.19 | 1.06 | 1.0954E-005 | | 1.3648E-004 | | |
| | | 1496.00 | 1.05 | 2.3240E-006 | | 2.6956E-007 | | |
| | | 1588.23* | 3.60 | 7.3820E-007 | | 7.4033E-007 | | |
| | | 1630.47 | 1.95 | 1.2707E-006 | | -1.2856E-009 | | |
| | | PA-234B | 63.00 | 3.20 | | 6.5526E-007 | 7.21E-008 | 7.5600E-007 |
| | | | 94.67 | 14.30 | | 1.3077E-007 | | 1.9657E-007 |
| | | | 98.44 | 23.00 | | 7.2108E-008 | | -5.6487E-008 |
| | | | 99.70 | 4.80 | | 3.4264E-007 | | 8.1515E-008 |
| | | | 111.00 | 10.80 | | 1.5421E-007 | | 9.7611E-008 |
| | | | 125.40 | 1.00 | | 1.6968E-006 | | -1.1982E-007 |
| | | | 131.20 | 20.00 | | 8.6539E-008 | | 7.4436E-008 |
| | 152.70 | | 6.70 | 2.6419E-007 | 2.7261E-007 | | | |
| | 186.00 | | 2.00 | 1.0999E-006 | 4.4341E-006 | | | |
| | 200.90 | | 1.00 | 2.0015E-006 | 2.6911E-007 | | | |
| | 202.90 | | 1.20 | 1.6733E-006 | -3.8141E-007 | | | |
| | 226.40 | | 5.90 | 3.4537E-007 | 1.9175E-007 | | | |
| | 227.20 | | 5.50 | 3.7070E-007 | 1.9853E-007 | | | |
| | 248.90 | | 2.80 | 6.8903E-007 | -3.8690E-007 | | | |
| | 272.10 | | 1.00 | 2.0459E-006 | 1.0987E-006 | | | |
| | 293.70 | | 3.90 | 7.1766E-007 | 3.6555E-006 | | | |
| | 369.80 | | 2.90 | 7.1962E-007 | 1.2002E-007 | | | |
| | 372.40 | 1.30 | 1.5727E-006 | -7.0560E-007 | | | | |
| | 458.80 | 1.50 | 1.4812E-006 | 1.3344E-007 | | | | |
| | 506.80 | 1.60 | 1.8958E-006 | -5.5923E-007 | | | | |
| | 513.70 | 1.30 | 2.5046E-006 | -2.2409E-007 | | | | |
| | 565.90 | 1.40 | 1.7269E-006 | 1.6773E-007 | | | | |

| Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|--------------|--------------|-------------|-------------------|----------------------|-------------------|
| PA-234B | 568.70 | 3.30 | 7.3234E-007 | 7.21E-008 | 5.6866E-008 |
| | 569.50 | 10.00 | 2.4177E-007 | | 1.1922E-007 |
| | 574.00 | 2.00 | 1.1876E-006 | | -1.8042E-006 |
| | 664.80 | 1.30 | 1.9532E-006 | | -5.1278E-007 |
| | 666.70 | 1.60 | 1.5728E-006 | | 1.0091E-006 |
| | 669.90 | 1.40 | 1.7662E-006 | | -5.0851E-008 |
| | 692.70 | 1.50 | 1.8270E-006 | | 5.7135E-007 |
| | 699.00 | 4.60 | 5.9248E-007 | | 2.5955E-007 |
| | 706.10 | 3.10 | 8.6171E-007 | | 1.8698E-007 |
| | 733.00 | 9.00 | 3.0143E-007 | | 1.4113E-007 |
| | 738.00 | 1.00 | 2.5147E-006 | | -2.3615E-006 |
| | 742.81 | 2.40 | 1.0934E-006 | | 3.0386E-007 |
| | 755.60 | 1.40 | 1.8812E-006 | | 2.8458E-007 |
| | 780.70 | 1.10 | 2.5166E-006 | | 5.7929E-007 |
| | 786.27 | 1.40 | 1.9096E-006 | | -2.3880E-006 |
| | 793.60 | 1.50 | 1.9166E-006 | | 1.1106E-006 |
| | 796.30 | 3.80 | 7.8208E-007 | | 1.2383E-006 |
| | 805.80 | 3.30 | 8.2971E-007 | | -8.2459E-008 |
| | 819.60 | 2.60 | 9.9808E-007 | | 9.8931E-008 |
| | 826.30 | 4.00 | 6.4387E-007 | | -8.0917E-008 |
| | 831.60 | 5.50 | 4.9043E-007 | | -1.6702E-007 |
| | 876.40 | 4.00 | 7.2922E-007 | | 3.6447E-007 |
| | 880.50 | 4.00 | 7.2378E-007 | | 1.5370E-007 |
| | 880.51 | 9.00 | 3.2168E-007 | | 6.8312E-008 |
| | 883.24 | 15.00 | 1.9090E-007 | | 9.7110E-008 |
| | 899.00 | 4.10 | 7.4940E-007 | | 6.8371E-007 |
| | 925.00 | 2.90 | 1.0194E-006 | | 2.4656E-007 |
| | 926.00 | 11.00 | 2.6327E-007 | | -1.5809E-008 |
| | 927.10 | 11.00 | 2.7007E-007 | | 7.3471E-008 |
| | 946.00 | 12.00 | 2.5450E-007 | | 2.4164E-007 |
| | 949.00 | 8.00 | 3.7757E-007 | | 4.5851E-007 |
| | 978.80 | 1.40 | 2.2406E-006 | | 1.0624E-006 |
| | 980.50 | 2.00 | 1.5673E-006 | | 9.7550E-007 |
| | 980.50 | 3.00 | 1.0448E-006 | | 6.5033E-007 |
| 984.00 | 1.90 | 1.6338E-006 | 4.5651E-008 | | |
| 1353.30 | 1.70 | 1.5263E-006 | -1.4107E-006 | | |
| 1394.10 | 3.00 | 8.4235E-007 | -1.1945E-006 | | |
| 1452.70 | 1.00 | 3.1833E-006 | -1.0275E-005 | | |
| 1668.50 | 1.20 | 1.7071E-006 | 2.5018E-007 | | |
| 1694.60 | 1.20 | 1.7845E-006 | 8.7312E-008 | | |
| TH-234 | 63.29 | 4.50 | 5.0533E+006 | 5.05E+006 | 4.9321E+006 |
| | 92.38 | 2.60 | 8.2775E+006 | | 3.4568E+007 |
| | 92.80 | 2.60 | 8.2194E+006 | | 3.1949E+007 |
| + U-235 | 72.70 | 0.11 | 1.6693E-005 | 3.55E-008 | -2.5506E-006 |
| | 89.95* | 2.80 | 4.7200E-007 | | 2.8012E-007 |
| | 93.35* | 4.50 | 3.1850E-007 | | 4.2711E-007 |
| | 94.00 | 0.40 | 3.8695E-006 | | 2.3803E-006 |
| | 105.00 | 2.10 | 6.2862E-007 | | -2.9521E-007 |
| | 109.16 | 1.50 | 8.9941E-007 | | -6.7060E-008 |
| | 140.76 | 0.22 | 6.4154E-006 | | 4.1898E-007 |
| | 143.76* | 10.90 | 1.3725E-007 | | -4.6871E-008 |

| | Nuclide Name | Energy (keV) | Yield (%) | Line MDA (uCi/g) | Nuclide MDA (uCi/g) | Activity (uCi/g) |
|---|--------------|--------------|-----------|-------------------|----------------------|-------------------|
| + | U-235 | 163.33 | 5.00 | 3.0016E-007 | 3.55E-008 | -1.0624E-007 |
| | | 182.61 | 0.40 | 4.2747E-006 | | 7.2673E-008 |
| | | 185.71* | 57.50 | 3.5518E-008 | | 7.1566E-008 |
| | | 194.94 | 0.59 | 2.7465E-006 | | 1.3752E-006 |
| | | 202.11 | 1.00 | 1.6475E-006 | | -6.0269E-007 |
| | | 205.31 | 5.00 | 3.3227E-007 | | -7.3465E-008 |
| | | 279.50 | 0.27 | 6.0267E-006 | | 1.6219E-006 |

+ = Nuclide identified during the nuclide identification

* = Energy line found in the spectrum

> = MDA value not calculated

@ = Half-life too short to be able to perform the decay correction



**Ford Nuclear Reactor
Storage Ports - Final Disposition**

Revision: 00

Appendix J
Analytical Results from Eberline Analytical for Final Status Survey
Of the Soil under the Former Storage Port No. 1

UM-2008-12-17-01 (4)
UM-2009-02-06-02 (5)
UM-2009-02-06-03 (6)
UM-2009-02-06-04 (7)

University of Michigan

Phoenix Memorial Lab

STANDARD LEVEL IV
REPORT OF ANALYSIS

WORK ORDER #09-02104-OR

March 3, 2009

EBERLINE ANALYTICAL
OAK RIDGE LABORATORY
OAK RIDGE, TN

TABLE OF CONTENTS

| SECTION | DESCRIPTION | PAGE |
|---------|--|------|
| I | Chain Of Custody | 004 |
| II | Sample Acknowledgement | 008 |
| III | Case Narrative | 011 |
| IV | Analytical Results Summary | 014 |
| V | Analytical Standard | 017 |
| VI | Quality Control Sample Results Summary | 020 |
| VII | Laboratory Technician's Notes | 025 |
| VIII | Analytical Data (Iron-55) | 031 |
| IX | Analytical Data (Gamma Spectroscopy) | 146 |
| | Last page | 286 |



EBERLINE ANALYTICAL CORPORATION
601 SCARBORO ROAD
OAK RIDGE, TENNESSEE 37830
PHONE (865) 481-0683
FAX (865) 483-4621

EBS-OR-28435

March 3, 2009

Chris Becker
University of Michigan
Phoenix Memorial Lab
2301 Bonisteel Blvd.
Ann Arbor, MI 48109

CASE NARRATIVE
Work Order # 09-02104-OR

SAMPLE RECEIPT

This work order contains four soil samples received 2/23/2009. These samples were analyzed for Iron-55 and by Gamma Spectroscopy.

| <u>CLIENT ID</u> | <u>LAB ID</u> | <u>CLIENT ID</u> | <u>LAB ID</u> |
|------------------|---------------|------------------|---------------|
| UM-2008-12-17-01 | 09-02104-04 | UM-2009-02-06-03 | 09-02104-06 |
| UM-2009-02-06-02 | 09-02104-05 | UM-2009-02-06-04 | 09-02104-07 |

ANALYTICAL METHODS

Iron-55 was performed using EML Method E-Fe-01-01 modified. Gamma Spectroscopy was performed using Method LANL ER-130 Modified.

ANALYTICAL RESULTS

Combined Standard Uncertainty is reported at 2-sigma value.

IRON-55

A representative aliquot from each sample was placed into a Petri geometry container. Samples were then counted on a planar low energy photon spectroscopy (LEPS) detector.

Samples demonstrated non-detect equivalent results for Iron-55 activity. Results for the Iron-55 method blank demonstrated non-detect equivalent activity. Results for the Iron-55 replicate demonstrated a high relative percent difference; however, normalized difference is within acceptable limits for the analytical technique. Results for the Americium-241 and Cobalt-57 laboratory control sample demonstrated an acceptable percent recovery.

GAMMA SPECTROSCOPY

Samples for Gamma Spectroscopy analysis were prepared by transferring a known mass/aliquot of each prepared and homogenized sample to a standard geometry container. Samples were counted on High Purity Germanium (HPGe) gamma ray detectors.


ANALYTICAL RESULTS CONTINUED

GAMMA SPECTROSCOPY continued

Samples demonstrated non-detect equivalent results for Cerium-139, Cobalt-60, Cesium-134, Europium-152, Europium-154 and Manganese-54 activity. Results for the method blank demonstrated non-detect equivalent activity for all gamma-emitting radionuclides as reported. Results for the Cobalt-60, Cesium-134 and Europium-154 replicate demonstrated a high relative percent difference; however, normalized difference is within acceptable limits for the analytical technique. Results for the Cobalt-60 and Cesium-137 laboratory control sample demonstrated an acceptable percent recovery.

CERTIFICATION OF ACCURACY

I certify that this data report is in compliance with the terms and conditions of the Purchase Order, both technically and for completeness, for other than the conditions detailed above. Release of the data contained in this hard copy data package has been authorized by the cognizant project manager or his/her designee to be accurate as verified by the following signature.


M.R. McDougal
Laboratory Manager

Date: 3/3/2009

| Eberline Analytical Final Report of Analysis | | | Report To: | | | | | Work Order Details | | | | | |
|---|-------------|------------------|---|--------------|---------------|----------|---------------|-----------------------|---------------|----------|----------|----------|--------------|
| | | | Chris Becker Phoenix Memorial Lab 2301 Bonisteel Blvd. Ann Arbor, MI 48109 | | | | | SDG: | 09-02104 | | | | |
| | | | | | | | | Purchase Order: | 5000002634 | | | | |
| | | | | | | | | Analysis Category: | ENVIRONMENTAL | | | | |
| | | | | | | | | Sample Matrix: | SO | | | | |
| Lab ID | Sample Type | Client ID | Sample Date | Receipt Date | Analysis Date | Batch ID | Analyte | Method | Result | CU | CSU | MDA | Report Units |
| 09-02104-01 | LCS | KNOWN | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Americium-241 | EML Fe-01-01 Modified | 3.73E+03 | 1.16E+02 | | | pCi/g |
| 09-02104-01 | LCS | KNOWN | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cobalt-57 | EML Fe-01-01 Modified | 1.18E+03 | 3.31E+01 | | | pCi/g |
| 09-02104-01 | LCS | SPIKE | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Americium-241 | EML Fe-01-01 Modified | 3.62E+03 | 4.35E+02 | 4.35E+02 | 4.91E+00 | pCi/g |
| 09-02104-01 | LCS | SPIKE | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cobalt-57 | EML Fe-01-01 Modified | 1.33E+03 | 1.35E+02 | 1.35E+02 | 4.80E+00 | pCi/g |
| 09-02104-02 | MBL | BLANK | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Iron-55 | EML Fe-01-01 Modified | 4.29E+00 | 8.18E+00 | 8.18E+00 | 9.13E+00 | pCi/g |
| 09-02104-03 | DUP | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Iron-55 | EML Fe-01-01 Modified | -7.20E-01 | 2.54E+00 | 2.54E+00 | 3.86E+00 | pCi/g |
| 09-02104-04 | DO | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Iron-55 | EML Fe-01-01 Modified | -5.29E-01 | 2.43E+00 | 2.43E+00 | 3.89E+00 | pCi/g |
| 09-02104-05 | TRG | UM-2009-02-06-02 | 02/11/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Iron-55 | EML Fe-01-01 Modified | -1.46E+00 | 3.24E+00 | 3.24E+00 | 3.87E+00 | pCi/g |
| 09-02104-06 | TRG | UM-2009-02-06-03 | 02/11/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Iron-55 | EML Fe-01-01 Modified | -3.86E-01 | 2.07E+00 | 2.07E+00 | 3.37E+00 | pCi/g |
| 09-02104-07 | TRG | UM-2009-02-06-04 | 02/13/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Iron-55 | EML Fe-01-01 Modified | -4.72E-01 | 2.55E+00 | 2.55E+00 | 4.16E+00 | pCi/g |
| 09-02104-01 | LCS | KNOWN | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cobalt-60 | LANL ER-130 Modified | 1.23E+02 | 3.39E+00 | | | pCi/g |
| 09-02104-01 | LCS | KNOWN | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cesium-137 | LANL ER-130 Modified | 7.64E+01 | 2.22E+00 | | | pCi/g |
| 09-02104-01 | LCS | SPIKE | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cobalt-60 | LANL ER-130 Modified | 1.30E+02 | 6.04E+00 | 6.04E+00 | 5.22E-01 | pCi/g |
| 09-02104-01 | LCS | SPIKE | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cesium-137 | LANL ER-130 Modified | 8.15E+01 | 5.30E+00 | 5.30E+00 | 4.71E-01 | pCi/g |
| 09-02104-02 | MBL | BLANK | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cerium-139 | LANL ER-130 Modified | -5.06E-03 | 1.76E-02 | 1.76E-02 | 3.06E-02 | pCi/g |
| 09-02104-02 | MBL | BLANK | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cobalt-60 | LANL ER-130 Modified | -3.98E-03 | 3.63E-02 | 3.63E-02 | 6.69E-02 | pCi/g |
| 09-02104-02 | MBL | BLANK | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cesium-134 | LANL ER-130 Modified | 1.92E-02 | 3.02E-02 | 3.02E-02 | 5.60E-02 | pCi/g |
| 09-02104-02 | MBL | BLANK | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Europium-152 | LANL ER-130 Modified | -4.75E-02 | 1.70E-01 | 1.70E-01 | 3.48E-01 | pCi/g |
| 09-02104-02 | MBL | BLANK | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Europium-154 | LANL ER-130 Modified | -1.11E-02 | 8.19E-02 | 8.19E-02 | 1.68E-01 | pCi/g |
| 09-02104-02 | MBL | BLANK | 02/24/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Manganese-54 | LANL ER-130 Modified | 1.42E-02 | 2.83E-02 | 2.83E-02 | 5.88E-02 | pCi/g |
| 09-02104-03 | DUP | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cerium-139 | LANL ER-130 Modified | -1.48E-02 | 2.81E-02 | 2.81E-02 | 4.66E-02 | pCi/g |
| 09-02104-03 | DUP | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cobalt-60 | LANL ER-130 Modified | 2.56E-02 | 3.11E-02 | 3.11E-02 | 5.97E-02 | pCi/g |
| 09-02104-03 | DUP | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cesium-134 | LANL ER-130 Modified | 1.33E-03 | 2.30E-02 | 2.30E-02 | 3.83E-02 | pCi/g |
| 09-02104-03 | DUP | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Europium-152 | LANL ER-130 Modified | -6.92E-02 | 2.08E-01 | 2.08E-01 | 3.14E-01 | pCi/g |
| 09-02104-03 | DUP | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Europium-154 | LANL ER-130 Modified | 1.65E-02 | 7.33E-02 | 7.33E-02 | 1.36E-01 | pCi/g |
| 09-02104-03 | DUP | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Manganese-54 | LANL ER-130 Modified | 2.06E-02 | 2.71E-02 | 2.71E-02 | 5.22E-02 | pCi/g |

CU=Counting Uncertainty;CSU=Combined Standard Uncertainty (2-sigma);MDA=Minimal Detected Activity;LCS=Laboratory Control Sample; MBL=Blank; DUP=Duplicate; TRG=Normal Sample; DO=Duplicate Original



EBERLINE
SERVICES

EBERLINE ANALYTICAL CORPORATION

601 SCARBORO ROAD OAK RIDGE, TN 37830 865/481-0683 Fax 865/483-4621

| Eberline Analytical Final Report of Analysis | | | Report To: | | | | | Work Order Details: | | | | | | | | |
|---|-------------|------------------|---|--------------|---------------|----------|--------------|----------------------|-----------|----------|-----------------|------------|--------------|--------------------|---------------|--|
| | | | Chris Becker Phoenix Memorial Lab 2301 Bonisteel Blvd. Ann Arbor, MI 48109 | | | | | SDG: | 09-02104 | | Purchase Order: | 5000002634 | | Analysis Category: | ENVIRONMENTAL | |
| Lab ID | Sample Type | Client ID | Sample Date | Receipt Date | Analysis Date | Batch ID | Analyte | Method | Result | CU | CSU | MDA | Report Units | | | |
| 09-02104-04 | DO | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cerium-139 | LANL ER-130 Modified | 1.30E-02 | 2.78E-02 | 2.78E-02 | 4.83E-02 | pCi/g | | | |
| 09-02104-04 | DO | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cobalt-60 | LANL ER-130 Modified | 1.60E-03 | 2.77E-02 | 2.77E-02 | 5.04E-02 | pCi/g | | | |
| 09-02104-04 | DO | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cesium-134 | LANL ER-130 Modified | 5.21E-03 | 2.57E-02 | 2.57E-02 | 4.30E-02 | pCi/g | | | |
| 09-02104-04 | DO | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Europium-152 | LANL ER-130 Modified | 2.19E-01 | 2.23E-01 | 2.23E-01 | 3.17E-01 | pCi/g | | | |
| 09-02104-04 | DO | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Europium-154 | LANL ER-130 Modified | 2.12E-02 | 8.37E-02 | 8.37E-02 | 1.53E-01 | pCi/g | | | |
| 09-02104-04 | DO | UM-2008-12-17-01 | 01/09/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Manganese-54 | LANL ER-130 Modified | 2.14E-02 | 2.82E-02 | 2.82E-02 | 4.82E-02 | pCi/g | | | |
| 09-02104-05 | TRG | UM-2009-02-06-02 | 02/11/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cerium-139 | LANL ER-130 Modified | -1.60E-02 | 2.34E-02 | 2.34E-02 | 3.87E-02 | pCi/g | | | |
| 09-02104-05 | TRG | UM-2009-02-06-02 | 02/11/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cobalt-60 | LANL ER-130 Modified | 7.64E-02 | 3.19E-02 | 3.19E-02 | 6.51E-02 | pCi/g | | | |
| 09-02104-05 | TRG | UM-2009-02-06-02 | 02/11/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cesium-134 | LANL ER-130 Modified | 1.79E-02 | 3.03E-02 | 3.03E-02 | 5.38E-02 | pCi/g | | | |
| 09-02104-05 | TRG | UM-2009-02-06-02 | 02/11/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Europium-152 | LANL ER-130 Modified | 5.10E-01 | 1.19E-01 | 1.19E-01 | 3.58E-01 | pCi/g | | | |
| 09-02104-05 | TRG | UM-2009-02-06-02 | 02/11/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Europium-154 | LANL ER-130 Modified | -7.99E-02 | 1.08E-01 | 1.08E-01 | 1.77E-01 | pCi/g | | | |
| 09-02104-05 | TRG | UM-2009-02-06-02 | 02/11/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Manganese-54 | LANL ER-130 Modified | -2.30E-04 | 2.90E-02 | 2.90E-02 | 5.36E-02 | pCi/g | | | |
| 09-02104-06 | TRG | UM-2009-02-06-03 | 02/17/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cerium-139 | LANL ER-130 Modified | 1.25E-02 | 4.03E-02 | 4.03E-02 | 7.04E-02 | pCi/g | | | |
| 09-02104-06 | TRG | UM-2009-02-06-03 | 02/17/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cobalt-60 | LANL ER-130 Modified | 7.07E-02 | 8.29E-02 | 8.29E-02 | 1.58E-01 | pCi/g | | | |
| 09-02104-06 | TRG | UM-2009-02-06-03 | 02/17/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cesium-134 | LANL ER-130 Modified | 1.87E-02 | 6.21E-02 | 6.21E-02 | 1.00E-01 | pCi/g | | | |
| 09-02104-06 | TRG | UM-2009-02-06-03 | 02/17/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Europium-152 | LANL ER-130 Modified | 9.04E-01 | 5.11E-01 | 5.11E-01 | 1.00E+00 | pCi/g | | | |
| 09-02104-06 | TRG | UM-2009-02-06-03 | 02/17/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Europium-154 | LANL ER-130 Modified | -4.91E-02 | 1.61E-01 | 1.61E-01 | 2.99E-01 | pCi/g | | | |
| 09-02104-06 | TRG | UM-2009-02-06-03 | 02/17/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Manganese-54 | LANL ER-130 Modified | 2.02E-02 | 6.08E-02 | 6.08E-02 | 1.11E-01 | pCi/g | | | |
| 09-02104-07 | TRG | UM-2009-02-06-04 | 02/13/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cerium-139 | LANL ER-130 Modified | -1.17E-02 | 4.08E-02 | 4.08E-02 | 6.93E-02 | pCi/g | | | |
| 09-02104-07 | TRG | UM-2009-02-06-04 | 02/13/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cobalt-60 | LANL ER-130 Modified | -4.62E-02 | 8.18E-02 | 8.18E-02 | 1.32E-01 | pCi/g | | | |
| 09-02104-07 | TRG | UM-2009-02-06-04 | 02/13/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Cesium-134 | LANL ER-130 Modified | 7.58E-03 | 5.90E-02 | 5.90E-02 | 9.39E-02 | pCi/g | | | |
| 09-02104-07 | TRG | UM-2009-02-06-04 | 02/13/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Europium-152 | LANL ER-130 Modified | 3.87E-01 | 3.45E-01 | 3.45E-01 | 7.89E-01 | pCi/g | | | |
| 09-02104-07 | TRG | UM-2009-02-06-04 | 02/13/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Europium-154 | LANL ER-130 Modified | -6.13E-03 | 1.81E-01 | 1.81E-01 | 3.09E-01 | pCi/g | | | |
| 09-02104-07 | TRG | UM-2009-02-06-04 | 02/13/09 00:00 | 2/23/2009 | 2/24/2009 | 09-02104 | Manganese-54 | LANL ER-130 Modified | 5.79E-03 | 6.36E-02 | 6.36E-02 | 1.13E-01 | pCi/g | | | |

CU=Counting Uncertainty;CSU=Combined Standard Uncertainty (2-sigma);MDA=Minimal Detected Activity;LCS=Laboratory Control Sample; MBL=Blank; DUP=Duplicate; TRG=Normal Sample; DO=Duplicate Original



EBERLINE
SERVICES

EBERLINE ANALYTICAL CORPORATION

601 SCARBORO ROAD OAK RIDGE, TN 37830 865/481-0683 FAX 865/483-4621

Preliminary Data Report & Analytical Calculations
Work Order: 09-02104-Fe055-1

| Lab Fraction | Nuclide | Sample Desc | Client Identification | Activity Units | Results | Error Estimate | MDA | LSC Known | LCS %R | LCS Flag | RPD Flag | Sample Date | Sample Aliquot | Counting Date/Time | Identified |
|--------------|---------|-------------|-----------------------|----------------|-----------|----------------|----------|-----------|--------|----------|----------|----------------|----------------|--------------------|------------|
| 01 | AM-241 | LCS | LCS | pCi/g | 3.62E+03 | 4.35E+02 | 4.91E+00 | 3.73E+03 | 97.12 | OK | | 02/24/09 00:00 | 1.00E+00 | 02/24/09 12:48 | YES |
| 01 | CO-57 | LCS | LCS | pCi/g | 1.33E+03 | 1.35E+02 | 4.80E+00 | 1.18E+03 | 112.24 | OK | | 02/24/09 00:00 | 1.00E+00 | 02/24/09 12:48 | YES |
| 02 | FE-55 | MBL | BLANK | pCi/g | 4.29E+00 | 8.18E+00 | 9.13E+00 | | | | | 02/24/09 00:00 | 1.00E+00 | 02/24/09 13:22 | NO |
| 03 | FE-55 | DUP | UM-2008-12-17-01 | pCi/g | -7.20E-01 | 2.54E+00 | 3.86E+00 | | | | OK | 01/09/09 00:00 | 2.97E+01 | 02/24/09 14:22 | NO |
| 04 | FE-55 | DO | UM-2008-12-17-01 | pCi/g | -5.29E-01 | 2.43E+00 | 3.89E+00 | | | | | 01/09/09 00:00 | 2.97E+01 | 02/24/09 15:24 | NO |
| 05 | FE-55 | TRG | UM-2009-02-06-02 | pCi/g | -1.46E+00 | 3.24E+00 | 3.87E+00 | | | | | 02/11/09 00:00 | 3.05E+01 | 02/24/09 16:30 | NO |
| 06 | FE-55 | TRG | UM-2009-02-06-03 | pCi/g | -3.86E-01 | 2.07E+00 | 3.37E+00 | | | | | 02/17/09 00:00 | 3.61E+01 | 02/24/09 17:30 | NO |
| 07 | FE-55 | TRG | UM-2009-02-06-04 | pCi/g | -4.72E-01 | 2.55E+00 | 4.16E+00 | | | | | 02/13/09 00:00 | 2.86E+01 | 02/24/09 18:33 | NO |

Preliminary Data Report & Analytical Calculations
Work Order: 09-02104-Gamma-1

| Lab Fraction | Nuclide | Sample Desc | Client Identification | Activity Units | Results | Error Estimate | MDA | LSC Known | LCS %R | LCS Flag | RPD Flag | Sample Date | Sample Allquot | Counting Date/Time | Identified |
|--------------|---------|-------------|-----------------------|----------------|-----------|----------------|----------|-----------|--------|----------|----------|----------------|----------------|--------------------|------------|
| 01 | CO-60 | LCS | LCS | pCi/g | 1.30E+02 | 6.04E+00 | 5.22E-01 | 1.23E+02 | 105.11 | OK | | 02/24/09 00:00 | 1.00E+00 | 02/24/09 14:56 | YES |
| 01 | CS-137 | LCS | LCS | pCi/g | 8.15E+01 | 5.30E+00 | 4.71E-01 | 7.64E+01 | 106.69 | OK | | 02/24/09 00:00 | 1.00E+00 | 02/24/09 14:56 | YES |
| 02 | CE-139 | MBL | BLANK | pCi/g | -5.06E-03 | 1.76E-02 | 3.06E-02 | | | | | 02/24/09 00:00 | 1.00E+00 | 02/24/09 14:37 | NO |
| 02 | CO-60 | MBL | BLANK | pCi/g | -3.88E-03 | 3.63E-02 | 6.68E-02 | | | | | 02/24/09 00:00 | 1.00E+00 | 02/24/09 14:37 | NO |
| 02 | CS-134 | MBL | BLANK | pCi/g | 1.92E-02 | 3.02E-02 | 5.60E-02 | | | | | 02/24/09 00:00 | 1.00E+00 | 02/24/09 14:37 | NO |
| 02 | EU-152 | MBL | BLANK | pCi/g | -4.75E-02 | 1.70E-01 | 3.46E-01 | | | | | 02/24/09 00:00 | 1.00E+00 | 02/24/09 14:37 | NO |
| 02 | EU-154 | MBL | BLANK | pCi/g | -1.11E-02 | 8.19E-02 | 1.68E-01 | | | | | 02/24/09 00:00 | 1.00E+00 | 02/24/09 14:37 | NO |
| 02 | MN-54 | MBL | BLANK | pCi/g | 1.42E-02 | 2.83E-02 | 5.88E-02 | | | | | 02/24/09 00:00 | 1.00E+00 | 02/24/09 14:37 | NO |
| 03 | CE-139 | DUP | UM-2008-12-17-01 | pCi/g | -1.48E-02 | 2.81E-02 | 4.66E-02 | | | | | 01/09/09 00:00 | 7.17E+02 | 02/24/09 15:28 | NO |
| 03 | CO-60 | DUP | UM-2008-12-17-01 | pCi/g | 2.56E-02 | 3.11E-02 | 5.97E-02 | | | | INV | 01/09/09 00:00 | 7.17E+02 | 02/24/09 15:28 | NO |
| 03 | CS-134 | DUP | UM-2008-12-17-01 | pCi/g | 1.33E-03 | 2.30E-02 | 3.83E-02 | | | | INV | 01/09/09 00:00 | 7.17E+02 | 02/24/09 15:28 | NO |
| 03 | EU-152 | DUP | UM-2008-12-17-01 | pCi/g | -8.92E-02 | 2.08E-01 | 3.14E-01 | | | | | 01/09/09 00:00 | 7.17E+02 | 02/24/09 15:28 | NO |
| 03 | EU-154 | DUP | UM-2008-12-17-01 | pCi/g | 1.65E-02 | 7.33E-02 | 1.36E-01 | | | | OK | 01/09/09 00:00 | 7.17E+02 | 02/24/09 15:28 | NO |
| 03 | MN-54 | DUP | UM-2008-12-17-01 | pCi/g | 2.06E-02 | 2.71E-02 | 5.22E-02 | | | | | 01/09/09 00:00 | 7.17E+02 | 02/24/09 15:28 | NO |
| 04 | CE-139 | DO | UM-2008-12-17-01 | pCi/g | 1.30E-02 | 2.78E-02 | 4.83E-02 | | | | | 01/09/09 00:00 | 7.17E+02 | 02/24/09 16:33 | NO |
| 04 | CO-60 | DO | UM-2008-12-17-01 | pCi/g | 1.60E-03 | 2.77E-02 | 5.04E-02 | | | | | 01/09/09 00:00 | 7.17E+02 | 02/24/09 16:33 | NO |
| 04 | CS-134 | DO | UM-2008-12-17-01 | pCi/g | 5.21E-03 | 2.57E-02 | 4.30E-02 | | | | | 01/09/09 00:00 | 7.17E+02 | 02/24/09 16:33 | NO |
| 04 | EU-152 | DO | UM-2008-12-17-01 | pCi/g | 2.19E-01 | 2.23E-01 | 3.17E-01 | | | | | 01/09/09 00:00 | 7.17E+02 | 02/24/09 16:33 | NO |
| 04 | EU-154 | DO | UM-2008-12-17-01 | pCi/g | 2.12E-02 | 8.37E-02 | 1.53E-01 | | | | | 01/09/09 00:00 | 7.17E+02 | 02/24/09 16:33 | NO |
| 04 | MN-54 | DO | UM-2008-12-17-01 | pCi/g | 2.14E-02 | 2.82E-02 | 4.82E-02 | | | | | 01/09/09 00:00 | 7.17E+02 | 02/24/09 16:33 | YES |
| 05 | CE-139 | TRG | UM-2009-02-06-02 | pCi/g | -1.60E-02 | 2.34E-02 | 3.87E-02 | | | | | 02/11/09 00:00 | 6.73E+02 | 02/24/09 15:27 | NO |
| 05 | CO-60 | TRG | UM-2009-02-06-02 | pCi/g | 7.64E-02 | 3.19E-02 | 6.51E-02 | | | | | 02/11/09 00:00 | 6.73E+02 | 02/24/09 15:27 | YES |
| 05 | CS-134 | TRG | UM-2009-02-06-02 | pCi/g | 1.79E-02 | 3.03E-02 | 5.38E-02 | | | | | 02/11/09 00:00 | 6.73E+02 | 02/24/09 15:27 | NO |
| 05 | EU-152 | TRG | UM-2009-02-06-02 | pCi/g | 5.10E-01 | 1.19E-01 | 3.58E-01 | | | | | 02/11/09 00:00 | 6.73E+02 | 02/24/09 15:27 | YES |
| 05 | EU-154 | TRG | UM-2009-02-06-02 | pCi/g | -7.99E-02 | 1.08E-01 | 1.77E-01 | | | | | 02/11/09 00:00 | 6.73E+02 | 02/24/09 15:27 | NO |
| 05 | MN-54 | TRG | UM-2009-02-06-02 | pCi/g | -2.30E-04 | 2.90E-02 | 5.36E-02 | | | | | 02/11/09 00:00 | 6.73E+02 | 02/24/09 15:27 | NO |
| 06 | CE-139 | TRG | UM-2009-02-06-03 | pCi/g | 1.25E-02 | 4.03E-02 | 7.04E-02 | | | | | 02/17/09 00:00 | 6.82E+02 | 02/24/09 15:38 | NO |
| 06 | CO-60 | TRG | UM-2009-02-06-03 | pCi/g | 7.07E-02 | 8.29E-02 | 1.58E-01 | | | | | 02/17/09 00:00 | 6.82E+02 | 02/24/09 15:38 | NO |
| 06 | CS-134 | TRG | UM-2009-02-06-03 | pCi/g | 1.87E-02 | 6.21E-02 | 1.00E-01 | | | | | 02/17/09 00:00 | 6.82E+02 | 02/24/09 15:38 | NO |
| 06 | EU-152 | TRG | UM-2009-02-06-03 | pCi/g | 9.04E-01 | 5.11E-01 | 1.00E+00 | | | | | 02/17/09 00:00 | 6.82E+02 | 02/24/09 15:38 | NO |
| 06 | EU-154 | TRG | UM-2009-02-06-03 | pCi/g | -4.91E-02 | 1.61E-01 | 2.99E-01 | | | | | 02/17/09 00:00 | 6.82E+02 | 02/24/09 15:38 | NO |
| 06 | MN-54 | TRG | UM-2009-02-06-03 | pCi/g | 2.02E-02 | 6.08E-02 | 1.11E-01 | | | | | 02/17/09 00:00 | 6.82E+02 | 02/24/09 15:38 | NO |
| 07 | CE-139 | TRG | UM-2009-02-06-04 | pCi/g | -1.17E-02 | 4.08E-02 | 6.93E-02 | | | | | 02/13/09 00:00 | 6.61E+02 | 02/24/09 16:39 | NO |
| 07 | CO-60 | TRG | UM-2009-02-06-04 | pCi/g | -4.62E-02 | 8.18E-02 | 1.32E-01 | | | | | 02/13/09 00:00 | 6.61E+02 | 02/24/09 16:39 | NO |
| 07 | CS-134 | TRG | UM-2009-02-06-04 | pCi/g | 7.58E-03 | 5.90E-02 | 9.39E-02 | | | | | 02/13/09 00:00 | 6.61E+02 | 02/24/09 16:39 | NO |
| 07 | EU-152 | TRG | UM-2009-02-06-04 | pCi/g | 3.87E-01 | 3.48E-01 | 7.89E-01 | | | | | 02/13/09 00:00 | 6.61E+02 | 02/24/09 16:39 | NO |
| 07 | EU-154 | TRG | UM-2009-02-06-04 | pCi/g | -6.13E-03 | 1.81E-01 | 3.09E-01 | | | | | 02/13/09 00:00 | 6.61E+02 | 02/24/09 16:39 | NO |
| 07 | MN-54 | TRG | UM-2009-02-06-04 | pCi/g | 5.79E-03 | 6.36E-02 | 1.13E-01 | | | | | 02/13/09 00:00 | 6.61E+02 | 02/24/09 16:39 | NO |



Ford Nuclear Reactor Storage Ports - Final Disposition

Revision: 00

Appendix K

ORISE Confirmation Samples Collected by NRC

June 1, 2009

Mr. Jeremy Tapp
U.S. Nuclear Regulatory Commission
Region III
2443 Warrenville Road
Lisle, IL 60532-4351

**SUBJECT: ORISE CONTRACT NO. DE-AC05-06OR23100
LETTER REPORT FOR ANALYTICAL RESULTS FOR TWO SOIL
SAMPLES AND ONE CONCRETE SAMPLE FROM THE FORD
REACTOR AT THE UNIVERSITY OF MICHIGAN, ANN ARBOR,
MICHIGAN
[05000002/2009002] (RFTA NO. 09-001)
DCN: 1790-LR-01-0**

Dear Mr. Tapp:

The Oak Ridge Institute for Science and Education (ORISE) received two soil samples and one concrete sample on March 26, 2009. The samples were associated with the Ford Reactor at the University of Michigan in Ann Arbor, Michigan. The samples were analyzed by gamma spectroscopy for cobalt-60 with a requested detection limit of 0.4 pCi/g and for europium-152 with a requested detection limit of 1.0 pCi/g. Iron-55 (Fe-55) analysis was also requested with a detection limit of 1,000 pCi/g. The sample identifications are presented in Table 1, the data for gamma spectroscopy are presented in Table 2, and the Fe-55 data are presented in Table 3. The pertinent procedure references are included with the respective data tables.

This letter report was delayed due to analytical problems associated with the Fe-55 analysis. We apologize for the delay, but we believe this was necessary to achieve more defensible analytical results.

ORISE's Quality Control (QC) requirements were met for these analyses. The QC files are available for your review upon request.

My contact information is listed below. You may also contact Wade Ivey at 865.576.9184 with any questions or comments.

Sincerely,



Dale Condra, Manager
Laboratory

RDC:WPI:bf

Enclosures

c: T. Carter, NRC/FSME/DWMEP 7J18
T. Patterson, NRC/FSME/TWTFN 8D42
W. Snell, NRC Region III

E. Abelquist, ORISE
T. Vitkus, ORISE
File 1790

| Distribution approval and concurrence : | Initials |
|---|------------|
| Technical Review | <i>DC</i> |
| Quality Review | <i>TLB</i> |

TABLE 1

**SAMPLE IDENTIFICATIONS
AND COLLECTION DATA
FORD REACTOR
UNIVERSITY OF MICHIGAN
ANN ARBOR, MICHIGAN**

| ORISE Sample ID | NRC Region III Sample ID | Collection Date | Collection Time |
|----------------------------|-------------------------------------|------------------------|----------------------------|
| 1790S0001 | UOM-09-1-01 | 3/25/2009 | 11:12 AM |
| 1790S0002 | UOM-09-1-02 | 3/25/2009 | 11:27 AM |
| 1790M0001 | UOM-09-1-03 | 3/25/2009 | 12:15 PM |

TABLE 2

CONCENTRATIONS OF SELECTED
 GAMMA EMITTING RADIONUCLIDES
 IN SOIL AND CONCRETE SAMPLES
 BY GAMMA SPECTROSCOPY CP1, REVISION 16
 FORD REACTOR
 UNIVERSITY OF MICHIGAN
 ANN ARBOR, MICHIGAN

| ORISE Sample ID | NRC Region III Sample ID | Radionuclide Concentrations, TPUs, and MDCs ^a (pCi/g) | |
|--------------------|-----------------------------|---|-------------------|
| | | Co-60 | Eu-152 |
| 1790S0001 | UOM-09-1-01 | 0.03 ± 0.03 ^b , 0.03 | 0.02 ± 0.01, 0.03 |
| 1790S0002 | UOM-09-1-02 | 0.01 ± 0.02, 0.03 | 0.06 ± 0.02, 0.04 |
| 1790M0001 | UOM-09-1-03 | 0.04 ± 0.03, 0.05 | 0.08 ± 0.03, 0.06 |

^aThe MDCs are after the comma.

^bUncertainties represent the 95% confidence level, based on total propagated uncertainties.

TABLE 3

CONCENTRATIONS OF IRON-55
 IN SOIL AND CONCRETE SAMPLES
 BY LIQUID SCINTILLATION ANALYSIS
 AP16, REVISION 1; CP4, REVISION 3
 FORD REACTOR
 UNIVERSITY OF MICHIGAN
 ANN ARBOR, MICHIGAN

| ORISE Sample ID | NRC Region III Sample ID | Fe-55 Concentrations, TPUs, and MDCs ^a (pCi/g wet weight) |
|--------------------|-----------------------------|--|
| 1790S0001 | UOM-09-1-01 | 0.3 ± 1.4 ^b , 2.4 |
| 1790S0002 | UOM-09-1-02 | 0.7 ± 1.4, 2.4 |
| 1790M0001 | UOM-09-1-03 | 0.7 ± 1.3, 2.3 |

^aThe MDCs are after the comma.

^bUncertainties represent the 95% confidence level, based on total propagated uncertainties.

Appendix J:
Recordable Occurrence
Letter to the NRC in
Regard to the FNR Flood



February 14, 2013

Document Control Room
U.S. Nuclear Regulatory Commission
Two White Flint North
11545 Rockville Pike
(Mail Code: 03H8)
Rockville, Maryland 20852-2738

**RE: Reportable Occurrence # 24
Reactor Building Flood - Ruptured Fire Suppression Line
University of Michigan / Ford Nuclear Reactor
Reactor License R-28 / Docket 50-2
Technical Specification (Section 1.0 / Item 8)**

Decommissioning Branch / Materials Safety Branch:

In accordance with the University of Michigan (U-M) – Ford Nuclear Reactor (FNR) technical specifications [Section 6.7(2)(a)], the U-M is submitting this reportable occurrence report for a flooding event that occurred within the facility on Monday evening, January 28, 2013 at approximately 20:00 hours. The FNR (License R-28 / Docket 50-2) is a non-power reactor in the final stages of decommissioning (final status survey) and is currently an empty and gutted building. No licensed radioactive material was known to be released from the restricted area as a result of this event.

The U-M believes this flooding event may be a reportable occurrence as defined in the Technical Specifications (Section 1.0 / Definitions / 'Reportable Occurrence' / Item 8): *'Conditions arising from natural or man-made events that affect or threaten to affect the safe operation of the facility.'*

A NRC Region III Materials Safety inspector happened to be at the U-M the night of the flood and observed U-M staff handling the event at the FNR facility the next morning (Tuesday, January 29, 2013). That inspector reported his findings back to the Region III offices. In addition, the U-M Radiation Safety Officer notified the NRC Decommissioning Project Manager at NRC headquarters in Washington, D.C. about the flood event on Tuesday morning, January 29th.

On January 28th, a four inch fire suppression line ruptured in Room 2111 on the second floor of the reactor building. We believe the break occurred due to freeze/thaw weather experienced over the previous week, added to the lack of heat in the facility as the decommissioning process had removed all mechanical systems. Room 2111 is located over the north area of the reactor building first floor.

The rupture caused extensive flooding of the north portion of the first floor, the open area beneath the first floor where the reactor pool had been removed, and the reactor basement. The volume of water released from the fire suppression line was estimated to be 150,000 - 200,000 gallons and was based on an approximate flow rate of 4,000 - 5,000 gallons per minute for approximately 40 minutes. The time is estimated from the time it took for water to flow under the door separating the structure from the adjacent Phoenix Lab where workers noted it, to the time when maintenance staff actually turned off the water. A more accurate estimate of the total volume of water released was not possible because the fire suppression line was not metered.

Water from the ruptured fire suppression line was channeled by cutout areas of the first floor slab to the basement. The slab cutouts were created by the removal of imbedded piping earlier in the decommissioning process. The bulk of the water escaped through cuts in the first floor and basement floor slab where soil beneath the reactor building was exposed. No water was intentionally pumped-out into the sanitary sewer system from the FNR building, however, water did drain from the FNR basement into the connecting Phoenix building basement tunnel, eventually finding its way to the Phoenix sanitary sewer system and Phoenix retention tank pit area.

Soil / sediment from the exposed soils on the first floor & basement floor slab pipe trenches of the FNR was washed into the lower levels of the FNR basement and the base of the reactor pool / hold-up tank area.

It should be noted that a comprehensive final status survey was conducted by a decommissioning contractor between November 26 – December 12, 2012 and confirmatory FSS surveys were conducted by the NRC / ORAU consultants the week of December 3, 2012. No residual radioactivity above the established gross beta DCGL (5125 dpm/100 cm²) for structural surfaces was discovered during these FSS activities.

A comprehensive radiological survey was conducted after the flooding event using a final status survey (FSS) approach (survey scans, static readings, and swipes). The radiological survey revealed no contamination within the facility. The survey was conducted on all floor levels impacted by the flood water (2nd floor, 1st floor, and basement). A contamination survey conducted in the Phoenix basement tunnel also revealed no contamination. The swipes were counted using a liquid scintillation counter (LSC) and/or gas proportional counter (GPC) and no counts statistically above background were noted.

In addition, 3 water and 2 sediment/soil samples were collected from the impacted FNR basement and reactor pool hold-up tank area and analyzed using a sensitive HPGe gamma spectrometer. The HPGe system is calibrated to the same geometry (500 ml plastic bottles) as the samples counted. No contamination was identified in the water or soil/sediment samples. The minimum detectable activity (MDA) for the primary FNR sourced radionuclides of

interest (Co-60, Ag-108m, and Cs-137) in the water and soil/sediment samples were less than 0.1 pCi/ml and less than 0.1 pCi/g, respectively.

A ground water sample was collected on February 12, 2013 from a monitoring well located at the front (south end) of the Phoenix building. The screen length in this monitoring well is 5 feet (10-slot PVC). The perched water under the FNR and Phoenix buildings flows in a north-to-south direction. The static water level of this monitoring well was 38.88 feet below the top of the well casing, which corresponds to a groundwater elevation of 808.26 feet. This sample was analyzed using the HPGe gamma spectrometer. No reactor sourced contaminant isotopes were detected. The MDA was less than 0.1 pCi/ml for Co-60, Ag-108m and Cs-137.


It should also be noted that the expandable plug inserted into the foundation drain tile pipe located in the east wall of the FNR basement did not leak any of the flood water or sediment into the truncated drain tile pipe. In addition, when the drain tile plug was carefully removed, no water or sediment came into the FNR basement through the drain tile pipe.

After a post-flood follow-up conference call with the NRC decommissioning branch staff on February 13, 2013, a decision was made to obtain and analyze an additional four sediment / soil samples from the pipe trenches and near the former sump area. Split samples in these strategic locations will be collected so the NRC can have independent analyses of the samples conducted by the ORAU staff.

In accordance with Section 6.7 / Item #2 ('Non-Routine Reports') of the FNR Technical Specifications, corrective action to prevent recurrence of this flooding event included turning off the water to the fire suppression line in question and assessing other water lines within the FNR building. There is currently only one active water line in the FNR building; that line is located in the 1st floor stairwell, and the temperature in that area has never dropped below 36 degrees Fahrenheit in the past 4 years.

Thank you for your time and consideration with respect to this report. Please do not hesitate to contact me at OSEH / Radiation Safety Service (734) 647-2251 or 764-6200) should you have any questions or comments regarding this report or the flooding event.

Sincerely,



Mark L. Driscoll
Director / Radiation Safety Officer
OSEH / Radiation Safety Service

Appendix K:
Individual Survey Unit
Exposure Calculations

Calculated TEDE by Survey Unit Results

| Survey Unit | Class | MDC | Survey Unit Mean (dpm/100 cm ²) | Standard Deviation | DCGL | TEDE (mRem/year) | Calculated based on |
|-------------|-------|-------|--|--------------------|-------|------------------|---------------------|
| | | | | | | | |
| FNR - 1-1 | 1 | 1,087 | 717 | 343 | 5,125 | 5.30 | MDC |
| FNR - 1-10 | 1 | 1,336 | -801 | 953 | 5,125 | 6.52 | MDC |
| FNR - 1-11 | 2 | 1,514 | 354 | 436 | 5,125 | 7.39 | MDC |
| FNR - 1-12 | 1 | 1,336 | -308 | 611 | 5,125 | 6.52 | MDC |
| FNR - 1-13 | 1 | 1,313 | -164 | 1,059 | 5,125 | 6.41 | MDC |
| FNR - 1-14 | 2 | 1,336 | -528 | 255 | 5,125 | 6.52 | MDC |
| FNR - 1-15 | 2 | 1,336 | -56 | 434 | 5,125 | 6.52 | MDC |
| FNR - 1-16 | 1 | 1,336 | -473 | 207 | 5,125 | 6.52 | MDC |
| FNR - 1-17 | 1 | 1,074 | -70 | 325 | 5,125 | 5.24 | MDC |
| FNR - 1-18 | 2 | 1,074 | 119 | 218 | 5,125 | 5.24 | MDC |
| FNR - 1-2 | 1 | 1,313 | 263 | 320 | 5,125 | 6.41 | MDC |
| FNR - 1-3 | 1 | 1,313 | 413 | 462 | 5,125 | 6.41 | MDC |
| FNR - 1-4 | 1 | 1,087 | 630 | 241 | 5,125 | 5.30 | MDC |
| FNR - 1-5 | 1 | 1,105 | 215 | 806 | 5,125 | 5.39 | MDC |
| FNR - 1-6 | 1 | 1,105 | -5 | 296 | 5,125 | 5.39 | MDC |
| FNR - 1-7 | 1 | 1,105 | 286 | 496 | 5,125 | 5.39 | MDC |
| FNR - 1-8 | 1 | 1,105 | -140 | 271 | 5,125 | 5.39 | MDC |
| FNR - 1-9 | 1 | 1,105 | -121 | 352 | 5,125 | 5.39 | MDC |
| FNR - 2-1 | 2 | 1,105 | 126 | 325 | 5,125 | 5.39 | MDC |
| FNR - 2-10 | 2 | 1,514 | 533 | 640 | 5,125 | 7.39 | MDC |
| FNR - 2-11 | 2 | 1,413 | 898 | 782 | 5,125 | 6.89 | MDC |
| FNR - 2-12 | 1 | 1,514 | 947 | 495 | 5,125 | 7.39 | MDC |
| FNR - 2-13 | 2 | 1,514 | 371 | 544 | 5,125 | 7.39 | MDC |
| FNR - 2-2 | 1 | 1,087 | 469 | 283 | 5,125 | 5.30 | MDC |
| FNR - 2-3 | 1 | 1,105 | 75 | 579 | 5,125 | 5.39 | MDC |
| FNR - 2-4 | 2 | 1,141 | 205 | 458 | 5,125 | 5.56 | MDC |
| FNR - 2-5 | 2 | 1,141 | 454 | 456 | 5,125 | 5.56 | MDC |
| FNR - 2-6 | 2 | 1,105 | 236 | 388 | 5,125 | 5.39 | MDC |
| FNR - 2-7 | 1 | 1,105 | 501 | 321 | 5,125 | 5.39 | MDC |
| FNR - 2-8 | 2 | 1,105 | 217 | 340 | 5,125 | 5.39 | MDC |
| FNR - 2-9 | 2 | 1,105 | 264 | 345 | 5,125 | 5.39 | MDC |
| FNR - 3-1 | 2 | 1,105 | 507 | 488 | 5,125 | 5.39 | MDC |
| FNR - 3-10 | 2 | 1,141 | 191 | 472 | 5,125 | 5.56 | MDC |
| FNR - 3-11 | 1 | 1,087 | 671 | 156 | 5,125 | 5.30 | MDC |
| FNR - 3-12 | 1 | 1,336 | -523 | 347 | 5,125 | 6.52 | MDC |
| FNR - 3-13 | 1 | 1,105 | -345 | 304 | 5,125 | 5.39 | MDC |
| FNR - 3-14 | 2 | 1,336 | -211 | 370 | 5,125 | 6.52 | MDC |
| FNR - 3-15 | 1 | 1,087 | 777 | 560 | 5,125 | 5.30 | MDC |
| FNR - 3-16 | 2 | 1,074 | 75 | 396 | 5,125 | 5.24 | MDC |
| FNR - 3-2 | 2 | 1,105 | 712 | 409 | 5,125 | 5.39 | MDC |
| FNR - 3-3 | 1 | 1,141 | 857 | 335 | 5,125 | 5.56 | MDC |
| FNR - 3-4 | 2 | 1,141 | 497 | 556 | 5,125 | 5.56 | MDC |
| FNR - 3-5 | 1 | 1,105 | 528 | 490 | 5,125 | 5.39 | MDC |
| FNR - 3-6 | 2 | 1,105 | 324 | 327 | 5,125 | 5.39 | MDC |
| FNR - 3-7 | 1 | 1,514 | 293 | 437 | 5,125 | 7.39 | MDC |

Calculated TEDE by Survey Unit Results

| Survey Unit | Class | MDC | Survey Unit Mean | Standard Deviation | DCGL | TEDE (mRem/year) | Calculated based on |
|--------------|-------|-------|------------------|--------------------|-------|------------------|---------------------|
| | | | | | | | |
| FNR - 3-8 | 2 | 1,514 | 524 | 537 | 5,125 | 7.39 | MDC |
| FNR - 3-9 | 1 | 1,141 | 400 | 495 | 5,125 | 5.56 | MDC |
| FNR - 4-1 | 3 | 1,371 | 846 | 802 | 5,125 | 6.69 | MDC |
| FNR - 4-2 | 1 | 888 | 550 | 656 | 5,125 | 4.33 | MDC |
| FNR - B-1 | 1 | 1,087 | 287 | 247 | 5,125 | 5.30 | MDC |
| FNR - B-2 | 1 | 1,313 | 195 | 305 | 5,125 | 6.41 | MDC |
| FNR - B-3 | 1 | 1,313 | 181 | 363 | 5,125 | 6.41 | MDC |
| FNR - B-4 | 1 | 1,313 | -379 | 367 | 5,125 | 6.41 | MDC |
| FNR - B-5 | 1 | 1,336 | -142 | 353 | 5,125 | 6.52 | MDC |
| FNR - B-6 | 2 | 1,105 | 93 | 285 | 5,125 | 5.39 | MDC |
| FNR - Misc-1 | 1 | 888 | 12 | 213 | 5,125 | 4.33 | MDC |
| FNR - Misc-2 | 1 | 1,087 | 1,867 | 1,218 | 5,125 | 9.11 | Average Activity |
| FNR - R&O-1 | 3 | 888 | 1,356 | 296 | 5,125 | 6.61 | Average Activity |
| FNR - R&O-2 | 1 | 1,087 | 573 | 474 | 5,125 | 5.30 | MDC |
| FNR - S-1 | 3 | 1,105 | 79 | 525 | 5,125 | 5.39 | MDC |
| FNR - S-2 | 2 | 1,105 | 178 | 450 | 5,125 | 5.39 | MDC |
| FNR - S-3 | 3 | 1,105 | 365 | 529 | 5,125 | 5.39 | MDC |
| FNR - S-4 | 1 | 1,371 | 853 | 606 | 5,125 | 6.69 | MDC |
| FNR - S-5 | 2 | 1,371 | 654 | 539 | 5,125 | 6.69 | MDC |

Appendix L:
RESRAD Output Reports
for Foundation Drain Tile

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Table of Contents

I: Mixture Sums and Single Radionuclide Guidelines

| | |
|--|----|
| Dose Conversion Factor (and Related) Parameter Summary ... | 2 |
| Site-Specific Parameter Summary | 4 |
| Summary of Pathway Selections | 9 |
| Contaminated Zone and Total Dose Summary | 10 |
| Total Dose Components | |
| Time = 0.000E+00 | 11 |
| Time = 1.000E+00 | 12 |
| Time = 3.000E+00 | 13 |
| Time = 1.000E+01 | 14 |
| Time = 3.000E+01 | 15 |
| Time = 1.000E+02 | 16 |
| Time = 3.000E+02 | 17 |
| Time = 1.000E+03 | 18 |
| Dose/Source Ratios Summed Over All Pathways | 19 |
| Single Radionuclide Soil Guidelines | 19 |
| Dose Per Nuclide Summed Over All Pathways | 20 |
| Soil Concentration Per Nuclide | 20 |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Dose Conversion Factor (and Related) Parameter Summary

Dose Library: FGR 12 & FGR 11

| Menu | Parameter | Current Value# | Base Case* | Parameter Name |
|------|---|----------------|------------|----------------|
| A-1 | DCF's for external ground radiation, (mrem/yr)/(pCi/g) | | | |
| A-1 | Ag-108 (Source: FGR 12) | 1.143E-01 | 1.143E-01 | DCF1(1) |
| A-1 | Ag-108m (Source: FGR 12) | 9.640E+00 | 9.640E+00 | DCF1(2) |
| A-1 | Ba-137m (Source: FGR 12) | 3.606E+00 | 3.606E+00 | DCF1(3) |
| A-1 | C-14 (Source: FGR 12) | 1.345E-05 | 1.345E-05 | DCF1(4) |
| A-1 | Co-60 (Source: FGR 12) | 1.622E+01 | 1.622E+01 | DCF1(5) |
| A-1 | Cs-137 (Source: FGR 12) | 7.510E-04 | 7.510E-04 | DCF1(6) |
| A-1 | Eu-152 (Source: FGR 12) | 7.006E+00 | 7.006E+00 | DCF1(7) |
| A-1 | Gd-152 (Source: FGR 12) | 0.000E+00 | 0.000E+00 | DCF1(8) |
| A-1 | H-3 (Source: FGR 12) | 0.000E+00 | 0.000E+00 | DCF1(9) |
| B-1 | Dose conversion factors for inhalation, mrem/pCi: | | | |
| B-1 | Ag-108m+D | 2.830E-04 | 2.830E-04 | DCF2(1) |
| B-1 | C-14(p) (Class: ORGANIC) | 2.090E-06 | 2.090E-06 | DCF2(2) |
| B-1 | C-14(g) (Class: CO2) | 2.350E-08 | 2.350E-08 | C14GInhDCF |
| B-1 | Co-60 | 2.190E-04 | 2.190E-04 | DCF2(3) |
| B-1 | Cs-137+D | 3.190E-05 | 3.190E-05 | DCF2(4) |
| B-1 | Eu-152 | 2.210E-04 | 2.210E-04 | DCF2(5) |
| B-1 | Gd-152 | 2.430E-01 | 2.430E-01 | DCF2(7) |
| B-1 | H-3 | 6.400E-08 | 6.400E-08 | DCF2(8) |
| D-1 | Dose conversion factors for ingestion, mrem/pCi: | | | |
| D-1 | Ag-108m+D | 7.620E-06 | 7.620E-06 | DCF3(1) |
| D-1 | C-14 | 2.090E-06 | 2.090E-06 | DCF3(2) |
| D-1 | Co-60 | 2.690E-05 | 2.690E-05 | DCF3(3) |
| D-1 | Cs-137+D | 5.000E-05 | 5.000E-05 | DCF3(4) |
| D-1 | Eu-152 | 6.480E-06 | 6.480E-06 | DCF3(5) |
| D-1 | Gd-152 | 1.610E-04 | 1.610E-04 | DCF3(7) |
| D-1 | H-3 | 6.400E-08 | 6.400E-08 | DCF3(8) |
| D-34 | Food transfer factors: | | | |
| D-34 | Ag-108m+D , plant/soil concentration ratio, dimensionless | 1.500E-01 | 1.500E-01 | RTF(1,1) |
| D-34 | Ag-108m+D , beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 3.000E-03 | 3.000E-03 | RTF(1,2) |
| D-34 | Ag-108m+D , milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 2.500E-02 | 2.500E-02 | RTF(1,3) |
| D-34 | | | | |
| D-34 | C-14 , plant/soil concentration ratio, dimensionless | 5.500E+00 | 5.500E+00 | RTF(2,1) |
| D-34 | C-14 , beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 3.100E-02 | 3.100E-02 | RTF(2,2) |
| D-34 | C-14 , milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 1.200E-02 | 1.200E-02 | RTF(2,3) |
| D-34 | | | | |
| D-34 | Co-60 , plant/soil concentration ratio, dimensionless | 8.000E-02 | 8.000E-02 | RTF(3,1) |
| D-34 | Co-60 , beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 2.000E-02 | 2.000E-02 | RTF(3,2) |
| D-34 | Co-60 , milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 2.000E-03 | 2.000E-03 | RTF(3,3) |
| D-34 | | | | |
| D-34 | Cs-137+D , plant/soil concentration ratio, dimensionless | 4.000E-02 | 4.000E-02 | RTF(4,1) |
| D-34 | Cs-137+D , beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 3.000E-02 | 3.000E-02 | RTF(4,2) |
| D-34 | Cs-137+D , milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 8.000E-03 | 8.000E-03 | RTF(4,3) |
| D-34 | | | | |
| D-34 | Eu-152 , plant/soil concentration ratio, dimensionless | 2.500E-03 | 2.500E-03 | RTF(5,1) |
| D-34 | Eu-152 , beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 2.000E-03 | 2.000E-03 | RTF(5,2) |
| D-34 | Eu-152 , milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 5.000E-05 | 5.000E-05 | RTF(5,3) |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Dose Conversion Factor (and Related) Parameter Summary (continued)

Dose Library: FGR 12 & FGR 11

| Menu | Parameter | Current Value# | Base Case* | Parameter Name |
|------|--|----------------|------------|----------------|
| D-34 | Gd-152 , plant/soil concentration ratio, dimensionless | 2.500E-03 | 2.500E-03 | RTF(7,1) |
| D-34 | Gd-152 , beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 2.000E-03 | 2.000E-03 | RTF(7,2) |
| D-34 | Gd-152 , milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 2.000E-05 | 2.000E-05 | RTF(7,3) |
| D-34 | | | | |
| D-34 | H-3 , plant/soil concentration ratio, dimensionless | 4.800E+00 | 4.800E+00 | RTF(8,1) |
| D-34 | H-3 , beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 1.200E-02 | 1.200E-02 | RTF(8,2) |
| D-34 | H-3 , milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 1.000E-02 | 1.000E-02 | RTF(8,3) |
| D-34 | | | | |
| D-5 | Bioaccumulation factors, fresh water, L/kg: | | | |
| D-5 | Ag-108m+D , fish | 5.000E+00 | 5.000E+00 | BIOFAC(1,1) |
| D-5 | Ag-108m+D , crustacea and mollusks | 7.700E+02 | 7.700E+02 | BIOFAC(1,2) |
| D-5 | | | | |
| D-5 | C-14 , fish | 5.000E+04 | 5.000E+04 | BIOFAC(2,1) |
| D-5 | C-14 , crustacea and mollusks | 9.100E+03 | 9.100E+03 | BIOFAC(2,2) |
| D-5 | | | | |
| D-5 | Co-60 , fish | 3.000E+02 | 3.000E+02 | BIOFAC(3,1) |
| D-5 | Co-60 , crustacea and mollusks | 2.000E+02 | 2.000E+02 | BIOFAC(3,2) |
| D-5 | | | | |
| D-5 | Cs-137+D , fish | 2.000E+03 | 2.000E+03 | BIOFAC(4,1) |
| D-5 | Cs-137+D , crustacea and mollusks | 1.000E+02 | 1.000E+02 | BIOFAC(4,2) |
| D-5 | | | | |
| D-5 | Eu-152 , fish | 5.000E+01 | 5.000E+01 | BIOFAC(5,1) |
| D-5 | Eu-152 , crustacea and mollusks | 1.000E+03 | 1.000E+03 | BIOFAC(5,2) |
| D-5 | | | | |
| D-5 | Gd-152 , fish | 2.500E+01 | 2.500E+01 | BIOFAC(7,1) |
| D-5 | Gd-152 , crustacea and mollusks | 1.000E+03 | 1.000E+03 | BIOFAC(7,2) |
| D-5 | | | | |
| D-5 | H-3 , fish | 1.000E+00 | 1.000E+00 | BIOFAC(8,1) |
| D-5 | H-3 , crustacea and mollusks | 1.000E+00 | 1.000E+00 | BIOFAC(8,2) |

#For DCF1(XXX) only, factors are for infinite depth & area. See ETEG table in Ground Pathway of Detailed Report.

*Base Case means Default.Lib w/o Associate Nuclide contributions.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Site-Specific Parameter Summary

| Menu | Parameter | User Input | Default | Used by RESRAD (If different from user input) | Parameter Name |
|------|---|------------|-----------|--|----------------|
| R011 | Area of contaminated zone (m*2) | 5.000E+01 | 1.000E+04 | --- | AREA |
| R011 | Thickness of contaminated zone (m) | 1.000E+00 | 2.000E+00 | --- | THICK0 |
| R011 | Fraction of contamination that is submerged | 0.000E+00 | 0.000E+00 | --- | SUBMFRACT |
| R011 | Length parallel to aquifer flow (m) | not used | 1.000E+02 | --- | LCZPAQ |
| R011 | Basic radiation dose limit (mrem/yr) | 2.500E+01 | 3.000E+01 | --- | BRDL |
| R011 | Time since placement of material (yr) | 0.000E+00 | 0.000E+00 | --- | TI |
| R011 | Times for calculations (yr) | 1.000E+00 | 1.000E+00 | --- | T (2) |
| R011 | Times for calculations (yr) | 3.000E+00 | 3.000E+00 | --- | T (3) |
| R011 | Times for calculations (yr) | 1.000E+01 | 1.000E+01 | --- | T (4) |
| R011 | Times for calculations (yr) | 3.000E+01 | 3.000E+01 | --- | T (5) |
| R011 | Times for calculations (yr) | 1.000E+02 | 1.000E+02 | --- | T (6) |
| R011 | Times for calculations (yr) | 3.000E+02 | 3.000E+02 | --- | T (7) |
| R011 | Times for calculations (yr) | 1.000E+03 | 1.000E+03 | --- | T (8) |
| R011 | Times for calculations (yr) | not used | 0.000E+00 | --- | T (9) |
| R011 | Times for calculations (yr) | not used | 0.000E+00 | --- | T(10) |
| R012 | Initial principal radionuclide (pCi/g): Ag-108m | 4.760E+01 | 0.000E+00 | --- | S1(1) |
| R012 | Initial principal radionuclide (pCi/g): C-14 | 1.020E+01 | 0.000E+00 | --- | S1(2) |
| R012 | Initial principal radionuclide (pCi/g): Co-60 | 3.300E+00 | 0.000E+00 | --- | S1(3) |
| R012 | Initial principal radionuclide (pCi/g): Cs-137 | 2.000E+00 | 0.000E+00 | --- | S1(4) |
| R012 | Initial principal radionuclide (pCi/g): Eu-152 | 6.000E-01 | 0.000E+00 | --- | S1(5) |
| R012 | Initial principal radionuclide (pCi/g): H-3 | 1.900E+00 | 0.000E+00 | --- | S1(8) |
| R012 | Concentration in groundwater (pCi/L): Ag-108m | not used | 0.000E+00 | --- | W1(1) |
| R012 | Concentration in groundwater (pCi/L): C-14 | not used | 0.000E+00 | --- | W1(2) |
| R012 | Concentration in groundwater (pCi/L): Co-60 | not used | 0.000E+00 | --- | W1(3) |
| R012 | Concentration in groundwater (pCi/L): Cs-137 | not used | 0.000E+00 | --- | W1(4) |
| R012 | Concentration in groundwater (pCi/L): Eu-152 | not used | 0.000E+00 | --- | W1(5) |
| R012 | Concentration in groundwater (pCi/L): H-3 | not used | 0.000E+00 | --- | W1(8) |
| R013 | Cover depth (m) | 5.000E+00 | 0.000E+00 | --- | COVER0 |
| R013 | Density of cover material (g/cm*3) | 1.500E+00 | 1.500E+00 | --- | DENSCV |
| R013 | Cover depth erosion rate (m/yr) | 1.000E-03 | 1.000E-03 | --- | VCV |
| R013 | Density of contaminated zone (g/cm*3) | 1.500E+00 | 1.500E+00 | --- | DENSCZ |
| R013 | Contaminated zone erosion rate (m/yr) | 1.000E-03 | 1.000E-03 | --- | VCZ |
| R013 | Contaminated zone total porosity | 4.000E-01 | 4.000E-01 | --- | TPCZ |
| R013 | Contaminated zone field capacity | 2.000E-01 | 2.000E-01 | --- | FCCZ |
| R013 | Contaminated zone hydraulic conductivity (m/yr) | 1.000E+01 | 1.000E+01 | --- | HCCZ |
| R013 | Contaminated zone b parameter | 5.300E+00 | 5.300E+00 | --- | BCZ |
| R013 | Average annual wind speed (m/sec) | 2.000E+00 | 2.000E+00 | --- | WIND |
| R013 | Humidity in air (g/m*3) | 8.000E+00 | 8.000E+00 | --- | HUMID |
| R013 | Evapotranspiration coefficient | 5.000E-01 | 5.000E-01 | --- | EVAPTR |
| R013 | Precipitation (m/yr) | 1.000E+00 | 1.000E+00 | --- | PRECIP |
| R013 | Irrigation (m/yr) | 2.000E-01 | 2.000E-01 | --- | RI |
| R013 | Irrigation mode | overhead | overhead | --- | IDITCH |
| R013 | Runoff coefficient | 2.000E-01 | 2.000E-01 | --- | RUNOFF |
| R013 | Watershed area for nearby stream or pond (m*2) | not used | 1.000E+06 | --- | WAREA |
| R013 | Accuracy for water/soil computations | not used | 1.000E-03 | --- | EPS |
| R014 | Density of saturated zone (g/cm*3) | not used | 1.500E+00 | --- | DENSAQ |
| R014 | Saturated zone total porosity | not used | 4.000E-01 | --- | TPSZ |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Site-Specific Parameter Summary (continued)

| Menu | Parameter | User Input | Default | Used by RESRAD (If different from user input) | Parameter Name |
|------|--|------------|-----------|--|----------------|
| R014 | Saturated zone effective porosity | not used | 2.000E-01 | --- | EPSZ |
| R014 | Saturated zone field capacity | not used | 2.000E-01 | --- | FCSZ |
| R014 | Saturated zone hydraulic conductivity (m/yr) | not used | 1.000E+02 | --- | HCSZ |
| R014 | Saturated zone hydraulic gradient | not used | 2.000E-02 | --- | HGWT |
| R014 | Saturated zone b parameter | not used | 5.300E+00 | --- | BSZ |
| R014 | Water table drop rate (m/yr) | not used | 1.000E-03 | --- | VWT |
| R014 | Well pump intake depth (m below water table) | not used | 1.000E+01 | --- | DWIBWT |
| R014 | Model: Nondispersion (ND) or Mass-Balance (MB) | not used | ND | --- | MODEL |
| R014 | Well pumping rate (m ³ /yr) | not used | 2.500E+02 | --- | UW |
| R015 | Number of unsaturated zone strata | not used | 1 | --- | NS |
| R015 | Unsat. zone 1, thickness (m) | not used | 4.000E+00 | --- | H(1) |
| R015 | Unsat. zone 1, soil density (g/cm ³) | not used | 1.500E+00 | --- | DENSUZ(1) |
| R015 | Unsat. zone 1, total porosity | not used | 4.000E-01 | --- | TPUZ(1) |
| R015 | Unsat. zone 1, effective porosity | not used | 2.000E-01 | --- | EPUZ(1) |
| R015 | Unsat. zone 1, field capacity | not used | 2.000E-01 | --- | FCUZ(1) |
| R015 | Unsat. zone 1, soil-specific b parameter | not used | 5.300E+00 | --- | BUZ(1) |
| R015 | Unsat. zone 1, hydraulic conductivity (m/yr) | not used | 1.000E+01 | --- | HCUZ(1) |
| R016 | Distribution coefficients for Ag-108m | | | | |
| R016 | Contaminated zone (cm ³ /g) | 0.000E+00 | 0.000E+00 | --- | DCNUCC(1) |
| R016 | Unsat. zone 1 (cm ³ /g) | not used | 0.000E+00 | --- | DCNUCU(1,1) |
| R016 | Saturated zone (cm ³ /g) | not used | 0.000E+00 | --- | DCNUCS(1) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 1.558E+00 | ALEACH(1) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(1) |
| R016 | Distribution coefficients for C-14 | | | | |
| R016 | Contaminated zone (cm ³ /g) | 0.000E+00 | 0.000E+00 | --- | DCNUCC(2) |
| R016 | Unsat. zone 1 (cm ³ /g) | not used | 0.000E+00 | --- | DCNUCU(2,1) |
| R016 | Saturated zone (cm ³ /g) | not used | 0.000E+00 | --- | DCNUCS(2) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 1.558E+00 | ALEACH(2) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(2) |
| R016 | Distribution coefficients for Co-60 | | | | |
| R016 | Contaminated zone (cm ³ /g) | 1.000E+03 | 1.000E+03 | --- | DCNUCC(3) |
| R016 | Unsat. zone 1 (cm ³ /g) | not used | 1.000E+03 | --- | DCNUCU(3,1) |
| R016 | Saturated zone (cm ³ /g) | not used | 1.000E+03 | --- | DCNUCS(3) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 3.333E-04 | ALEACH(3) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(3) |
| R016 | Distribution coefficients for Cs-137 | | | | |
| R016 | Contaminated zone (cm ³ /g) | 4.600E+03 | 4.600E+03 | --- | DCNUCC(4) |
| R016 | Unsat. zone 1 (cm ³ /g) | not used | 4.600E+03 | --- | DCNUCU(4,1) |
| R016 | Saturated zone (cm ³ /g) | not used | 4.600E+03 | --- | DCNUCS(4) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 7.246E-05 | ALEACH(4) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(4) |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Site-Specific Parameter Summary (continued)

| Menu | Parameter | User Input | Default | Used by RESRAD (If different from user input) | Parameter Name |
|------|--|------------|------------|--|----------------|
| R016 | Distribution coefficients for Eu-152 | | | | |
| R016 | Contaminated zone (cm**3/g) | -1.000E+00 | -1.000E+00 | 8.249E+02 | DCNUCC(5) |
| R016 | Unsaturated zone 1 (cm**3/g) | not used | -1.000E+00 | --- | DCNUCU(5,1) |
| R016 | Saturated zone (cm**3/g) | not used | -1.000E+00 | --- | DCNUCS(5) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 4.040E-04 | ALEACH(5) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(5) |
| R016 | Distribution coefficients for H-3 | | | | |
| R016 | Contaminated zone (cm**3/g) | 0.000E+00 | 0.000E+00 | --- | DCNUCC(8) |
| R016 | Unsaturated zone 1 (cm**3/g) | not used | 0.000E+00 | --- | DCNUCU(8,1) |
| R016 | Saturated zone (cm**3/g) | not used | 0.000E+00 | --- | DCNUCS(8) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 1.558E+00 | ALEACH(8) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(8) |
| R016 | Distribution coefficients for daughter Gd-152 | | | | |
| R016 | Contaminated zone (cm**3/g) | -1.000E+00 | -1.000E+00 | 8.249E+02 | DCNUCC(7) |
| R016 | Unsaturated zone 1 (cm**3/g) | not used | -1.000E+00 | --- | DCNUCU(7,1) |
| R016 | Saturated zone (cm**3/g) | not used | -1.000E+00 | --- | DCNUCS(7) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 4.040E-04 | ALEACH(7) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(7) |
| R017 | Inhalation rate (m**3/yr) | 1.140E+04 | 8.400E+03 | --- | INHALR |
| R017 | Mass loading for inhalation (g/m**3) | 1.000E-04 | 1.000E-04 | --- | MLINH |
| R017 | Exposure duration | 2.500E+01 | 3.000E+01 | --- | ED |
| R017 | Shielding factor, inhalation | 4.000E-01 | 4.000E-01 | --- | SHF3 |
| R017 | Shielding factor, external gamma | 7.000E-01 | 7.000E-01 | --- | SHF1 |
| R017 | Fraction of time spent indoors | 5.710E-02 | 5.000E-01 | --- | FIND |
| R017 | Fraction of time spent outdoors (on site) | 5.710E-02 | 2.500E-01 | --- | FOTD |
| R017 | Shape factor flag, external gamma | 1.000E+00 | 1.000E+00 | >0 shows circular AREA. | FS |
| R017 | Radii of shape factor array (used if FS = -1): | | | | |
| R017 | Outer annular radius (m), ring 1: | not used | 5.000E+01 | --- | RAD_SHAPE(1) |
| R017 | Outer annular radius (m), ring 2: | not used | 7.071E+01 | --- | RAD_SHAPE(2) |
| R017 | Outer annular radius (m), ring 3: | not used | 0.000E+00 | --- | RAD_SHAPE(3) |
| R017 | Outer annular radius (m), ring 4: | not used | 0.000E+00 | --- | RAD_SHAPE(4) |
| R017 | Outer annular radius (m), ring 5: | not used | 0.000E+00 | --- | RAD_SHAPE(5) |
| R017 | Outer annular radius (m), ring 6: | not used | 0.000E+00 | --- | RAD_SHAPE(6) |
| R017 | Outer annular radius (m), ring 7: | not used | 0.000E+00 | --- | RAD_SHAPE(7) |
| R017 | Outer annular radius (m), ring 8: | not used | 0.000E+00 | --- | RAD_SHAPE(8) |
| R017 | Outer annular radius (m), ring 9: | not used | 0.000E+00 | --- | RAD_SHAPE(9) |
| R017 | Outer annular radius (m), ring 10: | not used | 0.000E+00 | --- | RAD_SHAPE(10) |
| R017 | Outer annular radius (m), ring 11: | not used | 0.000E+00 | --- | RAD_SHAPE(11) |
| R017 | Outer annular radius (m), ring 12: | not used | 0.000E+00 | --- | RAD_SHAPE(12) |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Site-Specific Parameter Summary (continued)

| Menu | Parameter | User Input | Default | Used by RESRAD (if different from user input) | Parameter Name |
|------|--|------------|-----------|--|----------------|
| R017 | Fractions of annular areas within AREA: | | | | |
| R017 | Ring 1 | not used | 1.000E+00 | --- | FRACA(1) |
| R017 | Ring 2 | not used | 2.732E-01 | --- | FRACA(2) |
| R017 | Ring 3 | not used | 0.000E+00 | --- | FRACA(3) |
| R017 | Ring 4 | not used | 0.000E+00 | --- | FRACA(4) |
| R017 | Ring 5 | not used | 0.000E+00 | --- | FRACA(5) |
| R017 | Ring 6 | not used | 0.000E+00 | --- | FRACA(6) |
| R017 | Ring 7 | not used | 0.000E+00 | --- | FRACA(7) |
| R017 | Ring 8 | not used | 0.000E+00 | --- | FRACA(8) |
| R017 | Ring 9 | not used | 0.000E+00 | --- | FRACA(9) |
| R017 | Ring 10 | not used | 0.000E+00 | --- | FRACA(10) |
| R017 | Ring 11 | not used | 0.000E+00 | --- | FRACA(11) |
| R017 | Ring 12 | not used | 0.000E+00 | --- | FRACA(12) |
| R018 | Fruits, vegetables and grain consumption (kg/yr) | not used | 1.600E+02 | --- | DIET(1) |
| R018 | Leafy vegetable consumption (kg/yr) | not used | 1.400E+01 | --- | DIET(2) |
| R018 | Milk consumption (L/yr) | not used | 9.200E+01 | --- | DIET(3) |
| R018 | Meat and poultry consumption (kg/yr) | not used | 6.300E+01 | --- | DIET(4) |
| R018 | Fish consumption (kg/yr) | not used | 5.400E+00 | --- | DIET(5) |
| R018 | Other seafood consumption (kg/yr) | not used | 9.000E-01 | --- | DIET(6) |
| R018 | Soil ingestion rate (g/yr) | 0.000E+00 | 3.650E+01 | --- | SOIL |
| R018 | Drinking water intake (L/yr) | not used | 5.100E+02 | --- | DWI |
| R018 | Contamination fraction of drinking water | not used | 1.000E+00 | --- | FDW |
| R018 | Contamination fraction of household water | not used | 1.000E+00 | --- | FHHW |
| R018 | Contamination fraction of livestock water | not used | 1.000E+00 | --- | FLW |
| R018 | Contamination fraction of irrigation water | not used | 1.000E+00 | --- | FIRW |
| R018 | Contamination fraction of aquatic food | not used | 5.000E-01 | --- | FR9 |
| R018 | Contamination fraction of plant food | not used | -1 | --- | FPLANT |
| R018 | Contamination fraction of meat | not used | -1 | --- | FMEAT |
| R018 | Contamination fraction of milk | not used | -1 | --- | FMILK |
| R019 | Livestock fodder intake for meat (kg/day) | not used | 6.800E+01 | --- | LF15 |
| R019 | Livestock fodder intake for milk (kg/day) | not used | 5.500E+01 | --- | LF16 |
| R019 | Livestock water intake for meat (L/day) | not used | 5.000E+01 | --- | LWI5 |
| R019 | Livestock water intake for milk (L/day) | not used | 1.600E+02 | --- | LWI6 |
| R019 | Livestock soil intake (kg/day) | not used | 5.000E-01 | --- | LSI |
| R019 | Mass loading for foliar deposition (g/m ² *3) | not used | 1.000E-04 | --- | MLFD |
| R019 | Depth of soil mixing layer (m) | 1.500E-01 | 1.500E-01 | --- | DM |
| R019 | Depth of roots (m) | not used | 9.000E-01 | --- | DROOT |
| R019 | Drinking water fraction from ground water | not used | 1.000E+00 | --- | FGWDW |
| R019 | Household water fraction from ground water | not used | 1.000E+00 | --- | FGWHH |
| R019 | Livestock water fraction from ground water | not used | 1.000E+00 | --- | FGLW |
| R019 | Irrigation fraction from ground water | not used | 1.000E+00 | --- | FGWIR |
| R19B | Wet weight crop yield for Non-Leafy (kg/m ² *2) | not used | 7.000E-01 | --- | YV(1) |
| R19B | Wet weight crop yield for Leafy (kg/m ² *2) | not used | 1.500E+00 | --- | YV(2) |
| R19B | Wet weight crop yield for Fodder (kg/m ² *2) | not used | 1.100E+00 | --- | YV(3) |
| R19B | Growing Season for Non-Leafy (years) | not used | 1.700E-01 | --- | TE(1) |
| R19B | Growing Season for Leafy (years) | not used | 2.500E-01 | --- | TE(2) |
| R19B | Growing Season for Fodder (years) | not used | 8.000E-02 | --- | TE(3) |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Site-Specific Parameter Summary (continued)

| Menu | Parameter | User Input | Default | Used by RESRAD (If different from user input) | Parameter Name |
|------|--|------------|------------|--|----------------|
| R19B | Translocation Factor for Non-Leafy | not used | 1.000E-01 | --- | TIV(1) |
| R19B | Translocation Factor for Leafy | not used | 1.000E+00 | --- | TIV(2) |
| R19B | Translocation Factor for Fodder | not used | 1.000E+00 | --- | TIV(3) |
| R19B | Dry Foliar Interception Fraction for Non-Leafy | not used | 2.500E-01 | --- | RDRY(1) |
| R19B | Dry Foliar Interception Fraction for Leafy | not used | 2.500E-01 | --- | RDRY(2) |
| R19B | Dry Foliar Interception Fraction for Fodder | not used | 2.500E-01 | --- | RDRY(3) |
| R19B | Wet Foliar Interception Fraction for Non-Leafy | not used | 2.500E-01 | --- | RWET(1) |
| R19B | Wet Foliar Interception Fraction for Leafy | not used | 2.500E-01 | --- | RWET(2) |
| R19B | Wet Foliar Interception Fraction for Fodder | not used | 2.500E-01 | --- | RWET(3) |
| R19B | Weathering Removal Constant for Vegetation | not used | 2.000E+01 | --- | WLAM |
| C14 | C-12 concentration in water (g/cm ³) | 2.000E-05 | 2.000E-05 | --- | C12WTR |
| C14 | C-12 concentration in contaminated soil (g/g) | 3.000E-02 | 3.000E-02 | --- | C12CZ |
| C14 | Fraction of vegetation carbon from soil | 2.000E-02 | 2.000E-02 | --- | CSOIL |
| C14 | Fraction of vegetation carbon from air | 9.800E-01 | 9.800E-01 | --- | CAIR |
| C14 | C-14 evasion layer thickness in soil (m) | 3.000E-01 | 3.000E-01 | --- | DMC |
| C14 | C-14 evasion flux rate from soil (1/sec) | 7.000E-07 | 7.000E-07 | --- | EVSN |
| C14 | C-12 evasion flux rate from soil (1/sec) | 1.000E-10 | 1.000E-10 | --- | REVSN |
| C14 | Fraction of grain in beef cattle feed | 8.000E-01 | 8.000E-01 | --- | AVFG4 |
| C14 | Fraction of grain in milk cow feed | 2.000E-01 | 2.000E-01 | --- | AVFG5 |
| STOR | Storage times of contaminated foodstuffs (days): | | | | |
| STOR | Fruits, non-leafy vegetables, and grain | 1.400E+01 | 1.400E+01 | --- | STOR_T(1) |
| STOR | Leafy vegetables | 1.000E+00 | 1.000E+00 | --- | STOR_T(2) |
| STOR | Milk | 1.000E+00 | 1.000E+00 | --- | STOR_T(3) |
| STOR | Meat and poultry | 2.000E+01 | 2.000E+01 | --- | STOR_T(4) |
| STOR | Fish | 7.000E+00 | 7.000E+00 | --- | STOR_T(5) |
| STOR | Crustacea and mollusks | 7.000E+00 | 7.000E+00 | --- | STOR_T(6) |
| STOR | Well water | 1.000E+00 | 1.000E+00 | --- | STOR_T(7) |
| STOR | Surface water | 1.000E+00 | 1.000E+00 | --- | STOR_T(8) |
| STOR | Livestock fodder | 4.500E+01 | 4.500E+01 | --- | STOR_T(9) |
| R021 | Thickness of building foundation (m) | not used | 1.500E-01 | --- | FLOOR1 |
| R021 | Bulk density of building foundation (g/cm ³) | not used | 2.400E+00 | --- | DENSFL |
| R021 | Total porosity of the cover material | not used | 4.000E-01 | --- | TPCV |
| R021 | Total porosity of the building foundation | not used | 1.000E-01 | --- | TPFL |
| R021 | Volumetric water content of the cover material | not used | 5.000E-02 | --- | PH2OCV |
| R021 | Volumetric water content of the foundation | not used | 3.000E-02 | --- | PH2OFL |
| R021 | Diffusion coefficient for radon gas (m/sec): | | | | |
| R021 | in cover material | not used | 2.000E-06 | --- | DIFCV |
| R021 | in foundation material | not used | 3.000E-07 | --- | DIFFL |
| R021 | in contaminated zone soil | not used | 2.000E-06 | --- | DIFCZ |
| R021 | Radon vertical dimension of mixing (m) | not used | 2.000E+00 | --- | HMIX |
| R021 | Average building air exchange rate (1/hr) | not used | 5.000E-01 | --- | REXG |
| R021 | Height of the building (room) (m) | not used | 2.500E+00 | --- | HRM |
| R021 | Building interior area factor | not used | 0.000E+00 | --- | FAI |
| R021 | Building depth below ground surface (m) | not used | -1.000E+00 | --- | DMFL |
| R021 | Emanating power of Rn-222 gas | not used | 2.500E-01 | --- | EMANA(1) |
| R021 | Emanating power of Rn-220 gas | not used | 1.500E-01 | --- | EMANA(2) |
| TITL | Number of graphical time points | 32 | --- | --- | NPTS |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Site-Specific Parameter Summary (continued)

| Menu | Parameter | User Input | Default | Used by RESRAD (If different from user input) | Parameter Name |
|------|---|------------|---------|--|----------------|
| TITL | Maximum number of integration points for dose | 17 | --- | --- | LYMAX |
| TITL | Maximum number of integration points for risk | 1 | --- | --- | KYMAX |

Summary of Pathway Selections

| Pathway | User Selection |
|-----------------------------|----------------|
| 1 -- external gamma | active |
| 2 -- inhalation (w/o radon) | active |
| 3 -- plant ingestion | suppressed |
| 4 -- meat ingestion | suppressed |
| 5 -- milk ingestion | suppressed |
| 6 -- aquatic foods | suppressed |
| 7 -- drinking water | suppressed |
| 8 -- soil ingestion | active |
| 9 -- radon | suppressed |
| Find peak pathway doses | active |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Contaminated Zone Dimensions

Initial Soil Concentrations, pCi/g

| | | | |
|--------------|---------------------|---------|-----------|
| Area: | 50.00 square meters | Ag-108m | 4.760E+01 |
| Thickness: | 1.00 meters | C-14 | 1.020E+01 |
| Cover Depth: | 5.00 meters | Co-60 | 3.300E+00 |
| | | Cs-137 | 2.000E+00 |
| | | Eu-152 | 6.000E-01 |
| | | H-3 | 1.900E+00 |

Total Dose TDOSE(t), mrem/yr

Basic Radiation Dose Limit = 2.500E+01 mrem/yr

Total Mixture Sum M(t) = Fraction of Basic Dose Limit Received at Time (t)

| | | | | | | | | |
|------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| t (years): | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.000E+01 | 1.000E+02 | 3.000E+02 | 1.000E+03 |
| TDOSE(t): | 1.777E-25 | 1.576E-25 | 1.239E-25 | 5.350E-26 | 4.879E-27 | 2.965E-30 | 0.000E+00 | 0.000E+00 |
| M(t): | 7.107E-27 | 6.303E-27 | 4.958E-27 | 2.140E-27 | 1.952E-28 | 1.186E-31 | 0.000E+00 | 0.000E+00 |

Maximum TDOSE(t): 1.777E-25 mrem/yr at t = 0.000E+00 years

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 0.000E+00 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 1.775E-25 | 0.9991 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 1.587E-28 | 0.0009 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 1.777E-25 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 0.000E+00 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.775E-25 | 0.9991 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.587E-28 | 0.0009 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.777E-25 | 1.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 1.000E+00 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 1.574E-25 | 0.9990 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 1.525E-28 | 0.0010 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 1.576E-25 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 1.000E+00 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.574E-25 | 0.9990 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.525E-28 | 0.0010 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.576E-25 | 1.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 3.000E+00 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 1.238E-25 | 0.9989 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 1.408E-28 | 0.0011 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 1.239E-25 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 3.000E+00 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.238E-25 | 0.9989 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.408E-28 | 0.0011 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.239E-25 | 1.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 1.000E+01 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 5.340E-26 | 0.9980 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 1.066E-28 | 0.0020 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 5.350E-26 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 1.000E+01 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.340E-26 | 0.9980 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.066E-28 | 0.0020 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 5.350E-26 | 1.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 3.000E+01 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 4.831E-27 | 0.9901 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 4.808E-29 | 0.0099 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 4.879E-27 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 3.000E+01 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 4.831E-27 | 0.9901 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 4.808E-29 | 0.0099 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 4.879E-27 | 1.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 1.000E+02 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 2.965E-30 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 2.965E-30 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 1.000E+02 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 2.965E-30 | 1.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 2.965E-30 | 1.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 3.000E+02 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 3.000E+02 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 1.000E+03 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 1.000E+03 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Dose/Source Ratios Summed Over All Pathways
Parent and Progeny Principal Radionuclide Contributions Indicated

| Parent (i) | Product (j) | Thread Fraction | DSR(j,t) At Time in Years (mrem/yr)/(pCi/g) | | | | | | | |
|---------------|----------------|--------------------|---|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| | | | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.000E+01 | 1.000E+02 | 3.000E+02 | 1.000E+03 |
| Ag-108m+D | Ag-108m+D | 1.000E+00 | 1.171E-32 | 2.489E-33 | 1.123E-34 | 2.196E-39 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| C-14 | C-14 | 1.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Co-60 | Co-60 | 1.000E+00 | 5.380E-26 | 4.771E-26 | 3.752E-26 | 1.618E-26 | 1.464E-27 | 3.261E-31 | 1.198E-41 | 0.000E+00 |
| Cs-137+D | Cs-137+D | 1.000E+00 | 3.484E-32 | 3.453E-32 | 3.392E-32 | 3.187E-32 | 2.666E-32 | 1.427E-32 | 2.393E-33 | 4.624E-36 |
| Eu-152 | Eu-152 | 7.208E-01 | 1.907E-28 | 1.832E-28 | 1.692E-28 | 1.281E-28 | 5.776E-29 | 3.561E-30 | 1.243E-33 | 1.401E-45 |
| Eu-152 | Eu-152 | 2.792E-01 | 7.385E-29 | 7.097E-29 | 6.554E-29 | 4.960E-29 | 2.237E-29 | 1.379E-30 | 4.814E-34 | 0.000E+00 |
| Eu-152 | Gd-152 | 2.792E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Eu-152 | ΣDSR(j) | | 7.385E-29 | 7.097E-29 | 6.554E-29 | 4.960E-29 | 2.237E-29 | 1.379E-30 | 4.814E-34 | 0.000E+00 |
| H-3 | H-3 | 1.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

The DSR includes contributions from associated (half-life ≤ 30 days) daughters.

Single Radionuclide Soil Guidelines G(i,t) in pCi/g
Basic Radiation Dose Limit = 2.500E+01 mrem/yr

| Nuclide (i) | t= | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.000E+01 | 1.000E+02 | 3.000E+02 | 1.000E+03 |
|----------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Ag-108m | *2.609E+13 | *2.609E+13 | *2.609E+13 | *2.609E+13 | *2.609E+13 | *2.609E+13 | *2.609E+13 | *2.609E+13 | *2.609E+13 |
| C-14 | *4.455E+12 | *4.455E+12 | *4.455E+12 | *4.455E+12 | *4.455E+12 | *4.455E+12 | *4.455E+12 | *4.455E+12 | *4.455E+12 |
| Co-60 | *1.132E+15 | *1.132E+15 | *1.132E+15 | *1.132E+15 | *1.132E+15 | *1.132E+15 | *1.132E+15 | *1.132E+15 | *1.132E+15 |
| Cs-137 | *8.704E+13 | *8.704E+13 | *8.704E+13 | *8.704E+13 | *8.704E+13 | *8.704E+13 | *8.704E+13 | *8.704E+13 | *8.704E+13 |
| Eu-152 | *1.765E+14 | *1.765E+14 | *1.765E+14 | *1.765E+14 | *1.765E+14 | *1.765E+14 | *1.765E+14 | *1.765E+14 | *1.765E+14 |
| H-3 | *9.597E+15 | *9.597E+15 | *9.597E+15 | *9.597E+15 | *9.597E+15 | *9.597E+15 | *9.597E+15 | *9.597E+15 | *9.597E+15 |

*At specific activity limit

Summed Dose/Source Ratios DSR(i,t) in (mrem/yr)/(pCi/g)
and Single Radionuclide Soil Guidelines G(i,t) in pCi/g
at tmin = time of minimum single radionuclide soil guideline
and at tmax = time of maximum total dose = 0.000E+00 years

| Nuclide (i) | Initial (pCi/g) | tmin (years) | DSR(i,tmin) (pCi/g) | G(i,tmin) (pCi/g) | DSR(i,tmax) (pCi/g) | G(i,tmax) (pCi/g) |
|----------------|--------------------|-----------------|------------------------|----------------------|------------------------|----------------------|
| Ag-108m | 4.760E+01 | 0.000E+00 | 0.000E+00 | *2.609E+13 | 0.000E+00 | *2.609E+13 |
| C-14 | 1.020E+01 | 0.000E+00 | 0.000E+00 | *4.455E+12 | 0.000E+00 | *4.455E+12 |
| Co-60 | 3.300E+00 | 0.000E+00 | 5.380E-26 | *1.132E+15 | 5.380E-26 | *1.132E+15 |
| Cs-137 | 2.000E+00 | 0.000E+00 | 0.000E+00 | *8.704E+13 | 0.000E+00 | *8.704E+13 |
| Eu-152 | 6.000E-01 | 0.000E+00 | 2.645E-28 | *1.765E+14 | 2.645E-28 | *1.765E+14 |
| H-3 | 1.900E+00 | 0.000E+00 | 0.000E+00 | *9.597E+15 | 0.000E+00 | *9.597E+15 |

*At specific activity limit

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\WORKER.RAD

Individual Nuclide Dose Summed Over All Pathways
Parent Nuclide and Branch Fraction Indicated

| Nuclide (j) | Parent (i) | THF(i) | DOSE(j,t), mrem/yr | | | | | | | | |
|----------------|---------------|-----------|--------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| | | | t= | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.000E+01 | 1.000E+02 | 3.000E+02 | 1.000E+03 |
| Ag-108m | Ag-108m | 1.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| C-14 | C-14 | 1.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Co-60 | Co-60 | 1.000E+00 | 1.775E-25 | 1.574E-25 | 1.238E-25 | 5.340E-26 | 4.831E-27 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Cs-137 | Cs-137 | 1.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Eu-152 | Eu-152 | 7.208E-01 | 1.144E-28 | 1.099E-28 | 1.015E-28 | 7.683E-29 | 3.466E-29 | 2.137E-30 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Eu-152 | Eu-152 | 2.792E-01 | 4.431E-29 | 4.258E-29 | 3.932E-29 | 2.976E-29 | 1.342E-29 | 8.277E-31 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Eu-152 | ΣDOSE(j) | | 1.587E-28 | 1.525E-28 | 1.408E-28 | 1.066E-28 | 4.808E-29 | 2.965E-30 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Gd-152 | Eu-152 | 2.792E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| H-3 | H-3 | 1.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

THF(i) is the thread fraction of the parent nuclide.

Individual Nuclide Soil Concentration
Parent Nuclide and Branch Fraction Indicated

| Nuclide (j) | Parent (i) | THF(i) | S(j,t), pCi/g | | | | | | | | |
|----------------|---------------|-----------|---------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| | | | t= | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.000E+01 | 1.000E+02 | 3.000E+02 | 1.000E+03 |
| Ag-108m | Ag-108m | 1.000E+00 | 4.760E+01 | 9.968E+00 | 4.371E-01 | 7.718E-06 | 2.029E-19 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| C-14 | C-14 | 1.000E+00 | 1.020E+01 | 2.147E+00 | 9.517E-02 | 1.744E-06 | 5.103E-20 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Co-60 | Co-60 | 1.000E+00 | 3.300E+00 | 2.892E+00 | 2.222E+00 | 8.830E-01 | 6.322E-02 | 6.208E-06 | 2.197E-17 | 0.000E+00 | 0.000E+00 |
| Cs-137 | Cs-137 | 1.000E+00 | 2.000E+00 | 1.954E+00 | 1.866E+00 | 1.586E+00 | 9.978E-01 | 1.970E-01 | 1.911E-03 | 1.719E-10 | 0.000E+00 |
| Eu-152 | Eu-152 | 7.208E-01 | 4.325E-01 | 4.104E-01 | 3.696E-01 | 2.561E-01 | 8.979E-02 | 2.292E-03 | 6.434E-08 | 7.544E-24 | 0.000E+00 |
| Eu-152 | Eu-152 | 2.792E-01 | 1.675E-01 | 1.590E-01 | 1.432E-01 | 9.919E-02 | 3.478E-02 | 8.876E-04 | 2.492E-08 | 2.922E-24 | 0.000E+00 |
| Eu-152 | ΣS(j): | | 6.000E-01 | 5.694E-01 | 5.127E-01 | 3.553E-01 | 1.246E-01 | 3.179E-03 | 8.926E-08 | 1.047E-23 | 0.000E+00 |
| Gd-152 | Eu-152 | 2.792E-01 | 0.000E+00 | 1.047E-15 | 2.983E-15 | 8.350E-15 | 1.613E-14 | 1.975E-14 | 1.832E-14 | 1.380E-14 | 0.000E+00 |
| H-3 | H-3 | 1.000E+00 | 1.900E+00 | 3.782E-01 | 1.499E-02 | 1.856E-07 | 1.771E-21 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

THF(i) is the thread fraction of the parent nuclide.

RESCALC.EXE execution time = 0.46 seconds

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Table of Contents

I: Mixture Sums and Single Radionuclide Guidelines

| | |
|--|----|
| Dose Conversion Factor (and Related) Parameter Summary ... | 2 |
| Site-Specific Parameter Summary | 4 |
| Summary of Pathway Selections | 9 |
| Contaminated Zone and Total Dose Summary | 10 |
| Total Dose Components | |
| Time = 0.000E+00 | 12 |
| Time = 1.000E+00 | 13 |
| Time = 3.000E+00 | 14 |
| Time = 1.000E+01 | 15 |
| Time = 3.000E+01 | 16 |
| Time = 1.000E+02 | 17 |
| Time = 3.000E+02 | 18 |
| Time = 1.000E+03 | 19 |
| Dose/Source Ratios Summed Over All Pathways | 20 |
| Single Radionuclide Soil Guidelines | 20 |
| Dose Per Nuclide Summed Over All Pathways | 21 |
| Soil Concentration Per Nuclide | 21 |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Dose Conversion Factor (and Related) Parameter Summary
 Dose Library: FGR 12 & FGR 11

| Menu | Parameter | Current Value# | Base Case* | Parameter Name |
|------|--|----------------|------------|----------------|
| A-1 | DCF's for external ground radiation, (mrem/yr)/(pCi/g) | | | |
| A-1 | Ag-108 (Source: FGR 12) | 1.143E-01 | 1.143E-01 | DCF1(1) |
| A-1 | Ag-108m (Source: FGR 12) | 9.640E+00 | 9.640E+00 | DCF1(2) |
| A-1 | Ba-137m (Source: FGR 12) | 3.606E+00 | 3.606E+00 | DCF1(3) |
| A-1 | C-14 (Source: FGR 12) | 1.345E-05 | 1.345E-05 | DCF1(4) |
| A-1 | Co-60 (Source: FGR 12) | 1.622E+01 | 1.622E+01 | DCF1(5) |
| A-1 | Cs-137 (Source: FGR 12) | 7.510E-04 | 7.510E-04 | DCF1(6) |
| A-1 | Eu-152 (Source: FGR 12) | 7.006E+00 | 7.006E+00 | DCF1(7) |
| A-1 | Gd-152 (Source: FGR 12) | 0.000E+00 | 0.000E+00 | DCF1(8) |
| A-1 | H-3 (Source: FGR 12) | 0.000E+00 | 0.000E+00 | DCF1(9) |
| B-1 | Dose conversion factors for inhalation, mrem/pCi: | | | |
| B-1 | Ag-108m+D | 2.830E-04 | 2.830E-04 | DCF2(1) |
| B-1 | C-14(p) (Class: ORGANIC) | 2.090E-06 | 2.090E-06 | DCF2(2) |
| B-1 | C-14(g) (Class: CO2) | 2.350E-08 | 2.350E-08 | C14GInhDCF |
| B-1 | Co-60 | 2.190E-04 | 2.190E-04 | DCF2(3) |
| B-1 | Cs-137+D | 3.190E-05 | 3.190E-05 | DCF2(4) |
| B-1 | Eu-152 | 2.210E-04 | 2.210E-04 | DCF2(5) |
| B-1 | Gd-152 | 2.430E-01 | 2.430E-01 | DCF2(7) |
| B-1 | H-3 | 6.400E-08 | 6.400E-08 | DCF2(8) |
| D-1 | Dose conversion factors for ingestion, mrem/pCi: | | | |
| D-1 | Ag-108m+D | 7.620E-06 | 7.620E-06 | DCF3(1) |
| D-1 | C-14 | 2.090E-06 | 2.090E-06 | DCF3(2) |
| D-1 | Co-60 | 2.690E-05 | 2.690E-05 | DCF3(3) |
| D-1 | Cs-137+D | 5.000E-05 | 5.000E-05 | DCF3(4) |
| D-1 | Eu-152 | 6.480E-06 | 6.480E-06 | DCF3(5) |
| D-1 | Gd-152 | 1.610E-04 | 1.610E-04 | DCF3(7) |
| D-1 | H-3 | 6.400E-08 | 6.400E-08 | DCF3(8) |
| D-34 | Food transfer factors: | | | |
| D-34 | Ag-108m+D, plant/soil concentration ratio, dimensionless | 1.500E-01 | 1.500E-01 | RTF(1,1) |
| D-34 | Ag-108m+D, beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 3.000E-03 | 3.000E-03 | RTF(1,2) |
| D-34 | Ag-108m+D, milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 2.500E-02 | 2.500E-02 | RTF(1,3) |
| D-34 | C-14, plant/soil concentration ratio, dimensionless | 5.500E+00 | 5.500E+00 | RTF(2,1) |
| D-34 | C-14, beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 3.100E-02 | 3.100E-02 | RTF(2,2) |
| D-34 | C-14, milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 1.200E-02 | 1.200E-02 | RTF(2,3) |
| D-34 | Co-60, plant/soil concentration ratio, dimensionless | 8.000E-02 | 8.000E-02 | RTF(3,1) |
| D-34 | Co-60, beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 2.000E-02 | 2.000E-02 | RTF(3,2) |
| D-34 | Co-60, milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 2.000E-03 | 2.000E-03 | RTF(3,3) |
| D-34 | Cs-137+D, plant/soil concentration ratio, dimensionless | 4.000E-02 | 4.000E-02 | RTF(4,1) |
| D-34 | Cs-137+D, beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 3.000E-02 | 3.000E-02 | RTF(4,2) |
| D-34 | Cs-137+D, milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 8.000E-03 | 8.000E-03 | RTF(4,3) |
| D-34 | Eu-152, plant/soil concentration ratio, dimensionless | 2.500E-03 | 2.500E-03 | RTF(5,1) |
| D-34 | Eu-152, beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 2.000E-03 | 2.000E-03 | RTF(5,2) |
| D-34 | Eu-152, milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 5.000E-05 | 5.000E-05 | RTF(5,3) |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Dose Conversion Factor (and Related) Parameter Summary (continued)

Dose Library: FGR 12 & FGR 11

| Menu | Parameter | Current Value# | Base Case* | Parameter Name |
|------|--|----------------|------------|----------------|
| D-34 | Gd-152 , plant/soil concentration ratio, dimensionless | 2.500E-03 | 2.500E-03 | RTF(7,1) |
| D-34 | Gd-152 , beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 2.000E-03 | 2.000E-03 | RTF(7,2) |
| D-34 | Gd-152 , milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 2.000E-05 | 2.000E-05 | RTF(7,3) |
| D-34 | | | | |
| D-34 | H-3 , plant/soil concentration ratio, dimensionless | 4.800E+00 | 4.800E+00 | RTF(8,1) |
| D-34 | H-3 , beef/livestock-intake ratio, (pCi/kg)/(pCi/d) | 1.200E-02 | 1.200E-02 | RTF(8,2) |
| D-34 | H-3 , milk/livestock-intake ratio, (pCi/L)/(pCi/d) | 1.000E-02 | 1.000E-02 | RTF(8,3) |
| D-34 | | | | |
| D-5 | Bioaccumulation factors, fresh water, L/kg: | | | |
| D-5 | Ag-108m+D , fish | 5.000E+00 | 5.000E+00 | BIOFAC(1,1) |
| D-5 | Ag-108m+D , crustacea and mollusks | 7.700E+02 | 7.700E+02 | BIOFAC(1,2) |
| D-5 | | | | |
| D-5 | C-14 , fish | 5.000E+04 | 5.000E+04 | BIOFAC(2,1) |
| D-5 | C-14 , crustacea and mollusks | 9.100E+03 | 9.100E+03 | BIOFAC(2,2) |
| D-5 | | | | |
| D-5 | Co-60 , fish | 3.000E+02 | 3.000E+02 | BIOFAC(3,1) |
| D-5 | Co-60 , crustacea and mollusks | 2.000E+02 | 2.000E+02 | BIOFAC(3,2) |
| D-5 | | | | |
| D-5 | Cs-137+D , fish | 2.000E+03 | 2.000E+03 | BIOFAC(4,1) |
| D-5 | Cs-137+D , crustacea and mollusks | 1.000E+02 | 1.000E+02 | BIOFAC(4,2) |
| D-5 | | | | |
| D-5 | Eu-152 , fish | 5.000E+01 | 5.000E+01 | BIOFAC(5,1) |
| D-5 | Eu-152 , crustacea and mollusks | 1.000E+03 | 1.000E+03 | BIOFAC(5,2) |
| D-5 | | | | |
| D-5 | Gd-152 , fish | 2.500E+01 | 2.500E+01 | BIOFAC(7,1) |
| D-5 | Gd-152 , crustacea and mollusks | 1.000E+03 | 1.000E+03 | BIOFAC(7,2) |
| D-5 | | | | |
| D-5 | H-3 , fish | 1.000E+00 | 1.000E+00 | BIOFAC(8,1) |
| D-5 | H-3 , crustacea and mollusks | 1.000E+00 | 1.000E+00 | BIOFAC(8,2) |

#For DCF1(XXX) only, factors are for infinite depth & area. See ETEG table in Ground Pathway of Detailed Report.

*Base Case means Default.Lib w/o Associate Nuclide contributions.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Site-Specific Parameter Summary

| Menu | Parameter | User Input | Default | Used by RESRAD (If different from user input) | Parameter Name |
|------|---|------------|-----------|--|----------------|
| R011 | Area of contaminated zone (m*2) | 5.000E+01 | 1.000E+04 | --- | AREA |
| R011 | Thickness of contaminated zone (m) | 1.000E+00 | 2.000E+00 | --- | THICK0 |
| R011 | Fraction of contamination that is submerged | 0.000E+00 | 0.000E+00 | --- | SUBMFRACT |
| R011 | Length parallel to aquifer flow (m) | 1.000E+02 | 1.000E+02 | --- | LCZPAQ |
| R011 | Basic radiation dose limit (mrem/yr) | 2.500E+01 | 3.000E+01 | --- | BRDL |
| R011 | Time since placement of material (yr) | 0.000E+00 | 0.000E+00 | --- | TI |
| R011 | Times for calculations (yr) | 1.000E+00 | 1.000E+00 | --- | T (2) |
| R011 | Times for calculations (yr) | 3.000E+00 | 3.000E+00 | --- | T (3) |
| R011 | Times for calculations (yr) | 1.000E+01 | 1.000E+01 | --- | T (4) |
| R011 | Times for calculations (yr) | 3.000E+01 | 3.000E+01 | --- | T (5) |
| R011 | Times for calculations (yr) | 1.000E+02 | 1.000E+02 | --- | T (6) |
| R011 | Times for calculations (yr) | 3.000E+02 | 3.000E+02 | --- | T (7) |
| R011 | Times for calculations (yr) | 1.000E+03 | 1.000E+03 | --- | T (8) |
| R011 | Times for calculations (yr) | not used | 0.000E+00 | --- | T (9) |
| R011 | Times for calculations (yr) | not used | 0.000E+00 | --- | T(10) |
| R012 | Initial principal radionuclide (pCi/g): Ag-108m | 4.760E+01 | 0.000E+00 | --- | S1(1) |
| R012 | Initial principal radionuclide (pCi/g): C-14 | 1.020E+01 | 0.000E+00 | --- | S1(2) |
| R012 | Initial principal radionuclide (pCi/g): Co-60 | 3.300E+00 | 0.000E+00 | --- | S1(3) |
| R012 | Initial principal radionuclide (pCi/g): Cs-137 | 2.000E+00 | 0.000E+00 | --- | S1(4) |
| R012 | Initial principal radionuclide (pCi/g): Eu-152 | 6.000E-01 | 0.000E+00 | --- | S1(5) |
| R012 | Initial principal radionuclide (pCi/g): H-3 | 1.900E+00 | 0.000E+00 | --- | S1(8) |
| R012 | Concentration in groundwater (pCi/L): Ag-108m | not used | 0.000E+00 | --- | W1(1) |
| R012 | Concentration in groundwater (pCi/L): C-14 | not used | 0.000E+00 | --- | W1(2) |
| R012 | Concentration in groundwater (pCi/L): Co-60 | not used | 0.000E+00 | --- | W1(3) |
| R012 | Concentration in groundwater (pCi/L): Cs-137 | not used | 0.000E+00 | --- | W1(4) |
| R012 | Concentration in groundwater (pCi/L): Eu-152 | not used | 0.000E+00 | --- | W1(5) |
| R012 | Concentration in groundwater (pCi/L): H-3 | not used | 0.000E+00 | --- | W1(8) |
| R013 | Cover depth (m) | 5.000E+00 | 0.000E+00 | --- | COVER0 |
| R013 | Density of cover material (g/cm*3) | 1.500E+00 | 1.500E+00 | --- | DENSCV |
| R013 | Cover depth erosion rate (m/yr) | 1.000E-03 | 1.000E-03 | --- | VCV |
| R013 | Density of contaminated zone (g/cm*3) | 1.500E+00 | 1.500E+00 | --- | DENSCZ |
| R013 | Contaminated zone erosion rate (m/yr) | 1.000E-03 | 1.000E-03 | --- | VCZ |
| R013 | Contaminated zone total porosity | 4.000E-01 | 4.000E-01 | --- | TPCZ |
| R013 | Contaminated zone field capacity | 2.000E-01 | 2.000E-01 | --- | FCCZ |
| R013 | Contaminated zone hydraulic conductivity (m/yr) | 1.000E+01 | 1.000E+01 | --- | HCCZ |
| R013 | Contaminated zone b parameter | 5.300E+00 | 5.300E+00 | --- | BCZ |
| R013 | Average annual wind speed (m/sec) | 2.000E+00 | 2.000E+00 | --- | WIND |
| R013 | Humidity in air (g/m*3) | 8.000E+00 | 8.000E+00 | --- | HUMID |
| R013 | Evapotranspiration coefficient | 5.000E-01 | 5.000E-01 | --- | EVAPTR |
| R013 | Precipitation (m/yr) | 1.000E+00 | 1.000E+00 | --- | PRECIP |
| R013 | Irrigation (m/yr) | 2.000E-01 | 2.000E-01 | --- | RI |
| R013 | Irrigation mode | overhead | overhead | --- | IDITCH |
| R013 | Runoff coefficient | 2.000E-01 | 2.000E-01 | --- | RUNOFF |
| R013 | Watershed area for nearby stream or pond (m*2) | 1.000E+06 | 1.000E+06 | --- | WAREA |
| R013 | Accuracy for water/soil computations | 1.000E-03 | 1.000E-03 | --- | EPS |
| R014 | Density of saturated zone (g/cm*3) | 1.500E+00 | 1.500E+00 | --- | DENSAQ |
| R014 | Saturated zone total porosity | 4.000E-01 | 4.000E-01 | --- | TPSZ |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Site-Specific Parameter Summary (continued)

| Menu | Parameter | User Input | Default | Used by RESRAD (If different from user input) | Parameter Name |
|------|--|------------|-----------|--|----------------|
| R014 | Saturated zone effective porosity | 2.000E-01 | 2.000E-01 | --- | EPSZ |
| R014 | Saturated zone field capacity | 2.000E-01 | 2.000E-01 | --- | FCSZ |
| R014 | Saturated zone hydraulic conductivity (m/yr) | 1.000E+02 | 1.000E+02 | --- | HCSZ |
| R014 | Saturated zone hydraulic gradient | 2.000E-02 | 2.000E-02 | --- | HGWT |
| R014 | Saturated zone b parameter | 5.300E+00 | 5.300E+00 | --- | BSZ |
| R014 | Water table drop rate (m/yr) | 1.000E-03 | 1.000E-03 | --- | VWT |
| R014 | Well pump intake depth (m below water table) | 1.000E+01 | 1.000E+01 | --- | DWIEWT |
| R014 | Model: Nondispersion (ND) or Mass-Balance (MB) | ND | ND | --- | MODEL |
| R014 | Well pumping rate (m ³ /yr) | 2.500E+02 | 2.500E+02 | --- | UW |
| R015 | Number of unsaturated zone strata | 1 | 1 | --- | NS |
| R015 | Unsat. zone 1, thickness (m) | 4.000E+00 | 4.000E+00 | --- | H(1) |
| R015 | Unsat. zone 1, soil density (g/cm ³) | 1.500E+00 | 1.500E+00 | --- | DENSUZ(1) |
| R015 | Unsat. zone 1, total porosity | 4.000E-01 | 4.000E-01 | --- | TPUZ(1) |
| R015 | Unsat. zone 1, effective porosity | 2.000E-01 | 2.000E-01 | --- | EPUZ(1) |
| R015 | Unsat. zone 1, field capacity | 2.000E-01 | 2.000E-01 | --- | FCUZ(1) |
| R015 | Unsat. zone 1, soil-specific b parameter | 5.300E+00 | 5.300E+00 | --- | BUZ(1) |
| R015 | Unsat. zone 1, hydraulic conductivity (m/yr) | 1.000E+01 | 1.000E+01 | --- | HCUZ(1) |
| R016 | Distribution coefficients for Ag-108m | | | | |
| R016 | Contaminated zone (cm ³ /g) | 0.000E+00 | 0.000E+00 | --- | DCNUCC(1) |
| R016 | Unsat. zone 1 (cm ³ /g) | 0.000E+00 | 0.000E+00 | --- | DCNUCU(1,1) |
| R016 | Saturated zone (cm ³ /g) | 0.000E+00 | 0.000E+00 | --- | DCNUCS(1) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 1.558E+00 | ALEACH(1) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(1) |
| R016 | Distribution coefficients for C-14 | | | | |
| R016 | Contaminated zone (cm ³ /g) | 0.000E+00 | 0.000E+00 | --- | DCNUCC(2) |
| R016 | Unsat. zone 1 (cm ³ /g) | 0.000E+00 | 0.000E+00 | --- | DCNUCU(2,1) |
| R016 | Saturated zone (cm ³ /g) | 0.000E+00 | 0.000E+00 | --- | DCNUCS(2) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 1.558E+00 | ALEACH(2) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(2) |
| R016 | Distribution coefficients for Co-60 | | | | |
| R016 | Contaminated zone (cm ³ /g) | 1.000E+03 | 1.000E+03 | --- | DCNUCC(3) |
| R016 | Unsat. zone 1 (cm ³ /g) | 1.000E+03 | 1.000E+03 | --- | DCNUCU(3,1) |
| R016 | Saturated zone (cm ³ /g) | 1.000E+03 | 1.000E+03 | --- | DCNUCS(3) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 3.333E-04 | ALEACH(3) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(3) |
| R016 | Distribution coefficients for Cs-137 | | | | |
| R016 | Contaminated zone (cm ³ /g) | 4.600E+03 | 4.600E+03 | --- | DCNUCC(4) |
| R016 | Unsat. zone 1 (cm ³ /g) | 4.600E+03 | 4.600E+03 | --- | DCNUCU(4,1) |
| R016 | Saturated zone (cm ³ /g) | 4.600E+03 | 4.600E+03 | --- | DCNUCS(4) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 7.246E-05 | ALEACH(4) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(4) |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Site-Specific Parameter Summary (continued)

| Menu | Parameter | User Input | Default | Used by RESRAD (If different from user input) | Parameter Name |
|------|--|------------|------------|--|----------------|
| R016 | Distribution coefficients for Eu-152 | | | | |
| R016 | Contaminated zone (cm**3/g) | -1.000E+00 | -1.000E+00 | 8.249E+02 | DCNUCC(5) |
| R016 | Unsaturated zone 1 (cm**3/g) | -1.000E+00 | -1.000E+00 | 8.249E+02 | DCNUCU(5,1) |
| R016 | Saturated zone (cm**3/g) | -1.000E+00 | -1.000E+00 | 8.249E+02 | DCNUCS(5) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 4.040E-04 | ALEACH(5) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(5) |
| R016 | Distribution coefficients for H-3 | | | | |
| R016 | Contaminated zone (cm**3/g) | 0.000E+00 | 0.000E+00 | --- | DCNUCC(8) |
| R016 | Unsaturated zone 1 (cm**3/g) | 0.000E+00 | 0.000E+00 | --- | DCNUCU(8,1) |
| R016 | Saturated zone (cm**3/g) | 0.000E+00 | 0.000E+00 | --- | DCNUCS(8) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 1.558E+00 | ALEACH(8) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(8) |
| R016 | Distribution coefficients for daughter Gd-152 | | | | |
| R016 | Contaminated zone (cm**3/g) | -1.000E+00 | -1.000E+00 | 8.249E+02 | DCNUCC(7) |
| R016 | Unsaturated zone 1 (cm**3/g) | -1.000E+00 | -1.000E+00 | 8.249E+02 | DCNUCU(7,1) |
| R016 | Saturated zone (cm**3/g) | -1.000E+00 | -1.000E+00 | 8.249E+02 | DCNUCS(7) |
| R016 | Leach rate (/yr) | 0.000E+00 | 0.000E+00 | 4.040E-04 | ALEACH(7) |
| R016 | Solubility constant | 0.000E+00 | 0.000E+00 | not used | SOLUBK(7) |
| R017 | Inhalation rate (m**3/yr) | 8.400E+03 | 8.400E+03 | --- | INHALR |
| R017 | Mass loading for inhalation (g/m**3) | 1.000E-04 | 1.000E-04 | --- | MLINH |
| R017 | Exposure duration | 3.000E+01 | 3.000E+01 | --- | ED |
| R017 | Shielding factor, inhalation | 4.000E-01 | 4.000E-01 | --- | SHF3 |
| R017 | Shielding factor, external gamma | 7.000E-01 | 7.000E-01 | --- | SHF1 |
| R017 | Fraction of time spent indoors | 6.833E-01 | 5.000E-01 | --- | FIND |
| R017 | Fraction of time spent outdoors (on site) | 8.330E-02 | 2.500E-01 | --- | FOTD |
| R017 | Shape factor flag, external gamma | 1.000E+00 | 1.000E+00 | >0 shows circular AREA. | FS |
| R017 | Radii of shape factor array (used if FS = -1): | | | | |
| R017 | Outer annular radius (m), ring 1: | not used | 5.000E+01 | --- | RAD_SHAPE(1) |
| R017 | Outer annular radius (m), ring 2: | not used | 7.071E+01 | --- | RAD_SHAPE(2) |
| R017 | Outer annular radius (m), ring 3: | not used | 0.000E+00 | --- | RAD_SHAPE(3) |
| R017 | Outer annular radius (m), ring 4: | not used | 0.000E+00 | --- | RAD_SHAPE(4) |
| R017 | Outer annular radius (m), ring 5: | not used | 0.000E+00 | --- | RAD_SHAPE(5) |
| R017 | Outer annular radius (m), ring 6: | not used | 0.000E+00 | --- | RAD_SHAPE(6) |
| R017 | Outer annular radius (m), ring 7: | not used | 0.000E+00 | --- | RAD_SHAPE(7) |
| R017 | Outer annular radius (m), ring 8: | not used | 0.000E+00 | --- | RAD_SHAPE(8) |
| R017 | Outer annular radius (m), ring 9: | not used | 0.000E+00 | --- | RAD_SHAPE(9) |
| R017 | Outer annular radius (m), ring 10: | not used | 0.000E+00 | --- | RAD_SHAPE(10) |
| R017 | Outer annular radius (m), ring 11: | not used | 0.000E+00 | --- | RAD_SHAPE(11) |
| R017 | Outer annular radius (m), ring 12: | not used | 0.000E+00 | --- | RAD_SHAPE(12) |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Site-Specific Parameter Summary (continued)

| Menu | Parameter | User Input | Default | Used by RESRAD (If different from user input) | Parameter Name |
|------|--|------------|-----------|--|----------------|
| R017 | Fractions of annular areas within AREA: | | | | |
| R017 | Ring 1 | not used | 1.000E+00 | --- | FRACA(1) |
| R017 | Ring 2 | not used | 2.732E-01 | --- | FRACA(2) |
| R017 | Ring 3 | not used | 0.000E+00 | --- | FRACA(3) |
| R017 | Ring 4 | not used | 0.000E+00 | --- | FRACA(4) |
| R017 | Ring 5 | not used | 0.000E+00 | --- | FRACA(5) |
| R017 | Ring 6 | not used | 0.000E+00 | --- | FRACA(6) |
| R017 | Ring 7 | not used | 0.000E+00 | --- | FRACA(7) |
| R017 | Ring 8 | not used | 0.000E+00 | --- | FRACA(8) |
| R017 | Ring 9 | not used | 0.000E+00 | --- | FRACA(9) |
| R017 | Ring 10 | not used | 0.000E+00 | --- | FRACA(10) |
| R017 | Ring 11 | not used | 0.000E+00 | --- | FRACA(11) |
| R017 | Ring 12 | not used | 0.000E+00 | --- | FRACA(12) |
| R018 | Fruits, vegetables and grain consumption (kg/yr) | 1.600E+02 | 1.600E+02 | --- | DIET(1) |
| R018 | Leafy vegetable consumption (kg/yr) | 1.400E+01 | 1.400E+01 | --- | DIET(2) |
| R018 | Milk consumption (L/yr) | 9.200E+01 | 9.200E+01 | --- | DIET(3) |
| R018 | Meat and poultry consumption (kg/yr) | 6.300E+01 | 6.300E+01 | --- | DIET(4) |
| R018 | Fish consumption (kg/yr) | 5.400E+00 | 5.400E+00 | --- | DIET(5) |
| R018 | Other seafood consumption (kg/yr) | 9.000E-01 | 9.000E-01 | --- | DIET(6) |
| R018 | Soil ingestion rate (g/yr) | 3.650E+01 | 3.650E+01 | --- | SOIL |
| R018 | Drinking water intake (L/yr) | 5.100E+02 | 5.100E+02 | --- | DWI |
| R018 | Contamination fraction of drinking water | 1.000E+00 | 1.000E+00 | --- | FDW |
| R018 | Contamination fraction of household water | not used | 1.000E+00 | --- | FHHW |
| R018 | Contamination fraction of livestock water | 1.000E+00 | 1.000E+00 | --- | FLW |
| R018 | Contamination fraction of irrigation water | 1.000E+00 | 1.000E+00 | --- | FIRW |
| R018 | Contamination fraction of aquatic food | 5.000E-01 | 5.000E-01 | --- | FR9 |
| R018 | Contamination fraction of plant food | -1 | -1 | 0.250E-01 | FPLANT |
| R018 | Contamination fraction of meat | -1 | -1 | 0.250E-02 | FMEAT |
| R018 | Contamination fraction of milk | -1 | -1 | 0.250E-02 | FMILK |
| R019 | Livestock fodder intake for meat (kg/day) | 6.800E+01 | 6.800E+01 | --- | LFI5 |
| R019 | Livestock fodder intake for milk (kg/day) | 5.500E+01 | 5.500E+01 | --- | LFI6 |
| R019 | Livestock water intake for meat (L/day) | 5.000E+01 | 5.000E+01 | --- | LWI5 |
| R019 | Livestock water intake for milk (L/day) | 1.600E+02 | 1.600E+02 | --- | LWI6 |
| R019 | Livestock soil intake (kg/day) | 5.000E-01 | 5.000E-01 | --- | LSI |
| R019 | Mass loading for foliar deposition (g/m ² *3) | 1.000E-04 | 1.000E-04 | --- | MLFD |
| R019 | Depth of soil mixing layer (m) | 1.500E-01 | 1.500E-01 | --- | DM |
| R019 | Depth of roots (m) | 9.000E-01 | 9.000E-01 | --- | DROOT |
| R019 | Drinking water fraction from ground water | 1.000E+00 | 1.000E+00 | --- | FGWDW |
| R019 | Household water fraction from ground water | not used | 1.000E+00 | --- | FGWHH |
| R019 | Livestock water fraction from ground water | 1.000E+00 | 1.000E+00 | --- | FGWLW |
| R019 | Irrigation fraction from ground water | 1.000E+00 | 1.000E+00 | --- | FGWIR |
| R19B | Wet weight crop yield for Non-Leafy (kg/m ² *2) | 7.000E-01 | 7.000E-01 | --- | YV(1) |
| R19B | Wet weight crop yield for Leafy (kg/m ² *2) | 1.500E+00 | 1.500E+00 | --- | YV(2) |
| R19B | Wet weight crop yield for Fodder (kg/m ² *2) | 1.100E+00 | 1.100E+00 | --- | YV(3) |
| R19B | Growing Season for Non-Leafy (years) | 1.700E-01 | 1.700E-01 | --- | TE(1) |
| R19B | Growing Season for Leafy (years) | 2.500E-01 | 2.500E-01 | --- | TE(2) |
| R19B | Growing Season for Fodder (years) | 8.000E-02 | 8.000E-02 | --- | TE(3) |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Site-Specific Parameter Summary (continued)

| Menu | Parameter | User Input | Default | Used by RESRAD (If different from user input) | Parameter Name |
|------|--|------------|------------|--|----------------|
| R19B | Translocation Factor for Non-Leafy | 1.000E-01 | 1.000E-01 | --- | TIV(1) |
| R19B | Translocation Factor for Leafy | 1.000E+00 | 1.000E+00 | --- | TIV(2) |
| R19B | Translocation Factor for Fodder | 1.000E+00 | 1.000E+00 | --- | TIV(3) |
| R19B | Dry Foliar Interception Fraction for Non-Leafy | 2.500E-01 | 2.500E-01 | --- | RDRY(1) |
| R19B | Dry Foliar Interception Fraction for Leafy | 2.500E-01 | 2.500E-01 | --- | RDRY(2) |
| R19B | Dry Foliar Interception Fraction for Fodder | 2.500E-01 | 2.500E-01 | --- | RDRY(3) |
| R19B | Wet Foliar Interception Fraction for Non-Leafy | 2.500E-01 | 2.500E-01 | --- | RWET(1) |
| R19B | Wet Foliar Interception Fraction for Leafy | 2.500E-01 | 2.500E-01 | --- | RWET(2) |
| R19B | Wet Foliar Interception Fraction for Fodder | 2.500E-01 | 2.500E-01 | --- | RWET(3) |
| R19B | Weathering Removal Constant for Vegetation | 2.000E+01 | 2.000E+01 | --- | WLAM |
| C14 | C-12 concentration in water (g/cm**3) | 2.000E-05 | 2.000E-05 | --- | C12WTR |
| C14 | C-12 concentration in contaminated soil (g/g) | 3.000E-02 | 3.000E-02 | --- | C12CZ |
| C14 | Fraction of vegetation carbon from soil | 2.000E-02 | 2.000E-02 | --- | CSOIL |
| C14 | Fraction of vegetation carbon from air | 9.800E-01 | 9.800E-01 | --- | CAIR |
| C14 | C-14 evasion layer thickness in soil (m) | 3.000E-01 | 3.000E-01 | --- | DMC |
| C14 | C-14 evasion flux rate from soil (1/sec) | 7.000E-07 | 7.000E-07 | --- | EVSN |
| C14 | C-12 evasion flux rate from soil (1/sec) | 1.000E-10 | 1.000E-10 | --- | REVSN |
| C14 | Fraction of grain in beef cattle feed | 8.000E-01 | 8.000E-01 | --- | AVFG4 |
| C14 | Fraction of grain in milk cow feed | 2.000E-01 | 2.000E-01 | --- | AVFG5 |
| STOR | Storage times of contaminated foodstuffs (days): | | | | |
| STOR | Fruits, non-leafy vegetables, and grain | 1.400E+01 | 1.400E+01 | --- | STOR_T(1) |
| STOR | Leafy vegetables | 1.000E+00 | 1.000E+00 | --- | STOR_T(2) |
| STOR | Milk | 1.000E+00 | 1.000E+00 | --- | STOR_T(3) |
| STOR | Meat and poultry | 2.000E+01 | 2.000E+01 | --- | STOR_T(4) |
| STOR | Fish | 7.000E+00 | 7.000E+00 | --- | STOR_T(5) |
| STOR | Crustacea and mollusks | 7.000E+00 | 7.000E+00 | --- | STOR_T(6) |
| STOR | Well water | 1.000E+00 | 1.000E+00 | --- | STOR_T(7) |
| STOR | Surface water | 1.000E+00 | 1.000E+00 | --- | STOR_T(8) |
| STOR | Livestock fodder | 4.500E+01 | 4.500E+01 | --- | STOR_T(9) |
| R021 | Thickness of building foundation (m) | not used | 1.500E-01 | --- | FLOOR1 |
| R021 | Bulk density of building foundation (g/cm**3) | not used | 2.400E+00 | --- | DENSFL |
| R021 | Total porosity of the cover material | not used | 4.000E-01 | --- | TPCV |
| R021 | Total porosity of the building foundation | not used | 1.000E-01 | --- | TPFL |
| R021 | Volumetric water content of the cover material | not used | 5.000E-02 | --- | PH2OCV |
| R021 | Volumetric water content of the foundation | not used | 3.000E-02 | --- | PH2OFL |
| R021 | Diffusion coefficient for radon gas (m/sec): | | | | |
| R021 | in cover material | not used | 2.000E-06 | --- | DIFCV |
| R021 | in foundation material | not used | 3.000E-07 | --- | DIFFL |
| R021 | in contaminated zone soil | not used | 2.000E-06 | --- | DIFCZ |
| R021 | Radon vertical dimension of mixing (m) | not used | 2.000E+00 | --- | HMIX |
| R021 | Average building air exchange rate (1/hr) | not used | 5.000E-01 | --- | REXG |
| R021 | Height of the building (room) (m) | not used | 2.500E+00 | --- | HRM |
| R021 | Building interior area factor | not used | 0.000E+00 | --- | FAI |
| R021 | Building depth below ground surface (m) | not used | -1.000E+00 | --- | DMFL |
| R021 | Emanating power of Rn-222 gas | not used | 2.500E-01 | --- | EMANA(1) |
| R021 | Emanating power of Rn-220 gas | not used | 1.500E-01 | --- | EMANA(2) |
| TITL | Number of graphical time points | 32 | --- | --- | NPTS |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Site-Specific Parameter Summary (continued)

| Menu | Parameter | User Input | Default | Used by RESRAD (If different from user input) | Parameter Name |
|------|---|------------|---------|--|----------------|
| TITL | Maximum number of integration points for dose | 17 | --- | --- | LYMAX |
| TITL | Maximum number of integration points for risk | 1 | --- | --- | KYMAX |

Summary of Pathway Selections

| Pathway | User Selection |
|-----------------------------|----------------|
| 1 -- external gamma | active |
| 2 -- inhalation (w/o radon) | active |
| 3 -- plant ingestion | active |
| 4 -- meat ingestion | active |
| 5 -- milk ingestion | active |
| 6 -- aquatic foods | active |
| 7 -- drinking water | active |
| 8 -- soil ingestion | active |
| 9 -- radon | suppressed |
| Find peak pathway doses | active |

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 4.280E+00 years

Water Dependent Pathways

| Radio- Nuclide Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|------------------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 5.381E+00 | 0.9181 | 4.747E-03 | 0.0008 | 0.000E+00 | 0.0000 | 2.138E-02 | 0.0036 | 8.656E-04 | 0.0001 | 1.578E-02 | 0.0027 | 5.423E+00 | 0.9254 |
| C-14 | 3.244E-01 | 0.0554 | 1.106E-01 | 0.0189 | 0.000E+00 | 0.0000 | 5.132E-04 | 0.0001 | 5.818E-05 | 0.0000 | 1.981E-04 | 0.0000 | 4.358E-01 | 0.0744 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 6.142E-25 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 7.743E-28 | 0.0000 |
| H-3 | 1.416E-03 | 0.0002 | 1.093E-08 | 0.0000 | 0.000E+00 | 0.0000 | 6.174E-06 | 0.0000 | 1.680E-07 | 0.0000 | 4.783E-07 | 0.0000 | 1.423E-03 | 0.0002 |
| Total | 5.707E+00 | 0.9737 | 1.153E-01 | 0.0197 | 0.000E+00 | 0.0000 | 2.190E-02 | 0.0037 | 9.240E-04 | 0.0002 | 1.598E-02 | 0.0027 | 5.861E+00 | 1.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 0.000E+00 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 1.027E-24 | 0.9991 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 9.182E-28 | 0.0009 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 1.028E-24 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 0.000E+00 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.027E-24 | 0.9991 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 9.182E-28 | 0.0009 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.028E-24 | 1.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 1.000E+00 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 9.108E-25 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 8.824E-28 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 9.117E-25 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 1.000E+00 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 1.555E+00 | 0.9204 | 1.319E-03 | 0.0008 | 0.000E+00 | 0.0000 | 5.776E-03 | 0.0034 | 1.715E-04 | 0.0001 | 4.045E-03 | 0.0024 | 1.566E+00 | 0.9271 |
| C-14 | 9.224E-02 | 0.0546 | 3.023E-02 | 0.0179 | 0.000E+00 | 0.0000 | 1.332E-04 | 0.0001 | 1.400E-05 | 0.0000 | 5.576E-05 | 0.0000 | 1.227E-01 | 0.0726 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 9.108E-25 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 8.824E-28 | 0.0000 |
| H-3 | 4.772E-04 | 0.0003 | 3.541E-09 | 0.0000 | 0.000E+00 | 0.0000 | 1.912E-06 | 0.0000 | 4.560E-08 | 0.0000 | 1.566E-07 | 0.0000 | 4.794E-04 | 0.0003 |
| Total | 1.648E+00 | 0.9753 | 3.155E-02 | 0.0187 | 0.000E+00 | 0.0000 | 5.911E-03 | 0.0035 | 1.855E-04 | 0.0001 | 4.101E-03 | 0.0024 | 1.689E+00 | 1.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 3.000E+00 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 7.163E-25 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 8.148E-28 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 7.171E-25 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 3.000E+00 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 5.253E+00 | 0.9186 | 4.631E-03 | 0.0008 | 0.000E+00 | 0.0000 | 2.085E-02 | 0.0036 | 8.383E-04 | 0.0001 | 1.536E-02 | 0.0027 | 5.295E+00 | 0.9259 |
| C-14 | 3.146E-01 | 0.0550 | 1.071E-01 | 0.0187 | 0.000E+00 | 0.0000 | 4.967E-04 | 0.0001 | 5.621E-05 | 0.0000 | 1.920E-04 | 0.0000 | 4.225E-01 | 0.0739 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 7.163E-25 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 8.148E-28 | 0.0000 |
| H-3 | 1.475E-03 | 0.0003 | 1.137E-08 | 0.0000 | 0.000E+00 | 0.0000 | 6.419E-06 | 0.0000 | 1.742E-07 | 0.0000 | 4.978E-07 | 0.0000 | 1.482E-03 | 0.0003 |
| Total | 5.569E+00 | 0.9738 | 1.118E-01 | 0.0195 | 0.000E+00 | 0.0000 | 2.135E-02 | 0.0037 | 8.947E-04 | 0.0002 | 1.555E-02 | 0.0027 | 5.719E+00 | 1.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 1.000E+01 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 3.089E-25 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 6.167E-28 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 3.096E-25 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 1.000E+01 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 1.722E-03 | 0.9152 | 1.560E-06 | 0.0008 | 0.000E+00 | 0.0000 | 7.156E-06 | 0.0038 | 3.477E-07 | 0.0002 | 5.488E-06 | 0.0029 | 1.737E-03 | 0.9229 |
| C-14 | 1.070E-04 | 0.0569 | 3.744E-05 | 0.0199 | 0.000E+00 | 0.0000 | 1.795E-07 | 0.0001 | 2.136E-08 | 0.0000 | 6.580E-08 | 0.0000 | 1.447E-04 | 0.0769 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 3.089E-25 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 6.167E-28 | 0.0000 |
| H-3 | 3.414E-07 | 0.0002 | 2.705E-12 | 0.0000 | 0.000E+00 | 0.0000 | 1.572E-09 | 0.0000 | 4.652E-11 | 0.0000 | 1.178E-10 | 0.0000 | 3.432E-07 | 0.0002 |
| Total | 1.830E-03 | 0.9722 | 3.900E-05 | 0.0207 | 0.000E+00 | 0.0000 | 7.337E-06 | 0.0039 | 3.691E-07 | 0.0002 | 5.554E-06 | 0.0030 | 1.882E-03 | 1.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 3.000E+01 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 2.795E-26 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 2.782E-28 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 2.823E-26 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 3.000E+01 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 4.567E-17 | 0.9074 | 4.135E-20 | 0.0008 | 0.000E+00 | 0.0000 | 1.897E-19 | 0.0038 | 9.217E-21 | 0.0002 | 1.455E-19 | 0.0029 | 4.605E-17 | 0.9151 |
| C-14 | 3.156E-18 | 0.0627 | 1.104E-18 | 0.0219 | 0.000E+00 | 0.0000 | 5.295E-21 | 0.0001 | 6.301E-22 | 0.0000 | 1.941E-21 | 0.0000 | 4.269E-18 | 0.0848 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 2.795E-26 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 2.782E-28 | 0.0000 |
| H-3 | 3.286E-21 | 0.0001 | 2.603E-26 | 0.0000 | 0.000E+00 | 0.0000 | 1.513E-23 | 0.0000 | 4.477E-25 | 0.0000 | 1.133E-24 | 0.0000 | 3.303E-21 | 0.0001 |
| Total | 4.883E-17 | 0.9702 | 1.146E-18 | 0.0228 | 0.000E+00 | 0.0000 | 1.950E-19 | 0.0039 | 9.848E-21 | 0.0002 | 1.474E-19 | 0.0029 | 5.032E-17 | 1.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 1.000E+02 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 6.226E-30 | 0.2663 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 1.715E-29 | 0.7337 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 2.338E-29 | 1.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 1.000E+02 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 6.226E-30 | 0.2663 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 1.715E-29 | 0.7337 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 2.338E-29 | 1.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 3.000E+02 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)
As mrem/yr and Fraction of Total Dose At t = 3.000E+02 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|------------------|---------------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 1.000E+03 years

Water Independent Pathways (Inhalation excludes radon)

| Radio- Nuclide | Ground | | Inhalation | | Radon | | Plant | | Meat | | Milk | | Soil | |
|-------------------|-----------|--------|------------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

Total Dose Contributions TDOSE(i,p,t) for Individual Radionuclides (i) and Pathways (p)

As mrem/yr and Fraction of Total Dose At t = 1.000E+03 years

Water Dependent Pathways

| Radio- Nuclide | Water | | Fish | | Radon | | Plant | | Meat | | Milk | | All Pathways* | |
|-------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|--------|
| | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. | mrem/yr | fract. |
| Ag-108m | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| C-14 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Co-60 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Cs-137 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Eu-152 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| H-3 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |
| Total | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 | 0.000E+00 | 0.0000 |

*Sum of all water independent and dependent pathways.

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Dose/Source Ratios Summed Over All Pathways
Parent and Progeny Principal Radionuclide Contributions Indicated

| Parent (i) | Product (j) | Thread Fraction | DSR(j,t) At Time in Years (mrem/yr)/(pCi/g) | | | | | | | |
|---------------|----------------|--------------------|---|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| | | | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.000E+01 | 1.000E+02 | 3.000E+02 | 1.000E+03 |
| Ag-108m+D | Ag-108m+D | 1.000E+00 | 6.777E-32 | 3.290E-02 | 1.112E-01 | 3.649E-05 | 9.675E-19 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| C-14 | C-14 | 1.000E+00 | 0.000E+00 | 1.203E-02 | 4.142E-02 | 1.419E-05 | 4.185E-19 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Co-60 | Co-60 | 1.000E+00 | 3.112E-25 | 2.760E-25 | 2.171E-25 | 9.362E-26 | 8.470E-27 | 1.887E-30 | 6.932E-41 | 0.000E+00 |
| Cs-137+D | Cs-137+D | 1.000E+00 | 2.016E-31 | 1.998E-31 | 1.963E-31 | 1.844E-31 | 1.542E-31 | 8.256E-32 | 1.385E-32 | 2.675E-35 |
| Eu-152 | Eu-152 | 7.208E-01 | 1.103E-27 | 1.060E-27 | 9.789E-28 | 7.409E-28 | 3.342E-28 | 2.060E-29 | 7.190E-33 | 5.605E-45 |
| Eu-152 | Eu-152 | 2.792E-01 | 4.273E-28 | 4.106E-28 | 3.792E-28 | 2.870E-28 | 1.295E-28 | 7.981E-30 | 2.785E-33 | 2.803E-45 |
| Eu-152 | Gd-152 | 2.792E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Eu-152 | ΣDSR(j) | | 4.273E-28 | 4.106E-28 | 3.792E-28 | 2.870E-28 | 1.295E-28 | 7.981E-30 | 2.785E-33 | 2.803E-45 |
| H-3 | H-3 | 1.000E+00 | 0.000E+00 | 2.523E-04 | 7.799E-04 | 1.806E-07 | 1.738E-21 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

The DSR includes contributions from associated (half-life ≤ 30 days) daughters.

Single Radionuclide Soil Guidelines G(i,t) in pCi/g
Basic Radiation Dose Limit = 2.500E+01 mrem/yr

| Nuclide (i) | t= | 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.000E+01 | 1.000E+02 | 3.000E+02 | 1.000E+03 |
|----------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Ag-108m | *2.609E+13 | 7.598E+02 | 2.248E+02 | 6.851E+05 | *2.609E+13 | *2.609E+13 | *2.609E+13 | *2.609E+13 | *2.609E+13 |
| C-14 | *4.455E+12 | 2.079E+03 | 6.036E+02 | 1.762E+06 | *4.455E+12 | *4.455E+12 | *4.455E+12 | *4.455E+12 | *4.455E+12 |
| Co-60 | *1.132E+15 | *1.132E+15 | *1.132E+15 | *1.132E+15 | *1.132E+15 | *1.132E+15 | *1.132E+15 | *1.132E+15 | *1.132E+15 |
| Cs-137 | *8.704E+13 | *8.704E+13 | *8.704E+13 | *8.704E+13 | *8.704E+13 | *8.704E+13 | *8.704E+13 | *8.704E+13 | *8.704E+13 |
| Eu-152 | *1.765E+14 | *1.765E+14 | *1.765E+14 | *1.765E+14 | *1.765E+14 | *1.765E+14 | *1.765E+14 | *1.765E+14 | *1.765E+14 |
| H-3 | *9.597E+15 | 9.909E+04 | 3.205E+04 | 1.384E+08 | *9.597E+15 | *9.597E+15 | *9.597E+15 | *9.597E+15 | *9.597E+15 |

*At specific activity limit

Summed Dose/Source Ratios DSR(i,t) in (mrem/yr)/(pCi/g)
and Single Radionuclide Soil Guidelines G(i,t) in pCi/g
at tmin = time of minimum single radionuclide soil guideline
and at tmax = time of maximum total dose = 4.280 ± 0.009 years

| Nuclide (i) | Initial (pCi/g) | tmin (years) | DSR(i,tmin) | G(i,tmin) (pCi/g) | DSR(i,tmax) | G(i,tmax) (pCi/g) |
|----------------|--------------------|-----------------|-------------|----------------------|-------------|----------------------|
| Ag-108m | 4.760E+01 | 4.283 ± 0.009 | 1.139E-01 | 2.194E+02 | 1.139E-01 | 2.194E+02 |
| C-14 | 1.020E+01 | 4.285 ± 0.009 | 4.272E-02 | 5.851E+02 | 4.272E-02 | 5.852E+02 |
| Co-60 | 3.300E+00 | 0.000E+00 | 3.112E-25 | *1.132E+15 | 1.861E-25 | *1.132E+15 |
| Cs-137 | 2.000E+00 | 0.000E+00 | 0.000E+00 | *8.704E+13 | 0.000E+00 | *8.704E+13 |
| Eu-152 | 6.000E-01 | 0.000E+00 | 1.530E-27 | *1.765E+14 | 1.291E-27 | *1.765E+14 |
| H-3 | 1.900E+00 | 3.007 ± 0.006 | 7.799E-04 | 3.205E+04 | 7.489E-04 | 3.338E+04 |

*At specific activity limit

Summary : RESRAD Default Parameters

File : C:\USERS\THANSEN\DESKTOP\U OF MI\FARMER.RAD

Individual Nuclide Dose Summed Over All Pathways
Parent Nuclide and Branch Fraction Indicated

| Nuclide (j) | Parent (i) | THF(i) | DOSE(j,t), mrem/yr | | | | | | | |
|----------------|---------------|-----------|--------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| | | | t= 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.000E+01 | 1.000E+02 | 3.000E+02 | 1.000E+03 |
| Ag-108m | Ag-108m | 1.000E+00 | 0.000E+00 | 1.566E+00 | 5.295E+00 | 1.737E-03 | 4.605E-17 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| C-14 | C-14 | 1.000E+00 | 0.000E+00 | 1.227E-01 | 4.225E-01 | 1.447E-04 | 4.269E-16 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Co-60 | Co-60 | 1.000E+00 | 1.027E-24 | 9.108E-25 | 7.163E-25 | 3.089E-25 | 2.795E-26 | 6.226E-30 | 0.000E+00 | 0.000E+00 |
| Cs-137 | Cs-137 | 1.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Eu-152 | Eu-152 | 7.208E-01 | 6.618E-28 | 6.360E-28 | 5.873E-28 | 4.445E-28 | 2.005E-28 | 1.236E-29 | 0.000E+00 | 0.000E+00 |
| Eu-152 | Eu-152 | 2.792E-01 | 2.564E-28 | 2.464E-28 | 2.275E-28 | 1.722E-28 | 7.767E-29 | 4.789E-30 | 0.000E+00 | 0.000E+00 |
| Eu-152 | ΣDOSE(j) | | 9.182E-28 | 8.824E-28 | 8.148E-28 | 6.167E-28 | 2.782E-28 | 1.715E-29 | 0.000E+00 | 0.000E+00 |
| Gd-152 | Eu-152 | 2.792E-01 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| H-3 | H-3 | 1.000E+00 | 0.000E+00 | 4.794E-04 | 1.482E-03 | 3.432E-07 | 3.303E-21 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

THF(i) is the thread fraction of the parent nuclide.


Individual Nuclide Soil Concentration
Parent Nuclide and Branch Fraction Indicated

| Nuclide (j) | Parent (i) | THF(i) | S(j,t), pCi/g | | | | | | | |
|----------------|---------------|-----------|---------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| | | | t= 0.000E+00 | 1.000E+00 | 3.000E+00 | 1.000E+01 | 3.000E+01 | 1.000E+02 | 3.000E+02 | 1.000E+03 |
| Ag-108m | Ag-108m | 1.000E+00 | 4.760E+01 | 9.968E+00 | 4.371E-01 | 7.718E-06 | 2.029E-19 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| C-14 | C-14 | 1.000E+00 | 1.020E+01 | 2.147E+00 | 9.517E-02 | 1.744E-06 | 5.103E-20 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| Co-60 | Co-60 | 1.000E+00 | 3.300E+00 | 2.892E+00 | 2.222E+00 | 8.830E-01 | 6.322E-02 | 6.208E-06 | 2.197E-17 | 0.000E+00 |
| Cs-137 | Cs-137 | 1.000E+00 | 2.000E+00 | 1.954E+00 | 1.866E+00 | 1.586E+00 | 9.978E-01 | 1.970E-01 | 1.911E-03 | 1.719E-10 |
| Eu-152 | Eu-152 | 7.208E-01 | 4.325E-01 | 4.104E-01 | 3.696E-01 | 2.561E-01 | 8.979E-02 | 2.292E-03 | 6.434E-08 | 7.544E-24 |
| Eu-152 | Eu-152 | 2.792E-01 | 1.675E-01 | 1.590E-01 | 1.432E-01 | 9.919E-02 | 3.478E-02 | 8.876E-04 | 2.492E-08 | 2.922E-24 |
| Eu-152 | ΣS(j): | | 6.000E-01 | 5.694E-01 | 5.127E-01 | 3.553E-01 | 1.246E-01 | 3.179E-03 | 8.926E-08 | 1.047E-23 |
| Gd-152 | Eu-152 | 2.792E-01 | 0.000E+00 | 1.047E-15 | 2.983E-15 | 8.350E-15 | 1.613E-14 | 1.975E-14 | 1.832E-14 | 1.380E-14 |
| H-3 | H-3 | 1.000E+00 | 1.900E+00 | 3.782E-01 | 1.499E-02 | 1.856E-07 | 1.771E-21 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

THF(i) is the thread fraction of the parent nuclide.


RESCALC.EXE execution time = 0.78 seconds

DOSE: All Nuclides Summed, All Pathways Summed



○ Ag-108m ◇ C-14 □ Co-60 △ Cs-137 ▽ Eu-152 * H-3 * Total

DOSE: All Nuclides Summed, All Pathways Summed



Appendix M:
Quality Assurance
Precision Comparison
Results

Quality Assurance Precision Comparison Results

| Location | Gross Counts cpm/100cm ² | | RPD |
|-------------------|--|-----|-------|
| | FSS | QA | |
| FNR_B-1_F1_C_020 | 299 | 307 | 2.6% |
| FNR_B-1_F1_C_022 | 266 | 318 | 17.8% |
| FNR_B-2_F1_C_019 | 276 | 297 | 7.3% |
| FNR_B-3_W1_C_017 | 269 | 279 | 3.6% |
| FNR_B-4_W1_C_020 | 239 | 242 | 1.2% |
| FNR_B-4_W1_C_026 | 270 | 252 | 6.9% |
| FNR_B-5_W1_C_019 | 300 | 319 | 6.1% |
| FNR_B-6_C1_D_018 | 226 | 293 | 25.8% |
| FNR_1-1_F1_C_019 | 350 | 307 | 13.1% |
| FNR_1-2_F1_C_020 | 310 | 284 | 8.8% |
| FNR_1-3_F1_C_017 | 279 | 261 | 6.7% |
| FNR_1-4_F1_C_018 | 311 | 328 | 5.3% |
| FNR_1-5_W1_C_020 | 259 | 306 | 16.6% |
| FNR_1-6_W1_C_020 | 237 | 265 | 11.2% |
| FNR_1-7_W1_C_017 | 296 | 306 | 3.3% |
| FNR_1-8_W1_D_020 | 212 | 301 | 34.7% |
| FNR_1-8_W1_D_025 | 258 | 264 | 2.3% |
| FNR_1-9_W1_A_018 | 268 | 266 | 0.7% |
| FNR_1-10_W1_C_017 | 220 | 141 | 43.8% |
| FNR_1-11_W1_A_017 | 348 | 343 | 1.4% |
| FNR_1-12_W1_D_018 | 255 | 235 | 8.2% |
| FNR_1-13_F1_C_020 | 264 | 283 | 6.9% |
| FNR_1-13_F1_C_023 | 460 | 493 | 6.9% |
| FNR_1-14_W1_D_019 | 264 | 250 | 5.4% |
| FNR_1-15_C1_D_019 | 236 | 240 | 1.7% |
| FNR_1-16_W1_D_021 | 247 | 261 | 5.5% |
| FNR_1-16_W1_C_028 | 267 | 254 | 5.0% |
| FNR_1-17_C1_M_021 | 168 | 145 | 14.7% |
| FNR_1-17_C1_M_024 | 223 | 200 | 10.9% |
| FNR_1-18_C1_M_017 | 170 | 183 | 7.4% |
| FNR_2-1_W1_D_018 | 246 | 247 | 0.4% |
| FNR_2-2_F1_C_019 | 266 | 290 | 8.6% |
| FNR_2-3_W1_C_018 | 265 | 328 | 21.2% |

| Location | Gross Counts cpm/100cm ² | | RPD |
|-------------------|--|-----|-------|
| | FSS | QA | |
| FNR_2-4_W1_C_018 | 287 | 368 | 24.7% |
| FNR_2-5_W1_A_020 | 343 | 317 | 7.9% |
| FNR_2-5_W1_B_028 | 308 | 400 | 26.0% |
| FNR_2-6_W1_A_018 | 322 | 319 | 0.9% |
| FNR_2-7_W1_A_019 | 312 | 310 | 0.6% |
| FNR_2-8_W1_A_017 | 341 | 317 | 7.3% |
| FNR_2-9_C1_D_020 | 284 | 333 | 15.9% |
| FNR_2-9_W1_A_022 | 301 | 357 | 17.0% |
| FNR_2-10_W1_W_020 | 546 | 549 | 0.5% |
| FNR_2-10_W1_W_026 | 609 | 571 | 6.4% |
| FNR_2-11_F1_C_017 | 395 | 435 | 9.6% |
| FNR_2-12_W1_A_017 | 402 | 429 | 6.5% |
| FNR_2-13_C1_D_019 | 299 | 311 | 3.9% |
| FNR_3-1_C1_C_020 | 270 | 281 | 4.0% |
| FNR_3-1_W1_D_025 | 310 | 278 | 10.9% |
| FNR_3-2_C1_D_020 | 286 | 323 | 12.2% |
| FNR_3-2_W1_A_022 | 341 | 354 | 3.7% |
| FNR_3-3_W1_A_017 | 347 | 346 | 0.3% |
| FNR_3-4_W1_A_017 | 351 | 347 | 1.1% |
| FNR_3-5_W1_A_018 | 323 | 323 | 0.0% |
| FNR_3-6_C1_C_020 | 284 | 310 | 8.8% |
| FNR_3-6_W1_A_025 | 310 | 346 | 11.0% |
| FNR_3-7_W1_W_020 | 549 | 612 | 10.9% |
| FNR_3-8_W1_D_020 | 315 | 295 | 6.6% |
| FNR_3-8_W1_A_022 | 373 | 350 | 6.4% |
| FNR_3-9_F1_C_018 | 315 | 317 | 0.6% |
| FNR_3-10_C1_C_020 | 241 | 262 | 8.3% |
| FNR_3-10_C1_C_022 | 268 | 312 | 15.2% |
| FNR_3-11_F1_C_018 | 336 | 325 | 3.3% |
| FNR_3-12_W1_D_018 | 238 | 258 | 8.1% |
| FNR_3-12_W1_D_022 | 270 | 298 | 9.9% |
| FNR_3-13_W1_D_018 | 260 | 268 | 3.0% |
| FNR_3-14_W1_D_017 | 186 | 280 | 40.3% |
| FNR_3-15_F1_C_017 | 286 | 194 | 38.3% |
| FNR_3-16_S1_M_016 | 168 | 144 | 15.4% |

| Location | Gross Counts cpm/100cm ² | | RPD |
|---------------------|--|-----|-------|
| | FSS | QA | |
| FNR_4-1_W1_R_017 | 443 | 424 | 4.4% |
| FNR_4-2_W1_M_018 | 181 | 181 | 0.0% |
| FNR_S-1_W1_A_017 | 242 | 291 | 18.4% |
| FNR_S-2_F1_C_020 | 264 | 335 | 23.7% |
| FNR_S-2_F1_C_029 | 301 | 343 | 13.0% |
| FNR_S-3_W1_D_019 | 289 | 251 | 14.1% |
| FNR_S-4_C1_M_020 | 298 | 247 | 18.7% |
| FNR_S-4_C1_M_027 | 277 | 206 | 29.4% |
| FNR_S-5_W1_D_017 | 308 | 308 | 0.0% |
| FNR_R&O-1_F1_M_017 | 298 | 281 | 5.9% |
| FNR_R&O-2_F1_C_020 | 315 | 312 | 1.0% |
| FNR_R&O-2_F1_C_040 | 313 | 313 | 0.0% |
| FNR_R&O-2_F1_C_060 | 302 | 299 | 1.0% |
| FNR_R&O-2_F1_C_080 | 318 | 368 | 14.6% |
| FNR_R&O-2_F1_C_084 | 366 | 394 | 7.4% |
| FNR_MISC-1_S1_M_017 | 175 | 181 | 3.4% |
| FNR_MISC-2_F1_C_005 | 334 | 371 | 10.5% |
| Maximum | | | 43.8% |