

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 14

Scenario: CMP22

Continued on Page 392

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																							
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																							
Circuit:	BUS 2A																																							
Schematic:	B253867																																							
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52CC-MG1	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52TC-MG1	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52X-MG1	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	74/1-MG1	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	INDLTS-MG1	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
Schematic: B253867 Amps @ 125VDC Totals:							0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12		
Circuit: BUS 2A Amps @ 125VDC Totals:							3.28	15.28	3.25	3.25	3.25	3.25	3.25	3.25	3.28	15.28	3.25	3.25	5.25	3.28	15.28	3.25	3.25	5.25	3.28	15.28	3.25	3.25	5.25	3.28	15.28	3.25	3.25	5.25	3.28	15.28	3.25	3.25	5.25	3.28

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 15

Scenario: CMP22

Continued on Page 393

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	2/SI3-SI3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-SI3	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-SI3	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-SI3	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74-SI3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-A-SI3	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-SI3	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 300925 Amps @ 125VDC Totals:							0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 16

Scenario: CMP22

Continued on Page 394

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	BUS 6A																																			
Schematic:	9321-LL-3117 SH 03A																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-JV-TS-N-2A (2)	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3117 SH 03A Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 17

Scenario: CMP22

Continued on Page 395

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:20:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	27-S1/6A-6A	ABB / TYPE 27N, SERIES 411T, #411	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-S2/6A-6A	ABB / TYPE 27N, SERIES 411T, #411	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	47X-SG22-U13A	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	62-1/6A-6A	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	62/6A-6A	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-N-SG22-U13A	UNKNOWN / NE-2, NEON LAMP, 200	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3118 SH 03B Amps @ 125VDC Totals:							0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 18

Scenario: CMP22

Continued on Page 396

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	13BX/O-6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	13BX/R-6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-6A	WHSE / DB-75-CC	Z	25.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-6A	WHSE / DB-75-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-6A	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/6A-6A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
4	INDLTS-6A	UNKNOWN / INDICATING LIGHT	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	INDLTS-N-6A	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-TS MON-6A	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3118 SH 04 Amps @ 125VDC Totals:							0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 19

Scenario: CMP22

Continued on Page 397

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Qty	Device ID	Mfg/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52CC-3AT6A	WHSE / DB-75-CC	Z	25.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52LO-3AT6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52TC-3AT6A	WHSE / DB-75-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-3AT6A	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/3AT6A-3AT6A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	7BX/O-3AT6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	7BX/R-3AT6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	7BX1/O-3AT6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	7BX1/R-3AT6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-3AT6A	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3118 SH 05 Amps @ 125VDC Totals:							0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 20

Scenario: CMP22

Continued on Page 398

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	13CX/O-EG3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	13CX/R-EG3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	13CX1/O-EG3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	13CX1/R-EG3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-EG3	WHSE / DB-75-CC	Z	25.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-EG3	WHSE / DB-75-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-EG3	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/EG3-EG3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
4	INDLTS-EG3	UNKNOWN / INDICATING LIGHT	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	INDLTS-N-EG3	ALCO / NEON- BND-2R	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3118 SH 07 Amps @ 125VDC Totals:							0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 21

Scenario: CMP22

Continued on Page 399

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	BUS 6A																																	
Schematic:	9321-LL-3118 SH 09																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-MCC6B	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-MCC6B	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-MCC6B	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
2	INDLTS-MCC6B	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-MCC6B	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3118 SH 09 Amps @ 125VDC Totals:							0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 22

Scenario: CMP22

Continued on Page 400

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-LTIE	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52CC-MCC7A	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-LTIE	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-MCC7A	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-LTIE	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-MCC7A	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
Schematic: 9321-LL-3118 SH 10 Amps @ 125VDC Totals:							0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 23

Scenario: CMP22

Continued on Page 401

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	BUS 6A																																					
Schematic:	9321-LL-3118 SH 16																																					
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	2-1/AF3-AF3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	2-2/AF3-AF3	A-B / 700-RTC	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-AF3	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-AF3	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-AF3	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/AF3-AF3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	BFD/3-AF3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-AF3	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-AF3	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3118 SH 16 Amps @ 125VDC Totals:							0.46	0.46	0.46	0.46	0.46	0.46	0.48	12.48	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 24

Scenario: CMP22

Continued on Page 402

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	BUS 6A																																			
Schematic:	9321-LL-3118 SH 18																																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-TAO	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-TAO	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-TAO	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74TAO-TAO	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	86TAO-TAO	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	BFD/1-TAO	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-TAO	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3118 SH 18 Amps @ 125VDC Totals:							0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 25

Scenario: CMP22

Continued on Page 403

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	BUS 6A																																	
Schematic:	A208088																																	
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	EDD1	ASCO / AUTO TRANSFER P/N 302A	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: A208088 Amps @ 125VDC Totals:							0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 26

Scenario: CMP22

Continued on Page 404

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-MG2	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-MG2	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-MG2	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/2-MG2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-MG2	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225131 Amps @ 125VDC Totals:							0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 27

Scenario: CMP22

Continued on Page 405

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	BUS 6A																																					
Schematic:	B225132																																					
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	2/C3	AGASTAT / 7000 SERIES	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	52CC-C3	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-C3	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-C3	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
2	INDLTS-C3	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225132 Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 28

Scenario: CMP22

Continued on Page 406

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	2/RHR2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-RHR2	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-RHR2	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-RHR2	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74-RHR2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-N-RHR2	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
3	INDLTS-RHR2	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: B225137 Amps @ 125VDC Totals:							0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 29

Scenario: CMP22

Continued on Page 407

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52CC-R2	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52TC-R2	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-R2	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74-R2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-N-R2	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
2	INDLTS-R2	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225142 Amps @ 125VDC Totals:							0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 30

Scenario: CMP22

Continued on Page 408

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	2/CRF5	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	52CC-CRF5	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-CRF5	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-CRF5	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74-CRF5	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-CRF5	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-CRF5	ALCO / NEON- BND-2R	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225143 Amps @ 125VDC Totals:							0.26	0.26	0.26	0.28	12.28	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 31

Scenario: CMP22

Continued on Page 409

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	BUS 6A																																			
Schematic:	B225144																																			
Qty	Device ID	Mfg/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-PC	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-PC	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-PC	WHSE / X-CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
2	JNDLTS-PC	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225144 Amps @ 125VDC Totals:							0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 32

Scenario: CMP22

Continued on Page 410

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	2/CS2-CS2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	52CC-CS2	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-CS2	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-CS2	WHSE / X-CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74-CS2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-CS2	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-CS2	ALCO / NEON-BND-2R	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225146 Amps @ 125VDC Totals:							0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 33

Scenario: CMP22

Continued on Page 411

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	2/SW3-SW3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	52CC-SW3	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-SW3	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-SW3	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/SW3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-N-SW3	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
3	INDLTS-SW3	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	M-SW3	UNKNOWN / TIME METER	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	S8C-SW3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225149 Amps @ 125VDC Totals:							0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 34

Scenario: CMP22

Continued on Page 412

				Time Step:		15		16		17		18		19		20		21		22		23		24		25		26		27		28	
				Time Step Range:		0:00:25.0 - 0:00:25.1		0:00:25.1 - 0:00:26.0		0:00:26.0 - 0:00:30.0		0:00:30.0 - 0:00:30.1		0:00:30.1 - 0:00:31.0		0:00:31.0 - 0:00:35.0		0:00:35.0 - 0:00:35.1		0:00:35.1 - 0:00:36.0		0:01:00.0 - 0:20:00.0		0:20:00.0 - 0:20:01.0		0:20:01.0 - 0:20:01.1		0:20:01.1 - 0:21:00.0		0:21:00.0 - 0:30:00.0			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	52CC-CC3	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
1	52TC-CC3	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
1	52X-CC3	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
1	74-CC3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	86-CC3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	CC3-2TD-CC3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
3	INDLTS-CC3	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	
1	INDLTS-N-CC3	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	

Schematic: B225151 Amps @ 125VDC Totals: 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.41 12.41 0.39

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 35

Scenario: CMP22

Continued on Page 413

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	BUS 6A																																					
Schematic:	IP2-S-000194																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	2/SW6-SW6	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	52CC-SW6	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-SW6	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-SW6	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/SW6	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-N-SW6	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
3	INDLTS-SW6	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	M-SW6	UNKNOWN / TIME METER	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	S8B-SW6	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: IP2-S-000194 Amps @ 125VDC Totals:				0.41	12.41	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	
Circuit: BUS 6A Amps @ 125VDC Totals:				5.47	17.47	5.44	5.47	17.47	5.44	5.47	17.47	5.44	5.47	17.47	5.44	5.44	5.44	5.47	17.47	5.44	5.44	5.44	5.47	17.47	5.44	5.47	17.47	5.44	5.47	17.47	5.44	5.47	17.47	5.44	5.47	17.47	5.44	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 36

Scenario: CMP22

Continued on Page 414

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																		
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																		
Circuit:	DA5 XFR SW																																		
Schematic:	195B47																																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	DA5	ASCO / TYPE BULLETIN 908, ASSUN	Z	0.95	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: 195B47 Amps @ 125VDC Totals:							0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95		
Circuit: DA5 XFR SW Amps @ 125VDC Totals:							0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 37

Scenario: CMP22

Continued on Page 415

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DG22-CONTROL																																			
Schematic:	A208540																																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	86-EDG 22	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	86X-EDG 22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CVX-EDG 22	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	INDLTS-GEN-EDG 22	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	VBR-EDG 22	WHSE / CV	Z	0.20	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
Schematic: A208540 Amps @ 125VDC Totals:							0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 39

Scenario: CMP22

Continued on Page 417

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	PDT-EDG 22	UNKNOWN / UNKNOWN TIME DELA	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	R1-EDG 22	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	R2-EDG 22	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	RR-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SDR-EDG 22	AMERACE / CAT. NO. E7022PE004	Z	0.06	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	UPR-EDG 22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
Schematic: IP2-S-000285 Amps @ 125VDC Totals:							2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.18	2.18	2.18	2.18	2.18	2.18	2.18	2.18	2.18	2.18	2.18	2.18	2.18	2.18	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 40

Scenario: CMP22

Continued on Page 418

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																		
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INDLTS-EDG 22	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	JWPS(3,4)-EDG 22	WHSE / Nbfd	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	K1-EDG 22	WHSE / TYPE MLLO-2H	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	K1T-EDG 22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
1	K2-EDG 22	WHSE / TYPE MLLO-2H	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	K4-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
Schematic: IP2-S-000365 Amps @ 125VDC Totals:							0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39		
Circuit: DG22-CONTROL Amps @ 125VDC Totals:							3.23	3.23	3.23	3.23	3.23	3.23	3.23	3.23	3.23	3.23	3.23	3.23	3.23	3.23	3.23	3.23	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 41

Scenario: CMP22

Continued on Page 419

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DG23-CONTROL																																			
Schematic:	A208540																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	86-EDG 23	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	86X-EDG 23	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CVX-EDG 23	WHSE / MG-6	Z	0.06	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	INDLTS-GEN-EDG 23	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	VBR-EDG 23	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: A208540 Amps @ 125VDC Totals:							0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 43

Scenario: CMP22

Continued on Page 421

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	PDT-EDG 23	UNKNOWN / UNKNOWN TIME DELA	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	R1-EDG 23	WHSE / BFD	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	R2-EDG 23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	RR-EDG 23	UNKNOWN / UNKNOWN W/ DIODE IS	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SDR-EDG 23	UNKNOWN / UNKNOWN TIME DELA	Z	0.07	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	UPR-EDG 23	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
Schematic: IP2-S-000286 Amps @ 125VDC Totals:							1.76	1.76	1.76	1.76	1.76	1.76	1.76	1.76	1.76	1.76	1.76	2.11	2.11	2.11	2.11	2.11	2.11	2.11	2.11	2.11	2.11	2.11	2.11	2.11	2.11	2.11	2.11	2.11

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 44

Scenario: CMP22

Continued on Page 422

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																		
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																		
Circuit:	DG23-CONTROL																																		
Schematic:	IP2-S-000366																																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INDLTS-EDG 23	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	JWPS(3,4)X-EDG 23	WHSE / NBFD	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	K1-EDG 23	WHSE / TYPE MLLO-2H	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	K2-EDG 23	WHSE / TYPE MLLO-2H	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	K4-EDG 23	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
Schematic: IP2-S-000366 Amps @ 125VDC Totals:							0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39		
Circuit: DG23-CONTROL Amps @ 125VDC Totals:							2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37	2.37

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 45

Scenario: CMP22

Continued on Page 423

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-01																																			
Schematic:	9321-LL-3132 SH 07																																			
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	85L2/345-345kV LINE	UNKNOWN / PILOT WIRE RECIEVER	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	86X1-345kV LINE	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	87L2/345-345kV LINE	WHSE / TYPE HCB, DIFF CURRENT	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-345kV LINE (2)	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	TD1/345-345kV LINE	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TD2/345-345kV LINE	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TD2X-345kV LINE	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TD3/345-345kV LINE	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 9321-LL-3132 SH 07 Amps @ 125VDC Totals:							0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 46

Scenario: CMP22

Continued on Page 424

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-01																																			
Schematic:	9321-LL-3132 SH 09																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	85L2/138-138kV LINE	UNKNOWN / PILOT WRE RECIEVER	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	87L2/138-138kV LINE	WHSE / TYPE HCB, DIFF CURRENT	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-138kV LINE (2)	UNKNOWN / LIGHT WTH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	TD1-138kV LINE	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TD2-138kV LINE	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TD2X-138kV LINE	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TD3-138kV LINE	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 9321-LL-3132 SH 09 Amps @ 125VDC Totals:							0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 47

Scenario: CMP22

Continued on Page 425

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28									
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0									
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	81T2-UVUF	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225122 Amps @ 125VDC Totals:							0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 48

Scenario: CMP22

Continued on Page 426

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28										
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0										
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	27-6/62-UUVUF	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	27-6/62X-UUVUF	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	27-6/CS-UUVUF	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	27-6/X1-UUVUF	WHSE / MG-6, 24 V, W/ 300 OHM RE	Z	0.32	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: B225125 Amps @ 125VDC Totals:							0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	
Circuit: DP22-01 Amps @ 125VDC Totals:							2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 49

Scenario: CMP22

Continued on Page 427

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28														
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0														
Circuit:	DP22-02																														
Schematic:	9321-LL-3132 SH 11																														
Qty	Device ID	Mfg/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div					
1	201/C-BKR-7	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	294/T-BKR-7	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
Schematic: 9321-LL-3132 SH 11 Amps @ 125VDC Totals:							0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21			
Circuit: DP22-02 Amps @ 125VDC Totals:							0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 50

Scenario: CMP22

Continued on Page 428

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-03																																	
Schematic:	9321-LL-3132 SH 02																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	62/UT	UNKNOWN / TD-53 TIME DELAY REL	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	86/UT	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-MISC LO RLY (2)	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	INDLTS-N-MISC LO RLY (2)	UNKNOWN / NE-2, NEON LAMP, 200	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3132 SH 02 Amps @ 125VDC Totals:							0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 51

Scenario: CMP22

Continued on Page 429

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-03																																	
Schematic:	9321-LL-3132 SH 04																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	86/STBU	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
Schematic: 9321-LL-3132 SH 04 Amps @ 125VDC Totals:							0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 52

Scenario: CMP22

Continued on Page 430

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-03																																	
Schematic:	9321-LL-3132 SH 05																																	
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	25X2-MISC LO RLY	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 9321-LL-3132 SH 05 Amps @ 125VDC Totals:							0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 53

Scenario: CMP22

Continued on Page 431

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																
Circuit:	DP22-03																																
Schematic:	9321-LL-3132 SH 13																																
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	86/STBU-A	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
Schematic: 9321-LL-3132 SH 13 Amps @ 125VDC Totals:							0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
Circuit: DP22-03 Amps @ 125VDC Totals:							0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 54

Scenario: CMP22

Continued on Page 432

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-04																																			
Schematic:	B209518																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div		
1	INDLTS-V951	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV951	ASCO / CAT. NO. NP8320A183V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B209518 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 55

Scenario: CMP22

Continued on Page 433

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-04																																	
Schematic:	B209519																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V953	UNKNOWN / LIGHT W/TH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV953	ASCO / CAT. NO. NP8320A183V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B209519 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 56

Scenario: CMP22

Continued on Page 434

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-04																																			
Schematic:	B209520																																			
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V955C	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV955C	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B209520 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 57

Scenario: CMP22

Continued on Page 435

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-04																																	
Schematic:	B209521																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V955D	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV955D	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B209521 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 58

Scenario: CMP22

Continued on Page 436

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28															
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0															
Circuit:	DP22-04																															
Schematic:	B209522																															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V955E	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV955E	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B209522 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 59

Scenario: CMP22

Continued on Page 437

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-04																																			
Schematic:	B209523																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	INDLTS-V955F	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	SOV955F	ASCO / CAT. NO. NP8320A183E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: B209523 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16		
Circuit: DP22-04 Amps @ 125VDC Totals:							0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 60

Scenario: CMP22

Continued on Page 438

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-05																																	
Schematic:	208416																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	1789/BRR-V1789	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-V1789	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV1789	ASCO / CAT. NO. NP8320A183V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 208416 Amps @ 125VDC Totals:							0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 61

Scenario: CMP22

Continued on Page 439

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	1788/ARR-V1788	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-V1788	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV1788	ASCO / CAT. NO. NP8320A183V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 208417 Amps @ 125VDC Totals:							0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 62

Scenario: CMP22

Continued on Page 440

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22-05																																					
Schematic:	208419																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	548/ARR-V548	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
2	INDLTS-V548	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV548	ASCO / CAT. NO. NP8314C28V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 208419 Amps @ 125VDC Totals:							0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 63

Scenario: CMP22

Continued on Page 441

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-05																																			
Schematic:	208421																																			
Qty	Device ID	Mfgr/Model	Trp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	549/BRR-V549	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-V549	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV549	ASCO / CAT. NO. NP8314C28V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 208421 Amps @ 125VDC Totals:							0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 64

Scenario: CMP22

Continued on Page 442

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0
Circuit:	DP22-05																
Schematic:	303686																

Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	SOV1600A	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV1600B	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1600D	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV265	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: 303686 Amps @ 125VDC Totals: 0.42

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 65

Scenario: CMP22

Continued on Page 443

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-05																																	
Schematic:	303845																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	SOV1286	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1600E	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1600F	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1600G	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 303845 Amps @ 125VDC Totals:							0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 66

Scenario: CMP22

Continued on Page 444

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-05																																			
Schematic:	304159																																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	SOV1284	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1285	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1600H	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1600J	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1600K	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 304159 Amps @ 125VDC Totals:							0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 67

Scenario: CMP22

Continued on Page 445

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-05																																			
Schematic:	A207559																																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	1/SJAE-X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	33-2X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	33-4X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: A207559 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 68

Scenario: CMP22

Continued on Page 446

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22-05																																					
Schematic:	B207571																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
2	INDLTS-SAEIV	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV1430	ASCO / CAT. NO. NP8321A5DE	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1433	ASCO / CAT. NO. 8300C58RF	Z	0.29	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B207571 Amps @ 125VDC Totals:							0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 69

Scenario: CMP22

Continued on Page 447

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22-05																																					
Schematic:	B208435																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	10SGIS/BRR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	9SGIS/BRR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: B208435 Amps @ 125VDC Totals:							0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21		
Circuit: DP22-05 Amps @ 125VDC Totals:							3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 70

Scenario: CMP22

Continued on Page 448

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-06																																			
Schematic:	225242																																			
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-SBIF-2	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 225242 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 71

Scenario: CMP22

Continued on Page 449

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-06																																			
Schematic:	9321-LL-3131, SH 21																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
2	INDLTS-MSIV-21,22	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3131 SH 21 Amps @ 125VDC Totals:							0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 72

Scenario: CMP22

Continued on Page 450

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-06																																	
Schematic:	9321-LL-3131 SH 25																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	201-CRMIV-B	ASCO / CAT. NO. 206-381-2RVF	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	202-CRMIV-B	ASCO / CAT. NO. 206-381-2RVF	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	203-CRMIV-B	ASCO / CAT. NO. 206-381-2RVF	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	204-CRMIV-B	ASCO / CAT. NO. 206-381-2RVF	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
8	INDLTS-CRMIV-B	UNKNOWN / INDICATING LIGHT	Z	0.26	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	RM/BRR-CRMIV-B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 9321-LL-3131 SH 25 Amps @ 125VDC Totals:							1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 73

Scenario: CMP22

Continued on Page 451

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Qty	Device ID	Mfg/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	SOV417L-C	ASCO / CAT. NO. 206-381-6RG	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV417L-D	ASCO / CAT. NO. 206-381-6RF	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV427L-C	ASCO / CAT. NO. 206-381-6RG	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV427L-D	ASCO / CAT. NO. 206-381-6RF	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV437L-C	ASCO / CAT. NO. 206-381-6RG	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV437L-D	ASCO / CAT. NO. 206-381-6RF	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV447L-C	ASCO / CAT. NO. 206-381-6RG	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV447L-D	ASCO / CAT. NO. 206-381-6RF	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 9321-LL-3601 SH 03 Amps @ 125VDC Totals:							2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	2.25	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 74

Scenario: CMP22

Continued on Page 452

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28															
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0															
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	796BRR-V796	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
3	INDLTS-V796	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	SOV796	ASCO / CAT. NO. NPK831654V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: A208425 Amps @ 125VDC Totals:							0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 75

Scenario: CMP22

Continued on Page 453

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-06																																			
Schematic:	A208844																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-MOV956F	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: A208844 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 76

Scenario: CMP22

Continued on Page 454

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-06																																			
Schematic:	A209515																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	20/5-SGI2	ASCO / CAT. NO. NPK8316A54V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	20/6-SGI2	ASCO / CAT. NO. NPK8316A54V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/7-SGI2	ASCO / CAT. NO. NPK8316A54V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/8-SGI2	ASCO / CAT. NO. NPK8316A54V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
9	INDLTS-SGI2	UNKNOWN / INDICATING LIGHT	Z	0.29	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	SG2X-SGI2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: A209515 Amps @ 125VDC Totals: 0.83 0.83 0.83 0.83 0.83 0.83 0.83 0.83 0.83 0.83 0.83 0.83 0.83 0.83 0.83 0.83 0.83 0.83

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 77

Scenario: CMP22

Continued on Page 455

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-06																																	
Schematic:	B209524																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	956BRR-V956B	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-A-V956B	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
2	INDLTS-V956B	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV956B	ASCO / CAT. NO. NP8314C28V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: B209524 Amps @ 125VDC Totals: 0.29

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 78

Scenario: CMP22

Continued on Page 456

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-06																																	
Schematic:	B209525																																	
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-A-V956D	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
2	INDLTS-V956D	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV956D	ASCO / CAT. NO. NP8314C28V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B209525 Amps @ 125VDC Totals:							0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 79

Scenario: CMP22

Continued on Page 457

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-06																																	
Schematic:	B209526																																	
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	956HBRR-V956H	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-A-V956H	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
2	INDLTS-V956H	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV956H	ASCO / CAT. NO.206-381-4RVU	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B209526 Amps @ 125VDC Totals:							0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43	0.43

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 80

Scenario: CMP22

Continued on Page 458

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28														
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0														
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	1705BRR-V1705	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	1728BRR-V1728	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	1787BRR-V1787	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	202BRR-V202	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	552BRR-V552	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	798BRR-V798	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
2	INDLTS-V1705	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
2	INDLTS-V1728	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
2	INDLTS-V1787	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
3	INDLTS-V202	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	
2	INDLTS-V552	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
3	INDLTS-V798	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	
1	SOV1705	ASCO / CAT. NO. NP831655V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	SOV1728	ASCO / CAT. NO. NPK831654V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	SOV1787	ASCO / CAT. NO. NP8320A183V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	SOV202	ASCO / CAT. NO. NP8320A185V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	SOV552	ASCO / CAT. NO. 206-381-6RF	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	SOV798	ASCO / CAT. NO.206-381-4RVU	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: B225206 Amps @ 125VDC Totals:							1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 81

Scenario: CMP22

Continued on Page 459

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28															
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	INDLTS-IVSW3518	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	IVSW3518	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B226967 Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 82

Scenario: CMP22

Continued on Page 460

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V1413	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV1413-V1413	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: IP2-S-000006 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 83

Scenario: CMP22

Continued on Page 461

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-06																																	
Schematic:	IP2-S-000197																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-MOV1810	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: IP2-S-000197 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 84

Scenario: CMP22

Continued on Page 462

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-06																																			
Schematic:	IP2-S-000198																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-MOV744	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: IP2-S-000198 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 85

Scenario: CMP22

Continued on Page 463

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-06																																			
Schematic:	IP2-S-000201																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-MOV842	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: IP2-S-000201 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 86

Scenario: CMP22

Continued on Page 464

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-MOV856F	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: IP2-S-000212 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 87

Scenario: CMP22

Continued on Page 465

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-06																																	
Schematic:	IP2-S-000225																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	NDLTS-MOV894C	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: IP2-S-000225 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 88

Scenario: CMP22

Continued on Page 466

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INDLTS-MOV894A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
Schematic: IP2-S-000226 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02		
Circuit: DP22-06 Amps @ 125VDC Totals:							8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 89

Scenario: CMP22

Continued on Page 467

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22-08																																					
Schematic:	110E073 SH 11																																					
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	BYA/RT/BX-RX TRIP TR B	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	S166/ST-52/RTB	GE / TYPE HGA	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	S167/ST1-52/RTB	GE / TYPE HGA	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	UV-52/BYA-RX TRIP TR B	UNKNOWN / UV RELAY	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	UV-52/RTB-RX TRIP TR B	UNKNOWN / UV RELAY	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 110E073 SH 11 Amps @ 125VDC Totals:							0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	0.32	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 90

Scenario: CMP22

Continued on Page 468

Time Step:	15	16	17	18	19	20	21	22	23	24	25	26	27	28																		
	Time Step Range:		0:00:25.0 - 0:00:25.1		0:00:25.1 - 0:00:26.0		0:00:26.0 - 0:00:30.0		0:00:30.0 - 0:00:30.1		0:00:30.1 - 0:00:31.0		0:00:31.0 - 0:00:35.0		0:00:35.0 - 0:00:35.1		0:00:35.1 - 0:00:36.0		0:00:36.0 - 0:01:00.0		0:01:00.0 - 0:20:00.0		0:20:00.0 - 0:20:01.0		0:20:01.0 - 0:20:01.1		0:20:01.1 - 0:21:00.0		0:21:00.0 - 0:30:00.0			
Circuit:	DP22-08																															
Schematic:	110E073 SH 9																															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	27/2X-1/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/3X-1/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/RCP21X-RX TRIP TR B	WHSE / TYPE BFD, STYLE 5072A49	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/RCP22X-RX TRIP TR B	WHSE / TYPE BFD, STYLE 5072A49	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/RCP23X-RX TRIP TR B	WHSE / TYPE BFD, STYLE 5072A49	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/RCP24X-RX TRIP TR B	WHSE / TYPE BFD, STYLE 5072A49	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 110E073 SH 9 Amps @ 125VDC Totals:							0.63		0.63		0.63		0.63		0.63		0.63		0.63		0.63		0.63		0.63		0.63		0.63		0.63	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 91

Scenario: CMP22

Continued on Page 469

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28													
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0													
Circuit:	DP22-08																													
Schematic:	110E073 SH 10																													
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-L58-B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 110E073 SH 10 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 93

Scenario: CMP22

Continued on Page 471

Circuit:	DP22-08	Schematic:	110E073 SH 3	Time Step:	15	16	17	18	19	20	21	22	23	24	25	26	27	28
				Time Step Range:	0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0

Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	1/NC32B/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC32B/Y-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC32B/Z-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC33B/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC33B/Z-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC35A/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC35A/Y-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC35A/Z-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC36A/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC36A/Y-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC36A/Z-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC38B/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC38B/Z-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC39A/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC39B/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC47B/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC47B/Z-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: 110E073 SH 3 Amps @ 125VDC Totals: 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 94

Scenario: CMP22

Continued on Page 472

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-08																																	
Schematic:	110E073 SH 5																																	
Qty	Device ID	Mfgri/Model	Trp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	SIAM/1-X-RX TRIP TR B	WHSE / TYPE BFD, STYLE 5072A49	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SIAM/2-X-RX TRIP TR B	WHSE / TYPE BFD, STYLE 5072A49	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 110E073 SH 5 Amps @ 125VDC Totals:							0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 95

Scenario: CMP22

Continued on Page 473

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-08																																			
Schematic:	110E073 SH 8																																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	1/MT/1-X-RX TRIP TR B	WHSE / TYPE BFD, STYLE 5072A49,	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	1/MT/2-X-RX TRIP TR B	WHSE / TYPE BFD, STYLE 5072A49,	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: 110E073 SH 8 Amps @ 125VDC Totals:							0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21		
Circuit: DP22-08 Amps @ 125VDC Totals:							6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 96

Scenario: CMP22

Continued on Page 474

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																		
Circuit: DP22-09		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																		
Schematic: 9321-LL-3140 SH 12		Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	1X/RS-BFP22 TT		WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/RSV-BFP22 TT		UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/TT-1-BFP22 TT		UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/TT-2-BFP22 TT		UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	3RS/BFP2		WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63/BOX-BFP22 TT		UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63/DPX-BFP22 TT		UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63X/BFP2		UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63X/LV-BFP22 TT		WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63X/SCMIN-BFP22 TT		UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63X1/BFP2		WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63X2/BFP2		WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	74-BFP22 T T		WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-A-BFP22 T T		UNKNOWN / LIGHT W/ 10000 OHM,	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
2	INDLTS-B-BFP22 T T		UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-BFP22 T T		UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	UNKWN-RELAY-BFP22 T T		UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: 9321-LL-3140 SH 12 Amps @ 125VDC Totals: 1.65

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 97

Scenario: CMP22

Continued on Page 475

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	20/LP-SVC2	UNKNOWN / SOV - OPERATES AS V	Z	0.30	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	33X-BFP22 LPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	33X/1-BFP22 LPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	33X/2-BFP22 LPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	33X/3-BFP22 LPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	72L/BFP22 LPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	72R/BFP22 LPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-BFP22 LPSVC2	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3140 SH 14 Amps @ 125VDC Totals:							0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 98

Scenario: CMP22

Continued on Page 476

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22-09																																					
Schematic:	9321-LL-3140 SH 15																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	20/HP-SVC2	UNKNOWN / SOV - OPERATES AS V	Z	0.30	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	33X/1-BFP22 HPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	33X/2-BFP22 HPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	33X/3-BFP22 HPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	72L/BFP22 HPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	72R/BFP22 HPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-BFP22 HPSVC2	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3140 SH 15 Amps @ 125VDC Totals:							0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86	0.86

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 99

Scenario: CMP22

Continued on Page 477

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																		
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																		
Circuit:	DP22-09																																		
Schematic:	9321-LL-3140 SH 16																																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	20/BFPR2	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	80X1/BFPR2	UNKNOWN / FLOW SWITCH	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	INDLTS-BFP22 BFPR2	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	TD/BFPR2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: 9321-LL-3140 SH 16 Amps @ 125VDC Totals:							0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36	0.36		
Circuit: DP22-09 Amps @ 125VDC Totals:							3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84	3.84

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 100

Scenario: CMP22

Continued on Page 478

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-11																																			
Schematic:	225232																																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	2/CC1-1	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	2/CC5	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	2/SWG-2	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	2/SWG-2	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/EGX	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/SWX	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
3	INDLTS-B-RSIL	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 225232 Amps @ 125VDC Totals:							0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 101

Scenario: CMP22

Continued on Page 479

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52/CS1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	52/CS2X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/SI1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/SI2X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/SI3X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
13	INDLTS-A-RSIL	UNKNOWN / INDICATING LIGHT	Z	0.42	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	SI/RL	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225227 Amps @ 125VDC Totals:							0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Scenario: CMP22

Continued from Page 102

Continued on Page 480

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28															
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	2/CC1	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	2/CC2	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	2/CC4	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	2/SW2	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	2/SW3-1	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	2/SW5	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	2/SW6-1	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/CC1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/CC2X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/CC3X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: B225228 Amps @ 125VDC Totals: 0.80

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 103

Scenario: CMP22

Continued on Page 481

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-11																																			
Schematic:	B225229																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52/RHR2/X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225229 Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 104

Scenario: CMP22

Continued on Page 482

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																							
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																							
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	52/SW1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	52/SW2X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/SW3X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/SW4X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/SW5X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/SW6X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225231 Amps @ 125VDC Totals:							0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 105

Scenario: CMP22

Continued on Page 483

				Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
				Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div										
1	RS6/X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225233 Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 106

Scenario: CMP22

Continued on Page 484

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-11																																	
Schematic:	B225234																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	1810/X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225234 Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	
Circuit: DP22-11 Amps @ 125VDC Totals:							3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 107

Scenario: CMP22

Continued on Page 485

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28													
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0													
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V1629	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1630	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1631	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV1629	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1630	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1631	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 225188 Amps @ 125VDC Totals:							0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 108

Scenario: CMP22

Continued on Page 486

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-12																																			
Schematic:	225209																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
3	INDLTS-LCV1003A	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
3	INDLTS-LCV1003B	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
3	INDLTS-V1609	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	SOV1003A	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1003B	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1609	ASCO / CAT. NO. NP831655V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TD-LCV1003A	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TD-LCV1003B	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: 225209 Amps @ 125VDC Totals: 0.74

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 109

Scenario: CMP22

Continued on Page 487

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V523	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV523	ASCO / CAT. NO. NP8314C28V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B209864 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 110

Scenario: CMP22

Continued on Page 488

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
2	INDLTS-RCV018	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1036A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1037A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1038A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1039A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1632	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1677	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV018	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1036A	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1037A	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1038A	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1039A	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1632	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1677	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225205 Amps @ 125VDC Totals:							0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 111

Scenario: CMP22

Continued on Page 489

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-12																																			
Schematic:	B225207																																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V1036B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1037B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1038B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV1036B	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1037B	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1038B	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1039B	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225207 Amps @ 125VDC Totals:							0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 112

Scenario: CMP22

Continued on Page 490

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																		
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div							
1	ANNUN-WASTE CP	UNKNOWN / UNKNOWN ANNUNCIAT	P	6.83	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: UNKNOWN Amps @ 125VDC Totals:							6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83		
Circuit: DP22-12 Amps @ 125VDC Totals:							9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 113

Scenario: CMP22

Continued on Page 491

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-13																																			
Schematic:	9321-LL-3131 SH 11																																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	1X/AF3-AFPR3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/AFPR3	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
3	INDLTS-AFPR3	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3131 SH 11 Amps @ 125VDC Totals:							0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 114

Scenario: CMP22

Continued on Page 492

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22-13																																					
Schematic:	9321-LL-3131 SH 11A																																					
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	80X1A/AFPR3	GE / TYPE HGA	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	80X2A/AFPR3	GE / TYPE HGA	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: 9321-LL-3131 SH 11A Amps @ 125VDC Totals:							0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11		
Circuit: DP22-13 Amps @ 125VDC Totals:							0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 115

Scenario: CMP22

Continued on Page 493

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																		
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																		
Qty	Device ID	Mfg/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div					
1	30/4-TRFOA	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	30/X1-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	30/X2-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	30/X3-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	30/X4-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	30/X5-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	30/X6-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	30/X7-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	30/X8-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	30FX-TRFOA	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	30X1-TRFOA	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	HORN-TRFOA	PANALARM / HORN FOR ANNUNCIATION	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	INDLTS-TRFOA	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50			
1	M4-TRFOA	PANALARM / FLASHER RELAY, MODEL 11	Z	0.04	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	REACTOR-FIRST OUT ANN	PANALARM / SERIES 10, MODEL 11	Z	3.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	TURB-FIRST OUT ANN	PANALARM / SERIES 10, MODEL 11	Z	6.83	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
Schematic: 9321-LL-3135 SH 02 Amps @ 125VDC Totals:							11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24		
Circuit: DP22-14 Amps @ 125VDC Totals:							11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 116

Scenario: CMP22

Continued on Page 494

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22-15																																					
Schematic:	311906																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	33X/PCV455C-PCV455C	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	INDLTS-PCV455C	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV455C	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 311906 Amps @ 125VDC Totals:							0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 117

Scenario: CMP22

Continued on Page 495

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-15																																	
Schematic:	9321-LL-3131 SH 15A																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	20-4-SW CNTL VLVS	ASCO / CAT. NO. NPK8316A74V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20-6-SW CNTL VLVS	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20-8-SW CNTL VLVS	ASCO / CAT. NO. 8211D3	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
5	INDLTS-SW CNTL VLVS	UNKNOWN / INDICATING LIGHT	Z	0.16	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3131 SH 15A Amps @ 125VDC Totals:							0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	0.47	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 118

Scenario: CMP22

Continued on Page 496

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-15																																			
Schematic:	B207581																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-TCV1105	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV1171-TCV1105	ASCO / CAT. NO. NP831655E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV5005-TCV1105	ASCO / CAT. NO. 8211D3	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B207581 Amps @ 125VDC Totals:							0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 119

Scenario: CMP22

Continued on Page 497

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22-15																																					
Schematic:	B225181																																					
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	20-V204B	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	INDLTS-V203	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V204B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V246	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V261A (2)	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV213	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV246	ASCO / CAT. NO. NP831655V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV261A (2)	ASCO / CAT. NO. NP831655V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: B225181 Amps @ 125VDC Totals: 0.63

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 120

Scenario: CMP22

Continued on Page 498

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28															
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V1870	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V261A (3)	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V310	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV261D	ASCO / CAT. NO. NP831655V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1870	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV310	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225182 Amps @ 125VDC Totals:							0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 121

Scenario: CMP22

Continued on Page 499

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-15																																			
Schematic:	B225183																																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V839C	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V839D	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V839G	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V839H	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV839C	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV839D	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV839G	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV839H	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: B225183 Amps @ 125VDC Totals: 0.65

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 122

Scenario: CMP22

Continued on Page 500

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28															
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V553B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V553D	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V560	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV553B	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV553D	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV560	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225184 Amps @ 125VDC Totals:							0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 123

Scenario: CMP22

Continued on Page 501

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28															
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V890B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V890D	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V891B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V891D	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V896B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V896D	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV890B	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV890D	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV891B	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV891D	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV896B	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV896D	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225185 Amps @ 125VDC Totals:							0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 124

Scenario: CMP22

Continued on Page 502

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-15																																			
Schematic:	B225191																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-LCV112B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
2	INDLTS-RCV017	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	LCV112B	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV017	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225191 Amps @ 125VDC Totals:							0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 125

Scenario: CMP22

Continued on Page 503

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22-15																																					
Schematic:	B225192																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
2	NDLTS-TCV149	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV149-TCV149	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225192 Amps @ 125VDC Totals:							0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 126

Scenario: CMP22

Continued on Page 504

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22-15																																					
Schematic:	B225193																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
2	INDLTS-LVC459	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1276A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	LVC459	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1276A	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225193 Amps @ 125VDC Totals:							0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 127

Scenario: CMP22

Continued on Page 505

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28															
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	74/DG21-21 DG TROUB	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	74/DG22-22 DG TROUB	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	74/DG23-23 DG TROUB	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B228092 Amps @ 125VDC Totals:							0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 128

Scenario: CMP22

Continued on Page 506

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22-15																																	
Schematic:	IP2-S-000089																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-PCV455A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: IP2-S-000089 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 129

Scenario: CMP22

Continued on Page 507

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																
Circuit:	DP22-15																																
Schematic:	IP2-S-000329																																
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INDLTS-MCC24A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	INDLTS-MCC27A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	INDLTS-MCC29A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
Schematic: IP2-S-000329 Amps @ 125VDC Totals:							0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05		
Circuit: DP22-15 Amps @ 125VDC Totals:							5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 130

Scenario: CMP22

Continued on Page 508

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																							
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																							
Circuit:	DP22-16																																							
Schematic:	9321-LL-3130 SH 03																																							
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	1/30 HP MOTOR-LLV1	UNKNOWN / 1/30 HP MOTOR, LLV1	I	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
2	INDLTS-LLV1	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	LRB1-LLV1	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	M/LLV1-LLV1	UNKNOWN / FIELD FOR 1/30 HP MO	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	RES/LLV1-LLV1	UNKNOWN / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	TD/LRB1	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	TD1-LRB1	AGASTAT / 7000 SERIES	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	TD1X/LRB-1	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	TD2X/LRB-1	SCCA / MODEL 1080811, TIME DELA	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	TDX/LRB1	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: 9321-LL-3130 SH 03 Amps @ 125VDC Totals:							0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89			
Circuit: DP22-16 Amps @ 125VDC Totals:							0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 131

Scenario: CMP22

Continued on Page 509

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	40-GEN BU LO	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	40X-GEN BU LO	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	46/1-GEN BU LO	UNKNOWN / UNKNOWN	P	1.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	60-GEN BU LO	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	62/BU	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	62BU1/AUX	AGASTAT / TYPE TR-5	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63X/BU	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	81BU/1	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	81BU/2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	81BU/62X	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	86/BU	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	86X-1/BU	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-GEN BU LO	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	TR 1-GEN BU LO	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 9321-LL-3130 SH 06 Amps @ 125VDC Totals:							1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 132

Scenario: CMP22

Continued on Page 510

			Time Step:																											
			15		16		17		18		19		20		21		22		23		24		25		26		27		28	
			0:00:25.0 - 0:00:25.1		0:00:25.1 - 0:00:26.0		0:00:26.0 - 0:00:30.0		0:00:30.0 - 0:00:30.1		0:00:30.1 - 0:00:31.0		0:00:31.0 - 0:00:35.0		0:00:35.0 - 0:00:35.1		0:00:35.1 - 0:00:36.0		0:00:36.0 - 0:01:00.0		0:01:00.0 - 0:20:00.0		0:20:00.0 - 0:20:01.0		0:20:01.0 - 0:20:01.1		0:20:01.1 - 0:21:00.0		0:21:00.0 - 0:30:00.0	
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	86X/BU	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
Schematic: A207325 Amps @ 125VDC Totals:							0.00		0.00		0.00		0.00		0.00		0.00		0.00		0.00		0.00		0.00		0.00		0.00	
Circuit: DP22-17 Amps @ 125VDC Totals:							1.99		1.99		1.99		1.99		1.99		1.99		1.99		1.99		1.99		1.99		1.99		1.99	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 133

Scenario: CMP22

Continued on Page 511

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Qty	Device ID	Mfg/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	717-FWISOL-B	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	F/11X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	F/12X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	F/13X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	F/14X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	F/15X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	F/16X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
3	INDLTS-FWISOL B	UNKNOWN / 3 TERM MONITORING	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 199B23 Amps @ 125VDC Totals:							0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 134

Scenario: CMP22

Continued on Page 512

Circuit:	DP22-18	Time Step:	15	16	17	18	19	20	21	22	23	24	25	26	27	28
Schematic:	225018	Time Step Range:	0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0

Qty	Device ID	Mfr/Model	Tpt	Amps @ 125	Inrush	Tog	15		16		17		18		19		20		21		22		23		24		25		26		27		28	
							NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	2/SI/D2-B SI ACT	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	74X10-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	INDLTS-A-B SI ACT	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
4	INDLTS-B-B SI ACT	UNKNOWN / 3 TERM MONITORING	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60		
1	SI/20X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SI/21X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SI/22X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SI/23X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SI/24X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SI/25AX-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SI/25X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SI/26X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SI/27X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SI/28X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SIA/2-K1-B SI ACT	ELECTROSW / ER-LOR, K1 COIL	Z	1.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	SIA/2-R-B SI ACT	ELECTROSW / ER-LOR, R COIL	Z	10.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	SIA/2-T-B SI ACT	ELECTROSW / ER-LOR, T COIL	Z	4.60	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	SI/2-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SIM/2-K1-B SI ACT	ELECTROSW / ER-LOR, K1 COIL	Z	1.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	SIM/2-R-B SI ACT	ELECTROSW / ER-LOR, R COIL	Z	10.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	SIM/2-T-B SI ACT	ELECTROSW / ER-LOR, T COIL	Z	4.60	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		

Schematic: 225018 Amps @ 125VDC Totals: 1.41 1.41 1.41 1.41 1.41 1.41 1.41 1.41 1.41 1.41 1.41 1.41 1.41 1.41 1.41 1.41 1.41

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 135

Scenario: CMP22

Continued on Page 513

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28															
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0															
Qty	Device ID	Mfrgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	AS2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	CA2-1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	CA2-2X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	CA2-3X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	CA2-4X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	CA2-K1	ELECTROSW / ER-LOR, K1 COIL	Z	1.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CA2-R	ELECTROSW / ER-LOR, R COIL	Z	10.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CA2-T	ELECTROSW / ER-LOR, T COIL	Z	4.60	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CB2-1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	CB2-K1	ELECTROSW / ER-LOR, K1 COIL	Z	1.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CB2-R	ELECTROSW / ER-LOR, R COIL	Z	10.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CB2-T	ELECTROSW / ER-LOR, T COIL	Z	4.60	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	INDLTS-A-CNTM ISOL A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-A-CNTM SP	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-BORN TK LVLB	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	S2-1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	S2-K1	ELECTROSW / ER-LOR, K1 COIL	Z	1.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	S2-R	ELECTROSW / ER-LOR, R COIL	Z	10.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	S2-T	ELECTROSW / ER-LOR, T COIL	Z	4.60	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	V2-K1	ELECTROSW / ER-LOR, K1 COIL	Z	1.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	V2-R	ELECTROSW / ER-LOR, R COIL	Z	10.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	V2-T	ELECTROSW / ER-LOR, T COIL	Z	4.60	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00

Schematic: 225026 Amps @ 125VDC Totals: 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 136

Scenario: CMP22

Continued on Page 514

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	27/2/2A-ICS-SG21B2A-U26	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/2/5A-ICS-SG21B5A-U14	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/2A/X11-SG21B2A-U26A	WHSE / TYPE SG, 12V COIL, WITH 4	Z	0.24	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/2A/X12-SG21B2A-U26A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/2A/X13	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/5A/X11-SG21B5A-U14A	WHSE / TYPE SG, 12V COIL, WITH 4	Z	0.24	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/5A/X12-SG21B5A-U14A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/5A/X13	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-SG21B2A-U26A (2)	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-SG21B5A-U14A (2)	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3117 SH 02 Amps @ 125VDC Totals:							1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32	1.32

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 137

Scenario: CMP22

Continued on Page 515

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28															
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	27-61-ICS	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-61/X1	WHSE / TYPE SG, 12V COIL, WITH 4	Z	0.24	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-61/X2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-61/X3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-62-ICS	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-62/X1	WHSE / TYPE SG, 12V COIL, WITH 4	Z	0.24	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-62/X2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-62/X3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-63-ICS	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-63/X1	WHSE / TYPE SG, 12V COIL, WITH 4	Z	0.24	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-63/X2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-63/X3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-27-61	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-27-62	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-27-63	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3117 SH 22 Amps @ 125VDC Totals:							1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 139

Scenario: CMP22

Continued on Page 517

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22-18																																					
Schematic:	9321-LL-3118 SH 20																																					
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	1X/BFPT2-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	71/1X-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	71/2X-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	71/3X-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	71/4X-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	BFP2-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	BFPB-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	BFPB/2-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-ABFP 21/23	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3118 SH 20 Amps @ 125VDC Totals:							0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	0.85	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 140

Scenario: CMP22

Continued on Page 518

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22-18																																					
Schematic:	9321-LL-3118 SH 20A																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	R1-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 9321-LL-3118 SH 20A Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 141

Scenario: CMP22

Continued on Page 519

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22-18																																					
Schematic:	9321-LL-3131 SH 21																																					
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	20/21-2	ASCO / CAT. NO. WJNP831666V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	20/21-4	ASCO / CAT. NO. WJNP8316E34V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/22-2	ASCO / CAT. NO. WJNP831666V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/22-4	ASCO / CAT. NO. WJNP8316E34V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/23-2	ASCO / CAT. NO. WJNP831666V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/23-4	ASCO / CAT. NO. WJNP8316E34V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/24-2	ASCO / CAT. NO. WJNP831666V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/24-4	ASCO / CAT. NO. WJNP8316E34V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	74X8	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	JNDLTS-MS STOP VLVS (2	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3131 SH 21 Amps @ 125VDC Totals:							1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 142

Scenario: CMP22

Continued on Page 520

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28															
Circuit: DP22-18		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0															
Schematic: A241685		Qty	Device ID	Mfgr/Model	Trp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	2TD2/SL2-MS ISOL B	AGASTAT / 7000 SERIES	Z	0.06	0.00	On			N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	74X2	WHSE / BFD	Z	0.10	0.00	On			N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	74X4	WHSE / BFD	Z	0.10	0.00	On			N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	74X6	WHSE / BFD	Z	0.10	0.00	On			N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
3	INDLTS-A-MS ISOL B	UNKNOWN / 3 TERM MONITORING/	Z	0.10	0.00	On			N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	MS11-MS ISOL B	WHSE / BFD	Z	0.10	0.00	On			N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	MS12-MS ISOL B	WHSE / BFD	Z	0.10	0.00	On			N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	MS13-MS ISOL B	WHSE / BFD	Z	0.10	0.00	On			N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	MS14-MS ISOL B	WHSE / BFD	Z	0.10	0.00	On			N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SL2	WHSE / BFD	Z	0.10	0.00	On			N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TR2-MS ISOL B	WHSE / BFD	Z	0.10	0.00	On			N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TR2-X-MS ISOL B	WHSE / BFD	Z	0.10	0.00	On			N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: A241685 Amps @ 125VDC Totals: 1.16

Circuit: DP22-18 Amps @ 125VDC Totals: 12.81

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 143

Scenario: CMP22

Continued on Page 521

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-19																																			
Schematic:	9321-LL-3130 SH 02B																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	20/ASB-T/G A-S TRIP	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63X1/AST3-T/G A-S TRIP	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63X2/AST3-T/G A-S TRIP	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	F15X1-T/G A-S TRIP	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-A-T/G A-S TRIP	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-T/G A-S TRIP	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50

Schematic: 9321-LL-3130 SH 02B Amps @ 125VDC Totals: 0.41

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 144

Scenario: CMP22

Continued on Page 522

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	20/DV1B	ASCO / CAT. NO. FT8316E36	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	20/DV2B	ASCO / CAT. NO. FT8316E36	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/DV3B	ASCO / CAT. NO. FT8316E36	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/DV4B	ASCO / CAT. NO. FT8316E36	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/DV5B	ASCO / CAT. NO. FT8316E36	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	20/DV6B	ASCO / CAT. NO. FT8316E36	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	AST/X-LP STM DMP11	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
7	INDLTS-A-LP STM DMP11	UNKNOWN / INDICATING LIGHT	Z	0.22	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
3	INDLTS-B-LP STM DMP11	UNKNOWN / 3 TERM MONITORING	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: A207325 Amps @ 125VDC Totals:				1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	
Circuit: DP22-19 Amps @ 125VDC Totals:				1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 145

Scenario: CMP22

Continued on Page 523

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22-20																																			
Schematic:	307670																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	7422-TB OS TRIP B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-B-TB OS TRIP B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 307670 Amps @ 125VDC Totals:							0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 147

Scenario: CMP22

Continued on Page 525

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																		
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																		
Circuit:	DP22A-01																																		
Schematic:	A206900																																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INVERTER EGA6	TOPAZ / 1 KVA INVERTER	P	10.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: A206900 Amps @ 125VDC Totals:							10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	
Circuit: DP22A-01 Amps @ 125VDC Totals:							10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00	10.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 148

Scenario: CMP22

Continued on Page 526

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																		
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																		
Circuit:	DP22A-02																																		
Schematic:	206799																																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	OPXB-RCS OPS	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	OPXB1-RCS OPS	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	OPXB2-RCS OPS	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: 206799 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31		
Circuit: DP22A-02 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 149

Scenario: CMP22

Continued on Page 527

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22A-03																																					
Schematic:	B235113																																					
Qty	Device ID	Mfg/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	SOV1311	ASCO / CAT. NO. NP831665E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	TC1113S/X-V1311	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: B235113 Amps @ 125VDC Totals:							0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24		
Circuit: DP22A-03 Amps @ 125VDC Totals:							0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 150

Scenario: CMP22

Continued on Page 528

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																		
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INDLTS-SOVE-5	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	INDLTS-SOVEW-2	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	SOVE-5	ASCO / CAT. NO. NP831655E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	SOVEW-2	ASCO / CAT. NO. 206-381-3FR	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: A208548 Amps @ 125VDC Totals:							0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45		
Circuit: DP22AA-01 Amps @ 125VDC Totals:							0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 151

Scenario: CMP22

Continued on Page 529

				Time Step:		15		16		17		18		19		20		21		22		23		24		25		26		27		28				
				Time Step Range:		0:00:25.0 - 0:00:25.1		0:00:25.1 - 0:00:26.0		0:00:26.0 - 0:00:30.0		0:00:30.0 - 0:00:30.1		0:00:30.1 - 0:00:31.0		0:00:31.0 - 0:00:35.0		0:00:35.0 - 0:00:35.1		0:00:35.1 - 0:00:36.0		0:00:36.0 - 0:01:00.0		0:01:00.0 - 0:20:00.0		0:20:00.0 - 0:20:01.0		0:20:01.0 - 0:20:01.1		0:20:01.1 - 0:21:00.0		0:21:00.0 - 0:30:00.0				
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-SOV3401	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	INDLTS-SOV3402	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	INDLTS-SOV3412	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	INDLTS-SOV3413	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	SOV3401	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV3402	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV3412	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV3413	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: A208551 Amps @ 125VDC Totals:							0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38		
Circuit: DP22AA-02 Amps @ 125VDC Totals:							0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 152

Scenario: CMP22

Continued on Page 530

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28															
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0															
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V3403	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V3404	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V3405	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V3406	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV3403	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV3404	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV3405	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV3406	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: A208551 Amps @ 125VDC Totals:				0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	
Circuit: DP22AA-03 Amps @ 125VDC Totals:				0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 153

Scenario: CMP22

Continued on Page 531

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	JNDLTS-V3407	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	JNDLTS-V3408	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	JNDLTS-V3409	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	JNDLTS-V3410	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	JNDLTS-V3411	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	SOV3407	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV3408	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV3409	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV3410	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV3411	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: A208551 Amps @ 125VDC Totals:							0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48		
Circuit: DP22AA-04 Amps @ 125VDC Totals:							0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 154

Scenario: CMP22

Continued on Page 532

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	DP22AA-05																																					
Schematic:	IP2-S-000092																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	INDLTS-A-V5019	UNKNOWN / LIGHT W/ 2500 OHM RE	Z	0.05	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	INDLTS-A-V5023	UNKNOWN / LIGHT W/ 2500 OHM RE	Z	0.05	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	INDLTS-V5019	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	INDLTS-V5023	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	SOV5019	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV5023	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: IP2-S-000092 Amps @ 125VDC Totals:							0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24		
Circuit: DP22AA-05 Amps @ 125VDC Totals:							0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 155

Scenario: CMP22

Continued on Page 533

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0	
Circuit:	DP22AA-06																	
Schematic:	B209543																	

Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V5046	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V5050	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV5046	ASCO / CAT. NO. NP8316A54E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV5050	ASCO / CAT. NO. NP8320A187E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: B209543 Amps @ 125VDC Totals: 0.31

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 156

Scenario: CMP22

Continued on Page 534

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22AA-06																																			
Schematic:	B209545																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V5047	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V5051	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV5047	ASCO / CAT. NO. NP8316A54E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV5051	ASCO / CAT. NO. NP8320A187E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: B209545 Amps @ 125VDC Totals: 0.31

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 157

Scenario: CMP22

Continued on Page 535

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	DP22AA-06																																	
Schematic:	B209546																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V5048	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V5052	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV5048	ASCO / CAT. NO. NP8316A54E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV5052	ASCO / CAT. NO. NP8320A187E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B209546 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 158

Scenario: CMP22

Continued on Page 536

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																				
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																				
Circuit:	DP22AA-06																																				
Schematic:	B209547																																				
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INDLTS-V5049	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	INDLTS-V5053	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	SOV5049	ASCO / CAT. NO. NP8316A54E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	SOV5053	ASCO / CAT. NO. NP8320A187E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: B209547 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31		
Circuit: DP22AA-06 Amps @ 125VDC Totals:							1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 159

Scenario: CMP22

Continued on Page 537

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	DP22AA-07																																			
Schematic:	322462																																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	33X/3518-EPFP3518	WHSE / NBFD	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: 322462 Amps @ 125VDC Totals:							0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07		
Circuit: DP22AA-07 Amps @ 125VDC Totals:							0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 160

Scenario: CMP22

Continued on Page 538

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28												
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0												
Qty	Device ID	Mfg/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	LP-213	UNKNOWN / EMERGENCY LTG PAN	Z	57.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
Schematic: A251037 Amps @ 125VDC Totals:							57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20		
Circuit: PP22-02-PG5 Amps @ 125VDC Totals:							57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 161

Scenario: CMP22

Continued on Page 539

				Time Step:		15		16		17		18		19		20		21		22		23		24		25		26		27		28		
				Time Step Range:		0:00:25.0 - 0:00:25.1		0:00:25.1 - 0:00:26.0		0:00:26.0 - 0:00:30.0		0:00:30.0 - 0:00:30.1		0:00:30.1 - 0:00:31.0		0:00:31.0 - 0:00:35.0		0:00:35.0 - 0:00:35.1		0:00:35.1 - 0:00:36.0		0:01:00.0 - 0:01:00.0		0:20:00.0 - 0:20:01.0		0:20:01.0 - 0:20:01.1		0:20:01.1 - 0:21:00.0		0:21:00.0 - 0:30:00.0				
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	GEN REG INV1	UNKNOWN / GEN REG. INVERTER	P	2.69	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: IP2--S-000054 Amps @ 125VDC Totals:							2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69		
Circuit: PP22-07 Amps @ 125VDC Totals:							2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 162

Scenario: CMP22

Continued on Page 540

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	PP22-09																																			
Schematic:	9321-LL-3114 SH 02																																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-UT3	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-UT3	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-UT3	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-UT3	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-UT3 (1)	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 02 Amps @ 125VDC Totals:							0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 163

Scenario: CMP22

Continued on Page 541

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	PP22-09																																	
Schematic:	9321-LL-3114 SH 03																																	
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52M-UT3-ST6	WHSE / M-SPRING CHARGING MTR	P	5.50	20.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52M-UT3-ST6-I	WHSE / M-SPRING CHARGING MTR	P	5.50	20.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52MR-UT3-ST6	UNKNOWN / MR- MECH RELEASE R	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52MX-UT3-ST6	UNKNOWN / MX-CHARGING MTR AL	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-UT3-ST6	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-UT3-ST6	WHSE / 75DH500 Stored Energy	Z	5.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-UT3-ST6	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-UT3-ST6	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 03 Amps @ 125VDC Totals:							0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 164

Scenario: CMP22

Continued on Page 542

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	PP22-09																																	
Schematic:	9321-LL-3114 SH 04																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-UT4	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-UT4	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-UT4	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-UT4	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-UT4 (1)	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 04 Amps @ 125VDC Totals:							0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 165

Scenario: CMP22

Continued on Page 543

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	PP22-09																																			
Schematic:	9321-LL-3114 SH 05																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52M-UT4-ST6	WHSE / M-SPRING CHARGING MTR	P	5.50	20.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52M-UT4-ST6-I	WHSE / M-SPRING CHARGING MTR	P	5.50	20.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52MR-UT4-ST6	UNKNOWN / MR- MECH RELEASE R	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52MX-UT4-ST6	UNKNOWN / MX-CHARGING MTR AL	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-UT4-ST6	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-UT4-ST6	WHSE / 75DH500 Stored Energy	Z	5.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-UT4-ST6	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	JNDLTS-UT4-ST6	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 05 Amps @ 125VDC Totals:					0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 166

Scenario: CMP22

Continued on Page 544

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	PP22-09																																	
Schematic:	9321-LL-3114 SH 06																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-ST6	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-ST6	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-ST6	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-ST6	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-ST6 (1)	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 06 Amps @ 125VDC Totals:							0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 167

Scenario: CMP22

Continued on Page 545

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28															
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0															
Qty	Device ID	Mfg/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52CC-RCP23	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-RCP23	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-RCP23	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-RCP23	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-RCP23	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	S4-RCP23	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 9321-LL-3114 SH 07 Amps @ 125VDC Totals:							0.16	0.16	0.16	4.31	4.31	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 168

Scenario: CMP22

Continued on Page 546

Circuit:	PP22-09	Time Step:	15	16	17	18	19	20	21	22	23	24	25	26	27	28
Schematic:	9321-LL-3114 SH 09	Time Step Range:	0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0

Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-HDP21	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52TC-HDP21	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-HDP21	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-HDP21	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-HDP21	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60

Schematic: 9321-LL-3114 SH 09 Amps @ 125VDC Totals: 0.06 0.06 0.06 4.21 4.21 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 169

Scenario: CMP22

Continued on Page 547

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div								
1	52CC-SS3	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52TC-SS3	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-SS3	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-SS3	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-SS3	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 10 Amps @ 125VDC Totals:							0.06	0.06	0.06	4.21	4.21	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 170

Scenario: CMP22

Continued on Page 548

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Circuit:	PP22-09																																					
Schematic:	9321-LL-3114 SH 11																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52CC-RCP22	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52TC-RCP22	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-RCP22	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-RCP22	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-RCP22	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	S9-RCP22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 9321-LL-3114 SH 11 Amps @ 125VDC Totals:							0.16	0.16	0.16	4.31	4.31	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 171

Scenario: CMP22

Continued on Page 549

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52CC-CP23	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52TC-CP23	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-CP23	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-CP23	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CPAS/23-CP23	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-A-CP23	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
3	INDLTS-CP23	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 12 Amps @ 125VDC Totals:							0.18	0.18	0.18	4.33	4.33	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 172

Scenario: CMP22

Continued on Page 550

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52CC-HDP22	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52TC-HDP22	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-HDP22	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-HDP22	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-HDP22	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 14 Amps @ 125VDC Totals:							0.06	0.06	0.06	4.21	4.21	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 173

Scenario: CMP22

Continued on Page 551

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
,1	62/ST6	UNKNOWN / TD-53 TIME DELAY REL	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	62/UT3	UNKNOWN / TD-53 TIME DELAY REL	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	62/UT4	UNKNOWN / TD-53 TIME DELAY REL	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	86/ST6	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	86/UT3	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	86/UT4	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	INDLTS-N-ST6	UNKNOWN / NE-2, NEON LAMP, 200	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-UT3	UNKNOWN / NE-2, NEON LAMP, 200	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-UT4	UNKNOWN / NE-2, NEON LAMP, 200	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-ST6 (2)	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-UT3 (2)	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-UT4 (2)	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3114 SH 17 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 174

Scenario: CMP22

Continued on Page 552

				Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
				Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	PP22-09																																					
Schematic:	9321-LL-3114 SH 18																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	71X/HDT	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	86X/ST6-OP	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	86X/ST6-RESET	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 9321-LL-3114 SH 18 Amps @ 125VDC Totals:							0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 175

Scenario: CMP22

Continued on Page 553

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	PP22-09																																	
Schematic:	9321-LL-3114 SH 19																																	
Qty	Device ID	Mfg/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-GT26	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-GT26	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-GT26	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-GT26	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
4	INDLTS-GT26	UNKNOWN / INDICATING LIGHT	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 19 Amps @ 125VDC Totals:							0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 176

Scenario: CMP22

Continued on Page 554

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	PP22-09																																	
Schematic:	9321-LL-3114 SH 20																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	51N-SS22RW3	WHSE / 51N OVERCURRENT RELAY	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-SS22RW3	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-SS22RW3	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-SS22RW3	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-SS22RW3	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	JNDLTS-SS22RW3	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 20 Amps @ 125VDC Totals:							0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 177

Scenario: CMP22

Continued on Page 555

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Qty	Device ID	Mfg/Model	Trp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52CC-SS6	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52TC-SS6	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-SS6	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-SS6	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-SS6	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 16 Amps @ 125VDC Totals:							0.06	0.06	0.06	4.21	4.21	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 178

Scenario: CMP22

Continued on Page 556

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	27-3/62-BUS 3 UV/UF	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	27-3/62X-BUS 3 UV/UF	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-3/ICS-BUS 3 UV/UF	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-3/X1-BUS 3 UV/UF	WHSE / MG-6, 24 V, W/ 300 OHM RE	Z	0.32	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-3/X2-BUS 3 UV/UF	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-3/X3-BUS 3 UV/UF	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	81-3/ICS-BUS 3 UV/UF	WHSE / KF	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	81-3/X1-BUS 3 UV/UF	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	RES-BUS 3 UV/UF	UNKNOWN / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225123 Amps @ 125VDC Totals:							1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 179

Scenario: CMP22

Continued on Page 557

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	27-4/62-BUS 4 UV/UF	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-4/62X-BUS 4 UV/UF	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-4/ICS-BUS 4 UV/UF	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-4/X1-BUS 4 UV/UF	WHSE / MG-6, 24 V, W/ 300 OHM RES	Z	0.32	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-4/X2-BUS 4 UV/UF	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-4/X3-BUS 4 UV/UF	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	81-4/ICS-BUS 4 UV/UF	WHSE / KF	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	81-4/X1-BUS 4 UV/UF	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	RES-BUS 4 UV/UF	UNKNOWN / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225124 Amps @ 125VDC Totals:							1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10	1.10

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 180

Scenario: CMP22

Continued on Page 558

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	27-3/62A-BUS 3 UV/UF	AGASTAT / 2122DH39YC	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	27-3A-BUS 3 UV/UF	ABB / TYPE 27N, SERIES 411T, #411	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-4/62A-BUS 4 UV/UF	AGASTAT / 2122DH39YC	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-4A-BUS 4 UV/UF	ABB / TYPE 27N, SERIES 411T, #411	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225173 Amps @ 125VDC Totals:							0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 181

Scenario: CMP22

Continued on Page 559

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	43/CWP22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	49A/T-CWP22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	49A/X-CWP22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	49C/T-CWP22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	49C/X-CWP22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-CWP22	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-CWP22	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-CWP22	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-CWP22	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	62/CWP22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	62FLT/CWP22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63AR/CWP22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
4	INDLTS-CWP22	UNKNOWN / INDICATING LIGHT	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: B231669 Amps @ 125VDC Totals:							0.91	0.91	0.91	5.06	5.06	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 182

Scenario: CMP22

Continued on Page 560

Circuit:	PP22-09	Schematic:	B231670	Time Step:	15	16	17	18	19	20	21	22	23	24	25	26	27	28
				Time Step Range:	0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0

Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	43/CWP24	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	49A/T-CWP24	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	49A/X-CWP24	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	49C/T-CWP24	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	49C/X-CWP24	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-CWP24	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-CWP24	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-CWP24	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-CWP24	UNKNOWN / Y-CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	62/CWP24	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	62FLT/CWP24	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63AR/CWP24	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
4	JNDLTS-CWP24	UNKNOWN / INDICATING LIGHT	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60

Schematic: B231670 Amps @ 125VDC Totals: 0.91 0.91 0.91 5.06 5.06 0.91 0.91 0.91 0.91 0.91 0.91 0.91 0.91

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 183

Scenario: CMP22

Continued on Page 561

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																					
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																					
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	43/CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	49A/T-CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	49A/X-CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	49C/T-CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	49C/X-CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	52CC-CWP26	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52TC-CWP26	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52X-CWP26	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52Y-CWP26	UNKNOWN / Y-CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	62/CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	62FLT/CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63AR/CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
4	INDLTS-CWP26	UNKNOWN / INDICATING LIGHT	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: B231671 Amps @ 125VDC Totals:				0.91	0.91	0.91	5.06	5.06	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	
Circuit: PP22-09 Amps @ 125VDC Totals:				7.03	7.03	7.03	48.53	48.53	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	7.03	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 184

Scenario: CMP22

Continued on Page 562

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 12S	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	53A-GEN EXC BKR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	53B-GEN EXC BKR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	53TD-GEN EXC BKR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	53X-GEN EXC BKR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	FILTER 53A-GEN EXC BKR	UNKNOWN / FILTER FOR GEN FF R	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	FILTER 53B-GEN EXC BKR	UNKNOWN / FILTER FOR GEN FF R	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	FILTER 53TD-GEN EXC BKR	UNKNOWN / FILTER FOR GEN FF R	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	FILTER 53X-GEN EXC BKR	UNKNOWN / FILTER FOR GEN FF R	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 1986M03453 Amps @ 125VDC Totals:							0.82		0.82		0.82		0.82		0.82		0.82		0.82		0.82		0.82		0.82		0.82		0.82		0.82		0.82	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 185

Scenario: CMP22

Continued on Page 563

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	PP22-10																																			
Schematic:	1986M03496																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	57/CC-GEN EXC BKR	GE / Close Solenoid AKR-4B-50, GE B	Z	1.75	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	57/MTR-GEN EXC BKR	GE / Motor AKR-4B-50, GE BREAKER	P	5.00	27.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	57/TC-GEN EXC BKR	GE / TC AKR-4B-50, GE BREAKER	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	57/W-GEN EXC BKR	GE / W AKR-4B-50, GE BREAKER	Z	0.02	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	57/X-GEN EXC BKR	GE / X AKR-4B-50, GE BREAKER	Z	1.05	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	BATTERY LINE FILTER PN	GE / BATTERY LINE FILTER PANEL	Z	1.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 1986M03496 Amps @ 125VDC Totals:							1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 186

Scenario: CMP22

Continued on Page 564

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																			
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																			
Circuit:	PP22-10																																			
Schematic:	1986M03516																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	74T-GEN EXC BKR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TLED-1-GEN EXC BKR	UNKNOWN / LED	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TLED-2-GEN EXC BKR	UNKNOWN / LED	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TLED-3-GEN EXC BKR	UNKNOWN / LED	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TLED-4-GEN EXC BKR	UNKNOWN / LED	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	ZD-GEN EXC BKR	UNKNOWN / ZENER DIODE 24V, 10W	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 1986M03516 Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 187

Scenario: CMP22

Continued on Page 565

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																	
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																	
Circuit:	PP22-10																																	
Schematic:	9321-LL-3130 SH 05																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	59T/TDPU-GEN EXC BKR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 9321-LL-3130 SH 05 Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	
Circuit: PP22-10 Amps @ 125VDC Totals:							2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 188

Scenario: CMP22

Continued on Page 566

				Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																						
				Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																						
Circuit:	PP22-11																																								
Schematic:	110E073 SH 11																																								
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div							
1	52CC-BYA	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00					
1	52CC-RTB	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00			
1	52R-RTB	UNKNOWN / R- 52R, RESET Rx Trip	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	52TC-BYA	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00			
1	52TC-RTB	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00			
1	52X-BYA	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00			
1	52X-RTB	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00			
1	INDLTS-A-RTB	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50			
1	INDLTS-B-RTB	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50			
1	INDLTS-BYA	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50			
Schematic: 110E073 SH 11 Amps @ 125VDC Totals:							0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08				
Circuit: PP22-11 Amps @ 125VDC Totals:							0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 189

Scenario: CMP22

Continued on Page 567

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INVERTER PA	SCI / 10 KVA INV, SV12100/TS100NB	P	27.46	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: 011D13784 Amps @ 125VDC Totals:							27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46		
Circuit: PP22-14 Amps @ 125VDC Totals:							27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 190

Scenario: CMP22

Continued on Page 568

		Time Step:		15	16	17	18	19	20	21	22	23	24	25	26	27	28																		
		Time Step Range:		0:00:25.0 - 0:00:25.1	0:00:25.1 - 0:00:26.0	0:00:26.0 - 0:00:30.0	0:00:30.0 - 0:00:30.1	0:00:30.1 - 0:00:31.0	0:00:31.0 - 0:00:35.0	0:00:35.0 - 0:00:35.1	0:00:35.1 - 0:00:36.0	0:00:36.0 - 0:01:00.0	0:01:00.0 - 0:20:00.0	0:20:00.0 - 0:20:01.0	0:20:01.0 - 0:20:01.1	0:20:01.1 - 0:21:00.0	0:21:00.0 - 0:30:00.0																		
Circuit:	PP22-15																																		
Schematic:	1975M1487																																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INVERTER 22	SCI / INV 22	P	46.57	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: 1975M1487 Amps @ 125VDC Totals:							46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57		
Circuit: PP22-15 Amps @ 125VDC Totals:							46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 191

Scenario: CMP22

Circuit:	BC-22	Schematic:	IP2-S-000358	Time Step:	Time Step Range:																												
					29	30	31	32	33	34	35	36	37																				
				0:30:00.0 - 1:00:00.0		1:00:00.0 - 1:30:00.0		1:30:00.0 - 1:59:00.0		1:59:00.0 - 1:59:00.1		1:59:00.1 - 1:59:01.0		1:59:01.0 - 1:59:01.1		1:59:01.1 - 1:59:02.0		1:59:02.0 - 1:59:02.1		1:59:02.1 - 2:00:00.0													
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	27/B22	ABB / CAT. NO. 439U6345	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00											
Schematic: IP2-S-000358 Amps @ 125VDC Totals:							0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.00	0.00	0.00	0.00	0.00	0.00										
Circuit: BC-22 Amps @ 125VDC Totals:							0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.00	0.00	0.00	0.00	0.00	0.00									

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 192

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																								
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																								
Circuit:	BUS 2A																																			
Schematic:	9321-LL-3117 SH 03A																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	27-S1/2A-2A	ABB / TYPE 27N, SERIES 411T, #411	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-S2/2A-2A	ABB / TYPE 27N, SERIES 411T, #411	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	47X-SG21-U26A	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	62-1/2A-2A	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	62/2A-2A	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-N-SG21-U26A	UNKNOWN / NE-2, NEON LAMP, 200	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-UV-TS-N-2A (1)	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3117 SH 03A Amps @ 125VDC Totals:							0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.29	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 193

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																										
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																										
Circuit:	BUS 2A																																					
Schematic:	9321-LL-3117 SH 06																																					
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	26BX/O-2A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	26BX/R-2A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	52CC-2A	WHSE / DB-75-CC	Z	25.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00						
1	52TC-2A	WHSE / DB-75-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00						
1	52X-2A	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00						
1	74/2A-2A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
4	INDLTS-2A	UNKNOWN / INDICATING LIGHT	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60						
1	INDLTS-N-2A	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	INDLTS-TS MON-2A	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
				Schematic: 9321-LL-3117 SH 06 Amps @ 125VDC Totals:				0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42		
																				0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 194

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																					
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	21BX/O-EG2A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	21BX/R-EG2A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	21BX1/O-EG2A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	21BX1/R-EG2A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	52CC-EG2A	WHSE / DB-75-CC	Z	25.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
1	52TC-EG2A	WHSE / DB-75-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
1	52X-EG2A	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
1	74/EG2A-EG2A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
4	INDLTS-EG2A	UNKNOWN / INDICATING LIGHT	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	
1	INDLTS-N-EG2A	ALCO / NEON- BND-2R	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
Schematic: 9321-LL-3117 SH 08 Amps @ 125VDC Totals:							0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.61	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 195

Scenario: CMP22

Circuit:	BUS 2A	Time Step:	29	30	31	32	33	34	35	36	37						
Schematic:	9321-LL-3117 SH 11	Time Step Range:	0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0						

Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	52CC-LT1N	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52CC-MCC1	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52CC-MCC10	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52CC-MCC3	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52CC-MCC4A	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52CC-MCC8A	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-LT1N	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-MCC1	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-MCC10	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-MCC3	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-MCC4A	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-MCC8A	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-LT1N	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-MCC1	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-MCC10	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-MCC3	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-MCC4A	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	1.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-MCC8A	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00

Schematic: 9321-LL-3117 SH 11 Amps @ 125VDC Totals: 0.00 0.00 0.00 0.03 12.03 0.00 0.00 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 196

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Circuit:	BUS 2A																												
Schematic:	A208088																												
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	EDD2	ASCO / AUTO TRANSFER P/N 302A	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
Schematic: A208088 Amps @ 125VDC Totals:							0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 197

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																												
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																												
Qty	Device ID	Mfr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	2/SI2A-SI2A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-SI2A	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-SI2A	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-SI2A	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74-SI2A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	JNDLTS-N-SI2A	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
2	JNDLTS-SI2A	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225135 Amps @ 125VDC Totals:							0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 198

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																												
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	2/SW5B-SW5B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-SW5B	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-SW5B	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-SW5B	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/SW5B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-N-SW5B	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
3	INDLTS-SW5B	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	M-SW5B	UNKNOWN / TIME METER	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	S25A-SW5B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225141 Amps @ 125VDC Totals:							0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 199

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																																										
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																																										
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div																						
1	52CC-PBU2	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00																						
1	52TC-PBU2	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00																						
1	52X-PBU2	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00																						
1	74/PBU2-PBU2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																						
1	86-PBU2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																						
2	INDLTS-PBU2	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50																						

Schematic: B225145 Amps @ 125VDC Totals: 0.24 0.24 0.24 0.24 0.24 0.24 0.24 0.24 0.24 0.24 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 200

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	2/SW2A-SW2A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	52CC-SW2A	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00						
1	52TC-SW2A	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00						
1	52X-SW2A	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00						
1	74/SW2A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	INDLTS-N-SW2A	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
3	INDLTS-SW2A	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60						
1	M-SW2A	UNKNOWN / TIME METER	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	S24A-SW2A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
Schematic: B225147 Amps @ 125VDC Totals:							0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.00	0.00	0.00	0.00	0.00	0.00							

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 201

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37														
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0														
Qty	Device ID	Mfrgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	52CC-CC2	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-CC2	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-CC2	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74-CC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	86-CC2	WHSE / 86 LOCKOUT RELAY (0.48kV)	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CC2/2TD-CC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
3	INDLTS-CC2	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	INDLTS-N-CC2	ALCO / NEON- BND-2R	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50

Schematic: B225150 Amps @ 125VDC Totals: 0.28 0.28 0.28 0.28 0.28 0.28 0.28 0.28 0.28 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 202

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																										
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:01.1	1:59:01.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																										
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	2-CRF3-CRF 23	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-CRF 23	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-CRF 23	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-CRF 23	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74-CRF 23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	JNDLTS-CRF 23	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	JNDLTS-N-CRF 23	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225152 Amps @ 125VDC Totals:							0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 203

Scenario: CMP22

Circuit:	BUS 2A	Schematic:	B253867	Time Step:	29	30	31	32	33	34	35	36	37																
				Time Step Range:	0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																

Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	52CC-MG1	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-MG1	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-MG1	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/1-MG1	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-MG1	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50

Schematic: B253867 Amps @ 125VDC Totals:	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12
Circuit: BUS 2A Amps @ 125VDC Totals:	3.25	3.25	3.25	3.28	15.28	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25	3.25

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 204

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																																														
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																																														
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div																						
1	2/SI3-SI3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																				
1	52CC-SI3	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00																				
1	52TC-SI3	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00																				
1	52X-SI3	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00																				
1	74-SI3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																				
2	INDLTS-A-SI3	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50																				
1	INDLTS-N-SI3	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50																				
Schematic: 300925 Amps @ 125VDC Totals:							0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26																				
																							0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 205

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Circuit:	BUS 6A																												
Schematic:	9321-LL-3117 SH 03A																												
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	INDLTS-UV-TS-N-2A (2)	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
Schematic: 9321-LL-3117 SH 03A Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 206

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																				
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																				
Circuit:	BUS 6A																															
Schematic:	9321-LL-3118 SH 03B																															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	27-S1/6A-6A	ABB / TYPE 27N, SERIES 411T, #411	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
1	27-S2/6A-6A	ABB / TYPE 27N, SERIES 411T, #411	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
1	47X-SG22-U13A	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
1	62-1/6A-6A	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
1	62/6A-6A	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
1	INDLTS-N-SG22-U13A	UNKNOWN / NE-2, NEON LAMP, 200	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50												
Schematic: 9321-LL-3118 SH 03B Amps @ 125VDC Totals:							0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 207

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	13BX/O-6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	13BX/R-6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-6A	WHSE / DB-75-CC	Z	25.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-6A	WHSE / DB-75-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-6A	WHSE / X-CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/6A-6A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
4	JNDLTS-6A	UNKNOWN / INDICATING LIGHT	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	JNDLTS-N-6A	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	JNDLTS-TS MON-6A	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3118 SH 04 Amps @ 125VDC Totals:							0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 208

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																												
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																												
Circuit:	BUS 6A																																							
Schematic:	9321-LL-3118 SH 05																																							
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52CC-3AT6A	WHSE / DB-75-CC	Z	25.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52LO-3AT6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52TC-3AT6A	WHSE / DB-75-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-3AT6A	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/3AT6A-3AT6A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	7BX/O-3AT6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	7BX/R-3AT6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	7BX1/O-3AT6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	7BX1/R-3AT6A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-3AT6A	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3118 SH 05 Amps @ 125VDC Totals:							0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66	0.66

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 209

Scenario: CMP22

			Time Step:		29	30	31	32	33	34	35	36	37															
			Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0															
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	13CX/O-EG3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	13CX/R-EG3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	13CX1/O-EG3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	13CX1/R-EG3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	52CC-EG3	WHSE / DB-75-CC	Z	25.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00						
1	52TC-EG3	WHSE / DB-75-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00						
1	52X-EG3	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00						
1	74/EG3-EG3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
4	JNDLTS-EG3	UNKNOWN / INDICATING LIGHT	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60						
1	JNDLTS-N-EG3	ALCO / NEON- BND-2R	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						

Schematic: 9321-LL-3118 SH 07 Amps @ 125VDC Totals: 0.61 0.61 0.61 0.61 0.61 0.61 0.61 0.61 0.61 0.61 0.61 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 210

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Circuit:	BUS 6A																											
Schematic:	9321-LL-3118 SH 09																											
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	52CC-MCC6B	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-MCC6B	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-MCC6B	WHSE / X-CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
2	INDLTS-MCC6B	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-MCC6B	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3118 SH 09 Amps @ 125VDC Totals:							0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 211

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																								
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																								
Circuit:	BUS 6A																																			
Schematic:	9321-LL-3118 SH 10																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52CC-LTIE	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00														
1	52CC-MCC7A	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	52TC-LTIE	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00								
1	52TC-MCC7A	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00								
1	52X-LTIE	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00								
1	52X-MCC7A	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
Schematic: 9321-LL-3118 SH 10 Amps @ 125VDC Totals:							0.00	0.00	0.00	0.03	12.03	12.03	12.03	12.03	12.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 212

Scenario: CMP22

			Time Step:		29	30	31	32	33	34	35	36	37																					
			Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																					
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	2-1/AF3-AF3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
1	2-2/AF3-AF3	A-B / 700-RTC	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
1	52CC-AF3	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00												
1	52TC-AF3	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00												
1	52X-AF3	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00												
1	74/AF3-AF3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
1	BFD/3-AF3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
2	INDLTS-AF3	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50												
1	INDLTS-N-AF3	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50												
Schematic: 9321-LL-3118 SH 16 Amps @ 125VDC Totals:								0.46		0.46		0.46		0.46		0.46		0.46		0.46		0.46		0.00		0.00		0.00		0.00		0.00		0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 213

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Circuit:	BUS 6A																													
Schematic:	9321-LL-3118 SH 18																													
Qty	Device ID	Mfg/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	52CC-TAO	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-TAO	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-TAO	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/TAO-TAO	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	86/TAO-TAO	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	BFD/1-TAO	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	JNDLTS-TAO	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3118 SH 18 Amps @ 125VDC Totals:							0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 214

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																							
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																							
Circuit:	BUS 6A																																		
Schematic:	A208088																																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	EDD1	ASCO / AUTO TRANSFER P/N 302A1	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00													
Schematic: A208088 Amps @ 125VDC Totals:							0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 215

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																				
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																				
Circuit:	BUS 6A																															
Schematic:	B225131																															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	52CC-MG2	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-MG2	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-MG2	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/2-MG2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-MG2	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225131 Amps @ 125VDC Totals:							0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 216

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Circuit:	BUS 6A																												
Schematic:	B225132																												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	2/C3	AGASTAT / 7000 SERIES	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	52CC-C3	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00							
1	52TC-C3	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00							
1	52X-C3	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00							
2	INDLTS-C3	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
Schematic: B225132 Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 217

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																																															
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																																															
Circuit:	BUS 6A																																																										
Schematic:	B225137																																																										
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div																							
1	2/RHR2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																													
1	52CC-RHR2	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00																													
1	52TC-RHR2	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00																													
1	52X-RHR2	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00																													
1	74-RHR2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																													
1	INDLTS-N-RHR2	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50																													
3	INDLTS-RHR2	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60																													
Schematic: B225137 Amps @ 125VDC Totals:							0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28																					
																								0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 218

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Circuit:	BUS 6A																											
Schematic:	B225142																											
Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	52CC-R2	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-R2	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-R2	WHSE / X-CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74-R2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-N-R2	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
2	INDLTS-R2	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225142 Amps @ 125VDC Totals:							0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 219

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	2/CRF5	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-CRF5	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-CRF5	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-CRF5	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74-CRF5	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-CRF5	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-CRF5	ALCO / NEON- BND-2R	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225143 Amps @ 125VDC Totals:							0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 220

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Circuit:	BUS 6A																													
Schematic:	B225144																													
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	52CC-PC	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-PC	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-PC	WHSE / X- CLOSING RELAY (0.48KV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
2	INDLTS-PC	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225144 Amps @ 125VDC Totals:							0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 221

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																												
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	2/CS2-CS2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-CS2	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-CS2	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-CS2	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74-CS2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-CS2	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-CS2	ALCO / NEON- BND-2R	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225146 Amps @ 125VDC Totals:							0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.26

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 222

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																												
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	2/SW3-SW3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52CC-SW3	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-SW3	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-SW3	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74/SW3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	JNDLTS-N-SW3	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
3	JNDLTS-SW3	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	M-SW3	UNKNOWN / TIME METER	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	S8C-SW3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225149 Amps @ 125VDC Totals:							0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 223

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																										
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																										
Circuit:	BUS 6A																																					
Schematic:	B225151																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-CC3	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-CC3	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-CC3	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	74-CC3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	86-CC3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	CC3-2TD-CC3	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
3	JNDLTS-CC3	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	JNDLTS-N-CC3	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: B225151 Amps @ 125VDC Totals:							0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 224

Scenario: CMP22

				Time Step:		29	30	31	32	33	34	35	36	37																			
Circuit: BUS 6A				Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																			
Schematic: IP2-S-000194																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	2/SW6-SW6	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00											
1	52CC-SW6	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00											
1	52TC-SW6	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00											
1	52X-SW6	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00											
1	74/SW6	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00											
1	INDLTS-N-SW6	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50											
3	INDLTS-SW6	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60											
1	M-SW6	UNKNOWN / TIME METER	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00											
1	S8B-SW6	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00											
Schematic: IP2-S-000194 Amps @ 125VDC Totals:							0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.00	0.00	0.00	0.00	0.00											
Circuit: BUS 6A Amps @ 125VDC Totals:							5.44	5.44	5.44	5.47	17.47	17.47	17.47	17.47	17.47	17.47	17.47	17.47	0.00	0.00	0.00	0.00	0.00										

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 225

Scenario: CMP22

				Time Step:		29	30	31	32	33	34	35	36	37											
				Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0											
Circuit:	DA5 XFR SW																								
Schematic:	195B47																								
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	DA5	ASCO / TYPE BULLETIN 908, ASSUM Z		0.95	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00					
Schematic: 195B47 Amps @ 125VDC Totals:							0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.00	0.00	0.00	0.00	0.00	0.00	
Circuit: DA5 XFR SW Amps @ 125VDC Totals:							0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 226

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																									
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																									
Circuit: DG22-CONTROL																																					
Schematic: A208540																																					
Qty	Device ID	Mfg/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div									
1	86-EDG 22	WHSE / MG-6	Z	0.06	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00									
1	86X-EDG 22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00									
1	CVX-EDG 22	WHSE / MG-6	Z	0.06	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00									
1	INDLTS-GEN-EDG 22	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	VBR-EDG 22	WHSE / CV	Z	0.20	0.00	On	N	0.00	N	1.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00									
Schematic: A208540 Amps @ 125VDC Totals:							0.02	0.22	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 227

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Qty	Device ID	Mfg/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	32X-EDG 22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	51VX-EDG 22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	AGA/1-EDG 22	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	AGA/2-EDG 22	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
16	ANNUNCLTS-EDG 22	UNKNOWN / INDICATING LIGHT	Z	0.51	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	ANNUNHORN-EDG 22	PANALARM / HORN FOR ANNUNCI	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	ASR-EDG 22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	ASV/1-EDG 22	ROSS / SERIES 27	Z	0.14	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	ASV/2-EDG 22	ROSS / SERIES 27	Z	0.14	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CR/1-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CR/2-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	EDD6	ASCO / AUTO TRANSFER P/N 302A1	Z	0.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	ESR/1-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	ESR/2-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	ESRX/1-EDG 22	WHSE / Nbfd	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	ESRX/2-EDG 22	WHSE / Nbfd	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	ESS-EDG 22	UNKNOWN / 1 PUSHBUTTON LT & 1	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	FLD FLASH-EDG 22	ALCO / FIELD FLASH	Z	17.55	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	FODPR-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	FODSR-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	FR-EDG 22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	H/HWTR-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	HL/LOTR-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	HLOTR/1-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	HR-EDG 22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	HWTR-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	HWTR/1-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	X1X-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	LAPR-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	LFLLR-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	LODFR-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	LODSR-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	NST-EDG 22	UNKNOWN / UNKNOWN TIME DELA	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	OCR-EDG 22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	OCT/1-EDG 22	AMERACE / CAT. NO. 7012PD	Z	0.06	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	OCT/2-EDG 22	AMERACE / CAT. NO. 7012PD	Z	0.06	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	OPR-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	OPT1-EDG 22	AMERACE / CAT. NO. 7012PD	Z	0.06	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	OPT2-EDG 22	AMERACE / CAT. NO. 7012PD	Z	0.06	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	OSR-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 228

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																								
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																								
Circuit:	DG22-CONTROL																																			
Schematic:	IP2-S-000285																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	PDT-EDG 22	UNKNOWN / UNKNOWN TIME DELA	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	R1-EDG 22	WHSE / BFD	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	R2-EDG 22	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	RR-EDG 22	UNKNOWN / UNKNOWN W/ DIODE	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SDR-EDG 22	AMERACE / CAT. NO. E7022PE004	Z	0.06	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	UPR-EDG 22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
Schematic: IP2-S-000285 Amps @ 125VDC Totals:							1.55	2.18	2.18	2.18	2.18	2.18	2.18	2.18	2.18	2.18	2.18	2.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 229

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																				
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																				
Circuit:	DG22-CONTROL																															
Schematic:	IP2-S-000365																															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	INDLTS-EDG 22	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50										
1	JWPS(3,4)-EDG 22	WHSE / NBFD	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	K1-EDG 22	WHSE / TYPE MLLO-2H	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	K1T-EDG 22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00										
1	K2-EDG 22	WHSE / TYPE MLLO-2H	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	K4-EDG 22	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00										
Schematic: IP2-S-000365 Amps @ 125VDC Totals:							0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.00	0.00	0.00	0.00	0.00											
Circuit: DG22-CONTROL Amps @ 125VDC Totals:							1.96	2.79	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59	2.59	0.00	0.00	0.00	0.00	0.00										

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 230

Scenario: CMP22

Qty	Device ID	Mfg/Model	Tp	Amps @ 125	Inrush	Tog	Time Step: 29		Time Step: 30		Time Step: 31		Time Step: 32		Time Step: 33		Time Step: 34		Time Step: 35		Time Step: 36		Time Step: 37										
							NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI
1	86-EDG 23	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00									
1	86X-EDG 23	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00									
1	CVX-EDG 23	WHSE / MG-6	Z	0.06	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00									
1	INDLTS-GEN-EDG 23	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	VBR-EDG 23	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
Schematic: A208540 Amps @ 125VDC Totals:							0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.00	0.00	0.00	0.00	0.00	0.00									

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 232

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	PDT-EDG 23	UNKNOWN / UNKNOWN TIME DELA	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	R1-EDG 23	WHSE / BFD	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	R2-EDG 23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	RR-EDG 23	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SDR-EDG 23	UNKNOWN / UNKNOWN TIME DELA	Z	0.07	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	UPR-EDG 23	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00

Schematic: IP2-S-000286 Amps @ 125VDC Totals: 2.11 1.91 1.91 1.91 1.91 1.91 1.91 1.91 1.91 1.91 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 233

Scenario: CMP22

Circuit: DG23-CONTROL Schematic: IP2-S-000366	Time Step:	29	30	31	32	33	34	35	36	37										
	Time Step Range:	0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0										

Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-EDG 23	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50										
1	JWPS(3,4)X-EDG 23	WHSE / NBFD	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	K1-EDG 23	WHSE / TYPE MLLO-2H	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	K2-EDG 23	WHSE / TYPE MLLO-2H	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	K4-EDG 23	UNKNOWN / UNKNOWN W/ DIODE	Z	0.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00										

Schematic: IP2-S-000366 Amps @ 125VDC Totals: 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.39 0.00 0.00 0.00 0.00 0.00

Circuit: DG23-CONTROL Amps @ 125VDC Totals: 2.72 2.51 2.51 2.51 2.51 2.51 2.51 2.51 2.51 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 234

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																								
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																								
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	85L2/345-345kV LINE	UNKNOWN / PILOT WIRE RECIEVER	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	86X1-345kV LINE	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	87L2/345-345kV LINE	WHSE / TYPE HCB, DIFF CURRENT	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	INDLTS-345kV LINE (2)	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	TD1/345-345kV LINE	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	TD2/345-345kV LINE	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	TD2X-345kV LINE	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	TD3/345-345kV LINE	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
Schematic: 9321-LL-3132 SH 07 Amps @ 125VDC Totals:							0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 235

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37												
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	85L2/138-138kV LINE	UNKNOWN / PILOT WIRE RECIEVER	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	87L2/138-138kV LINE	WHSE / TYPE HCB, DIFF CURRENT	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	INDLTS-138kV LINE (2)	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	TD1-138kV LINE	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	TD2-138kV LINE	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	TD2X-138kV LINE	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	TD3-138kV LINE	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: 9321-LL-3132 SH 09 Amps @ 125VDC Totals:							0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 236

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																									
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																									
Circuit:	DP22-01																																				
Schematic:	B225122																																				
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	B1T2-UVUF	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00															
Schematic: B225122 Amps @ 125VDC Totals:							0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.00	0.00	0.00	0.00	0.00															

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 237

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																								
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																								
Circuit:	DP22-01																																			
Schematic:	B225125																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div								
1	27-6/62-UVUF	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	27-6/62X-UVUF	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	27-6/CS-UVUF	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	27-6/X1-UVUF	WHSE / MG-6, 24 V, W/ 300 OHM RE	Z	0.32	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
Schematic: B225125 Amps @ 125VDC Totals:							0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
Circuit: DP22-01 Amps @ 125VDC Totals:							2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	2.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 238

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																			
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																			
Circuit:	DP22-02																														
Schematic:	9321-LL-3132 SH 11																														
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	201/C-BKR-7	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
1	294/T-BKR-7	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00			
Schematic: 9321-LL-3132 SH 11 Amps @ 125VDC Totals:							0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
Circuit: DP22-02 Amps @ 125VDC Totals:							0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 239

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																											
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																											
Circuit:	DP22-03																																						
Schematic:	9321-LL-3132 SH 02																																						
Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	82/UT	UNKNOWN / TD-53 TIME DELAY REL	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
1	86/UT	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00									
3	INDLTS-MISC LO RLY (2)	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60									
1	INDLTS-N-MISC LO RLY (2)	UNKNOWN / NE-2, NEON LAMP, 200	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
Schematic: 9321-LL-3132 SH 02 Amps @ 125VDC Totals:							0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 240

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	86/STBU	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
Schematic: 9321-LL-3132 SH 04 Amps @ 125VDC Totals:							0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 241

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																								
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																								
Circuit:	DP22-03																																			
Schematic:	9321-LL-3132 SH 05																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	25X2-MISC LO RLY	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
Schematic: 9321-LL-3132 SH 05 Amps @ 125VDC Totals:							0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 242

Scenario: CMP22

Circuit:	DP22-03	Schematic:	9321-LL-3132 SH 13	Time Step:	29	30	31	32	33	34	35	36	37																										
					Time Step Range:	0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																									
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	86/STBU-A	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00															
Schematic: 9321-LL-3132 SH 13 Amps @ 125VDC Totals:							0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
Circuit: DP22-03 Amps @ 125VDC Totals:							0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 243

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Circuit:	DP22-04																												
Schematic:	B209518																												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	INDLTS-V951	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	SOV951	ASCO / CAT. NO. NP8320A183V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
Schematic: B209518 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.00	0.00	0.00	0.00	0.00							

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 244

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																									
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																									
Circuit:	DP22-04																																				
Schematic:	B209519																																				
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	INDLTS-V953	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50															
1	SOV953	ASCO / CAT. NO. NP8320A183V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00															
Schematic: B209519 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 245

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																										
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																										
Circuit:	DP22-04																																					
Schematic:	B209520																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	INDLTS-V955C	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	SOV955C	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
Schematic: B209520 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 246

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																								
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																								
Circuit:	DP22-04																																			
Schematic:	B209521																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div										
1	INDLTS-V955D	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50										
1	SOV955D	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
Schematic: B209521 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00									

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 247

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Circuit:	DP22-04																											
Schematic:	B209522																											
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div
1	INDLTS-V955E	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV955E	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B209522 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 248

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																			
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																			
Circuit:	DP22-04																														
Schematic:	B209523																														
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INDLTS-V955F	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	SOV955F	ASCO / CAT. NO. NP8320A183E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
Schematic: B209523 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.00	0.00	0.00	0.00	0.00	0.00								
Circuit: DP22-04 Amps @ 125VDC Totals:							0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.00	0.00	0.00	0.00	0.00	0.00							

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 249

Scenario: CMP22

				Time Step:		29	30	31	32	33	34	35	36	37																				
				Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																				
Circuit:	DP22-05																																	
Schematic:	208416																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	1789/BRR-V1789	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
2	INDLTS-V1789	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50												
1	SOV1789	ASCO / CAT. NO. NP8320A183V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
Schematic: 208416 Amps @ 125VDC Totals:							0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 250

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																													
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																													
Circuit:	DP22-05																																								
Schematic:	208417																																								
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div							
1	1788/ARR-V1788	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
2	INDLTS-V1788	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	SOV1788	ASCO / CAT. NO. NP8320A183V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
Schematic: 208417 Amps @ 125VDC Totals:								0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 251

Scenario: CMP22

		Time Step:																			
		29	30	31	32	33	34	35	36	37											
Circuit:		Time Step Range:																			
DP22-05		0:30:00.0 -	1:00:00.0 -	1:30:00.0 -	1:59:00.0 -	1:59:00.1 -	1:59:01.0 -	1:59:01.1 -	1:59:02.0 -	1:59:02.1 -											
Schematic: 208419		1:00:00.0	1:30:00.0	1:59:00.0	1:59:00.1	1:59:01.0	1:59:01.1	1:59:02.0	1:59:02.1	2:00:00.0											

Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	S48/ARR-V548	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
2	INDLTS-V548	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50												
1	SOV548	ASCO / CAT. NO. NP8314C28V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
Schematic: 208419 Amps @ 125VDC Totals:								0.28		0.28		0.28		0.28		0.28		0.28		0.28		0.28		0.28		0.00		0.00		0.00		0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 252

Scenario: CMP22

				Time Step:		29	30	31	32	33	34	35	36	37															
				Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	549/BRR-V549	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
2	INDLTS-V549	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	SOV549	ASCO / CAT. NO. NP8314C28V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
Schematic: 208421 Amps @ 125VDC Totals:							0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.00	0.00	0.00	0.00	0.00						

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 253

Scenario: CMP22

				Time Step:		29	30	31	32	33	34	35	36	37								
				Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0								
Circuit:	DP22-05																					
Schematic:	303686																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	SOV1600A	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV1600B	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV1600D	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV265	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: 303686 Amps @ 125VDC Totals:							0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 254

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Circuit:	DP22-05																												
Schematic:	303845																												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	SOV1286	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	SOV1600E	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	SOV1600F	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	SOV1600G	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
Schematic: 303845 Amps @ 125VDC Totals:							0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 255

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Circuit:	DP22-05																											
Schematic:	304159																											
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	SOV1284	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV1285	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV1600H	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV1600J	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV1600K	ASCO / CAT. NO. HCX8262220	Z	0.09	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
Schematic: 304159 Amps @ 125VDC Totals:							0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 256

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																						
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																						
Circuit:	DP22-05																																	
Schematic:	A207559																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	1/SJAE-X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	33-2X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	33-4X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
Schematic: A207559 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.00	0.00	0.00	0.00	0.00											

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 257

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Qty	Device ID	Mfg/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
2	INDLTS-SAEIV	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	SOV1430	ASCO / CAT. NO. NP8321A5DE	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
1	SOV1433	ASCO / CAT. NO. 8300C58RF	Z	0.29	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
Schematic: B207571 Amps @ 125VDC Totals:							0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.46	0.00	0.00	0.00	0.00	0.00								

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 258

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																			
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	10SGIS/BRR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
1	9SGIS/BRR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
Schematic: B208435 Amps @ 125VDC Totals:							0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.00	0.00	0.00	0.00	0.00									
Circuit: DP22-05 Amps @ 125VDC Totals:							3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	3.50	0.00	0.00	0.00	0.00	0.00										

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 259

Scenario: CMP22

Circuit:	DP22-06	Time Step:	29	30	31	32	33	34	35	36	37																
Schematic:	225242	Time Step Range:	0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	INDLTS-SBIF-2	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50					
Schematic: 225242 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.00	0.00	0.00	0.00	0.00	0.00					

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 260

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Circuit:	DP22-06																												
Schematic:	9321-LL-3131 SH 21																												
Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	Ni	Div	
2	INDLTS-MSIV-21,22	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
Schematic: 9321-LL-3131 SH 21 Amps @ 125VDC Totals:							0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.00	0.00	0.00	0.00	0.00	0.00						

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 261

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Qty	Device ID	Mfgr/Model	tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	20/1-CRMIV-B	ASCO / CAT. NO. 206-381-2RVF	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	20/2-CRMIV-B	ASCO / CAT. NO. 206-381-2RVF	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	20/3-CRMIV-B	ASCO / CAT. NO. 206-381-2RVF	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	20/4-CRMIV-B	ASCO / CAT. NO. 206-381-2RVF	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
8	INDLTS-CRMIV-B	UNKNOWN / INDICATING LIGHT	Z	0.26	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60						
1	RM/BRR-CRMIV-B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
Schematic: 9321-LL-3131 SH 25 Amps @ 125VDC Totals:							1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	1.38	0.00	0.00	0.00	0.00	0.00					

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 264

Scenario: CMP22

				Time Step:		29		30		31		32		33		34		35		36		37								
				Time Step Range:		0:30:00.0 - 1:00:00.0		1:00:00.0 - 1:30:00.0		1:30:00.0 - 1:59:00.0		1:59:00.0 - 1:59:01.0		1:59:01.0 - 1:59:01.1		1:59:01.1 - 1:59:02.0		1:59:02.0 - 1:59:02.1		1:59:02.1 - 2:00:00.0										
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-MOV956F	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
Schematic: A208844 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 265

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																									
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																									
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	20/5-SGI2	ASCO / CAT. NO. NPK8316A54V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	20/6-SGI2	ASCO / CAT. NO. NPK8316A54V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	20/7-SGI2	ASCO / CAT. NO. NPK8316A54V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	20/8-SGI2	ASCO / CAT. NO. NPK8316A54V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
9	JNDLTS-SGI2	UNKNOWN / INDICATING LIGHT	Z	0.29	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	
1	SG2X-SGI2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: A209515 Amps @ 125VDC Totals:							0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.83	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 267

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Circuit:	DP22-06																											
Schematic:	B209525																											
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	INDLTS-A-V956D	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
2	INDLTS-V956D	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV956D	ASCO / CAT. NO. NP8314C28V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B209525 Amps @ 125VDC Totals:							0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 270

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37														
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0														
Circuit:	DP22-06																									
Schematic:	B226967																									
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	INDLTS-IVSW3518	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	IVSW3518	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B226967 Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 271

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Circuit:	DP22-06																											
Schematic:	IP2-S-000006																											
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	INDLTS-V1413	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV1413-V1413	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: IP2-S-000006 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 272

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																						
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																						
Circuit:	DP22-06																																	
Schematic:	IP2-S-000197																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-MOV1810	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50												
Schematic: IP2-S-000197 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.00	0.00	0.00	0.00	0.00											

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 273

Scenario: CMP22

			Time Step:																							
			29		30		31		32		33		34		35		36		37							
			0:30:00.0 - 1:00:00.0		1:00:00.0 - 1:30:00.0		1:30:00.0 - 1:59:00.0		1:59:00.0 - 1:59:00.1		1:59:00.1 - 1:59:01.0		1:59:01.0 - 1:59:01.1		1:59:01.1 - 1:59:02.0		1:59:02.0 - 1:59:02.1		1:59:02.1 - 2:00:00.0							
			Time Step Range:																							
Qty	Device ID	Mfgnr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	INDLTS-MOV744	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
Schematic: IP2-S-000198 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 274

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																							
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																							
Circuit:	DP22-06																																		
Schematic:	IP2-S-000201																																		
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	INDLTS-MOV842	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50													
Schematic: IP2-S-000201 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 275

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																									
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																									
Circuit:	DP22-06																																				
Schematic:	IP2-S-000212																																				
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	JNDLTS-MOV856F	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50															
Schematic: IP2-S-000212 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 276

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																							
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																							
Circuit:	DP22-06																																		
Schematic:	IP2-S-000225																																		
Qty	Device ID	Mfg/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	INDLTS-MOV894C	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50													
Schematic: IP2-S-000225 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 277

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INDLTS-MOV894A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
Schematic: IP2-S-000226 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.00	0.00	0.00	0.00	0.00	0.00							
Circuit: DP22-06 Amps @ 125VDC Totals:							8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	8.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00						

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 278

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																								
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																								
Circuit:	DP22-08																																			
Schematic:	110E073 SH 11																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	BYA/RT/BX-RX TRIP TR B	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	S166/ST-52/RTB	GE / TYPE HGA	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	S167/ST1-52/RTB	GE / TYPE HGA	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	UV-52/BYA-RX TRIP TR B	UNKNOWN / UV RELAY	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	UV-52/RTB-RX TRIP TR B	UNKNOWN / UV RELAY	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: 110E073 SH 11 Amps @ 125VDC Totals: 0.32 0.32 0.32 0.32 0.32 0.32 0.32 0.32 0.32 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 280

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																								
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																								
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-L58-B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50												
Schematic: 110E073 SH 10 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 282

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																												
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																												
Qty	Device ID	Mfg/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	1/NC32B/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC32B/Y-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC32B/Z-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC33B/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC33B/Z-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC35A/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC35A/Y-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC35A/Z-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC36A/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC36A/Y-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC36A/Z-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC38B/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC38B/Z-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC39A/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC39B/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC47B/X-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	1/NC47B/Z-RX TRIP TR B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: 110E073 SH 3 Amps @ 125VDC Totals: 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77 1.77 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 283

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																												
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																												
Circuit:	DP22-08																																							
Schematic:	110E073 SH 5																																							
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	SIAM/1-X-RX TRIP TR B	WHSE / TYPE BFD, STYLE 5072A49	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	SIAM/2-X-RX TRIP TR B	WHSE / TYPE BFD, STYLE 5072A49	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
Schematic: 110E073 SH 5 Amps @ 125VDC Totals:							0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 284

Scenario: CMP22

				Time Step:		29	30	31	32	33	34	35	36	37																										
				Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																										
Circuit:	DP22-08																																							
Schematic:	110E073 SH 8																																							
Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	1/MT1-X-RX TRIP TR B	WHSE / TYPE BFD, STYLE 5072A49	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	1/MT2-X-RX TRIP TR B	WHSE / TYPE BFD, STYLE 5072A49	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: 110E073 SH 8 Amps @ 125VDC Totals:							0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
Circuit: DP22-08 Amps @ 125VDC Totals:							6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	6.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 285

Scenario: CMP22

Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	Time Step: 29		Time Step: 30		Time Step: 31		Time Step: 32		Time Step: 33		Time Step: 34		Time Step: 35		Time Step: 36		Time Step: 37											
							NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	1X/RS-BFP22 TT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	20/RSV-BFP22 TT	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	20/TT-1-BFP22 TT	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	20/TT-2-BFP22 TT	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	3RS/BFP2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	63/BOX-BFP22 TT	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	63/DPX-BFP22 TT	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	63X/BFP2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	63X/LV-BFP22 TT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	63X/SCMIN-BFP22 TT	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	63X1/BFP2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	63X2/BFP2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	74-BFP22 T T	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	INDLTS-A-BFP22 T T	UNKNOWN / LIGHT W/ 10000 OHM.	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
2	INDLTS-B-BFP22 T T	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
1	INDLTS-N-BFP22 T T	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
1	UNKWN-RELAY-BFP22 T T	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								

Schematic: 9321-LL-3140 SH 12 Amps @ 125VDC Totals: 1.65 1.65 1.65 1.65 1.65 1.65 1.65 1.65 1.65 1.65 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 286

Scenario: CMP22

Circuit:	DP22-09	Schematic:	9321-LL-3140 SH 14	Time Step:		29	30	31	32	33	34	35	36	37																		
				Time Step Range:	0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 12S	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	20/LP-SVC2	UNKNOWN / SOV - OPERATES AS V	Z	0.30	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	33X-BFP22 LPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	33X/1-BFP22 LPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	33X/2-BFP22 LPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	33X/3-BFP22 LPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	72L/BFP22 LPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	72R/BFP22 LPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
2	INDLTS-BFP22 LPSVC2	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3140 SH 14 Amps @ 125VDC Totals:							0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 287

Scenario: CMP22

				Time Step:		29		30		31		32		33		34		35		36		37													
				Time Step Range:		0:30:00.0 - 1:00:00.0		1:00:00.0 - 1:30:00.0		1:30:00.0 - 1:59:00.0		1:59:00.0 - 1:59:00.1		1:59:00.1 - 1:59:01.0		1:59:01.0 - 1:59:01.1		1:59:01.1 - 1:59:02.0		1:59:02.0 - 1:59:02.1		1:59:02.1 - 2:00:00.0													
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	20/HP-SVC2	UNKNOWN / SOV - OPERATES AS V	Z	0.30	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	33X/1-BFP22 HPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	33X/2-BFP22 HPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	33X/3-BFP22 HPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	72L/BFP22 HPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	72R/BFP22 HPSVC2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
2	INDLTS-BFP22 HPSVC2	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
Schematic: 9321-LL-3140 SH 15 Amps @ 125VDC Totals:							0.86		0.86		0.86		0.86		0.86		0.86		0.86		0.86		0.86		0.86		0.00		0.00		0.00		0.00		0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 288

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																						
Circuit: DP22-09		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																						
Schematic: 9321-LL-3140 SH 16																																		

Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	20/BFPR2	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	80X1/BFPR2	UNKNOWN / FLOW SWITCH	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-BFP22 BFPR2	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	TD/BFPR2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: 9321-LL-3140 SH 16 Amps @ 125VDC Totals: 0.36 0.36 0.36 0.36 0.36 0.36 0.36 0.36 0.36 0.00 0.00 0.00 0.00 0.00

Circuit: DP22-09 Amps @ 125VDC Totals: 3.84 3.84 3.84 3.84 3.84 3.84 3.84 3.84 3.84 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 289

Scenario: CMP22

				Time Step:		29		30		31		32		33		34		35		36		37								
				Time Step Range:		0:30:00.0 - 1:00:00.0		1:00:00.0 - 1:30:00.0		1:30:00.0 - 1:59:00.0		1:59:00.0 - 1:59:00.1		1:59:00.1 - 1:59:01.0		1:59:01.0 - 1:59:01.1		1:59:01.1 - 1:59:02.0		1:59:02.0 - 1:59:02.1		1:59:02.1 - 2:00:00.0								
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	2/CC1-1	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	2/CC5	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	2/SW3-2	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	2/SW6-2	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	52/EGX	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	52/SWX	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
3	INDLTS-B-RSIL	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60						
Schematic: 225232 Amps @ 125VDC Totals:							0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.54	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 290

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																										
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																										
Circuit:	DP22-11																																					
Schematic:	B225227																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52/CS1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	52/CS2X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/SI1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/SI2X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52/SI3X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
13	INDLTS-A-RSIL	UNKNOWN / INDICATING LIGHT	Z	0.42	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	SI/RL	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225227 Amps @ 125VDC Totals:							0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 291

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	2/CC1	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	2/CC2	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	2/CC4	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	2/SW2	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	2/SW3-1	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	2/SW5	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	2/SW6-1	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	52/CC1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	52/CC2X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	52/CC3X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
Schematic: B225228 Amps @ 125VDC Totals:							0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 292

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																							
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																							
Circuit:	DP22-11																																		
Schematic:	B225229																																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	52/RHR2/X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00													
Schematic: B225229 Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 293

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Circuit:	DP22-11																												
Schematic:	B225231																												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	52/SW1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	52/SW2X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	52/SW3X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	52/SW4X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	52/SW5X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	52/SW6X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
Schematic: B225231 Amps @ 125VDC Totals:							0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 294

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																							
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																							
Circuit:	DP22-11																																		
Schematic:	B225233																																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	RS6X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00													
Schematic: B225233 Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.00	0.00	0.00	0.00	0.00	0.00												

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 295

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																				
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																				
Circuit:	DP22-11																															
Schematic:	B225234																															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	1810/X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
Schematic: B225234 Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.00	0.00	0.00	0.00	0.00										
Circuit: DP22-11 Amps @ 125VDC Totals:							3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	3.15	0.00	0.00	0.00	0.00	0.00											

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 296

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																										
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																										
Circuit:	DP22-12																																					
Schematic:	225188																																					
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	INDLTS-V1629	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	INDLTS-V1630	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	INDLTS-V1631	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	SOV1629	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV1630	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV1631	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
Schematic: 225188 Amps @ 125VDC Totals:							0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 297

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																								
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																								
Circuit:	DP22-12																																			
Schematic:	225209																																			
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
3	INDLTS-LCV1003A	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
3	INDLTS-LCV1003B	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
3	INDLTS-V1609	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	SOV1003A	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1003B	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1609	ASCO / CAT. NO. NP831655V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TD-LCV1003A	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TD-LCV1003B	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 225209 Amps @ 125VDC Totals:							0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 298

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																											
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																											
Circuit:	DP22-12																																						
Schematic:	B209864																																						
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div							
1	INDLTS-V523	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	SOV523	ASCO / CAT. NO. NP8314C28V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
Schematic: B209864 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 299

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																										
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																										
Qty	Device ID	Mfgr/Model	Tp	Amps @ 12S	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
2	INDLTS-RCV018	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1036A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1037A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1038A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1039A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1632	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V1677	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV018	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1036A	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1037A	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1038A	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1039A	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1632	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV1677	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225205 Amps @ 125VDC Totals:							0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.81	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 300

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																			
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	INDLTS-V1036B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	INDLTS-V1037B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	INDLTS-V1038B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	SOV1036B	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	SOV1037B	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	SOV1038B	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	SOV1039B	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: B225207 Amps @ 125VDC Totals:							0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 301

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																						
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																						
Circuit:	DP22-12																																	
Schematic:	UNKNOWN																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	ANNUN-WASTE CP	UNKNOWN / UNKNOWN ANNUNCIAT	P	6.83	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00												
Schematic: UNKNOWN Amps @ 125VDC Totals:							6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	6.83	0.00	0.00	0.00	0.00	0.00												
Circuit: DP22-12 Amps @ 125VDC Totals:							9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	9.31	0.00	0.00	0.00	0.00	0.00												

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 302

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																												
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																												
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	1X/AF3-AFPR3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	20/AFPR3	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
3	INDLTS-AFPR3	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3131 SH 11 Amps @ 125VDC Totals:							0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 303

Scenario: CMP22

Circuit:	DP22-13	Schematic:	9321-LL-3131 SH 11A	Time Step:	29	30	31	32	33	34	35	36	37																																									
					Time Step Range:	0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																																								
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	80X1A/AFPR3	GE / TYPE HGA	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	80X2A/AFPR3	GE / TYPE HGA	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: 9321-LL-3131 SH 11A Amps @ 125VDC Totals:							0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					
Circuit: DP22-13 Amps @ 125VDC Totals:							0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 304

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																			
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																			
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	30/4-TRFOA	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	30/X1-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	30/X2-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	30/X3-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	30/X4-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	30/X5-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	30/X6-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	30/X7-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	30/X8-TRFOA	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	30FX-TRFOA	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	30X1-TRFOA	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	HORN-TRFOA	PANALARM / HORN FOR ANNUNCIATION	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	INDLTS-TRFOA	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	M4-TRFOA	PANALARM / FLASHER RELAY, MODEL 11	Z	0.04	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	REACTOR-FIRST OUT ANN	PANALARM / SERIES 10, MODEL 11	Z	3.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	TURB-FIRST OUT ANN	PANALARM / SERIES 10, MODEL 11	Z	6.83	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: 9321-LL-3135 SH 02 Amps @ 125VDC Totals:				11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Circuit: DP22-14 Amps @ 125VDC Totals:				11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	11.24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 305

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																					
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	33XPCV455C-PCV455C	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
1	INDLTS-PCV455C	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	SOV455C	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
Schematic: 311906 Amps @ 125VDC Totals:								0.26		0.26		0.26		0.26		0.26		0.26		0.26		0.26		0.26		0.00		0.00		0.00		0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 306

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																			
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																			
Circuit:	DP22-15																														
Schematic:	9321-LL-3131 SH 15A																														
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	20-4-SW CNTL VLVS	ASCO / CAT. NO. NPK8316A74V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
1	20-6-SW CNTL VLVS	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
1	20-8-SW CNTL VLVS	ASCO / CAT. NO. 8211D3	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
5	INDLTS-SW CNTL VLVS	UNKNOWN / INDICATING LIGHT	Z	0.16	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60									

Schematic: 9321-LL-3131 SH 15A Amps @ 125VDC Totals: 0.47 0.47 0.47 0.47 0.47 0.47 0.47 0.47 0.47 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 307

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																															
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div															
1	INDLTS-TCV1105	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50															
1	SOV1171-TCV1105	ASCO / CAT. NO. NP831655E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00															
1	SOV5005-TCV1105	ASCO / CAT. NO. 8211D3	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00															
Schematic: B207581 Amps @ 125VDC Totals:							0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00															

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 308

Scenario: CMP22

				Time Step:		29	30	31	32	33	34	35	36	37												
				Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0												
Circuit:	DP22-15																									
Schematic:	B225181																									
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	20-V204B	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	INDLTS-V203	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	INDLTS-V204B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	INDLTS-V246	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	INDLTS-V261A (2)	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	SOV213	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV246	ASCO / CAT. NO. NP831655V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV261A (2)	ASCO / CAT. NO. NP831655V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						

Schematic: B225181 Amps @ 125VDC Totals: 0.63 0.63 0.63 0.63 0.63 0.63 0.63 0.63 0.63 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 309

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Circuit:	DP22-15																													
Schematic:	B225182																													
Qty	Device ID	Mfgr/Model	Trp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-V1870	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
1	INDLTS-V261A (3)	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
1	INDLTS-V310	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
1	SOV261D	ASCO / CAT. NO. NP831655V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SOV1870	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SOV310	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								

Schematic: B225182 Amps @ 125VDC Totals: 0.48 0.48 0.48 0.48 0.48 0.48 0.48 0.48 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 310

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																						
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																						
Circuit:	DP22-15																																	
Schematic:	B225183																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	INDLTS-V839C	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	INDLTS-V839D	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	INDLTS-V839G	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	INDLTS-V839H	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	SOV839C	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV839D	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV839G	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV839H	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						

Schematic: B225183 Amps @ 125VDC Totals: 0.65 0.65 0.65 0.65 0.65 0.65 0.65 0.65 0.65 0.65 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 311

Scenario: CMP22

				Time Step:		29	30	31	32	33	34	35	36	37																								
				Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																								
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	INDLTS-V553B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V553D	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-V560	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	SOV553B	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV553D	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SOV560	ASCO / CAT. NO. LB-83146	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225184 Amps @ 125VDC Totals:							0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 312

Scenario: CMP22

			Time Step:		29	30	31	32	33	34	35	36	37														
			Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0														
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	INDLTS-V890B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	INDLTS-V890D	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	INDLTS-V891B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	INDLTS-V891D	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	INDLTS-V896B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	INDLTS-V896D	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	SOV890B	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	SOV890D	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	SOV891B	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	SOV891D	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	SOV896B	ASCO / CAT. NO. LBX-831614	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	SOV896D	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
Schematic: B225185 Amps @ 125VDC Totals:							0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.00	0.00	0.00	0.00	0.00				

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 313

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																						
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																						
Circuit:	DP22-15																																	
Schematic:	B225191																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	INDLTS-LCV112B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
2	INDLTS-RCV017	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	LCV112B	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV017	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
Schematic: B225191 Amps @ 125VDC Totals:							0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 314

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Circuit:	DP22-15																													
Schematic:	B225192																													
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
2	INDLTS-TCV149	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
1	SOV149-TCV149	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
Schematic: B225192 Amps @ 125VDC Totals:							0.17		0.17		0.17		0.17		0.17		0.17		0.17		0.17		0.00		0.00		0.00		0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 315

Scenario: CMP22

				Time Step:		29	30	31	32	33	34	35	36	37														
				Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0														
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
2	INDLTS-LVC459	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	INDLTS-V1276A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	LVC459	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV1276A	ASCO / CAT. NO. NP8316A55V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
Schematic: B225193 Amps @ 125VDC Totals:							0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.00	0.00	0.00	0.00	0.00	0.00						

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 316

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																																
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	74/DG21-21 DG TROUB	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	74/DG22-22 DG TROUB	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	74/DG23-23 DG TROUB	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B228092 Amps @ 125VDC Totals:							0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08		

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 317

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																					
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																					
Circuit:	DP22-15																																
Schematic:	IP2-S-000089																																
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	JNDLTS-PCV455A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50											
Schematic: IP2-S-000089 Amps @ 125VDC Totals:							0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 318

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Circuit:	DP22-15																												
Schematic:	IP2-S-000329																												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	INDLTS-MCC24A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	INDLTS-MCC27A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	INDLTS-MCC29A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
Schematic: IP2-S-000329 Amps @ 125VDC Totals:							0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Circuit: DP22-15 Amps @ 125VDC Totals:							5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	5.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 319

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	1/30 HP MOTOR-LLV1	UNKNOWN / 1/30 HP MOTOR, LLV1	I	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
2	INDLTS-LLV1	UNKNOWN / INDICATING LIGHT	Z	0.06	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	LRB1-LLV1	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	M/LLV1-LLV1	UNKNOWN / FIELD FOR 1/30 HP MO	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	RES/LLV1-LLV1	UNKNOWN / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	TD/LRB1	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	TD1-LRB1	AGASTAT / 7000 SERIES	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	TD1X/LRB-1	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	TD2X/LRB-1	SCCA / MODEL 1080811, TIME DELA	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	TDX/LRB1	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: 9321-LL-3130 SH 03 Amps @ 125VDC Totals:							0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.00	0.00	0.00	0.00	0.00						
Circuit: DP22-16 Amps @ 125VDC Totals:							0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.89	0.00	0.00	0.00	0.00	0.00					

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 320

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37												
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	40-GEN BU LO	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	40X-GEN BU LO	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	46/1-GEN BU LO	UNKNOWN / UNKNOWN	P	1.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	60-GEN BU LO	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	62/BU	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	62BU1/AUX	AGASTAT / TYPE TR-5	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	63X/BU	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	81BU/1	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	81BU/2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	81BU/62X	AGASTAT / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	86/BU	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00				
1	86X-1/BU	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	INDLTS-GEN BU LO	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50				
1	TR 1-GEN BU LO	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				

Schematic: 9321-LL-3130 SH 06 Amps @ 125VDC Totals: 1.99 1.99 1.99 1.99 1.99 1.99 1.99 1.99 1.99 1.99 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 321

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																														
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																														
Circuit:	DP22-17																																									
Schematic:	A207325																																									
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	86X/BU	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00				
Schematic: A207325 Amps @ 125VDC Totals:							0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
Circuit: DP22-17 Amps @ 125VDC Totals:							1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	1.99	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 322

Scenario: CMP22

				Time Step:																																	
				29	30	31	32	33	34	35	36	37																									
				Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																							
Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div					
1	717-FW-ISOL-B	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00													
1	F/11X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00													
1	F/12X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00													
1	F/13X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00													
1	F/14X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00													
1	F/15X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00													
1	F/16X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00													
3	INDLTS-FW ISOL B	UNKNOWN / 3 TERM MONITORING/	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60													

Schematic: 199B23 Amps @ 125VDC Totals: 0.79 0.79 0.79 0.79 0.79 0.79 0.79 0.79 0.79 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 323

Scenario: CMP22

			Time Step:		29	30	31	32	33	34	35	36	37															
			Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0															
Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	2/SI/D2-B SI ACT	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	74X10-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	INDLTS-A-B SI ACT	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
4	INDLTS-B-B SI ACT	UNKNOWN / 3 TERM MONITORING/	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60								
1	SI/20X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SI/21X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SI/22X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SI/23X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SI/24X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SI/25AX-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SI/25X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SI/26X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SI/27X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SI/28X-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SIA/2-K1-B SI ACT	ELECTROSW / ER-LOR, K1 COIL	Z	1.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00								
1	SIA/2-R-B SI ACT	ELECTROSW / ER-LOR, R COIL	Z	10.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00								
1	SIA/2-T-B SI ACT	ELECTROSW / ER-LOR, T COIL	Z	4.60	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00								
1	SIB2-B SI ACT	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SIM/2-K1-B SI ACT	ELECTROSW / ER-LOR, K1 COIL	Z	1.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00								
1	SIM/2-R-B SI ACT	ELECTROSW / ER-LOR, R COIL	Z	10.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00								
1	SIM/2-T-B SI ACT	ELECTROSW / ER-LOR, T COIL	Z	4.60	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00								

Schematic: 225018 Amps @ 125VDC Totals: 1.41 1.41 1.41 1.41 1.41 1.41 1.41 1.41 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 324

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	AS2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	CA2-1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	CA2-2X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	CA2-3X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	CA2-4X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	CA2-K1	ELECTROSW / ER-LOR, K1 COIL	Z	1.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CA2-R	ELECTROSW / ER-LOR, R COIL	Z	10.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CA2-T	ELECTROSW / ER-LOR, T COIL	Z	4.60	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CB2-1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	CB2-K1	ELECTROSW / ER-LOR, K1 COIL	Z	1.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CB2-R	ELECTROSW / ER-LOR, R COIL	Z	10.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CB2-T	ELECTROSW / ER-LOR, T COIL	Z	4.60	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	JNDLTS-A-CNTM ISOL A	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	JNDLTS-A-CNTM SP	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	JNDLTS-BORN TK LVLB	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	S2-1X	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	S2-K1	ELECTROSW / ER-LOR, K1 COIL	Z	1.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	S2-R	ELECTROSW / ER-LOR, R COIL	Z	10.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	S2-T	ELECTROSW / ER-LOR, T COIL	Z	4.60	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	V2-K1	ELECTROSW / ER-LOR, K1 COIL	Z	1.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	V2-R	ELECTROSW / ER-LOR, R COIL	Z	10.10	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	V2-T	ELECTROSW / ER-LOR, T COIL	Z	4.60	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00

Schematic: 225026 Amps @ 125VDC Totals: 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.78 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 325

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Qty	Device ID	Mfg/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	27/2A-ICS-SG21B2A-U26	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/25A-ICS-SG21B5A-U14	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/2AX11-SG21B2A-U26A	WHSE / TYPE SG, 12V COIL, WITH 4	Z	0.24	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/2AX12-SG21B2A-U26A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/2AX13	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/5AX11-SG21B5A-U14A	WHSE / TYPE SG, 12V COIL, WITH 4	Z	0.24	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/5AX12-SG21B5A-U14A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27/5AX13	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-SG21B2A-U26A (2	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-SG21B5A-U14A (2	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50

Schematic: 9321-LL-3117 SH 02 Amps @ 125VDC Totals: 1.32 1.32 1.32 1.32 1.32 1.32 1.32 1.32 1.32 1.32 1.32 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 326

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	27-61-ICS	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-61/X1	WHSE / TYPE SG, 12V COIL, WITH 4	Z	0.24	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-61/X2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-61/X3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-62-ICS	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-62/X1	WHSE / TYPE SG, 12V COIL, WITH 4	Z	0.24	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-62/X2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-62/X3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-63-ICS	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-63/X1	WHSE / TYPE SG, 12V COIL, WITH 4	Z	0.24	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-63/X2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-63/X3	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	JNDLTS-27-61	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	JNDLTS-27-62	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	JNDLTS-27-63	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3117 SH 22 Amps @ 125VDC Totals:							1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	1.98	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 327

Scenario: CMP22

Circuit:	DP22-18	Time Step:	29	30	31	32	33	34	35	36	37								
Schematic:	9321-LL-3118 SH 02	Time Step Range:	0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0								

Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI		Div		NI		Div		NI		Div		NI		Div		NI		Div		NI		Div	
							NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	2/11/11X-SG22B6A/3A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	2/12-SG22B6A/3A	AGASTAT / AGA 2414	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	2/13-SG22B6A/3A	AGASTAT / AGA 2412	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	27/1/3A-ICS-SG22B3A-U1A	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	27/1/6A-ICS-SG22B6A-U13	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	27/3A/X1-SG22B3A-U1A	WHSE / TYPE SG, 12V COIL, WITH 4	Z	0.24	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	27/3A/X2-SG22B3A-U1A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	27/3A/X3-SG22B3A-U1A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	27/3A/X4-SG22B3A-U1A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	27/6A/X1-SG22B6A-U13A	WHSE / TYPE SG, 12V COIL, WITH 4	Z	0.24	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	27/6A/X2-SG22B6A-U13A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	27/6A/X3-SG22B6A-U13A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	27/8A/X4-SG22B6A-U13A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	3/11-SG22B6A/3A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	3/12-SG22B6A/3A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	3/13-SG22B6A/3A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	3/13A-SG22B6A/3A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	3/14-SG22B6A/3A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	3/14A-SG22B6A/3A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	3/15-SG22B6A/3A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	5/12-SG22B6A/3A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	5/13-SG22B6A/3A	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	86/3A/O-SG22B3A-U1A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	86/3A/R-SG22B3A-U1A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	86/6A/O-SG22B6A-U13A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	86/6A/R-SG22B6A-U13A	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	INDLTS-A-SG22B3A-U1A	UNKNOWN / LIGHT W/400K OHM RE	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50										
1	INDLTS-A-SG22B6A-U13A	UNKNOWN / LIGHT W/400K OHM RE	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50										
1	INDLTS-SG22B3A-U1A (2)	UNKNOWN / LIGHT W/200K OHM RE	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50										
1	INDLTS-SG22B6A-U13A (2)	UNKNOWN / LIGHT W/200K OHM RE	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50										
1	INDLTS-SG22B6A/3A	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50										

Schematic: 9321-LL-3118 SH 02 Amps @ 125VDC Totals: 3.18 3.18 3.18 3.18 3.18 3.18 3.18 3.18 3.18 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 328

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																												
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																												
Circuit:	DP22-18																																							
Schematic:	9321-LL-3118 SH 20																																							
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	1X/BFPT2-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	71/1X-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	71/2X-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	71/3X-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	71/4X-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	BFP2-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	BFPB-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	BFPB/2-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-ABFP 21/23	UNKNOWN / 3 TERM MONITORING/	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50

Schematic: 9321-LL-3118 SH 20 Amps @ 125VDC Totals: 0.85 0.85 0.85 0.85 0.85 0.85 0.85 0.85 0.85 0.85 0.85 0.85 0.85 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 329

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	R1-ABFP 21/23	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
Schematic: 9321-LL-3118 SH 20A Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm -

Battery: 22

Continued from Page 330

Scenario: CMP22

Circuit:	DP22-18	Schematic:	9321-LL-3131 SH 21	Time Step:		29	30	31	32	33	34	35	36	37																
				Time Step Range:	0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Qty	Device ID	Mfgnr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	20/21-2	ASCO / CAT. NO. WJNP831666V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	20/21-4	ASCO / CAT. NO. WJNP8316E34V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	20/22-2	ASCO / CAT. NO. WJNP831666V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	20/22-4	ASCO / CAT. NO. WJNP8316E34V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	20/23-2	ASCO / CAT. NO. WJNP831666V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	20/23-4	ASCO / CAT. NO. WJNP8316E34V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	20/24-2	ASCO / CAT. NO. WJNP831666V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	20/24-4	ASCO / CAT. NO. WJNP8316E34V	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	74X8	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	INDLTS-MS STOP VLVS (2)	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
Schematic: 9321-LL-3131 SH 21 Amps @ 125VDC Totals:							1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	1.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 331

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																				
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																				
Qty	Device ID	Mfg/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	2/TD2/SL2-MS ISOL B	AGASTAT / 7000 SERIES	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	74X2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	74X4	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	74X6	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
3	JNDLTS-A-MS ISOL B	UNKNOWN / 3 TERM MONITORING/	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	MS11-MS ISOL B	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	MS12-MS ISOL B	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	MS13-MS ISOL B	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	MS14-MS ISOL B	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	SL2	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TR2-MS ISOL B	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	TR2-X-MS ISOL B	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: A241685 Amps @ 125VDC Totals: 1.16 1.16 1.16 1.16 1.16 1.16 1.16 1.16 1.16 0.00 0.00 0.00 0.00 0.00

Circuit: DP22-18 Amps @ 125VDC Totals: 12.81 12.81 12.81 12.81 12.81 12.81 12.81 12.81 12.81 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 332

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	20/ASB-T/G A-S TRIP	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63X1/AST3-T/G A-S TRIP	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	63X2/AST3-T/G A-S TRIP	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	F15X1-T/G A-S TRIP	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-A-T/G A-S TRIP	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-T/G A-S TRIP	UNKNOWN / NEON	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3130 SH 02B Amps @ 125VDC Totals:							0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.41	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 333

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	20/DV1B	ASCO / CAT. NO. FT8316E36	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	20/DV2B	ASCO / CAT. NO. FT8316E36	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	20/DV3B	ASCO / CAT. NO. FT8316E36	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	20/DV4B	ASCO / CAT. NO. FT8316E36	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	20/DV5B	ASCO / CAT. NO. FT8316E36	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	20/DV6B	ASCO / CAT. NO. FT8316E36	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	ASTX-LP STM DMPII	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
7	INDLTS-A-LP STM DMPII	UNKNOWN / INDICATING LIGHT	Z	0.22	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60										
3	INDLTS-B-LP STM DMPII	UNKNOWN / 3 TERM MONITORING/	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60										
Schematic: A207325 Amps @ 125VDC Totals:							1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	1.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Circuit: DP22-19 Amps @ 125VDC Totals:							1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	1.61	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 334

Scenario: CMP22

						Time Step:		29	30	31	32	33	34	35	36	37												
						Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	74/22-TB OS TRIP B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	INDLTS-B-TB OS TRIP B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
Schematic: 307670 Amps @ 125VDC Totals:							0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.00	0.00	0.00	0.00	0.00							

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 335

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																													
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																													
Qty	Device ID	Mfrgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	20/GLLB	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20/GLRB	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20/GULB	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20/GURB	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20/SLLB	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20/SLRB	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20/SULB	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20/SURB	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20X/GLLB	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20X/GLRB	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20X/GULB	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20X/GURB	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20X/SLLB	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20X/SLRB	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20X/SULB	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	20X/SURB	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
5	INDLTS-A-TB OS TRIP B	UNKNOWN / 3 TERM MONITORING/	Z	0.16	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60																	
1	INDLTS-TB OS TRIP B	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50																	
1	LTB1-TB OS TRIP B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	LTB2-TB OS TRIP B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	R/ROP2	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	VB1-TB OS TRIP B	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	VB2-TB OS TRIP B	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	VB3-TB OS TRIP B	UNKNOWN / UNKNOWN W/ DIODE II	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	VB4-TB OS TRIP B	WHSE / TYPE ARD4S	Z	0.12	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	VTB1-TB OS TRIP B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	VTB2-TB OS TRIP B	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
1	VTB3-TB OS TRIP B	SIEMENS / CODE 82E TYPE 3TH4	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																	
Schematic: A236330 Amps @ 125VDC Totals:				3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	3.18	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Circuit: DP22-20 Amps @ 125VDC Totals:				3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	3.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 336

Scenario: CMP22

						Time Step: 29		30		31		32		33		34		35		36		37													
						Time Step Range:		0:30:00.0 - 1:00:00.0		1:00:00.0 - 1:30:00.0		1:30:00.0 - 1:59:00.0		1:59:00.0 - 1:59:00.1		1:59:01.0 - 1:59:01.1		1:59:01.1 - 1:59:02.0		1:59:02.0 - 1:59:02.1		1:59:02.1 - 2:00:00.0													
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div					
1	INVERTER EGA6	TOPAZ / 1 KVA INVERTER	P	10.00	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00											
Schematic: A206900 Amps @ 125VDC Totals:							10.00		10.00		10.00		10.00		10.00		10.00		10.00		10.00		10.00		0.00		0.00		0.00		0.00		0.00		
Circuit: DP22A-01 Amps @ 125VDC Totals:							10.00		10.00		10.00		10.00		10.00		10.00		10.00		10.00		10.00		10.00		0.00		0.00		0.00		0.00		0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 337

Scenario: CMP22

				Time Step:		29		30		31		32		33		34		35		36		37												
				Time Step Range:		0:30:00.0 - 1:00:00.0		1:00:00.0 - 1:30:00.0		1:30:00.0 - 1:59:00.0		1:59:00.0 - 1:59:00.1		1:59:00.1 - 1:59:01.0		1:59:01.0 - 1:59:01.1		1:59:01.1 - 1:59:02.0		1:59:02.0 - 1:59:02.1		1:59:02.1 - 2:00:00.0												
Circuit:	DP22A-02																																	
Schematic:	206799																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	OPXB-RCS OPS	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	OPXB1-RCS OPS	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	OPXB2-RCS OPS	WHSE / BFD	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: 206799 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
Circuit: DP22A-02 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 338

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Circuit:	DP22A-03																													
Schematic:	B235113																													
Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	SOV1311	ASCO / CAT. NO. NP831665E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	TC1113S/X-V1311	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
Schematic: B235113 Amps @ 125VDC Totals:							0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.00	0.00	0.00	0.00	0.00								
Circuit: DP22A-03 Amps @ 125VDC Totals:							0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.00	0.00	0.00	0.00	0.00								

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 339

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:01.0 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Circuit:	DP22AA-01																												
Schematic:	A208548																												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	INDLTS-SOVE-5	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	INDLTS-SOVEW-2	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	SOVE-5	ASCO / CAT. NO. NP831655E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	SOVEW-2	ASCO / CAT. NO. 206-381-3FR	Z	0.28	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							

Schematic: A208548 Amps @ 125VDC Totals: 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.00 0.00 0.00 0.00 0.00

Circuit: DP22AA-01 Amps @ 125VDC Totals: 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 340

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																				
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																				
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	INDLTS-SOV3401	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	INDLTS-SOV3402	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	INDLTS-SOV3412	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	INDLTS-SOV3413	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50		
1	SOV3401	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV3402	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV3412	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	SOV3413	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
Schematic: A208551 Amps @ 125VDC Totals:							0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
Circuit: DP22AA-02 Amps @ 125VDC Totals:							0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.38	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 341

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																									
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																									
Circuit: DP22AA-03		Schematic: A208551																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	JNDLTS-V3403	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	JNDLTS-V3404	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	JNDLTS-V3405	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	JNDLTS-V3406	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	
1	SOV3403	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	SOV3404	UNKNOWN / UNKNOWN	Z	0.15	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	SOV3405	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	SOV3406	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: A208551 Amps @ 125VDC Totals:				0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	
Circuit: DP22AA-03 Amps @ 125VDC Totals:				0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 342

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																			
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																			
Circuit:	DP22AA-04																														
Schematic:	A208551																														
Qty	Device ID	Mfr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INDLTS-V3407	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	INDLTS-V3408	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	INDLTS-V3409	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	INDLTS-V3410	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	INDLTS-V3411	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	SOV3407	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
1	SOV3408	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
1	SOV3409	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
1	SOV3410	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
1	SOV3411	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
Schematic: A208551 Amps @ 125VDC Totals:							0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Circuit: DP22AA-04 Amps @ 125VDC Totals:							0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.48	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 343

Scenario: CMP22

				Time Step:		29		30		31		32		33		34		35		36		37																		
				Time Step Range:		0:30:00.0 - 1:00:00.0		1:00:00.0 - 1:30:00.0		1:30:00.0 - 1:59:00.0		1:59:00.0 - 1:59:01.0		1:59:01.0 - 1:59:01.1		1:59:01.1 - 1:59:02.0		1:59:02.0 - 1:59:02.1		1:59:02.1 - 2:00:00.0																				
Qty	Device ID	Mfrgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div								
1	INDLTS-A-V5019	UNKNOWN / LIGHT W/ 2500 OHM RE	Z	0.05	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
1	INDLTS-A-V5023	UNKNOWN / LIGHT W/ 2500 OHM RE	Z	0.05	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
1	INDLTS-V5019	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
1	INDLTS-V5023	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50								
1	SOV5019	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	SOV5023	VALCOR / V526 Series	Z	0.08	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
Schematic: IP2-S-000092 Amps @ 125VDC Totals:							0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.00	0.00	0.00	0.00	0.00															
Circuit: DP22AA-05 Amps @ 125VDC Totals:							0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.00	0.00	0.00	0.00	0.00														

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 344

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Circuit:	DP22AA-06																												
Schematic:	B209543																												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	INDLTS-V5046	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	INDLTS-V5050	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	SOV5046	ASCO / CAT. NO. NP8316A54E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	SOV5050	ASCO / CAT. NO. NP8320A187E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
Schematic: B209543 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 345

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																						
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																						
Circuit:	DP22AA-06																																	
Schematic:	B209545																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div						
1	INDLTS-V5047	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	INDLTS-V5051	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50						
1	SOV5047	ASCO / CAT. NO. NP8316A54E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
1	SOV5051	ASCO / CAT. NO. NP8320A187E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00						
Schematic: B209545 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 346

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Circuit:	DP22AA-06																												
Schematic:	B209546																												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	INDLTS-V5048	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	INDLTS-V5052	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50							
1	SOV5048	ASCO / CAT. NO. NP8316A54E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
1	SOV5052	ASCO / CAT. NO. NP8320A187E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00							
Schematic: B209546 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 347

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																			
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																			
Circuit:	DP22AA-06																														
Schematic:	B209547																														
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INDLTS-V5049	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	INDLTS-V5053	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50									
1	SOV5049	ASCO / CAT. NO. NP8316A54E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
1	SOV5053	ASCO / CAT. NO. NP8320A187E	Z	0.14	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
Schematic: B209547 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.00	0.00	0.00	0.00	0.00									
Circuit: DP22AA-06 Amps @ 125VDC Totals:							1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	1.24	0.00	0.00	0.00	0.00	0.00									

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 348

Scenario: CMP22

Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	Time Step: 29		Time Step: 30		Time Step: 31		Time Step: 32		Time Step: 33		Time Step: 34		Time Step: 35		Time Step: 36		Time Step: 37											
							NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	33X/3518-EPFP3518	WHSE / Nbfd	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
Schematic: 322462 Amps @ 125VDC Totals:							0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.00	0.00	0.00	0.00	0.00	0.00									
Circuit: DP22AA-07 Amps @ 125VDC Totals:							0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.00	0.00	0.00	0.00	0.00								

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 349

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																								
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																								
Circuit:	PP22-02-PG5																																			
Schematic:	A251037																																			
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	LP-213	UNKNOWN / EMERGENCY LTG PAN Z	Z	57.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00														
Schematic: A251037 Amps @ 125VDC Totals:							57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	0.00	0.00	0.00	0.00	0.00												
Circuit: PP22-02-PG5 Amps @ 125VDC Totals:							57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	57.20	0.00	0.00	0.00	0.00	0.00											

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 350

Scenario: CMP22

		Time Step:		29		30		31		32		33		34		35		36		37													
		Time Step Range:		0:30:00.0 - 1:00:00.0		1:00:00.0 - 1:30:00.0		1:30:00.0 - 1:59:00.0		1:59:00.0 - 1:59:01.1		1:59:01.1 - 1:59:01.0		1:59:01.1 - 1:59:01.1		1:59:01.0 - 1:59:02.0		1:59:02.0 - 1:59:02.1		1:59:02.1 - 2:00:00.0													
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	GEN REG INV1	UNKNOWN / GEN REG. INVERTER	P	2.69	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00											
Schematic: IP2--S-000054 Amps @ 125VDC Totals:							2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	0.00	0.00	0.00	0.00	0.00										
Circuit: PP22-07 Amps @ 125VDC Totals:							2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	2.69	0.00	0.00	0.00	0.00	0.00	0.00									

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 351

Scenario: CMP22

Circuit:	PP22-09	Time Step:	29	30	31	32	33	34	35	36	37						
Schematic:	9321-LL-3114 SH 02	Time Step Range:	0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0						

Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-UT3	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-UT3	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-UT3	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-UT3	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-UT3 (1)	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60

Schematic: 9321-LL-3114 SH 02 Amps @ 125VDC Totals: 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 352

Scenario: CMP22

Circuit:	PP22-09	Schematic:	9321-LL-3114 SH 03	Time Step:	29	30	31	32	33	34	35	36	37																									
					Time Step Range:	0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																								
Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	52M-UT3-ST6	WHSE / M-SPRING CHARGING MTR	P	5.50	20.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52M-UT3-ST6-I	WHSE / M-SPRING CHARGING MTR	P	5.50	20.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52MR-UT3-ST6	UNKNOWN / MR- MECH RELEASE R	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52MX-UT3-ST6	UNKNOWN / MX-CHARGING MTR AU	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-UT3-ST6	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-UT3-ST6	WHSE / 75DH500 Stored Energy	Z	5.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-UT3-ST6	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-UT3-ST6	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60

Schematic: 9321-LL-3114 SH 03 Amps @ 125VDC Totals: 0.09 0.09 0.09 0.09 0.09 0.09 0.09 0.09 5.14 25.14 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 353

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																												
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																												
Circuit:	PP22-09																																							
Schematic:	9321-LL-3114 SH 04																																							
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52CC-UT4	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52TC-UT4	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-UT4	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-UT4	UNKNOWN / Y - CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-UT4 (1)	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 04 Amps @ 125VDC Totals:							0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 354

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																										
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																										
Qty	Device ID	Mfgr/Model	Typ	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52M-UT4-ST6	WHSE / M-SPRING CHARGING MTR	P	5.50	20.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52M-UT4-ST6-I	WHSE / M-SPRING CHARGING MTR	P	5.50	20.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52MR-UT4-ST6	UNKNOWN / MR- MECH RELEASE R	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52MX-UT4-ST6	UNKNOWN / MX-CHARGING MTR AL	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-UT4-ST6	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-UT4-ST6	WHSE / 75DH500 Stored Energy	Z	5.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-UT4-ST6	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-UT4-ST6	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 05 Amps @ 125VDC Totals:							0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 355

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																						
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																						
Circuit:	PP22-09																																	
Schematic:	9321-LL-3114 SH 06																																	
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-ST6	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-ST6	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-ST6	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-ST6	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-ST6 (1)	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 06 Amps @ 125VDC Totals:							0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 356

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Circuit:	PP22-09																												
Schematic:	9321-LL-3114 SH 07																												
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	52CC-RCP23	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
1	52TC-RCP23	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
1	52X-RCP23	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
1	52Y-RCP23	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
3	INDLTS-RCP23	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	
1	S4-RCP23	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
Schematic: 9321-LL-3114 SH 07 Amps @ 125VDC Totals:							0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 357

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37														
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0														
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	52CC-HDP21	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-HDP21	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-HDP21	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-HDP21	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-HDP21	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 09 Amps @ 125VDC Totals:							0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 358

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																				
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																				
Circuit:	PP22-09																															
Schematic:	9321-LL-3114 SH 10																															
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-SS3	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-SS3	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-SS3	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-SS3	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-SS3	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 10 Amps @ 125VDC Totals:							0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 359

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Circuit:	PP22-09																													
Schematic:	9321-LL-3114 SH 11																													
Qty	Device ID	Mfg/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-RCP22	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-RCP22	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-RCP22	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-RCP22	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
3	INDLTS-RCP22	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
1	S9-RCP22	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: 9321-LL-3114 SH 11 Amps @ 125VDC Totals: 0.16 0.16 0.16 0.16 0.16 0.16 0.16 0.16 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 360

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																										
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																										
Circuit:	PP22-09																																					
Schematic:	9321-LL-3114 SH 12																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 126	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	52CC-CP23	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-CP23	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-CP23	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52Y-CP23	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	CPAS/23-CP23	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	INDLTS-A-CP23	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
3	INDLTS-CP23	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60
Schematic: 9321-LL-3114 SH 12 Amps @ 126VDC Totals:							0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18	0.18

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 361

Scenario: CMP22

Circuit:	PP22-09	Time Step:	29	30	31	32	33	34	35	36	37						
Schematic:	9321-LL-3114 SH 14	Time Step Range:	0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0						

Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div							
1	52CC-HDP22	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00													
1	52TC-HDP22	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00													
1	52X-HDP22	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00													
1	52Y-HDP22	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00													
3	INDLTS-HDP22	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60													

Schematic: 9321-LL-3114 SH 14 Amps @ 125VDC Totals: 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.06 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 362

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																										
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																										
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div
1	62/ST6	UNKNOWN / TD-53 TIME DELAY REL	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	62/UT3	UNKNOWN / TD-53 TIME DELAY REL	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	62/UT4	UNKNOWN / TD-53 TIME DELAY REL	Z	0.07	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	86/ST6	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	86/UT3	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	86/UT4	WHSE / TYPE WL	Z	20.16	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	INDLTS-N-ST6	UNKNOWN / NE-2, NEON LAMP, 200	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-UT3	UNKNOWN / NE-2, NEON LAMP, 200	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-N-UT4	UNKNOWN / NE-2, NEON LAMP, 200	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-ST6 (2)	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-UT3 (2)	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-UT4 (2)	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 9321-LL-3114 SH 17 Amps @ 125VDC Totals:							0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.31

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 363

Scenario: CMP22

				Time Step:		29		30		31		32		33		34		35		36		37												
				Time Step Range:		0:30:00.0 - 1:00:00.0		1:00:00.0 - 1:30:00.0		1:30:00.0 - 1:59:00.0		1:59:00.0 - 1:59:01.1		1:59:01.1 - 1:59:01.0		1:59:01.1 - 1:59:02.0		1:59:02.0 - 1:59:02.1		1:59:02.1 - 2:00:00.0														
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	71X/HDT	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
1	86X/ST6-OP	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
.1	86X/ST6-RESET	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00				
Schematic: 9321-LL-3114 SH 18 Amps @ 125VDC Totals:							0.15		0.15		0.15		0.15		0.15		0.15		0.15		0.15		0.15		0.00		0.00		0.00		0.00		0.00	

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 364

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																							
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																							
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	52CC-GT26	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	1.00	N	0.00	N	0.00													
1	52TC-GT26	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00													
1	52X-GT26	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	1.00	N	1.00	N	0.00	N	0.00													
1	52Y-GT26	UNKNOWN / Y- CUT-OFF RELAY(69	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	1.00	N	1.00	N	0.00	N	0.00													
4	JNDLTS-GT26	UNKNOWN / INDICATING LIGHT	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60													
Schematic: 9321-LL-3114 SH 19 Amps @ 125VDC Totals:							0.08	0.08	0.08	0.08	0.08	0.13	68.63	0.08	0.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 365

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																										
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																										
Circuit:	PP22-09																																					
Schematic:	9321-LL-3114 SH 20																																					
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	51N-SS22RW3	WHSE / 51N OVERCURRENT RELAY	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00								
1	52CC-SS22RW3	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00								
1	52TC-SS22RW3	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00								
1	52X-SS22RW3	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00								
1	52Y-SS22RW3	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00								
3	INDLTS-SS22RW3	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60								

Schematic: 9321-LL-3114 SH 20 Amps @ 125VDC Totals: 0.26 0.26 0.26 0.26 0.26 0.26 0.26 0.26 0.26 0.26 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 366

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																					
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																					
Circuit:	PP22-09																																
Schematic:	9321-LL-3114 SH 16																																
Qty	Device ID	Mfr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	52CC-SS6	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
1	52TC-SS6	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
1	52X-SS6	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
1	52Y-SS6	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	
3	INDLTS-SS6	UNKNOWN / INDICATING LIGHT	Z	0.10	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	
Schematic: 9321-LL-3114 SH 16 Amps @ 125VDC Totals:							0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 367

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37													
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0													
Circuit:	PP22-09																								
Schematic:	B225123																								
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	
1	27-3/62-BUS 3 UV/UF	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	27-3/62X-BUS 3 UV/UF	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	27-3/1CS-BUS 3 UV/UF	WHSE / CV	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	27-3/X1-BUS 3 UV/UF	WHSE / MG-6, 24 V, W/ 300 OHM RE	Z	0.32	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	27-3/X2-BUS 3 UV/UF	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	27-3/X3-BUS 3 UV/UF	WHSE / SG	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	81-3/1CS-BUS 3 UV/UF	WHSE / KF	Z	0.20	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	81-3/X1-BUS 3 UV/UF	WHSE / MG-6	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	
1	RES-BUS 3 UV/UF	UNKNOWN / UNKNOWN	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	

Schematic: B225123 Amps @ 125VDC Totals: 1.10 1.10 1.10 1.10 1.10 1.10 1.10 1.10 1.10 1.10 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 369

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																														
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																														
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	27-3/62A-BUS 3 UV/UF	AGASTAT / 2122DH39YC	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00		
1	27-3A-BUS 3 UV/UF	ABB / TYPE 27N, SERIES 411T, #411	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-4/62A-BUS 4 UV/UF	AGASTAT / 2122DH39YC	Z	0.06	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	27-4A-BUS 4 UV/UF	ABB / TYPE 27N, SERIES 411T, #411	Z	0.05	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
Schematic: B225173 Amps @ 125VDC Totals:							0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 372

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																																
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																																
Qty	Device ID	Mfg/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div										
1	43/CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	49A/T-CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	49A/X-CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	49C/T-CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	49C/X-CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	52CC-CWP26	WHSE / 75DH500-CC	Z	68.50	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00										
1	52TC-CWP26	WHSE / 75DH500-TC	Z	4.15	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00										
1	52X-CWP26	WHSE / 75DH500 Solenoid Operated	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00										
1	52Y-CWP26	UNKNOWN / Y- CUT-OFF RELAY(6.9	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00										
1	62/CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	62FLT/CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
1	63AR/CWP26	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00										
4	JNDLTS-CWP26	UNKNOWN / INDICATING LIGHT	Z	0.13	0.00	On	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60	N	0.60												
Schematic: B231671 Amps @ 125VDC Totals:							0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.91	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
Circuit: PP22-09 Amps @ 125VDC Totals:							7.03	7.03	7.03	7.03	7.03	7.03	7.09	75.59	12.09	32.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 373

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																		
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																		
Circuit:	PP22-10																													
Schematic:	1986M03453																													
Qty	Device ID	Mfgr/Model	Tr	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div		
1	53A-GEN EXC BKR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	53B-GEN EXC BKR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	53TD-GEN EXC BKR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	53X-GEN EXC BKR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	FILTER 53A-GEN EXC BKR	UNKNOWN / FILTER FOR GEN FF R	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	FILTER 53B-GEN EXC BKR	UNKNOWN / FILTER FOR GEN FF R	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	FILTER 53TD-GEN EXC BKR	UNKNOWN / FILTER FOR GEN FF R	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	FILTER 53X-GEN EXC BKR	UNKNOWN / FILTER FOR GEN FF R	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00

Schematic: 1986M03453 Amps @ 125VDC Totals: 0.82 0.82 0.82 0.82 0.82 0.82 0.82 0.82 0.82 0.00 0.00 0.00 0.00 0.00

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 376

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																										
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																										
Circuit:	PP22-10																																					
Schematic:	9321-LL-3130 SH 05																																					
Qty	Device ID	Mfr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	59T/TDPU-GEN EXC BKR	UNKNOWN / UNKNOWN	Z	0.10	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00																
Schematic: 9321-LL-3130 SH 05 Amps @ 125VDC Totals:							0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.00	0.00	0.00	0.00	0.00															
Circuit: PP22-10 Amps @ 125VDC Totals:							2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	2.03	0.00	0.00	0.00	0.00	0.00															

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 377

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																														
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																														
Circuit:	PP22-11																																									
Schematic:	110E073 SH 11																																									
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div				
1	52CC-BYA	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00		
1	52CC-RTB	WHSE / DB-50-CC	Z	12.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52R-RTB	UNKNOWN / R- 52R, RESET Rx Trip	Z	0.03	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00
1	52TC-BYA	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52TC-RTB	WHSE / DB-50-TC	Z	2.00	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-BYA	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	52X-RTB	WHSE / X- CLOSING RELAY (0.48kV)	Z	0.03	0.00	On	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00	N	0.00
1	INDLTS-A-RTB	UNKNOWN / INDICATING LIGHT	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-B-RTB	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
1	INDLTS-BYA	UNKNOWN / LIGHT WITH UNKNOWN	Z	0.03	0.00	On	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50	N	0.50
Schematic: 110E073 SH 11 Amps @ 125VDC Totals:				0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08		
Circuit: PP22-11 Amps @ 125VDC Totals:				0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 378

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																	
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																	
Circuit:	PP22-14																												
Schematic:	011D13784																												
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INVERTER PA	SCI / 10 KVA INV, SV12100/TS100NB	P	27.46	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00									
Schematic: 011D13784 Amps @ 125VDC Totals:							27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	0.00	0.00	0.00	0.00	0.00						
Circuit: PP22-14 Amps @ 125VDC Totals:							27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	27.46	0.00	0.00	0.00	0.00	0.00						

Load Tabulation

Generation Date: 07/15/2014 06:22 pm

Battery: 22

Continued from Page 379

Scenario: CMP22

		Time Step:		29	30	31	32	33	34	35	36	37																					
		Time Step Range:		0:30:00.0 - 1:00:00.0	1:00:00.0 - 1:30:00.0	1:30:00.0 - 1:59:00.0	1:59:00.0 - 1:59:00.1	1:59:00.1 - 1:59:01.0	1:59:01.0 - 1:59:01.1	1:59:01.1 - 1:59:02.0	1:59:02.0 - 1:59:02.1	1:59:02.1 - 2:00:00.0																					
Circuit:	PP22-15																																
Schematic:	1975M1487																																
Qty	Device ID	Mfgr/Model	Tp	Amps @ 125	Inrush	Tog	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div	NI	Div			
1	INVERTER 22	SCI / INV 22	P	46.57	0.00	On	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00	N	1.00													
Schematic: 1975M1487 Amps @ 125VDC Totals:							46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	0.00	0.00	0.00	0.00	0.00											
Circuit: PP22-15 Amps @ 125VDC Totals:							46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	46.57	0.00	0.00	0.00	0.00	0.00											

**Attachment K
Cell Sizing Worksheet**

By: _____ **Date:** _____

Check: _____ **Date:** _____

Cell Sizing Worksheet

Generation Date: 07/16/2014 05:35 pm

Battery: 22

Lowest Expected Electrolyte Temp:	59 F	Minimum Cell Voltage:	1.86 VPC	Cell Mfg:	EXIDE	Sized By:
(1)	(2)	(3)	(4)	(5)	(6)	(7)
Period	Load (amperes)	Change in Load (amperes)	Duration of Period (minutes)	Time to End of Section (minutes)	Capacity At T Min Rate Amps/Pos (RT)	Required Section Size Positive Plates (3)/(6)

Section 1 - First 1 Periods Only - If A2 is greater than A1, go to Section A2.

1	A1 = 316.29	A1 - A0 = 316.29	M1 = 1	T = M1 +...+ M1 = 1	105.76	2.99
Sec 1 Total:						2.99

Section 3 - First 3 Periods Only - If A4 is greater than A3, go to Section A4.

1	A1 = 316.29	A1 - A0 = 316.29	M1 = 1	T = M1 +...+ M3 = 21	82.24	3.85
2	A2 = 242.3	A2 - A1 = -73.99	M2 = 19	T = M2 +...+ M3 = 20	83.10	-0.89
3	A3 = 263.64	A3 - A2 = 21.34	M3 = 1	T = M3 +...+ M3 = 1	105.76	0.20
Sec 3 Total:						3.16

Section 4 - First 4 Periods Only - If A5 is greater than A4, go to Section A5.

1	A1 = 316.29	A1 - A0 = 316.29	M1 = 1	T = M1 +...+ M4 = 30	75.86	4.17
2	A2 = 242.3	A2 - A1 = -73.99	M2 = 19	T = M2 +...+ M4 = 29	76.52	-0.97
3	A3 = 263.64	A3 - A2 = 21.34	M3 = 1	T = M3 +...+ M4 = 10	93.30	0.23
4	A4 = 242.22	A4 - A3 = -21.42	M4 = 9	T = M4 +...+ M4 = 9	94.50	-0.23
Sec 4 Total:						3.2

Section 6 - First 6 Periods Only - If A7 is greater than A6, go to Section A7.

1	A1 = 316.29	A1 - A0 = 316.29	M1 = 1	T = M1 +...+ M6 = 90	50.93	6.21
2	A2 = 242.3	A2 - A1 = -73.99	M2 = 19	T = M2 +...+ M6 = 89	51.21	-1.44
3	A3 = 263.64	A3 - A2 = 21.34	M3 = 1	T = M3 +...+ M6 = 70	57.26	0.37
4	A4 = 242.22	A4 - A3 = -21.42	M4 = 9	T = M4 +...+ M6 = 69	57.61	-0.37
5	A5 = 241.41	A5 - A4 = -0.81	M5 = 30	T = M5 +...+ M6 = 60	60.91	-0.01
6	A6 = 241.79	A6 - A5 = 0.38	M6 = 30	T = M6 +...+ M6 = 30	75.86	0.01
Sec 6 Total:						4.77

Section 8 - First 8 Periods Only - If A9 is greater than A8, go to Section A9.

1	A1 = 316.29	A1 - A0 = 316.29	M1 = 1	T = M1 +...+ M8 = 120	44.05	7.18
2	A2 = 242.3	A2 - A1 = -73.99	M2 = 19	T = M2 +...+ M8 = 119	44.23	-1.67
3	A3 = 263.64	A3 - A2 = 21.34	M3 = 1	T = M3 +...+ M8 = 100	48.29	0.44
4	A4 = 242.22	A4 - A3 = -21.42	M4 = 9	T = M4 +...+ M8 = 99	48.54	-0.44
5	A5 = 241.41	A5 - A4 = -0.81	M5 = 30	T = M5 +...+ M8 = 90	50.93	-0.02
6	A6 = 241.79	A6 - A5 = 0.38	M6 = 30	T = M6 +...+ M8 = 60	60.91	0.01
7	A7 = 241.49	A7 - A6 = -0.3	M7 = 29	T = M7 +...+ M8 = 30	75.86	-0.00
8	A8 = 310.15	A8 - A7 = 68.66	M8 = 1	T = M8 +...+ M8 = 1	105.76	0.65
Sec 8 Total:						6.15

Maximum Section Size (8) 6.15 + Random Section Size (9) 0.00 = Uncorrected Size - (US) (10) 6.15
 US (11) 6.15 x Temp. Corr. (12) 1.118 x Design Margin (13) 1.00 x Aging Factor (14) 1.25 = (15) 8.59
 When the cell size (15) is greater than the standard cell size, the next larger cell is required.
 Required cell size (16) 9 Positive Plates. Therefore cell (17) _____ is required.

**Attachment L
Voltage Profile**

By: _____ Date: _____
Check: _____ Date: _____

Voltage Profile

Generation Date: 07/16/2014 05:39 pm

Battery: 22

Load (amperes)	Corrected Load (amps)	Time (min.)	AMP-HRS Removed	AMP-HR/ Pos Plt	AMPS/ Pos Plt	Cell Voltage (Volts)	Terminal Voltage (Volts)
316.29	442.01	1	7.37	0.67	40.18	* 1.984	115.08
242.30	338.62	2	13.01	1.18	30.78	* 2.000	116.00
242.30	338.62	3	18.65	1.70	30.78	2.000	116.00
242.30	338.62	4	24.30	2.21	30.78	1.999	115.95
242.30	338.62	5	29.94	2.72	30.78	1.998	115.87
242.30	338.62	6	35.58	3.23	30.78	1.997	115.80
242.30	338.62	7	41.23	3.75	30.78	1.995	115.72
242.30	338.62	8	46.87	4.26	30.78	1.994	115.65
242.30	338.62	9	52.52	4.77	30.78	1.993	115.57
242.30	338.62	10	58.16	5.29	30.78	1.991	115.49
242.30	338.62	11	63.80	5.80	30.78	* 1.990	115.41
242.30	338.62	12	69.45	6.31	30.78	1.989	115.35
242.30	338.62	13	75.09	6.83	30.78	1.988	115.29
242.30	338.62	14	80.73	7.34	30.78	* 1.987	115.23
242.30	338.62	15	86.38	7.85	30.78	* 1.986	115.20
242.30	338.62	16	92.02	8.37	30.78	1.985	115.16
242.30	338.62	17	97.66	8.88	30.78	1.985	115.12
242.30	338.62	18	103.31	9.39	30.78	1.984	115.08
242.30	338.62	19	108.95	9.90	30.78	1.984	115.06
242.30	338.62	20	114.60	10.42	30.78	1.983	115.03
263.64	368.44	21	120.74	10.98	33.49	* 1.978	114.70
242.22	338.50	22	126.38	11.49	30.77	* 1.982	114.98
242.22	338.50	23	132.02	12.00	30.77	* 1.982	114.96
242.22	338.50	24	137.66	12.51	30.77	1.981	114.92
242.22	338.50	25	143.30	13.03	30.77	1.981	114.89
242.22	338.50	26	148.94	13.54	30.77	1.981	114.87
242.22	338.50	27	154.59	14.05	30.77	1.980	114.83
242.22	338.50	28	160.23	14.57	30.77	1.979	114.79
242.22	338.50	29	165.87	15.08	30.77	1.978	114.74
242.22	338.50	30	171.51	15.59	30.77	1.977	114.68
241.41	337.37	31	177.13	16.10	30.67	1.976	114.64
241.41	337.37	32	182.76	16.61	30.67	1.975	114.57
241.41	337.37	33	188.38	17.13	30.67	1.974	114.51
241.41	337.37	34	194.00	17.64	30.67	1.972	114.38
241.41	337.37	35	199.63	18.15	30.67	1.971	114.32
241.41	337.37	36	205.25	18.66	30.67	1.970	114.27
241.41	337.37	37	210.87	19.17	30.67	1.969	114.22
241.41	337.37	38	216.49	19.68	30.67	* 1.968	114.17
241.41	337.37	39	222.12	20.19	30.67	* 1.968	114.12
241.41	337.37	40	227.74	20.70	30.67	* 1.967	114.06
241.41	337.37	41	233.36	21.21	30.67	* 1.966	114.01

** Denotes Extrapolated Data. Please Verify the Battery Characteristics Library.

Voltage Profile

Generation Date: 07/16/2014 05:39 pm

Battery: 22

Load (amperes)	Corrected Load (amps)	Time (min.)	AMP-HRS Removed	AMP-HR/ Pos Pit	AMPS/ Pos Pit	Cell Voltage (Volts)	Terminal Voltage (Volts)
241.41	337.37	42	238.98	21.73	30.67	* 1.966	114.04
241.41	337.37	43	244.61	22.24	30.67	* 1.965	114.00
241.41	337.37	44	250.23	22.75	30.67	1.967	114.11
241.41	337.37	45	255.85	23.26	30.67	1.967	114.09
241.41	337.37	46	261.48	23.77	30.67	1.967	114.06
241.41	337.37	47	267.10	24.28	30.67	1.966	114.04
241.41	337.37	48	272.72	24.79	30.67	1.966	114.02
241.41	337.37	49	278.34	25.30	30.67	1.965	113.99
241.41	337.37	50	283.97	25.82	30.67	1.965	113.96
241.41	337.37	51	289.59	26.33	30.67	1.964	113.94
241.41	337.37	52	295.21	26.84	30.67	1.964	113.91
241.41	337.37	53	300.83	27.35	30.67	1.963	113.88
241.41	337.37	54	306.46	27.86	30.67	1.963	113.85
241.41	337.37	55	312.08	28.37	30.67	1.963	113.88
241.41	337.37	56	317.70	28.88	30.67	1.963	113.84
241.41	337.37	57	323.33	29.39	30.67	1.961	113.72
241.41	337.37	58	328.95	29.90	30.67	1.960	113.68
241.41	337.37	59	334.57	30.42	30.67	1.959	113.64
241.41	337.37	60	340.19	30.93	30.67	1.959	113.61
241.79	337.90	61	345.83	31.44	30.72	1.958	113.57
241.79	337.90	62	351.46	31.95	30.72	1.958	113.54
241.79	337.90	63	357.09	32.46	30.72	1.957	113.52
241.79	337.90	64	362.72	32.97	30.72	1.957	113.49
241.79	337.90	65	368.35	33.49	30.72	1.956	113.47
241.79	337.90	66	373.98	34.00	30.72	1.956	113.45
241.79	337.90	67	379.62	34.51	30.72	1.956	113.42
241.79	337.90	68	385.25	35.02	30.72	1.955	113.40
241.79	337.90	69	390.88	35.53	30.72	1.956	113.47
241.79	337.90	70	396.51	36.05	30.72	1.956	113.46
241.79	337.90	71	402.14	36.56	30.72	1.956	113.44
241.79	337.90	72	407.77	37.07	30.72	1.956	113.42
241.79	337.90	73	413.41	37.58	30.72	1.955	113.41
241.79	337.90	74	419.04	38.09	30.72	1.955	113.39
241.79	337.90	75	424.67	38.61	30.72	1.955	113.37
241.79	337.90	76	430.30	39.12	30.72	1.954	113.35
241.79	337.90	77	435.93	39.63	30.72	1.954	113.33
241.79	337.90	78	441.56	40.14	30.72	1.954	113.31
241.79	337.90	79	447.20	40.65	30.72	1.953	113.29
241.79	337.90	80	452.83	41.17	30.72	1.953	113.27
241.79	337.90	81	458.46	41.68	30.72	1.953	113.25
241.79	337.90	82	464.09	42.19	30.72	1.952	113.22

*** Denotes Extrapolated Data. Please Verify the Battery Characteristics Library.

Voltage Profile

Generation Date: 07/16/2014 05:39 pm

Battery: 22

Load (amperes)	Corrected Load (amps)	Time (min.)	AMP-HRS Removed	AMP-HR/ Pos Plt	AMPS/ Pos Plt	Cell Voltage (Volts)	Terminal Voltage (Volts)
241.79	337.90	83	469.72	42.70	30.72	1.952	113.20
241.79	337.90	84	475.35	43.21	30.72	1.951	113.18
241.79	337.90	85	480.99	43.73	30.72	1.951	113.14
241.79	337.90	86	486.62	44.24	30.72	1.950	113.12
241.79	337.90	87	492.25	44.75	30.72	1.950	113.10
241.79	337.90	88	497.88	45.26	30.72	1.951	113.13
241.79	337.90	89	503.51	45.77	30.72	1.950	113.12
241.79	337.90	90	509.14	46.29	30.72	1.950	113.11
241.49	337.48	91	514.77	46.80	30.68	1.950	113.10
241.49	337.48	92	520.39	47.31	30.68	1.950	113.08
241.49	337.48	93	526.02	47.82	30.68	1.949	113.06
241.49	337.48	94	531.64	48.33	30.68	1.949	113.05
241.49	337.48	95	537.27	48.84	30.68	1.949	113.03
241.49	337.48	96	542.89	49.35	30.68	1.948	113.01
241.49	337.48	97	548.52	49.87	30.68	1.948	112.98
241.49	337.48	98	554.14	50.38	30.68	1.948	112.96
241.49	337.48	99	559.77	50.89	30.68	1.947	112.93
241.49	337.48	100	565.39	51.40	30.68	1.947	112.91
241.49	337.48	101	571.02	51.91	30.68	1.946	112.88
241.49	337.48	102	576.64	52.42	30.68	1.946	112.86
241.49	337.48	103	582.27	52.93	30.68	1.945	112.83
241.49	337.48	104	587.89	53.44	30.68	1.945	112.80
241.49	337.48	105	593.51	53.96	30.68	1.944	112.77
241.49	337.48	106	599.14	54.47	30.68	1.944	112.74
241.49	337.48	107	604.76	54.98	30.68	1.943	112.71
241.49	337.48	108	610.39	55.49	30.68	1.943	112.68
241.49	337.48	109	616.01	56.00	30.68	* 1.942	112.65
241.49	337.48	110	621.64	56.51	30.68	* 1.942	112.62
241.49	337.48	111	627.26	57.02	30.68	1.942	112.61
241.49	337.48	112	632.89	57.54	30.68	1.941	112.59
241.49	337.48	113	638.51	58.05	30.68	1.941	112.57
241.49	337.48	114	644.14	58.56	30.68	1.941	112.55
241.49	337.48	115	649.76	59.07	30.68	1.940	112.53
241.49	337.48	116	655.39	59.58	30.68	1.940	112.52
241.49	337.48	117	661.01	60.09	30.68	1.940	112.50
241.49	337.48	118	666.64	60.60	30.68	1.939	112.48
241.49	337.48	119	672.26	61.11	30.68	1.939	112.46
310.15	433.43	120	679.48	61.77	39.40	1.916	111.10

*** Denotes Extrapolated Data. Please Verify the Battery Characteristics Library.

**Attachment M
Load Profile Graph**

By: _____ Date: _____

Check: _____ Date: _____

LOAD PROFILE

Battery Name: 22

Generation Date: 07/16/2014 05:38 pm

