

Nuclear Plant
ENGINEERING

Technical Report

no.

NPE-89-002

**Susquehanna SES
Emergency Core
Cooling Systems'
Outage Report for Unit 1**

January 1989

PENNSYLVANIA POWER & LIGHT COMPANY

PP&L

8903020047 890224
PDR ADCK 05000387
PDC

Handwritten text at the top center, possibly a date or page number.



SUSQUEHANNA STEAM ELECTRIC STATION
EMERGENCY CORE COOLING SYSTEMS' OUTAGE REPORT
FOR UNIT ONE

Contributors

Christopher A. Boschetti


December 1988

Approved by:

Michael B. Detamore

M. B. Detamore

Supervisor-Systems Engineering



SUMMARY

This report was prepared for Unit One of the Susquehanna Steam Electric Station (SSES) in response to the TMI Action Plan Requirement II.K.3.17, "Report on Outages of Emergency Core Cooling Systems." This requirement states that licensees will submit a report detailing out of service information for all Emergency Core Cooling (ECC) systems covering five years of operation. This data is required to demonstrate that cumulative allowed outage times are not warranted for these systems.

This report presents out of service data for the first five years of commercial operation (period ending June 8, 1988) for the High Pressure Coolant Injection (HPCI) system, Automatic Depressurization System (ADS), Core Spray (CS) system, and the Residual Heat Removal (RHR) system in the Low Pressure Cooling Injection (LPCI) mode of operation. Also included are the support systems which are necessary for the ECC systems to function. In addition, system unavailability is calculated.




TABLE OF CONTENTS

| <u>SECTION</u> | <u>PAGE</u> |
|--------------------------------------------------------------------------------|-------------|
| DEFINITIONS | 1 |
| LIST OF TABLES | 3 |
| LIST OF FIGURES | 4 |
| 1.0 INTRODUCTION | 5 |
| 2.0 DATA COLLECTION AND ANALYSIS METHODOLOGY | 7 |
| 3.0 RESULTS | 11 |
| 4.0 REFERENCES | 34 |
| APPENDIX I: Database Structure | |
| APPENDIX II: High Pressure Coolant Injection System | |
| APPENDIX III: Automatic Depressurization System | |
| APPENDIX IV: Core Spray System | |
| APPENDIX V: Residual Heat Removal System (Low Pressure Coolant Injection Mode) | |
| APPENDIX VI: Emergency Service Water System | |
| APPENDIX VII: DC Power System | |
| APPENDIX VIII: AC Power System | |

DEFINITIONS

Functional Unavailability: The time period in which the system (division, channel, or component) could not perform its function if called upon. This demand is caused by an initiating event which could lead to a severe accident condition.

Administrative Unavailability: The time period in which the system (division, channel, or component) could still perform its function even though it was declared inoperable according to the plant Technical Specifications.

Preventive Maintenance (PM): A scheduled task in which a component or set of components are examined or serviced to ensure that they will perform as expected.

Corrective Maintenance (CM): An unscheduled task which is performed after a component or set of components have been examined or operated and determined to be in an unacceptable state of degradation.

Testing: A scheduled task in which a component or set of components are operated to ensure that they will perform as expected.

Plant Modification (MOD): A scheduled task which changes the design of a plant system.

System: A set of components which interact to perform a given function.

Division: A set of components within a system that can still perform the given system function.

Channel: A set of components within a division that can still perform the given system function.

Component: A component includes all of the equipment specific to that component required for that component to function (i.e., pump breaker is considered part of the pump).

Frontline System: A system which performs a specific safety function (i.e., reactor vessel injection).

Support System: A system which supplies the necessary facilities to enable a frontline system to perform its function.

Common System: A system capable of supporting Unit One and Unit Two operation simultaneously. This system can be either a frontline or support system.

Out of Service (OOS or O/S) Time: Time at which the system was declared inoperable by plant Technical Specifications.

Return Time: Time at which the affected equipment was declared operable (This includes time to tag out, repair/replace, test, restore, and closeout of Administrative paperwork).

Failure: An event that inhibits the function of the component. For example, a pump does not start when needed or stops spuriously, or a valve does not open/close on demand. This event always leads to corrective maintenance.

Repair Time: The time during which the component is actually being repaired.

Down Time: The time during which the component is out of service.

Initiating Event: An occurrence of some event that places the plant in an unplanned abnormal state which requires actuation of systems to mitigate its affects. Presently, only those events which effect the reactor core while at power are considered.

LIST OF TABLES

TITLE

Critical Hours for Unit One

Activities resulting in an LCO during 1983
(6/8/83 to 12/31/83) for SSES Unit One

Activities resulting in an LCO during 1984
(1/1/84 to 12/31/84) for SSES Unit One

Activities resulting in an LCO during 1985
(1/1/85 to 12/31/85) for SSES Unit One

Activities resulting in an LCO during 1986
(1/1/86 to 12/31/86) for SSES Unit One

Activities resulting in an LCO during 1987
(1/1/87 to 12/31/87) for SSES Unit One

Activities resulting in an LCO during 1988
(1/1/88 to 6/7/88) for SSES Unit One

AC Power Supplies for HPCI System
DC Power Supplies for HPCI System

HPCI System Database Records

ADS Database Records


AC Power Supplies for the Core Spray System
DC Power Supplies for the Core Spray System
Core Spray System Database Records

AC Power Supplies for the RHR System (LPCI Mode)
DC Power Supplies for the RHR System (LPCI Mode)
RHR System (LPCI Mode) Database Records

AC Power Supplies for the ESW System
DC Power Supplies for the ESW System
ESW Database Records

125V DC Database Records
250V DC Database Records

Preferred Power Supplies and Component for 13.8 KV
Startup Buses
AC Power Database Records



LIST OF FIGURES

TITLE

The LCO Log Sheet

Form Used for Log Sheet Entry Analysis

Flowchart of the Method Used to Analyze LCO Log Sheet Entries

Simplified Diagram of the HPCI System

Simplified Diagram of a Safety Relief Valve

Simplified Diagram of the Steam Pressure Relief System

Simplified Diagram of the Core Spray System (LOOP A)

Simplified Diagram of the LPCI Mode of RHR (LOOP A)

Simplified Diagram of the Emergency Service Water System (Loop A)

Flow path of the Emergency Service Water System

Simplified Diagram of One Channel in the 125V DC Power System

Simplified Diagram of the 250 VDC Power System (Division I)


Simplified Diagram of the 250 VDC Power System (Division II)

Offsite Power Supply to 13.8 KV Startup Buses

Diagram of the AC Power Distribution System

Loads on Each 480V Load Center

120V AC Power Scheme



1.0 INTRODUCTION

In this section the background for the NRC requirement is discussed, as well as the overall scope of this report. The material covered includes: the background of the NRC requirement, the purpose of this document and the organization of the material presented..

1.1 Background

The Nuclear Regulatory Commission (NRC) in 1981 developed an action plan (ref. 1) as a result of the accident at Three Mile Island which was implemented as part of the plant licensing process. The requirements presented in the action plan included various measures which were identified (ref. 2) to improve the capability of plants to mitigate the consequences of a loss of coolant accident (LOCA), and loss of feedwater event (task II.K). As a result, PP&L committed to implement these tasks as part of the plant operating license (ref. 3). Specifically, task II.K.3.17 of the action plan requires a report of Emergency Core Cooling (ECC) system outages for boiling water reactors.. The systems subject to this requirement for SSES Unit One are the High Pressure Coolant Injection (HPCI) system, Automatic Depressurization System (ADS) Core Spray (CS) system and Residual Heat Removal (RHR) system (in the low pressure coolant injection mode of operation). Further clarification of this task (ref. 4) defines the NRC position and requirements which are repeated below:

"Several components of the Emergency Core Cooling (ECC) systems are permitted by Technical Specifications to have substantial outage times (e.g., 72 hours for one diesel-generator; 14 days for the HPCI system). In addition, there are no cumulative outage time limitations for ECC systems. Licensees should submit a report detailing outage dates and lengths of outages for all ECC systems for the last 5 years of operation. The report should also include the causes of the outages (i.e., controller failure, spurious isolation)."

"The present Technical Specifications contain limits on allowable outage times for ECC systems and components. However, there are no cumulative outage time limitations on these same systems. It is possible that ECC equipment could meet present Technical Specification requirements but have a high unavailability because of frequent outages within the allowable Technical Specifications."

"The licensees should submit a report detailing outage dates and length of outages for all ECC systems for the last 5 years of operation, including causes of the outages. This report will provide the staff with a quantification of historical unreliability due to test and maintenance outages, which will be used to determine if a need exists for cumulative outage requirements in the Technical Specifications."

"Based on the above guidance and clarification, a detailed report should be submitted. The report should contain (1) outage dates and duration of outages; (2) cause of the outage; (3) ECC systems or components involved in the outage; and (4) corrective action taken. Test and maintenance outages should be included in the above listings which are to cover the last 5 years of operation. The licensee should propose changes to improve the availability of ECC equipment, if needed."

As a result of this requirement, this study was performed in order to collect the necessary information for Unit One ECC systems. In addition, overall system unavailability was calculated.

1.2 Purpose and Scope

This report was prepared in response to task II.K.3.17, "Report on outages of ECC systems." Outage data for the first five years of commercial operation (period ending June 7, 1988) for Unit One of the SSES was gathered for the HPCI, ADS, Core Spray, and RHR (LPCI mode of operation) systems. Systems which are required by the ECC systems in order to perform their intended function are defined as support systems. Outage data for these support systems are also included in this report. These support systems are the Emergency Service Water (ESW) system, the 125V DC power system, the 250V DC power system, and the AC power system.

Also, for each of the systems, unavailability calculations were performed. These calculations were deemed necessary in order to demonstrate that the systems are being taken out of service for acceptable lengths of time and that the allowed outage times imposed by the plant Technical Specifications need not be changed to cumulative allowed outage times.

This document also includes a discussion of the system outage data collection and analysis method (Section 2.0), a discussion of the results (Section 3.0), and presents in a set of appendices the data used in calculating unavailabilities for each system analyzed.

2.0 DATA COLLECTION AND ANALYSIS METHODOLOGY

In this section the database used to extract the required outage data for this report is discussed, along with the method used to collect and analyze the raw data for input into the database. The material covered includes: the database overview, the method of raw data collection, the method of raw data analysis, and the calculation of system unavailability.

2.1 Database Overview

The database used to extract the outage data for the ECC systems and support systems was developed in 1987, when Pennsylvania Power & Light (PP&L) in cooperation with Idaho National Engineering Laboratory (INEL) reviewed plant data taken from Limiting Condition for Operation (LCO) log sheets for safety related systems. Data was collected for both units from the date of initial criticality, (for Unit 1, 9/10/82 and Unit 2, 5/8/84) analyzed, and placed in a Ashton-Tate DBASE III+ database on an International Business Machine (IBM) personal computer. There is a separate database file for each safety related system. This activity is being performed by PP&L with the database updated monthly. The database file structure is defined in Appendix I.

2.2 Method of Raw Data Collection

2.2.1 Definition of System and Component Boundaries

Prior to collecting plant data, system and component boundaries were defined to ensure system outages were consistently and properly assigned. In defining the system boundaries two classes of systems were considered, frontline systems and support systems. Frontline systems perform a specific safety function: such as injecting water into the reactor vessel (i.e., HPCI). Support systems supply necessary facilities to enable a frontline system to perform its safety function, (i.e., AC power provides motive force). An outage was collected for a frontline system if it only caused the frontline system to be out of service. An outage was collected for a support system if it caused more than one frontline system to be out of service.

As an example, if the circuit breaker for the RHR injection valve failed open, the outage required for repair would be collected for the RHR system because it only affected the RHR system. If, however, the AC power motor control center failed, the outage would be collected for the AC power system, because its failure would cause other systems to become unavailable (ref. 5).

Component boundaries were also defined. After investigating available information on the subject it was decided to adopt those defined in reference 6.

2.2.2 Data Recording Process

The outages of systems identified in the SSES plant Technical Specifications (ref. 7) (i.e., ECC systems) are controlled by System Status and Control procedure AD-QA-302 (ref. 8). This procedure requires operators to keep a daily log of all systems in an outage which require entering a LCO. These log sheets form the primary source of safety system outage information. The outages for each of the safety related systems covered in the SSES Probabilistic Risk Assessment (ref. 9) were identified from the log sheets and recorded. A sample LCO log sheet is shown in Figure 1.

The information recorded on the log sheet was usually insufficient to determine if an outage represented a functional unavailability or an administrative unavailability. Thus, other sources of information were queried. The second source of information used was the Plant Maintenance Information System (PMIS). The PMIS is discussed in Section 2.3.

2.3 Method of Raw Data Evaluation

As presented in Section 2.2.2 the LCO log sheets were used as the raw data source. Each log sheet was reviewed and applicable outage entries were recorded. A sample of the form used to record the outage entries for a safety related system is presented in Figure 2.

However, the LCO log sheet entry does not include all of the information required to complete the form (Figure 2). For example, the impact of the outage on the system (division, channel, or component), the information required to determine whether the outage was administrative and/or included a component failure, and the plant condition at the time the outage occurred usually could not be determined. Therefore, other sources of information were considered. As stated previously, the PMIS was used as a secondary source of information.

The PMIS is a computer based system intended to assist in the scheduling, tracking, and historical retention of work activities at Susquehanna. It includes the tracking and scheduling of Preventive Maintenance, Corrective Maintenance, Testing, and other Work Authorizing documents. Information within PMIS is sorted by the system of interest (i.e., RHR) and is organized in chronological order. This information includes unit number, equipment number, problem and action taken, work authorizing document number, and the applicable technical specification. The edits for each system are used to identify the information presented above.

If sufficient information was not available from the PMIS edit, other sources of information were identified and reviewed. This involved reading surveillance procedures, checking electrical elementary diagrams, piping and instrumentation diagrams, work authorizations (including WAs for preventive maintenance, corrective maintenance or other work), or equipment release forms.

Once all of the outage information is recorded, each outage entry is input into the database described in Section 2.1. These entries are then printed and reviewed for correctness. Once reviewed and signed off they become an official record within the database. The flow chart depicted in Figure 3 graphically presents the method which is used to evaluate the LCO log sheet entries.

2.4 Calculation of System Unavailability

One use of the data collected is to calculate overall system unavailability. This unavailability is used to demonstrate that plant systems are being taken out of service (OOS) for acceptable lengths of time when the potential for a severe accident condition exists. In this calculation, functional unavailable hours were used, along with the hours the system was required to be functional during a single calendar year. The equation used for the calculation is:

$P(\text{system being functionally OOS}) =$

$$[A/\text{CRITHRS} + B/2(\text{CRITHRS}) + C/4(\text{CRITHRS}) + D/\text{COMP}(\text{CRITHRS})] \quad (1)$$

where: A = the total functional unavailable hours which impact the system only,

B = the total functional unavailable hours which impact the division only,

C = the total functional unavailable hours which impact the channel only,

D = the total functional unavailable hours which impact the component only,

CRITHRS = number of hours the system was required to be functional,

COMP = number of components under observation..

The observation time period used in this calculation was a single calendar year. As a result, a trend can be developed over the five-year period of interest.. The method of determining the values for each variable used in equation (1) is discussed below.

2.4.1 Functional Unavailable hours (A,B,C,D)

The value for each time period was taken from each ECC systems' database using a program sorting routine..

2.4.2 Required Operable Hours (CRITHRS)

The value for each time period was determined by first identifying the criteria in which each frontline system (ECC system) and support system was required to be operable in order to respond to an initiating event which could lead to a severe accident. This time period covers reactor criticality to cold shutdown. From comparing this criteria to the plant Technical Specifications (ref. 8), the frontline systems (i.e., ECC systems) are required to be operable during plant Operating Conditions 1, 2, and 3. Based upon a review of the plant operating records, the time in which the systems are required to be operable is dominated by the time in which Unit One was critical (Condition 1, and part of Condition 2). Therefore, it was assumed that the time in which the systems are required to be operable is equal to the time in which the Unit One was critical over the observation time period. Table 1 presents the critical hours for Unit One over the five year period. The support systems are required to be operable during all plant operating conditions (ref. 8) to satisfy the above criteria. Therefore, the value used are the calendar hours during the observation time period (i.e., there are 8766 hours per year).

2.4.3 Components Under Observation (COMP)

The number of components for each system which are required to be functional were identified from P&ID's, maintenance work orders (used to identify blocking requirements) and also surveillance procedures.

3.0 RESULTS

This section presents the results from evaluating the outages for the ECC systems and their support systems. The material covered includes: a discussion of how the result tables were prepared, and the organization of the appendices which present the data obtained from the DBASE III+ database for each system.

3.1 Results Preparation

Each systems' database was queried according to the appropriate observation time period (i.e., yearly) over the first five years of commercial operation using a computer program developed in-house. This computer program reviewed the applicable database records and provided output in a form similar to that presented in Tables 2 through 7.

These tables present the results of an edit performed on each system database for Unit One, on a yearly basis, starting from the date of commercial operation (6/8/83) covering a period of five years. The unavailability of each system was calculated using equation (1) presented in Section 2.4. Also, the unavailability of each division (and channel where applicable) was calculated using the applicable portion of equation (1).

As discussed in Section 2.4, unavailabilities were calculated using the functional unavailable hours and also the number of hours the system was required to be operable during the time interval of interest. The critical hours for Unit One are presented in Table 1.

3.2 Appendices Organization

An Appendix for each system evaluated is presented which contains a brief system description (ref. 9) and also the information which resides in the database that was used in calculating the results.

Table 1: Critical Hours for Unit One

| <u>Time Interval</u> | <u>Critical Hours</u> |
|----------------------|-----------------------|
| 6/8/83 - 12/31/83 | 3745.00 |
| 1/1/84 - 12/31/84 | 6432.00 |
| 1/1/85 - 12/31/85 | 5496.00 |
| 1/1/86 - 12/31/86 | 6048.00 |
| 1/1/87 - 12/31/87 | 5540.00 |
| 1/1/88 - 6/7/88 | 3357.00 |

TABLE 2: Activities Resulting in an LCO During 1983 (6/8/83-12/31/83) for SSES Unit One

| System | Unavailability (1) | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total (2) OOS Hours | Total OOS Hours for:- | | | |
|-----------------|--------------------|------------------------------------|-----------------------------------|--------|-------|-----|---------------------|-----------------------|--------|-------|-----|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| HPCI | 1.91E-02 | 71.39 | 0 | 55.48 | 15.91 | 0 | 125.73 | 0 | 99.55 | 26.18 | 0 |
| ADS | 1.28E-04 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel A | 8.01E-04 | 3.00 | 0 | 3.00 | 0 | 0 | 3.00 | 0 | 3.00 | 0 | 0 |
| ADS-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-* | N/A | 0 | 0 | 0 | 0 | 0 | 16.67 | 0 | 16.67 | 0 | 0 |
| Core Spray | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-* | N/A | 0 | 0 | 0 | 0 | 0 | 5.26 | 0 | 0 | 5.26 | 0 |
| RHR (3) | 3.50E-02 | 0 | 0 | 0 | 0 | 0 | 3.35 | 0 | 0 | 3.35 | 0 |
| RHR-Division I | 6.59E-03 | 24.67 | 0 | 24.67 | 0 | 0 | 140.67 | 0 | 140.67 | 0 | 0 |
| RHR-Channel A | 2.61E-02 | 97.58 | 0 | 97.58 | 0 | 0 | 97.58 | 0 | 97.58 | 0 | 0 |
| RHR-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-Division II | 4.90E-02 | 183.50 | 0 | 183.50 | 0 | 0 | 246.95 | 246.95 | 0 | 0 | 0 |
| RHR-Channel B | 2.27E-03 | 8.50 | 8.50 | 0 | 0 | 0 | 9.80 | 9.80 | 0 | 0 | 0 |
| RHR-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-* | N/A | 0 | 0 | 0 | 0 | 0 | 37.42 | 0 | 37.42 | 0 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

TABLE 2: Activities Resulting in an LCO During 1983 (6/8/83-12/31/83) for SSES Unit One

| System | Unavailability ⁽¹⁾ | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total ⁽²⁾ OOS Hours | Total OOS Hours for: | | | |
|---------------------|-------------------------------|------------------------------------|-----------------------------------|------|------|-----|--------------------------------|----------------------|-------|------|--------|
| | | | PM | CH | TEST | MOD | | PM | CH | TEST | MOD |
| ESW | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ESW-Division I | 7.67E-04 | 3.83 | 0 | 3.83 | 0 | 0 | 246.16 | 0 | 3.83 | 0 | 242.33 |
| ESW-Channel A | 1.40E-04 | 7.00 | 7.00 | 0 | 0 | 0 | 7.00 | 7.00 | 0 | 0 | 0 |
| ESW-Channel C | 1.12E-04 | 5.58 | 5.58 | 0 | 0 | 0 | 5.58 | 5.58 | 0 | 0 | 0 |
| ESW-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 57.50 | 0 | 57.50 | 0 | 0 |
| ESW-Channel B | 2.38E-03 | 11.89 | 4.22 | 7.67 | 0 | 0 | 11.89 | 4.22 | 7.67 | 0 | 0 |
| ESW-Channel D | 8.45E-03 | 4.22 | 4.22 | 0 | 0 | 0 | 4.22 | 4.22 | 0 | 0 | 0 |
| ESW-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

TABLE 2: Activities Resulting in an LCO During 1983 (6/8/83-12/31/83) for SSES Unit One

| System | Unavailability (1) | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total (2) OOS Hours | Total OOS Hours for: | | | |
|---------------------------------|--------------------|------------------------------------|-----------------------------------|--------|------|-----|---------------------|----------------------|--------|------|-----|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| AC Power (13.8kv) | 1.34E-02 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. I | 2.67E-02 | 133.95 | 0 | 133.95 | 0 | 0 | 135.37 | 1.42 | 133.95 | 0 | 0 |
| AC Power-Div. II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power (4160V) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0.97 | 0 | 0 | 0.97 | 0 |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 1.05 | 0 | 0 | 1.05 | 0 |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0.52 | 0 | 0 | 0.52 | 0 |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 1.08 | 0 | 0 | 1.08 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 4.83 | 4.00 | 0 | 0.83 | 0 |
| AC Power (480V) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. I (Swing Bus) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. II (Swing Bus) | 1.55E-03 | 7.75 | 7.75 | 0 | 0 | 0 | 7.75 | 7.75 | 0 | 0 | 0 |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power (120V) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

TABLE 3: Activities Resulting in an LCO During 1984 (1/1/84-12/31/84) for SSES Unit One

| System | Unavailability ⁽¹⁾ | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total ⁽²⁾ OOS Hours | Total OOS Hours for: | | | |
|--------------------|-------------------------------|------------------------------------|-----------------------------------|-------|------|-----|--------------------------------|----------------------|--------|--------|-----|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| HPCI | 5.33E-03 | 34.30 | 0 | 32.67 | 1.63 | 0 | 69.07 | 4.00 | 61.14 | 3.93 | 0 |
| ADS | 3.59E-04 | 0 | 0 | 0 | 0 | 0 | 12.22 | 0 | 0 | 12.22 | 0 |
| ADS-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 4.00 | 0 | 0 | 4.00 | 0 |
| ADS-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 2.25 | 0 | 0 | 2.25 | 0 |
| ADS-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-* | N/A | 9:23 | 0 | 0 | 9.23 | 0 | 294.36 | 0 | 33.35 | 261.01 | 0 |
| Core Spray | 0 | 0 | 0 | 0 | 0 | 0 | 132.91 | 0 | 129.33 | 3.58 | 0 |
| CS-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 4.25 | 4.25 | 0 | 0 | 0 |
| CS-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 3.92 | 0 | 0 | 3.92 | 0 |
| CS-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-* | N/A | 0 | 0 | 0 | 0 | 0 | 16.98 | 0 | 15.48 | 1.50 | 0 |
| RHR ⁽³⁾ | 0 | 0 | 0 | 0 | 0 | 0 | 19.92 | 0 | 0 | 19.92 | 0 |
| RHR-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 46.78 | 0 | 0 | 46.78 | 0 |
| RHR-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 5.73 | 0 | 5.73 | 0 | 0 |
| RHR-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 40.00 | 37.00 | 0 | 3.00 | 0 |
| RHR-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 31.68 | 0 | 0 | 31.68 | 0 |
| RHR-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0.17 | 0.17 | 0 | 0 | 0 |
| RHR-* | N/A | 0 | 0 | 0 | 0 | 0 | 1.17 | 0 | 0 | 1.17 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and division or channels which are tested sequentially.

TABLE 3: Activities Resulting in an LCO During 1984 (1/1/84-12/31/84) for SSES Unit One

| System | Unavailability ⁽¹⁾ | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total ⁽²⁾ OOS Hours | Total OOS Hours for: | | | |
|-------------------|-------------------------------|------------------------------------|-----------------------------------|-------|--------|-----|--------------------------------|----------------------|--------|--------|-----|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| ESW | 1.27E-02 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ESW-Division I | 1.44E-02 | 126.00 | 0 | 0 | 126.00 | 0 | 145.00 | 0 | 0 | 145.00 | 0 |
| ESW-Channel A | 6.56E-04 | 5.75 | 0 | 5.75 | 0 | 0 | 5.75 | 0 | 5.75 | 0 | 0 |
| ESW-Channel C | 2.93E-03 | 25.70 | 0 | 17.50 | 8.20 | 0 | 25.70 | 0 | 17.50 | 8.20 | 0 |
| ESW-Division II | 7.99E-03 | 70.00 | 0 | 70.00 | 0 | 0 | 670.80 | 0 | 670.80 | 0 | 0 |
| ESW-Channel B | 2.08E-03 | 18.25 | 0 | 18.25 | 0 | 0 | 18.25 | 0 | 18.25 | 0 | 0 |
| ESW-Channel D | 2.57E-04 | 2.25 | 0 | 2.25 | 0 | 0 | 2.25 | 0 | 2.25 | 0 | 0 |
| ESW-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC | 1.24E-04 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-Div. I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-Div. II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-* | N/A | 6.50 | 0 | 6.50 | 0 | 0 | 6.96 | 0 | 6.96 | 0 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

TABLE 3: Activities Resulting in an LCO During 1984 (1/1/84-12/31/84) for SSES Unit One

| System | Unavailability (1) | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total (2) OOS Hours | Total OOS Hours for: | | | |
|------------------------------|--------------------|------------------------------------|-----------------------------------|------|------|-----|---------------------|----------------------|-------|------|-----|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| AC Power (13.8kv) | 5.52E-04 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. I | 1.45E-04 | 1.27 | 0 | 1.27 | 0 | 0 | 1.27 | 0 | 1.27 | 0 | 0 |
| AC Power-Div. II | 9.58E-04 | 8.40 | 8.00 | 0 | 0.40 | 0 | 25.28 | 8.00 | 16.88 | 0.40 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power (4160V) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 2.79 | 0 | 0 | 2.79 | 0 |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 1.63 | 0 | 0 | 1.63 | 0 |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 2.39 | 0 | 0 | 2.39 | 0 |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 1.73 | 0 | 0 | 1.73 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power (480V) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. I (Swing Bus) | 0 | 0 | 0 | 0 | 0 | 0 | 12.53 | 12.53 | 0 | 0 | 0 |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. II (Swing Bus) | 0 | 0 | 0 | 0 | 0 | 0 | 8.83 | 8.83 | 0 | 0 | 0 |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power (120V) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

TABLE 4: Activities Resulting in an LCO During 1985 (1/1/85-12/31/85) for SSES Unit One

| System | Unavailability (1) | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total (2) OOS Hours | Total OOS Hours for: | | | |
|-----------------|--------------------|------------------------------------|-----------------------------------|-------|-------|-----|---------------------|----------------------|--------|-------|-----|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| HPCI | 1.32E-02 | 72.32 | 11.49 | 43.35 | 17.48 | 0 | 224.09 | 40.82 | 110.82 | 72.45 | 0 |
| ADS | 1.17E-04 | 0 | 0 | 0 | 0 | 0 | 6.24 | 0 | 0 | 6.24 | 0 |
| ADS-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-* | N/A | 2.58 | 0 | 0 | 2.58 | 0 | 37.30 | 0 | 29.97 | 7.33 | 0 |
| Core Spray | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 4.50 | 4.50 | 0 | 0 | 0 |
| CS-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 2.58 | 2.58 | 0 | 0 | 0 |
| CS-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-* | N/A | 0 | 0 | 0 | 0 | 0 | 0.33 | 0 | 0 | 0.33 | 0 |
| RHR (3) | 5.22E-03 | 0 | 0 | 0 | 0 | 0 | 0.70 | 0 | 0 | 0.70 | 0 |
| RHR-Division I | 9.25E-03 | 50.83 | 50.83 | 0 | 0 | 0 | 50.83 | 50.83 | 0 | 0 | 0 |
| RHR-Channel A | 2.39E-03 | 13.13 | 0 | 13.13 | 0 | 0 | 13.13 | 0 | 13.13 | 0 | 0 |
| RHR-Channel C | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 15.17 | 0 | 15.17 | 0 | 0 |
| RHR-Channel B | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-Channel D | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are listed sequentially.

19

TABLE 4: Activities Resulting in an LCO During 1985 (1/1/85-12/31/85) for SSES Unit One

| System | Unavailability ⁽¹⁾ | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total ⁽²⁾ OOS Hours | Total OOS Hours for: | | | |
|-------------------|-------------------------------|------------------------------------|-----------------------------------|-------|-------|-------|--------------------------------|----------------------|-------|-------|-------|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| ESW | 5.20E-03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ESW-Division I | 2.04E-03 | 17.91 | 0 | 0 | 17.91 | 0 | 17.91 | 0 | 0 | 17.91 | 0 |
| ESW-Channel A | 2.73E-03 | 23.92 | 13.25 | 0 | 10.67 | 0 | 23.92 | 13.25 | 0 | 10.67 | 0 |
| ESW-Channel C | 3.58E-03 | 31.42 | 25.42 | 0 | 6.00 | 0 | 31.42 | 25.42 | 0 | 6.00 | 0 |
| ESW-Division II | 3.21E-03 | 28.16 | 10.50 | 0 | 17.66 | 0 | 28.16 | 10.50 | 0 | 17.66 | 0 |
| ESW-Channel B | 1.63E-03 | 14.33 | 0 | 10.75 | 3.58 | 0 | 14.33 | 0 | 10.75 | 3.58 | 0 |
| ESW-Channel D | 2.34E-03 | 20.53 | 0 | 18.00 | 2.53 | 0 | 20.53 | 0 | 18.00 | 2.53 | 0 |
| ESW-* | N/A | 108.54 | 23.47 | 0 | 0 | 85.07 | 108.54 | 23.47 | 0 | 0 | 85.07 |
| 125V DC | 1.43E-04 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-* | N/A | 10.02 | 0 | 10.02 | 0 | 0 | 10.19 | 0 | 10.02 | 0.17 | 0 |
| 250V DC | 9.51E-05 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-Div. I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-Div. II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-* | N/A | 5.00 | 0 | 5.00 | 0 | 0 | 31.83 | 0 | 31.83 | 0 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

TABLE 4: Activities Resulting in an LCO During 1985 (1/1/85-12/31/85) for SSES Unit One

| System | Unavailability ⁽¹⁾ | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total ⁽²⁾ OOS Hours | Total OOS Hours for: | | | | |
|------------------------------|-------------------------------|------------------------------------|-----------------------------------|------|------|-----|--------------------------------|----------------------|----|------|-------|--|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD | |
| AC Power (13.8kv) | 4.49E-03 | | | | | | | | | | | |
| AC Power-Div. I | 8.97E-03 | 78.66 | 69.73 | 8.93 | 0 | 0 | 78.66 | 69.73 | 0 | 8.93 | 0 | |
| AC Power-Div. II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power (4160V) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 12.60 | 0 | 0 | 1.77 | 10.83 | |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 1.80 | 0 | 0 | 1.80 | 0 | |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 1.97 | 0 | 0 | 1.97 | 0 | |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 10.47 | 0 | 0 | 2.00 | 8.47 | |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power (480V) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power-Div. I (Swing Bus) | 0 | 0 | 0 | 0 | 0 | 0 | 9.67 | 9.67 | 0 | 0 | 0 | |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power-Div. II (Swing Bus) | 0 | 0 | 0 | 0 | 0 | 0 | 6.00 | 6.00 | 0 | 0 | 0 | |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 12.58 | 12.58 | 0 | 0 | 0 | |
| AC Power (120V) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power-Channel D | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| AC Power-* | | | | | | | | | | | | |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

TABLE 5: Activities Resulting in an LCO During 1986 (1/1/86-12/31/86) for SSES Unit One

| System | Unavailability (1) | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total (2) OOS Hours | Total OOS Hours for: | | | |
|-----------------|--------------------|------------------------------------|-----------------------------------|-------|-------|-----|---------------------|----------------------|---------|-------|-----|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| HPCI | 2.73E-02 | 170.51 | 68.58 | 81.00 | 20.93 | 0 | 1764.85 | 68.58 | 1666.47 | 29.80 | 0 |
| ADS | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0.83 | 0 | 0.83 | 0 | 0 |
| ADS-* | N/A | 0 | 0 | 0 | 0 | 0 | 2.50 | 0 | 2.50 | 0 | 0 |
| Core Spray | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 337.58 | 0 | 337.58 | 0 | 0 |
| CS-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 3.92 | 0 | 0 | 3.92 | 0 |
| CS-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 2.43 | 0 | 0 | 2.43 | 0 |
| CS-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-* | N/A | 0 | 0 | 0 | 0 | 0 | 5.92 | 0 | 0 | 5.92 | 0 |
| RHR (3) | 1.40E-03 | 0 | 0 | 0 | 0 | 0 | 5.71 | 5.24 | 0 | 0.47 | 0 |
| RHR-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 95.95 | 0 | 0.58 | 95.37 | 0 |
| RHR-Channel A | 1.90E-03 | 11.50 | 7.92 | 3.58 | 0 | 0 | 11.50 | 7.92 | 3.58 | 0 | 0 |
| RHR-Channel C | 1.57E-03 | 9.50 | 5.92 | 3.58 | 0 | 0 | 13.03 | 5.92 | 3.58 | 3.53 | 0 |
| RHR-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 65.00 | 0 | 0 | 65.00 | 0 |
| RHR-Channel B | 9.71E-04 | 5.87 | 3.17 | 2.70 | 0 | 0 | 5.87 | 3.17 | 2.70 | 0 | 0 |
| RHR-Channel D | 1.16E-03 | 7.00 | 4.58 | 2.42 | 0 | 0 | 10.50 | 4.58 | 2.42 | 3.50 | 0 |
| RHR-* | N/A | 0 | 0 | 0 | 0 | 0 | 5.29 | 2.45 | 0 | 2.84 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are listed sequentially.

TABLE 5: Activities Resulting in an LCO during 1986 (1/1/86-12/31/86) for SSES Unit One

| System | Unavailability (1) | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total (2) OOS Hours | Total OOS Hours for: | | | |
|-------------------|--------------------|------------------------------------|-----------------------------------|--------|------|-----|---------------------|----------------------|--------|-------|-----|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| ESW | 1.74E-02 | 0 | 0 | 0 | 0 | 0 | 30.83 | 0 | 0 | 30.83 | 0 |
| ESW-Div. I | 1.74E-03 | 15.25 | 10.67 | 4.58 | 0 | 0 | 15.25 | 10.67 | 4.58 | 0 | 0 |
| ESW-Channel A | 3.48E-02 | 305.66 | 0.58 | 305.08 | 0 | 0 | 310.46 | 0.58 | 309.88 | 0 | 0 |
| ESW-Channel C | 7.41E-03 | 64.92 | 0 | 64.92 | 0 | 0 | 64.92 | 0 | 64.92 | 0 | 0 |
| ESW-Div. II | 1.19E-02 | 104.58 | 0 | 104.58 | 0 | 0 | 104.58 | 0 | 104.58 | 0 | 0 |
| ESW-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ESW-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ESW-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC | 4.64E-04 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-* | N/A | 48.80 | 0 | 48.80 | 0 | 0 | 86.20 | 0 | 48.80 | 37.40 | 0 |
| 250V DC | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-Div. I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-Div. II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

1
2
3
1

TABLE 5: Activities Resulting in an LCO During 1986 (1/1/86-12/31/86) for SSES Unit One

| System | Unavailability ⁽¹⁾ | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total ⁽²⁾ OOS Hours | Total OOS Hours for: | | | |
|------------------------------|-------------------------------|------------------------------------|-----------------------------------|------|-------|-----|--------------------------------|----------------------|------|-------|-----|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| AC Power (13.8kv) | 2.13E-03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. II | 4.26E-03 | 37.32 | 37.32 | 0 | 0 | 0 | 37.32 | 37.32 | 0 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power (4160V) | | | | | | | | | | | |
| AC Power-Channel A | 3.86E-03 | 33.80 | 19.67 | 0 | 14.13 | 0 | 37.26 | 19.67 | 0 | 17.59 | 0 |
| AC Power-Channel B | 1.99E-03 | 17.45 | 0 | 0 | 17.45 | 0 | 22.19 | 1.27 | 0 | 20.92 | 0 |
| AC Power-Channel C | 1.62E-03 | 14.23 | 0 | 0 | 14.23 | 0 | 17.15 | 0 | 0 | 17.15 | 0 |
| AC Power-Channel D | 1.79E-03 | 15.59 | 0 | 0 | 15.59 | 0 | 18.51 | 0 | 0 | 18.51 | 0 |
| AC Power-* | N/A | 4.83 | 0 | 0 | 4.83 | 0 | 12.90 | 7.00 | 0 | 5.90 | 0 |
| AC Power (480V) | | | | | | | | | | | |
| AC Power-Div. I (Swing Bus) | 0 | 0 | 0 | 0 | 0 | 0 | 12.00 | 12.00 | 0 | 0 | 0 |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. II (Swing Bus) | 9.27E-03 | 81.23 | 74.56 | 6.67 | 0 | 0 | 102.48 | 95.81 | 6.67 | 0 | 0 |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power (120V) | | | | | | | | | | | |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

TABLE 6: Activities Resulting in an LCO During 1987 (1/1/87-12/31/87) for SSES Unit One

| System | Unavailability ⁽¹⁾ | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total ⁽²⁾ OOS Hours | Total OOS Hours for: | | | |
|--------------------|-------------------------------|------------------------------------|-----------------------------------|--------|------|-------|--------------------------------|----------------------|--------|--------|-------|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| HPCI | 3.00E-02 | 166.83 | 2.58 | 142.25 | 3.75 | 18.25 | 754.61 | 40.91 | 149.16 | 546.29 | 18.25 |
| ADS | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Core Spray | 3.72E-03 | 0 | 0 | 0 | 0 | 0 | 23.00 | 18.70 | 0 | 4.30 | 0 |
| CS-Division I | 1.51E-03 | 8.37 | 8.37 | 0 | 0 | 0 | 8.00 | 8.00 | 0 | 0 | 0 |
| CS-Channel A | 1.44E-03 | 8.00 | 8.00 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Division II | 5.20E-03 | 28.80 | 11.05 | 17.75 | 0 | 0 | 780.91 | 24.72 | 756.19 | 0 | 0 |
| CS-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 11.36 | 0 | 3.09 | 8.27 | 0 |
| CS-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR ⁽³⁾ | 2.11E-03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-Division I | 5.87E-03 | 18.67 | 18.67 | 0 | 0 | 0 | 18.67 | 18.67 | 0 | 0 | 0 |
| RHR-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 9.08 | 9.08 | 0 | 0 | 0 |
| RHR-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-Division-II | 4.82E-04 | 2.67 | 0 | 2.67 | 0 | 0 | 6.44 | 0 | 6.44 | 0 | 0 |
| RHR-Channel B | 7.53E-04 | 4.17 | 4.17 | 0 | 0 | 0 | 4.17 | 4.17 | 0 | 0 | 0 |
| RHR-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-* | N/A | 0 | 0 | 0 | 0 | 0 | 1.16 | 0 | 0 | 1.16 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

TABLE 6: Activities Resulting in an LCO During 1987 (1/1/87-12/31/87) for SSES Unit One

| System | Unavailability ⁽¹⁾ | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total ⁽²⁾ OOS Hours | Total OOS Hours for: | | | |
|-------------------|-------------------------------|------------------------------------|-----------------------------------|------|------|-------|--------------------------------|----------------------|------|--------|-------|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| ESW | 3.60E-03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ESW-Division I | 3.93E-03 | 34.47 | 24.05 | 0 | 0 | 10.42 | 226.66 | 24.05 | 0 | 192.19 | 10.42 |
| ESW-Channel A | 2.33E-03 | 20.42 | 20.42 | 0 | 0 | 0 | 23.67 | 20.42 | 0 | 3.25 | 0 |
| ESW-Channel C | 2.17E-03 | 19.00 | 19.00 | 0 | 0 | 0 | 23.38 | 19.00 | 0 | 4.38 | 0 |
| ESW-Div. II | 1.02E-03 | 8.96 | 8.96 | 0 | 0 | 0 | 213.71 | 8.96 | 0 | 204.75 | 0 |
| ESW-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ESW-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ESW-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC | 2.79E-04 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel A | 1.97E-04 | 1.73 | 0 | 1.73 | 0 | 0 | 1.73 | 0 | 1.73 | 0 | 0 |
| 125V DC-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-* | N/A | 5.73 | 0 | 5.73 | 0 | 0 | 5.73 | 0 | 5.73 | 0 | 0 |
| 250V DC | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-Div. I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-Div. II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

TABLE 6: Activities Resulting in an LCO During 1987 (1/1/87-12/31/87) for SSES Unit One

| System | Unavailability (1) | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total (2) OOS Hours | Total OOS Hours for: | | | |
|------------------------------|--------------------|------------------------------------|-----------------------------------|-------|------|-----|---------------------|----------------------|-------|------|-----|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| AC Power (13.8kv) | 1.49E-03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. I | 0 | 0 | 0 | 0 | 0 | 0 | 11.58 | 0 | 11.58 | 0 | 0 |
| AC Power-Div. II | 2.97E-03 | 26.06 | 0 | 26.06 | 0 | 0 | 26.06 | 0 | 26.06 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power(4160V) | 1.52E-03 | 0 | 0 | 0 | 0 | 0 | 0.38 | 0 | 0.38 | 0 | 0 |
| AC Power-Channel A | 1.95E-03 | 17.08 | 0 | 17.08 | 0 | 0 | 21.93 | 0 | 17.08 | 4.85 | 0 |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 3.97 | 0 | 0 | 3.97 | 0 |
| AC Power-Channel C | 1.88E-03 | 16.50 | 0 | 16.50 | 0 | 0 | 19.61 | 0 | 16.50 | 3.11 | 0 |
| AC Power-Channel D | 2.27E-03 | 19.92 | 0 | 19.92 | 0 | 0 | 22.95 | 0 | 19.92 | 3.03 | 0 |
| AC Power-* | N/A | 1.82 | 1.82 | 0 | 0 | 0 | 11.64 | 1.89 | 0 | 9.75 | 0 |
| AC Power (480V) | 2.32E-03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. | 1.45E-03 | 12.75 | 9.42 | 3.33 | 0 | 0 | 12.75 | 9.42 | 3.33 | 0 | 0 |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. II (Swing Bus) | 2.46E-03 | 21.58 | 9.08 | 12.50 | 0 | 0 | 30.25 | 17.75 | 12.50 | 0 | 0 |
| AC Power-Channel B | 1.45E-03 | 12.75 | 0 | 12.75 | 0 | 0 | 12.75 | 0 | 12.75 | 0 | 0 |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power (120V) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

27

TABLE 7: Activities Resulting in an LCO During 1988 (1/1/88-6/8/88) for SSES Unit One

| System | Unavailability ⁽¹⁾ | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total ⁽²⁾ OOS Hours | Total OOS Hours for: | | | |
|---------------------------------|-------------------------------|------------------------------------|-----------------------------------|----|------|-----|--------------------------------|----------------------|------|------|-----|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| AC Power (13.8kv) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power (4160V) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 1.15 | 0 | 1.15 | 0 | 0 |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0.78 | 0 | 0.78 | 0 | 0 |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0.81 | 0 | 0.81 | 0 | 0 |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0.68 | 0 | 0.68 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 6.00 | 0 | 4.58 | 1.42 | 0 |
| AC Power (480V) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. I (Swing Bus) | 0 | 0 | 0 | 0 | 0 | 0 | 7.83 | 7.83 | 0 | 0 | 0 |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Div. II (Swing Bus) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power (120V) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| AC Power-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

TABLE 7: Activities Resulting in an LCO During 1988 (1/1/88-6/8/88) for SSES Unit One

| System | Unavailability ⁽¹⁾ | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total ⁽²⁾ OOS Hours | Total OOS Hours for: | | | |
|---------------------|-------------------------------|------------------------------------|-----------------------------------|------|------|-----|--------------------------------|----------------------|------|-------|-----|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| ESW | 3.47E-03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ESW-Div. I | 3.30E-03 | 28.92 | 28.92 | 0 | 0 | 0 | 35.25 | 28.92 | 0 | 6.33 | 0 |
| ESW-Channel A | 3.49E-04 | 3.06 | 3.06 | 0 | 0 | 0 | 3.06 | 3.06 | 0 | 0 | 0 |
| ESW-Channel C | 1.37E-03 | 12.00 | 12.00 | 0 | 0 | 0 | 12.00 | 12.00 | 0 | 0 | 0 |
| ESW-Div. II | 2.78E-03 | 24.41 | 24.41 | 0 | 0 | 0 | 24.41 | 24.41 | 0 | 0 | 0 |
| ESW-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ESW-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ESW-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC | 1.31E-05 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 125V DC-* | N/A | 0.92 | 0 | 0.92 | 0 | 0 | 14.50 | 0 | 0.92 | 13.58 | 0 |
| 250V DC | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 250V DC-* | N/A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

1
20
1

TABLE 7: Activities Resulting in an LCO During 1988 (1/1/88-6/8/88) for SSES Unit One

| System | Unavailability ⁽¹⁾ | Total Functional Unavailable Hours | Functional Unavailable Hours for: | | | | Total ⁽²⁾ OOS Hours | Total OOS Hours for: | | | |
|--------------------|-------------------------------|------------------------------------|-----------------------------------|------|------|-----|--------------------------------|----------------------|------|-------|--------|
| | | | PM | CM | TEST | MOD | | PM | CM | TEST | MOD |
| HPCI | 4.11E-04 | 1.58 | 0 | 0.58 | 1.00 | 0 | 191.01 | 12.91 | 3.16 | 15.44 | 159.50 |
| ADS | 1.23E-04 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ADS-* | N/A | 2.83 | 0 | 0 | 2.83 | 0 | 2.83 | 0 | 0 | 2.83 | 0 |
| Core Spray | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 1.19 | 0 | 0 | 1.19 | 0 |
| CS-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 0.58 | 0 | 0 | 0.58 | 0 |
| CS-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CS-* | N/A | 0 | 0 | 0 | 0 | 0 | 2.58 | 0 | 0 | 2.58 | 0 |
| RHR ⁽³⁾ | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-Division I | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-Channel A | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-Channel C | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-Division II | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-Channel B | 0 | 0 | 0 | 0 | 0 | 0 | 14.58 | 14.58 | 0 | 0 | 0 |
| RHR-Channel D | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| RHR-* | N/A | 0 | 0 | 0 | 0 | 0 | 1.67 | 0 | 0 | 1.67 | 0 |

Notes:

- (1) Calculated using only "functional unavailable" hours.
- (2) Sum of "functional unavailable" + "administrative unavailable" hours.
- (3) RHR in the LPCI mode of operation.
- (*) Includes component impact and divisions or channels which are tested sequentially.

LCO LOG SHEET
 UNIT _____ DATE _____

| | | | | | | |
|----------------|--------------------|---------------------|----------------------|-------------------------------|---------------------|------------|
| SYSTEM | O.O.S Date/Time | IMPACT Date/Time | REASON: | Circle One S CH PH CH O | I.S. SECTION | S.S. INIT. |
| OPER. COND. | REFERENCE FORMS | | ACTION REQUIREMENTS: | | RETURN Date/Time | S.S. INIT |
| SYSTEM | O.O.S Date/Time | IMPACT Date/Time | REASON: | Circle One S CH PH CH O | I.S. SECTION | S.S. INIT. |
| OPER. COND. | REFERENCE FORMS | | ACTION REQUIREMENTS: | | RETURN Date/Time | S.S. INIT |
| SYSTEM | O.O.S Date/Time | IMPACT Date/Time | REASON: | Circle One S CH PH CH O | I.S. SECTION | S.S. INIT. |
| OPER. COND. | REFERENCE FORMS | | ACTION REQUIREMENTS: | | RETURN Date/Time | S.S. INIT |
| SYSTEM | O.O.S Date/Time | IMPACT Date/Time | REASON: | Circle One S CH PH CH O | I.S. SECTION | S.S. INIT. |
| OPER. COND. | REFERENCE FORMS | | ACTION REQUIREMENTS: | | RETURN Date/Time | S.S. INIT |

Daily Review _____ Reviewed _____
 initials Day Shift Supervisor / Date

Figure 1: The LCO Log Sheet





FIGURE 3: FLOWCHART OF THE METHOD USED TO ANALYZE LCO LOG SHEET ENTRIES



4.0 REFERENCES

1. NUREG-0737, "Clarification of TMI Action Plan Requirements", November, 1980..
2. NUREG-0626, "Generic Evaluation of Feedwater Transients and Small Break Loss-of-Coolant Accidents in GE-Designed Operating Plants and Near-Term Operating License Applications," Recommendation A.6, January, 1980..
3. "Final Safety Analysis Report," Susquehanna Steam Electric Station, page 18.1-103..
4. NUREG-0776, "Susquehanna SES Safety Evaluation Report," Supplement 1, page 3-159.
5. Kukielka, Sanders, Boschetti, Carr; "Safety System Unavailability Monitoring program: 1986 - A status report," Pennsylvania Power & Light, August, 1987.
6. Reliability Data Book for Components in Swedish Nuclear Power Plants, Nuclear Safety Board of the Swedish Utilities.
7. NUREG-0931, "Technical Specification Susquehanna Steam Electric Station, Unit 1," July, 1982.
8. "System Status and Equipment Control," AD-QA-302, Rev. 4, Susquehanna Steam Electric Station.
9. "Susquehanna Steam Electric Station Probabilistic Risk Assessment Report," Volume II, Rev. 1, 1986.



DATABASE STRUCTURE

APPENDIX I



Database Structure

| <u>Field Name</u> | <u>Type</u> | <u>Width</u> | <u>Field Name</u> | <u>Type</u> | <u>Width</u> |
|-------------------|-------------|--------------|-------------------|-------------|--------------|
| UNITSYSTEM | Character | 3 | CAUSE_PM | Character | 1 |
| SYS | Character | 2 | CAUSE_CM | Character | 1 |
| TS_SECTION | Character | 11 | CAUSE_S | Character | 1 |
| REF_FORM1 | Character | 14 | CAUSE_MOD | Character | 1 |
| REF_FORM2 | Character | 14 | VALID | Character | 1 |
| REF_FORM3 | Character | 14 | FAILURE | Character | 1 |
| RHR_MODE | Character | 1 | CRIT_TIME | Numeric | 7 |
| OOS_DATE | Date | 8 | SD_TIME | Numeric | 7 |
| OOS_TIME | Character | 4 | CRITSDTIME | Numeric | 7 |
| MOD_DATE | Date | 8 | PLANT_STAT | Character | 1 |
| MOD_TIME | Character | 4 | SYSTEM | Character | 1 |
| RETRN_DATE | Date | 8 | DIVISION | Character | 1 |
| RETRN_TIME | Character | 4 | CHANNEL | Character | 1 |
| COMPONENT | Character | 5 | COMP | Character | 1 |
| ID | Character | 11 | REPAIRTIME | Numeric | 7 |
| DESCRIPTION | Character | 254 | NAME | Character | 40 |
| | | | ANAL_BY | Character | 3 |
| | | | REV_BY | Character | 3 |

The UNITSYSTEM field (UNITSYSTEM) - contains a one character unit designator (1 for Unit 1, 2 for Unit 2, or 0 for systems which affect both units) in the first position and a two character system designator in the second and third positions. The system designator is defined to be the plant startup system number.

The SYSTEM field (SYS) - contains a two character code for the unavailable system. This is the same as the two characters in the Unitsystem field.

The TECHNICAL SPECIFICATION field (TS_SECTION) - contains the Susquehanna Technical Specification number taken from the LCO log sheet.

The REFERENCE FORM fields (REF_FORM1 - 3) - contains the Susquehanna procedure numbers, work authorization numbers, or equipment release form numbers taken from the LCO log sheet. These reference forms are used to identify what task(s) were performed during the outage.

The RHR MODE field (RHR_MODE) is unique to the RHR system and contains which mode of RHR was affected by the outage (Mode 1 is RHR general, Mode 2 is suppression pool cooling, Mode 3 is shutdown cooling, Mode 4 is low pressure coolant injection mode, and Mode 5 is containment spray).

The OUT OF SERVICE (OOS) Date field (OOSDATE) - contains the OOS date taken from the LCO log sheet.

The OOS TIME field (OOS_TIME) - contains the OOS time taken from the LCO log sheet.

The MODIFIED OOS DATE field (MOD_DATE) - contains the modified OOS date. This date is used to calculate the unavailable time when there is an overlap in LCO time/date periods for the system, division (channel, or component).

The MODIFIED OOS TIME field (MOD_TIME) - contains the modified OOS time. This time is used to calculate the unavailable time when there is an overlap LCO in time periods for the system (division, channel, or component).

The RETURN TO SERVICE DATE field (RETRN_DATE) - contains the date that the system was declared operable and was taken from the LCO log sheet.

The RETURN TO SERVICE TIME field (RETRN_TIME) - contains the time that the system was declared operable and was taken from the LCO log sheet.

The COMPONENT field (COMPONENT) - contains a five character code.

The COMPONENT IDENTIFIER field (ID) - contains the specific Susquehanna component identification designator taken from the LCO log sheet or from reference forms.

The DESCRIPTION field (DESCRIPTION) - contains the problem description taken from the LCO log sheet or reference forms.

The PREVENTATIVE MAINTENANCE CAUSE field (CAUSE_CM) - contains a 'Y' if the unavailability was due to corrective maintenance being performed.

The TEST CAUSE field (CAUSE_S) - contains a 'Y' if the unavailability was due to a test being performed.

The PLANT MODIFICATION CAUSE field (CAUSE_MOD) - contains a 'Y' if the unavailability was due to plant modifications being performed.

The VALID field (VALID) - contains a 'Y' if the task being performed resulted in a functional unavailability or contains a 'N' if the unavailability was administrative.

The FAILURE field (FAILURE) - contains a 'Y' if the unavailability resulted from a component failure, or contains 'N' if no failure occurred.

The CRITICAL UNAVAILABLE Hours field (CRIT_TIME) - contains the unavailable hours while the reactor was critical.

The SHUTDOWN UNAVAILABLE HOURS field (SD_TIME) - contains the unavailable hours when the reactor was shutdown.

The TOTAL UNAVAILABLE HOURS field (CRITSDTIME) - contains the total unavailable hours (critical plus shutdown unavailable hours).

The PLANTS STATUS FIELD (PLANSTAT) - contains the plant mode of operation (per the Technical Specifications) when the system outage occurred.

The SYSTEM LEVEL UNAVAILABILITY field (SYSTEM) - contains a 'Y' if the unavailability was at the system level.

The DIVISION LEVEL UNAVAILABILITY field (DIVISION) - contains the division (i.e., 1 or 2) if the unavailability was at the division level.

The CHANNEL LEVEL UNAVAILABILITY field (CHANNEL) - contains the channel (i.e., A, B, C, or D) if the unavailability was at the channel. A '*' in the field means that each channel was tested sequentially.

The COMPONENT LEVEL UNAVAILABILITY field (COMP) - contains a 'Y' if the unavailability was at the component level.. A '*' in the field means that each component was tested sequentially.

The REPAIR TIME field (REPAIRTIME) - contains the repair time in hours if known. (Currently not evaluated.)


The SYSTEM NAME field (NAME) - contains the system name spelled out in full.

The ANALYZED BY field (ANAL_By) - contains the initials of the individual who recorded and analyzed the LCO entry.

The REVIEWED BY field (REV_BY) - contains the initials of the individual who reviewed the LCO entry in the database.

APPENDIX II.

HIGH PRESSURE COOLANT INJECTION SYSTEM



HIGH PRESSURE COOLANT INJECTION SYSTEM

SYSTEM DESCRIPTION

Function

The primary function of the High Pressure Coolant Injection (HPCI) system is to provide makeup water during events which reduce reactor water inventory and do not cause a rapid depressurization. The HPCI system is part of the emergency core cooling system (ECCS). The system is redundant to the reactor core isolation cooling (RCIC) system and can perform the makeup function of the RCIC system in the event of its failure.

Design and Operation

The HPCI system is a single loop system consisting of turbine-driven injection and booster pumps, piping, valves, controls, and instrumentation. A simplified flow diagram is shown in Figure 4. The system is designed to pump water into the reactor vessel with a maximum capacity of 5000 gpm for a range of reactor pressures between 150 and 1150 psig. Two sources of cooling water are available, the condensate storage tank (CST), which contains demineralized water, and the suppression pool. Initially, the HPCI pump takes suction from the CST through normally open manual valve F010 and motor-operated valve (MOV) F004. The pump suction automatically transfers to the suppression pool on low CST level or high suppression pool level. This transfer is accomplished by a signal that opens the suppression pool suction valve, F042. Once valve F042 is fully open, valve-position-limit switch contacts act to automatically close the CST suction valve, F004. The system is designed to take suction from a source that is less than 170°F. Events which raise the suppression pool temperature above 170°F may require a manual suction transfer back to the CST. The pump is located below the level of the CST and the suppression pool to ensure a positive suction head from either source.

Upon initiation of the HPCI system, a normally closed injection valve, F006, automatically opens, allowing water to be pumped into the reactor vessel through the main feedwater header B. The feedwater spargers distribute the flow within the downcomer, causing the injected water to mix with water or steam in the vessel. A minimum-flow bypass is provided for pump protection. The bypass valve, F012, automatically opens on a low-flow signal when pump discharge pressure is greater than 125 psig. This valve automatically closes on a high-flow signal. When the bypass is open, flow is directed to the suppression pool. A full-flow test line is also provided to recirculate water back to the CST. The two isolation valves, F008 and F011, are equipped with interlocks to automatically close the test line (if open) upon generation of a HPCI initiation signal.

The HPCI turbine is driven by reactor steam. The inboard and outboard HPCI isolation valves, F002 and F003, in the steam line to the HPCI turbine are normally open to keep the piping to the turbine at an elevated temperature, thus permitting rapid startup of the HPCI system. Upon receiving a signal from the HPCI isolation logic, these valves will close and cannot be reopened until the isolation signal is cleared and the logic is reset. Isolation valve F002 is powered from Division I 480 V AC power and controlled by isolation logic system A; F003 is powered from Division II 250 V DC power and controlled by isolation logic system B.

Steam is admitted to the HPCI turbine through supply valve F001, turbine stop valve 15612, and turbine control valve 15611, all of which are normally closed and are opened by a HPCI initiation signal. Exhaust steam from the turbine is discharged to the suppression pool, while condensed steam from the steam lines and leakage from the turbine gland seals are routed to a barometric condenser.

The HPCI system is automatically actuated on low reactor water level (level 2) or high drywell pressure. If automatic actuation fails, the system can be manually initiated from the control room.

A HPCI initiation signal automatically results in an actuation signal to the following valves:

- 1.. Normally closed HPCI turbine cooling-water valve F059 receives "open" signal.
- 2.. Normally closed HPCI full flow test valves F008 and F011 receive "close" signals.
- 3.. Normally open HPCI/CST suction valve F004 receives "open" signal.
- 4.. Normally closed HPCI pump injection valve F006 receives "open" signal.
- 5.. Normally closed HPCI steam supply valve F001 receives "open" signal.
- 6.. Normally open HPCI pump-discharge valve F007 receives "open" signal.

The initiation of HPCI also automatically starts the condenser vacuum pump and the auxiliary lubricating oil pump, which is required to open the hydraulically operated turbine stop valve 15612 and turbine control valve 15611.

The HPCI flow controller, which provides a control signal to the control valve, 15611, can be operated in an automatic or a manual mode. When the flow controller is in the automatic mode, the HPCI pump flow rate and turbine speed will automatically satisfy and maintain the flow-control setpoint value. The setpoint can be manually changed by the operator in order to maintain the reactor water level.

There are several diagnostic trip signals that shut down the HPCI turbine by closing the turbine stop valve, 15612. Minimum flow valve F012 and injection valve F006 are subsequently closed.

A HPCI turbine trip results from any of the following:

1. Two of two high reactor water level signals (level 8).
2. Remote manual turbine trip.
3. Low pump suction pressure.
4. High turbine exhaust pressure (50 psig).
5. Turbine overspeed.

6. Isolation of the HPCI steam supply (see below).

With the exception of the trip caused by a high reactor water level and HPCI isolation, the HPCI system will automatically restart once the trip signal is cleared. The signal for a high reactor water level "seals in" but is reset if a subsequent low-level (level 2) signal is received, allowing the system to automatically restart.

The HPCI steam supply is isolated manually or automatically by closing the inboard and/or outboard isolation valves. There is no automatic reopen capability. The automatic isolation results from any of the following:

1. High differential temperature in the HPCI equipment area.
2. High temperature in the HPCI equipment area.
3. High differential temperature in the steam line space.
4. High temperature in the steam line space.
5. High flow in the steam line.
6. High pressure in the exhaust line of the turbine rupture disks.
7. Low steam supply pressure (104 psig).
8. High temperature in the inlet to the equipment room emergency air cooler.
9. Manual isolation if the system has been initiated.

When the HPCI system is operating, the operator controls the flow rate by adjusting the HPCI flow controller as indicated earlier. When the system is automatically initiated, it is set to deliver full flow (5000 gpm). For most events if the operator fails to take control of the flow, the reactor water level will cycle between the set levels for HPCI initiation and trip, levels 2 and 8, respectively.

Extensive indication of system status is available in the control room. Specific indications include the following:

1. Pump discharge flow.
2. Pump discharge pressure.
3. Position of all motor-operated valves.
4. Turbine inlet pressure.
5. Low level in the condensate storage tank.
6. Suppression pool level.
7. Suppression pool temperature.
8. Turbine exhaust pressure.
9. Pump suction pressure.

System Interfaces

Instrumentation

The HPCI water source is normally the CST. An automatic transfer of pump suction from the CST to the suppression pool occurs on low CST level or high suppression pool level. Level in the CST is monitored by two level switches, either of which can initiate suction transfer. The same is true of suppression pool level. The CST instrumentation and logic is completely independent of that from the suppression pool. The instrumentation that initiates HPCI suction transfer is independent of that which initiates RCIC suction transfer.

Electric Power

The initial startup and operation of the HPCI system is completely independent of AC power supplies. The system requires 250 V DC power for the auxiliary lubricating oil pump, the condensate transfer pump, and the motor-operated valves; 125 V DC power is required for the turbine-driven pump flow controller and the instrumentation associated with HPCI initiation and operation. The DC power is supplied from the ESS bus through a charger or, in the event of AC power failure, from 125 V and 250 V batteries.

The fans of the two room cooling units require 480 V AC power. The HPCI steam-supply isolation valve (F002) is supplied by 480 V AC power. However, the valve is normally open and is therefore not required to operate during system startup or operation.

Room/Pump Cooling

In order to ensure correct operation of the HPCI control system, the temperature of the HPCI pump room must be maintained within prescribed limits. This temperature control is normally provided by reactor building zone I HVAC. Zone I HVAC is shut down by a low reactor water level (level 2) or high drywell pressure. These same signals will initiate the Emergency Service Water (ESW) system, which will automatically circulate water through the two redundant room cooling units. The HVAC system will also be unavailable in the event of a loss of offsite power. However, ESW will be initiated automatically by the diesel start logic. The room cooling units are both supplied by ESW loop B. However, there is a plant modification that will allow both loop A and B to each feed one room cooler (this is to be completed in 1987). The fans of the cooling units are interlocked to start when the HPCI steam supply valve (F001) is opened. The turbine and pump lubricating oil is cooled by water supplied from the discharge of the pump.

Water Sources

The CST (the normally aligned suction source) and the suppression pool (the alternative source) are shared with other systems (e.g., RCIC, CSS, LPCI).

The condensate storage facility consists of two 300,000 gallon tanks, one for each reactor unit, and a single (shared) 680,000 gallon refueling water storage tank. There are numerous interconnections between the tanks, and condensate transfers can be accomplished by means of the refueling water pumps and condensate transfer pumps.

Each CST is designed to maintain a minimum reserve of 135,000 gallons specifically for the use of the HPCI and RCIC systems in the particular unit. CST level is normally maintained between 165,000 gallons (the low level alarm setpoint) and 270,000 gallons (the high level alarm setpoint).

The HPCI system pipes are normally pressurized by means of the condensate transfer system to prevent waterhammer on initiation. This system was not modeled, but the rate of pipe failure (rupture) that was used in the fault tree implicitly includes the effect of failure in the condensate transfer system.

Table 8. AC power supplies for HPCI


| ESF 4.16 kV bus | 480 V MCC bus | Component supplied |
|-----------------|---------------|--------------------|
| 1A202 | 1B226 | Room cooler A fan |
| 1A203 | 1B237 | 1F002 |
| 1A204 | 1B247 | Room cooler B fan |

Table 9. DC power supplies for HPCI

| Load center | Distribution panel or control center | Component supplied |
|-------------|------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1D622 | 125 V DC distribution panel 1D624 | HPCI logic Pneumatic valves: 1F029 1F054 1F025 |
| 1D612 | 125 V DC distribution panel 1D614 | HPCI logic Pneumatic valves: 1F026 1F028 |
| 1D662 | 250 V DC control center 1D254 1D264 1D274 | Motor-operated valves: 1F079 Motor-operated valves: 1F001 ^a 1F003 1F004 1F006 ^a 1F011 1F012 ^a 1F042 1F059 ^a 1F075 Motor-operated valves: 1F007 1F008 1F066 Vacuum pump Condensate pump Auxiliary lube oil pump |

^aValves that change position for the automatic initiation of HPCI.

11-7



SUSQUEHANNA
STEAM ELECTRIC STATION

SIMPLIFIED DIAGRAM
OF THE
HPCI SYSTEM

FIGURE 4

REV. 01

| U N 1 Y | S L S Y | P L N Y | C O N T | TECH. SPEC | OOS DATE | OOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDN TIME (HRS) | TOTAL TIME (HRS) | P M E O | C O M P O N E N T I D | S O C C Y I H O S V A M N P | V F A A L I D L | DESCRIPTION OF EVENT |
|------------------|------------------|------------------|------------------|------------|----------|----------|----------|----------|-------------|-------------|-----------------|-------------------|------------------|------------------|-----------------------------------------------------|--------------------------------------------------------------------|--------------------------------------|--------------------------------------------------------------------------------------------------------------------------------|
| 152 | 1 | 3.5.1 | | | 05/22/83 | 1325 | 06/22/83 | 1325 | 06/22/83 | 1515 | 1.83 | 0.00 | 1.83 | Y | N/A | Y | N N | INVESTIGATE POSSIBLE FLOW ERROR IN HPCI SYS. |
| 152 | 1 | 3.5.1 | | | 06/24/83 | 0838 | 06/24/83 | 0838 | 06/24/83 | 0839 | 0.02 | 0.00 | 0.02 | Y | IN012A-D | Y | N N | HPCI STEAM SYS. ISOL HPCI OOS DUE TO SI-152-211. (CHANNEL CHECK OF TURBINE EXHAUST DIAPHRAGM PRESSURE CHANNELS IN012A THRU D.) |
| 152 | 1 | 3.5.1 | | | 05/02/83 | 1120 | 08/02/83 | 1120 | 08/02/83 | 1945 | 8.42 | 0.00 | 8.42 | Y | IN005 | Y | N N | HPCI FAILED TO PASS REQUIREMENT OF SO-152-002. |
| 152 | 1 | 3.5.1 | | | 08/05/83 | 0115 | 08/05/83 | 0115 | 08/06/83 | 2050 | 43.58 | 0.00 | 43.58 | Y | IF059 | Y | Y Y | HPCI L.O CLR VLV IF059 EKR TRIPPED WILL NOT STAY RESET. |
| 152 | 1 | 3.5.1 | | | 09/27/83 | 0900 | 09/27/83 | 0900 | 09/29/83 | 0446 | 43.77 | 0.00 | 43.77 | Y | IN017A/B | Y | N N | HPCI OOS DUE TO WORK ON PSHIN017A/B. |
| 152 | 1 | 3.5.1 | | | 10/01/83 | 0330 | 10/01/83 | 0330 | 10/01/83 | 0545 | 2.25 | 0.00 | 2.25 | Y | N/A | Y | Y N | HPCI OOS DUE TO EKRS OPENED FOR THERMAL INSPECTION. |
| 152 | 1 | 3.5.1 | | | 10/03/83 | 0656 | 10/03/83 | 0656 | 10/03/83 | 1650 | 11.90 | 0.00 | 11.90 | Y | IF059 | Y | Y N | HPCI OOS IF059 VALVE DE-ENERGIZED FOR OPERATOR INSPECTION. |
| 152 | 1 | 3.5.1 | | | 10/05/83 | 1050 | 10/05/83 | 1050 | 10/05/83 | 1108 | 0.30 | 0.00 | 0.30 | Y | IF012 | Y | N N | OPENED IF012 MAIN FLOW VLV & EKR FOR MAINT TO CHECK SEAL. |
| 152 | 1 | 3.5.1 | | | 11/30/83 | 0950 | 11/30/83 | 0950 | 11/30/83 | 2055 | 11.08 | 0.00 | 11.08 | Y | N/A | Y | Y N | HPCI O/S FOR SO-152-003 WILL BE O/S FOR HOURS. (18 MONTH HPCI SYSTEM AND LOGIC FUNCTIONAL TEST.) |
| 152 | 2 | 3.5.1/3.0.3 | | | 12/04/83 | 0910 | 12/04/83 | 0910 | 12/04/83 | 1145 | 0.00 | 2.58 | 2.58 | Y | N/A | Y | Y N | HPCI O/S FOR SO-152-003. |
| ### Total ### | | | | | | | | | | | 123.15 | 2.58 | 125.73 | | | | | |

| U S | P C | TECH. SPEC | DOO DATE | DOO TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M | COMPONENT ID | S D C C | Y F | DESCRIPTION OF EVENT |
|---------------|-----|-------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---------|--------------|---------|-----|-------------------------------------------------------------------------------------------------------|
| N Y | L O | | | | | | | | | | | M E O | | Y I H O | A A | |
| I S | M N | | | | | | | | | | | S D | | S V A N | L I | |
| I | T D | | | | | | | | | | | T | | N P | O L | |
| 152 | 1 | 3.5.1 | 02/21/84 | 0700 | 02/21/84 | 0700 | 02/21/84 | 0915 | 2.25 | 0.00 | 2.25 | Y | 1F003 | Y | N N | HPCI INOP. OPENED HPCI OUTBOARD STM SUPPLY VALVE (HV-1F003) BEFORE 10264031. |
| 152 | 1 | 3.5.1 | 05/09/84 | 1800 | 05/09/84 | 1800 | 05/09/84 | 2200 | 4.00 | 0.00 | 4.00 | Y | 1U209A | Y | N N | HPCI "B" LOOP ROOM COOLER DOO FOR CLEANING. |
| 152 | 1 | 3.5.1 | 05/19/84 | 1424 | 05/19/84 | 1424 | 05/20/84 | 1257 | 22.55 | 0.00 | 22.55 | Y | 1F204 | Y | N N | HPCI INOP WILL NOT PUMP > 5000GPM AT 12000 PER SW R1002. ALSO, OIL LEAK. |
| 152 | 1 | 3.5.1 | 05/22/84 | 2217 | 05/22/84 | 2217 | 05/22/84 | 2255 | 0.63 | 0.00 | 0.63 | Y | 1F002 | Y | Y N | HPCI OUT OF SERVICE FOR PERFORMANCE OF SO-152-004. |
| 152 | 1 | 3.5.1 | 06/18/84 | 0952 | 06/18/84 | 0952 | 06/18/84 | 1140 | 1.80 | 0.00 | 1.80 | Y | 1N005 | Y | N N | HPCI NOT IN AUTO TO PERFORM SO-152-002. |
| 152 | 2 | 3.5.1.C | 07/03/84 | 1545 | 07/03/84 | 1545 | 07/03/84 | 2000 | 0.00 | 4.25 | 4.25 | Y | 1F005 | Y | Y Y | HPCI ISOLATED FROM SERVICE DUE TO DISCHARGE CHECK VALVE NOT HOLDING AND LIFTING SUCTION RELIEF VALVE. |
| 152 | 1 | 3.5.1 | 07/31/84 | 0720 | 07/31/84 | 0720 | 07/31/84 | 2215 | 14.92 | 0.00 | 14.92 | Y | N/A | Y | Y N | HPCI SYS OUT OF SERVICE TO REPACK VARIOUS VALVES. |
| 152 | 1 | 3.3.2.6 | 09/12/84 | 1330 | 09/12/84 | 1330 | 09/12/84 | 1410 | 0.67 | 0.00 | 0.67 | Y | 1N001D | Y | N N | STEAM LINE LOW PRESSURE SWITCH PSL E11-1N001D FOR HPCI ISOLATION LOGIC INCP FOR MAINTENANCE. |
| 152 | 1 | 3.5.1 | 10/18/84 | 1450 | 10/18/84 | 1450 | 10/19/84 | 0420 | 6.52 | 6.98 | 13.50 | Y | 1P204 | Y | Y N | HPCI SYS DECLARED INOP DUE TO EXCESSIVE VIBRATION ON MAIN PUMP. |
| 152 | 1 | 3.5.1 | 11/11/84 | 0940 | 11/11/84 | 0940 | 11/11/84 | 0942 | 0.03 | 0.00 | 0.03 | Y | 1F003 | Y | N N | HPCI O/S TO STOP E 1F003 O.B STM ISOLATION. |
| 152 | 1 | 3.5.1 | 11/20/84 | 1600 | 11/20/84 | 1600 | 11/20/84 | 1700 | 1.00 | 0.00 | 1.00 | Y | 1F002 | Y | Y N | HPCI O/S FOR SO-152-004. |
| 152 | 1 | 3.5.1 | 12/14/84 | 1330 | 12/14/84 | 1330 | 12/14/84 | 1358 | 0.47 | 0.00 | 0.47 | Y | 1N005 | Y | N N | HPCI FLOW CONTROLLER IN MANUAL FOR SO-152-002. |
| 152 | 1 | 3.6.3/3.5.1 | 12/20/84 | 1340 | 12/20/84 | 1340 | 12/20/84 | 1640 | 3.00 | 0.00 | 3.00 | Y | 1F003 | Y | N N | MANUALLY ENCASED HPCI STEAM SUPPLY VALVE 1F003 TO STOP STEAM LEAK. |
| ### Total ### | | | | | | | | | 57.84 | 11.23 | 69.07 | | | | | |


| U S N I | P C L S T | TECH. SPEC | DOO DATE | DOO TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M | COMPONENT ID | S O C C | Y I H G | Z F A A L I | DESCRIPTION OF EVENT |
|-----------|-----------|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---------|--------------|---------|---------|-------------|------------------------------------------------------------------------------------------|
| 152 | 1 | | 01/28/86 | 1640 | 01/28/86 | 1640 | 01/28/86 | 1600 | 1.33 | 0.00 | 1.33 | Y | 1N0248/D | | Y | N | REACTOR WATER LEVEL SWITCH CALIBRATION (1N0248/D). |
| 152 | 1 | | 01/29/86 | 2206 | 01/29/86 | 2200 | 01/30/86 | 1135 | 13.58 | 0.00 | 13.58 | Y | N/A | Y | | N | QUARTERLY VALVE EXERCISING (40-152-004). |
| 152 | 1 | | 01/30/86 | 0330 | 01/30/86 | 0730 | 01/30/86 | 0730 | 0.60 | 0.60 | 0.00 | Y | 1-55-001 | Y | | N | UNAVAILABLE TO BACKSEAT INSTRUMENTATION ROOT VALVE LSH-IN014. |
| 152 | 1 | | 04/20/86 | 1550 | 04/20/86 | 1550 | 04/20/86 | 1847 | 2.95 | 0.00 | 2.95 | Y | 1P204 | Y | | N | HPCI PUMP TUNEUP. |
| 152 | 4 | | 04/21/86 | 2002 | 04/21/86 | 2002 | 04/22/86 | 0330 | 3.97 | 3.50 | 7.47 | Y | 1F003 | Y | | N | F14 VALVE 1F003 VALVE PACKING (UNIT SHUT DOWN). |
| 152 | 1 | | 04/29/86 | 0945 | 04/29/86 | 0945 | 04/29/86 | 1140 | 1.92 | 0.00 | 1.92 | Y | 1F006 | Y | | N | HPCI PUMP PERFORMANCE VERIFICATION EST TO-CST (INJECTION VALVE CLOSED AND DE-ENERGIZED). |
| 152 | 1 | | 05/15/86 | 1338 | 05/15/86 | 1338 | 05/15/86 | 1560 | 1.37 | 0.00 | 1.37 | Y | 1N0248/D | | Y | N | SURVEILLANCE OF REACTOR WATER LEVEL INITIATION SWITCHES (1 OF 4 AT A TIME). |
| 152 | 1 | | 07/11/86 | 1115 | 07/11/86 | 1115 | 07/11/86 | 1215 | 1.00 | 0.00 | 1.00 | Y | 1N0248/D | | | N | REACTOR WATER LEVEL TRIP SWITCH CALIBRATION. |
| 152 | 1 | | 07/15/86 | 0200 | 07/15/86 | 0200 | 09/18/86 | 2000 | 1436.65 | 141.35 | 1578.00 | Y | 1F100 | Y | | N | VALVE 1F100 DUAL INDICATION. |
| 152 | 1 | | 08/11/86 | 1115 | 08/11/86 | 1115 | 08/11/86 | 1145 | 0.50 | 0.00 | 0.50 | Y | 1N0248-D | | | N | SURVEILLANCE OF INITIATION SWITCHES. |
| 152 | 1 | | 09/09/86 | 1030 | 09/09/86 | 1030 | 09/09/86 | 1110 | 0.67 | 0.00 | 0.67 | Y | 1N0248/D | | | N | REACTOR WATER HIGH LEVEL TRIP FUNCTIONAL TEST. |
| 152 | 1 | | 10/10/86 | 1030 | 10/10/86 | 1030 | 10/10/86 | 1130 | 1.00 | 0.00 | 1.00 | Y | 1N012A-D | | | N | TURBINE EXHAUST DIAPHRAGM FAILED SURVEILLANCE (51-152-311). |
| 152 | 1 | | 10/20/86 | 1140 | 10/20/86 | 1140 | 10/20/86 | 1460 | 2.33 | 0.00 | 2.33 | Y | 1N005 | Y | | N | HPCI FLOW RATE PRESSURE TEST. |
| 152 | 1 | | 11/07/86 | 0900 | 11/07/86 | 0900 | 11/10/86 | 1600 | 81.00 | 0.00 | 81.00 | Y | 1B211 | Y | | N | REMOVE PIPE NIFFLE ON TURBINE. |
| 152 | 1 | | 11/12/86 | 0936 | 11/12/86 | 0936 | 11/12/86 | 1023 | 0.78 | 0.00 | 0.78 | Y | 1N0248/D | | | N | CALIBRATE LEVEL INITIATION SWITCHES LIS-621-1N0248 & D. |
| 152 | 1 | | 12/01/86 | 0920 | 12/01/86 | 0920 | 12/01/86 | 0950 | 0.50 | 0.00 | 0.50 | Y | 1S211 | Y | | N | HPCI MECHANICAL OVERSPEED TRIP CHECK. |
| 152 | 1 | | 12/10/86 | 0500 | 12/10/86 | 0500 | 12/13/86 | 0135 | 68.58 | 0.00 | 68.58 | Y | N/A | Y | | N | HPCI O/S FOR SYSTEM FM'S. |
| 152 | 1 | | 12/13/86 | 0846 | 12/13/86 | 0846 | 12/13/86 | 0920 | 0.57 | 0.00 | 0.57 | Y | 1N0248/D | | | N | REACTOR WATER LEVEL SENSOR FUNCTIONAL TEST FOR LIS-621-1N0248 & D. |
| 152 | 1 | | 12/26/86 | 1145 | 12/26/86 | 1145 | 12/26/86 | 1215 | 0.50 | 0.00 | 0.50 | Y | 1F002 | Y | | N | 1F002 CLOSED FOR BAYWELL LEAKAGE TESTING. |
| 152 | 1 | | 12/29/86 | 1903 | 12/29/86 | 1903 | 12/29/86 | 1951 | 0.60 | 0.00 | 0.60 | Y | 1F002 | Y | | N | 1F002 CLOSED FOR BAYWELL LEAKAGE TESTING. |
| 152 Total | | | | | | | | | 1670.00 | 144.85 | 1764.85 | | | | | | |

II-11

| U S I | P C I | TECH. SPEC | CGS DATE | DOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | F C M | COMPONENT ID | S D C C | Y F | DESCRIPTION OF EVENT |
|---------------|-------|-------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|-------|--------------|---------|-----|---------------------------------------------------------------------------------------------------|
| I | T O | | | | | | | | | | | | | | | |
| 152 | 1 | 3.5.1 | 01/02/87 | 1315 | 01/02/87 | 1315 | 01/02/87 | 1330 | 0.25 | 0.00 | 0.25 | Y | N/A | Y | Y N | HPCI INOP DURING TP (MONTHLY OVERSPEED TRIP CHECK). |
| 152 | 1 | 3.3.3.3.5.1 | 01/08/87 | 1125 | 01/08/87 | 1125 | 01/08/87 | 1635 | 5.17 | 0.00 | 5.17 | Y | IN0248/D | Y | N N | HPCI INOP DURING PERFORMANCE OF SI ON LEVEL B INSTRUMENTATION. |
| 152 | 1 | 3.5.1 | 02/02/87 | 1115 | 02/02/87 | 1115 | 02/02/87 | 1145 | 0.50 | 0.00 | 0.50 | Y | N/A | Y | Y N | HPCI INOP FOR OVERSPEED TRIP CHECK. |
| 152 | 1 | 3.5.1 | 02/05/87 | 0930 | 02/05/87 | 0930 | 02/05/87 | 1005 | 0.58 | 0.00 | 0.58 | Y | IN0248/D | Y | N N | HPCI INOP FOR IIC SURVEILLANCE ON IN0248/D. |
| 152 | 1 | 3.5.1 | 02/23/87 | 0800 | 02/23/87 | 0600 | 02/23/87 | 1700 | 9.00 | 0.00 | 9.00 | Y | 1F603 | Y | Y Y | HPCI O/S FOR INSPECTION AND REPAIR OF TOPAZ INVERTER FAILURE. |
| 152 | 1 | 3.5.1 | 03/02/87 | 1515 | 03/02/87 | 1515 | 03/02/87 | 1700 | 1.75 | 0.00 | 1.75 | Y | 1F603 | Y | Y N | HPCI INOP DURING PACKING REWORK OF 1F603. |
| 152 | 1 | 3.5.1 | 03/05/87 | 0415 | 03/05/87 | 0415 | 03/10/87 | 1200 | 127.75 | 0.00 | 127.75 | Y | N/A | Y | Y N | HPCI O/S FOR WORK ON 1F001, 1F003, 1F007, AND VARIOUS INSTRUMENTATION. ALSO PERFORMED 50-152-002. |
| 152 | 1 | 3.5.1 | 03/10/87 | 1401 | 03/10/87 | 1401 | 03/10/87 | 1445 | 0.73 | 0.00 | 0.73 | Y | IN0248/D | Y | N N | HPCI O/S FOR IIC SURVEILLANCE ON IN0248/D (54" TRIP). |
| 152 | 1 | 3.6.3 | 03/12/87 | 1300 | 03/12/87 | 1300 | 03/12/87 | 1430 | 1.50 | 0.00 | 1.50 | Y | 1F603 | Y | Y N | HPCI STEAM SUPPLY VALVE (1F603) REQUIRED PACKING ADJUSTMENT. |
| 152 | 1 | | 04/27/87 | 1730 | 04/27/87 | 1730 | 04/27/87 | 2240 | 5.17 | 0.00 | 5.17 | Y | N/A | Y | N N | PIPE ROUTING AREA TSH FAULTY - AFFECTS ISOLATION ONLY. |
| 152 | 1 | 3.6.3.3.5.1 | 05/22/87 | 0015 | 05/22/87 | 0015 | 05/22/87 | 1830 | 18.25 | 0.00 | 18.25 | Y | 1F602 | Y | Y N | HPCI INOP FOR 1F602 MODIFICATION WORK. |
| 152 | 1 | 3.5.1 | 05/26/87 | 0745 | 05/26/87 | 0745 | 05/26/87 | 1000 | 2.25 | 0.00 | 2.25 | Y | 1F603 | Y | Y N | HPCI INOP FOR MAINTENANCE TO RETROGRADE PRESSURE SEAL FOR OUTBOARD ISOLATION VALVE 1F003. |
| 152 | 1 | 3.5.1 | 05/26/87 | 2141 | 05/26/87 | 2141 | 05/26/87 | 2200 | 0.32 | 0.00 | 0.32 | Y | 1F603 | Y | N N | HPCI INVERTER O/S FOR TEST EQUIPMENT HOOPUP. |
| 152 | 1 | 3.5.1 | 05/27/87 | 1715 | 05/27/87 | 1715 | 05/27/87 | 1950 | 2.58 | 0.00 | 2.58 | Y | 1F603 | Y | Y N | HPCI O/S TO PERFORM CALIBRATION OF TOPAZ INVERTER. |
| 152 | 1 | 3.6.3 | 06/05/87 | 1125 | 06/05/87 | 1125 | 06/05/87 | 1250 | 1.42 | 0.00 | 1.42 | Y | IN012A/C | Y | N N | HPCI O/S TO REPLACE BANANA JACKS FOR HPCI TURBINE EXHAUST PRESSURE SENSORS (FSH-IN012A/C). |
| 152 | 1 | 3.5.1 | 06/15/87 | 0500 | 06/15/87 | 0500 | 06/16/87 | 0700 | 26.00 | 0.00 | 26.00 | Y | N/A | Y | Y N | HPCI TAKEN O/S FOR SCHEDULED EQ INSPECTION. |
| 152 | 1 | 3.3.3.3.5.1 | 07/07/87 | 1310 | 07/07/87 | 1310 | 07/07/87 | 1435 | 1.58 | 0.00 | 1.58 | Y | IN0248/D | Y | N N | HPCI O/S FOR IN0248/D SURVEILLANCE (54" TRIP). |
| 152 | 1 | | 08/05/87 | 0850 | 08/05/87 | 0850 | 08/05/87 | 1115 | 2.42 | 0.00 | 2.42 | Y | N/A | Y | Y N | HPCI OUT OF SERVICE FOR SURVEILLANCE (VALVE EXERCISING). |
| 152 | 1 | | 08/06/87 | 1428 | 08/06/87 | 1428 | 08/06/87 | 1454 | 0.47 | 0.00 | 0.47 | Y | IN0248/D | Y | N N | HPCI HIGH LEVEL CALIBRATION SI. |
| 152 | 1 | 3.3.3.3.5.1 | 09/03/87 | 1406 | 09/03/87 | 1406 | 09/03/87 | 1445 | 0.65 | 0.00 | 0.65 | Y | IN0248/D | Y | N N | HPCI O/S FOR SI. |
| 152 | 5 | 3.4.B | 10/14/87 | 1400 | 10/14/87 | 1400 | 11/05/87 | 1710 | 0.00 | 531.17 | 531.17 | Y | 08A-102-1A | Y | N N | HPCI STEAM LINE WELD 08A-102-1-1A FAILED IN-SERVICE INSPECTION (ISIT). |
| 152 | 1 | 3.5.1 | 11/21/87 | 1700 | 11/21/87 | 1700 | 11/21/87 | 1900 | 2.10 | 0.00 | 2.10 | Y | 1F606 | Y | N N | HPCI O/S FOR SI WITH UNIT SHUTDOWN AND DEPRESSURIZED. |
| 152 | 1 | 3.5.1 | 12/08/87 | 0845 | 12/08/87 | 0845 | 12/08/87 | 0925 | 0.67 | 0.00 | 0.67 | Y | IN0248/D | Y | N N | HPCI O/S FOR SI ON HIGH LEVEL TRIP. |
| 152 | 1 | 3.5.1 | 12/10/87 | 0445 | 12/10/87 | 0445 | 12/10/87 | 1615 | 5.50 | 0.00 | 5.50 | Y | N/A | Y | N N | PACKING ADJUSTMENT ON 1F001 AND 1F007 VALVES. |
| 152 | 1 | 3.5.1 | 12/31/87 | 1010 | 12/31/87 | 1010 | 12/31/87 | 1700 | 6.83 | 0.00 | 6.83 | Y | 1F607 | Y | N N | PACKING ADJUSTMENT ON 1F607 VALVE. |
| *** Total *** | | | | | | | | | 223.44 | 531.17 | 754.61 | | | | | |

11-12

| U S N Y I S Y | P C L O N N T O | TECH. SPEC | OOS DATE | OOS TIME | MOO DATE | MOO TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDN TIME (HRS) | TOTAL P C T M TIME M H E O (HRS) S P T | COMPONENT ID | S D C C Y I H O S V A M N P D L | Y F A A L I D L | DESCRIPTION OF EVENT | |
|------------------------|--------------------------|-------------|----------|-------------|-------------|-------------|----------------|----------------|-----------------------|-------------------------|-------------------------------------------------|--------------|------------------------------------------|--------------------------|----------------------|--------------------------------------------------------------------------------------------------|
| 152 | 1 | 3.3.3.3.5.1 | 01/08/89 | 1030 | 01/08/89 | 1030 | 01/08/89 | 1100 | 0.50 | 0.00 | 0.50 | Y | 1N0248/D | I | N N | HPCI HIGH LEVEL TRIP DISABLED FOR SI. |
| 152 | 1 | 3.3.2 | 01/20/89 | 1930 | 01/20/89 | 1630 | 01/20/89 | 1305 | 2.58 | 0.00 | 2.58 | Y | N/A | Y | X N | HPCI TEMP CHANNEL O/S FOR MAINTENANCE. |
| 152 | 1 | 3.3.3.3.5.1 | 02/07/89 | 0835 | 02/07/89 | 0835 | 02/07/89 | 1000 | 1.42 | 0.00 | 1.42 | Y | 1N0248/D | I | N N | HPCI HIGH LEVEL TRIP OUT OF SERVICE FOR SI. |
| 152 | 1 | 3.3.3.3.5.1 | 02/07/89 | 1100 | 02/07/89 | 1100 | 02/07/89 | 1247 | 1.78 | 0.00 | 1.78 | Y | 1N0248/D | I | N N | HPCI HIGH LEVEL TRIP OUT OF SERVICE FOR SI. |
| 152 | 1 | 3.5.1.C | 02/19/89 | 0510 | 02/19/89 | 0510 | 02/19/89 | 1500 | 9.83 | 0.00 | 9.83 | Y | 1P204 | Y | N N | HPCI INCP FOR MAINTENANCE FM'S - CALIBRATION CHECK ON PUMP TRIPS (INSPECTED ONE AT A TIME). TFIS |
| 152 | 1 | 3.6.3 | 02/19/89 | 0940 | 02/19/89 | 0940 | 02/19/89 | 1245 | 3.08 | 0.00 | 3.08 | Y | 1F003 | Y | N N | PACKING ADJUSTMENT ON HPCI 1F003 VALVE - NO BLOCKING USED. |
| 152 | 1 | 3.6.3 | 03/23/89 | 1460 | 03/23/89 | 1460 | 03/30/89 | 0830 | 159.50 | 0.00 | 159.50 | Y | 1F100 | Y | N N | HPCI WARMUP VALVE (1F100) HAD DUEL INDICATION. |
| 152 | 1 | 3.3.9 | 03/28/89 | 1250 | 03/28/89 | 1250 | 03/28/89 | 1336 | 0.67 | 0.00 | 0.67 | Y | 1N0248/D | I | N Y | 54" TPIF DISABLED FOR SURVEILLANCE. |
| 152 | 1 | 3.3.3.3.5.1 | 04/06/89 | 1410 | 04/06/89 | 1410 | 04/06/89 | 1445 | 0.58 | 0.00 | 0.58 | Y | 1N0248/D | I | N N | HIGH LEVEL TRIP FOR HPCI O/S ONE AT A TIME FOR 1&C SURVEILLANCE. |
| 152 | 1 | | 05/03/89 | 0830 | 05/03/89 | 0830 | 05/03/89 | 1015 | 1.75 | 0.00 | 1.75 | Y | 1N0248/D | I | N N | HPCI 8X HIGH WATER LEVEL TRIP INCP FOR 1&C SURV. - INCP'S HPCI. |
| 152 | 1 | 3.5.1 | 05/09/89 | 0110 | 05/09/89 | 0110 | 05/09/89 | 0210 | 1.00 | 0.00 | 1.00 | Y | N/A | Y | N N | HPCI O/S FOR VALVE STROKE TIMING. |
| 152 | 1 | 3.3.2 | 05/12/89 | 0850 | 05/12/89 | 0850 | 05/12/89 | 1600 | 7.17 | 0.00 | 7.17 | Y | 1N0120 | Y | N N | HPCI EXHAUST DIAPHRAGM PRESS SWITCH FSH-E41-N0120 FAILED SURVEILLANCE ACCEPTANCE CRITERIA. |
| 152 | 1 | 3.5.1.C | 05/20/89 | 0125 | 05/20/89 | 0125 | 05/26/89 | 0200 | 0.58 | 0.00 | 0.58 | Y | 1P203 | Y | Y Y | HPCI INVERTER POWER FAILURE - INVERTER OUT OF SERVICE. |
| 152 | 1 | | 06/01/89 | 1121 | 06/01/89 | 1121 | 06/01/89 | 1155 | 0.57 | 0.00 | 0.57 | Y | 1N0248/D | I | N N | HPCI SYSTEM LEVEL B ACTUATION INST. O/S WHILE PERFORMING SI. |
| *** Total:*** | | | | | | | | | 191.01 | 0.00 | 191.01 | | | | | |



APPENDIX III

AUTOMATIC DEPRESSURIZATION SYSTEM



AUTOMATIC DEPRESSURIZATION SYSTEM

SYSTEM DESCRIPTION

Function

The primary function of the Automatic Depressurization System (ADS) is to depressurize the reactor during events which reduce reactor water inventory and insufficient makeup is being provided by high pressure makeup systems. The ADS rapidly decreases reactor pressure below the shutoff head of low pressure makeup systems, and below the setpoint of the low pressure injection valve permissive signal.

Design and Operation

The ADS accomplishes reactor depressurization by using 6 of the 16 Safety Relief Valves (SRVs) in the nuclear steam pressure relief system. All 16 SRVs act to protect the reactor vessel and connected piping from overpressurization by automatic and self-actuated operations which discharge reactor steam to the suppression pool. The six ADS valves have additional control circuits to perform the ADS function.

Functional Modes of the Nuclear Steam Pressure Relief System

The nuclear steam pressure relief system is designed to operate in three functional modes: the overpressure safety valve mode, the overpressure relief mode, and the depressurization (ADS) mode. These are briefly described below.

In the overpressure safety valve mode, the SRVs are self-actuated. A coil spring normally holds the valve shut against normal operating pressure (refer to Figure 5). As reactor pressure increases above the spring setpoint, it causes the valve seat to lift, compressing the spring and opening the valve. The spring setpoints are staggered to give a range of relief capacity and to distribute blowdown to the suppression pool. The SRVs reclose when the reactor pressure is reduced below that necessary to overcome the spring closing force.

Individual SRVs can be manually opened from the control room by operation of the solenoid valve. In the overpressure relief mode, a reactor pressure increase is detected by sensors. When the pressure exceeds the sensor setpoint, a signal is generated which operates a pilot solenoid valve. This solenoid valve allows gas from the Containment Instrument Gas (CIG) system to open the SRV via a pneumatic cylinder which overcomes the spring closing force (a minimum of 65 psid is required). If the Containment Instrument Gas system is unavailable, gas is supplied from an accumulator (which is sufficient for one operation against normal drywell pressure). The SRV recloses when the open signal is removed, which causes the solenoid valve to vent air from the pneumatic cylinder (to containment) and allows the spring to force the valve seat shut.

In the depressurization (ADS) mode, an initiation signal is generated during conditions of decreased reactor water inventory which is indicative of insufficient makeup from high pressure systems. These signals operate pilot solenoid valves which open the six ADS (SRVs) valves as described in the overpressure relief mode. However, these solenoid valves are separate from those performing the overpressure relief mode. In addition, there are two

solenoids per ADS (SRV) valve, one from Division 1 logic and one from Division 2 logic. The valve can be opened by either solenoid valve. The ADS solenoids connect the pneumatic cylinder to an additional accumulator to assure ADS operation even when Containment Instrument Gas is unavailable.

ADS Initiation

The initiation of ADS can occur in either of the following ways.

1. Both a high drywell pressure and a low reactor water level (level 1) are required as initiating conditions. However, ADS will actuate only if the following permissive conditions exist: low reactor water level (level 3) conformity signal and adequate discharge pressure from a Residual Heat Removal (RHR) pump or Core Spray (CS) loop (two pumps). The signals produced by these conditions start an actuation timer. After the timer runs out, an ADS initiation signal is generated. If all the initiating and permissive conditions exist when the timer runs out, ADS will be initiated. ADS can be manually initiated only if the permissive conditions exist (the lack of an initiating condition does not preclude manual initiation).
2. A low reactor water level (level 1) starts a drywell pressure signal bypass timer. When this timer runs out, the need for a high drywell pressure signal is bypassed. If the level 1 condition still exists, the actuation timer is started. After the actuation timer runs out, an ADS initiation signal is generated if all permissive conditions are satisfied (as in item 1 above).

Many provisions exist to prevent inadvertent ADS initiation. If any of the initiating or permissive conditions do not exist when the actuation timer runs out, ADS will not be initiated and the timers (bypass and actuation) will reset. The timers permit the operator to determine if ADS should occur. Clear indication is provided in the control room so that the operator can make a determination. A manual inhibit switch and a manual actuation timer reset are available to prevent or recycle initiation.

System Interfaces

Instrumentation

The initiating signal for the automatic depressurization system depends on the output of instruments that are also used to initiate other systems. These instruments sense:

1. Low reactor water (level 1).
2. Low reactor water (level 3)
3. High drywell pressure.

A permissive signal is required for the automatic initiation of the ADS valves. This signal is derived from sensors which monitor the discharge pressure of the RHR pumps and Core Spray pumps. In order to satisfy the permissive requirement, the following conditions must be fulfilled for ADS Division 1 logic: either RHR pump A is running or RHR pump C is running or Core Spray pumps A and C are running. The same conditions must be met for ADS Division 2 logic, except that RHR pumps B and D or Core Spray pumps B and D would be involved. This permissive is also required for manual initiation.


Even if these permissives do not exist, depressurization can still be accomplished by manually opening SRVs in the relief mode.

Electric Power

The automatic depressurization system requires 125 V DC power to operate the initiation logic and the SRVs. This power is supplied from the ESS buses through chargers, or, in the event of AC power failure, from two 125 V DC batteries. The power comes from 125 V DC distribution panel 1D614 for logic channels A and C and from 125 V DC distribution panel 1D624 for logic channels B and D as well as. The 10 remaining SRVs receive power from distribution panel 1D614.

Containment Instrument Gas

Containment Instrument Gas (CIG) is required for ADS operation. Two separate and independent headers are provided which are pressurized to 150 psig by the CIG compressors or bottled gas (if the compressors are unavailable). An alarm is provided in the control room on low header pressure. Each header serves three ADS valves to prevent the loss of all ADS valves due to the unavailability of a header (through blockage or leakage). Each ADS valve is also provided with an accumulator which can provide adequate gas pressure for one actuation in the event of CIG unavailability. A check valve assures each accumulator is not discharged due to a break or leak in the header (shown on Figure 6).




SUSQUEHANNA
STEAM ELECTRIC STATION

SAFETY RELIEF VALVE

FIGURE 5

REV. 01



**SUSQUEHANNA
STEAM ELECTRIC STATION**

**SIMPLIFIED DIAGRAM OF THE
STEAM PRESSURE RELIEF SYSTEM**

FIGURE 6 REV. 01

| U S F C | TECH. SPEC | ODS DATE | ODS TIME | MOO DATE | MOO TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M | COMPONENT ID | S D C C | Y F | DESCRIPTION OF EVENT |
|---------|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---------|--------------|---------|-----|-------------------------------------------------|
| I S T | N M D | | | | | | | | | | | | | | |
| 165 | 2 | 3.4.2.C | 12/04/83 | 0215 | 12/04/83 | 0215 | 12/04/83 | 1855 | 0.00 | 16.67 | 16.67 | Y | N/A | Y | N N B & A ACOUSTICAL MON INCOPERABLE FOR B SRV. |
| ### | Total | ### | | | | | | | 0.00 | 16.67 | 16.67 | | | | |

| U S I S T | P C L O N N T | TECH. SPEC | DOO DATE | DOO TIME | MOO DATE | MOO TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDN TIME (HRS) | TOTAL TIME (HRS) | F C T M N E O S O | COMPONENT ID | S O C C Y I H O A A S V A M L I N P G L | DESCRIPTION OF EVENT | |
|---------------|---------------|-------------|----------|----------|----------|----------|-------------|-------------|-----------------|-------------------|------------------|-------------------|--------------|-----------------------------------------|----------------------|------------------------------------------------------------------------------|
| 183 | 2 | 3.5.1.0 | 02/25/84 | 1437 | 02/25/84 | 1437 | 02/25/84 | 1614 | 1.62 | 0.00 | 1.62 | Y | N/A | | N N | ADS INOP FOR PERFORMANCE OF TP-125-006. |
| 183 | 2 | 3.5.1.0 | 02/25/84 | 1835 | 02/25/84 | 1835 | 02/25/84 | 2355 | 5.25 | 5.08 | 5.33 | Y | N/A | | N N | ADS INOP FOR TP-125-006. |
| 183 | 2 | 3.5.1.0 | 02/25/84 | 2350 | 02/25/84 | 2355 | 02/26/84 | 2359 | 0.00 | 23.08 | 23.08 | Y | 1F013M | | Y N Y | *M* ADS VALVE INOP. FAILED TO CLOSE DURING TESTING. |
| 183 | 2 | 3.5.1.0 | 02/26/84 | 0150 | 02/26/84 | 0150 | 02/26/84 | 0530 | 0.00 | 3.67 | 3.67 | Y | N/A | | N N | ADS INOP FOR TP-125-006. |
| 183 | 2 | 3.5.1 | 02/27/84 | 1722 | 02/27/84 | 1722 | 02/28/84 | 0338 | 5.42 | 4.85 | 10.27 | Y | 1F013M | | Y N N | *M* SKV SELENOID BLOCK REPLACEMENT. |
| 183 | 1 | 3.5.1.0.2 | 02/28/84 | 0924 | 02/28/84 | 0924 | 02/28/84 | 1012 | 0.87 | 0.00 | 0.87 | Y | N/A | | N N | ADS AIR SUPPLY ISOLATED FOR SO-183-002. |
| 183 | 1 | 3.3.3/3.5.1 | 08/28/84 | 0810 | 08/28/84 | 0810 | 08/28/84 | 1025 | 2.25 | 0.00 | 2.25 | Y | N/A | | Y N | ADS INOP FOR IIC SURVEILLANCE. |
| 183 | 1 | 3.3.3/3.5.1 | 08/30/84 | 0927 | 08/30/84 | 0927 | 08/30/84 | 0543 | 0.27 | 0.00 | 0.27 | Y | N/A | | N N | ADS INOP DUE TO PERFORMANCE OF SI-183-201. |
| 183 | 1 | 3.3.3/3.5.1 | 08/30/84 | 1311 | 08/30/84 | 1311 | 08/30/84 | 1540 | 2.48 | 0.00 | 2.48 | Y | N/A | | Y N | ADS INOP DUE TO PERFORMANCE OF SI-180-203. |
| 183 | 1 | 3.3.7.5 ? | 09/07/84 | 0750 | 09/07/84 | 0750 | 09/07/84 | 0755 | 0.13 | 0.00 | 0.13 | Y | N/A | | Y N N | ADS ACOUSTIC MONITORS O/S FOR IIC SURVEILLANCE. |
| 183 | 1 | 3.5.1 | 09/07/84 | 1255 | 09/07/84 | 1255 | 09/07/84 | 1312 | 0.28 | 0.00 | 0.28 | Y | N/A | | N N | ADS O/S FOR IIC SURVEILLANCE. |
| 183 | 1 | 3.3.3/3.5.1 | 09/19/84 | 0019 | 09/19/84 | 0019 | 09/19/84 | 0125 | 1.10 | 0.00 | 1.10 | Y | ING16A-D | | N N | IIC PERFORMING SURV ON RHR FP PERMISSIVE FOR ADS - THIS INOP'S ADS. |
| 183 | 1 | 3.3.3/3.5.1 | 09/26/84 | 0136 | 09/26/84 | 0136 | 09/28/84 | 0236 | 1.00 | 0.00 | 1.00 | Y | ING09A/B | | N N | ADS SYSTEM INOP FOR IIC SURV ON CS FP DISCH PRESS CHANNELS. |
| 183 | 1 | 3.3.3/3.5.1 | 09/28/84 | 0300 | 09/28/84 | 0300 | 09/28/84 | 0339 | 0.65 | 0.00 | 0.65 | Y | ING16A-D | | Y N | ADS SYSTEM INOP FOR IIC SURV ON DRYWELL PRESS CHANNELS. |
| 183 | 1 | 3.3.3 | 10/08/84 | 1250 | 10/08/84 | 1250 | 10/08/84 | 1326 | 0.60 | 0.00 | 0.60 | Y | N/A | | N N | ADS TIMER O/S. INOPS ADS SYS WHILE PERFORMING SURVEILLANCE. |
| 183 | 1 | 3.3.3/3.5.1 | 10/18/84 | 0356 | 10/18/84 | 0356 | 10/18/84 | 0455 | 0.98 | 0.00 | 0.98 | Y | N/A | | N N | ADS INOP DURING PERFORMANCE OF SI-149-303 ON RHR FP DISCH PRESS CHANNEL. |
| 183 | 2 | 3.5.1/3.3.3 | 10/19/84 | 0805 | 10/19/84 | 0805 | 10/19/84 | 1160 | 0.90 | 2.92 | 2.92 | Y | N/A | | N N | ADS SYSTEM INOPERABLE DURING PERFORMANCE OF SI-149-302. |
| 183 | 1 | 3.5.1 | 10/24/84 | 0515 | 10/24/84 | 0515 | 10/24/84 | 0915 | 4.00 | 0.00 | 4.00 | Y | N/A | | N N | ADS O/S TO PERFORM IIC SURVEILLANCE SI-183-308 DIVISION 1 24 HRS. |
| 183 | 1 | 3.5.1 | 10/24/84 | 0920 | 10/24/84 | 0920 | 10/24/84 | 1135 | 2.25 | 0.00 | 2.25 | Y | N/A | | N N | ADS O/S TO PERFORM IIC SURVEILLANCE SI-183-308, DIV II SWITCH. |
| 183 | 1 | 3.5.1 | 10/26/84 | 0604 | 10/26/84 | 0604 | 10/26/84 | 0606 | 0.93 | 0.00 | 0.93 | Y | N/A | | N N | ADS SYSTEM INOPERABLE DURING SI-183-301. |
| 183 | 1 | 3.3.3/3.5.1 | 10/26/84 | 1600 | 10/26/84 | 1600 | 10/26/84 | 1145 | 1.75 | 0.00 | 1.75 | Y | ING10A-D | | Y N | HIGH DRYWELL PRESS CHANNELS TO ADS SYSTEM OOS FOR PERFORMANCE OF SI-183-321. |
| 183 | 1 | 3.3.3/3.5.1 | 11/08/84 | 0940 | 11/08/84 | 0940 | 11/08/84 | 1034 | 0.90 | 0.00 | 0.90 | Y | N/A | | Y N | *A* & *B* ADS SYS INOP FOR PERFORMANCE OF SI-153-322. |
| 183 | 1 | 3.5.1 | 11/16/84 | 1250 | 11/16/84 | 1250 | 11/16/84 | 1410 | 1.33 | 0.00 | 1.33 | Y | N/A | | N N | ADS SYSTEM O/S FOR SI-149-202 AND SI-149-203. |
| 183 | 1 | 3.5.1 | 11/21/84 | 1100 | 11/21/84 | 1100 | 11/21/84 | 1150 | 0.83 | 0.00 | 0.83 | Y | N/A | | Y N | ADS SYSTEM INOP WHILE PERFORMING SI-83-205 R1 VESSEL LOW-LOW LEVEL. |
| 183 | 1 | 3.5.1 | 11/26/84 | 0845 | 11/26/84 | 0845 | 11/26/84 | 0907 | 0.37 | 0.00 | 0.37 | Y | N/A | | Y N | ADS O/S TO PERFORM SI-163-221. |
| 183 | 1 | 3.3.3/3.5.1 | 12/09/84 | 1060 | 12/09/84 | 1060 | 12/09/84 | 1010 | 0.17 | 0.00 | 0.17 | Y | N/A | | N N | ADS TIMERS INOP FOR IIC SURVEILLANCE. |
| 183 | 1 | 3.5.1 | 12/15/84 | 1311 | 12/15/84 | 1311 | 12/15/84 | 1524 | 2.22 | 0.00 | 2.22 | Y | N/A | | N N | PES INOP FOR PERFORMANCE OF SO-149-202 AND SI-140-203. |
| 183 | 1 | 3.5.1 | 12/21/84 | 0815 | 12/21/84 | 0815 | 12/31/84 | 0850 | 123.65 | 116.93 | 240.58 | Y | N/A | | N N | ADS O/S FOR IIC SURVEILLANCE SI-183-201. |
| ### Total ### | | | | | | | | | 156.30 | 156.53 | 312.83 | | | | | |

111-7

Page No. 1
 05/20/86

| U S | F C | TECH. SPEC | DOS DATE | DOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | UPIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M | COMPONENT ID | S B C C | Y F | DESCRIPTION OF EVENT |
|---------------|-----|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---------|--------------|-------------|-----|--------------------------------------------------------------------------------------|
| N Y | L O | | | | | | | | | | | N E O | | I H G A A | | |
| I S | N N | | | | | | | | | | | S D | | S V A K L I | | |
| I | T D | | | | | | | | | | | T | | N F D L | | |
| 183 | 1 | 3.5.1 | 01/08/85 | 0920 | 01/08/85 | 0920 | 01/08/85 | 0547 | 0.45 | 0.00 | 0.45 | Y | N/A | Y | N N | ADS TIMER SURV BY IIC INOP COMPLETE ADS SYS. |
| 183 | 1 | 3.3.7.5 | 01/10/85 | 0502 | 01/10/85 | 0502 | 01/11/85 | 1100 | 29.97 | 0.00 | 29.97 | Y | N/A | Y | N N | SPV "K" ACOUSTIC MONITOR INOP - SPILLING. |
| 183 | 1 | 3.5.1 | 01/15/85 | 0805 | 01/15/85 | 0805 | 01/15/85 | 1120 | 3.25 | 0.00 | 3.25 | Y | N/A | | N N | ADS SYSTEM INOPERABLE DURING SI-149-303 AND 302. |
| 183 | 1 | 3.3.3 | 01/16/85 | 1455 | 01/18/85 | 1455 | 01/18/85 | 1545 | 0.83 | 0.00 | 0.83 | Y | N/A | | Y N | SI-183-208 RA WATER LOW LEVEL 3 INOPS ADS. |
| 183 | 1 | 3.3.3 | 01/26/85 | 0900 | 01/26/85 | 0900 | 01/26/85 | 1030 | 1.50 | 0.00 | 1.50 | Y | N/A | | N N | ADS INOP DURING SI ON C.S. DISCH PRESS PERMISSIVE. |
| 183 | 1 | 3.5.1 | 01/27/85 | 1330 | 01/27/85 | 1330 | 01/27/85 | 1515 | 1.75 | 0.00 | 1.75 | Y | N/A | | Y N | ADS INOP FOR PERFORMANCE OF SI-183-321. |
| 183 | 1 | 3.5.1.0 | 02/08/85 | 1008 | 02/08/85 | 1008 | 02/08/85 | 1100 | 0.87 | 0.00 | 0.87 | Y | N/A | Y | N N | ADS INOP DURING TIMER CHECKS. |
| 183 | 1 | 3.5.1 | 11/24/85 | 2195 | 11/24/85 | 2195 | 11/25/85 | 0330 | 4.92 | 0.00 | 4.92 | Y | N/A | Y | N N | BOTH DIVISIONS OF BOTTLED AIR VALVED OUT (A DIVISION AND B DIVISION) FOR 1E-1.5-402. |
| ### Total ### | | | | | | | | | 43.54 | 0.00 | 43.54 | | | | | |

| U N I T | S Y S T E M | P L A N T | TECH. SPEC | OOS DATE | OOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CAIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL F C T M TIME (HRS) | COMPONENT ID | S Y S T E M | D I S T R I B U T I O N | C O N T R O L | V A L V E | F A U L T | DESCRIPTION OF EVENT |
|------------------|----------------------------|-----------------------|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|--------------------------|--------------|----------------------------|----------------------------------------------------------|---------------------------------|-----------------------|-----------------------|----------------------------------------------------------------------------------------|
| 163 | I | | | 04/24/86 | 0830 | 04/24/86 | 0830 | 04/24/86 | 1100 | 2.50 | 0.00 | 2.50 | Y | 1F013 | Y | N | N | | VALVE B-21-F013 - POSITION INDICATION INOPERABLE. SRV VALVE NOT ASSIGNED TO A CHANNEL. |
| 163 | I | | | 08/08/86 | 1050 | 08/08/86 | 1050 | 08/08/86 | 1140 | 0.83 | 0.00 | 0.83 | Y | 6R1140 | D | N | N | | REPLACE DRYWELL PRESSURE BYPASS TIMER 621C-11140 - CHANNEL D. |
| *** Total *** | | | | | | | | | | 3.33 | 0.00 | 3.33 | | | | | | | |

| U S P C | TECH. SPEC | DOS DATE | DOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL F 2 T H TIME (HRS) | COMPONENT ID | S D C C | Y F | DESCRIPTION OF EVENT |
|---------|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|--------------------------|--------------|---------|-----|----------------------|
| N Y L D | | | | | | | | | | M E O | | Y I N O | A A | |
| I S N N | | | | | | | | | | S D | | S V A N | L I | |
| I I O | | | | | | | | | | I | | N P | D L | |

*** Total ***

0.00 0.00 0.00

III-10



Page No. 1
 09/29/68


| U S N I S I | P C L D N N T D | TECH. SPEC | OGS DATE | OGS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL F C I M TIME H M S (HRS) | COMPONENT ID | S Y S T E M | D E S C R I P T O R | V E N T U R E | Y E A R | F A I L U R E | DESCRIPTION OF EVENT |
|----------------------|--------------------------|-------------|----------|-------------|----------|-------------|----------------|----------------|-----------------------|---------------------------|--------------------------------------|--------------|----------------------------|------------------------------------------------|---------------------------------|------------------|---------------------------------|-------------------------------------------------------------------------------------------|
| 105 | 1 | 3.3.3.3.5.1 | 04/14/68 | 0910 | 04/14/68 | 0910 | 04/14/68 | 1200 | 2.83 | 0.00 | 2.83 | Y | 14042A | Y | Y | N | | ADS 14042A DUE TO FAILURE OF 14042A TO MEET ACCEPTANCE CRITERIA WHILE PERFORMING THE SER. |
| *** Total *** | | | | | | | | | 2.83 | 0.00 | 2.83 | | | | | | | |

III-11



APPENDIX IV

CORE SPRAY SYSTEM



CORE SPRAY SYSTEM

SYSTEM DESCRIPTION

Function

The function of the reactor Core Spray (CS) system is to provide makeup water and spray cooling for the core during events which reduce reactor water inventory following reactor depressurization. The CS system is part of the low pressure Emergency Core Cooling Systems (ECCS) and is an alternative to the Residual Heat Removal (RHR) system (LPCI mode).

Design and Operation:

The CS system consists of two redundant loops, A and B. Successful system operation is dependent on the sequence of events. During some events, analysis has shown that one pump injection is sufficient to adequately cool the core, while in others, two pumps are required for success. Each loop takes suction from the suppression pool and pumps the water into a separate spray sparger above the core in the reactor vessel. An alternative suction source, through two normally locked-closed manual valves, is the Condensate Storage Tank (CST). Since the two loops are independent and are redundant, only loop A is described here and shown in the simplified diagram of Figure 7.

Each loop contains two centrifugal pumps, each of which can deliver flow needed for successful system operation and adequate spray distribution. Each pump has a capacity of 3175 gpm at a reactor pressure of 105 psig. The system is designed to take suction from a source that is less than 212°F. Events which raise the suppression pool temperature above 212°F may require a manual suction transfer to the CST. The pumps are located below the level of the suppression pool and the CST to ensure a positive suction head from either source.

The two pumps of CS loop A (pumps A and C) are aligned to take suction from the suppression pool through a normally open motor-operated valve (MOV), F001A. Each pump discharges through a separate check valve to a common header. A minimum-flow bypass line connects the discharge of each pump to the suppression pool through a common valve, F031A. This valve is normally open, and closes when the flow through the discharge header exceeds the flow setpoint. The function of the bypass line is to prevent pump damage from overheating when the discharge line valves are closed or the reactor pressure exceeds the CS discharge pressure after system initiation. A full flow test line that bypasses the reactor is provided for system full flow tests. It returns the flow to the suppression pool through a normally closed valve, F015A.

Loop A discharges to the spray spargers through a normally open valve F004A, normally closed valve F005A, testable check valve F006A, and locked-open manual valve F007A. A bypass around F006A is provided through valve F037A to equalize the pressure across the check valve disk and minimize the required opening force when testing the testable check valve F006A.

The CS system is automatically actuated by low reactor water level (level 1), or high drywell pressure and low reactor pressure. The actuation signal will start the pumps. The system will inject when an additional low reactor pressure permissive signal is also present which allows valve F005A to be

opened. The system can be manually actuated, but injection will occur only if the low reactor pressure permissive is satisfied.

When the system is operating, the operator controls the flow rate to the reactor by throttling valve F005A or stopping and starting the pumps as necessary. There is no automatic flow control of the system.

The operator has the following indications available in the control room:

1. Discharge pressure of loops A and B.
2. System flow (each loop).
3. Position indication for all motor-operated valves.
4. Pump motor currents.

System Interfaces

Instrumentation

The low reactor pressure permissive signal common to both the Core Spray and Residual Heat Removal (LPCI mode) systems, does not allow these systems to inject into the reactor until reactor pressure is below 436 psig. For the Core Spray system, this signal must exist along with a pump initiation signal before a signal to open injection valve F005 is generated. Also, the Core Spray pump discharge pressure signal is one of the permissives needed for the initiation of the Automatic Depressurization System (ADS).

Electric Power

The CS system requires 4.16 kV AC power to operate the pumps and 480 V AC power for the motor-operated valves. Also, 125 V DC power is used for the control logic of both pumps and valves. The AC power is supplied from the ESS buses, which are energized either by offsite power or, in the event of its failure, the diesel generators. The DC power is supplied from the ESS bus via a charger or, in the event of AC power failure, from four 125 V batteries.

Room/Pump Cooling

The CS system pump rooms are normally cooled by reactor building Zone I HVAC. This system is isolated by a low reactor water level (level 1) or high drywell pressure. These same signals will initiate the Emergency Service Water (ESW) system, which will automatically supply cooling water to the CS room coolers. The HVAC system will also be unavailable in the event of a loss of offsite power. However, the ESW system is initiated automatically by the diesel start logic. The pumps for a loop of Core Spray are located in the same room. The fans of the cooling units are interlocked to start when the pump breakers close.

The CS pumps do not rely on support systems for other cooling requirements. The pump seal cooling and lubricating water is supplied by the pump discharge flow.

Water Sources

The suppression pool (the normally aligned suction source) and the Condensate Storage Tank (the alternate suction source) are shared with other systems. The inventory of the suppression pool is assumed to be adequate for long term operation of all low pressure makeup systems.

The condensate storage facility consists of two 300,000 gallon tanks, one for each reactor unit, and a single (shared) 680,000 gallon refueling water storage tank. There are numerous interconnections between the tanks, and condensate transfers can be accomplished by means of the refueling water pumps and condensate transfer pumps.

Each CST is designed to maintain a minimum reserve of 135,000 gallons specifically for the use of the HPCI and RCIC systems in the particular unit. CST level is normally maintained between 165,000 gallons (the low level alarm setpoint) and 270,000 gallons (the high level alarm setpoint).

Condensate Transfer System

The system pipes are normally pressurized by means of the condensate transfer system to prevent waterhammer on initiation. This system was not modeled, but the rate of pipe failure (rupture) that was used in the fault tree implicitly includes the effect of failure in the condensate transfer system.

Table 12. AC power supplies for Core Spray

| ESF 4.16 kV bus | 480 V MCC | Component supplied |
|-----------------|-----------|-----------------------------------------------------|
| 1A201 | - | CS pump A |
| | 1B216 | F031A ^a CSS room cooler fan A |
| 1A202 | - | CS pump B |
| | 1B226 | F031B ^a F001B CS room cooler fan B |
| 1A203 | - | CS pump C |
| | 1B237 | F015A CS room cooler fan C |
| 1A204 | - | CS pump D |
| | 1B247 | F015B CS room cooler fan D |

^aValves that change position for the automatic initiation of CS.

Table 13. DC power supplies for Core Spray

| Battery | 125 V DC load center | Component supplied |
|---------|----------------------|------------------------------------------|
| 1D610 | 1D614 | CS pump A switchgear Division 1 logic |
| 1D620 | 1D624 | CS pump B switchgear Division 2 logic |
| 1D630 | 1D634 | CS pump C switchgear |
| 1D640 | 1D644 | CS pump D switchgear |

IV-5




FIGURE 7

REV.

***** CS
 BEGIN DATE: 06/08/83

 END DATE: 12/31/83

Page No. 1
 09/20/88

| U S P C | TECH. SPEC | DOS DATE | GOS MOD DATE | MOD RETURN | RETURN | CRIT | SHUTDOWN | TOTAL P C T M | COMPONENT ID | S G C C | Y F | DESCRIPTION OF EVENT |
|---------------|------------|----------|--------------|------------|-----------|----------|----------|---------------|--------------|---------|-------|--------------------------------------------------------|
| N Y L O | | | TIME | TIME DATE | TIME DATE | TIME | TIME | TIME M M E O | | Y I H O | A A | |
| I S M N | | | | | | (HRS) | (HRS) | (HRS) S D | | S V A M | L I | |
| T T O | | | | | | | | T | | N P | D L | |
| 151 1 | 3.5.1 | 08/08/83 | 0840 | 08/08/83 | 0840 | 08/08/83 | 1300 | 4.33 0.00 | 4.33 Y | IN006B | Y N M | 'A' CS LOOP INOPERABLE FOR CALIB. OF FIS-E21-1N006B. |
| 151 1 | 3.6.3 | 12/03/83 | 1442 | 12/03/83 | 1442 | 12/03/83 | 1506 | 0.00 0.40 | 0.40 Y | 1F037B | Y N N | CS F037B INTERLOCKS DEFEATED & 4LV OPEN FOR SD-00-019. |
| 151 1 | 3.6.3 | 12/03/83 | 1510 | 12/03/83 | 1510 | 12/03/83 | 1542 | 0.00 0.53 | 0.53 Y | 1F037A | Y N N | CS F037A INTERLOCK DEFEATED & 4LV OPEN FOR SD-00-019. |
| *** Total *** | | | | | | | | 4.33 0.93 | 5.26 | | | |

IV-6

| U S | P C | TECH. SPEC | 00S DATE | 00S TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M | COMPONENT ID | S O C C | V F | DESCRIPTION OF EVENT |
|---------------|-----|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---------|--------------|---------|-----|------------------------------------------------------------------------------------------------------------------|
| N Y | L O | | | | | | | | | | H M E D | | | / I H O | A A | |
| I S | N N | | | | | | | | | | S O | | | S V A M | L I | |
| T | T G | | | | | | | | | | T | | | N P | D L | |
| 151 | 3 | 3.5.2 | 01/23/84 | 0825 | 01/23/84 | 0825 | 01/23/84 | 1260 | 0.00 | 3.58 | 3.58 | Y | 1F005A/B | Y | N N | ECCS RHR AND CORE SPRAY INOP INJECTION VALVES CLOSED & DEENERGIZED FOR F-200. |
| 151 | 3 | 3.5.2 | 01/26/84 | 1640 | 01/26/84 | 1640 | 02/01/84 | 0200 | 0.00 | 129.33 | 129.33 | Y | N/A | Y | N N | ONLY ONE ECCS SUBSYSTEM (RHR LOOP) AVAILABLE WHEN S/D & WITH JUST POOL GATES INSTALLED. |
| 151 | 1 | 3.5.1 | 04/24/84 | 0616 | 04/24/84 | 0616 | 04/24/84 | 1200 | 5.73 | 0.00 | 5.73 | Y | 1U211A | Y | N N | 'A' CORE SF ROOM COOLER INOP. |
| 151 | 1 | 3.5.1.A | 10/07/84 | 0230 | 10/07/84 | 0230 | 10/07/84 | 1215 | 9.75 | 0.00 | 9.75 | Y | N/A | Y | N N | CORE SPRAY LOOP 'A' LEAK DETECTION INSTRUMENTATION QUESTIONABLE AFTER CHANGE IN D.P READINGS. |
| 151 | 1 | 3.5.1.A | 10/09/84 | 0805 | 10/09/84 | 0805 | 10/09/84 | 1220 | 4.25 | 0.00 | 4.25 | Y | 1P206A | 1 | N N | 'A' LOOP CORE SPRAY INOP FOR FM. |
| 151 | 1 | 3.5.1.E | 10/26/84 | 0115 | 10/26/84 | 0115 | 10/26/84 | 0245 | 1.50 | 0.00 | 1.50 | Y | N/A | 1 | N N | CORE SPRAY HEADER DELTA-P INSTRUMENT CHANNEL INOP FOR SI-162-201. |
| 151 | 1 | 3.5.1.A.1 | 10/26/84 | 1400 | 10/26/84 | 1400 | 10/26/84 | 1755 | 3.92 | 0.00 | 3.92 | Y | 1P206B/D | 2 | N N | CORE SPRAY PUMPS 'B' AND 'D' DECLARED INOP DUE TO FAILING ISI FOR PUMP DELTA-F DURING PERFORMANCE OF SO-151-002. |
| *** Total *** | | | | | | | | | 25.15 | 132.91 | 158.06 | | | | | |

IV-7

***** CS *****
 BEGIN DATE: 01/01/85 END DATE: 06/07/85

Page No. 1
 09/20/88

| U S | P C | TECH. SPEC | DOS DATE | DOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | F C T M | COMPONENT ID | S D C C | Y I H O A A | V F | DESCRIPTION OF EVENT |
|---------------|-----|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---------|--------------|---------|-------------|-----|--------------------------------------------------------------------------|
| I | T | | | | | | | | | | | | | | | | |
| 151 | 1 | 3.5.1.E | 07/13/85 | 1100 | 07/13/85 | 1100 | 07/13/85 | 1120 | 0.33 | 0.00 | 0.33 | Y | N/A | 1 | N N | N N | CORE SPRAY SPARGER BREAK DETECTION CHANNELS A AND B INOP FOR SI-162-201. |
| 151 | 1 | 3.5.1 | 07/17/85 | 1030 | 07/17/85 | 1030 | 07/17/85 | 1500 | 1.50 | 0.00 | 1.50 | Y | 1F031A | 1 | N N | N N | 'A' LOOP CORE SPRAY INOP DUE TO MIN FLOW VALVE FLOW SWITCH DOS FOR 16E. |
| 151 | 1 | 3.5.1 | 07/18/85 | 0825 | 07/18/85 | 0825 | 07/18/85 | 1100 | 2.58 | 0.00 | 2.58 | Y | 1F031B | 2 | N N | N N | 'B' LOOP CORE SPRAY INOP DUE TO MIN FLOW VALVE FLOW SWITCH DOS FOR 16E. |
| *** Total *** | | | | | | | | | 7.41 | 0.00 | 7.41 | | | | | | |

 BEGIN DATE: 01/01/86

 END DATE: 12/31/86


Page No. 1
 09/26/88

| U | S | P | C | TECH. SPEC | OOS DATE | OOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P | C | T | H | COMPONENT ID | S | D | C | Y | F | DESCRIPTION OF EVENT | |
|---------------|---|---|---|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---|---|---|----------|--------------|---|---|---|---|---|----------------------|-------------------------------------------------------------------------|
| N | Y | L | Q | | | | | | | | | | M | N | E | O | | | Y | N | O | N | A | | |
| I | S | N | N | | | | | | | | | | | S | D | | | | S | Y | A | M | L | I | |
| I | T | D | | | | | | | | | | | | | | | | | N | P | D | L | | | |
| 151 | I | | | | 01/29/86 | 2000 | 01/29/86 | 2000 | 01/29/86 | 2145 | 1.75 | 0.00 | 1.75 | Y | | | N/A | | | | | | N | N | ESS VALVE EXERCISING. |
| 151 | I | | | | 05/02/86 | 1330 | 05/02/86 | 1330 | 05/02/86 | 1415 | 0.75 | 0.00 | 0.75 | Y | | | 1N007A/B | | | | | | N | N | SURVEILLANCE OF HIGH/LOW PRESSURE INTERFACE VALVE LEAKAGE MONITORS. |
| 151 | I | | | | 06/30/86 | 0030 | 06/30/86 | 0030 | 06/30/86 | 0100 | 0.50 | 0.00 | 0.50 | Y | | | 1N007A/B | | | | | | N | N | SURVEILLANCE OF HIGH/LOW PRESSURE INTERFACE VALVE LEAKAGE MONITORS. |
| 151 | I | | | | 09/03/86 | 1450 | 09/03/86 | 1450 | 09/03/86 | 1845 | 3.92 | 0.00 | 3.92 | Y | | | 1N003A | | | | | | N | N | CALIBRATION CHECK OF FIE21 IN003A SENSOR IN LOOP A. |
| 151 | I | | | | 09/05/86 | 1055 | 09/05/86 | 1055 | 09/05/86 | 1321 | 2.43 | 0.00 | 2.43 | Y | | | 1F031A | | | | | | N | N | CALIBRATION CHECK OF B LOOP PI-1001B SENSOR - F031A AFFECTED. |
| 151 | I | | | | 11/16/86 | 1000 | 11/16/86 | 1000 | 11/16/86 | 1230 | 2.50 | 0.00 | 2.50 | Y | | | N/A | | | | | | N | N | CORE SPRAY SPARGER BREAK DETECTION INOP DURING SURVEILLANCE. |
| 151 | I | | | | 11/18/86 | 1250 | 11/18/86 | 1250 | 11/18/86 | 1315 | 0.42 | 0.00 | 0.42 | Y | | | 1N007A/B | | | | | | N | N | PSH 1N007A & B SENSOR INOP DURING SURVEILLANCE. ONE DIVISION AT A TIME. |
| 151 | I | | | | 12/07/86 | 1540 | 12/07/86 | 1540 | 12/21/86 | 1715 | 249.63 | 87.95 | 337.58 | Y | | | 1F015A | | | | | | N | N | 1F015A FULL FLOW TEST VALVE LEAKING. |
| *** Total *** | | | | | | | | | | | 261.90 | 87.95 | 349.85 | | | | | | | | | | | | |

| U S N Y I S T | P C L O N N T G | TECH. SPEC | DOS DATE | DOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M M E O S O T | COMPONENT ID | S D C C Y I H O S V A M N P B L | Y F A A L I B L | DESCRIPTION OF EVENT |
|------------------------|--------------------------|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|------------------------------|--------------|------------------------------------------|--------------------------|----------------------------------------------------------------------------|
| 151 | 1 | 3.5.1 | 01/29/87 | 0945 | 01/29/87 | 0945 | 01/29/87 | 1400 | 4.25 | 0.00 | 4.25 | Y | N/A | 1 | N N | CORE SPRAY BELTA PRESS. BREAK DETECTOR CHANNELS SEQUENTIALLY DOS FOR SURV. |
| 151 | 1 | 3.5.1 | 02/24/87 | 0700 | 02/24/87 | 0700 | 02/25/87 | 0045 | 17.75 | 0.00 | 17.75 | Y | IF605B | 2 | Y Y | 'B' LOOP OF CORE SPRAY DOS FOR REPAIR OF INJECTION VALVE FC05B. |
| 151 | 1 | 3.5.1 | 03/30/87 | 0650 | 03/30/87 | 0650 | 03/30/87 | 0921 | 0.52 | 0.00 | 0.52 | Y | N/A | 1 | N N | CORE SPRAY SPRAYER BREAK DETECTOR INOP DURING ST. |
| 151 | 1 | 3.5.1 | 04/28/87 | 0830 | 04/28/87 | 0830 | 04/28/87 | 0645 | 0.25 | 0.00 | 0.25 | Y | N/A | 1 | N N | CORE SPRAY LEAK DETECTION SI. |
| 151 | 1 | 3.4.3.2 | 05/11/87 | 0915 | 05/11/87 | 0915 | 05/11/87 | 1000 | 0.75 | 0.00 | 0.75 | Y | IN007A/B | 1 | N N | CORE SPRAY PSH-IN007A,B DOS ONE AT A TIME FOR ST. |
| 151 | 1 | 3.5.1 | 05/29/87 | 0805 | 05/29/87 | 0805 | 05/29/87 | 0905 | 1.00 | 0.00 | 1.00 | Y | N/A | 1 | N N | CORE SPRAY HEADER DELTA PRESS. INSTRUMENT DOS FOR SURV. |
| 151 | 1 | 3.5.1 | 06/29/87 | 0830 | 06/29/87 | 0830 | 06/29/87 | 0900 | 0.50 | 0.00 | 0.50 | Y | N/A | 1 | N N | 'A' CORE SPRAY PUMP DOS FOR ELECTRICAL MAINTENANCE AND INSPECTION. |
| 151 | 1 | 3.5.1 | 06/29/87 | 0930 | 06/29/87 | 0930 | 06/29/87 | 1730 | 3.00 | 0.00 | 3.00 | Y | N/A | 1 | N N | CORE SPRAY BREAK DETECTOR SYSTEM DOS FOR TROUBLE-SHOOTING. |
| 151 | 3 | 3.4.3.2 | 07/11/87 | 1330 | 07/11/87 | 1330 | 07/11/87 | 1540 | 6.00 | 2.17 | 2.17 | Y | N/A | 1 | N N | CORE SPRAY LEAK DETECTOR PSH-E21-IN007A,B DOS ONE AT A TIME FOR ST. |
| 151 | 1 | 3.5.1 | 07/30/87 | 1615 | 07/30/87 | 1615 | 07/30/87 | 1640 | 0.42 | 0.00 | 0.42 | Y | N/A | 1 | N N | CORE SPRAY LEAK DETECTION SI. |
| 151 | 1 | 3.5.1 | 08/12/87 | 0850 | 08/12/87 | 0850 | 08/12/87 | 0925 | 0.58 | 0.00 | 0.58 | Y | IN007A/B | 1 | N N | CORE SPRAY PSH-IN007A,B D/S ONE AT A TIME FOR ST. |
| 151 | 1 | 3.5.1 | 08/26/87 | 0600 | 08/26/87 | 0600 | 08/26/87 | 1430 | 6.37 | 0.00 | 6.37 | Y | IP206A/C | 1 | Y N | CORE SPRAY PUMP 'A' AND 'C' DOS FOR MOTOR OIL PA'S. |
| 151 | 1 | 3.5.1 | 08/27/87 | 0607 | 08/27/87 | 0607 | 08/27/87 | 1710 | 11.05 | 0.00 | 11.05 | Y | IP206B/D | 2 | Y N | CORE SPRAY PUMP 'B' AND 'D' DOS FOR MOTOR OIL PA'S. |
| 151 | 1 | 3.5.1 | 09/08/87 | 0430 | 09/08/87 | 0430 | 09/08/87 | 1645 | 14.25 | 0.00 | 14.25 | Y | IU2110 | 2 | N N | 'B' LOOP CS DOS TO REPAIR ROOH COOLER LEAK. |
| 151 | 1 | 3.5.1 | 09/08/87 | 1850 | 09/08/87 | 1850 | 09/08/87 | 2230 | 3.67 | 0.00 | 3.67 | Y | IU211A | 1 | N N | 'A' LOOP CS DOS TO REPAIR ROOH COOLER LEAK. |
| 151 | 1 | 3.5.1 | 09/11/87 | 1335 | 09/11/87 | 1335 | 09/11/87 | 1413 | 0.63 | 0.00 | 0.63 | Y | N/A | 1 | N N | LOOP OF CS DOS DUE TO SI-199-207 ON IV'S (EXCESS FLOW CHECK VALVES). |
| 151 | 1 | 3.5.1 | 09/11/87 | 1414 | 09/11/87 | 1414 | 09/11/87 | 1430 | 0.27 | 0.00 | 0.27 | Y | N/A | 2 | N N | LOOP OF CS DOS DUE TO SI-199-207 ON IV'S (EXCESS FLOW CHECK VALVES). |
| 151 | 5 | 3.4.7 | 09/29/87 | 1600 | 09/29/87 | 1600 | 10/07/87 | 1845 | 0.00 | 192.75 | 192.75 | Y | N/A | 2 | N N | CORE SPRAY LOOP B SWIBERS REMOVED. |
| 151 | 5 | 3.4.8 | 10/14/87 | 1400 | 10/14/87 | 1400 | 11/05/87 | 1710 | 0.00 | 531.17 | 531.17 | Y | CCA-107-2 | 2 | N N | CORE SPRAY WELD DCA-107-2-FWS FAILED ISI. |
| 151 | 1 | 3.5.1 | 12/04/87 | 0850 | 12/04/87 | 0850 | 12/04/87 | 0945 | 0.92 | 0.00 | 0.92 | Y | N/A | 1 | N N | CS SPRAYER LEAK DETECTION SI. |
| 151 | 1 | 3.5.1 | 12/14/87 | 0640 | 12/14/87 | 0640 | 12/14/87 | 1700 | 10.33 | 0.00 | 10.33 | Y | IU211A | 1 | N N | CORE SPRAY ROOH COOLER FLEX HOSE REPLACED. |
| 151 | 1 | 3.5.1 | 12/18/87 | 0405 | 12/18/87 | 0405 | 12/18/87 | 1745 | 13.67 | 0.00 | 13.67 | Y | IU2110 | 2 | N N | CORE SPRAY ROOH COOLER FLEX HOSE REPLACED. |
| 000 Total 000 | | | | | | | | | 97.18 | 726.09 | 823.27 | | | | | |


IV-10

| U S | P C | TECH. SPEC | EOS DATE | EOS MOD DATE | MOD RETURN | RETURN | CRIT | SHUTDOWN | TOTAL P C T M | COMPONENT ID | S D C E | V F | DESCRIPTION OF EVENT | | | |
|-------|-----|------------|----------|--------------|------------|--------|----------|----------|---------------|--------------|---------|-----|----------------------|---|-----|-------------------------------------------------------------------------------------|
| N Y | L O | | TIME | TIME | TIME DATE | TIME | TIME | TIME | TIME N M E O | | Y I H G | A A | | | | |
| I S | N N | | | | | | (HRS) | (HRS) | (HRS) S D | | S V A H | L I | | | | |
| I | I G | | | | | | | | T | | N F | D L | | | | |
| 151 | 1 | 3.5.1 | 04/04/68 | 0845 | 04/04/68 | 0845 | 04/04/68 | 0916 | 0.52 | 0.00 | 0.52 | Y | N/A | 1 | N N | CORE SPRAY SPARGER BREAK DETECTION CHANNELS 0/5 ONE AT A TIME FOR IBC SURVEILLANCE. |
| 151 | 1 | 3.5.1 | 05/05/68 | 1655 | 05/05/68 | 1655 | 05/05/68 | 1730 | 0.58 | 0.00 | 0.58 | Y | N/A | 2 | N N | DIV 11 CORE SPRAY LOOP INOP FOR AUTO INITIATION DURING U-2 LOGA/LOGF TEST. |
| 151 | 1 | 3.5.1.A | 05/06/68 | 0810 | 05/06/68 | 0810 | 05/06/68 | 1045 | 2.58 | 0.00 | 2.58 | Y | N/A | 4 | N N | CORE SPRAY BREAK DETECTION INDICATION 0/5 FOR SURVEILLANCE. |
| 151 | 1 | 3.4.3.2 | 05/16/68 | 0815 | 05/16/68 | 0815 | 05/16/68 | 0855 | 0.67 | 0.00 | 0.67 | Y | N/A | 1 | N N | CORE SPRAY LEAK DETECTION INOP FOR SURVEILLANCE. |
| Total | | | | | | | | | 4.35 | 0.00 | 4.35 | | | | | |



APPENDIX V

RESIDUAL HEAT REMOVAL (LPCI MODE) SYSTEM.



RESIDUAL HEAT REMOVAL SYSTEM

The Residual Heat Removal (RHR) system can be used in seven modes:

1. Low Pressure Coolant Injection (LPCI) mode.
2. Suppression Pool Cooling Mode (SPCM).
3. Shutdown Cooling Mode (SDCM).
4. Steam Condensing mode.
5. Containment Spray mode.
6. Fuel Pool Cooling mode.
7. Reactor Head Spray mode.

In the Low Pressure Coolant Injection mode, the RHR system is used to provide makeup water during events which reduce the reactor water inventory and involve a reactor depressurization.

In the Suppression Pool Cooling Mode, the RHR system is used to transfer heat from the suppression pool to the spray pond (the ultimate heat sink) via the RHR heat exchangers. The RHR Service Water (RHRSW) system is used to remove heat from the RHR heat exchangers and transfers it from the RHR system to the spray pond.

In the Shutdown Cooling Mode, the RHRSW and RHR systems are used to transfer heat from the reactor coolant to the spray pond. This is accomplished by circulating reactor water through the RHR heat exchangers and by using RHR Service Water to cool the heat exchangers. This can be established when the reactor pressure is less than 98 PSIG.

In the Steam Condensing mode, the RHR system is used to condense steam from the reactor. The condensate is diverted to the suppression pool or pumped back to the reactor vessel by the Reactor Core Isolation Cooling (RCIC) pump. This mode is designed for reactor shutdown from high pressure when the power-conversion system is not available. This mode of RHR has been deleted as a result of system modifications.

In the Containment Spray mode, the RHR system is used to pump water from the suppression pool directly into the containment drywell and wetwell.

In the Fuel Pool Cooling mode, the RHR system is used to transfer heat from the fuel pool to the spray pond. The fuel pool cooling mode was not modeled because no initiating event considered in the PRA affects the fuel pool.

LOW PRESSURE COOLANT INJECTION (LPCI) MODE

DESCRIPTION

Function

The function of the LPCI mode is to provide makeup water during events which reduce the reactor water inventory and involve a reactor depressurization. The LPCI mode of the RHR system is part of the Emergency Core Cooling System (ECCS) and is an alternative to the Core Spray (CS) system.

Design and Operation

The RHR system consists of two redundant loops, A and B. Successful system operation requires full flow from one pump but both loops are initiated simultaneously. Figure 8 shows a simplified diagram of loop A. Each loop consists of two pumps (12,200 gpm/pump), each of which takes suction from the suppression pool and pumps the water into the reactor vessel through the recirculation loop discharge piping. Since loops A and B are redundant, only loop A will be described.

The two pumps in loop A, (pumps A and C), are aligned to take suction from the suppression pool through normally open motor-operated valves (MOV) (F004A and F004C). Each pump discharges through its own check valve to a common header. A minimum-flow bypass line connects the combined discharge of both pumps to the suppression pool through MOV F007A. This valve is normally open and closes when the flow through the discharge header into the reactor or the suppression pool exceeds the high-flow setpoint. The function of the bypass line is to prevent pump damage from overheating when the discharge line valves are closed or the reactor pressure exceeds 430 PSIG. The common discharge passes through an RHR heat exchanger, via normally open MOVs F003A and F047A, and a normally open heat-exchanger bypass valve, MOV F048A. The majority of flow bypasses the heat exchanger. Loop A discharges into the recirculation loop on the discharge side of the recirculation pump via normally open MOV F017A, normally closed MOV F015A, testable check valve F050A, and locked-open manual valve F060A. For test purposes F050A is provided with a bypass, F122A. In order to avoid pumping water back through the recirculation pump, the recirculation loop discharge valve MOV F031A closes on an LPCI initiation signal to isolate the recirculation pump. Alternative discharge paths downstream of the heat exchanger (which are not part of the LPCI mode) to the containment spray, through MOVs F016A and F021A, and the head spray (loop A only), through MOVs F023 and F022, are normally isolated. Therefore, in the standby condition, there is only one closed MOV in the LPCI loop A discharge path (F015A). Full flow tests can be performed via a test line to the suppression pool via (normally closed) MOVs F028A and F024A.

The RHR pumps will automatically start on receiving any of the following initiation signals:

1. Low reactor water level (level 1).
2. High drywell pressure and low reactor pressure.
3. RHR manual initiation.

Injection valve MOV F015A(B) will open on receiving a level 1 or high drywell pressure signal and a low reactor pressure permissive signal. Manual initiation is also possible, but the low reactor pressure permissive is still required.

The recirculation loop discharge valves, MOV F031A(B), close on receiving a low reactor pressure signal (with a LPCI initiation signal present).

If the RHR system is in use at the time of LPCI initiation, it will automatically reconfigure to the LPCI mode.

The operator has the following major indications available in the control room:

1. System flow.
2. Position indication for all motor-operated valves.
3. Loop discharge pressures.

System Interfaces

Instrumentation

The low reactor pressure permissive signal common to both the Residual Heat Removal (LPCI mode) and Core Spray systems, does not allow these systems to inject into the reactor until reactor pressure is below 430 psig. For the LPCI mode, the signal must exist along with a pump initiation signal before a signal to open injection valve F015 is generated.

Electric Power

The RHR system requires: 4.16 kV AC power to operate the LPCI pumps, 480 V AC power for the motor-operated valves, and 125 V DC power for the control logic of pumps and valves. Normally, the 4.16 kV AC system receives offsite power through an Engineered Safeguards Systems (ESS) bus. Should the offsite power supply to an ESS bus fail, a diesel generator will start up to reenergize the bus. The DC power is supplied from the ESS bus through a charger or, in the event of AC power failure, from 125 V batteries.

Room/Pump Cooling

Each loop of RHR (two pumps) is located in a room in the reactor building basement, with these rooms being normally cooled by reactor building Zone 1 HVAC. This system is isolated by a low reactor water level (level 1) or high drywell pressure signal. These same signals will automatically initiate the Emergency Service Water (ESW) system which will supply cooling water to the room coolers (there are two room coolers/loop of RHR) of RHR. It should be noted that the ESW system will also be initiated by the diesel generator start logic. Also, the fan of each room cooling unit in an RHR loop is interlocked to start when the pumps in that particular loop start.

Each RHR pump requires cooling for its lubricating oil and mechanical seal. The seal water and lube oil coolers are cooled by water from the ESW system, therefore the loss of adequate flow from the ESW system will result in the failure of RHR pumps. RHR pumps A and D are cooled by ESW loop A, RHR pumps B and C are cooled by ESW loop B.

Water Sources

The suppression pool is the only source of water for LPCI.

Condensate Transfer System

The system pipes are normally kept filled by means of the condensate transfer system to prevent waterhammer on initiation. This system was not modeled, but the rate of pipe failure (rupture) that was used in the fault tree analysis implicitly includes the effect of failure in the condensate transfer system.

Table-15. AC power supplies for the RHR system

| ESF 4.16 kV bus | 480 V MCC bus | Component supplied |
|-----------------|---------------|-------------------------------------------------------------------------------------------|
| 1A201 | | RHR Pump A |
| | 1B216 | F003A F004A F006A F010A F017A F028A F047A Room Cooler Fan A |
| | 1B217 | F016A F020 F021A |
| 1A202 | | RHR Pump B |
| | 1B226 | F003B F004B F006B F010B F016B F017B F028B F047B Room Cooler Fan B |
| | 1B227 | F021B |
| 1A203 | | RHR Pump C |
| | 1B236 | F009 F027A |
| | 1B237 | F004C F006C F022 F024A F048A Room Cooler Fan C |
| 1A204 | | RHR Pump D |
| | 1B246 | F027B F048B |

Table 15. AC power supplies for the RHR system (continued)

| ESF 4.16 kV bus | 480 V. MCC bus | Component supplied |
|--------------------|----------------|------------------------------------------------------------------------------------------|
| | 1B247 | F004D F006D F024B Room Cooler Fan D |
| 1A201 ^a | 1B219 | F007A ^b F015A ^b F031A ^d F032A ^d |
| 1A202 ^c | 1B229 | F007B ^b F015B ^b F031B ^d F032B ^d |

^aMCC 1B219 is normally supplied from bus 1A201, but if this bus fails, it will be supplied from bus 1A203.

^bValves that have to change position for the automatic initiation of LPCI

^cMCC 1B229 is normally supplied from bus 1A202, but if this bus fails, it will be supplied from bus 1A204.


^dThese valves are in the recirculation loop.

Table 16. DC power supplies for the RHR system

| 125 V DC load center | 125 V distribution panel. | Component supplied |
|-------------------------|------------------------------|--------------------------|
| 1D612 | 1D614 | RHR pump A control logic |
| 1D622 | 1D624 | RHR pump B control logic |
| 1D632 | 1D634 | RHR pump C control logic |
| 1D642 | 1D644 | RHR pump D control logic |

| 250 V DC control center | Component supplied |
|----------------------------|-----------------------|
| 1D274 | F008 F023 |

8-A



SUSQUEHANNA
STEAM ELECTRIC STATION

SIMPLIFIED DIAGRAM
OF LPCI
MODE OF RHR (LOOP A)

FIGURE 8

REV. 0

GN23

| OS | FC | TECH. SPEC | OS DATE | OS TIME | MO DATE | MO TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | PCT | Y | M | COMPONENT ID | SD | CC | VF | DESCRIPTION OF EVENT |
|---------------|----|-------------|----------|---------|----------|---------|-------------|-------------|-----------------|---------------------|------------------|-----|---|--------|--------------|----|----|----|--------------------------------------------------------------------|
| NY | LO | | | | | | | | | | | | | | | | | | |
| IS | NN | | | | | | | | | | | | | | | | | | |
| Y | TD | | | | | | | | | | | | | | | | | | |
| 149 | 1 | 3.5.1 | 06/09/83 | 0115 | 06/09/83 | 0720 | 06/15/83 | 2030 | 122.45 | 34.72 | 157.17 | Y | | N/A | 2 | | Y | N | "B" LOOP RHR INOPERABLE FOR LCPI INJECTION. |
| 149 | 3 | 3.6.2.2&2.3 | 06/13/83 | 0115 | 06/14/83 | 1810 | 06/14/83 | 1810 | 0.00 | 0.00 | 0.00 | Y | | N/A | 2 | | Y | N | "B" LOOP RHR UNYAIL. FOR LPCI MOVE. |
| 149 | 3 | 3.4.9.2 | 06/30/83 | 0224 | 06/30/83 | 0224 | 06/30/83 | 0545 | 0.00 | 3.35 | 3.35 | Y | | N/A | Y | | N | N | NO SDC IN OPERATION. |
| 149 | 3 | 3.4.9.2 | 06/30/83 | 1140 | 06/30/83 | 1140 | 07/01/83 | 1400 | 0.00 | 26.33 | 26.33 | Y | | N/A | 2 | | Y | N | "B" LOOP RHR INOPERABLE FOR SHUTDOWN COOLING. |
| 149 | 1 | 3.5.1 | 08/15/83 | 0500 | 08/15/83 | 0500 | 08/19/83 | 0520 | 96.33 | 0.00 | 96.33 | Y | | IF031A | A | | Y | N | "A" RHR PUMP O/S SUCTION VLV SHUT TO TRY TO SEAT DISCH. VALVE. |
| 149 | 1 | 3.5.1 | 08/23/83 | 1450 | 08/23/83 | 1450 | 08/23/83 | 1605 | 1.25 | 0.00 | 1.25 | Y | | IF031A | A | | Y | N | "A" RHR PUMP ISOL. TO ATTEMPT TO SEAT DISCH VLV. |
| 149 | 3 | 3.4.9.2 | 08/30/83 | 0415 | 06/30/83 | 0415 | 08/30/83 | 0533 | 0.00 | 1.30 | 1.30 | Y | | N/A | B | | N | N | B RHR INOPERABLE SDC INOPERABLE DUE TO RHR RELAY INSPECTION. |
| 149 | 3 | 3.4.9.2 | 08/31/83 | 0200 | 08/31/83 | 0200 | 08/31/83 | 0230 | 0.00 | 0.50 | 0.50 | Y | | IF013A | 1 | | Y | N | "A" LOOP RHR INOPERABLE FOR SDC DUE TO 13A VALVE INOPERABLE. |
| 149 | 1 | 3.5.1 | 09/21/83 | 0500 | 09/21/83 | 0500 | 09/22/83 | 0510 | 24.17 | 0.00 | 24.17 | Y | | IF031A | 1 | | Y | N | "A" RHR PUMP O/S TO REPAIR DISCHARGE CHECK VLV. |
| 149 | 1 | 3.6.2.2&2.3 | 10/14/83 | 0910 | 10/14/83 | 0910 | 10/14/83 | 1740 | 8.50 | 0.00 | 8.50 | Y | | 1P202B | B | | Y | N | 1B RHR PUMP B/R O/S FOR FM WOFF. |
| 149 | 1 | 3.5.1 | 11/06/83 | 0445 | 11/06/83 | 0445 | 11/07/83 | 1810 | 37.42 | 0.00 | 37.42 | Y | | IF021B | Y | | N | N | CHECK VALVE IF021B WILL NOT SEAT. |
| 149 | 3 | 3.4.9.2 | 12/05/83 | 0100 | 12/05/83 | 0100 | 12/09/83 | 2100 | 0.00 | 116.00 | 116.00 | Y | | N/A | 1 | | N | N | "A" RHR S/D COOLING INOPERABLE. |
| 149 | 3 | 3.9.11.2 | 12/07/83 | 2100 | 12/09/83 | 2100 | 12/12/83 | 1200 | 0.00 | 63.00 | 63.00 | Y | | N/A | 2 | | N | N | ONLY ONE LOOP OF RHR AVAILABLE FOR SDC. |
| 149 | 5 | 3.9.11 | 12/13/83 | 0535 | 12/13/83 | 0535 | 12/13/83 | 0602 | 0.00 | 0.45 | 0.45 | Y | | N/A | 2 | | N | N | "B" RHR LOOP ISOLATED WHILE IN SDC DUE TO BLOWN RPS FUSE-EFS TRIP. |
| *** Total *** | | | | | | | | | 290.12 | 245.65 | 535.77 | | | | | | | | |

***** FHR *****
 BEGIN DATE: 01/01/84 END DATE: 12/31/84

| MS | PC | TECH. SPEC | DOS DATE | OOS TIME | MO DATE | MO TYPE | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | PCT | M | COMPONENT ID | S | C | D | Y | F | DESCRIPTION OF EVENT |
|------------|----|------------|----------|----------|----------|---------|-------------|-------------|-----------------|---------------------|------------------|-----|-------------|--------------|---|---|---|---|--------------------------------------------------------------------------------------------------|----------------------|
| 1 | 5 | L | | | | | | | | | | | | | | | | | | |
| 1 | S | N | | | | | | | | | | | | | | | | | | |
| 1 | | Y | | | | | | | | | | | | | | | | | | |
| 149 | 1 | 3.5.1 | 04/24/84 | 0616 | 04/24/84 | 0616 | 04/24/84 | 1200 | 5.73 | 0.00 | 5.73 | Y | N/A | A | N | N | N | N | "A" RHR ROOM COOLER INOP. | |
| 149 | 1 | 3.6.2.2 | 07/21/84 | 1355 | 07/21/84 | 1355 | 07/23/84 | 1040 | 44.75 | 0.00 | 44.75 | Y | 1P2026/D | 1 | N | N | N | N | "B" & "D" RHR PUMPS OUT OF SERVICE. | |
| 149 | 1 | 3.6.3 | 07/21/84 | 2140 | 07/21/84 | 2140 | 07/23/84 | 1040 | 37.00 | 0.00 | 37.00 | Y | 1F122B/0508 | 2 | N | N | N | N | DURING PERFORMANCE OF MONTHLY FM-50406, 1F122B/0508 INDICATION FLAGGERS. | |
| 149 | 1 | 3.3.2 | 08/07/84 | 1830 | 08/07/84 | 1830 | 08/08/84 | 1425 | 19.92 | 0.00 | 19.92 | Y | N/A | Y | N | N | N | N | SLURV. PAST DUE FOR SAUTERMAN COOLING DELTA-T AND HIGH TEMP ISOLATION SWITCHES. | |
| 149 | 1 | 3.5.1.6 | 08/20/84 | 1140 | 08/20/84 | 1140 | 08/21/84 | 1921 | 31.66 | 0.00 | 31.66 | Y | 1P202B | B | N | N | N | N | "B" RHR PP DECLARED INOP DUE TO FAILING DELTA-P FOR ISI FECTION OF 50-149-002. | |
| 149 | 1 | 3.5.1 | 09/09/84 | 1610 | 09/09/84 | 1610 | 09/09/84 | 1640 | 0.50 | 0.00 | 0.50 | Y | 1F064A-D | 1 | N | N | N | N | "A" LOOP RHR INOP FOR INJECTION WHILE PERFORMING 50-149-005 ON PUMP SUCTION VALVES. | |
| 149 | 1 | 3.5.1 | 09/09/84 | 2120 | 09/09/84 | 2120 | 09/09/84 | 2150 | 0.50 | 0.00 | 0.50 | Y | 1F064A-D | 2 | N | N | N | N | "B" LOOP RHR INOP FOR INJECTION WHILE PERFORMING 50-149-005 ON PUMP SUCTION VALVES. | |
| 149 | 1 | 3.5.1 | 09/10/84 | 0106 | 09/10/84 | 0106 | 09/10/84 | 0116 | 0.17 | 0.00 | 0.17 | Y | 1P202D | D | N | N | N | N | "D" RHR PUMP INOP FOR BREAKER INSPECTION. | |
| 149 | 1 | 3.4.3.2 | 10/25/84 | 1335 | 10/25/84 | 1335 | 10/25/84 | 1445 | 1.17 | 0.00 | 1.17 | Y | 1N022A | 1 | N | N | N | N | FSM-E11-N022A & B COS ONE AT A TIME FOR PERFORMANCE OF SI-149-310. (RHR HIGH PRESSURE MONITORS.) | |
| 149 | 1 | 3.5.1 | 12/09/84 | 1630 | 12/09/84 | 1630 | 12/09/84 | 1900 | 2.50 | 0.00 | 2.50 | Y | N/A | 2 | N | N | N | N | "B" LOOP RHR INOP DURING VAL EXERCISE. | |
| 149 | 1 | 3.5.1 | 12/09/84 | 2013 | 12/09/84 | 2013 | 12/09/84 | 2145 | 1.53 | 0.00 | 1.53 | Y | N/A | 1 | N | N | N | N | "A" LOOP RHR INOP DURING VAL EXERCISE. | |
| 149 Totals | | | | | | | | | 145.45 | 0.00 | 145.45 | | | | | | | | | |

| N Y I | P C | TECH. SPEC | DOS DATE | DOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M | CONFIDENT ID | S B C C | Y F | DESCRIPTION OF EVENT |
|---------------|-----|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---------|--------------|---------|-----|-------------------------------------------------------------------------------------------|
| | | | | | | | | | | | | | | | | |
| 149 | 3 | 3.9.11.2 | 02/13/85 | 1111 | 02/13/85 | 1111 | 02/13/85 | 1153 | 5.60 | 0.70 | 6.70 | Y | N/A | 7 | N N | NO RHR LOOP IN SDC SO U-2 CAN PERFORM RHR QUARTERLY FLOW SURVEILLANCE. |
| 149 | 1 | 3.8.2.2 | 07/09/85 | 0530 | 07/09/85 | 0530 | 07/09/85 | 2040 | 15.17 | 0.00 | 15.17 | Y | 151-029 | 2 | N N | 'B' LOOP RHR INCP FOR REPAIR OF 151-029 B LOOP HQ2 VENT. |
| 149 | 1 | 3.8.2.2 | 10/06/85 | 1925 | 10/06/85 | 1925 | 10/08/85 | 2215 | 50.83 | 0.00 | 50.83 | P | 1E205A | 1 | Y N | A RHR HEAT EXCHANGER OOS FOR MAINT. A LOOP SUPP POOL SPRAY AND A LOOP SUFF EGOL CIG INCP. |
| 149 | 1 | 3.5.1 | 12/16/85 | 0352 | 12/16/85 | 0352 | 12/16/85 | 1700 | 13.13 | 0.00 | 13.13 | Y | 1F004A | A | Y N | 'A' RHR PP OOS FOR MAINT ON OIL COOLER AND 'A' PUMP SUCTION VLV INDICATION (1F004A). |
| *** Total *** | | | | | | | | | 79.13 | 0.70 | 79.83 | | | | | |

||||| SFR |||||
 BEGIN DATE: 01/01/86 END DATE: 12/31/86

| SY | PC | TECH. SPEC | DOS DATE | OGS TIME | MOG DATE | MOG TIME | RETURN DATE | RETURN TIME | CALL TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M | COMPONENT I D | S D C C | V F | DESCRIPTION OF EVENT | | | | | | |
|-----|-------|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---------|---------------|---------|--------|-----------------------------------------------------------------------|--|--|--|--|--|--|
| N Y | L O | | | | | | | | | | | N E G | | Y I H O | A A | | | | | | | |
| I S | N N | | | | | | | | | | | S O | | S V A H | L I | | | | | | | |
| T | I D | | | | | | | | | | | T | | N R | B L | | | | | | | |
| 149 | 1 | 3.5.1b | 02/04/86 | 0530 | 02/04/86 | 0730 | 02/04/86 | 1240 | 3.17 | 0.00 | 3.17 | Y | 1F006B | B | Y N | STROKE F006B FOR 'B' PUMP - F006B CLOSED. | | | | | | |
| 149 | 1 | 3.5.1 | 02/06/86 | 1645 | 02/06/86 | 1645 | 02/06/86 | 1245 | 2.00 | 0.00 | 2.00 | Y | 1F006D | D | Y N | F006D CLOSED TO STROKE F006B. | | | | | | |
| 149 | 1 | 3.5.1 | 02/07/86 | 0750 | 02/07/86 | 0750 | 02/07/86 | 1025 | 2.50 | 0.00 | 2.50 | Y | 1F006B | B | Y N | F006D CLOSED TO STROKE F006B. | | | | | | |
| 149 | 1 | 3.5.1 | 02/12/86 | 0950 | 02/12/86 | 0950 | 02/12/86 | 1745 | 7.92 | 0.00 | 7.92 | Y | 1F006A | A | Y N | F006A CLOSED TO SET LIMITS ON F006A. | | | | | | |
| 149 | 1 | 3.5.1 | 02/13/86 | 1100 | 02/13/86 | 1100 | 02/13/86 | 1655 | 5.92 | 0.00 | 5.92 | Y | 1F006C | C | Y N | F006C CLOSED TO SET LIMITS ON F006C. | | | | | | |
| 149 | 2 | 3.5.1 | 02/15/86 | 1330 | 02/15/86 | 1330 | 02/15/86 | 1520 | 0.00 | 4.63 | 4.63 | Y | N/A | 2 | N N | 'B' LOOP INCP FOR LFCL. | | | | | | |
| 149 | 1 | 3.4.3.2 | 05/02/86 | 1000 | 05/02/86 | 1600 | 05/02/86 | 1110 | 1.17 | 0.00 | 1.17 | Y | N/A | 1 | N N | FUNCTION CHECK OF HIGH/LOW PRESSURE INTERFACE VALVE LEAKAGE MONITERS. | | | | | | |
| 149 | 3 | 3.4.9.2 | 06/07/86 | 0730 | 06/07/86 | 0730 | 06/11/86 | 0652 | 0.00 | 95.37 | 95.37 | Y | N/A | 1 | N N | 'A' LOOP INCP FOR VALVE INSPECTION. | | | | | | |
| 149 | 3 | 3.4.9.2 | 06/11/86 | 0740 | 06/11/86 | 0740 | 06/13/86 | 1750 | 0.00 | 60.17 | 60.17 | Y | N/A | 2 | N N | 'B' LOOP VALVE INSPECTION. | | | | | | |
| 149 | 3 | 3.4.9.2 | 06/12/86 | 0210 | 06/12/86 | 0610 | 06/12/86 | 1045 | 0.00 | 2.45 | 2.45 | Y | N/A | 1 | N N | SEC INCP FOR PUMP FLUSH. | | | | | | |
| 149 | 3 | 3.4.9.2 | 06/12/86 | 1814 | 06/12/86 | 1814 | 06/12/86 | 1650 | 0.00 | 0.80 | 0.80 | Y | N/A | Y | N N | SEC O/S & OTHER LOOP INCP TO ENAF RFS POWER. | | | | | | |
| 149 | 3 | 3.4.9.2 | 06/13/86 | 0921 | 06/13/86 | 0921 | 06/13/86 | 1107 | 0.00 | 1.77 | 1.77 | Y | N/A | Y | N N | SEC O/S FOR RFS TRANSFER. | | | | | | |
| 149 | 3 | 3.4.9.2 | 06/14/86 | 0328 | 06/14/86 | 0328 | 06/14/86 | 0339 | 0.00 | 0.22 | 0.22 | Y | N/A | Y | N N | SEC O/S FOR RFS TRANSFER. | | | | | | |
| 149 | 3 | 3.4.9.2 | 06/14/86 | 0847 | 06/14/86 | 0847 | 06/14/86 | 1126 | 0.00 | 2.65 | 2.65 | Y | N/A | Y | N N | SEC O/S FOR RFS TRANSFER. | | | | | | |
| 149 | 1 | 3.4.3.2 | 07/02/86 | 0750 | 07/02/86 | 0750 | 07/02/86 | 0635 | 0.75 | 0.00 | 0.75 | Y | 1N022A/B | 1 | N N | CHECK HIGH PRESSURE DISCHARGE SWITCHES PSH-E11-M022 A & B. | | | | | | |
| 149 | 1 | 3.3.7.1 | 07/02/86 | 0950 | 07/02/86 | 0950 | 07/02/86 | 1045 | 0.92 | 0.00 | 0.92 | Y | 1N01B | 1 | N N | FUNCTIONAL CHECK OF PEN-C11-M01B SENSOR. | | | | | | |
| 149 | 1 | 3.5.1 | 09/02/86 | 0730 | 09/02/86 | 0730 | 09/02/86 | 1105 | 3.58 | 0.00 | 3.58 | Y | 1P202A | A | Y N | A PUMP OUT OF SERVICE TO REPLACE AGASTAT RELAY. | | | | | | |
| 149 | 1 | 3.5.1 | 09/02/86 | 1115 | 09/02/86 | 1115 | 09/02/86 | 1450 | 3.55 | 0.00 | 3.55 | Y | 1P202C | C | Y N | C PUMP OUT OF SERVICE TO REPLACE AGASTAT RELAY. | | | | | | |
| 149 | 1 | 3.5.1 | 09/03/86 | 0735 | 09/03/86 | 0735 | 09/03/86 | 1017 | 2.70 | 0.00 | 2.70 | Y | 1P202B | B | Y N | 'B' PUMP OUT OF SERVICE TO REPLACE AGASTAT RELAY. | | | | | | |
| 149 | 1 | 3.5.1 | 09/03/86 | 1025 | 09/03/86 | 1025 | 09/03/86 | 1250 | 2.42 | 0.00 | 2.42 | Y | 1P202D | D | Y N | 'D' PUMP OUT OF SERVICE TO REPLACE AGASTAT RELAY. | | | | | | |
| 149 | 3 | 3.4.4 | 09/17/86 | 0429 | 09/17/86 | 0429 | 09/17/86 | 0457 | 0.00 | 0.47 | 0.47 | Y | N/A | Y | N N | ARM LOOP SHUTDOWN FOR SURVEILLANCE. | | | | | | |
| 149 | 1 | 3.4.5.1 | 09/25/86 | 0601 | 09/25/86 | 0601 | 09/25/86 | 0353 | 3.53 | 0.00 | 3.53 | Y | 1P202C | C | N N | 'C' PUMP WILL NOT START DUE TO UNIT 2 LOCA LOGIC TEST. | | | | | | |
| 149 | 1 | 3.5.1 | 09/27/86 | 0220 | 09/27/86 | 0220 | 09/27/86 | 0550 | 3.50 | 0.00 | 3.50 | Y | 1P202B | B | N N | 'B' PUMP WILL NOT START DUE TO UNIT 2 LOCA LOGIC TEST. | | | | | | |
| 149 | 1 | 3.3.2 | 11/26/86 | 0540 | 11/26/86 | 0540 | 11/26/86 | 0915 | 0.56 | 0.00 | 0.56 | Y | 1N030C | 1 | N N | DIVISION 1 LEAK DETECTION TEMP ELEMENT TE-E11-IN030C UNAVAILABLE. | | | | | | |
| 149 | Total | | | | | | | | | | | | 44.32 | 180.53 | 212.65 | | | | | | | |

V-12

 BEGIN DATE: 01/01/87

RNR *****
 END DATE: 12/31/87

| U | P | TECH. SPEC | LOG DATE | LOG TIME | MOD DATE | MSG TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | F | C | T | M | COMPONENT ID | S | D | C | J | F | DESCRIPTION OF EVENT |
|---------------|---|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---|--------|---|---|--------------|---|---|---|---|---|---------------------------------------------------------------------------|
| 4 | L | | | | | | | | | | | | | | | | | | | | | |
| 7 | S | N | | | | | | | | | | | | | | | | | | | | |
| Y | T | D | | | | | | | | | | | | | | | | | | | | |
| 149 | 1 | 3.4.3.2 | 03/25/87 | 0930 | 03/25/87 | 0930 | 03/25/87 | 1005 | 0.58 | 0.00 | 0.58 | Y | N/A | | | | Y | N | N | | | LEAKAGE MONITOR O/S FOR SI'S. |
| 149 | 1 | 3.4.3 | 06/19/87 | 1055 | 06/19/87 | 1055 | 06/19/87 | 1130 | 0.58 | 0.00 | 0.58 | Y | N/A | | | | | N | N | | | ALL LEAKAGE CONTROL SENSOR O/S ONE AT A TIME FOR SI. |
| 149 | 1 | 3.5.1 | 07/01/87 | 0920 | 07/01/87 | 0920 | 07/01/87 | 1330 | 4.17 | 0.00 | 4.17 | Y | 1P202B | | | | | Y | N | | | RNR PUMP IS O/S FOR INSPECTION AND MAINTENANCE OF PUMP MOTOR. |
| 149 | 4 | 3.4.9.2 | 07/09/87 | 1620 | 07/09/87 | 1620 | 07/10/87 | 1100 | 0.00 | 16.67 | 16.67 | Y | 1F008C | | | | | | Y | N | | "A" LOOP OF RNR S/D COOLING O/S FOR OUTAGE WORK. |
| 149 | 1 | 3.8.2.3 | 08/17/87 | 0934 | 08/17/87 | 0934 | 08/17/87 | 1320 | 3.77 | 0.00 | 3.77 | Y | 1F018B | | | | | | | | | 1F018B VALVE OPEN WITH BREWER FACED OUT. |
| 149 | 1 | 3.5.1 | 08/17/87 | 1320 | 08/17/87 | 1320 | 08/17/87 | 1600 | 2.67 | 0.00 | 2.67 | Y | 1F018B | | | | | | | | | 1F018B VALVE CLOSED AND DE-ENERGIZED FOR ANTI-ROTATION COLLAR INSPECTION. |
| 149 | 4 | 3.4.9.2 | 12/28/87 | 0916 | 12/28/87 | 0916 | 12/28/87 | 1815 | 0.00 | 9.08 | 9.08 | Y | 1V216A | | | | | | | | | REPLACE FLEX HOSE ON RCOM COOLERS. |
| *** Total *** | | | | | | | | | 11.77 | 27.75 | 39.52 | | | | | | | | | | | |

***** GMR *****
BEGIN DATE: 01/01/88 END DATE: 06/07/88

| IS | PC | TECH. SPEC | OGS DATE | DOS | MOD DATE | MOD | RETURN | RETURN | EXIT | SHUTDOWN | TOTAL | P | C | T | M | COMPONENT | ID | S | D | C | C | Y | F | DESCRIPTION OF EVENT | |
|---------------|----|------------|----------|------|----------|------|----------|--------|-------|----------|-------|---|----------|---|--------|-----------|----|---|---|---|---|---|---|------------------------------------------------------------------------------------------------------------------------|--|
| NY | LO | | | | TIME | TIME | DATE | TIME | TIME | TIME | TIME | N | E | O | | | | | | | | | | | |
| IS | NY | | | | | | | | (HRS) | (HRS) | (HRS) | | | | | | | | | | | | | | |
| T | Y | | | | | | | | T | T | T | | | | | | | | | | | | | | |
| 147 | I | 3.4.3.2 | 01/11/88 | 0430 | 01/11/88 | 0430 | 01/11/88 | 1505 | 14.58 | 0.00 | 14.58 | | | Y | 1V210B | | | | | | | | | REF. ROOM COOLER FLEET HOSE REPLACEMENT 'B' DIV RHR. | |
| 148 | I | 3.4.3.2 | 01/27/88 | 1045 | 01/27/88 | 1045 | 01/27/88 | 1110 | 0.50 | 0.00 | 0.50 | Y | N/A | | | | | | | | | | | MONTHLY SI ON RHR HI/LOW PRESSURE MONITOR. | |
| 149 | I | 3.4.3.2 | 01/27/88 | 1040 | 01/27/88 | 1045 | 01/27/88 | 1110 | 0.50 | 0.00 | 0.50 | Y | N/A | | | | | | | | | | | MONTHLY SI ON RHR HI/LOW PRESSURE MONITOR. | |
| 149 | I | 3.4.3.2 | 04/28/88 | 0810 | 04/28/88 | 0810 | 04/28/88 | 0920 | 0.67 | 0.00 | 0.67 | Y | 1N022A/E | | | | | | | | | | | RHR LPCI INJECTION AND SEC SUCTION HIGH PRESSURE MONITORS O/S FOR IIC FUNCTIONAL GME AT A TIME FSH-1016 & FSH-N/224.E. | |
| *** Total *** | | | | | | | | | 16.25 | 0.00 | 16.25 | | | | | | | | | | | | | | |

APPENDIX VI

EMERGENCY SERVICE WATER SYSTEM

EMERGENCY SERVICE WATER SYSTEM

SYSTEM DESCRIPTION

Function

The function of the Emergency Service Water (ESW) system is to provide cooling water for the emergency diesel generators (short term cooling), both units' Residual Heat Removal (RHR) system (intermediate term cooling), the High Pressure Coolant Injection (HPCI) system (long term cooling), RCIC system (long term cooling), and essential bus room coolers in the event of any condition that requires the operation of the Emergency Core Cooling Systems, including the loss of offsite power. The ESW system also is a backup to both units' Service Water (SW) system which cools the Turbine Building Closed Cooling Water (TBCCW) system and Reactor Building Closed Cooling Water (RBCCW) system.

Design and Operation

As shown in the simplified diagram of Figure 9 (and 10), the ESW system consists of two independent loops, each of which is designed to supply 100 percent of the flow required by one division in both units and four emergency diesel generators. Each loop is equipped with two motor-driven pumps, a 36-inch header, and various valves. Since the two loops are similar and perform the same function, only loop A is described here.

The ESW system takes suction from the spray pond, which has a normal capacity of 25 million gallons. The system is designed to operate for up to 30 days without water makeup to the spray pond. In the event that makeup for the spray pond is required, water is supplied from either the circulating water system or the river-water makeup pumps.

Each of the two pumps in loop A is located in its own concrete basin inside the ESW pumphouse, and the pump suctions are in the spray pond. Each pump basin is equipped with a large-mesh fixed screen to prevent the entry of floating debris.

Each ESW pump discharges through a check valve and a normally open manual valve (0-11-005 for pump A) to the loop A header. A 36-inch pipe takes the water from the ESW pumphouse to the diesel generator enclosure and the reactor building. The diesel cooling is normally aligned to loop A. If there is insufficient flow from loop A, initially, (i.e., failure of one pump to start), and both pumps in loop B have started, then there is an automatic transfer to loop B of ESW. However, there is no automatic transfer back to loop A if loop B cannot adequately cool the diesels. This is important because of the ESW system's unique dependence on diesel power during a Loss Of Offsite Power (LOOP) event. This dependency can be shown in the following scenario. A loss of offsite power occurs. However, diesels A and B fail to start. Even though two ESW pumps are available to cool the diesels (one pump/diesel; also because both pumps are not available in loop A diesel cooling is transferred to loop B) the spray pond bypass valves (one valve/loop) that are required to open in order to allow flow return to the spray pond do not open because they normally receive power from diesels A (valve in loop A) and B (valve in loop B). Therefore, there is no cooling flow to the diesels and the diesels trip on overtemperature in about four minutes, resulting in a Station Blackout (SBO). All other loads on ESW loop A

are supplied through a locked-open manual valve, 1-11-102. Each of these loads has a manual valve for individual system isolation.

The return path is through a locked-open manual valve, 1-11-186. Downstream of this valve the ESW return line combines with the diesel return line and the Residual Heat Removal Service Water (RHRSW) systems return line to form a common return path to the spray pond through a locked-open manual valve, 0-12-012. The return line then divides, and the water is discharged to the spray pond through one of three paths. Motor-operated valve 01222A opens automatically when any pump in ESW system loop A or RHRSW loop A is started and admits the return water directly to the spray pond. In addition, the discharge from each loop can return through either of two spray networks that are sized according to the heat load that must be dissipated. (However, this is a manual action.) The larger spray network, supplied through valve 01224A1, was designed to dissipate the heat associated with one ESW loop and one RHR heat exchanger; the smaller network, supplied through valve 01224A2, was designed to dissipate the heat from either one RHR heat exchanger or the ESW loop. Both of these spray network valves are manually opened and have no automatic operation.

Each ESW pump receives a start signal when its associated diesel starts. Thus each ESW pump indirectly receives a start signal when offsite power is lost, or by low reactor water level (level 1) or high drywell pressure signals. The pump-start signal is received by the pump (45 seconds after the diesel starts for pumps A and B, and 53 seconds for pumps C and D). As stated earlier, loop A discharge valve 01222A receives an open signal on the starting of pump A or C. The operator can start any pump from the control room and open the spray pond return valves as required. Once the pump is running, no adjustments are required, as the individual coolers all have flow balancing valves.

The operator has the following indications available in the control room:

1. System pressure in each common pump discharge header.
2. System flow in each common pump discharge header.
3. Water level in the pump inlet basin.
4. Temperature and diesel-outlet high-temperature alarms.
5. Position of motor-operated valves.

System Interfaces

Instrumentation

The pump-start signal is derived from the diesel generator instrumentation and does not interface with any other systems. After the pump starts, the running signal is used to open the return valve to the spray pond.

Electric Power

The ESW system requires 4.16 kV AC power to operate the pumps, each of the four pumps being supplied from one of the four ESS buses. In addition, 480 V AC power is required for valve operation, and 125 V DC power is used for the control logic of the pumps and valves.

The ESS buses are energized from offsite power or, in the event of a loss of offsite power (LOOP), from the diesel generators. The diesels can operate

for about 4 minutes without ESW cooling to the diesel generators. Thus, in the event of a LOOP, the diesels will start and connect to the buses. The ESW system pumps are sequenced to start and supply cooling water to the diesels. The DC power is supplied from the ESS bus via a charger or, in the event of a DC power failure, from two 125 V batteries.

All the power supplies for the ESW system are listed in Tables 18 and 19.

Cooling


The motors of the ESW pumps are air cooled and do not rely on water for cooling. The pump house has an HVAC system. A failure in this system is assumed to not fail the ESW pumps, because the pump house has a common overhead area which allows ventilation to be performed by other non-failed components.

Table 18.. AC power supplies for the ESW system.

| ESF 4.16 kV bus. | 480 V MCC. | Component supplied |
|---------------------|------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1A201 | OB517 | ESW pump A Loop A return line to spray pond, HV-01222A Loop A return line to riser A1, HV-01224A1. Loop A return line to riser A2, HV-01224A2 Pump A discharge valve HV-011-01A Pump C discharge valve HV-011-01C |
| 1A202 | OB527 | ESW pump B Loop B return line to spray pond, HV-01222B Loop B return line to riser B1, HV-01224B1 Loop B return line to riser B2, HV-01224B2 Pump B discharge valve HV-011-01B Pump D discharge valve HV-011-01D |
| 1A203 | | ESW pump C |
| 1A204 | | ESW pump D |

Table 19. DC power supplies for the ESW system


| Battery | 125 V DC load center | Component supplied |
|---------|-------------------------|--------------------------|
| 610 | 1D614 | ESW pump A control logic |
| 620 | 1D624 | ESW pump B control logic |
| 610 | 1D614 | ESW pump C control logic |
| 620 | 1D624 | ESW pump D control logic |



**SUSQUEHANNA
STEAM ELECTRIC STATION**

SIMPLIFIED DIAGRAM OF
THE EMERGENCY SERVICE
WATER SYSTEM LOOP A

FIGURE 9 REV. 02



**SUSQUEHANNA
STEAM ELECTRIC STATION**

FLOWPATH OF THE
EMERGENCY SERVICE
WATER SYSTEM

FIGURE 10 REV. 01

ESW #####
 BEGIN DATE: 06/08/83 END DATE: 12/31/83

| LINE NO | TECH. SPEC | DOS DATE | DOS MOD DATE | MSR | RETURN DATE | RETURN TIME | CPIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P | C | T | M | COMPONENT ID | S | D | C | V | F | DESCRIPTION OF EVENT | |
|---------------|------------|----------|--------------|------|-------------|-------------|-----------------|---------------------|------------------|--------|--------|----|-----|--------------|----|----|----|----|----|-----------------------------------------------------------------|--|
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | | |
| 154 | 3 | 3.0.3 | 08/18/83 | 1155 | 08/18/83 | 1155 | 06/19/83 | 1545 | 3.83 | 0.00 | 3.83 | Y | | 9-12-012 | 1 | | Y | N | | "A" LOOP ESW INOPERABLE DUE TO 0-12-012 CLOSED 13.0.2 WPP TEST. | |
| 154 | 1 | 3.7.1.2 | 10/03/83 | 0800 | 10/07/83 | 0800 | 10/03/83 | 1500 | 7.07 | 0.00 | 7.00 | Y | | 0F504A | A | | Y | N | | "A" ESW PUMP O/S FOR FN. | |
| 154 | 1 | 3.7.1.2 | 10/04/83 | 0830 | 10/04/83 | 0830 | 10/04/83 | 1405 | 5.58 | 0.00 | 5.58 | Y | | 0F504C | C | | Y | N | | "C" ESW O/S FOR PH'S. | |
| 154 | 1 | 3.7.1.2 | 10/05/83 | 0635 | 10/05/83 | 0635 | 10/05/83 | 1048 | 4.22 | 0.00 | 4.22 | Y | | 0F504B | B | | Y | N | | "B" ESW PUMP O/S FOR FN. | |
| 154 | 1 | 3.7.1.2 | 10/05/83 | 1229 | 10/05/83 | 1229 | 10/05/83 | 1633 | 4.22 | 0.00 | 4.22 | Y | | 0F504D | D | | Y | N | | "D" ESW PUMP O/S FOR FN. | |
| 154 | 1 | 3.7.1.2 | 11/02/83 | 1105 | 11/02/83 | 1105 | 11/02/83 | 1245 | 0.00 | 7.67 | 7.67 | Y | | 0F504E | E | | Y | Y | | "E" ESW PUMP WOULD NOT START MAN. | |
| 154 | 3 | 3.7.1.1 | 12/05/83 | 0350 | 12/05/83 | 0350 | 12/15/83 | 0610 | 0.00 | 242.33 | 242.33 | Y | N/A | | 1 | | N | N | | "A" ESW LOOP DOS SW DIESEL TIE-IN. NOTE: "E" RS. | |
| 154 | 3 | 3.7.1.2 | 12/29/83 | 1430 | 12/29/83 | 1430 | 12/31/83 | 2400 | 0.00 | 57.50 | 57.50 | Y | N/A | | 2 | | N | N | | "B" LOOP ESW INCP. | |
| ### Total ### | | | | | | | | | 24.65 | | 307.50 | | | 332.35 | | | | | | | |

***** SPRAY *****
 BEGIN DATE: 06/08/83 END DATE: 12/31/83

| U S | P C | TECH. SPEC | DOS DATE | DOS MOD DATE | MOD RETURN | RETURN | CPIT | SHUTDOWN | TOTAL P C T M | COMPONENT ID | S D C C | V F | DESCRIPTION OF EVENT |
|---------------|-----|------------|----------|--------------|------------|--------|-------|----------|---------------|--------------|-------------|-----|----------------------|
| N Y | L O | | TIME | TIME DATE | TIME DATE | TIME | TIME | TIME | TIME M M E D | | Y I H O A A | | |
| I S | N N | | | | | | (HRS) | (HRS) | (HRS) S D | | S V A M L I | | |
| T | T D | | | | | | | | T | | N P D L | | |
| *** Total *** | | | | | | | 0.00 | 0.00 | 0.00 | | | | |

3

| U S N I T | P C | TECH. SPEC | O/S DATE | O/S TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M | COMPONENT ID | S D C C | V F | DESCRIPTION OF EVENT |
|---------------|-----|-------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---------|--------------|---------|-----|----------------------------------------------------------------------------------------------------------------------------|
| Y | L O | | | | | | | | | | | | | Y I H D | A A | |
| S | N N | | | | | | | | | | | | | S V A M | L I | |
| T | T C | | | | | | | | | | | | | N P | B L | |
| 154 | 1 | 3.7.1.2 | 06/17/84 | 0805 | 06/17/84 | 0805 | 06/17/84 | 1020 | 2.25 | 0.00 | 2.25 | Y | D-11-004 | D | Y Y | DISCHARGE VALVE FOR 'D' ESW PUMP TRIPPED ITS BREAKER AND BREAKER WON'T RESET - VALV IS CLOSED. 'D' ESW PUMP INOP. |
| 154 | 3 | 3.7.1.2 | 01/01/84 | 0600 | 01/01/84 | 0600 | 01/26/84 | 0648 | 0.00 | 600.80 | 600.80 | Y | N/A | 2 | N N | 'B' LOOP ESW INOP. |
| 154 | 3 | 3.7.1.2 | 01/26/84 | 0200 | 01/31/84 | 0000 | 01/31/84 | 1900 | 0.00 | 19.00 | 19.00 | Y | N/A | 1 | N N | 'A' ESW LOOP O/S TO PERFORM HYDRO. |
| 154 | 3 | 3.9.11.2 | 01/26/84 | 2100 | 01/26/84 | 2100 | 02/01/84 | 0300 | 0.00 | 126.00 | 126.00 | Y | N/A | 1 | Y N | 'A' ESW O/S FOR HYDRO & FLOW BALANCING. |
| 154 | 3 | 3.7.1.2 | 01/28/84 | 0543 | 01/31/84 | 0200 | 01/31/84 | 0200 | 0.00 | 0.00 | 0.00 | Y | OPS04A/C | 1 | Y N | ESW PUMPS 'A' & 'C' O/S FOR INSPECTION. |
| 154 | 3 | 3.7.1.2.8.1 | 01/29/84 | 1350 | 01/31/84 | 1900 | 01/31/84 | 1900 | 0.00 | 0.00 | 0.00 | Y | N/A | 1 | N N | 'A' LOOP ESW INOP DUE TO PROBLEMS WITH SPDS TIE-IN. |
| 154 | 3 | 4.7.1.3.A | 01/29/84 | 1350 | 01/29/84 | 1420 | 01/29/84 | 1420 | 0.00 | 0.00 | 0.00 | Y | N/A | Y | N N | BOTH LOOPS ESW INOP DUE TO SPRAY POND TEMP GREATER THAN 40 DEG F WITH NO SPRAY NETWORKS AVAILABLE. ADMINISTRATIVE PROBLEM. |
| 154 | 3 | 3.7.1.2.8.1 | 01/29/84 | 1350 | 01/29/84 | 1553 | 01/29/84 | 1553 | 0.00 | 0.00 | 0.00 | Y | N/A | Y | N N | BOTH LOOPS ESW INOP DUE TO PROBLEMS WITH SPDS TIE-IN. |
| 154 | 3 | 3.7.1.2 | 02/03/84 | 1400 | 02/03/84 | 1400 | 02/06/84 | 1200 | 0.00 | 70.00 | 70.00 | Y | N/A | 2 | Y N | 'B' ESW LOOP - O/S AND DRAINED. |
| 154 | 3 | 3.7.1.2 | 02/09/84 | 1958 | 02/09/84 | 1958 | 02/10/84 | 0410 | 0.00 | 8.20 | 8.20 | Y | OPS04C | C | Y Y | DURING PERFORMANCE OF SO-024-002C. 'C' ESW FP FAILED TO START AUTOMATICALLY AND SUBSEQUENTIALLY FAILED TO START MANUALLY. |
| 154 | 3 | 3.7.1.2 | 02/15/84 | 0520 | 02/15/84 | 0820 | 02/15/84 | 2100 | 0.00 | 12.67 | 12.67 | Y | N/A | B | Y N | 'B' ESW O/S FOR WIRE CHANGE - 'B' LOOP INOP. |
| 154 | 3 | 3.7.1.2 | 02/15/84 | 0400 | 02/15/84 | 0400 | 02/16/84 | 2130 | 0.00 | 17.50 | 17.50 | Y | OPS04C | C | Y N | PUMP 'C' INOP. |
| 154 | 3 | 3.7.1.2 | 02/17/84 | 0905 | 02/17/84 | 0905 | 02/17/84 | 1450 | 0.00 | 5.75 | 5.75 | Y | 1A20108 | A | Y N | 1A20108 BIR CFEN - 'A' ESW FP O/S FOR BYE INOP. |
| 154 | 1 | 3.7.1.2 | 03/24/84 | 0845 | 03/24/84 | 0845 | 03/24/84 | 1420 | 5.58 | 0.00 | 5.58 | Y | OPS04B | B | Y N | 'B' ESW PUMP INOP FOR MAINT. |
| *** Total *** | | | | | | | | | 7.83 | 859.92 | 867.75 | | | | | |

6-1A

BEGIN DATE: 01/01/84 SPRAY END DATE: 12/31/84

| U S P C | TECH. SFEC | 005 DATE | 005 | MOD DATE | MOD | RETURN | RETURN | CRIT | SHUTDOWN | TOTAL P C T M | COMPONENT ID | S D C C V F | DESCRIPTION OF EVENT |
|---------|------------|----------|------|----------|------|--------|--------|-------|----------|---------------|--------------|-------------|----------------------|
| NY LO | | TIME | TIME | TIME | DATE | TIME | TIME | TIME | TIME | TIME | | Y I H O A A | |
| IS NN | | | | | | | | (HRS) | (HRS) | (HRS) | S D | S V A M L I | |
| T T D | | | | | | | | | | | T | N P D L | |

*** Total ***

0.00 0.00 0.00

VI-10

ESW #####
 BEGIN DATE: 01/01/85 END DATE: 12/31/85

| U S N Y I S T | P C L O N N T O | TECH. SPEC | OS DATE | OS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDN TIME (HRS) | TOTAL P C T M TIME M E O (HRS) | COMPONENT ID | S D C C Y I H O S V A M N P D L | Y F A A L I D L | DESCRIPTION OF EVENT | |
|------------------------|--------------------------|-------------|----------|------------|----------|-------------|----------------|----------------|-----------------------|-------------------------|--------------------------------------|--------------|------------------------------------------|--------------------------|----------------------|---------------------------------------------------------------------------------|
| 054 | 1 | 3.7.1.2.A | 10/09/85 | 1150 | 10/09/85 | 1150 | 10/09/85 | 2230 | 10.67 | 0.00 | 10.67 | Y | 0P504A | A | Y N | 'A' ESW PUMP INOP DURING PERFORMANCE OF SE-054-001. |
| 054 | 1 | 3.7.1.2 | 10/10/85 | 0300 | 10/10/85 | 0330 | 10/10/85 | 2100 | 18.00 | 0.00 | 18.00 | Y | 0-11-004 | D | Y N | 'D' ESW PUMP O/S FOR REPAIRS TO DISCH. CHECK VALVE. |
| 054 | 1 | 3.7.1.2.A.1 | 10/21/85 | 0900 | 10/21/85 | 0900 | 10/21/85 | 1500 | 6.00 | 0.00 | 6.00 | Y | 0P504C | C | Y N | 'C' ESW PUMP INOPERABLE FOR SURVEILLANCE TESTING. |
| 054 | 1 | 3.7.1.2.A.1 | 10/22/85 | 0930 | 10/22/85 | 0930 | 10/22/85 | 1305 | 3.58 | 0.00 | 3.58 | Y | 0P540B | B | Y N | 'B' ESW PUMP INOPERABLE FOR SURVEILLANCE TESTING. |
| 054 | 1 | 3.7.1.2.A.1 | 10/23/85 | 0940 | 10/23/85 | 0940 | 10/23/85 | 1212 | 2.53 | 0.00 | 2.53 | Y | 0P504B | D | Y N | 'D' ESW PUMP INOP FOR SURV TEST. |
| 054 | 1 | 3.7.1.2 | 12/08/85 | 0915 | 12/08/85 | 0815 | 12/08/85 | 1515 | 7.00 | 0.00 | 7.00 | Y | N/A | 2 | Y N | 'B' LOOP ESW INOP FOR PERFORMANCE OF TP-054-050. |
| 054 | 1 | 3.7.1.2 | 12/09/85 | 1010 | 12/09/85 | 1010 | 12/09/85 | 1415 | 4.08 | 0.00 | 4.08 | Y | N/A | 2 | Y N | 'B' LOOP ESW INOP FOR PERFORMANCE OF TP-054-050. |
| 054 | 1 | 3.7.1.2 | 12/11/85 | 1415 | 12/11/85 | 1415 | 12/11/85 | 1700 | 2.75 | 0.00 | 2.75 | Y | N/A | 1 | Y N | 'A' LOOP ESW INOP FOR TP-054-050. |
| 054 | 1 | 3.7.1.2 | 12/12/85 | 0905 | 12/12/85 | 0905 | 12/12/85 | 1345 | 4.00 | 0.00 | 4.00 | Y | N/A | 1 | Y N | 'A' LOOP ESW INOP FOR TP-054-050. |
| 054 | 1 | 3.7.1.2 | 12/12/85 | 1310 | 12/12/85 | 1310 | 12/12/85 | 1945 | 6.58 | 0.00 | 6.58 | Y | N/A | 2 | Y N | 'B' LOOP ESW INOP FOR TP-054-050. |
| 054 | 1 | 3.7.1.2 | 12/16/85 | 0345 | 12/16/85 | 0345 | 12/16/85 | 1700 | 13.25 | 0.00 | 13.25 | Y | 0P504A | A | Y N | 'A' ESW PP O/S FOR MAINT TO CHANGE OIL. |
| 054 | 1 | 3.7.1.2 | 12/19/85 | 0420 | 12/19/85 | 0420 | 12/19/85 | 1915 | 14.92 | 0.00 | 14.92 | Y | 0P504C | C | Y N | 'C' ESW PUMP INOP FOR OIL CHANGE. |
| 054 | 1 | 3.7.1.2 | 12/23/85 | 0415 | 12/23/85 | 0415 | 12/23/85 | 1500 | 10.75 | 0.00 | 10.75 | Y | 0P504B | B | Y N | 'B' ESW PP O/S FOR MAINT. TO CHANGE OIL. |
| 054 | 1 | 3.7.1.2 | 12/26/85 | 0600 | 12/26/85 | 0600 | 12/26/85 | 1630 | 10.50 | 0.00 | 10.50 | Y | 0P504C | C | Y N | 'C' ESW PP O/S TO CHANGE OIL. |
| 154 | 5 | 3.7.1.2 | 04/21/85 | 1015 | 04/21/85 | 1015 | 04/21/85 | 1350 | 0.00 | 3.58 | 3.58 | Y | 1-11-102 | 1 | Y N | 'A' LOOP ESW O/S TO ALLOW FOR U-1 RX BUILD FLOW BALANCING AND WATERHAMMER TEST. |
| 154 | 1 | 3.7.1.2 | 12/07/85 | 0740 | 12/07/85 | 0740 | 12/07/85 | 1515 | 7.58 | 0.00 | 7.58 | Y | N/A | 1 | Y N | DIV I 'A' LOOP ESW INOP DURING TP. |
| ### Total ### | | | | | | | | | 122.19 | 3.58 | 125.77 | | | | | |

VI-11

***** SPRAY *****
 BEGIN DATE: 01/01/85 END DATE: 12/31/85

| U S | P C | TECH. SPEC | OS DATE | OS | MO DATE | MO | RETURN | RETURN | CRIT | SHUTDOWN | TOTAL P C T M | COMPONENT ID | S D C C | V F | DESCRIPTION OF EVENT | |
|---------------|-----|-------------|----------|------|----------|------|----------|--------|--------|----------|---------------|--------------|----------|-----|----------------------|---------------------------------------------------------------------------------------|
| N Y | L D | | TIME | TIME | TIME | DATE | TIME | TIME | (HRS) | (HRS) | (HRS) | S D | Y I H O | A A | | |
| I S | N N | | | | | | | | | | | | S V A N | L I | | |
| T | I D | | | | | | | | | | | | N P | D L | | |
| GSP | 1 | 3.7.1.1 | 06/14/85 | 0830 | 06/14/85 | 0830 | 06/14/85 | 1900 | 10.50 | 0.00 | 10.50 | Y | HV01222B | 2 | Y N | ESW LOOP 'B' INOP DUE TO SPRAY FLOW VALVS. HV-01222B AND HV-01222H MOV'G. |
| GSP | 1 | 3.7.1.2.A.3 | 10/24/85 | 0730 | 10/24/85 | 0730 | 10/25/85 | 1720 | 33.83 | 0.00 | 33.83 | Y | A-1,A-2 | Y | Y N | ESW 'A' LOOP INOPERABLE - A1 AND A2 SPRAY NETWORKS DUE FOR FMR FREE WOP. |
| GSP | 1 | 3.7.1.2 | 10/26/85 | 0815 | 10/26/85 | 0815 | 10/26/85 | 1520 | 7.08 | 0.00 | 7.08 | Y | B-2 | Y | Y N | ESW 'B' LOOP INOP FOR FMR ON SPRAY HEADER (B2 SPRAY NETWORK) INOP. |
| GSP | 1 | 3.7.1.2 | 10/28/85 | 0800 | 10/28/85 | 0800 | 10/28/85 | 1315 | 5.25 | 0.00 | 5.25 | Y | B-1 | Y | Y N | B-1 SPRAY FLOW NETWORK INOP DURING PERFORMANCE OF FMR 64-3042C. |
| GSP | 1 | 3.7.1.2 | 11/07/85 | 0750 | 11/07/85 | 0750 | 11/08/85 | 1525 | 31.58 | 0.00 | 31.58 | Y | A-1,A-2 | Y | Y N | 'A' LOOP ESW INOP FOR SPRAY NETWORK A-1 AND A-2 FLOW DOWN MOVS (INOPS SPRAY NETWORKS) |
| GSP | 1 | 3.7.1.2 | 11/09/85 | 0755 | 11/09/85 | 0755 | 11/09/85 | 1515 | 7.33 | 0.00 | 7.33 | Y | B-1,B-2 | Y | Y N | 'B' LOOP ESW SPRAY NETWORKS INOPERABLE FOR FLOWDOWN MOD. WORK. |
| GSP | 1 | 3.7.1.2 | 11/25/85 | 1315 | 11/25/85 | 1315 | 11/25/85 | 1715 | 4.00 | 0.00 | 4.00 | Y | A-1,A-2 | Y | Y N | ESW SPRAY NETWORK FLOWDOWN IN PROGRESS 'A' LOOP. |
| GSP | 1 | 3.7.1.2 | 11/26/85 | 0950 | 11/26/85 | 0950 | 11/26/85 | 1610 | 6.33 | 0.00 | 6.33 | Y | A-1,A-2 | Y | Y N | ESW SPRAY NETWORK FLOWDOWN IN PROGRESS LOOP 'A'. |
| GSP | 1 | 3.7.1.2 | 11/27/85 | 0950 | 11/27/85 | 0950 | 11/27/85 | 1443 | 4.88 | 0.00 | 4.88 | Y | B-1,B-2 | Y | Y N | 'B' LOOP ESW INOP DUE TO VALVES OPEN FOR NEW FLOWDOWN NETWORK. |
| GSP | 1 | 3.7.1.2 | 12/23/85 | 1305 | 12/23/85 | 1305 | 12/23/85 | 1745 | 4.67 | 0.00 | 4.67 | Y | B-1,B-2 | Y | Y N | 'B' LOOP ESW INOP FOR 'B' SPRAY NETWORK FLOWDOWN. |
| GSP | 1 | 3.7.1.2 | 12/23/85 | 1750 | 12/23/85 | 1750 | 12/23/85 | 1830 | 0.67 | 0.00 | 0.67 | Y | A-1,A-2 | Y | Y N | 'A' LOOP ESW INOP FOR 'A' SPRAY NETWORK FLOWDOWN. |
| GSP | 1 | 3.7.1.2 | 12/23/85 | 1835 | 12/23/85 | 1835 | 12/23/85 | 2130 | 2.92 | 0.00 | 2.92 | Y | B-1,B-2 | Y | Y N | 'B' LOOP ESW INOP FOR 'B' NETWORK FLOWDOWN. |
| 111 Total 111 | | | | | | | | | 119.04 | 0.00 | 119.04 | | | | | |

| U S N Y I S T | P C L O N N T D | TECH. SPEC. | OS DATE | OS TIME | MOD DATE TIME | MOD DATE TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M M E O S D T | COMPONENT ID | S Y S N | C I H V A M N | V F A A L I O L | DESCRIPTION OF EVENT |
|------------------------|--------------------------|-------------|----------|---------|------------------|------------------|-------------|-------------|--------------------|------------------------|---------------------|------------------------------|--------------|------------------|---------------------------------|--------------------------------------|------------------------------------------------------------------------|
| 054 | 1 | 3.7.1.2 | 01/14/86 | 1240 | 01/14/86 | 1240 | 01/14/86 | 1315 | 0.58 | 0.00 | 0.58 | Y | 0-11-001 | A | Y | N | 'A' PUMP BREAKER FACKED OUT TO TEST DISCHARGE CHECK VALVE. |
| 054 | 1 | 3.7.1.2 | 05/22/85 | 0109 | 05/22/86 | 0100 | 05/24/86 | 1755 | 52.50 | 2.42 | 64.92 | Y | 0P504C | C | Y | Y | ESW 'C' PUMP INOPERABLE DUE TO A SHEARED SHAFT. |
| 054 | 1 | 3.7.1.2 | 05/22/86 | 0100 | 05/24/86 | 1755 | 06/06/86 | 1100 | 0.00 | 305.08 | 305.08 | Y | 0P504A | A | Y | Y | PUMP 'A' DAMAGE TO PUMP SUCTION. ALL PUMPS ERODED, BUT ONLY 'A' INOP. |
| 054 | 3 | 3.7.1.2 | 06/06/86 | 1200 | 06/06/86 | 1200 | 06/10/86 | 1105 | 0.00 | 95.08 | 95.08 | Y | 0P504R/D | 2 | Y | N | ESW 'B' LOOP INOPERABLE FOR 'R' & 'D' PUMP REPAIRS. |
| 054 | 3 | 3.7.1.2 | 06/12/86 | 1050 | 06/12/86 | 1050 | 06/12/86 | 2130 | 0.00 | 10.67 | 10.67 | Y | 0P504A/C | 1 | Y | N | ESW 'A' LOOP INOPERABLE TO REPLACE RELAYS FOR PUMPS 'A' & 'C'. |
| 154 | 3 | 3.7.1.2 | 02/14/85 | 1410 | 02/14/86 | 1410 | 02/15/86 | 2100 | 11.63 | 19.20 | 30.83 | Y | N/A | Y | N | N | NO ESW COOLING FOR HPCT AND RCIC ROOMS. ESW INOPERABLE DUE TO TESTING. |
| ### Total ### | | | | | | | | | 74.71 | 432.45 | 507.16 | | | | | | |

BEGIN DATE: 01/01/86 SPRAY END DATE: 12/31/86

| U S N Y I S I | P C L O M N T O | TECH. SPEC | DOS DATE | DOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M M E O S O T | COMPONENT ID | S D C C Y I H O S V & M H P O L | Y F A A L I O L | DESCRIPTION OF EVENT |
|------------------------|--------------------------|------------|----------|-------------|----------|-------------|----------------|----------------|-----------------------|---------------------------|------------------------|------------------------------|--------------|------------------------------------------|--------------------------|------------------------------------------------------------------------------------|
| OSP | 1 | 3.7.1.2 | 02/14/86 | 1100 | 02/14/86 | 1100 | 02/14/86 | 1548 | 4.80 | 0.00 | 4.80 | Y | TI-012228 | A | N N | SPRAY POND TEMP SWITCH TI-012266 REPLACEMENT AND CALIBRATION. |
| OSP | 1 | 3.7.1.2 | 11/03/86 | 0900 | 11/03/86 | 0900 | 11/03/86 | 1830 | 9.50 | 0.00 | 9.50 | Y | HV01222B | 2 | Y N | 'B' LOOP DOS TO REPLACE AGASTAT RELAY ON SPRAY POND DISCHARGE BYPASS VALVE. |
| ISP | 1 | 3.7.1.2 | 10/12/86 | 1345 | 10/12/86 | 1345 | 10/12/86 | 1820 | 4.58 | 0.00 | 4.58 | Y | N/A | 1 | Y N | 'A' LOOP INOPERABLE FOR AGASTAT RELAY CHANGES FOR VALVES HV01222A AND HV01222B. A: |
| *** Total *** | | | | | | | | | 18.88 | 0.00 | 18.88 | | | | | |

VI-14

| HS | P C | TECH. SPEC. | DOE DATE | OS | MOG DATE | MOG | RETURN | RETURN | CRIT | SHUTDOWN | TOTAL P C T M | COMPONENT ID | S D C C | Y F | DESCRIPTION OF EVENT |
|---------------|-----|-------------|----------|------|----------|------|----------|--------|--------|----------|---------------|--------------|---------|-----|------------------------------------------------------------------------------------|
| NY | LR | | | TIME | TIME | DATE | TIME | TIME | TIME | TIME | M E D | | Y I H O | A A | |
| 15 | N 4 | | | | | | | | (HRS) | (HRS) | (HRS) | S D | S Y A H | L I | |
| 1 | 10 | | | | | | | | | | T | | N F | D L | |
| 054 | 1 | 3.7.1.2 | 02/12/87 | 0745 | 02/12/87 | 0745 | 02/12/87 | 1810 | 10.42 | 0.00 | 10.42 | Y N/A | 1 | Y N | REPLACED VARIOUS RELAYS PER FMR. |
| 054 | 1 | 3.7.1.2 | 02/26/87 | 0600 | 02/26/87 | 0600 | 02/26/87 | 1435 | 8.58 | 0.00 | 8.58 Y | QPS04B/D | 2 | Y N | "R" & "D" ESW PUMPS O/S FOR PM'S. |
| 054 | 1 | 3.7.1.2 | 02/27/87 | 0630 | 02/27/87 | 0630 | 02/27/87 | 1640 | 10.17 | 0.00 | 10.17 Y | QPS04A/C | 1 | Y N | "A" & "C" ESW PUMPS O/S FOR PM'S. |
| 054 | 1 | 3.7.1.2 | 03/25/87 | 0658 | 03/25/87 | 0658 | 03/25/87 | 2100 | 12.03 | 0.00 | 12.03 Y | N/A | 1 | N N | "A" LOOP ESW O/S FOR 18 MONTH LOGIC SURV. |
| 054 | 1 | 3.7.1.2 | 03/26/87 | 0825 | 03/26/87 | 0825 | 03/26/87 | 1500 | 6.58 | 0.00 | 6.58 Y | N/A | 1 | N N | "A" LOOP ESW O/S FOR 18 MONTH LOGIC SURV. |
| 054 | 1 | 3.7.1.2 | 03/27/87 | 0740 | 03/27/87 | 0740 | 03/27/87 | 1220 | 4.67 | 0.00 | 4.67 Y | N/A | 2 | N N | "R" LOOP ESW O/S FOR 18 MONTH LOGIC SURV. |
| 054 | 1 | 3.7.1.2 | 05/27/87 | 0940 | 05/27/87 | 0940 | 05/27/87 | 1200 | 2.33 | 0.00 | 2.33 Y | N/A | 2 | N N | "B" LOOP ESW INOP WHILE ISOLATION VALVES OPEN TO "E" DIESEL FOR TESTING. |
| 054 | 1 | 3.7.1.2 | 05/27/87 | 1300 | 05/27/87 | 1300 | 05/27/87 | 1345 | 0.75 | 0.00 | 0.75 Y | QPS04A/C | 1 | N N | "A" LOOP ESW O/S FOR "A" & "C" PUMP PERFORMANCE TEST. |
| 054 | 1 | 3.7.1.2 | 05/28/87 | 0500 | 05/28/87 | 0500 | 05/28/87 | 1853 | 13.08 | 0.00 | 13.08 Y | QPS04A/C | 1 | Y N | "A" LOOP ESW O/S FOR PUMP INSPECTION. |
| 054 | 1 | 3.7.1.2 | 05/30/87 | 0940 | 05/30/87 | 0940 | 05/30/87 | 1310 | 3.50 | 0.00 | 3.50 Y | N/A | 2 | N N | LOOP "B" ESW INOP WHILE LINED UP TO "E" DIESEL. |
| 054 | 1 | 3.7.1.2 | 09/09/87 | 0315 | 09/09/87 | 0315 | 09/09/87 | 2340 | 20.42 | 0.00 | 20.42 Y | QPS04A | A | Y Y | REPLACE "A" ESW PUMP END BELL AND LINER. |
| 054 | 1 | 3.7.1.2 | 09/10/87 | 0230 | 09/10/87 | 0230 | 09/10/87 | 2130 | 19.00 | 0.00 | 19.00 Y | QPS04C | C | Y N | REPLACE "C" ESW PUMP END BELL AND LINER. |
| 054 | 1 | 3.7.1.2 | 09/10/87 | 1009 | 09/10/87 | 1009 | 09/10/87 | 1032 | 0.38 | 0.00 | 0.38 Y | 2FU3 | 2 | Y N | WIRING CHANGE TO FUSE 2FU3. |
| 054 | 1 | 3.7.1.2 | 09/11/87 | 0240 | 09/11/87 | 0240 | 09/11/87 | 0555 | 3.25 | 0.00 | 3.25 Y | QPS04A | A | N N | TP-054-065 TESTS PUMP FLOW. |
| 054 | 1 | 3.7.1.2 | 09/11/87 | 0605 | 09/11/87 | 0605 | 09/11/87 | 1028 | 4.38 | 0.00 | 4.38 Y | QPS04C | C | N N | TP-054-065 TESTS PUMP FLOW. |
| 154 | 5 | 3.7.4 | 09/29/87 | 1600 | 09/29/87 | 1600 | 10/07/87 | 1815 | 0.00 | 194.25 | 194.25 Y | 1-11-102 | 2 | N N | ESW LOOP "B" ISOLATED TO REACTOR BUILDING (UNIT 1) FOR HANGERS AND SNUBBER TESTING |
| 154 | 5 | 3.7.1.2 | 10/06/87 | 1320 | 10/08/87 | 1320 | 10/15/87 | 1810 | 0.00 | 172.83 | 172.83 Y | 1-11-102 | 1 | N N | U-1 RB ISOLATED FROM ESW FOR SNUBBER WORK. |
| *** Total *** | | | | | | | | | 120.34 | 367.08 | 487.42 | | | | |

SPRAY #####
BEGIN DATE: 01/01/87 END DATE: 12/31/87

| U S | P C | TECH. SPEC | DOS DATE | DOS | MOD DATE | MOD | RETURN | RETURN | CRIT | SHUTDWN | TOTAL P C T H | COMPONENT ID | S D C C | Y F | DESCRIPTION OF EVENT |
|-----|-----|------------|----------|------|----------|------|--------|--------|-------|---------|---------------|--------------|---------|-----|----------------------|
| N Y | I O | | TIME | TIME | TIME | DATE | TIME | TIME | TIME | TIME | H M E D | | Y I H O | A A | |
| J S | N N | | | | | | | | (HRS) | (HRS) | (HRS) | S D | S V A M | L I | |
| T | T D | | | | | | | | | | T | | W P | D L | |

Total

0.00 0.00 0.00

VI-16

***** ESW *****
 BEGIN DATE: 01/01/88 END DATE: 06/07/88

| U S W Y I S T | P C L O N N T D | TECH. SPEC | OOS DATE | OOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL P C T M TIME M H E O (HRS) S D T | COMPONENT ID | S Y S M P | D I S A M P | C H O M P | V A L I D | DESCRIPTION OF EVENT |
|------------------------|--------------------------|------------|----------|-------------|----------|-------------|----------------|----------------|-----------------------|---------------------------|-------------------------------------------------|--------------|-----------------------|----------------------------|-----------------------|-----------------------|----------------------------------------------------------------------------|
| 054 | 1 | 3.7.1.2 | 02/04/88 | 0745 | 02/04/88 | 0745 | 02/04/88 | 0914 | 1.48 | 0.00 | 1.48 | Y | 0PS04A | A | Y | N | 'A' ESW PUMP O/S DURING SWAP OF BREAKER 1A201-08 WITH A SPARE BREAKER. |
| 054 | 1 | 3.7.1.2 | 02/22/88 | 0500 | 02/22/88 | 0500 | 02/22/88 | 1620 | 11.33 | 0.00 | 11.33 | Y | 0PS04C | C | Y | N | 'C' ESW PUMP O/S FOR CHECK VALVE MAINTENANCE & MOTOR WINDING INSPECTION. |
| 054 | 1 | 3.7.1.2 | 02/23/88 | 1715 | 02/23/88 | 1715 | 02/23/88 | 2150 | 4.59 | 0.00 | 4.59 | Y | 0PS04B/D | 2 | Y | N | 'B' & 'D' ESW PUMPS O/S TO ADJUST DISCHARGE CHECK VALVES. |
| 054 | 1 | 3.7.1.2 | 02/23/88 | 2200 | 02/23/88 | 2200 | 02/23/88 | 2335 | 1.58 | 0.00 | 1.58 | Y | 0PS04A | A | Y | N | 'A' ESW PUMP O/S TO ADJUST DISCHARGE CHECK VALVES. |
| 054 | 1 | 3.7.1.2 | 02/26/88 | 1930 | 02/26/88 | 1930 | 02/28/88 | 0025 | 28.92 | 0.00 | 28.92 | Y | HV01101A/C | 1 | Y | N | 'A' LOOP ESW O/S FOR CHECK VALVE INSPECTION AND DISCHARGE VALVE ADJUSTING. |
| 054 | 1 | 3.7.1.2 | 02/28/88 | 0040 | 02/28/88 | 0040 | 02/28/88 | 2030 | 19.83 | 0.00 | 19.83 | Y | HV01101B/D | 2 | Y | N | 'B' LOOP ESW O/S FOR CHECK VALVE INSPECTION AND DISCHARGE VALVE ADJUSTING. |
| 054 | 4 | 3.7.1.2 | 06/07/88 | 0740 | 06/07/88 | 0740 | 06/07/88 | 0820 | 0.00 | 0.67 | 0.67 | Y | 0PS04C | C | Y | N | 'C' ESW PUMP INOP WHILE BREAKER CHANGEOUT 1/P. (1A20303) |
| 154 | 1 | 3.7.1.2 | 04/13/88 | 2140 | 04/13/88 | 2140 | 04/14/88 | 0400 | 6.33 | 0.00 | 6.33 | Y | N/A | 1 | N | N | U-2 SURVEILLANCE INOPS 'A' LOOP OF ESW. |
| *** Total *** | | | | | | | | | 74.05 | 0.67 | 74.72 | | | | | | |

***** SPRAY *****

BEGIN DATE: 01/01/89

END DATE: 06/07/89

| U S | P C | TECH. SPEC | DOS DATE | DOS | MOD DATE | MOD | RETURN | RETURN | CRIT | SHUTDOWN | TOTAL P | C T M | COMPONENT ID | S D C C | Y F | DESCRIPTION OF EVENT |
|-----|-----|------------|----------|------|----------|------|--------|--------|-------|----------|---------|-------|--------------|---------|-----|----------------------|
| N Y | L D | | TIME | TIME | TIME | DATE | TIME | TIME | TIME | TIME | H M E O | | | Y I H O | A A | |
| I S | M N | | | | | | | (HRS) | (HRS) | (HRS) | S D | | | S Y A M | L I | |
| T | T D | | | | | | | | | | T | | | N P | O L | |

*** Total ***

0.00 0.00 0.00

APPENDIX VII

DC POWER SYSTEM

DC POWER SYSTEM

SYSTEM DESCRIPTION.

Function

The function of the DC power system is to provide electric power to plant systems used for the normal operation of the plant and also for systems used to mitigate events that may occur. The DC power system is divided in accordance with the two primary functions into the non-safety feature and the Essential Safety Systems (ESS) DC system. Only the ESS is discussed in this section.

The Class 1E DC power system provides a reliable source of DC power for Class 1E AC switchgear, diesel generators, valves, plant alarms and indicators, and the emergency lighting system.

Design and Operation

Class 1E DC power is provided at the 125 V and 250 V levels. There are four Class 1E 125 V channels (A, B, C, and D) and two Class 1E 250 V divisions (I and II).

The 24 V DC system, which is also a class 1E power supply, supplies radiation and neutron monitors for normal plant operation: Source Range Monitors, Intermediate Range Monitors, and Process Radiation Monitors. This system has no impact on accident mitigation. Even if the 24 V DC system failed, the series of events that would have to occur to affect the safe shutdown of the reactor following an initiating event have such low probabilities of failure that this system failure does not need to be considered. Therefore, the 24 V DC system was not modeled.

Figure 11 is a simplified diagram of one channel in the 125 V DC power system (each channel is identical in layout). The voltage supply on each channel is normally maintained by a charger powered from a 480 V load center. The charger also keeps a 125 V lead-acid battery charged. Power to the charger connected to each 125 V DC load center comes from an ESS 480 V AC load center through an intermediate motor control center (MCC) common to Units 1 and 2. (These common MCCs, OB516, OB526, OB536, and OB546, also provide diesel generator support.) The common MCCs are connected to a Unit 1 and 2 ESS 480 V AC load center through an automatic transfer switch. There is no preferred load center. The battery on each channel has a design discharge time of 4 hours with a full load.

Division I of the 250 V DC system (see Figure 12) is provided with one 250 V battery and two chargers. Each charger is powered from a separate 480 V AC MCC. Division II (See Figure 13) has one 250 V battery and one charger which is powered from a 480 V AC MCC. These two divisions provide DC power for larger loads, such as DC driven pumps and valves. The battery chargers are full-wave silicon-controlled rectifiers. They have the capacity to supply the largest combined loads on each DC load center and fully recharge the batteries within 12 hours. Like the batteries in the 125 V DC system, the 250 V batteries have a design discharge time of 4 hours with a full load.


Voltmeters and ammeters are used to continuously monitor the load centers and battery chargers. Ground-detection lights are located on each DC load

center to indicate the presence of bus grounding. Battery monitors check on the status of each battery and indicate whether the battery is losing normal charge. There are control room annunciators for each DC channel or division. These annunciators alarm when there is a problem with the DC load centers, chargers, batteries, control centers, or distribution panels.

Support Systems

The Class 1E 480 V AC distribution system is the power source for the DC battery chargers. The ventilation system supplies and exhausts the battery rooms to prevent hydrogen-gas buildup to combustible levels.

VII-3




SUSQUEHANNA
STEAM ELECTRIC STATION

SIMPLIFIED DIAGRAM
OF ONE CHANNEL IN THE
125 V DC POWER SYSTEM

FIGURE 11 REV. 01


VII-4



SUSQUEHANNA
STEAM ELECTRIC STATION
SIMPLIFIED DIAGRAM
OF 250 V DC
POWER SYSTEM
DIVISION

FIGURE 12 REV. 01

S-IIA



| | |
|------------------------------------------------------------------|---------|
| SUSQUEHANNA STEAM ELECTRIC STATION | |
| SIMPLIFIED DIAGRAM OF 250 V DC POWER SYSTEM DIVISION II | |
| FIGURE 13 | REV. 01 |

***** DC125 *****
 BEGIN DATE: 06/08/83 END DATE: 12/31/83

| U S F C | TECH. SPEC | 005 RATE | 005 | MOD DATE | MOO | RETURN | RETURN | CRIT | SHUTDOWN | TOTAL F C T H | COMPONENT ID | S O C C | V F | DESCRIPTION OF EVENT |
|---------|------------|----------|------|----------|------|--------|--------|-------|----------|---------------|--------------|---------|-----|----------------------|
| N L D | | | TIME | TIME | DATE | DATE | TIME | TIME | TIME | M E D | | Y I N D | A A | |
| Y S H R | | | | | | | | (HRS) | (HRS) | (HRS) | S D | S V A H | L I | |
| T I G | | | | | | | | | | | I | N P | D L | |

*** Total ***

0.00 0.00 0.00

| U S | P C | TECH. SPEC | DOS DATE | DOS TIME | NOV DATE | NOV TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL PCT N TIME H N E O (HRS) | COMPONENT ID | S D C C V F | DESCRIPTION OF EVENT |
|-----|-----|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|--------------------------------|--------------|-------------|----------------------|
| NY | LO | | | | | | | | | | | | Y I H O A A | |
| IS | NM | | | | | | | | | | | | S V A M L I | |
| T | TD | | | | | | | | | | | | N P D L | |

Total

0.00 0.00 0.00

VII-7

| U S N Y I S T | P C L O N H T C | TECH. SPEC | OS DATE | OS TIME | MO DATE | MO TIME | RET DATE | RET TIME | CRIT TIME (HRS) | SHUTDN TIME (HRS) | TOTAL P C T M TIME M H E D (HRS) S D | COMPONENT ID | S D C C Y I H O S V A M N P O L | V F A A L I O L | DESCRIPTION OF EVENT |
|------------------------|--------------------------|------------|----------|------------|----------|------------|----------|-------------|-----------------------|-------------------------|--------------------------------------------|--------------|------------------------------------------|--------------------------|-----------------------------------------------------------------------------|
| 102 | 1 | 3.8.2.1 | 01/02/85 | 1117 | 01/02/85 | 1117 | 01/02/85 | 1154 | 0.62 | 0.00 | 0.62 | Y | 10623 | Y Y N | 10623 BATTERY CHARGER REMOVED FROM SERVICE TO INVESTIGATE OATSS26 TROUBLE. |
| 102 | 1 | 3.8.2.1 | 01/02/85 | 1400 | 01/02/85 | 1400 | 01/02/85 | 1420 | 0.33 | 0.00 | 0.33 | Y | 10623 | Y Y N | 10623 BATTERY CHARGER REMOVED FROM SERVICE TO INVESTIGATE OATSS26 TROUBLE. |
| 102 | 1 | 3.8.2.1 | 01/03/85 | 1155 | 01/03/85 | 1155 | 01/03/85 | 1216 | 0.35 | 0.00 | 0.35 | Y | 10623 | Y Y N | 10623 BATTERY CHARGER REMOVED FROM SERVICE TO INVESTIGATE OATSS26 TROUBLE. |
| 102 | 1 | 3.8.2.1 | 01/21/85 | 1301 | 01/21/85 | 1301 | 01/21/85 | 1319 | 0.30 | 0.00 | 0.30 | Y | 10643 | Y Y N | 10643 BATTERY CHARGER REMOVED FROM SERVICE TO REPLACE TRANSDUCER IN CAFE. |
| 102 | 1 | 3.8.2.1 | 06/17/85 | 0830 | 06/17/85 | 0830 | 06/17/85 | 1045 | 2.25 | 0.00 | 2.25 | Y | 10610 | Y Y N | REPLACE CELLS 18, 9 AND 21 IN BATTERY BANK 10610. |
| 102 | 1 | 3.8.2.1 | 06/18/85 | 0635 | 06/18/85 | 0635 | 06/18/85 | 1030 | 3.92 | 0.00 | 3.92 | Y | 10630 | Y Y N | REPLACE DEFECTIVE CELL IN BATTERY 10630. |
| 102 | 1 | 3.8.2.1 | 06/19/85 | 0625 | 06/19/85 | 0625 | 06/19/85 | 0750 | 1.42 | 0.00 | 1.42 | Y | 10640 | Y Y N | U-1 BATTERY BANK 10640 REMOVED FROM SERVICE TO REPLACE BAD CELLS. |
| 102 | 1 | 3.8.2.1 | 09/04/85 | 1110 | 09/04/85 | 1110 | 09/04/85 | 1200 | 0.83 | 0.00 | 0.83 | Y | 10623 | Y Y Y | 10623 O/S TO REPLACE FAULTY CIRCUIT BOARD. |
| 102 | 1 | 3.8.2.1.B | 09/30/85 | 0650 | 09/30/85 | 0650 | 09/30/85 | 0100 | 0.17 | 0.00 | 0.17 | Y | 10643 | Y N N | 10643 BATTERY CHARGER NOT MAINTAINING 125 VDC VOLTAGE (VOLTAGE > 122 VDC). |
| ### Total ### | | | | | | | | | 10.19 | 0.00 | 10.19 | | | | |

| U S | F C | TECH. SPEC | DOS DATE | DOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M | COMPONENT ID | S D C C | V F | DESCRIPTION OF EVENT |
|---------------|-----|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---------|--------------|---------|-----|------------------------------------------------------------------------------------|
| N Y | L O | | | | | | | | | | | | | Y I H O | A A | |
| I S | N N | | | | | | | | | | | | | S Y A M | L I | |
| T | T D | | | | | | | | | | | | | N P | D L | |
| 102 | 3 | 3.8.2.2 | 02/17/86 | 1530 | 02/17/86 | 1530 | 02/18/86 | 2359 | 0.00 | 32.48 | 32.48 | Y | N/A | Y | N N | DIV 1A NOT ALIGNED TO NORMAL SOURCE FOR BATTERY TESTS 125V DC (ALL FOUR CHANNELS). |
| 102 | 1 | 3.8.2.1 | 04/28/86 | 1345 | 04/28/86 | 1345 | 04/28/86 | 1640 | 4.92 | 0.00 | 4.92 | Y | 10643 | Y | N N | INVESTIGATE BATTERY CHARGER 10643 - NO PROBLEMS WERE FOUND (125V DC). |
| 102 | 1 | 3.8.2.1 | 05/01/86 | 1400 | 05/01/86 | 1400 | 05/01/86 | 1500 | 1.00 | 0.00 | 1.00 | Y | 10643 | Y | Y Y | REPLACE 10643 BATTERY CHARGER AMPLIFIER BOARD (125V DC). |
| 192 | 1 | 3.8.2.1 | 05/16/86 | 0840 | 05/16/86 | 0840 | 05/16/86 | 0958 | 1.30 | 0.00 | 1.30 | -Y | 10643 | Y | Y Y | REPLACE 10643 BATTERY CHARGER CURRENT LIMIT AND AMPLIFIER BOARD (125V DC). |
| 102 | 2 | 3.8.2.1 | 12/19/86 | 2230 | 12/19/86 | 2230 | 12/21/86 | 2100 | 0.00 | 46.50 | 46.50 | Y | 10613 | Y | Y Y | BATTERY CHARGER 10613 INOPERABLE (125V DC). |
| *** Total *** | | | | | | | | | 7.22 | 78.98 | 86.20 | | | | | |

***** DC125 *****
 BEGIN DATE: 01/01/87 END DATE: 12/31/87

| U S P C | TECH. SPEC | DOS DATE | DOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M | COMPONENT ID | S D C C | V F | DESCRIPTION OF EVENT | |
|---------------|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---------|--------------|---------|-----|----------------------|--------------------------------------------------------|
| N Y L O | | | | | | | | | | | | | Y I H O | A A | | |
| I S N N | | | | | | | | | | | | | S V A M | L I | | |
| T T O | | | | | | | | | | | | | N P | G L | | |
| 102 | I | 3.8.2.1 | 02/09/87 | 0815 | 02/09/87 | 0815 | 02/09/87 | 0815 | 0.50 | 0.00 | 0.50 | Y | 10613 | | Y Y Y | CHARGER 10613 FAILED AS A RESULT OF CAPACITOR FAILURE. |
| 102 | I | 3.8.2.1 | 02/26/87 | 1030 | 02/20/87 | 1030 | 02/20/87 | 1135 | 1.08 | 0.00 | 1.08 | Y | 10613 | | Y Y Y | CHARGER 10613 FAILED AS A RESULT OF CAPACITOR FAILURE. |
| 102 | I | 3.8.2.1 | 02/20/87 | 1136 | 02/20/87 | 1136 | 02/20/87 | 1320 | 1.73 | 0.00 | 1.73 | Y | 10612 | A | Y N | BUS 10612 D/S FOR REPAIR. |
| 102 | I | 3.8.2.1 | 02/20/87 | 1321 | 02/20/87 | 1321 | 02/20/87 | 1730 | 4.15 | 0.00 | 4.15 | Y | 10613 | | Y Y N | CHARGER 10613 D/S FOR REPAIR. |
| *** Total *** | | | | | | | | | 7.46 | 0.00 | 7.46 | | | | | |

***** DC125 *****
 BEGIN DATE: 01/01/88 END DATE: 06/07/88

| U S P C | TECH. SPEC | OOS DATE | OOS MOD DATE | MOD RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDWN TIME (HRS) | TOTAL TIME (HRS) | P C T M | COMPONENT ID | S D C C V F | DESCRIPTION OF EVENT |
|---------------|------------|----------|---------------|-----------------|-------------|-----------------|--------------------|------------------|---------|--------------|-------------|-------------------------------------------------------------------------|
| N Y L O | | TIME | TIME DATE | TIME DATE | TIME | | | | M E O | | Y I H O A A | |
| I S M N | | | | | | | | | S D | | S V A M L I | |
| T T D | | | | | | | | | T | | N P D L | |
| 102 1 | 3.8.2.1 | 05/05/88 | 1325 05/05/88 | 1325 05/06/88 | 0300 | 13.58 | 0.00 | 13.58 | Y | 10610 | Y N M | 10610 CELL #45 TESTED AT 2.071 VOLTS - DOES NOT MEET CATEGORY B LIMITS. |
| 102 1 | 3.9.2.1 | 05/06/88 | 0205 05/06/88 | 0205 05/06/88 | 0300 | 0.92 | 0.00 | 0.92 | Y | 10610 | Y Y N | 10610 (125V DC BATTERY BANK) INCP WHILE REMOVING CELL #45. |
| *** Total *** | | | | | | 14.50 | 0.00 | 14.50 | | | | |

***** DC250 *****
 BEGIN DATE: 06/08/83 END DATE: 12/31/83

| U S P C | TECH. SPEC | COE DATE | DOS | MOD DATE | MOD | RETURN | RETURN | CRIT | SHUTDOWN | TOTAL P C T K | COMPONENT ID | S D E C | V F | DESCRIPTION OF EVENT |
|---------|------------|----------|------|----------|------|--------|--------|-------|----------|---------------|--------------|---------|-----|----------------------|
| N Y L O | | | TIME | TIME | TIME | DATE | TIME | TIME | TIME | TIME | M M E O | Y I H O | A A | |
| I S M N | | | | | | | | (HRS) | (HRS) | (HRS) | S D | S V A N | L I | |
| T T D | | | | | | | | | | T | | N P | O L | |

*** Total ***

0.00 0.00 0.00

VII-12

EC250
 BEGIN DATE: 01/01/84 END DATE: 12/31/84

| IS | PC | TECH. SPEC | DOS DATE | DOS TIME | MOD DATE | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P | C | T | M | COMPONENT ID | S | D | C | V | F | DESCRIPTION OF EVENT | |
|---------------|----|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---|---|---|--------|--------------|---|---|---|---|---|-------------------------------------------------------------------------|--|
| N | Y | L | O | | | | | | | | | | | | | | Y | I | H | O | A | A | |
| 1 | S | N | N | | | | | | | | | | | | | | S | V | A | M | L | I | |
| 1 | | T | D | | | | | | | | | | | | | | N | P | D | L | | | |
| 169 | 1 | 3.8.2.1 | 04/12/84 | 0830 | 04/12/84 | 0830 | 04/12/84 | 0844 | 0.23 | 0.00 | 0.23 | Y | | | 10653A | Y | N | N | | | | BATTERY CHARGER 10653A REMOVED FROM SERVICE TO ADJUST OUTPUT VOLTAGE. | |
| 168 | -1 | 3.8.2.1 | 04/12/84 | 0844 | 04/12/84 | 0844 | 04/12/84 | 0858 | 0.23 | 0.00 | 0.23 | Y | | | 10653B | Y | N | N | | | | BATTERY CHARGER 10653B REMOVED FROM SERVICE TO ADJUST OUTPUT VOLTAGE. | |
| 169 | 1 | 3.8.2.1 | 07/13/84 | 1259 | 07/13/84 | 1259 | 07/13/84 | 1743 | 4.73 | 0.00 | 4.73 | Y | | | 10653A | Y | Y | Y | | | | 10653A 256VDC BATTERY CHARGER - BLOWN CAPACITOR. | |
| 168 | 1 | 3.8.2 | 07/16/84 | 1120 | 07/16/84 | 1120 | 07/16/84 | 1306 | 1.77 | 0.00 | 1.77 | Y | | | 10653A | Y | Y | Y | | | | 10653A BATTERY CHARGER CUT OF SERVICE TO REPLACE CHARGER FAILURE BOARD. | |
| *** Total *** | | | | | | | | | 6.96 | 0.00 | 6.96 | | | | | | | | | | | | |

*****EC250*****
 BEGIN DATE: 01/01/85 END DATE: 12/31/85

| U S N I 1 5 1 | P C L O N N T P | TECH. SPEC | DOS DATE | DOS TIME | MOD DATE TIME | MOD TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDN TIME (HRS) | TOTAL F C T M TIME M A E O (HRS) S D T | COMPONENT ID | S D C C Y E H O S V A A N P D L | Y F A A L I | DESCRIPTION OF EVENT |
|------------------------|--------------------------|------------|----------|-------------|------------------|-------------|----------------|----------------|-----------------------|-------------------------|-------------------------------------------------|--------------|------------------------------------------|-------------------|-------------------------------------------------------------|
| 158 | 2 | 3.8.2.1 | 12/03/85 | 1455 | 12/03/85 | 1455 | 12/04/85 | 1745 | 0.00 | 26.83 | 26.83 | Y | 10653A/B | Y N N | 10653A/B WILL NOT OPERATE IN PARALLEL - ONLY 1 CHARGER 1/S. |
| 159 | 1 | 3.8.2.1 | 12/10/85 | 0730 | 12/10/85 | 0730 | 12/10/85 | 1230 | 5.00 | 0.00 | 5.00 | Y | 10653B | Y Y N | 10653B 250VIC BATTERY CHARGER, O/S FOR MAINTENANCE. |
| *** Total *** | | | | | | | | | 5.00 | 26.83 | 31.83 | | | | |

VII-14

***** DC250 *****
 BEGIN DATE: 01/01/86 END DATE: 12/31/86

| U S P C | TECH. SPEC | DOS DATE | DOS MOD DATE | MOD RETURN | RETURN | CRIT | SHUTDN | TOTAL P C T M | COMPONENT ID | S D C C | V F | DESCRIPTION OF EVENT |
|---------|------------|----------|--------------|------------|--------|-------|--------|---------------|--------------|---------|-----|----------------------|
| N Y L O | | TIME | TIME DATE | TIME DATE | TIME | TIME | TIME | TIME M M E D | | Y I H O | A A | |
| I S M N | | | | | | (HRS) | (HRS) | (HRS) S O | | S V A M | L I | |
| I T C | | | | | | | | T | | N P | D L | |

*** Total ***

0.00 0.00 0.00

***** DC250 *****
BEGIN DATE: 01/01/87 END DATE: 12/31/87

| U S N) I S T | P C L O N N T D | TECH. SPEC | DOS DATE | DOS TIME | MOD DATE TIME | MOD DATE | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL P C T H TIME H H E O (HRS) S D T | COMPONENT ID | S D C Z Y I H Q A R S V A M L I N P O L | Y F A R L I O L | DESCRIPTION OF EVENT |
|------------------------|--------------------------|------------|----------|-------------|------------------|-------------|----------------|----------------|-----------------------|---------------------------|-------------------------------------------------|--------------|--------------------------------------------------|--------------------------|----------------------|
|------------------------|--------------------------|------------|----------|-------------|------------------|-------------|----------------|----------------|-----------------------|---------------------------|-------------------------------------------------|--------------|--------------------------------------------------|--------------------------|----------------------|

*** Total ***

0.00 0.00 0.00


***** CC250 *****
 BEGIN DATE: 01/01/89 END DATE: 06/07/89

| U S P C | TECH. SPEC | DOS DATE | DOS | MOD DATE | MOD | RETURN | RETURN | CRIT | SHUTDOWN | TOTAL P C T M | COMPONENT ID | S O C C | V F | DESCRIPTION OF EVENT |
|---------|------------|----------|-----|----------|------|--------|--------|-------|----------|---------------|--------------|---------|-----|----------------------|
| N Y L O | | TIME | | TIME | TIME | DATE | TIME | TIME | TIME | TIME M N E O | | Y I H O | A A | |
| I S N N | | | | | | | | (HRS) | (HRS) | (HRS) | S D | S Y A M | L I | |
| T T E | | | | | | | | | | T | | N P | D L | |

*** Total ***


0.00 0.00 0.00

VII-17



APPENDIX VIII

AC POWER SYSTEM



AC POWER SYSTEM

SYSTEM DESCRIPTION

Function

The function of the AC power system is to provide electric power to plant systems used for the normal operation of the plant and also for systems used to mitigate events that may occur. The AC power system is divided in accordance with the two primary functions into the non-safety feature and the Essential Safety Systems (ESS) AC system. Only the ESS system is discussed in this section.

Design and Operation

Offsite power to the Class 1E AC power system is supplied by the non-Class 1E 13.8 kV system. The Class 1E ESS AC power is distributed at 4.16 kV. Offsite power is supplied to the 4.16 kV Class 1E ESS buses of Unit 1 via the 13.8 kV startup buses of Units 1 and 2. The Unit 1 startup bus and transformer are supplied directly by the Montour-Mountain 230 kV line as shown in Figure 14. The Unit 2 startup bus and transformer are connected to the 230-500 kV switchyard tie line.

Figure 15 is a diagram of the distribution of the power from the startup buses to the 4.16 kV and 480 V ESS buses. The Class 1E buses and safety-related loads are divided into four channels. The 4.16 kV bus of each channel is provided with connections to the two startup buses designated preferred and alternative power supplies. Each 4.16 kV bus is normally energized by a preferred startup bus. Two 4.16 kV buses are normally supplied by the startup bus 10 (1A201 and 1A203), and the other two 4.16 kV buses are normally supplied by the startup bus 20 (1A202 and 1A204).

If offsite power is lost to either startup bus, there is a fast transfer scheme between the startup buses that can be used to supply the startup bus from the other startup transformer, thus restoring power to both startup buses.

If either the 13.8 kV/4.16 kV ESS transformer fails or the 13.8 kV tie breaker fails to close when required, then two 4.16 kV buses will momentarily lose power. For example, a total loss of power to startup bus 10 or ESS transformer 10 will cut power to 4.16 kV buses 1A201 and 1A203. These buses will automatically transfer to the alternative offsite startup supply, thus supplying all four 4.16 kV buses from one startup bus.

If both preferred and alternative startup buses become deenergized or other failures prevent offsite power supplies to the 4.16 kV ESS buses, then the buses and the safety-related loads are picked up automatically by the diesel generator assigned to that bus.

Loads Supplied from the 4.16 kV Class 1E ESS Buses

Table 23 shows the loads on each Unit 1 4.16 kV ESS bus (Unit 2 buses have similar loads). This table also shows the connections from the preferred and alternative startup buses and the diesel generators.

480 V Load Centers

There are four 480 V load centers, one to each 4.16 kV ESS bus. Each load center receives its supply via a 4.16 kV/480 V ESS transformer from a 4.16 kV ESS bus as follows:

| <u>4.16 kV bus</u> | <u>4.16 kV/480 V ESS transformer</u> | <u>480 V load center</u> |
|--------------------|------------------------------------------|--------------------------|
| 1A201 | 1X210 | 1B210 |
| 1A202 | 1X220 | 1B220 |
| 1A203 | 1X230 | 1B230 |
| 1A204 | 1X240 | 1B240 |

Each load center can be supplied only from its corresponding ESS bus. Loss of power on a 4.16 kV ESS bus results in a loss of power to the 480 V load center.

Figure 16 shows the Motor Control Centers (MCCs) supplied by each 480 V load center. It can be seen that six of the MCCs (OB516, OB526, OB536, OB546, 1B219, and 1B229) can draw power from alternative 480 V load centers. MCCs 1B219 and 1B229 are designated Class 1E swing buses and supply the RHR injection valves, recirculation loop bypass valves, and recirculation discharge valves. The preferred power to buses 1B219 and 1B229 comes through the electrical isolation of a motor generator set. The alternative power, when required, comes directly from a load center. The motor generator set is used for electrically isolating the two load centers since faults at the swing buses cannot propagate to another load center. An automatic transfer switch is provided for transferring the swing buses from the preferred bus to the alternative bus upon loss of voltage on the preferred bus. If the undervoltage is caused by a fault on the swing bus itself, then the transfer is inhibited. If power is restored on the preferred load center bus, then the swing bus is transferred back to the preferred source.

Four MCCs can be supplied from either Unit 1 or Unit 2 480 V load centers. The function of these MCCs (OB516, OB526, OB536, OB546) is to provide diesel generator support and supply the 125 V DC battery chargers. The MCCs are connected by automatic transfer switches to their load centers. There is no preferred load center, and at any instant in time the MCCs can be supplied from Unit 1 or 2 480 V load centers. If the load center from which the MCC is being supplied fails, then the automatic transfer switch will transfer the MCC to the alternative load center.

120 V Power Scheme

As seen in Figure 17 there are ten 120 V AC power buses that are used to supply power to the plant (Unit 2 system arrangement is identical). Of these ten only two are needed by systems that are used to mitigate events as follows:

| <u>System</u> | <u>120 V power source</u> | <u>480 V supply</u> |
|------------------------------------------------------------|-------------------------------|-------------------------|
| Standby Liquid Control | 1Y216 1Y226 | 1B216 1B226 |
| High Pressure Coolant Injection (Level 8 Trip logic) | 1Y216 1Y226 | 1B216 1B226 |

1Y21(2,3,4)6 are supplied by only one 480 V Motor Control Center, while 1Y218 and 1Y128 can take power from one of two possible 480 V MCCs. The other 120 V buses receive power from a Motor Generator set connected to a 480 V MCC.

Protection of AC Supply Circuits

Protective trip devices are provided through circuit breakers in order to isolate faulty buses and equipment and thus prevent the propagation of supply disturbances and maintain continuity of power as far as possible to non-faulted equipment. High-speed disconnection of each 4.16 kV ESS bus from the offsite supplies prevents the propagation of an internal bus fault from one ESS bus to another. Overcurrent-sensing relays prevent damage to the diesel generator and motors connected to the 4.16 kV ESS buses. Overcurrent and ground sensing relays protect the 4.16 kV buses from faults originating in the 480 V load centers. Similar fault-sensing relays protect the load centers from MCC faults. Voltmeters and ammeters are provided to monitor all parts of the AC system from 500 kV down to 480 V. Control-room alarms monitor the status of the startup, auxiliary, and ESS transformers, circuit breakers, 4.16 kV buses, and 480 V load centers.

Instrumentation

The voltages and currents associated with the AC power distribution system are too high for standard voltmeters and ammeters. Therefore, potential and current transformers are used to transform the voltage and currents down to acceptable levels for the instrumentation. Conventional voltmeters (0-120 V) are used to measure the high voltages associated with the system at the 13.8 kV, 4.16 kV, and 480 V levels. The secondary of the potential transformers is also used as the sensing point for bus and feeder circuit undervoltage and overvoltage relays.

System Interfaces

DC Power

The operation of the Class 1E AC power system is supported by the DC power system (see Section B13). The DC system is required to control switch gear breakers and to start and control the diesel generators.


The 125 V DC system is required for diesel starting and operation. It supplies the diesel engine and generator control panels and is used for solenoid control valves, instrumentation, and control circuits. A loss of DC control power is indicated in the main control room.

Table 23. Preferred power supplies and components for 13.8 kv Startup Buses

| 4.16 kV ESS load center | Preferred startup bus | Breaker from preferred transformer to ESS load center | Breaker from alternate transformer to ESS load center | 125 V DC distribution panel | 125 V DC load center | Breaker from preferred 13.8 kv bus to ESS transformer |
|-------------------------------|-----------------------------|----------------------------------------------------------------|----------------------------------------------------------------|--------------------------------|-------------------------|-------------------------------------------------------------------|
| 1A201 | 10 (0A103) | 52-20101 | 52-20109 | 1D614 | 1D612 | 52-10306 |
| 1A202 | 20 (0A104) | 52-20209 | 52-20201 | 1D624 | 1D622 | 52-10412 |
| 1A203 | 10 (0A103) | 52-20301 | 52-20309 | 1D634 | 1D632 | 52-10312 |
| 1A204 | 20 (0A104) | 52-20409 | 52-20401 | 1D644 | 1D642 | 52-10406 |

VIII-4

S-III-S



**SUSQUEHANNA
STEAM ELECTRIC STATION**


OFFSITE POWER SUPPLY
TO 13.8 KV
STARTUP BUSES

FIGURE 14

REV. 01

00734

9-III A



*: The 'E' diesel can be substituted in place of the preferred diesel.


SUSQUEHANNA
STEAM ELECTRIC STATION

DIAGRAM OF THE
AC POWER DISTRIBUTION

FIGURE 15

REV. 01

VIII-7




SUSQUEHANNA
STEAM ELECTRIC STATION

LOADS ON EACH
480 V LOAD CENTER

FIGURE 16

REV. (

8-1111A



SUSQUEHANNA
STEAM ELECTRIC STATION

120 VOLT
AC POWER
S

| U S | F C | TECH. SPEC | OSD DATE | OSR | MOD DATE | MOD | RETURN | RETURN | CRIT | SHUTDN | TOTAL P C T M | COMPONENT ID | S D C C | V F | DESCRIPTION OF EVENT | |
|---------------|-----|------------|----------|------|----------|------|----------|--------|-------|--------|---------------|--------------|---------|-----|----------------------|-----------------------------------------------------------|
| N Y | L Q | | | TIME | TIME | DATE | DATE | TIME | TIME | TIME | M H E O | | Y I N G | A A | | |
| 1 5 | N N | | | | | | | | (HRS) | (HRS) | (HRS) | | S V A M | L I | | |
| T | T O | | | | | | | | | | T | | N F | D L | | |
| 103 | 3 | 3.2.1.1 | 06/24/83 | 1117 | 06/24/83 | 1117 | 06/27/83 | 0406 | 0.00 | 84.82 | 64.82 | Y | T-10 | 1 | Y Y | LOST T-10 FEHR FOR OFF-SITE POWER. |
| 103 | 1 | 3.2.1.1 | 09/07/83 | 0636 | 09/07/83 | 0630 | 09/09/83 | 0927 | 47.95 | 0.00 | 47.95 | Y | T-10 | 1 | Y N | T-10 FEHR O/S FOR REPLACEMENT. |
| 103 | 1 | 3.2.1.1 | 09/19/83 | 0542 | 09/19/83 | 0542 | 09/19/83 | 1645 | 11.05 | 0.00 | 11.05 | Y | T-10 | 1 | Y N | T-10 COS TO WORK MONTELA-MOUNTAIN LINE. |
| 103 | 1 | 3.2.1.1 | 09/20/83 | 0552 | 09/20/83 | 0552 | 09/20/83 | 1600 | 10.13 | 0.00 | 10.13 | Y | T-10 | 1 | Y N | T-10 OUT OF SERVICE TO WORK MONTELA-MOUNTAIN LINE. |
| 103 | 1 | 3.2.1.1 | 10/17/83 | 1410 | 10/17/83 | 1410 | 10/17/83 | 1535 | 1.42 | 0.00 | 1.42 | Y | T-10 | 1 | N N | T-10 TAP CHANGER IN MANUAL POSIT. FOR INVESTIGATION. |
| 104 | 1 | 3.2.1 | 09/23/83 | 0650 | 09/23/83 | 0250 | 09/23/83 | 1250 | 4.00 | 0.00 | 4.00 | Y | 1A20209 | Y | N N | 1A202-09 BRK RECONNECTED OUT FOR PM. |
| 104 | 1 | 3.3.3.1 | 10/17/83 | 0915 | 10/17/83 | 0915 | 10/17/83 | 0845 | 0.50 | 0.00 | 0.50 | Y | 1A201 | A | N N | 1A201 BUS UNDERVOLTAGE RELAY INOPERABLE FOR SURV. |
| 104 | 1 | 3.3.3.1 | 10/17/83 | 0855 | 10/17/83 | 0855 | 10/17/83 | 0915 | 0.33 | 0.00 | 0.33 | Y | 1A202 | B | N N | 1A202 BUS UNDERVOLTAGE RELAY INOPERABLE FOR SURV. |
| 104 | 1 | 3.3.3.1 | 10/17/83 | 0920 | 10/17/83 | 0920 | 10/17/83 | 0935 | 0.25 | 0.00 | 0.25 | Y | 1A203 | C | N N | 1A203 BUS UNDERVOLTAGE RELAY INOPERABLE FOR SURV. |
| 104 | 1 | 3.3.3.1 | 10/17/83 | 0940 | 10/17/83 | 0940 | 10/17/83 | 1000 | 0.33 | 0.00 | 0.33 | Y | 1A204 | D | N N | 1A204 BUS UNDERVOLTAGE RELAY INOPERABLE FOR SURV. |
| 104 | 1 | 3.3.3 | 11/17/83 | 0815 | 11/17/83 | 0815 | 11/17/83 | 0843 | 0.47 | 0.00 | 0.47 | Y | 1A201 | A | N N | 1A201 BUS UNDERVOLTAGE PROT. O/S FOR SURV. SM-104-009. |
| 104 | 1 | 3.3.3 | 11/17/83 | 0850 | 11/17/83 | 0850 | 11/17/83 | 0910 | 0.33 | 0.00 | 0.33 | Y | 1A202 | B | N N | 1A202 BUS UNDERVOLTAGE PROT. O/S FOR SURV. SM-104-010. |
| 104 | 1 | 3.3.3 | 11/17/83 | 0915 | 11/17/83 | 0915 | 11/17/83 | 0931 | 0.27 | 0.00 | 0.27 | Y | 1A203 | C | N N | 1A203 BUS UNDERVOLTAGE PROT. O/S FOR SURV. SM-104-011. |
| 104 | 1 | 3.3.3 | 11/17/83 | 0935 | 11/17/83 | 0935 | 11/17/83 | 0959 | 0.40 | 0.00 | 0.40 | Y | 1A204 | D | N N | 1A204 BUS UNDERVOLTAGE PROT. O/S FOR SURV. SM-104-012. |
| 104 | 3 | 3.2.1.2 | 12/19/83 | 2215 | 12/19/83 | 2215 | 12/19/83 | 2253 | 0.60 | 0.63 | 0.63 | Y | 1A202 | A | N N | 1A202 BUS INOPERABLE FROM OFF-SITE SUPPLY FOR 1F-(1-001). |
| 104 | 3 | 3.2.1.2 | 12/22/83 | 0750 | 12/22/83 | 0750 | 12/22/83 | 0815 | 0.60 | 0.42 | 0.42 | Y | 1A202 | E | N N | 41V BUS 1B O/S FOR UNDERVOLTAGE SURV. |
| 104 | 3 | 3.2.1.2 | 12/22/83 | 0815 | 12/22/83 | 0815 | 12/22/83 | 0836 | 0.00 | 0.35 | 0.35 | Y | 1A204 | D | N N | 41V BUS 1B O/S FOR UNDERVOLTAGE SURV. |
| 105 | 3 | 3.2.3.2 | 06/28/83 | 0845 | 06/28/83 | 0245 | 06/28/83 | 1630 | 0.00 | 7.75 | 7.75 | Y | 1B229 | 2 | Y N | CLEAN MCC1E229 (1A1S229). |
| 111 Total 111 | | | | | | | | | 77.43 | 73.97 | 151.40 | | | | | |

| | | | | | | | | | | | | | |
|---------------|---|---------|----------|------|----------|------|----------|------|-------|------|-------|---|-------|
| 101 | 1 | 3.8.1 | 12/19/84 | 0832 | 12/19/84 | 0832 | 12/19/84 | 0837 | 0.08 | 0.00 | 0.08 | Y | 1A203 |
| 104 | 1 | 3.8.1 | 12/19/84 | 0840 | 12/19/84 | 0840 | 12/19/84 | 0843 | 0.05 | 0.00 | 0.05 | Y | 1A204 |
| 105 | 1 | 3.8.3.1 | 10/08/84 | 0500 | 10/05/84 | 0500 | 10/08/84 | 1350 | 8.83 | 0.00 | 8.83 | f | 1B229 |
| 115 | 1 | 3.8.3.1 | 11/15/84 | 0528 | 11/16/84 | 0528 | 11/16/84 | 1800 | 12.53 | 0.00 | 12.53 | Y | 1B219 |
| ### Total ### | | | | | | | | | 54.07 | 2.37 | 56.45 | | |

C N N 1A203 'C' ESS SUS INOF FOR EA SWAY EG Un.
D N N 1A204 'D' ESS BUS INOF FOR EM SWAY.
2 N N SWING BUS M/G SET 1G203 O/S FOR PH - INOPS ATC SWITCH 1B229. (FER T.S. INTERPRETATION U-2 T.S.)
1 N N A SWING BUS NG SET O/S FOR PH.

| | | | | | | | | | | | | | |
|-----|---|-------------|----------|------|----------|------|----------|------|------|-------|-------|---|-------|
| 104 | 1 | 3.3.3/3.8.1 | 12/02/85 | 0823 | 12/02/85 | 0823 | 12/02/85 | 0835 | 0.20 | 0.00 | 0.20 | Y | 1A203 |
| 104 | 1 | 3.3.3/3.8.1 | 12/02/85 | 0836 | 12/02/85 | 0836 | 12/02/85 | 0846 | 0.17 | 0.00 | 0.17 | Y | 1A204 |
| 104 | 1 | 3.3.3/3.8.1 | 12/30/85 | 0745 | 12/30/85 | 0745 | 12/30/85 | 0755 | 0.17 | 0.00 | 0.17 | Y | 1A201 |
| 104 | 1 | 3.3.3/3.8.1 | 12/30/85 | 0800 | 12/30/85 | 0800 | 12/30/85 | 0808 | 0.13 | 0.00 | 0.13 | Y | 1A202 |
| 104 | 1 | 3.3.3/3.8.1 | 12/30/85 | 0810 | 12/30/85 | 0810 | 12/30/85 | 0820 | 0.17 | 0.00 | 0.17 | Y | 1A203 |
| 104 | 1 | 3.3.3/3.8.1 | 12/30/85 | 0825 | 12/30/85 | 0825 | 12/30/85 | 0835 | 0.17 | 0.00 | 0.17 | Y | 1A204 |
| 105 | 3 | 3.4.9.2 | 06/04/85 | 0900 | 06/04/85 | 0900 | 06/04/85 | 2135 | 0.00 | 12.58 | 12.58 | Y | 1B229 |
| 105 | 1 | 3.8.3.1 | 11/11/85 | 0530 | 11/11/85 | 0530 | 11/11/85 | 1510 | 9.67 | 0.00 | 9.67 | Y | 1B219 |
| 105 | 1 | 3.5.16 | 11/15/85 | 1110 | 11/15/85 | 1110 | 11/15/85 | 1710 | 6.00 | 0.00 | 6.00 | Y | 1B229 |

Total

100.67 33.08 133.75

| | | | |
|---|---|---|------------------------------------------------------------------------------------------|
| C | N | N | BUS 1A203 INOP FOR UV TRANSFER FROM OFFSITE PWR AND CG DURING PERFORMANCE OF SM-104-011. |
| D | N | N | BUS 1A204 INOP FOR UV TRANSFER FROM OFFSITE PWR AND CG DURING PERFORMANCE OF SM-104-012. |
| A | N | N | BUS 1A201 UNDERVOLTAGE TRANSFER INOP DURING PERFORMANCE OF SM-104-009. |
| B | N | N | BUS 1A202 UNDERVOLTAGE TRANSFER INOP DURING PERFORMANCE OF SM-104-010. |
| C | N | N | BUS 1A203 UNDERVOLTAGE TRANSFER INOP DURING PERFORMANCE OF SM-104-011. |
| D | N | N | BUS 1A204 UNDERVOLTAGE TRANSFER INOP DURING PERFORMANCE OF SM-104-012. |
| 2 | Y | N | DIV 2 SWING BUS DEENERGIZED. |
| 1 | N | N | 1B219 SWING BUS MS SET O/S FOR PM. |
| 2 | N | N | DIV 2 SWING BUS MS O/S FOR FA. |

VIII-13

| | | | | | | | | | | | | | | | | | |
|-----------|---|---------|----------|------|----------|------|----------|------|--------|-------|--------|---|-----------|---|---|---|------------------------------------------------------------------|
| 104 | 5 | 3.0.3 | 10/05/87 | 1726 | 10/05/87 | 1726 | 10/05/87 | 1730 | 0.00 | 0.67 | 0.07 | Y | 1A20401 | Y | N | N | 1A204-01 BREAKER OPERATION CHECK. |
| 104 | 1 | 3.7.1.2 | 10/10/87 | 0410 | 10/10/87 | 0410 | 10/10/87 | 2115 | 17.08 | 0.00 | 17.08 | Y | 1A201 | A | Y | N | 1A201 INOP FOR OUTAGE WORK & OP. |
| 104 | 1 | 3.7.1.2 | 10/11/87 | 0300 | 10/11/87 | 0300 | 10/11/87 | 1930 | 16.50 | 0.00 | 16.50 | Y | 1A203 | C | Y | N | 1A203 INOP FOR OUTAGE WORK & OP. |
| 104 | 1 | 3.3.3 | 10/16/87 | 0815 | 10/16/87 | 0815 | 10/16/87 | 0810 | 0.42 | 0.00 | 0.42 | Y | 1A201 | A | N | N | 1A201 O/S FOR UV RELAY TESTING. |
| 104 | 1 | 3.3.3 | 10/16/87 | 0855 | 10/16/87 | 0855 | 10/16/87 | 0910 | 0.25 | 0.00 | 0.25 | Y | 1A202 | B | N | N | 1A202 O/S FOR UV RELAY TESTING. |
| 104 | 1 | 3.3.3 | 10/16/87 | 0920 | 10/16/87 | 0920 | 10/16/87 | 0932 | 0.20 | 0.00 | 0.20 | Y | 1A203 | C | N | N | 1A203 O/S FOR UV RELAY TESTING. |
| 104 | 1 | 3.3.3 | 10/16/87 | 0940 | 10/16/87 | 0940 | 10/16/87 | 0955 | 0.25 | 0.00 | 0.25 | Y | 1A204 | D | N | N | 1A204 O/S FOR UV RELAY TESTING. |
| 104 | 1 | 3.3.3 | 10/16/87 | 1040 | 10/16/87 | 1040 | 10/16/87 | 1052 | 0.20 | 0.00 | 0.20 | Y | 1A201 | A | N | N | 1A201 O/S FOR UV RELAY TESTING. |
| 104 | 1 | 3.3.3 | 10/16/87 | 1105 | 10/16/87 | 1105 | 10/16/87 | 1117 | 0.20 | 0.00 | 0.20 | Y | 1A202 | B | N | N | 1A202 O/S FOR UV RELAY TESTING. |
| 104 | 1 | 3.3.3 | 10/16/87 | 1245 | 10/16/87 | 1245 | 10/16/87 | 1300 | 0.25 | 0.00 | 0.25 | Y | 1A203 | C | N | N | 1A203 O/S FOR UV RELAY TESTING. |
| 104 | 1 | 3.3.3 | 10/16/87 | 1301 | 10/16/87 | 1301 | 10/16/87 | 1310 | 0.15 | 0.00 | 0.15 | Y | 1A204 | D | N | N | 1A204 O/S FOR UV RELAY TESTING. |
| 104 | 5 | 3.3.3 | 11/01/87 | 0725 | 11/01/87 | 0725 | 11/01/87 | 1710 | 0.00 | 9.75 | 9.75 | Y | 1A2011-41 | J | N | N | TP ON 64Z UV RELAYS ON U-BUSES WITH UNIT S/D. |
| 104 | 1 | 3.3.3 | 11/16/87 | 0745 | 11/16/87 | 0745 | 11/16/87 | 0758 | 0.22 | 0.00 | 0.22 | Y | 1A201 | A | N | N | 1A201 O/S FOR UV RELAY TESTING. |
| 104 | 1 | 3.3.3 | 11/16/87 | 0802 | 11/16/87 | 0802 | 11/16/87 | 0810 | 0.13 | 0.00 | 0.13 | Y | 1A202 | B | N | N | 1A202 O/S FOR UV RELAY TESTING. |
| 104 | 1 | 3.3.3 | 11/16/87 | 0815 | 11/16/87 | 0815 | 11/16/87 | 0824 | 0.15 | 0.00 | 0.15 | Y | 1A203 | C | N | N | 1A203 O/S FOR UV RELAY TESTING. |
| 104 | 1 | 3.3.3 | 11/16/87 | 0828 | 11/16/87 | 0828 | 11/16/87 | 0833 | 0.09 | 0.00 | 0.09 | Y | 1A204 | D | N | N | 1A204 O/S FOR UV RELAY TESTING. |
| 104 | 1 | 3.8.3.1 | 12/17/87 | 0740 | 12/17/87 | 0740 | 12/17/87 | 0816 | 0.60 | 0.00 | 0.60 | Y | 1A201 | A | N | N | UV RELAY TESTING. |
| 104 | 1 | 3.8.3.1 | 12/17/87 | 0820 | 12/17/87 | 0820 | 12/17/87 | 0920 | 1.00 | 0.00 | 1.00 | Y | 1A202 | B | N | N | UV RELAY TESTING. |
| 104 | 1 | 3.8.3.1 | 12/17/87 | 0925 | 12/17/87 | 0925 | 12/17/87 | 0952 | 0.45 | 0.00 | 0.45 | Y | 1A203 | C | N | N | UV RELAY TESTING. |
| 104 | 1 | 3.8.3.1 | 12/17/87 | 0955 | 12/17/87 | 0955 | 12/17/87 | 1016 | 0.35 | 0.00 | 0.35 | Y | 1A204 | D | N | N | UV RELAY TESTING. |
| 105 | 1 | 3.5.1 | 02/10/87 | 0550 | 02/10/87 | 0550 | 02/10/87 | 1515 | 9.42 | 0.00 | 9.42 | Y | 1B219 | 1 | Y | N | "A" SWING BUS MG SET OOS FOR FM'S. |
| 105 | 1 | 3.5.1B | 02/13/87 | 0730 | 02/13/87 | 0730 | 02/13/87 | 1635 | 9.08 | 0.00 | 9.08 | Y | 1B229 | 2 | Y | N | 1B219, DIVISION 1 SWING BUS OOS FOR FM'S. |
| 105 | 1 | 3.8.3.3 | 02/18/87 | 1210 | 02/18/87 | 1210 | 02/18/87 | 1530 | 3.33 | 0.00 | 3.33 | Y | 1B219 | 1 | Y | N | "A" SWING BUS MG OOS FOR INSPECTION AND REPLACEMENT OF FREDSTAT. |
| 105 | 1 | 3.8.3.1 | 06/03/87 | 0320 | 06/03/87 | 0320 | 06/03/87 | 1550 | 12.50 | 0.00 | 12.50 | Y | 1B229 | 2 | Y | N | 1B229 OOS FOR MAINTENANCE. |
| 105 | 1 | 3.5.1 | 09/01/87 | 1920 | 09/01/87 | 1920 | 09/02/87 | 0400 | 8.67 | 0.00 | 8.67 | Y | 1B229 | 2 | N | N | 1B229, DIVISION 2 SWING BUS OOS FOR FM'S. |
| 105 | 5 | 3.7.1.2 | 10/03/87 | 1315 | 10/03/87 | 1315 | 10/04/87 | 0200 | 12.75 | 0.00 | 12.75 | Y | 1B220 | B | Y | N | 1B220 TAKEN O/S FOR OUTAGE WORK (ESW 'B' BYPASS VALVE) |
| 104 Total | | | | | | | | | 163.32 | 10.55 | 173.87 | | | | | | |

***** EAC *****
 BEGIN DATE: 01-01/88 END DATE: 06-07/88

| JS | PT | IEFH. SPEC | DOO DATE | DOO TIME | MOO DATE | MOO TIME | RETURN DATE | RETURN TIME | CRIT TIME (HRS) | SHUTDOWN TIME (HRS) | TOTAL TIME (HRS) | P C T M | COMPONENT ID | S G C C | V F | DESCRIPTION OF EVENT |
|---------------|-----|------------|----------|----------|----------|----------|-------------|-------------|-----------------|---------------------|------------------|---------|--------------|---------|-----|------------------------------------------------------------------------|
| 1 3 | 1 4 | | | | | | | | | | | | | | | |
| 1 | 1 | | | | | | | | | | | | | | | |
| 104 | 1 | 3.3.3.1 | 01/15/88 | 0810 | 01/15/88 | 0810 | 01/15/88 | 0829 | 0.32 | 0.00 | 0.32 | Y | 1A201 | A | N N | 4KV BUS UV RELAY TESTING - DG FEA BREAKER. |
| 104 | 1 | 3.3.3.1 | 01/15/88 | 0830 | 01/15/88 | 0830 | 01/15/88 | 0844 | 0.23 | 0.00 | 0.23 | Y | 1A202 | B | N N | 4KV BUS UV RELAY TESTING - DG FEA BREAKER. |
| 104 | 1 | 3.3.3.1 | 01/15/88 | 0845 | 01/15/88 | 0845 | 01/15/88 | 0856 | 0.18 | 0.00 | 0.18 | Y | 1A203 | C | N N | 4KV BUS UV RELAY TESTING - DG FEA BREAKER. |
| 104 | 1 | 3.3.3.1 | 01/15/88 | 0857 | 01/15/88 | 0857 | 01/15/88 | 0909 | 0.20 | 0.00 | 0.20 | Y | 1A204 | D | N N | 4KV BUS UV RELAY TESTING - DG FEA BREAKER. |
| 104 | 1 | 3.6.1.1 | 01/18/88 | 0530 | 01/18/88 | 0530 | 01/18/88 | 1005 | 4.58 | 0.00 | 4.58 | | 1A20101 | Y | N N | MAINTENANCE ON 4KV NORMAL SUPPLY BREAKER - ALTERNATE FEED AVAILABLE. |
| 104 | 1 | 3.8.3.1 | 02/16/88 | 0800 | 02/16/88 | 0800 | 02/16/88 | 0817 | 0.28 | 0.00 | 0.28 | Y | 1A201 | A | N N | 4KV BUS UV RELAY TESTING - DG FEA BREAKER. |
| 104 | 1 | 3.8.3.1 | 02/16/88 | 0818 | 02/16/88 | 0818 | 02/16/88 | 0829 | 0.18 | 0.00 | 0.18 | Y | 1A202 | B | N N | 4KV BUS UV RELAY TESTING - DG FEA BREAKER. |
| 104 | 1 | 3.8.3.1 | 02/16/88 | 0830 | 02/16/88 | 0830 | 02/16/88 | 0842 | 0.20 | 0.00 | 0.20 | Y | 1A203 | C | N N | 4KV BUS UV RELAY TESTING - DG FEA BREAKER. |
| 104 | 1 | 3.8.3.1 | 02/16/88 | 0843 | 02/16/88 | 0843 | 02/16/88 | 0852 | 0.15 | 0.00 | 0.15 | Y | 1A204 | D | N N | 4KV BUS UV RELAY TESTING - DG FEA BREAKER. |
| 104 | 4 | 3.3.3.1 | 03/18/88 | 0740 | 03/18/88 | 0740 | 03/18/88 | 0905 | 0.00 | 1.42 | 1.42 | Y | 1A2011-41 | Y | N N | 4KV BUS UV RELAY TESTING. |
| 104 | 1 | 3.3.3 | 04/15/88 | 1300 | 04/15/88 | 1300 | 04/15/88 | 1320 | 0.33 | 0.00 | 0.33 | Y | 1A201 | A | N N | 4KV BUS 1A201 INOP TO PERFORM FUNCTIONAL TEST ON DEGRADED VOLT RELAYS. |
| 104 | 1 | 3.3.3 | 04/15/88 | 1321 | 04/15/88 | 1321 | 04/15/88 | 1330 | 0.15 | 0.00 | 0.15 | Y | 1A202 | B | N N | 4KV BUS 1A202 INOP TO PERFORM FUNCTIONAL TEST ON DEGRADED VOLT RELAYS. |
| 104 | 1 | 3.3.3 | 04/15/88 | 1331 | 04/15/88 | 1331 | 04/15/88 | 1343 | 0.20 | 0.00 | 0.20 | Y | 1A203 | C | N N | 4KV BUS 1A203 INOP TO PERFORM FUNCTIONAL TEST ON DEGRADED VOLT RELAYS. |
| 104 | 1 | 3.3.3 | 04/15/88 | 1344 | 04/15/88 | 1344 | 04/15/88 | 1352 | 0.13 | 0.00 | 0.13 | Y | 1A204 | D | N N | 4KV BUS 1A204 INOP TO PERFORM FUNCTIONAL TEST ON DEGRADED VOLT RELAYS. |
| 104 | 1 | 3.3.3 | 05/16/88 | 0930 | 05/16/88 | 0930 | 05/16/88 | 0943 | 0.22 | 0.00 | 0.22 | Y | 1A201 | A | N N | 1A201 INOP FOR SURVEILLANCE. |
| 104 | 1 | 3.3.3 | 05/16/88 | 0958 | 05/16/88 | 0958 | 05/16/88 | 1012 | 0.23 | 0.00 | 0.23 | Y | 1A203 | C | N N | 1A203 INOP FOR SURVEILLANCE. |
| 104 | 1 | 3.3.3 | 05/16/88 | 1013 | 05/16/88 | 1013 | 05/16/88 | 1025 | 0.20 | 0.00 | 0.20 | Y | 1A204 | D | N N | 1A204 INOP FOR SURVEILLANCE. |
| 105 | 1 | 3.5.1 | 03/30/88 | 0730 | 03/30/88 | 0730 | 03/30/88 | 1520 | 7.83 | 0.00 | 7.83 | Y | 1B219 | I | N N | PH ON SWING BUS M/G SET, (1B219), BUS ENERGIZED. |
| ### Total ### | | | | | | | | | 15.83 | 1.42 | 17.25 | | | | | |

VIII-18