

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9208060197 DOC. DATE: 92/08/03 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 AUTH. NAME: KEISER, H.W. AUTHOR AFFILIATION: Pennsylvania Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Forwards "Susquehanna Steam Electric Station Unit 1 Sixth Refueling & Insp Outage Inservice Insp Outage Summary Rept," Books 1 & 2.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1 + 1,200
 TITLE: OR Submittal: Inservice Inspection/Testing/Relief from ASME Code

NOTES: LPDR 1 cy Transcripts. ; MAXWELL, G *See Report* 05000387

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD1-2 LA		1	0		PD1-2 PD		1	1
	RALEIGH, J.		2	2					
INTERNAL:	ACRS		0	0		NRR/DET/ECMB 9H		1	1
	NRR/DET/EMEB 7E		1	1		NUDOCS-ABSTRACT		1	1
	OC/LEMB		1	0		OGC/HDS2		1	0
	REG FILE 01		1	1		RES MILLMAN, G		1	1
	RES/DSIR/EIB		1	1					
EXTERNAL:	EG&G BROWN, B		1	1		EG&G RANSOME, C		1	1
	NRC PDR		1	1		NSIC		1	1
NOTES:			2	2					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 24 ENCL

13
24

MA2

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101-1179 • 215/774-5151

AUG 03 1992

Harold W. Keiser
Senior Vice President-Nuclear
215/774-4194

U.S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Mail Station PI-137
Washington, D.C. 20555

**SUSQUEHANNA STEAM ELECTRIC STATION
UNIT 1 SIXTH REFUELING AND INSPECTION OUTAGE
ISI SUMMARY REPORT**

PLA-3824


FILES R15-4, R41-2

Docket No. 50-387

Attached for your use is a copy of the Susquehanna Steam Electric Station Inservice Inspection Outage Summary Report for the Unit 1 Sixth Refueling and Inspection Outage. A copy of this report has also been sent to the Commonwealth of Pennsylvania.


If you have any questions, please contact us.

Very truly yours,



for H. W. Keiser


Attachment

cc: NRC Region I (w/o)
Mr. G. S. Barber, NRC Sr. Resident Inspector (w/o)
Mr. G. F. Maxwell, Acting NRC Project Manager (w/o)



A047





SUSQUEHANNA STEAM ELECTRIC STATION

Pennsylvania Power and Light Company

UNIT 1 SIXTH REFUELING AND INSPECTION OUTAGE

INSERVICE INSPECTION

*OUTAGE SUMMARY REPORT
BOOK 1*

July 24, 1992

9208060197

SUSQUEHANNA STEAM ELECTRIC STATION

Pennsylvania Power and Light Company

UNIT 1 SIXTH REFUELING AND INSPECTION OUTAGE

INSERVICE INSPECTION
OUTAGE SUMMARY REPORT

Prepared By:

John T. Lindberg
ISI Engineer

Approved By:

Sam Stanley
Plant Superintendent

July 24, 1992

TABLE OF CONTENTS

	PAGE
NIS-1 FORM	3
A. INTRODUCTION	5
B. PIPING AND COMPONENT EXAMINATIONS	6
C. REACTOR PRESSURE VESSEL INTERNAL EXAMINATIONS	11
D. REACTOR PRESSURE VESSEL EXTERNAL EXAMINATIONS	13
E. SYSTEM PRESSURE TESTS	16
F. MECHANICAL SNUBBER FUNCTIONAL TESTS	18
G. MECHANICAL SNUBBER VISUAL EXAMINATIONS	23
H. EROSION/CORROSION EXAMINATIONS	24
I. ASME REPAIRS AND REPLACEMENTS	33

APPENDICES

- A. CODE COMPLIANCE SUMMARY
- B. ASME SECTION XI AND AUGMENTED EXAMINATION DETAILED LISTING
- C. SNUBBER TESTING DETAILED LISTING
 - C.1 Snubber Functional Testing Listing
 - C.2 Snubber Visual Testing Listing
- D. ASME REPAIRS AND REPLACEMENTS NIS-2 Forms
 - D.1 Mechanical Maintenance NIS-2 Forms
 - D.2 Modification Installation Group NIS-2 Forms
 - D.3 E&S Construction NIS-2 Forms
 - D.4 Snubber Replacement NIS-2 Forms
- E. REACTOR PRESSURE VESSEL EXTERNAL EXAMINATIONS
- F. EROSION/CORROSION SCOPE OF EXAMINATIONS

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

As required by the Provisions of the ASME Code Rules

- PENNSYLVANIA POWER AND LIGHT COMPANY**
TWO NORTH 9th STREET, ALLENTOWN, PA 18101
1. Owner _____
(Name and Address of Owner)
2. Plant SUSQUEHANNA STEAM ELECTRIC STATION, RT. 11, BERWICK, PA 18603
(Name and Address of Plant)
3. Plant Unit ONE 4. Owner Certificate of Authorization (if required) N/A
5. Commercial Service Date 6/8/83 6. National Board Number for Unit N/A
7. Components Inspected

Component or Appurtenance	Manufacturer or Installer	Manufacturer or Installer Serial No.	State or Province No.	National Board No.
RHRSW	BECHTEL	0-16A	N/A	N/A
FPC	BECHTEL	0-35B	N/A	N/A
ESW	BECHTEL	0-54A,B	N/A	N/A
RHRSW	BECHTEL	1-16A	N/A	N/A
FPC	BECHTEL	1-35B	N/A	N/A
FEEDWATER	BECHTEL	1-45A	N/A	N/A
RHR	BECHTEL	1-49A,B,D,E,F,G	N/A	N/A
RCIC	BECHTEL	1-50B,C	N/A	N/A
CORE SPRAY	BECHTEL	1-51A	N/A	N/A
HPCI	BECHTEL	1-52A,B	N/A	N/A
SBLC	BECHTEL	1-53A	N/A	N/A
ESW	BECHTEL	1-54A	N/A	N/A
CRD	BECHTEL/NISCO	1-55B	N/A	N/A
RWCU	BECHTEL	1-61B	N/A	N/A
RPV	CB&I	B5023	B111230	3686
Nuclear Boiler	BECHTEL	1-62A	N/A	N/A

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM-NIS-1 (back)

8. Examination Dates 11/17/90 to 05/17/92 9. Inspection Interval from 6/8/83 to 6/1/89

10. Abstract of Examinations: Include a list of examinations and a statement concerning status of work required for current interval. SEE ATTACHED REPORT

11. Abstract of Conditions Noted. SEE ATTACHED REPORT

12. Abstract of Corrective Measures Recommended and Taken SEE ATTACHED REPORT

We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Date July 27 19 92 Signed [Signature] By [Signature]

Owner SUPT. OF PLANT

Certificate of Authorization No. (if applicable) N/A Expiration Date N/A

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Pennsylvania and employed by [Signature] of [Signature] have inspected the components described in this Owners' Data Report during the period 11/17/90 to 05/17/92 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners' Data Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date JULY 24 19 92

FACTORY MUTUAL SYSTEM

[Signature]
Inspector's Signature

Commissions NB 7525 PA 2159 NT
National Board, State, Province and No.

* ARKWRIGHT MUTUAL-INSURANCE COMPANY
225 WYMAN ST.
WALTHAM, MA. 02154

1981

1981

1981

1981

1981

1981

1981

1981

1981

1981

1981

1981

1981

1981

1981

INTRODUCTION

This report will document the Inservice Inspection (ISI), test, and repair/replacement activities associated with Susquehanna Steam Electric Station (SSES) Unit 1 for its Sixth fuel cycle. This timeline encompasses work performed from the time of breaker closure after the Unit 1 Fifth Refuel and Inspection Outage up to the time the breaker was closed following the Unit 1 Sixth Refuel and Inspection Outage.

1. SSES Unit 1 began commercial operation on June 8th 1983. The unit was shut down for its Sixth refueling and inspection outage on March 6th 1992 at 2340 hours, nineteen months into its 36 month 3rd Inspection Period of the First Ten Year Interval. The refueling outage was completed on May 17, 1992.
2. The applicable year and addenda of the ASME Boiler and Pressure Vessel Code, Division 1, Section XI for SSES Unit 1 is the 1980 Edition through and including the Winter 1980 Addenda. PP&L has selected the 10-year inspection interval as prescribed in IWA-2420, Plan B. The current dates for the first Ten Year Interval are:

1 st Period:	June 8, 1983 to June 8, 1986
2 nd Period:	June 9, 1986 to June 8, 1990
3 rd Period:	June 9, 1990 to June 1, 1994*

* *Inspection interval to be extended 358 days so that Unit 1 and Unit 2 may be brought in under the same code edition and addenda for the second ten year interval.*

3. This report is divided into the following sections:

- Piping and Components Examinations
- Reactor Pressure Vessel Internal Examinations
- Reactor Pressure Vessel External Examinations
- System Pressure Tests
- Snubber Functional Tests
- Snubber Visual Examinations
- Erosion/Corrosion Examinations
- ASME Repairs and Replacements

4. Each of these sections is handled as a separate entity within this report. All required information for each section is included in that section or in the noted appendices. Class 1, 2, and 3 components are included in this report. PP&L has committed to use the Outage Summary Report to transmit the NIS-2 Forms for ASME Section III components and R-1 Forms for ASME Section I, IV or VIII components.
5. The Authorized Nuclear Inservice Inspectors for this Period were:

David L. Daullary
William R. Rogers III
Delton E. Tillery

Arkwright Mutual Insurance Co.
225 Wyman Street
Waltham, Massachusetts

1919

1919

1919

1919

1919

1919

1919

1919

1919

1919

1919

1919

1919

1919

1919

1919

1919

1919

1919

1919

PIPING AND COMPONENTS EXAMINATIONS

1. Abstract of Examinations

The piping and component examinations were conducted in accordance with Section IWB, IWC, IWD, and IWF 2000 of ASME Section XI and PP&L Document ISI-T-107.0. 486 inspections were performed during the U1-6RIO. The NDE contractor utilized was General Electric, King of Prussia, PA. A detailed listing of the examinations performed this outage and the results are contained in Appendix B.

2. Code Compliance Summary

Appendix A provides a breakdown by Code Category and Item Number for all Section XI Class 1, 2, and 3 components. System Pressure Tests are covered in Section E of this abstract. This Summary includes the total number of selected components for the First Second and Third Periods. Percentages are shown for the first, second and third periods in relation to the First Interval.

3. Abstract of Conditions Noted and Corrective Action Taken

A total of 27 nonconformances were initiated during the Unit 1, Sixth Refuel and Inspection Outage for piping/components.

Four NCRs were initiated against linear indications that exceeded acceptance criteria. None were determined to be service induced by the PP&L Level III and Nuclear System Engineering. All unacceptable NCR conditions were corrected prior to returning the system to service.

The following is a synopsis of all NCRS initiated against Piping and Components:

See next page

MEMORANDUM FOR THE DIRECTOR

DATE: 10/10/50

TO: SAC, NEW YORK (100-100000-100000)

FROM: SA [Name], NEW YORK (100-100000-100000)

SUBJECT: [Subject Name]

Reference is made to [Subject Name]

On [Date], [Subject Name]

It was determined that [Subject Name]

The following information was obtained [Subject Name]

It is noted that [Subject Name]

UI-6RIO Piping & Components Non-Conformances

NCR #	COMPONENT	SYSTEM	EXPANDED	CONDITION	DISPOSITION
92-033	DBB1131-H2 (SPRING CAN)	CS/51A	DBB1131-HX-16A GBB1013-H32, H37, H31 (ANCHOR PT. TO ANCHOR PT.)	Cold setting out of tolerance	Rework
92-036	GBB1092-H3 (SPRING CAN)	RHR/49A	GBB1092-HX-204A & H28	Cold setting out of tolerance	Rework
92-047	DBB1051-H3 (SPRING CAN)	M.S./83	DBB1052-H4 DBB1051-H1	Cold setting out of tolerance	Rework
92-048	DBB1051-H2 (SNUBBER)	M.S./83	DBB1051-H1 & H3	Holes in concrete around base plate embedment	Rework
92-050	VNBB212-17-R (WELD)	M.S./83	No, not service induced manufacturing defect per Engineering	Linear indication	Repair
92-051	GBB1061-3-A (WELD)	RHR/49	No determined to be manufacturing defect	Linear indication	Repair
92-055	DBB1041-H14 (SWAY STRUT) DBB1041-H15 (SNUBBER)	M.S./83	Yes, line walkdown due to H2	Cold set out of tolerance	Use as is
92-056	DBB1111-H1 (SPRING CAN)	HPCI/52	DBB1141-H2, H3	X Dimension out of tolerance	Reinspection - Use as is
92-057	GBB1042-H1 (SPRING CAN)	RHR/49	GBB1061-H2 AND GBB1042-H2	X Dimension out of tolerance	Reinspection - Use as is
92-073	DCA1112-H14 (SNUBBER)	RHR/49	DCA1112-H12, H38, H5, H17, H3, H40, H16, DCA1111-H3, H22, H39, H27, H29, H1, H30, H31, H34, H35, DCB1021-H1, H2, H3	Missing snap ring and loose bolting	Reinspection - Use as is
92-074	RWS1001-HA6 (CONSTANT SPRING)	RXR/64A	RWS1001-HA5 AND HA7	Loose locking pin at travel stop assembly	Rework
92-075	DCA1111-H2 (SPRING CAN)	RHR/49	DCA1111-H22 and H39	X-Dimension out of tolerance	Reinspection - Use as is
92-088	HRC1051-H13 (SPRING CAN)	ESW/54C	HRC1051-H12, H14	Missing snap ring	Rework
92-096	RWS1002-H26 (SNUBBER)	RXR/64B	Not expanding detail drawing discrepancy	Bolting does not have lock nuts	Use as is
92-106	DBB1052-3M (WELD)	M.S./83	No-determined to be non-service induced per Engineering	Linear indication	Repair
92-108	GBC1014-H281 (SNUBBER)	M.S./83	Line walkdown anchor to anchor	Loose bolting	Rework
92-110	DCA1112-H17 (SNUBBER)	RHR/49	Line walkdown See NCR 92-073	Load stud not centered (+, -) 1/16"	Other - Snubber eliminated
92-111	DCA1112-H5 (SNUBBER)	RHR/49I	Line walkdown See NCR 92-073	Loose bolting	Rework

-- Continued --

Continued from Previous Page

NCR #	COMPONENT	SYSTEM	EXPANDED	CONDITION	DISPOSITION
92-115	CRD Drive (Flange Bolting)	CRD/55	No-Per Engineering evaluation of bolts	Mechanical damage and corrosion pitting	Use as is
92-116	DBB1041-H4 (Sway Strut)	M.S./83	Performed line walkdown See list on NCR 92-055	Missing/loose bolting and rust	Rework
92-119	VNBB21119-E	M.S./83	No-Determined to be manufacturing flaw per Engineering	Linear indication	Repair
92-120	GBC10103-H39 (Spring Can)	M.S./835	GBC10103-H272, H265	Cold set out of tolerance	Use as is
92-121	DCA1112-H12 (Snubber)	RHR/49I	Line walkdown See hanger list on NCR 92-073	Cold set out of tolerance	Reinspection- Use as is
92-122	DCA1111-H31 (Snubber)	RHR/49I	Line walkdown See list on NCR 92-073	Loose bolting	Rework
92-123	MST0221-H6 (Spring Can)	M.S./83C	MST0221-H39, H44 out of tolerance	Loose bolting and cold set out of tolerance	Rework
92-130	DBB1041-H8 (Sway Strut)	M.S./83F	Line walkdown anchor to anchor See list on NCR 92-055	Damaged rod eye	Rework
92-131	GBC10103-H262, H269, H270, H273, H46	M.S./83	Line walkdown GBC10103-H43, H272, H262, H265, H44, H270, H269, H45, H36, HX-400C	Loose bolting	Rework
92-132	Flange Bolting	RPV/62 RHR/49A	No	Galled Bolting	Replaced

NOTES:

- (1) All visually rejected supports were expanded to include first support upstream and downstream. Three line walkdowns were performed for all supports between anchor points on Core Spray and Main Steam.

[The page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. The text is scattered across the page and does not form any recognizable words or sentences.]



4. Incomplete Examinations


There were 23 examinations where access to the entire component was limited due to configurations or physical obstructions. These exams will be submitted for relief. The affected components are:

COMPONENT	DESCRIPTION	SYSTEM	COVERAGE
GBB1011-HW-2A, 2B, 2C, 2D, and H22	Pipe to lugs	C.S./51	89%
GBB1014-HW-1A, 1B, 1C, 1D, and H2	Pipe to lugs	C.S./51	89.36%
GBB1014-HW-18A, H35	Pipe to plate	C.S./51	39%
EBB1021-HW-1A, 1B, 1C 1D, and H11	Pipe to lugs	HPCI/52	*92%
DBB1212-HW-3A, 3B, 3C, 3D, and H21	Pipe to lugs	RCIC/50	88.2%
MST0222-HW-2A, 2B, 2C, 2D, 2E, 2F, 23G, 2H, H42	Pipe to lugs	M.S./83	*92%
DBB1071-1-B	Weld	RHR/49	83.8%
DCA1101-FW-1	Weld	RHR/49	*93.7%
GBB1061-HW-5A, 5B, 5C, 5D, and H5	Pipe to lugs	RHR/49	*92%
GBB1061-HW-5E, 5F, 5G, 5H, 5J, and H5	Pipe to lugs	RHR/49	*90.3%
GBB1062-HW-14A, 14B, 14C, 14D, 14E, 14F, 14G, 14H, and H14	Pipe to lugs	RHR/49	*93.9%
GBB1043-HW-2A, 2B, 2C, 2D, 6A, 6B, 6C, 6D, and H23	Pipe to lugs	RHR/49	*92%
VRRB311-2-U	Seam weld	RXR/64A	87.5%
VRRB311-2-V	Seam weld	RXR/64A	87.5%
VRRB312-10-U	Seam weld	RXR/64B	87.5%
VRRB312-3-B	Weld	RXR/64B	50%
RWS1002-HW-2A, 2B, 2C, 2D, 2E, 2F, 2G, and H26	Pipe to lugs	RXR/64B	*92%
VRRB312-3-A	Weldolet to pipe	RXR/64B	50%
DCA1031-FW-57	Pipe to pipe	RWCU/61	36%
VRRB311-2-B	Weld	RR	50%
VRRB312-10-B	Seam Weld	RR	50%
GBB1041-H57 HW-1A, 1B, 1C, 1D, HW-2A, 2B, 2C, 2D	Pipe to Lugs	RHR	*91.8%
VRRB312-10-V	Seam Weld	RR	87.5%

Note: * Denotes exam that will invoke full coverage per Code Case N460.

5. Applicable Code Cases

There were no code cases used other than the previously mentioned N-460.



6. Successive Inspections

There were no successive inspection per IWB 2420 performed during the U1-6RIO.

7. Special Examinations

Five components of the RXR system were examined using General Electric's Automated "SMART" System:

COMPONENT	DESCRIPTION	SIZE	SYSTEM	TYPE EXAM	RESULTS
VRRB311-FW-A14	Sweepolet to pipe	22"	RXR/64A	45 DEG RL	Geometric indications ID
VRRB311-FW-A14M	Sweepolet to pipe	22"	RXR/64A	45 DEG RL	Geometric indications ID
VRRB312-5-A	Elbow to pipe	12"	RXR/64B	45 DEG SHEAR	Geometric indications ID
VRRB312-6-A	Elbow to pipe	12"	RXR/64B	45 DEG SHEAR	Geometric indications ID
VRRB312-6-B	Elbow to pipe	12"	RXR/64B	45 DEG SHEAR	Geometric indications ID



REACTOR PRESSURE VESSEL INTERNAL EXAMINATIONS

1. Abstract of Examinations

RPV Internal Examinations were performed by CTS Power Services inspection personnel. CTS videotaped the components. PP&L ISI interpreted the recorded examination data. 219 components were examined during the U1-6RIO.

Between the U1-4RIO and U1-5RIO, all in vessel components were re-classified to more closely align along code requirements. Components that were previously classified as B-N-1 or B-N-2 categories may now fall into new classifications. Even though the majority of components are non-code, they are treated the same as code components. Each Reactor Vessel Internal component's classification is documented in PP&L Document ISI-T-118.0:

<u>CATEGORY</u>	<u>DESCRIPTION</u>
-----------------	--------------------

- | | |
|---------|---|
| ● AUG3 | Augmented inspections of feedwater nozzles and spargers per NUREG 0619. |
| ● AUG5 | Non-Code volumetric inspections of jet pump hold down beams. |
| ● AUG6 | Non-Code visual inspections of RPV internals (including steam dryer). |
| ● AUG7 | Non-Code volumetric inspections (excluding jet pump hold down beams). |
| ● B-N-1 | Reactor Vessel Interior (Code Inspection). |
| ● B-N-2 | Integrally welded core support structures and interior attachments to the reactor vessel (Code Inspection). |

Appendix B provides a detailed listing of the components examined under the above code categories.


2. Code Compliance Summary

Appendix A provides a breakdown by Code Category and Item for RPV Internal Examinations. This summary includes the total number of selected components for the first second and third period in relation to the First Inspection Interval.

3. Abstract of Conditions Noted and Corrective Actions Taken

There were two NCRs generated against In vessel ISI Components. All conditions were corrected or evaluated as acceptable for continued service per IWB-2420 prior to returning the unit to service.

NCR #	COMPONENT	CONDITION	DISPOSITION
92-070	Steam Dryer	Documentation of crack growth on Steam Dryer Support Ring	Use as is
92-113	Surveillance Specimen	Specimen holders found disengaged from lower bracket	Rework



4. Incomplete Examinations

There were (31) incomplete examinations during the U1-6RIO due to inaccessibility.

COMPONENT	COMMENTS	COVERAGE	#EXAMS
SBLC Standpipe	Accessible from one side only	50%	1
Shroud Support Legs C,E,F,K,M,N	Accessible from one side only	50%	6
Shroud Support Leg Welds C,E,F,K,M,N	Accessible from one side only	50%	6
Shroud Support Leg D and L	Inaccessible for examination	0%	2
Shroud Support Legs Welds D and L	Inaccessible for examination	0%	2
Core Support	Inaccessible for examination	0%	1
Core Support Plate Bolts	Inaccessible for examination	0%	1
Feedwater N4A, B, C, and D	Accessible on three sides	75%	4
N2J Jet Pump Riser Support Pad	Specimen Holder interference	75%	2
Top Guide	Scheduling interferences, not required this outage	0%	6

5. Applicable Code Cases

There were no code cases used during the report period.

6. Successive Inspections

There were no Code related successive inspections performed per IWB 2420 during the U1-6RIO.

7. Special Examinations

The inspections of Jet Pumps 1, 2, 10, 11, 12, and 20 were performed following the jet pump instrument sensing line Power uprate Project modifications (DCP 91-3022).



D. REACTOR PRESSURE VESSEL EXTERNAL EXAMINATIONS

1. Abstract of Examinations

The RPV External Examinations were conducted in accordance with Section IWB, 2500-1 of the ASME Section XI and PP&L Document ISI-T-107.0. 135 examinations were performed during the U1-6RIO. The NDE Contractor utilized was General Electric, King of Prussia, PA. A detailed listing of the examinations performed are contained in Appendix E. The results of these examinations are imbedded in Appendix B under the applicable code categories.

2. Code Compliance Summary

Section XI, Class 1 RPV components are included in a breakdown by Code Category and Item number in Appendix A. This summary includes percentages for the first and second period in relation to the First Interval.

3. Abstract of Conditions Noted and Corrective Action Taken

NCR 92-029 was written prior to the U1-6 RIO to document incomplete coverage for the magnetic particle examinations performed on the RPV nuts during the U1-5 RIO. The RPV nuts were re-examined during the U1-6 RIO by "Coil" method to obtain complete surface examination coverage.

One NCR was generated during the U1-6RIO. NCR 92-0160 was written to document a procedure violation from NDE Procedure NUT-6. The 4 hour time limit for a calibration check was violated. The NCR was dispositioned "USE-AS-IS".

4. Incomplete Examinations

There were eighteen examinations where access was limited due to configurations or physical obstructions. These exams will be submitted for relief except where noted. There were no component inspections deferred to later outages due to schedule limitations. The affected components are as follows:

COMPONENT	DESCRIPTION	COVERAGE
Vessel Seam Weld BF	Limited coverage due to a reinforcement pad. Manual examination performed to extent possible.	* 94.2%
Vessel Seam Weld BK	Limited coverage due to permanent insulation support interference. Manual examinations performed to extent possible.	78.5%
Vessel Seam Weld BM	Limited coverage due to permanent insulation support interference. Manual examinations performed to extent possible.	78.5%
Vessel Seam Weld BG	Limited coverage due to insulation support ring interference. Manual examinations performed to extent possible.	*90.4%



--CONTINUED FROM PREVIOUS PAGE--

COMPONENT	DESCRIPTION	COVERAGE
Vessel Seam Weld BH	Limited coverage due to insulation support ring interference. Manual examinations performed to extent possible.	*92%
Vessel Seam Weld BJ	Limited coverage due to insulation support ring interference. Manual examinations performed to extent possible.	*91.8%
Vessel Seam Weld AD Top	Limited coverage due to insulation bracket interference. Manual examinations performed to extent possible.	71.4%
Vessel Seam Weld AD Bottom	Limited coverage due to nozzle interference. Manual examinations performed to extent possible.	*99.7%
Vessel Seam Weld AE Top	Limited coverage due to nozzle interference. Manual examinations performed to extent possible.	*98.8%
CRD FB Welds	Surface exam limited by interference from the position indicator tubes, shoot out steel, flange shields and high radiation conditions.	0%
SB-E	Limited coverage due to interference from an insulation support structure.	40%
N2J Noz to Vessel	Limited coverage due to nozzle interference. Manual examinations performed to extent possible.	*99.5%
N4B Bore	Feedwater nozzle bore exam limited due to thermal pad interference. Manual examinations performed to extent possible	*92%
N4D Bore	Feedwater nozzle bore exam limited due to thermal pad interference. Manual examinations performed to extent possible.	*92%
N4A IR	Feedwater nozzle inner radius exam limited due to nozzle reinforcement boss interference. Manual examinations performed to extent possible.	*92%
N4D IR	Feedwater nozzle inner radius exam limited due to nozzle reinforcement boss. Manual examinations performed to extent possible.	*92%
N5A Noz to SE	Core Spray nozzle to vessel exam limited due to the taper-configuration of the safe-end. No manual exams performed.	*92.3%
N5B Noz to SE	Core Spray nozzle to vessel exam limited due to the taper-configuration of the safe-end. No manual exams performed.	*91.7%

* Denotes exam that will invoke full coverage per Code Case N-460.

5. Applicable Code Cases

There were no code cases used other than the previously mentioned N-460.

6. Successive Inspections

There were no successive inspections per IWB 2420 performed during the Unit 1-6RIO.

7. Special Examinations

Eight Reactor Recirculation nozzles, six Feedwater nozzles and two Core Spray nozzles were examined using General Electric's Automated "SMART" System:

COMPONENT	DESCRIPTION	SIZE	EXAM	RESULTS
N1B NOZ-SE	Recirc Suction (CS to SS)	28"	45 Shear 45 & 60 RL	Geometric Indications
N2B NOZ-SE	Recirc Discharge (CS to SS)	12"	45 Shear 45 & 60 RL	Geometric Indications
N2C NOZ-SE	Recirc Discharge (CS to SS)	12"	45 Shear 45 & 60 RL	Geometric Indications
N2D NOZ-SE	Recirc Discharge (CS to SS)	12"	45 Shear 45 & 60 RL	Geometric Indications
N2E NOZ-SE	Recirc Discharge (CS to SS)	12"	45 Shear 45 & 60 RL	Geometric Indications
N2G NOZ-SE	Recirc Discharge (CS to SS)	12"	45 Shear 45 & 60 RL	Geometric Indications
N2H NOZ-SE	Recirc Discharge (CS to SS)	12"	45 Shear 45 & 60 RL	Geometric Indications
N2J NOZ-SE	Recirc Discharge (CS to SS)	12"	45 Shear 45 & 60 RL	Geometric Indications
N4A NOZ-SE	Feedwater Discharge (CS to CS)	12"	45 Shear	Geometric Indications
N4B NOZ-SE	Feedwater Discharge (CS to CS)	12"	45 Shear	Geometric Indications
N4C NOZ-SE	Feedwater Discharge (CS to CS)	12"	45 Shear	Geometric Indications
N4D NOZ-SE	Feedwater Discharge (CS to CS)	12"	45 Shear	Geometric Indications
N4E NOZ-SE	Feedwater Discharge (CS to CS)	12"	45 Shear	Geometric Indications
N4F NOZ-SE	Feedwater Discharge (CS to CS)	12"	45 Shear	Geometric Indications
N5A NOZ-SE	Core Spray Discharge (CS to SS)	12"	45 Shear 45 & 60 RL	Geometric Indications
N5B NOZ-SE	Core Spray Discharge (CS to SS)	12"	45 Shear 45 & 60 RL	Geometric Indications

These exams may also be used as pre-stress improvement PSI.

E. SYSTEM PRESSURE TESTS

1. Abstract of Tests Conducted

CLASS 1 PARTIAL PENETRATION WELDS IN VESSELS - CODE CAT. B-E

INCORE PENETRATION COORDINATES		
56-41	48-49	
CONTROL ROD DRIVE PENETRATION COORDINATES		
50-47	50-51	54-43
58-27	58-31	58-35
58-39	58-43	54-47

SYSTEM PRESSURE TESTS AND HYDROSTATIC TESTS

TEST BOUNDARY	CLASS	CODE CATEGORY	TEST PROCEDURE
CLASS 1 Boundary	1	B-P	SE-100-002
N16B Nozzle	1	B-P	SE-100-002
FEEDWATER	2	C-H	SE-145-301
RCIC	2	C-H	SE-150-301
HPCI	2	C-H	SE-152-301
CORE SPRAY	2	C-H	SE-151-301
ESW A LOOP	3	D-A	SE-154-310
ESW B Loop	3	D-A	SE-154-311
ESW (Unit 1 and Common)	3	D-A	SE-054-301

2. Code Compliance Summary

The above tests fulfill the requirements of the ten year system hydrostatic pressure test.

3. Abstract of Conditions Noted and Corrective Action Taken

Through wall leakage on the pressure retaining boundary of the systems was identified. During performance of A and B ESW Hydrostatic testing leaks were found during the inspections. The through wall leakage was found at the flex hose connections to the RCIC and RHR room coolers. All leaks were documented and corrected by PP&L Maintenance Personnel. The flexible hoses were replaced and retested. The mode of failure was corrosion pitting. Further investigation of this problem is under evaluation.

4. Incomplete Examinations

There were no incomplete examinations during the U1-6RIO.

5. Applicable Code Cases


No Code Cases were used during the Unit 1-6RIO

6. Successive Inspections

There were no successive inspections per IWB 2420 performed during the U1-6RIO

7. Special Examinations

There were no special examinations performed during the U1-6RIO.



MECHANICAL SNUBBER FUNCTIONAL TESTS

1. Abstract of Examinations

A total of 670 mechanical snubbers were functionally tested. All snubbers were manufactured by Pacific Scientific. The contractor utilized was Wyle Testing. The snubbers were selected and tested in accordance with Susquehanna Steam Electric Station Technical Specification 3/4.7.4, Snubbers. PP&L previously submitted relief request #1RR-9 requesting specific relief from the requirements of IWF-5000 in ASME Section XI. This relief request is contained in document ISI-T-106, Inservice Inspection Program Plan First Ten Year Inspection Interval.

2. Code Compliance Summary

Per relief request #1RR-9, the functional testing of snubbers was conducted in accordance with the Plant Technical Specification 3/4.7.4. The requirements of this specification were satisfied.

3. Abstract of Conditions Noted and Corrective Actions Taken

- a. The testing options allowed by Unit 1 Technical Specifications resulted in snubbers being classified into one group for testing. This consisted of:

Size 1/4	Amount in Initial Sample	31
Size 1/2	Amount in Initial Sample	10
Size 1	Amount in Initial Sample	8
Size 3	Amount in Initial Sample	11
Size 10	Amount in Initial Sample	12
Size 35	Amount in Initial Sample	28
Size 100	Amount in Initial Sample	4
Comp Struts	Amount in Initial Sample	1
	TOTAL:	105

Testing of non-Technical Specification Snubbers occurred on a 10% basis.

Size 1/4	Amount in Initial Sample	1
Size 1	Amount in Initial Sample	1
Size 3	Amount in Initial Sample	2
Size 10	Amount in Initial Sample	2
Size 35	Amount in Initial Sample	2
	TOTAL:	8

- b. The following results were achieved during the testing:

<u>SIZE</u>	<u>TOTAL</u>	<u>#TESTED</u>	<u>#FAILED</u>
1/4	450	236	22
1/2	163	43	0
1	143	50	1
3	180	60	1
10	187	52	1
35	44	196	3
100	65	32	3
.05	5	0	0
.12	<u>4</u>	<u>0</u>	<u>0</u>
	1639	670	30

- c. The snubbers that failed testing were repaired or replaced. In either case, the snubbers (repaired or replaced) were successfully tested prior to their installation.


An engineering evaluation was performed on the piping system for all failed snubbers at their locations. The evaluation concluded that all supported components and piping systems were still capable of meeting their intended design function and service requirements.

- d. During testing of the special case snubbers, 7 of the 27 snubbers failed. Four were replaced with functionally acceptable ones. The other three failures were eliminated from the field. Fourteen special case snubbers were eliminated. Now there are only thirteen special case snubbers.
- e. A reduction program was also performed during this outage. A total of 548 snubbers were removed from service and not reinstalled. Each of these snubbers were functionally tested with the acceptable ones becoming spares and the rejected ones either being repaired or scrapped.
- f. A total of 31 nonconformances were initiated during U1-6RIO functional testing. All conditions were repaired, reworked, or evaluated acceptable for continued service.

-- See Next Page --

The following is a synopsis of NCRs initiated against snubbers for the outage:

NCR#	SYSTEM	COMPONENT	CONDITION	DISPOSITION
92-0157	83	DBB 102 H9	Internal torque broken	Rework
92-0150	83	DBB 102 H12	Cold set	Rework
92-141	92	EBD 113 H7, H9	Cold set	Rework
92-131	83	GBC 101 H262, H273	Loose jam nut	Rework
92-130	83	DBB 1041 H10	Cold set	Rework
92-127	83	SP DCA 128 H2062	NDE required	Rework
92-121	49	DCA 111 H12	Cold set	Use as is
92-110	49	DCA 111 H17	Load stud not centered	Rework
92-108	83	GBC 101 H281	Load stud missing	Rework
92-096	49	RWS 100 H26	Missing part	Rework
92-089	64	DCA 102 H3, N4A	Fluid spilled on units	Rework
92-089	54	HRC 105 H13	Missing return ring	Rework
92-087	83	GBC 101 H107 SP- HCC 131 H2019	Cold set	Use as is
92-085	n/a	Various	Procedure violation	Use as is
92-084	93	EBD 102 H55B	Cold set	Use as is
92-080	n/a	Various	Procedure violation	Use as is
92-079	64	SP DCA 121 H24	Cold set	Use as is
92-078	64	SP DCB 105 H11A SP DCB 120 H2001	Cold sets	Use as is
92-073	49	DCA 111 H14	Load stud alignment	Rework
92-071	83	DBB 101 H10B	Cold sets	Use as is
92-067	45	DLA 102 H8B	Rear bracket "s" dimension	Rework
92-062	45	DLA 102 H8B	Cold set	Rework
92-061	64	DCA 102 H7 SP- DCB 105 H2206	Cold sets	Use as is
92-059	49	RWS 100 H39, H46,H47	Cold sets	Use as is
92-055	83	DBB 104 H15	Cold set	Use as is
92-054	83	DBB 101 H13	Cold set / clevis	Use as is
92-053	16	SP HRC 136 H1001	Cold set	Use as is
92-048	83	DBB 105 H2	Holes in concrete	Rework
92-045	n/a	Various	Procedure violation	Use as is
92-044	84	HBD 101 H1	Cold set	Use as is
92-040	93	MSL 100 H9A	Procedure violation-Tag	Rework



4. Detailed Listing

- a. Procedure utilized: AD-QA-195 Rev 5.
- b. Snubbers tested: See tables below and on the next page for a summary of the Category, size, number tested, and number of failures.
- c. The Functional Test Tracking Report lists snubbers that were tested, replaced, or not replaced due to the snubber reduction program (See Appendix C.1).
- d. The NIS-2 Forms for repairs/replacements are listed in Appendix D.4

UNIT 1 - 6th FUNCTIONAL TESTING PLAN

SIZE	POP.	I.S.	FAIL
1/4	420	31	0
1/2	159	10	0
1	124	8	0
3	147	11	0
10	154	12	0
35	409	28	0
100	50	4	0
C.S.	11	1	0
Non Tech Spec	71	8	0

SPARES TESTED

SIZE:	PSA - 1/4	PSA - 1	PSA - 35	PSA - 100	TOTAL
TOTAL TESTED:	4	1	5	6	16
QUANTITY FAILED:	0	0	1	2	3

UNIT 1 - 6RIO
 SNUBBER FUNCTIONAL TESTING SUMMARY

Note: Failure Quantities Shown in ()

SIZE	SCHEDULED TESTS						ADDITIONAL TESTS			
PSA - ¼	31 (0)	1 (0)	7 (0)	19 (7)	2 0	60 (7)	176 (15)	- -	176 (15)	236 (22)
PSA - ½	10 (0)	-- -	3 (0)	-- -	1 (0)	14 (0)	29 (0)	- -	29 0	43 (0)
PSA - 1	8 (0)	1 (0)	9 (0)	1 (0)	1 (0)	20 (0)	30 (0)	- -	30 (0)	50 (0)
PSA - 3	11 (1)	2 (0)	5 (0)	7 (0)	2 (0)	27 (0)	32 (1)	1 (0)	33 (1)	60 (1)
PSA - 10	12 (0)	2 (0)	3 (1)	-- -	9 (0)	26 (1)	26 (0)	- -	26 (0)	52 (1)
PSA - 35	28 (0)	2 (0)	3 (0)	-- -	6 (1)	39 (1)	157 (2)	-- -	157 (2)	196 (3)
PSA - 100	4 (0)	- -	8 (0)	-- -	7 (2)	19 (2)	13 (1)	-- -	13 (1)	32 (3)
PSB - .05	1 (0)	-- -	-- -	-- -	-- -	(1) (0)	-- -	-- -	-- -	1 (0)
PSB - .12	-- -	-- -	-- -	-- -	-- -	-- -	-- -	-- -	-- -	-- -
TOTALS:	105 (0)	8 (0)	38 (1)	27 (7)	29 (3)	206 (11)	463 (19)	1 (0)	464 (19)	670 (30)

KEY:
 ()-Number failed

MECHANICAL SNUBBER VISUAL EXAMINATIONS

1. Abstract of Examinations

No visual examinations were performed during the Unit 1-6th RIO. The next visual examinations are scheduled for the Unit 1-7th RIO. The Technical Specification governing snubbers was changed relieving ISI from performing snubber visuals for this cycle.

2. Code Compliance Summary

Not applicable. The visual examinations are not Section XI visual examinations. They are performed in accordance with Plant Technical Specification 3/4.7.4.

3. Abstract of Conditions Noted and Corrective Actions Taken

None documented none applicable.

4. Incomplete Examinations

There were no incomplete examinations

5. Applicable Code Cases

No code cases were used since snubber visual examinations are not code exams.

6. Successive Inspections

There were no successive inspections

7. Special Examinations

There were no special examinations performed during the U1-6RIO.



EROSION/CORROSION EXAMINATIONS

1. Abstract of Examinations

General Electric performed non-code erosion/corrosion wall thickness examinations during the U1-6RIO. Scope of work was provided by PP&L Specification M-1414, Rev 5. A total of 154 components examined (see Appendix F of this report).

2. Code Compliance Summary

Not applicable since Erosion/Corrosion exams are not part of Section XI. However, a list of inspected components and erosion rates is attached as Appendix F of this report.

3. Abstract of Conditions Noted and Corrective Actions Taken

Evaluation of data is categorized with the distribution of results as follows:

<u>GROUP</u>	<u>DESCRIPTION (%EROSION)</u>	<u>COMPONENTS</u>
1	0% to 20% Erosion	28
2	21% to 30% Erosion	26
3	31% to 50% Erosion	39
4	51% to 99% Erosion	23
5	Erosion ≥ 100% Erosion	38

Percent erosion is determined as follows:

$$\% \text{ EROSION} = \frac{(\text{NOMINAL THICKNESS}) - (\text{MEASURED THICKNESS})}{(\text{NOMINAL THICKNESS}) - (\text{MINIMUM THICKNESS})} \times 100$$

-- See Next Page --

The following lines and related E/C components were scheduled and replaced with P22 material during the U1-6RIO.

UNIT 1-6, RIO P22 PIPE REPLACEMENTS

LINE/SIZE	SYSTEM	E/C Comp.	COMMENTS
SPHAD 148-1 1"	Condenser Drain	X-579 X-581	Pipe Replacement approx. 8' via WA C13795 / DCP 88-3062B
SPGAD 162-1 1"	AUX. Steam	X-135	Pipe Replacement approx. 4' via ECO 88-3062F / WA V13129
SPGAD 102-3 2" SPGAD 102-4 2"	EXT. Steam	X-127 X-589 X-26	Approx. 140' of line was replaced via ECO 91-6083A and WA C13879
SPGAD 102-1 2" SPGAD 102-2 2"	EXT Steam	X-193 X-194 X-590	Replaced approx. 120' of line via ECO 91 6083B and WA C13860
SPGAD 102-5 2" SPGAD 102-6 2"	EXT Steam	X-196 X-591 X-195	Approx. 100' of line was replaced via ECO 91 6083C and WA C13857
SPEAD 114-1 1"	HPCI	X-134 X-435	Approx 300' of line was replaced via ECO 91-6082 and WA C13882
SPEAD 114-3 1"	RCIC Stm. Drain	X-133 X-232	Approx 80' of line was replaced via ECO 91-6085 and WA C13885
SPEAD 114-8 1"	HPCI-RCIC Stm. Dm.	X-190A X-190B X-110 X-111	Approx 10' of line was replaced via ECO 91-6086 and WA C13853
HFD 101-2 16"	4th Stage Extraction Steam	X-250	Approximately 2' of spool replaced via ECO 91-6081 and WA C13763

Of the 153 components inspected (6) third stage Extraction Steam components were replaced, (4) 3rd stage Extraction Steam components were repaired and (24) 3rd stage Extraction Steam were recommended for possible replacement for the Unit 1-7 RIO. In addition (9) fourth stage Extraction Steam components were recommended for possible replacement during the Unit 1-7 RIO. An automated weld build-up was performed on Feedwater Tee "X-175". This component will be inspected and evaluated during the Unit 1-7 RIO. A summary of all erosion EWR's follows.

UNIT 1-6 RIO STANDARD PIPE REPLACEMENTS

EWR/COMP#	LINE SIZE	SYSTEM	ERO %	COMMENTS
M20053 HBD1091-E10	HBD1091 26"	3rd Extraction Steam	212%	Replaced 45 deg. elbow per WA S23537 ECO 92-6009
M20113 HBD1091-E7	HBD1091 18"	3rd Extraction Steam	162%	Replaced pipe by WA S23605 ECO 92-6009
M29167 HBD1092-E11	HBD1092 26"	3rd Extraction Steam	162%	Replaced 90 deg. elbow per WA S23550 ECO 92-6009
M20073 HBD1092-E4	HBD1092 18"	3rd Extraction Steam	156%	Replaced 45 deg. elbow per WA S23605 ECO 92-6009
M20077 HBD1092-E9	HBD1092 18"	3rd Extraction Steam	198%	Replaced pipe by WA S23551 ECO 92-6009
M29164 HBD1093-E9	HBD1093 26"	3rd Extraction Steam	182%	Replaced 90 deg. elbow per WA S23551 ECO 92-6009

UNIT 1-6 RIO PIPE REPAIRS

EWR/ COMP#	LINE SIZE	SYSTEM	ERO %	COMMENTS
M20111 HBD1091-E2	HBD1091 26"	3rd Extraction Steam	142%	Performed weld overlay of pipe per WA S23606
M20060 HBD10902-E7	HBD1092 20"	3rd Extraction Steam	157%	Performed weld overlay per WA S23606
M20061 HBD1092-E10A	HBD1092 26"	3rd Extraction Steam	190%	Performed weld overlay per WA S23606
M29165 HBD1092-E13	HBD1092 26"	3rd Extraction Steam	146%	Performed weld overlay per WA S23606
M20141 DLA1021 X-175B	DLA1021 12"	Feedwater	96%	Performed Auto weld build-up Per DCP 92-9024
M20062 HFD1011-E2 X-14	HFD1011 16"	4th Extraction Steam	166%	Performed weld overlay per WA S23607
VM20065 HFD1013-E2 X-251	HFD1013 16"	4th Extraction Steam	148%	Performed weld overlay per WA S23607
M20064 HFD1013-E1 X-254	HFD1013 16"	4th Extraction Steam	154%	Performed weld overlay per WA S23607

All repaired components are recommended for possible replacement during the Unit 1 7RIO. In addition, the following components are also recommended for possible replacement during the Unit 1-7 RIO.



UNIT 1-7 RIO RECOMMENDED PIPE REPLACEMENTS

EWR #/Comp.#	LINE/SIZE	SYSTEM	ERO %	COMMENTS
M20121 HBD1091-E12	HBD1091 26"	3rd Extraction Steam	108%	Recommended replacement Unit 1-7 RIO
M20116 HBD1091-E13	HBD1091 18"	3rd Extraction Steam	93%	Recommended replacement Unit 1-7 RIO
M20014 HBD1091-E14	HBD1091 18"	3rd Extraction Steam	122%	Recommended replacement Unit 1-7 RIO
M201112 HBD1091-E6	HBD1091 18"	3rd Extraction Steam	130%	Recommended replacement Unit 1-7 RIO
M20061 HBD1092-E10B	HBD1092 26"	3rd Extraction Steam	145%	Recommended replacement Unit 1-7 RIO
M29153 HBD1092-E12	HBD1092 26"	3rd Extraction Steam	109%	Recommended replacement Unit 1-7 RIO
M20093 HBD1092-E14	HBD1092 26"	3rd Extraction Steam	134%	Recommended replacement Unit 1-7 RIO
M20072 HBD1092-E2	HBD1092 26"	3rd Extraction Steam	124%	Recommended replacement Unit 1-7 RIO
M20090 HBD1092-E5	HBD1092 26"	3rd Extraction Steam	132%	Recommended replacement Unit 1-7 RIO
M20080 HBD1092-E6	HBD1092 18"	3rd Extraction Steam	126%	Recommended replacement Unit 1-7 RIO
M20076 HBD1092-E8	HBD1092 18"	3rd Extraction Steam	132%	Recommended replacement Unit 1-7 RIO
M20117 HBD1093-E1	HBD1093 26"	3rd Extraction Steam	126%	Recommended replacement Unit 1-7 RIO
M20079 HBD1093-E11	HBD1093 18"	3rd Extraction Steam	134%	Recommended replacement Unit 1, 7 RIO

-- Continued --

-- Continued From Previous Page --

EWR #	LINE/SIZE	SYSTEM	ERO %	COMMENTS
M20078 HBD1093-E12	HBD1093 18"	3rd Extraction Steam	126%	Recommended Replacement Unit 1-7 RIO
M20118 HBD1093-E2	HBD1093 26"	3rd Extraction Steam	74%	Recommended Replacement Unit 1-7 RIO
M21095 HBD1081-E2	HBD1081 16"	2nd Extraction Steam	155%	Recommended Replacement Unit 1-7 RIO
M20148 HFD1013-E3	HFD1013 16"	4th Extraction Steam	93%	Recommended Replacement Unit 1-7 RIO
M20104 HBD1091-E4	HBD 109-1 26"	3rd Extraction Steam	102%	Recommended Replacement U1-7 RIO
M20115 HBD1091-E5	HBD 109-1 26"	3rd Extraction Steam	118%	Recommended Replacement U1-7 RIO
M20105 HBD1092-E1	HBD 109-1 26"	3rd Extraction Steam	135%	Recommended Replacement U1-7 RIO
M20081 HBD1093-E3	HBD 109-3 26"	3rd Extraction Steam	145%	Recommended Replacement U1-7 RIO
M20091 HBD1093-E4A	HBD 109-3 26"	3rd Extraction Steam	134%	Recommended Replacement U1-7 RIO
M29168 HBD1093-E6A	HBD 109-3 26"	3rd Extraction Steam	137%	Recommended Replacement U1-7 RIO
M29163 HBD1093-E7	HBD 109-3 26"	3rd Extraction Steam	137%	Recommended Replacement U1-7 RIO
M29166 HBD1093-E8	HBD 109-3 26"	3rd Extraction Steam	140%	Recommended Replacement U1-7 RIO
M20052 HBD1091-E3 X-240B	HBD 1091-3 20"	3rd Extraction Steam	137%	Recommended Replacement U1-7 RIO

INSPECT UNIT 1-7 RIO

EWR #	LINE/SIZE	SYSTEM	ERO %	COMMENTS
M20176 GBD1182-E1 X-150	GBD 118-2 20"	Feedwater	58%	Inspect Next Outage
M20054 GBD1022-E2 X-154	GBD 102-2 4"	Extraction Steam Drain	72%	Inspect Next Outage
M20055 GBD1021-E2 X-155	GBD 102-1 4"	Extraction Steam Drain	60%	Inspect Next Outage
M20139 FCI-P49-951-E2 X-174	FCI-P49-951 26"	Main Steam	81%	Inspect Next Outage
M20138 DLA1021-E5 X-177	DLA 102-1 12"	Feedwater	66%	Inspect Next Outage
M20056 SPGBD1254- E1 X-206	SPGBD125-4 1"	MCPR Drain	63%	Inspect Next Outage
M20063 SPHBD110-8 E2 X-27	SPHBD110-8 2"	Extraction Steam Drain	70%	Inspect Next Outage
M20168 FCIP49-951-1 E1 X-459	FCIP49-951-1 26"	Main Steam	111%	Inspect Next Outage
M20167 FCIP49-953-1 E-2 X-460	FCIP49-953-1 26"	Main Steam	107%	Inspect Next Outage
M20166 FCIP49-952-1 E2 X-462	FCIP49-952-1 26"	Main Steam	65%	Inspect Next Outage
M20165 FCIP49-951-1 E4 X-464	FCIP49-951-1 26"	Main Steam	96%	Inspect Next Outage

-- Continued --

-- Continued From Previous Page --

EWR #	LINE/SIZE	SYSTEM	ERO %	COMMENTS
M20140 GBD1252-E1 X482B	GBD125-2 4"	MCPR	63%	Inspect Next Outage
M20120 SPHBD3023- 10E1 X-634	SPHBD3023-10 1.5"	Aux. Boiler Drain	96%	Inspect Next Outage
M20137 GAD1011-E1 X-12	GAD 101-1 10"	MSEPD	84%	Inspect Next Outage
M20196 HBD1081-E1 X-15	HBD 108-1 24"	Second Extraction Steam	82%	Inspect Next Outage

NO ACTION REQUIRED

EWR #	LINE/SIZE	SYSTEM	ERO %	COMMENTS
M20103 HBD1092- E3A	HBD 109-2 26"	3rd Extraction Steam	66%	No Action Required
M20074 HBD1093- E13	HBD109-3 18"	3rd Extraction Steam	70%	No Action Required
M20075 HBD1093- E14	HBD 109-3 18"	3rd Extraction Steam	82%	No Action Required
M20121 DBD1051- E7A X-68A	DBD105-1 16"	Feedwater	60%	No Action Required

The following 4th Extraction Steam line components were partially examined using UT. These examinations covered 4" down stream from the exit weld. Low areas were repaired with a weld overlay and are recommended for replacement during the Unit 1, 7RIO.

UNIT 1-6 RIO PARTIAL UT EXAMINATIONS

EWR#/COMP.	LINE/SIZE	SYSTEM	ERO%	COMMENTS
M20174/ HFD1011-E5	HFD101-1 16"	4th Extraction Steam	N/A	Component repaired with weld overlay per WA S23730
N/A/ HFD1012-E5	HFD101-2 16"	4th Extraction Steam	N/A	Component repaired with weld overleray per WA S23607
M20175/ HFD1013-E4	HFD101-3 16"	4th Extraction Steam	N/A	Component repaired with weld overlay per WA S23685
M20160/ HFD1013-E5	HFD101-3 16"	4th Extraction Steam	N/A	Component repaired with weld overlay per WA S23657
M20159/ HFD1013-E6	HFD101-3 16"	4th Extraction Steam	N/A	Component repaired with weld overlay per WA S23657

4. Incomplete Examinations

There were incomplete examinations identified on each individual data package. These incomplete examinations were due to physical interferences (instrument taps, clamps, etc.). In all cases, greater than 90% exam coverage was obtained.

5. Applicable Code Cases

Not applicable since Erosion/Corrosion exams are not part of Section XI.

6. Successive Inspections

Scheduling of successive inspections will be performed by Nuclear System Engineering in accordance with erosion rates identified in Specification M-1414. There were 61 components inspected having greater than 50.1% erosion. These exams are tentatively scheduled to be examined during the U1-7RIO.

ASME REPAIRS AND REPLACEMENTS

1. Introduction

This section of the Summary Report contains work performed on ASME Section I, III, IV, VIII or XI items identified by Design Change Packages (DCPs) and Work Authorizations (WAs). The scope of work addressed encompasses the period from the end of the U1-5RIO (breaker close) to the end of the U1-6RIO (breaker close).

2. Code Compliance Summary

All work on ASME Section XI items meet the requirements of IWA-4000 (Repairs) and IWA-7000 (Replacements) of Section XI.

3. Mechanical Maintenance is responsible for conducting repairs and replacements under the WA process and documenting work on NIS-2 Forms. The detailed listing of work performed is summarized in Appendix D.1 along with the NIS-2 Forms.
4. The Modifications Installation Group (MIG) is responsible for performing Design Changes in accordance with ASME XI under Work Authorizations (WAs). The detailed listing of work performed is summarized in Appendix D.2 along with the NIS-2 Forms.
5. E&S Construction conducts repairs delegated to them by Mechanical Maintenance. This work is completed under the WA process and is documented on NIS-2 Forms. The detailed listing of work performed is summarized in Appendix D.3 along with the NIS-2 Forms.
6. The ISI Group generates NIS-2 Forms to document the replacement snubbers to functional test failures. The detailed listing of the effected snubbers is in Appendix C. Appendix D.4 contains the NIS-2 Forms.



CODE COMPLIANCE SUMMARY

CODE COMPLIANCE SUMMARY - UNIT 1 6TH REFUELING AND INSPECTION OUTAGE
 (ASME SECTION XI APPENDIX B.1 ---- SYSTEM PRESSURE TESTS NOT INCLUDED)

CODE CATEGORY	ITEM	EXAM SCHEDULE GUIDELINE	1ST INT EXAMS	1ST PER SCH	1ST PER P/C REC	2ND PER SCH	2ND PER P/C REC	3RD PER SCH	5TH RFO P/C REC ACTUAL	6-RFO EXAMS SCHED	6-RFO P/C	% 1ST & 2ND PER OVER 1ST INT	% 1ST:2ND PER 5 & 6 RFO OVER: 1ST INT
AUG1	AUG1	X-E01	129	33	33	54	54	42	25	16	16	67.44	99.22
AUG2	AUG2	X-CATA	4	2	2	2	2	0	0	0	0	100.00	100.00
		X-CATB	63	27	34	12	12	19	8	11	11	73.02	103.17
		X-CATC	59	3	3	23	23	33	14	19	19	44.07	100.00
AUG3	AUG3	X-AUG3A	54	18	18	18	18	18	0	18	18	66.67	100.00
		X-AUG3B	12	0	0	6	6	6	6	0	0	50.00	100.00
		X-AUG3C	2	2	0	0	0	0	0	0	0	.00	.00
AUG4	AUG4	X-AUG4	3	3	3	0	0	0	0	0	0	100.00	100.00
AUG5	AUG5	X-PSI	6	0	0	0	0	6	0	6	0	.00	.00
		X-RE	40	0	0	0	0	40	20	20	20	.00	100.00
AUG6	AUG6	X-E01	1	0	0	0	0	1	0	1	1	.00	100.00
		X-OWA	1	0	0	0	0	1	0	1	1	.00	100.00
		X-PSI	22	0	0	0	0	22	0	22	0	.00	.00
		X-RE	100	0	0	0	0	100	50	50	50	.00	100.00
		X-RO	257	0	0	0	0	257	257	0	0	.00	100.00
AUG7	AUG7	X-RE	120	0	0	0	0	120	59	61	61	.00	100.00
AUG8	AUG8	X-PSI	8	0	0	0	0	8	0	0	0	.00	.00
B-A	B1.11	X-E01	10	0	0	6	6	4	0	4	4	60.00	100.00
	B1.12	X-E01	13	0	0	5	5	8	0	8	8	38.46	100.00
	B1.21	X-E01	1	0	0	1	1	0	0	0	0	100.00	100.00

REPORT DATE: 07/24/92

CODE COMPLIANCE SUMMARY - UNIT 1 6TH REFUELING AND INSPECTION OUTAGE
 (ASME SECTION XI APPENDIX B.1 - SYSTEM PRESSURE TESTS NOT INCLUDED)

CODE CATEGORY	ITEM	EXAM SCHEDULE GUIDELINE	1ST INT EXAMS	1ST PER SCH	1ST PER P/C REC	2ND PER SCH	2ND PER P/C REC	3RD PER SCH	5TH RFO P/C REC ACTUAL	6-RFO EXAMS SCHED	6-RFO P/C	% 1ST & 2ND PER OVER 1ST INT	% 1ST:2ND PER 5 & 6 RFO OVER 1ST INT
B-A	B1.21	X-ID	3	1	1	1	1	1	1	0	0	66.67	100.00
	B1.22	X-E01	8	0	0	8	8	0	0	0	0	100.00	100.00
		X-ID	6	2	2	2	2	2	2	0	0	66.67	100.00
	B1.30	Z	3	1	1	1	1	1	1	0	0	66.67	100.00
	B1.40	X-ID	6	2	2	2	2	2	2	0	0	66.67	100.00
B-D	B3.100	Z	30	10	10	12	12	8	0	8	8	73.33	100.00
	B3.90	Z	30	10	10	10	10	10	6	4	4	66.67	100.00
B-E	B4.11	X-ID	1	1	1	0	0	0	0	0	0	100.00	100.00
	B4.12	X-ID	47	16	16	13	13	18	9	9	9	61.70	100.00
	B4.13	X-ID	16	6	6	5	5	5	2	3	3	68.75	100.00
B-F	B5.10	Z	34	10	10	18	18	6	2	4	4	82.35	100.00
	B5.50	X-ID	8	2	2	2	2	4	0	4	4	50.00	100.00
		Z	4	0	0	4	4	0	0	0	0	100.00	100.00
	B5.51	X-ID	1	0	0	0	0	1	0	1	1	.00	100.00
B-G-1	B6.10	X-E01	76	0	0	0	0	76	0	76	76	.00	100.00
	B6.180	X-E01	16	0	0	0	0	16	16	0	0	.00	100.00
	B6.190	X-D	32	0	0	0	0	0	0	0	0	.00	.00
	B6.20	X-E01	86	0	0	76	76	10	0	0	0	88.37	88.37
	B6.200	X-E01	16	0	0	0	0	16	16	0	0	.00	100.00
	B6.30	X-B	8	0	0	4	4	4	4	0	0	50.00	100.00

REPORT DATE: 07/24/92

CODE COMPLIANCE SUMMARY - UNIT 1 6TH REFUELING AND INSPECTION OUTAGE
 PLASME SECTION A; APPENDIX B.1 SYSTEM PRESSURE TESTS NOT INCLUDED.


CODE CATEGORY	ITEM	EXAM SCHEDULE GUIDELINE	1ST	1ST	1ST	2ND	2ND	3RD	5TH	6-REF	6-REF P/C	% 1ST & 2ND PER OVER	% 1ST:2ND PER 5 & 6 RFG OVER
			INT EXAMS	PER SCH	PER P/C REC	PER SCH	PER P/C REC	PER SCH	PER P/C ACTUAL	EXAMS SCHED		1ST INT	1ST INT
B-G-1	B6.40	X-D	4	0	0	0	0	4	4	0	0	.00	100.00
	B6.50	X-E01	76	0	0	76	76	0	0	0	0	100.00	100.00
B-G-2	B7.50	X-ID	33	9	9	4	4	20	8	12	12	39.39	100.00
	B7.70	X-ID	40	22	22	7	7	11	4	7	7	72.50	100.00
	B7.80	X-D	176	57	57	70	70	49	25	24	24	72.16	100.00
B-H	B8.10	X-ID	11	3	3	3	3	5	3	2	2	54.55	100.00
B-J	B9.11	X-ID	314	100	100	98	98	116	64	52	52	63.06	100.00
	B9.12	X-ID	133	25	24	55	54	53	26	27	27	58.65	98.50
	B9.21	X-ID	6	2	2	1	1	3	0	3	3	50.00	100.00
	B9.31	X-ID	18	4	4	8	8	6	0	6	6	66.67	100.00
	B9.40	X-ID	14	4	4	5	5	5	3	2	2	64.29	100.00
B-K-1	B10.10	X-ID	93	28	28	29	29	36	12	24	24	61.29	100.00
B-L-2	B12.20	X-D	2	0	0	0	0	0	0	0	0	.00	.00
B-M-2	B12.40	X-D	20	0	0	5	5	8	2	6	6	25.00	65.00
B-N-1	B13.10	X-RE	22	0	0	20	20	2	1	1	1	90.91	100.00
		X-R0	339	128	128	202	202	10	10	0	0	97.35	100.29
B-N-2	B13.20	X-E01	63	6	6	44	45	13	0	12	12	80.95	100.00
		X-OWA	14	0	0	0	0	12	0	12	12	.00	85.71
		X-R0	4	0	0	0	0	4	0	4	4	.00	100.00
	B13.21	X-E01	12	1	1	7	7	4	0	3	3	66.67	91.67

REPORT DATE: 07/24/92

CODE COMPLIANCE SUMMARY - UNIT 1 6TH REFUELING AND INSPECTION OUTAGE
 (ASME SECTION XI APPENDIX B.1 ----- SYSTEM PRESSURE TESTS NOT INCLUDED)

CODE CATEGORY	ITEM	EXAM SCHEDULE GUIDELINE	1ST INT EXAMS	1ST PER SCH	1ST PER P/C REC	2ND PER SCH	2ND PER P/C REC	3RD PER SCH	5TH RFO P/C REC ACTUAL	6-RFO EXAMS SCHED	6-RFO P/C	% 1ST & 2ND PER OVER 1ST INT	% 1ST:2ND PER & 6 RFO OVER 1ST INT
B-N-2	B13.21	X-OWA	386	0	0	0	0	78	28	26	26	.00	13.99
B-O	B14.10	X-EOI	8	0	0	0	0	8	0	8	8	.00	100.00
C-A	C1.10	X-ID	1	0	0	1	1	0	0	0	0	100.00	100.00
	C1.20	X-ID	1	0	0	1	1	0	0	0	0	100.00	100.00
C-B	C2.21	X-ID	4	0	0	2	2	2	0	2	2	50.00	100.00
	C2.22	X-ID	2	0	0	1	1	1	0	1	1	50.00	100.00
C-C	C3.10	X-ID	8	4	4	1	1	3	0	3	3	62.50	100.00
	C3.40	X-ID	381	113	113	114	114	154	62	92	92	59.58	100.00
C-F	C5.11	X-ID	63	22	22	20	20	21	11	10	10	66.67	100.00
	C5.21	X-ID	114	40	40	34	34	40	18	22	22*	64.91	100.00
	C5.31	X-ID	6	2	2	2	2	2	1	1	1	66.67	100.00
C-F*	C5.11	X-ID	16	5	5	5	5	6	1	5	5	62.50	100.00
	C5.21	X-ID	20	6	6	6	6	8	2	6	6	60.00	100.00
	C5.22	X-ID	2	0	0	0	0	2	0	2	2	.00	100.00
	C5.31	X-ID	2	0	0	2	2	0	0	0	0	100.00	100.00
C-G	C6.10	X-D	1	0	0	0	0	1	0	0	0	.00	.00
		X-ID	15	5	5	5	5	5	3	2	2	66.67	100.00
D-B	D2.20	X-1P	9	9	9	0	0	0	0	0	0	100.00	100.00
		X-2P	14	0	0	14	14	0	0	0	0	100.00	100.00
		X-3P	9	0	0	0	0	9	4	5	5	.00	100.00

REPORT DATE: 07/24/92



CODE COMPLIANCE SUMMARY - UNIT : 6TH REFUELING AND INSPECTION OUTAGE
 (ASME SECTION XI APPENDIX B.1. ---- SYSTEM PRESSURE TESTS NOT INCLUDED)

CODE CATEGORY	ITEM	EXAM SCHEDULE GUIDELINE	1ST INT EXAMS	1ST PER SCH	1ST PER P/C REC	2ND PER SCH	2ND PER P/C REC	3RD PER SCH	5TH RFO P/C ACTUAL	6-RFO EXAMS SCHED	6-RFO P/C	% 1ST & 2ND PER OVER 1ST INT	% 1ST:2ND PER 5 & 6 RFO OVER 1ST INT
D-B	D2.30	X-1F	1	1	1	0	0	0	0	0	0	100.00	100.00
		X-2F	2	0	0	2	2	0	0	0	0	100.00	100.00
	D2.40	X-1P	9	9	9	0	0	0	0	0	0	100.00	100.00
		X-2P	4	0	0	4	4	0	0	0	0	100.00	100.00
		X-3P	6	0	0	0	0	6	2	4	4	.00	100.00
	D3.30	X-3P	1	0	0	0	0	1	0	1	1	.00	100.00
D-C	D3.20	X-2P	2	0	0	2	2	0	0	0	0	100.00	100.00
	D3.40	X-2P	1	0	0	1	1	0	0	0	0	100.00	100.00
		X-3P	1	0	0	0	0	1	1	0	0	.00	100.00
F-PMP	F-CSP	X-1F	1	1	1	0	0	0	0	0	0	100.00	100.00
	F-EWP	X-2F	1	0	0	1	1	0	0	0	0	100.00	100.00
	F-HIP	X-3P	2	0	0	0	0	2	0	2	2	.00	100.00
	F-RCP	X-1P	13	13	13	0	0	0	0	0	0	100.00	100.00
		X-2P	2	0	0	2	2	0	0	0	0	100.00	100.00
		X-3P	1	0	0	0	0	1	0	1	1	.00	100.00
	F-RHP	X-3P	1	0	0	0	0	1	0	1	1	.00	100.00
	F-RIP	X-1P	1	1	1	0	0	0	0	0	0	100.00	100.00
	F-RSP	X-1P	1	1	1	0	0	0	0	0	0	100.00	100.00
F-TRB	F-HIT	X-3P	1	0	0	0	0	1	0	1	1	.00	100.00
	F-RIT	X-3P	1	0	0	0	0	1	0	1	1	.00	100.00

REPORT DATE: 07/24/92



CODE COMPLIANCE SUMMARY - UNIT 1 6TH REFUELING AND INSPECTION OUTAGE
 (ASME SECTION XI APPENDIX B.1 ---- SYSTEM PRESSURE TESTS NOT INCLUDED)

CODE CATEGORY	ITEM	EXAM SCHEDULE GUIDELINE	1ST INT EXAMS	1ST PER SCH	1ST PER P/C REC	2ND PER SCH	2ND PER P/C REC	3RD PER SCH	5TH RFO P/C REC ACTUAL	6-RFO EXAMS SCHED	6-RFO P/C	% 1ST & 2ND PER OVER 1ST INT	% 1ST:2ND PER 5 & 6 RFO OVER 1ST INT
F-VSL	F-RHX	X-2P	2	0	0	2	2	0	0	0	0	100.00	100.00
	F-RPV	X-1C	10	0	0	6	6	4	3	1	1	60.00	100.00
	F-SSTK	X-2P	2	0	0	2	2	0	0	0	0	100.00	100.00
NCHOR	F-ANCH	X-1P	24	24	24	0	0	0	0	0	0	100.00	100.00
		X-2P	26	0	0	26	26	0	0	0	0	100.00	100.00
		X-3P	27	0	0	0	0	27	13	14	14	.00	100.00
RIGID	F-RIGD	X-1P	57	57	57	0	0	0	0	0	0	100.00	100.00
		X-2P	56	0	0	56	56	0	0	0	0	100.00	100.00
		X-3P	57	0	0	0	0	57	30	27	27	.00	100.00
SNUB	F-VT34	X-1P	120	120	120	0	0	0	0	0	0	100.00	100.00
		X-2P	112	0	0	112	112	0	0	0	0	100.00	100.00
		X-3P	116	0	0	0	0	116	56	56	56	.00	96.55
SPRNG	F-SPR	X-1P	112	112	112	0	0	0	0	0	0	100.00	100.00
		X-2P	110	0	0	110	110	0	0	0	0	100.00	100.00
		X-3P	111	0	0	0	0	111	59	52	52	.00	100.00
TOTAL			4786	1083	1087	1453	1453	1895	956	889	861	*****	*****

REPORT DATE: 07/24/92

***ASME SECTION XI AND AUGMENTED
EXAMINATIONS
DETAILED LISTING***

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - AS OF: 07/24/92

CODE CATEGORY: AUG1

ITEM: AUG1

CID ----- EXAM TYPE -----	DESC	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
DCA1092-FW-1 VOL	P-V	ISI-DCA-109-2	P-33	CS B	512018	04/12/92	Y	NRI
DLA1011-FW-3 VOL	FH-V	ISI-DLA-101-1	P-68	FW A	452001	04/16/92	Y	NRI
DLA1011-FW-7 VOL	E-P	ISI-DLA-101-1	P-68	FW A	452002	04/16/92	Y	O.D. GEOMETRY ACCPT
DLA1011-1-A VOL	P-E	ISI-DLA-101-1	P-68	FW A	452003	03/30/92	Y	O.D. GEOMETRY ACCPT
DLA1031-FW-5 VOL	P-V	ISI-DLA-103-1	P-68	FW B	452004	03/30/92	Y	NRI
DBA1021-FW-8 VOL	FH-V	ISI-DBA-102-1	P-27	HPCI	522001	04/05/92	Y	NRI
DBB1191-2A-F VOL	TEE SEAM	ISI-DBB-119-1	P-73	HPCI	522002	04/11/92	Y	NRI
SPDBA1151-FW-24 SUR	P-T	ISI-DBA-115-1		MS	832001	03/16/92	Y	NRI
SPDBA1151-FW-25 VOL	P-E	ISI-DBA-115-1	P-01	MS	832002	03/20/92	Y	ROOT GEOMETRY ACCPT
SPDBA1151-FW-26 VOL	P-P	ISI-DBA-115-1	P-01	MS	832003	03/20/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG1 ITEM: AUG1

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
SPDBA1151-FW-28 SUR	P-T	ISI-DBA-115-1		MS	832004	03/16/92	Y	NRI
SPDBA1151-FW-7 SUR	T-RED	ISI-DBA-115-1		MS	832005	03/16/92	Y	NRI
SPDBA1161-FW-38 VOL	E-P	ISI-DBA-116-1	P-01	MS	832006	04/18/92	Y	ROOT GEOMETRY ACCPT
SPDBA1161-FW-39 VOL	P-E	ISI-DBA-116-1	P-01	MS	832007	04/18/92	Y	ROOT GEOMETRY ACCPT
DBB1213-FW-5 VOL	P-E	ISI-DBB-121-3	P-18	RCIC	502001	03/16/92	Y	NRI
DBB1213-2-B VOL	E-P	ISI-DBB-121-3	P-18	RCIC	502002	03/16/92	Y	NRI
TALLY ITEM AUG1 16								
TALLY COECAT AUG1 16								

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG2

ITEM: AUG2

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP ---	NCR NO -----			RESOLUTION -----
DBB1071-1-B VOL	E-P	ISI-DBB-107-1		RHR A	492001	03/26/92	Y	NRI
DCA1081-2-A VOL	E-P	ISI-DCA-108-1	P-56	RHR B	492002	04/15/92	Y	NRI
DCA1101-FW-1 VOL	P-V	ISI-DCA-110-1	P-64	RHR A	492003	03/26/92	Y	NRI
DCB1021-FW-1 VOL	P-V	ISI-DCB-102-1	P-13	RHR A	492004	03/26/92	Y	NRI
N1B NOZ-SE VOL	NOZ-SE	FF113010 SHT 6101	V-29	RPV-E B	622001	04/03/92	Y	ID GEOMETRY ACCPT
N2B NOZ-SE VOL	SE-NOZ	FF113010 SHT 1201	V-27	RPV-E B	622002	04/03/92	Y	ROOT GEOMETRY ACCPT
N2C NOZ-SE VOL	SE-NOZ	FF113010 SHT 1201	V-27	RPV-E B	622003	04/03/92	Y	ROOT GEOMETRY ACCPT
N2D NOZ-SE VOL	SE-NOZ	FF113010 SHT 1201	V-27	RPV-E B	622004	04/03/92	Y	ROOT GEOMETRY ACCPT
N2E NOZ-SE VOL	SE-NOZ	FF113010 SHT 1201	V-27	RPV-E B	622005	04/03/92	Y	ID GEOMETRY ACCPT
N2G NOZ-SE VOL	SE-NOZ	FF113010 SHT 1201	V-27	RPV-E A	622006	04/03/92	Y	ID GEOMETRY ACCPT

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG2

ITEM: AUG2

CID --- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
N2H NOZ-SE VOL	SE-NOZ	FF113010 SHT 1201	V-27	RPV-E A	622007	04/03/92	Y	ROOT GEOMETRY ACCP
N2J NOZ-SE VOL	SE-NOZ	FF113010 SHT 3201	V-27	RPV-E A	622054	04/03/92	Y	ROOT GEOMETRY ACCP
N5A NOZ-SE VOL	SE-NOZ	FF113010 SHT 3201	V-27	RPV-E B	622008	04/24/92	Y	ROOT GEOMETRY ACCP
N5A SE-SEXT VOL	SE EXT-SE	FF113010 SHT 3201	V-15	RPV-E B	622009	04/18/92	Y	NRI
N5B NOZ-SE VOL	SE-NOZ	FF113010 SHT 3201	V-27	RPV-E A	622010	04/24/92	Y	ID GEOMETRY ACCP
N5B SE-SEXT VOL	SE EXT-SE	FF113010 SHT 3201	V-15	RPV-E A	622011	04/18/92	Y	NRI
N8A NOZ-SE VOL	NOZ-SE	FF113012 SHT 0201	V-24	RPV-E B	622012	03/26/92	Y	NRI
N8A SE-PEN SEAL VOL	SE-PEN SEAL	FF113012 SHT 0201	V-13	RPV-E B	622013	03/26/92	Y	NRI
N8B NOZ-SE VOL	NOZ-SE	FF113012 SHT 0201	V-24	RPV-E A	622014	04/03/92	Y	NRI
N8B SE-PEN SEAL VOL	SE-PEN SEAL	FF113012 SHT 0201	V-13	RPV-E A	622015	04/03/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG2

ITEM: AUG2

CID ---	DESC ---	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP ---	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
VRRB311-FW-A14 VOL	SWOL-P	ISI-VRR-B31-1	P-92	RR A	642001	04/03/92	Y	I.D. GEOMETRY ACPT
VRRB311-FW-A6 VOL	PU-P	ISI-VRR-B31-1	P-80	RR A	642002	03/30/92	Y	NRI
VRRB311-2-B VOL	P-WOL	ISI-VRR-B31-1	P-82	RR A	642003	05/06/92	Y	NRI
VRRB311-9-A VOL	P-E	ISI-VRR-B31-1	P-79	RR A	642004	04/01/92	Y	NRI
VRRB312-FW-B20 VOL	WOL-P	ISI-VRR-B31-2	P-05	RR B	642005	04/12/92	Y	NRI
VRRB312-FW-B3 VOL	E-V	ISI-VRR-B31-2	P-79	RR B	642016	05/06/92	Y	NRI
VRRB312-10-B VOL	P-WOL	ISI-VRR-B31-2	P-80	RR B	642006	05/06/92	Y	NRI
VRRB312-2-E VOL	P-E	ISI-VRR-B31-2	P-79	RR B	642007	04/12/92	Y	NRI
VRRB312-3-A VOL	P-WOL	ISI-VRR-B31-2	P-79	RR B	642008	05/06/92	Y	NRI
VRRB312-3-B VOL	P-WOL	ISI-VRR-B31-2	P-79	RR B	642049	05/06/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG2 ITEM: AUG2

<u>CID</u>	<u>DESC</u>	<u>ISI</u>	<u>CAL</u>	<u>SYSTEM</u>	<u>EXAM</u>	<u>ANII</u>	<u>PROGRAM</u>	<u>INDICATION</u>
<u>EXAM TYPE</u>		<u>ISO</u>	<u>BLOCK</u>	<u>LOOP</u>	<u>NO</u>	<u>SIGN-OFF</u>	<u>CREDIT</u>	<u>RESOLUTION</u>
					<u>NCR NO</u>			
TALLY ITEM AUG2	30							
TALLY CDECAT AUG2	30							



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG3

ITEM: AUG3

CID ---- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
N4A IR VOL	NOZ-IR	FF113012 SHT 0301	V-1	RPV-E B	622016	04/29/92	Y	NRI
N4A NOZ-SE VOL	SE-NOZ	FF113010 SHT 7701	V-22	RPV-E B	622017	04/21/92	Y	NRI
N4A-BORE VOL	FW NOZZLE BORE	FF113012 SHT 0301	V-1	RPV-E B	622018	04/24/92	Y	NRI
N4B IR VOL	NOZ-IR	FF113012 SHT 0301	V-1	RPV-E B	622019	04/29/92	Y	NRI
N4B NOZ-SE VOL	SE-NOZ	FF113010 SHT 7701	V-22	RPV-E B	622020	04/21/92	Y	NRI
N4B-BORE VOL	FW NOZZLE BORE	FF113012 SHT 0301	V-1	RPV-E B	622021	04/29/92	Y	NRI
N4C IR VOL	NOZ-IR	FF113012 SHT 0301	V-1	RPV-E B	622022	04/24/92	Y	NRI
N4C NOZ-SE VOL	SE-NOZ	FF113010 SHT 7701	V-22	RPV-E B	622023	04/21/92	Y	NRI
N4C-BORE VOL	FW NOZZLE BORE	FF113012 SHT 0301	V-1	RPV-E B	622024	04/24/92	Y	NRI
N4D IR VOL	NOZ-IR	FF113012 SHT 0301	V-1	RPV-E A	622025	04/29/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG3

ITEM: AUG3

<u>CID</u>	<u>DESC</u>	<u>ISI</u> <u>ISO</u>	<u>CAL</u> <u>BLOCK</u>	<u>SYSTEM</u>	<u>EXAM</u> <u>NO</u>	<u>ANII</u> <u>SIGN-OFF</u>	<u>PROGRAM</u> <u>CREDIT</u>	<u>INDICATION</u>
<u>EXAM TYPE</u>				<u>LOOP</u>	<u>NCR NO</u>			<u>RESOLUTION</u>
N4D NOZ-SE VOL	SE-NOZ	FF113010 SHT 7701	V-22	RPV-E A	622026	04/21/92	Y	NRI
N4D-BORE VOL	FW NOZZLE BORE	FF113012 SHT 0301	V-1	RPV-E A	622027	05/08/92	Y	NRI
N4E IR VOL	NOZ-IR	FF113012 SHT 0301	V-1	RPV-E A	622028	04/24/92	Y	NRI
N4E NOZ-SE VOL	SE-NOZ	FF113010 SHT 7701	V-22	RPV-E A	622029	04/21/92	Y	NRI
N4E-BORE VOL	FW NOZZLE BORE	FF113012 SHT 0301	V-1	RPV-E A	622030	04/24/92	Y	NRI
N4F IR VOL	NOZ-IR	FF113012 SHT 0301	V-1	RPV-E A	622031	04/24/92	Y	NRI
N4F NOZ-SE VOL	SE-NOZ	FF113010 SHT 7701	V-22	RPV-E A	622032	04/21/92	Y	NRI
N4F-BORE VOL	FW NOZZLE BORE	FF113012 SHT 0301	V-1	RPV-E A	622033	04/24/92	Y	NRI

TALLY ITEM AUG3 18
TALLY CDECAT AUG3 18

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG5

ITEM: AUG5

CID ---	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
JT PMP HLD DN BM 01 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I B	622092	04/03/92	Y	NRI
JT PMP HLD DN BM 01 VOL	HOLD DWN BM/BLT	ISI-C-199587		RPV-I B	622299	04/18/92	N	NRI
JT PMP HLD DN BM 02 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I B	622093	04/03/92	Y	NRI
JT PMP HLD DN BM 02 VOL	HOLD DWN BM/BLT	ISI-C-199587		RPV-I B	622300	04/18/92	N	NRI
JT PMP HLD DN BM 03 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I B	622094	04/03/92	Y	NRI
JT PMP HLD DN BM 04 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I B	622095	04/03/92	Y	NRI
JT PMP HLD DN BM 05 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I B	622096	04/03/92	Y	NRI
JT PMP HLD DN BM 06 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I B	622097	04/03/92	Y	NRI
JT PMP HLD DN BM 07 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I B	622098	04/03/92	Y	NRI
JT PMP HLD DN BM 08 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I B	622099	04/03/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG5

ITEM: AUG5

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
JT PMP HLD DN BM 09 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I B	622100	04/03/92	Y	NRI
JT PMP HLD DN BM 10 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I B	622101	04/03/92	Y	NRI
JT PMP HLD DN BM 10 VOL	HOLD DWN BM/BLT	ISI-C-199587		RPV-I B	622301	04/18/92	N	NRI
JT PMP HLD DN BM 11 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I A	622102	04/03/92	Y	NRI
JT PMP HLD DN BM 11 VOL	HOLD DWN BM/BLT	ISI-C-199587		RPV-I A	622302	04/18/92	N	NRI
JT PMP HLD DN BM 12 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I A	622103	04/03/92	Y	NRI
JT PMP HLD DN BM 12 VOL	HOLD DWN BM/BLT	ISI-C-199587		RPV-I A	622303	04/18/92	N	NRI
JT PMP HLD DN BM 13 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I A	622104	04/03/92	Y	NRI
JT PMP HLD DN BM 14 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I A	622105	04/03/92	Y	NRI
JT PMP HLD DN BM 15 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I A	622106	04/03/92	Y	NRI



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG5

ITEM: AUG5

CID ---	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP ---	NCR NO -----			RESOLUTION -----
JT PMP HLD DN BM 16 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I A	622107	04/03/92	Y	NRI
JT PMP HLD DN BM 17 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I A	622108	04/03/92	Y	NRI
JT PMP HLD DN BM 18 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I A	622109	04/03/92	Y	NRI
JT PMP HLD DN BM 19 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I A	622110	04/03/92	Y	NRI
JT PMP HLD DN BM 20 VOL	HOLD DWN BM/BLT	ISI-C-199587	GE	RPV-I A	622111	04/03/92	Y	NRI
JT PMP HLD DN BM 20 VOL	HOLD DWN BM/BLT	ISI-C-199587		RPV-I A	622304	04/20/92	N	NRI

TALLY ITEM AUG5 26
TALLY COECAT AUG5 26



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG6

ITEM: AUG6

CID ----- EXAM TYPE	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
DRYER SUPT RING HOR VT-3	HORIZONTAL FACE	D-205977	N/A	RPV-I N	622112 85-0113	03/26/92	Y	VARIOUS ACCP
DRYER SUPT RING VER VT-3	VERTICAL FACE	D-205977	N/A	RPV-I N	622113 85-0113	03/26/92	Y	VARIOUS ACCP
DRYER WELD DC-A-1 VT-3	DRAIN CHAN WELD	D-205977	N/A	RPV-I N	622114 89-0145	03/26/92	Y	INSTALL DAMAGE ACCP
DRYER WELD DC-A-2 VT-3	DRAIN CHAN WELD	D-205977	N/A	RPV-I N	622115 89-0145	03/26/92	Y	INSTALL DAMAGE ACCP
DRYER WELD DC-A-3 VT-3	DRAIN CHAN WELD	D-205977	N/A	RPV-I N	622116 89-0145	03/26/92	Y	INSTALL DAMAGE ACCP
DRYER WELD DC-B-1 VT-3	DRAIN CHAN WELD	D-205977	N/A	RPV-I N	622117	03/26/92	Y	NRI
DRYER WELD DC-B-2 VT-3	DRAIN CHAN WELD	D-205977	N/A	RPV-I N	622118	03/26/92	Y	NRI
DRYER WELD DC-B-3 VT-3	DRAIN CHAN WELD	D-205977	N/A	RPV-I N	622119	03/26/92	Y	NRI
DRYER WELD DC-C-1 VT-3	DRAIN CHAN WELD	D-205977	N/A	RPV-I N	622120	03/26/92	Y	NRI
DRYER WELD DC-C-2 VT-3	DRAIN CHAN WELD	D-205977	N/A	RPV-I N	622121	03/26/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG6

ITEM: AUG6

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
DRYER WELD DC-C-3 VT-3	DRAIN CHAN WELD	D-205977	N/A	RPV-I N	622122 89-0137	03/26/92	Y	CRACK ACCPT
DRYER WELD DC-D-1 VT-3	DRAIN CHAN WELD	D-205977	N/A	RPV-I N	622123	03/26/92	Y	WELD MISSING ACCPT/PER EVAL
DRYER WELD DC-D-2 VT-3	DRAIN CHAN WELD	D-205977	N/A	RPV-I N	622124	03/26/92	Y	NRI
DRYER WELD DC-D-3 VT-3	DRAIN CHAN WELD	D-205977	N/A	RPV-I N	622125	03/26/92	Y	NRI
DRYER WELD HE-A-1 VT-3	HOOD/END PANEL	D-205977	N/A	RPV-I N	622126	03/26/92	Y	NRI
DRYER WELD HE-A-2 VT-3	HOOD/END PANEL	D-205977	N/A	RPV-I N	622127	03/26/92	Y	NRI
DRYER WELD HE-B-1 VT-3	HOOD/END PANEL	D-205977	N/A	RPV-I N	622128	03/26/92	Y	NRI
DRYER WELD HE-B-2 VT-3	HOOD/END PANEL	D-205977	N/A	RPV-I N	622129	03/26/92	Y	NRI
DRYER WELD HE-C-1 VT-3	HOOD/END PANEL	D-205977	N/A	RPV-I N	622130 90-0251	03/26/92	Y	CRACK ACCPT
DRYER WELD HE-C-2 VT-3	HOOD/END PANEL	D-205977	N/A	RPV-I N	622131	03/26/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG6

ITEM: AUG6

CID ----- EXAM TYPE	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
DRYER WELD HE-D-1 VT-3	HOOD/END PANEL	D-205977	N/A	RPV-I N	622132	03/26/92	Y	NRI
DRYER WELD HE-D-2 VT-3	HOOD/END PANEL	D-205977	N/A	RPV-I N	622133	03/26/92	Y	NRI
DRYER WELD HE-E-1 VT-3	HOOD/END PANEL	D-205977	N/A	RPV-I N	622134	03/26/92	Y	NRI
DRYER WELD HE-E-2 VT-3	HOOD/END PANEL	D-205977	N/A	RPV-I N	622135	03/26/92	Y	NRI
DRYER WELD HE-F-1 VT-3	HOOD/END PANEL	D-205977	N/A	RPV-I N	622136	03/26/92	Y	NRI
DRYER WELD HE-F-2 VT-3	HOOD/END PANEL	D-205977	N/A	RPV-I	622137	03/26/92	Y	NRI
DRYER WELD TR-A-1/2 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622138	03/26/92	Y	NRI
DRYER WELD TR-A-3/4 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622139 90-0242	03/26/92	Y	CRACK ACCPT
DRYER WELD TR-A-5/6 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622140	03/26/92	Y	NRI
DRYER WELD TR-A-7/8 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622141 89-0151	03/26/92	Y	CRACK ACCPT

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG6

ITEM: AUG6

CID ----- EXAM TYPE	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
DRYER WELD TR-B-1/2 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622142	03/26/92	Y	NRI
DRYER WELD TR-B-3/4 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622143	03/26/92	Y	NRI
DRYER WELD TR-B-5/6 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622144	03/26/92	Y	NRI
DRYER WELD TR-B-7/8 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622145	03/26/92	Y	NRI
DRYER WELD TR-C-1/2 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622146	03/26/92	Y	NRI
DRYER WELD TR-C-3/4 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622147	03/26/92	Y	NRI
DRYER WELD TR-C-5/6 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622148	03/26/92	Y	NRI
DRYER WELD TR-C-7/8 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622149	03/26/92	Y	NRI
DRYER WELD TR-D-1/2 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622150	03/26/92	Y	NRI
DRYER WELD TR-D-3/4 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622151	03/26/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG6

ITEM: AUG6

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
DRYER WELD TR-D-5/6 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622152	03/26/92	Y	NRI
DRYER WELD TR-D-7/8 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622153	03/26/92	Y	NRI
DRYER WELD TR-E-1/2 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622154	03/26/92	Y	NRI
DRYER WELD TR-E-3/4 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622155	03/26/92	Y	NRI
DRYER WELD TR-E-5/6 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622156	03/26/92	Y	NRI
DRYER WELD TR-E-7/8 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622157	03/26/92	Y	NRI
DRYER WELD TR-F-1/2 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622158	03/26/92	Y	NRI
DRYER WELD TR-F-3/4 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622159 90-0242	03/26/92	Y	CRACK ACCEPTABLE
DRYER WELD TR-F-5/6 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622160	03/26/92	Y	NRI
DRYER WELD TR-F-7/8 VT-1	CAPTURE PLATE	D-205977	N/A	RPV-I N	622161	03/26/92	Y	CRACK ACCEPTABLE

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG6

ITEM: AUG6

CID ---	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
JT PMP HLD DN BM 01 VT-3	HOLD DWN BM/BLT	ISI-C-199587		RPV-I B	622273	N/A	N	NRI/PSI
JT PMP HLD DN BM 02 VT-3	HOLD DWN BM/BLT	ISI-C-199587		RPV-I B	622274	N/A	N	NRI/PSI
JT PMP HLD DN BM 10 VT-3	HOLD DWN BM/BLT	ISI-C-199587		RPV-I B	622275	N/A	N	NRI/PSI
JT PMP HLD DN BM 11 VT-3	HOLD DWN BM/BLT	ISI-C-199587		RPV-I A	622276	N/A	N	NRI/PSI
JT PMP HLD DN BM 12 VT-3	HOLD DWN BM/BLT	ISI-C-199587		RPV-I A	622277	N/A	N	NRI/PSI
JT PMP HLD DN BM 20 VT-3	HOLD DWN BM/BLT	ISI-C-199587		RPV-I A	622278	N/A	N	NRI/PSI
JT PMP 01 INST LINE VT-3	WELDS/SUPPORTS	ISI-RPV-INT-001 SHT 3		RPV-I	622289	N/A	N	NRI/PSI
JT PMP 02 INST LINE VT-3	WELDS/SUPPORTS	ISI-RPV-INT-001 SHT 3		RPV-I	622290	N/A	N	NRI/PSI
JT PMP 10 INST LINE VT-3	WELDS/SUPPORTS	ISI-RPV-INT-001 SHT 3		RPV-I	622291	N/A	N	NRI/PSI
JT PMP 11 INST LINE VT-3	WELDS/SUPPORTS	ISI-RPV-INT-001 SHT 3		RPV-I	622292	N/A	N	NRI/PSI



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG6

ITEM: AUG6

CID ----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM -----	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP ----	NCR NO -----			RESOLUTION -----
JT PMP 12 VT-3	INST LINE WELDS/SUPPORTS	ISI-RPV-INT-001 SHT 3		RPV-I	622293	N/A	N	NRI/PSI
JT PMP 20 VT-3	INST LINE WELDS/SUPPORTS	ISI-RPV-INT-001 SHT 3		RPV-I	622294	N/A	N	NRI/PSI
N2A JT PMP VT-3	RSTRAINR WEDGE/SCREWS	ISI-RPV-INT-001 SHT 3&4		RPV-I	622279	N/A	N	NRI/PSI
N2A JT PMP VT-3	01 JET PUMP/RISER	ISI-RPV-INT-001 SHT 3&4		RPV-I	622283	N/A	N	NRI/PSI
N2A JT PMP VT-3	02 JET PUMP/RISER	ISI-RPV-INT-001 SHT 3&4		RPV-I	622284	N/A	N	NRI/PSI
N2E JT PMP VT-3	RSTRAINR WEDGE/SCREWS	ISI-RPV-INT-001 SHT 3&4		RPV-I	622280	N/A	N	NRI/PSI
N2E JT PMP VT-3	10 JET PUMP/RISER	ISI-RPV-INT-001 SHT 3&4		RPV-I	622285	N/A	N	NRI/PSI
N2F JT PMP VT-3	RSTRAINR WEDGE/SCREWS	ISI-RPV-INT-001 SHT 3&4		RPV-I	622281	N/A	N	NRI/PSI
N2F JT PMP VT-3	11 JET PUMP/RISER	ISI-RPV-INT-001 SHT 3&4		RPV-I	622286	N/A	N	NRI/PSI
N2F JT PMP VT-3	12 JET PUMP/RISER	ISI-RPV-INT-001 SHT 3&4		RPV-I	622287	N/A	N	NRI/PSI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG6

ITEM: AUG6

CID ----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP	NCR NO -----			RESOLUTION -----
N2K JT PMP RSTRAINR VT-3	WEDGE/SCREWS	ISI-RPV-INT-001	SHT 3&4	RPV-1	622282	N/A	N	NRI/PSI
N2K JT PMP 20 VT-3	JET PUMP/RISER	ISI-RPV-INT-001	SHT 3&4	RPV-1	622288	N/A	N	NRI/PSI
SBLC STANDPIPE VT-3	LOWER PLENUM	ISI-C-199587		RPV-1	622258	04/03/92	Y	NRI
SHROUD ACCESS COVER VT-1	0 ACSS HOLE CVR	C-199587	SHT 3	N/A	RPV-1 N	622162	04/16/92	Y NRI

TALLY ITEM AUG6 74
TALLY CDECAT AUG6 74

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG7

ITEM: AUG7


CID --- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
DRYER RING CRACK A VOL	45'+4.00" HOR	D-205977	GE	RPV-I N	622163 92-070	03/30/92	Y	CRACK UAI
DRYER RING CRACK B VOL	45'-20.00" HOR	D-205977	GE	RPV-I N	622164 92-070	03/30/92	Y	CRACK UAI
DRYER RING CRACK C VOL	45'-18.75" HOR	D-205977	GE	RPV-I N	622165 92-070	03/30/92	Y	CRACK UAI
DRYER RING CRACK D VOL	45'-16.25" HOR	D-205977	GE	RPV-I N	622166 92-070	03/30/92	Y	CRACK UAI
DRYER RING CRACK E VOL	170'+18.50" HOR	D-205977	GE	RPV-I N	622167 92-070	03/30/92	Y	CRACK UAI
DRYER RING CRACK F VOL	170'+15.50" HOR	D-205977	GE	RPV-I N	622168 92-070	03/30/92	Y	CRACK UAI
DRYER RING CRACK G VOL	225'-45.00" VER	D-205977	GE	RPV-I N	622169 92-070	03/30/92	Y	CRACK UAI
DRYER RING CRACK H VOL	225'-34.00" VER	D-205977	GE	RPV-I N	622170 92-070	03/30/92	Y	CRACK UAI
DRYER RING CRACK I VOL	225'-25.50" VER	D-205977	GE	RPV-I N	622171 92-070	03/30/92	Y	CRACK UAI
DRYER RING CRACK J VOL	225'-20.00" _VER	D-205977	GE	RPV-I N	622172 92-070	03/30/92	Y	CRACK UAI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG7 ITEM: AUG7

CID ----- EXAM TYPE	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
DRYER RING CRACK K VOL	225'-7.00" VER	D-205977	GE	RPV-I N	622173 92-070	03/30/92	Y	CRACK UAI
DRYER RING CRACK L VOL	225'+6.25" VER	D-205977	GE	RPV-I N	622174 92-070	03/30/92	Y	CRACK UAI
DRYER RING CRACK M VOL	225'+7.75" VER	D-205977	GE	RPV-I N	622175 92-070	03/30/92	Y	CRACK UAI
SHROUD HEAD BOLT 01 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622176	03/20/92	Y	NRI
SHROUD HEAD BOLT 02 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622177	03/20/92	Y	NRI
SHROUD HEAD BOLT 03 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622178	03/20/92	Y	NRI
SHROUD HEAD BOLT 04 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622179	03/20/92	Y	NRI
SHROUD HEAD BOLT 05 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622180	03/20/92	Y	NRI
SHROUD HEAD BOLT 06 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622181	03/20/92	Y	NRI
SHROUD HEAD BOLT 07 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622182	03/20/92	Y	NRI



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG7

ITEM: AUG7

CID ----- EXAM TYPE	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
SHROUD HEAD BOLT 08 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622183	03/20/92	Y	NRI
SHROUD HEAD BOLT 09 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622184	03/20/92	Y	NRI
SHROUD HEAD BOLT 10 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622185	03/20/92	Y	NRI
SHROUD HEAD BOLT 11 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622186	03/20/92	Y	NRI
SHROUD HEAD BOLT 12 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622187	03/20/92	Y	NRI
SHROUD HEAD BOLT 13 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622188	03/20/92	Y	NRI
SHROUD HEAD BOLT 14 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622189	03/20/92	Y	NRI
SHROUD HEAD BOLT 15 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622190	03/20/92	Y	NRI
SHROUD HEAD BOLT 16 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622191	03/20/92	Y	NRI
SHROUD HEAD BOLT 17 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622192	03/20/92	Y	NRI


SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG7

ITEM: AUG7

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
SHROUD HEAD BOLT 18 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622193	03/20/92	Y	NRI
SHROUD HEAD BOLT 19 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622194	03/20/92	Y	NRI
SHROUD HEAD BOLT 20 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622195	03/20/92	Y	NRI
SHROUD HEAD BOLT 21 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622196	03/20/92	Y	NRI
SHROUD HEAD BOLT 22 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622197	03/20/92	Y	NRI
SHROUD HEAD BOLT 23 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622198	03/20/92	Y	NRI
SHROUD HEAD BOLT 24 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622199	03/20/92	Y	NRI
SHROUD HEAD BOLT 25 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622200	03/20/92	Y	NRI
SHROUD HEAD BOLT 26 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622201	03/20/92	Y	NRI
SHROUD HEAD BOLT 27 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622202	03/20/92	Y	NRI



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG7

ITEM: AUG7

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
SHROUD HEAD BOLT 28 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622203	03/20/92	Y	NRI
SHROUD HEAD BOLT 29 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622204	03/20/92	Y	NRI
SHROUD HEAD BOLT 30 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622205	03/20/92	Y	NRI
SHROUD HEAD BOLT 31 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622206	03/20/92	Y	NRI
SHROUD HEAD BOLT 32 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622207	03/20/92	Y	NRI
SHROUD HEAD BOLT 33 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622208	03/20/92	Y	NRI
SHROUD HEAD BOLT 34 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622209	03/20/92	Y	NRI
SHROUD HEAD BOLT 35 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622210	03/20/92	Y	NRI
SHROUD HEAD BOLT 36 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622211	03/20/92	Y	NRI
SHROUD HEAD BOLT 37 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622212	03/20/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS.- SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG7

ITEM: AUG7

CID ----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP	NCR NO -----			RESOLUTION -----
SHROUD HEAD BOLT 38 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622213	03/20/92	Y	NRI
SHROUD HEAD BOLT 39 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622214	03/20/92	Y	NRI
SHROUD HEAD BOLT 40 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622215	03/20/92	Y	NRI
SHROUD HEAD BOLT 41 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622216	03/20/92	Y	NRI
SHROUD HEAD BOLT 42 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622217	03/20/92	Y	NRI
SHROUD HEAD BOLT 43 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622218	03/20/92	Y	NRI
SHROUD HEAD BOLT 44 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622219	03/20/92	Y	NRI
SHROUD HEAD BOLT 45 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622220	03/20/92	Y	NRI
SHROUD HEAD BOLT 46 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622221	03/20/92	Y	NRI
SHROUD HEAD BOLT 47 VOL	HOLDDWN BOLT	C-213560 SHT 1	GE	RPV-I N	622222	03/20/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: AUG7 ITEM: AUG7

CID	DESC	ISI ISO	CAL BLOCK	SYSTEM	EXAM NO	ANII SIGN-OFF	PROGRAM CREDIT	INDICATION
EXAM TYPE				LOOP	NCR NO			RESOLUTION
SHROUD HEAD BOLT 48 VOL	HOLDDOWN BOLT	C-213560 SHT 1	GE	RPV-1 N	622223	03/20/92	Y	NRI

TALLY ITEM AUG7 61
 TALLY CDECAT AUG7 61



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-A

ITEM: B1.11

CID --- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP ---	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
AD-BOT VOL	SC3-SC4	ISI-C-198607	V-1	RPV-E	622034	05/08/92	Y	NRI
AD-TOP VOL	SC3-SC4	ISI-C-198607	V-1	RPV-E	622035	05/08/92	Y	30 SPOT INDICA ACCPT
AE-BOT VOL	SC4-SC5	ISI-C-198607	V-1	RPV-E	622036	05/08/92	Y	7 SPOT INDICA ACCPT
AE-TOP VOL	SC4-SC5	ISI-C-198607	V-1	RPV-E	622037	05/08/92	Y	NRI

TALLY ITEM B1.11 4

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-A

ITEM: B1.12

CID ---- EXAM TYPE -----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
BF VOL	SC2 LONG	ISI-C-198607	V-1	RPV-E	622038	05/01/92	Y	NRI
BG VOL	SC3 LONG	ISI-C-198607	V-1	RPV-E N	622039	04/18/92	Y	35 SPOT INDICA ACCPT
BH VOL	SC3 LONG	ISI-C-198607	V-1	RPV-E N	622040	04/18/92	Y	3 SPOT INDICA ACCPT
BJ VOL	SC3 LONG	ISI-C-198607	V-1	RPV-E N	622041	05/08/92	Y	5 SPOT INDICA ACCPT
BK VOL	SC4 LONG	ISI-C-198607	V-1	RPV-E N	622042	04/24/92	Y	NRI
BM VOL	SC4 LONG	ISI-C-198607	V-1	RPV-E N	622043	04/24/92	Y	2 SPOT INDICA ACCPT
BN VOL	SC5 LONG	ISI-C-198607	V-1	RPV-E N	622044	04/24/92	Y	NRI
BP VOL	SC5 LONG	ISI-C-198607	V-1	RPV-E N	622045	04/24/92	Y	NRI

TALLY ITEM B1.12 8
TALLY CDECAT B-A 12

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-D

ITEM: B3.100

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
N2J IR VOL	NOZ-IR	FF113010 SHT 9802	V-1	RPV-E A	622046	05/08/92	Y	NRI
N2K IR VOL	NOZ-IR	FF113010 SHT 9802	V-1	RPV-E A	622047	05/08/92	Y	NRI
N3A IR VOL	NOZ-IR	FF113010 SHT 6202	V-1	RPV-E	622048	04/18/92	Y	NRI
N3B IR VOL	NOZ-IR	FF113010 SHT 6202	V-1	RPV-E	622049	04/18/92	Y	NRI
N3C IR VOL	NOZ-IR	FF113010 SHT 6202	V-1	RPV-E	622050	04/18/92	Y	NRI
N3D IR VOL	NOZ-IR	FF113010 SHT 6202	V-1	RPV-E	622051	04/18/92	Y	NRI
N6A IR VOL	NOZ-IR	FF113010 SHT 5603	V-1	RPV-E	622052	04/18/92	Y	NRI
N7 IR VOL	NOZ-IR	FF113012 SHT 1301	V-1	RPV-E	622053	04/18/92	Y	NRI

TALLY ITEM B3.100 8

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-D

ITEM: B3.90

CID --- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
N2J VOL	NOZ-SC1	FF113010	SHT 9802	V-1	RPV-E A	622055	05/01/92	Y 2 SPOT INDICA ACCPT
N2K VOL	NOZ-SC1	FF113010	SHT 9802	V-1	RPV-E A	622056	05/08/92	Y 3 SPOT INDICA ACCPT
N8A VOL	NOZ-SC1	FF113010	SHT 6402	V-1	RPV-E B	622057	04/18/92	Y NRI
N8B VOL	NOZ-SC1	FF113010	SHT 6402	V-1	RPV-E A	622058	04/02/92	Y NRI

TALLY ITEM B3.90 4
TALLY CDECAT B-D 12

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-E

ITEM: B4.12

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP -----	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
CRD-50-47 VT-2	CRD PEN	ISI-C-198608	N/A	RPV-E N	622059	04/30/92	Y	NRI
CRD-50-51 VT-2	CRD PEN	ISI-C-198608	N/A	RPV-E N	622060	04/30/92	Y	NRI
CRD-54-43 VT-2	CRD PEN	ISI-C-198608	N/A	RPV-E N	622061	04/30/92	Y	NRI
CRD-54-47 VT-2	CRD PEN	ISI-C-198608	N/A	RPV-E N	622062	04/30/92	Y	NRI
CRD-58-27 VT-2	CRD PEN	ISI-C-198608	N/A	RPV-E N	622063	04/30/92	Y	NRI
CRD-58-31 VT-2	CRD PEN	ISI-C-198608	N/A	RPV-E N	622064	04/30/92	Y	NRI
CRD-58-35 VT-2	CRD PEN	ISI-C-198608	N/A	RPV-E N	622065	04/30/92	Y	NRI
CRD-58-39 VT-2	CRD PEN	ISI-C-198608	N/A	RPV-E N	622066	04/30/92	Y	NRI
CRD-58-43 VT-2	CRD PEN	ISI-C-198608	N/A	RPV-E N	622067	04/30/92	Y	NRI

TALLY ITEM B4.12 9

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-E ITEM: B4.13

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP ----	NCR NO -----			RESOLUTION -----
INCORE-48-49 VT-2	INCORE PEN	ISI-C-198608	N/A	RPV-E N	622068	04/30/92	Y	NRI
INCORE-56-41 VT-2	INCORE PEN	ISI-C-198608	N/A	RPV-E N	622069	04/30/92	Y	NRI
N16B VT-2	INST NOZ	ISI-C-198608	N/A	RPV-E N	622070	04/30/92	Y	NRI

TALLY ITEM B4.13 3
 TALLY CODECAT B-E 12

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-F

ITEM: B5.10

CID ----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM	EXAM NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP	NCR NO -----			RESOLUTION -----
N8A NOZ-SE VOL	NOZ-SE	FF113012 SHT 0201		RPV-E B	622071	03/26/92	Y	NRI
N8A NOZ-SE SUR	NOZ-SE	FF113012 SHT 0201	N/A	RPV-E B	622072	03/30/92	Y	NRI
N8B NOZ-SE VOL	NOZ-SE	FF113012 SHT 0201		RPV-E A	622073	04/03/92	Y	NRI
N8B NOZ-SE SUR	NOZ-SE	FF113012 SHT 0201	N/A	RPV-E A	622074	03/30/92	Y	NRI

TALLY ITEM B5.10 4

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-F

ITEM: B5.50

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
DCA1112-FW-18 SUR	E-FL	ISI-DCA-111-2		RHR A	492005	04/02/92	Y	NRI
DCA1112-FW-18 VOL	E-FL	ISI-DCA-111-2	P-13	RHR A	492006	04/03/92	Y	NRI
DCA1031-FW-60 SUR	P-T	ISI-DCA-103-1		RWCU	612004	04/12/92	Y	NRI
DCA1031-FW-60 VOL	P-T	ISI-DCA-103-1		RWCU	612005	04/28/92	Y	NRI

TALLY ITEM B5.50 4

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-F ITEM: B5.51

CID ---	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
DCA1031-FW-57 SUR	P-P	ISI-DCA-103-1		RWCU	612006	05/06/92	Y	NRI

TALLY ITEM B5.51 1
 TALLY CDECAT B-F 9

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-1

ITEM: B6.10

CID --- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
RPV-NUT-01 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-02 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-03 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-04 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-05 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-06 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-07 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-08 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-09 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-10 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-1 ITEM: B6.10

CID ---- EXAM TYPE -----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
RPV-NUT-11 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-12 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-13 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-14 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-15 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-16 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-17 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-18 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-19 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-20 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-1 ITEM: 86.10

CID ---- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
RPV-NUT-21 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-22 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-23 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-24 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-25 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-26 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-27 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-28 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-29 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-30 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-1 ITEM: B6.10

CID ----- EXAM TYPE -----	DESC -----	ISI ISO -----	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
RPV-NUT-31 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-32 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-33 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-34 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-35 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-36 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-37 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-38 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-39 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-40 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-1 ITEM: B6.10

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
RPV-NUT-41 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-42 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-43 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-44 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-45 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-46 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-47 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-48 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-49 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-50 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-1 ITEM: B6.10

CID ---- EXAM TYPE -----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
RPV-NUT-51 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-52 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-53 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-54 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-55 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-56 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-57 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-58 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-59 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-60 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-1 ITEM: B6.10

CID ---	DESC -----	ISI ISO ---	CAL BLOCK	SYSTEM	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT	INDICATION ----- RESOLUTION -----
RPV-NUT-61 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-62 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-63 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-64 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-65 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-66 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-67 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-68 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-69 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-70 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-1 ITEM: B6.10

CID ---	DESC ---	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
RPV-NUT-71 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-72 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-73 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-74 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-75 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI
RPV-NUT-76 SUR	RPV NUT	FF113010 SHT 8601	N/A	RPV-E N	622075	04/23/92	Y	NRI

TALLY ITEM B6.10 76
TALLY CDECAT B-G-1 76



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-2 ITEM: B7.50

CID ----- EXAM TYPE -----	DESC -----	ISI ISO -----	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
VNBB212-17-N-B VT-1	FLANGE BOLTING	ISI-VNB-B21-2		MS	832008	03/30/92	Y	NRI
VNBB212-17-S-B VT-1	FLANGE BOLTING	ISI-VNB-B21-2		MS	832009	03/30/92	Y	NRI
VNBB212-17-T-B VT-1	FLANGE BOLTING	ISI-VNB-B21-2		MS	832010	03/25/92	Y	NRI
VNBB212-18-E-B VT-1	FLANGE BOLTING	ISI-VNB-B21-2		MS	832011	03/30/92	Y	NRI
VNBB212-18-K-B VT-1	FLANGE BOLTING	ISI-VNB-B21-2		MS	832012	03/30/92	Y	NRI
DCA1112-FW16-BG VT-1	FLANGE BOLTING	ISI-DCA-111-2		RHR A	492007	04/02/92	Y	NRI
RPV-N6A-BG2 VT-1	SPARE FLG BLTS	FF113010 SHT 5603	N/A	RPV-E N	622076	04/24/92	Y	NRI
RPV-N6B-BG2 VT-1	HEAD SPRAY BLTS	FF113010 SHT 5603	N/A	RPV-E N	622077	05/20/92	Y	NRI
RPV-N7-BG2 VT-1	HEAD VENT BOLTS	FF113012 SHT 1301	N/A	RPV-E N	622078	05/20/92	Y	NRI
DCA1421-FL-1 VT-1	FLANGE BOLTING	ISI-DCA-142-1		RR A	642009	04/05/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-2 ITEM: B7.50

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
VRRB311-14-G-B VT-1	FLANGE BOLTING	ISI-VRR-B31-1		RR A	642010	03/30/92	Y	NRI
VRRB312-3-G-B VT-1	FLANGE BOLTING	ISI-VRR-B31-2		RR B	642011	04/03/92	Y	NRI

TALLY ITEM B7.50 12

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-2 ITEM: B7.70

CID ----- EXAM TYPE -----	DESC -----	ISI ISO -----	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
1F010A-BG2 VT-1	VALVE BOLTING	ISI-DLA-101-1		FW A	452005	04/03/92	Y	NRI
1F010B-BG2 VT-1	VALVE BOLTING	ISI-DLA-103-1		FW B	452006	03/30/92	Y	NRI
PSV1F013C-BG2 VT-1	VALVE BOLTING	ISI-VNB-B21-2		MS	832013	03/22/92	Y	NRI
PSV1F013M-BG2 VT-1	VALVE BOLTING	ISI-VNB-B21-2		MS	832014	03/20/92	Y	NRI
PSV1F013P-BG2 VT-1	VALVE BOLTING	ISI-VNB-B21-2		MS	832015	03/26/92	Y	NRI
PSV1F013S-BG2 VT-1	VALVE BOLTING	ISI-VNB-B21-2		MS	832016	03/20/92	Y	NRI
HV1F023B-BG2 VT-1	VALVE BOLTING	ISI-VRR-B31-2		RR B	642012	04/03/92	Y	NRI

TALLY ITEM B7.70 7

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-2 ITEM: B7.80

CID ----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
CRD-02-19-BLT VT-1	CRD HOUSING BLT			RPV-E	622500	04/22/92	Y	NRI
CRD-02-23-BLT VT-1	CRD HOUSING BLT			RPV-E	622501	04/22/92	Y	NRI
CRD-06-15-BLT VT-1	CRD HOUSING BLT			RPV-E	622502 92-115	04/22/92	Y	LINEAR PITTING REPLACE
CRD-06-43-BLT VT-1	CRD HOUSING BLT			RPV-E	622503 92-115	04/22/92	Y	LINEAR PITTING REPLACE
CRD-10-11-BLT VT-1	CRD HOUSING BLT			RPV-E	622504	04/22/92	Y	NRI
CRD-10-19-BLT VT-1	CRD HOUSING BLT			RPV-E	622505	04/22/92	Y	NRI
CRD-10-47-BLT VT-1	CRD HOUSING BLT			RPV-E	622506 92-115	04/22/92	Y	MECH DAMAGE REPLACE
CRD-10-51-BLT VT-1	CRD HOUSING BLT			RPV-E	622507	04/22/92	Y	NRI
CRD-14-23-BLT VT-1	CRD HOUSING BLT			RPV-E	622508 92-115	04/22/92	Y	LINEAR PITTING REPLACE
CRD-18-19-BLT VT-1	CRD HOUSING BLT			RPV-E	622509 92-115	04/22/92	Y	LINEAR PITTING REPLACE

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-2 ITEM: 87.80

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
CRD-18-47-BLT VT-1	CRD HOUSING BLT			RPV-E	622510	04/22/92	Y	NRI
CRD-18-55-BLT VT-1	CRD HOUSING BLT			RPV-E	622511 92-115	04/22/92	Y	LINEAR PITTING REPLACE
CRD-22-27-BLT VT-1	CRD HOUSING BLT			RPV-E	622512	04/22/92	Y	NRI
CRD-22-35-BLT VT-1	CRD HOUSING BLT			RPV-E	622513	04/22/92	Y	NRI
CRD-30-23-BLT VT-1	CRD HOUSING BLT			RPV-E	622514 92-115	04/22/92	Y	MECH DAMAGE REPLACE
CRD-38-11-BLT VT-1	CRD HOUSING BLT			RPV-E	622515 92-115	04/22/92	Y	LINEAR PITTING REPLACE
CRD-42-03-BLT VT-1	CRD HOUSING BLT			RPV-E	622516 92-115	04/22/92	Y	MECH DAMAGE REPLACE
CRD-42-07-BLT VT-1	CRD HOUSING BLT			RPV-E	622517 92-115	04/22/92	Y	LINEAR PITTING REPLACE
CRD-42-55-BLT VT-1	CRD HOUSING BLT			RPV-E	622518	04/22/92	Y	NRI
CRD-46-11-BLT VT-1	CRD HOUSING BLT			RPV-E	622519	04/22/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-G-2 ITEM: B7.80

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
CRD-46-35-BLT VT-1	CRD HOUSING BLT			RPV-E	622520	04/22/92	Y	NRI
CRD-50-11-BLT VT-1	CRD HOUSING BLT			RPV-E	622521 92-115	04/22/92	Y	LINEAR PITTING REPLACE
CRD-54-15-BLT VT-1	CRD HOUSING BLT			RPV-E	622522 92-115	04/22/92	Y	LINEAR PITTING REPLACE
CRD-54-23-BLT VT-1	CRD HOUSING BLT			RPV-E	622523	04/22/92	Y	NRI

TALLY ITEM B7.80 24
TALLY CDECAT B-G-2 43

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-H ITEM: B8.10

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
CG SUR	RPV-SUP SKIRT	ISI-C-199555	N/A	RPV-E N	622079	04/24/92	Y	NRI
SB-E VT-1	STAB BRACK	ISI-C-205754	N/A	RPV-E N	622080	05/08/92	Y	NRI

TALLY ITEM B8.10 2
 TALLY CDECAT B-H 2



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-J

ITEM: B9.11

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
DCA1091-1-D SUR	E-P	ISI-DCA-109-1		CS A	512001	03/26/92	Y	NRI
DCA1091-1-D VOL	E-P	ISI-DCA-109-1	P-33	CS A	512002	03/26/92	Y	NRI
DLA1021-5-E VOL	P-E	ISI-DLA-102-1	P-31	FW A	452007	04/18/92	Y	O.D. GEOMETRY ACCP
DLA1021-5-E SUR	P-E	ISI-DLA-102-1		FW A	452008	04/16/92	Y	NRI
DLA1043-1-1-1 VOL	P-SE	ISI-DLA-104-3	P-31	FW B	452009	04/16/92	Y	ROOT GEOMETRY ACCP
DLA1043-FW-1 SUR	P-SE	ISI-DLA-104-3		FW B	452010	04/05/92	Y	NRI
DLA1043-FW-2 VOL	T-P	ISI-DLA-104-3	P-31	FW B	452011	04/18/92	Y	NRI
DLA1043-FW-2 SUR	T-P	ISI-DLA-104-3		FW B	452012	03/28/92	Y	NRI
DLA1043-FW-3 VOL	P-E	ISI-DLA-104-3	P-31	FW B	452013	04/18/92	Y	O.D. GEOMETRY ACCP
DLA1043-FW-3 SUR	P-E	ISI-DLA-104-3		FW B	452014	04/16/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-J

ITEM: B9.11

CID ---	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
DLA1044-FW-1 VOL	P-SE	ISI-DLA-104-4	P-31	FW B	452015	04/16/92	Y	ROOT GEOMETRY ACCP
DLA1044-FW-1 SUR	P-SE	ISI-DLA-104-4		FW B	452016	04/05/92	Y	NRI
VNBB211-19-E SUR	P-FL	ISI-VNB-B21-1		MS	832017 92-119	05/20/92	Y	LINEAR REPAIR
VNBB211-19-E VOL	P-FL	ISI-VNB-B21-1	P-21	MS	832018	04/28/92	Y	NRI
VNBB212-FW-B3 SUR	P-E	ISI-VNB-B21-2		MS	832019	04/16/92	Y	NRI
VNBB212-FW-B3 VOL	P-E	ISI-VNB-B21-2	P-77	MS	832020	04/16/92	Y	NRI
VNBB212-17-M SUR	SWOL-P	ISI-VNB-B21-2		MS	832021	03/20/92	Y	NRI
VNBB212-17-M VOL	SWOL-P	ISI-VNB-B21-2	P-21	MS	832022	04/16/92	Y	NRI
VNBB212-17-R SUR	SWOL-P	ISI-VNB-B21-2		MS	832023 92-050	05/06/92	Y	LINEAR REPAIR
VNBB212-17-R VOL	SWOL-P	ISI-VNB-B21-2	P-21	MS	832024	04/16/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-J

ITEM: B9.11

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
VNBB212-17-T SUR	P-FL	ISI-VNB-B21-2		MS	832025	04/05/92	Y	NRI
VNBB212-17-T VOL	P-FL	ISI-VNB-B21-2	P-21	MS	832026	04/11/92	Y	NRI
VNBB212-18-B SUR	P-E	ISI-VNB-B21-2		MS	832027	03/20/92	Y	NRI
VNBB212-18-B VOL	P-E	ISI-VNB-B21-2	P-75	MS	832028	04/16/92	Y	GEOMETRY ACCP
VNBB212-18-D SUR	SWOL-P	ISI-VNB-B21-2		MS	832029	03/26/92	Y	NRI
VNBB212-18-D VOL	SWOL-P	ISI-VNB-B21-2	P-21	MS	832030	04/11/92	Y	NRI
DCA1112-FW-5 SUR	P-V	ISI-DCA-111-2		RHR A	492008	04/02/92	Y	NRI
DCA1112-FW-5 VOL	P-V	ISI-DCA-111-2	P-13	RHR A	492009	04/03/92	Y	NRI
DCA1112-3-A SUR	P-FL	ISI-DCA-111-2		RHR A	492010	04/30/92	Y	NRI
DCA1112-3-A VOL	P-FL	ISI-DCA-111-2	P-13	RHR A	492011	04/30/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-J

ITEM: B9.11

CID ;	DESC	ISI ISO	CAL BLOCK	SYSTEM	EXAM NO	AN11 SIGN-OFF	PROGRAM CREDIT	INDICATION
EXAM TYPE				LOOP	NCR NO			RESOLUTION
NBA PEN SEAL A WELD VOL	ASSEMBLY WELD	FF113013 SHT 601	P-13	RPV-E B	622081	03/26/92	Y	NRI
N8B PEN SEAL A WELD VOL	ASSEMBLY WELD	FF113013 SHT 601	P-13	RPV-E A	622082	04/03/92	Y	NRI
VRRB311-FW-A14M SUR	P-P	ISI-VRR-B31-1		RR A	642013	03/30/92	Y	NRI
VRRB311-FW-A14M VOL	P-P	ISI-VRR-B31-1	P-92	RR A	642011	04/03/92	Y	I. D. GEOMETRY ACCP
VRRB312-FW-B3 SUR	E-V	ISI-VRR-B31-2		RR B	642015	04/03/92	Y	NRI
VRRB312-FW-B3 VOL	E-V	ISI-VRR-B31-2	P-81	RR B	642016	05/06/92	Y	NRI
VRRB312-5-A SUR	E-P	ISI-VRR-B31-2		RR B	642017	04/01/92	Y	NRI
VRRB312-5-A VOL	E-P	ISI-VRR-B31-2	P-33	RR B	642018	04/21/92	Y	ROOT GEOMETRY ACCP
VRRB312-6-A SUR	E-P	ISI-VRR-B31-2		RR B	642019	04/01/92	Y	NRI
VRRB312-6-A VOL	E-P	ISI-VRR-B31-2	P-33	RR B	642020	04/21/92	Y	ROOT GEOMETRY ACCP



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-J

ITEM: B9.11

CID ----- EXAM TYPE -----	DESC -----	ISI ISO -----	CAL BLOCK -----	SYSTEM LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
VRRB312-6-B SUR	P-E	ISI-VRR-B31-2		RR B	642021	04/01/92	Y	NRI
VRRB312-6-B VOL	P-E	ISI-VRR-B31-2	P-33	RR B	642022	04/21/92	Y	ROOT GEOMETRY ACCPY
DCA1031-FW-10 SUR	E-E	ISI-DCA-103-1		RWCU	612008	04/02/92	Y	NRI
DCA1031-FW-10 VOL	E-E	ISI-DCA-103-1	P-05	RWCU	612009	04/02/92	Y	NRI
DCA1031-FW-41 SUR	P-T	ISI-DCA-103-1		RWCU	612021	04/05/92	Y	NRI
DCA1031-FW-41 VOL	P-T	ISI-DCA-103-1	P-05	RWCU	612020	04/11/92	Y	NRI
DCA1031-FW-48 SUR	E-P	ISI-DCA-103-1		RWCU	612010	04/03/92	Y	NRI
DCA1031-FW-48 VOL	E-P	ISI-DCA-103-1	P-05	RWCU	612011	04/03/92	Y	NRI
DCA1031-FW-49 SUR	P-E	ISI-DCA-103-1		RWCU	612012	04/03/92	Y	NRI
DCA1031-FW-49 VOL	P-E	ISI-DCA-103-1	P-05	RWCU	612013	04/03/92	Y	NRI



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-J ITEM: 89.11

CID ----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM -----	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
DCA1031-FW-50 SUR	P-P	ISI-DCA-103-1		RWCU	612014	04/03/92	Y	NRI
DCA1031-FW-50 VOL	P-P	ISI-DCA-103-1	P-05	RWCU	612015	04/03/92	Y	NRI

TALLY ITEM 89.11 52

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-J

ITEM: B9.12

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
DCA1112-3-B VOL	PIPE SEAM	ISI-DCA-111-2	P-13	RHR A	492012	04/30/92	Y	ROOT GEOMETRY ACCP
DCA1112-3-B SUR	PIPE SEAM	ISI-DCA-111-2		RHR A	492013	04/30/92	Y	NRI
DCA1112-4-F SUR	PIPE SEAM	ISI-DCA-111-2		RHR A	492014	04/03/92	Y	NRI
DCB1021-2-D VOL	PIPE SEAM	ISI-DCB-102-1	P-13	RHR A	492015	04/12/92	Y	NRI
DCA1421-1-D VOL	PIPE SEAM	ISI-DCA-142-1	P-05	RR B	642023	04/12/92	Y	NRI
DCA1421-1-D SUR	PIPE SEAM	ISI-DCA-142-1		RR B	642024	04/12/92	Y	NRI
VRRB311-2-U SUR	TEE SEAM	ISI-VRR-B31-1		RR A	642025	03/30/92	Y	NRI
VRRB311-2-U VOL	TEE SEAM	ISI-VRR-B31-1	P-82	RR A	642026	04/15/92	Y	NRI
VRRB311-2-V SUR	TEE SEAM	ISI-VRR-B31-1		RR A	642027	03/30/92	Y	NRI
VRRB311-2-V VOL	TEE SEAM	ISI-VRR-B31-1	P-82	RR A	642028 92-041	04/15/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-J

ITEM: B9.12

CID --- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
VRRB311-5-C VOL	ELBOW SEAM	ISI-VRR-B31-1	P-33	RR A	642029	04/01/92	Y	NRI
VRRB311-5-C SUR	ELBOW SEAM	ISI-VRR-B31-1		RR A	642030	03/30/92	Y	NRI
VRRB312-1-J SUR	ELBOW SEAM	ISI-VRR-B31-2		RR B	642031	04/01/92	Y	NRI
VRRB312-1-K SUR	PIPE SEAM	ISI-VRR-B31-2		RR B	642032	04/01/92	Y	NRI
VRRB312-1-K SUR	PIPE SEAM	ISI-VRR-B31-2		RR B	642032	04/01/92	Y	NRI
VRRB312-10-U SUR	TEE SEAM	ISI-VRR-B31-2		RR B	642033	03/30/92	Y	NRI
VRRB312-10-U VOL	TEE SEAM	ISI-VRR-B31-2	P-82	RR B	642034	04/15/92	Y	NRI
VRRB312-10-V SUR	TEE SEAM	ISI-VRR-B31-2		RR B	642035	03/30/92	Y	NRI
VRRB312-10-V VOL	TEE SEAM	ISI-VRR-B31-2	P-82	RR B	642036	04/15/92	Y	NRI
VRRB312-2-P SUR	ELBOW SEAM	ISI-VRR-B31-2		RR B	642037	04/03/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-J

ITEM: B9.12

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
VRRB312-2-P VOL	ELBOW SEAM	ISI-VRR-B31-2	P-81	RR B	642038	05/06/92	Y	NRI
VRRB312-2-Q SUR	ELBOW SEAM	ISI-VRR-B31-2		RR B	642039	04/03/92	Y	NRI
VRRB312-2-Q VOL	ELBOW SEAM	ISI-VRR-B31-2	P-81	RR B	642040	05/06/92	Y	NRI
VRRB312-5-C VOL	ELBOW SEAM	ISI-VRR-B31-2	P-33	RR B	642043	04/15/92	Y	NRI
VRRB312-5-C SUR	ELBOW SEAM	ISI-VRR-B31-2		RR B	642044	04/01/92	Y	NRI
VRRB312-6-C VOL	ELBOW SEAM	ISI-VRR-B31-2	P-33	RR B	642045	04/15/92	Y	NRI
VRRB312-6-C SUR	ELBOW SEAM	ISI-VRR-B31-2		RR B	642046	04/01/92	Y	NRI

TALLY ITEM B9.12 27



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-J

ITEM: B9.21

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP ----	NCR NO -----			RESOLUTION -----
SPDCA1021-FW-11 SUR	P-V	ISI-SP-DCA-102-1		RR B	642047	04/03/92	Y	NRI
SPDCA1022-FW10 SUR	RED-P	ISI-SP-DCA-102-2		RR A	642048	03/30/92	Y	NRI
SPDCA1062-30 SUR	E-P	ISI-SP-DCA-106-2		SBLC	532001	04/02/92	Y	NRI

TALLY ITEM B9.21 3



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-J

ITEM: B9.31

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
VNBB212-18-C SUR	P-SWOL	ISI-VNB-B21-2		MS	832031	03/30/92	Y	NRI
VNBB212-18-C VOL	P-SWOL	ISI-VNB-B21-2	P-75	MS	832032	04/16/92	Y	NRI
VRRB312-3-B VOL	P-WOL	ISI-VRR-B31-2	P-79	RR B	642049	05/06/92	Y	NRI
VRRB312-3-B SUR	P-WOL	ISI-VRR-B31-2		RR B	642050	04/05/92	Y	NRI
VRRB312-9-1-G SUR	P-SWOL	ISI-VRR-B31-2		RR	642051	04/11/92	Y	NRI
VRRB312-9-1-G VOL	P-SWOL	ISI-VRR-B31-2	P-58	RR	642052	04/12/92	Y	NRI

TALLY ITEM B9.31 6

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-J ITEM: B9.40

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
SPDCA1062-FW-24 SUR	P-T	ISI-SP-DCA-106-2		SBLC	532002	04/03/92	Y	NRI
SPDCA1064-FW-8 SUR	P-COUP	ISI-SP-DCA-106-4		SBLC	532003	04/02/92	Y	NRI
TALLY ITEM B9.40 2								
TALLY CDECAT B-J 90								

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-K-1

ITEM: B10.10

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
MST0222-HW-2A SUR	P-LUG/H42	ISI-VNB-B21-1-H		MS	832033	04/15/92	Y	NRI
MST0222-HW-2B SUR	P-LUG/H42	ISI-VNB-B21-2-H		MS	832033	04/15/92	Y	NRI
MST0222-HW-2C SUR	P-LUG/H42	ISI-VNB-B21-2-H		MS	832033	04/15/92	Y	NRI
MST0222-HW-2D SUR	P-LUG/H42	ISI-VNB-B21-2-H		MS	832033	04/15/92	Y	NRI
MST0222-HW-2E SUR	P-LUG/H42	ISI-VNB-B21-2-H		MS	832033	04/15/92	Y	NRI
MST0222-HW-2F SUR	P-LUG/H42	ISI-VNB-B21-2-H		MS	832033	04/15/92	Y	NRI
MST0222-HW-2G SUR	P-LUG/H42	ISI-VNB-B21-2-H		MS	832033	04/15/92	Y	NRI
MST0222-HW-2H SUR	P-LUG/H42	ISI-VNB-B21-2-H		MS	832033	04/15/92	Y	NRI
RWS1002-HW-2A SUR	P-LUG/H26	ISI-VRR-B31-2-H		RR B	642053	04/15/92	Y	NRI
RWS1002-HW-2B SUR	P-LUG/H26	ISI-VRR-B31-2-H		RR B	642053	04/15/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-K-1

ITEM: B10.10

CID ----- EXAM TYPE	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
RWS1002-HW-2C SUR	P-LUG/H26	ISI-VRR-B31-2-H		RR B	642053	04/15/92	Y	NRI
RWS1002-HW-2D SUR	P-LUG/H26	ISI-VRR-B31-2-H		RR B	642053	04/15/92	Y	NRI
RWS1002-HW-2E SUR	P-LUG/H26	ISI-VRR-B31-2-H		RR B	642053	04/15/92	Y	NRI
RWS1002-HW-2F SUR	P-LUG/H26	ISI-VRR-B31-2-H		RR B	642053	04/15/92	Y	NRI
RWS1002-HW-2G SUR	P-LUG/H26	ISI-VRR-B31-2-H		RR B	642053	04/15/92	Y	NRI
RWS1002-HW-2H SUR	P-LUG/H26	ISI-VRR-B31-2-H		RR B	642053	04/15/92	Y	NRI
1P401A-HW1 SUR	BRKT/HA6/H47	C-198638		RR A	642054	03/30/92	Y	NRI
1P401A-HW2 SUR	BRKT/H46	C-198638		RR A	642055	04/03/92	Y	NRI
1P401A-HW3 SUR	BRKT/HA5	C-198638		RR A	642056	03/30/92	Y	NRI
1P401A-HW4 SUR	BRKT/HA7	C-198638		RR A	642057	03/30/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-K-1

ITEM: B10.10

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
1P401B-HW1 SUR	BRKT/HB6/H42	C-198638		RR B	642058	04/01/92	Y	NRI
1P401B-HW2 SUR	BRKT/H41	C-198638		RR B	642059	04/01/92	Y	NRI
1P401B-HW3 SUR	BRKT/HB5	C-198638		RR B	642060	04/01/92	Y	NRI
1P401B-HW4 SUR	BRKT/HB7	C-198638		RR B	642061	04/01/92	Y	NRI

TALLY ITEM B10.10 24
TALLY CDECAT B-K-1 24

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-M-2 ITEM: B12.40

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
HV1F005A VT-3	VALVE INT SUR	ISI-DCA-109-1		CS A	003-92	03/18/92	Y	NRI
HV1F005B VT-3	VALVE INT SUR	ISI-DCA-109-2		CS B	035-92	04/14/92	Y	NRI
1F010A VT-3	VALVE INT SUR	ISI-DLA-101-1		FW	036-92	04/15/92	Y	VISUAL ACCPY
1F010B VT-3	VALVE INT SUR	ISI-DLA-103-1		FW	030-92	03/30/92	Y	NRI
HV1F015A VT-3	VALVE INT SUR	ISI-DCA-110-1		RHR A	032-92	03/30/92	Y	NRI
HV1F050A VT-3	VALVE INT SUR	ISI-DCA-110-1		RHR A	010-92	03/27/92	Y	NRI

TALLY ITEM B12.40 6
TALLY CDECAT B-M-2 6

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-N-1 ITEM: B13.10

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
RPV HEAD INTERIOR VT-3	INT SURFACES	ISI-C-198624	N/A	RPV-I N	622242	03/30/92	Y	NRI

TALLY ITEM B13.10 1
 TALLY CDECAT B-N-1 1

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-N-2 ITEM: B13.20

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ----		CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
BAFFLE PLATE WELD VT-1	RPV ATTACH WELD	ISI-RPV-INT-001	SHT 2	N/A	RPV-I N	622224	04/16/92	Y	NRI
DRYER SUP BRKT A VT-1	RPV ATTACH WELD	ISI-RPV-INT-001	SHT 2	N/A	RPV-I N	622225	04/16/92	Y	NRI
DRYER SUP BRKT B VT-1	RPV ATTACH WELD	ISI-RPV-INT-001	SHT 2	N/A	RPV-I N	622226	4/16/92	Y	NRI
DRYER SUP BRKT C VT-1	RPV ATTACH WELD	ISI-RPV-INT-001	SHT 2	N/A	RPV-I N	622227	04/16/92	Y	NRI
DRYER SUP BRKT D VT-1	RPV ATTACH WELD	ISI-RPV-INT-001	SHT 2	N/A	RPV-I N	622228	04/16/92	Y	NRI
N2A RISR SUP WELD A VT-1	RPV BELT ATTACH	ISI-RPV-INT-001	SHT 4		RPV-I	622297	04/16/92	Y	NRI
N2A RISR SUP WELD B VT-1	RPV BELT ATTACH	ISI-RPV-INT-001	SHT 4		RPV-I	622298	04/16/92	Y	NRI
N2J RISR SUP WELD A VT-1	RPV BELT ATTACH	ISI-RPV-INT-001	SHT 4	N/A	RPV-I N	622229	04/16/92	Y	NRI
N2J RISR SUP WELD B VT-1	RPV BELT ATTACH	ISI-RPV-INT-001	SHT 4	N/A	RPV-I N	622230	04/16/92	Y	NRI
N2K RISR SUP WELD A VT-1	RPV BELT ATTACH	ISI-RPV-INT-001	SHT 4	N/A	RPV-I N	622231	04/16/92	Y	NRI


SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-N-2

ITEM: B13.20

CID ----- EXAM TYPE	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
N4F BRKT WELD A VT-1	RPV ATTACH WELD	ISI-RPV-INT-001 SHT 1	N/A	RPV-I N	622232	04/16/92	Y	NRI
N4F BRKT WELD B VT-1	RPV ATTACH WELD	ISI-RPV-INT-001 SHT 1	N/A	RPV-I N	622233	04/16/92	Y	NRI
N5A BRKT WELD B VT-1	RPV ATTACH	ISI-RPV-INT-001 SHT 1		RPV-I	622295	04/16/92	Y	NRI
N5A BRKT WELD C VT-1	RPV ATTACH	ISI-RPV-INT-001 SHT 1		RPV-I	622296	04/16/92	Y	NRI
N5B BRKT WELD D VT-1	RPV ATTACH	ISI-RPV-INT-001 SHT 1	N/A	RPV-I N	622234	04/16/92	Y	NRI
SHRD SUP LEG WELD A VT-1	RPV ATTACH WELD	ISI-C-199587		RPV-I	622242	04/03/92	Y	NRI
SHRD SUP LEG WELD B VT-1	RPV ATTACH WELD	ISI-C-199587		RPV-I	622244	04/03/92	Y	NRI
SHRD SUP LEG WELD C VT-1	RPV ATTACH WELD	ISI-RPV-INT-001 SHT 2		RPV-I	622306	04/03/92	Y	NRI
SHRD SUP LEG WELD E VT-1	RPV ATTACH WELD	ISI-RPV-INT-001 SHT 2		RPV-I	622307	04/03/92	Y	NRI
SHRD SUP LEG WELD F VT-1	RPV ATTACH WELD	ISI-C-199587		RPV-I	622246	04/03/92	Y	NRI



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-N-2

ITEM: B13.20

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP ---	NCR NO -----			RESOLUTION -----
SHRD SUP LEG WELD G VT-1	RPV ATTACH WELD	ISI-C-199587		RPV-I	622248	04/03/92	Y	NRI
SHRD SUP LEG WELD H VT-1	RPV ATTACH WELD	ISI-C-199587		RPV-I	622250	04/03/92	Y	NRI
SHRD SUP LEG WELD J VT-1	RPV ATTACH WELD	ISI-C-199587		RPV-I	622252	04/03/92	Y	NRI
SHRD SUP LEG WELD K VT-1	RPV ATTACH WELD	ISI-RPV-INT-001 SHT 2		RPV-I	622309	04/03/92	Y	NRI
SHRD SUP LEG WELD M VT-1	RPV ATTACH WELD	ISI-RPV-INT-001 SHT 2		RPV-I	622309	04/03/92	Y	NRI
SHRD SUP LEG WELD N VT-1	RPV ATTACH WELD	ISI-C-199587		RPV-I	622254	04/03/92	Y	NRI
SHRD SUP LEG WELD P VT-1	RPV ATTACH WELD	ISI-C-199587		RPV-I	622256	04/03/92	Y	NRI
SURV SPEC BRKT 3B VT-1	RPV ATTACH WELD	ISI-RPV-INT-001 SHT 2	N/A	RPV-I	622235	04/16/92	Y	NRI

TALLY ITEM B13.20 28

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-N-2 ITEM: B13.21

CID ----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM -----	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			
BAFFLE PLATE VT-1	CORE SUPPORT	ISI-RPV-INT-001 SHT 2	N/A	RPV-I	622236	04/16/92	Y	NRI
FUEL SUP PC 10-23 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622259	04/03/92	Y	NRI
FUEL SUP PC 10-39 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622260	04/03/92	Y	NRI
FUEL SUP PC 14-23 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622261	04/03/92	Y	NRI
FUEL SUP PC 14-39 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622262	04/03/92	Y	NRI
FUEL SUP PC 18-15 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622263	04/03/92	Y	NRI
FUEL SUP PC 18-47 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622264	04/03/92	Y	NRI
FUEL SUP PC 30-11 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622265	04/03/92	Y	NRI
FUEL SUP PC 30-51 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622266	04/03/92	Y	NRI
FUEL SUP PC 42-15 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622267	04/03/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-N-2 ITEM: B13.21

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
FUEL SUP PC 42-47 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622268	04/03/92	Y	NRI
FUEL SUP PC 46-23 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622269	04/03/92	Y	NRI
FUEL SUP PC 46-39 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622270	04/03/92	Y	NRI
FUEL SUP PC 50-23 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622271	04/03/92	Y	NRI
FUEL SUP PC 50-39 VT-1	CORE SUPPORT	FF113011 SHT 9101		RPV-I	622272	04/03/92	Y	NRI
SHROUD VT-1	CORE SUPPORT	ISI-RPV-INT-001 SHT 1	N/A	RPV-I	622239	04/16/92	Y	NRI
SHROUD SUP LEG A VT-1	LOWER PLENUM	ISI-C-199587		RPV-I	622243	04/03/92	Y	NRI
SHROUD SUP LEG B VT-1	LOWER PLENUM	ISI-C-199587		RPV-I	622245	04/03/92	Y	NRI
SHROUD SUP LEG C VT-1	LOWER PLENUM	ISI-RPV-INT-001 SHT 2		RPV-I	622310	04/03/92	Y	NRI
SHROUD SUP LEG E VT-1	LOWER PLENUM	ISI-RPV-INT-001 SHT 2		RPV-I	622311	04/03/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-N-2 ITEM: B13.21

CID ----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM LOOP ----	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
EXAM TYPE ----- SHROUD SUP LEG F VT-1	LOWER PLENUM	ISI-C-199587		RPV-I	622247	04/03/92	Y	NRI
SHROUD SUP LEG G VT-1	LOWER PLENUM	ISI-C-199587		RPV-I	622249	04/03/92	Y	NRI
SHROUD SUP LEG H VT-1	LOWER PLENUM	ISI-C-199587		RPV-I	622251	04/03/92	Y	NRI
SHROUD SUP LEG J VT-1	LOWER PLENUM	ISI-C-199587		RPV-I	622253	04/03/92	Y	NRI
SHROUD SUP LEG K VT-1	LOWER PLENUM	ISI-RPV-INT-001 SHT 2		RPV-I	622312	04/03/92	Y	NRI
SHROUD SUP LEG M VT-1	LOWER PLENUM	ISI-RPV-INT-001 SHT 2		RPV-I	622313	04/03/92	Y	NRI
SHROUD SUP LEG N VT-1	LOWER PLENUM	ISI-C-199587		RPV-I	622255	04/03/92	Y	NRI
SHROUD SUP LEG P VT-1	LOWER PLENUM	ISI-C-199587		RPV-I	622257	04/03/92	Y	NRI
SHROUD SUPPORT VT-1	CORE SUPPORT	ISI-RPV-INT-001 SHT 1&2	N/A	RPV-I	622240	04/16/92	Y	NRI

TALLY ITEM B13.21 29
TALLY CDECAT B-N-2.57

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: B-0

ITEM: B14.10

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
CRD-02-19-B-A SUR	TUBE B-TUBE A	ISI-C-198607	N/A	RPV-E	622083	04/12/92	Y	NRI
CRD-02-19-F-B SUR	FL-CRD HOUSING	ISI-C-198607	N/A	RPV-E	622084	RRGEN-92	Y	NOT ACCESSIBLE
CRD-10-11-B-A SUR	TUBE B-TUBE A	ISI-C-198607	N/A	RPV-E	622085	04/12/92	Y	NRI
CRD-10-11-F-B SUR	FL-CRD HOUSING	ISI-C-198607	N/A	RPV-E	622086	RRGEN-92	Y	NOT ACCESSIBLE
CRD-30-03-B-A SUR	TUBE B-TUBE A	ISI-C-198607	N/A	RPV-E	622087	04/12/92	Y	NRI
CRD-30-03-F-B SUR	FL-CRD HOUSING	ISI-C-198607	N/A	RPV-E	622088	RRGEN-92	Y	NOT ACCESSIBLE
CRD-50-11-B-A SUR	TUBE B-TUBE A	ISI-C-198607	N/A	RPV-E	622089	04/12/92	Y	NRI
CRD-50-11-F-B SUR	FL-CRD HOUSING	ISI-C-198607	N/A	RPV-E	622090	RRGEN-92	Y	NOT ACCESSIBLE

TALLY ITEM B14.10 8
TALLY CDECAT B-0 8

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE


OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-B

ITEM: C2.21

CID ----	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
1E-205A-23 SUR	NOZ-SH	C-198636/RHR HX		RHR A	492016	03/20/92	Y	NRI
1E-205A-23 VOL	NOZ-SH	C-198636/RHR HX	P-86	RHR A	492017	04/03/92	Y	WELDING ACCPT

TALLY ITEM C2.21 2



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-B ITEM: C2.22

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
1E205A-23 VOL	NIRN4-A	C-198636P/RHR HX	P-91	RHR A	492018	03/26/92	Y	I.R. GEOMETRY ACCP
TALLY ITEM C2.22								1
TALLY CDECAT C-B								3

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-C

ITEM: C3.10

CID ----	DESC ----	ISI ISO ----	CAL BLOCK -----	SYSTEM -----	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
1E-205A-5 SUR	HX-SUP	C-198636/RHR HX		RHR A	492019	03/12/92	Y	NRI
1E-205A-5A SUR	HX-SUP	C-198636/RHR HX		RHR A	492020	03/12/92	Y	NRI
1E-205A-5C SUR	HX-SUP	C-198636/RHR HX		RHR A	492022	03/12/92	Y	NRI

TALLY ITEM C3.10 3

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-C

ITEM: C3.40

CID ; ----- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
GBB1011-HW-2A SUR	P-LUG/H22	ISI-GBB-101-1-H		CS A	512003	03/13/92	Y	NRI
GBB1011-HW-2B SUR	P-LUG/H22	ISI-GBB-101-1-H		CS A	512003	03/13/92	Y	NRI
GBB1011-HW-2C SUR	P-LUG/H22	ISI-GBB-101-1-H		CS A	512003	03/13/92	Y	NRI
GBB1011-HW-2D SUR	P-LUG/H22	ISI-GBB-101-1-H		CS A	512003	03/13/92	Y	NRI
GBB1013-HW-4I SUR	P-PLT/H37	ISI-GBB-101-3-H		CS A	512004	03/07/92	Y	NRI
GBB1013-HW-4J SUR	P-PLT/H37	ISI-GBB-101-3-H		CS A	512004	03/07/92	Y	NRI
GBB1013-HW-4K SUR	P-PLT/H37	ISI-GBB-101-3-H		CS A	512004	03/07/92	Y	NRI
GBB1013-HW-4L SUR	P-PLT/H37	ISI-GBB-101-3-H		CS A	512004	03/07/92	Y	NRI
GBB1014-HW-1A SUR	P-LUG/H2	ISI-GBB-101-4-H		CS B	512005	05/06/92	Y	NRI
GBB1014-HW-1B SUR	P-LUG/H2	ISI-GBB-101-4-H		CS B	512005	05/06/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-C

ITEM: C3.40

CID ----- EXAM TYPE -----	DESC -----	ISI ISO -----	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
GBB1014-HW-1C SUR	P-LUG/H2	ISI-GBB-101-4-H		CS B	512005	05/06/92	Y	NRI
GBB1014-HW-1D SUR	P-LUG/H2	ISI-GBB-101-4-H		CS B	512005	05/06/92	Y	NRI
GBB1014-HW-18A SUR	P-PLT/H35	ISI-GBB-101-4-H		CS B	512006	05/08/92	Y	NRI
GBB1014-HW-18B SUR	P-PLT/H35	ISI-GBB-101-4-H		CS B	512006	05/08/92	Y	NRI
GBB1014-HW-18C SUR	P-PLT/H35	ISI-GBB-101-4-H		CS B	512006	05/08/92	Y	NRI
GBB1014-HW-18D SUR	P-PLT/H35	ISI-GBB-101-4-H		CS B	512006	05/08/92	Y	NRI
EBB1021-HW-1A SUR	P-LUG/H11	ISI-EBB-102-1-H		HPCI	522003	03/26/92	Y	NRI
EBB1021-HW-1B SUR	P-LUG/H11	ISI-EBB-102-1-H		HPCI	522003	03/26/92	Y	NRI
EBB1021-HW-1C SUR	P-LUG/H11	ISI-EBB-102-1-H		HPCI	522003	03/26/92	Y	NRI
EBB1021-HW-1D SUR	P-LUG/H11	ISI-EBB-102-1-H		HPCI	522003	03/26/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-C

ITEM: C3.40

CID ----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM -----	EXAM NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			
HBB1081-HW-1 SUR	P-LUG/H3	ISI-HBB-108-1-H		HPCI	522004	03/12/92	Y	NRI
HBB1081-HW-2 SUR	P-SUP/H1	ISI-HBB-108-1-H		HPCI	522005	03/26/92	Y	NRI
DBB1011-HW-22A SUR	PL-P/H17	ISI-DBB-101-1-H		MS	832034	04/15/92	Y	NRI
DBB1011-HW-22B SUR	PL-P/H17	ISI-DBB-101-1-H		MS	832034	04/15/92	Y	NRI
DBB1011-HW-22C SUR	PL-P/H17	ISI-DBB-101-1-H		MS	832034	04/15/92	Y	NRI
GBB1311-HW1 SUR	P-PLT/H1	ISI-GBB-131-1-H		MSIV	832068	03/26/92	Y	NRI
DBB1211-HW-1 SUR	P-SAD/H7	ISI-DBB-121-1-H		RCIC	502017	03/13/92	Y	NRI
DBB1212-HW-2 SUR	IA/H14	ISI-DBB-121-2-H		RCIC	502018	03/16/92	Y	NRI
DBB1212-HW-3A SUR	P-LUG/H21	ISI-DBB-121-2-H		RCIC	502003	03/26/92	Y	NRI
DBB1212-HW-3B SUR	P-LUG/H21	ISI-DBB-121-2-H		RCIC	502003	03/26/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-C

ITEM: C3.40

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM- ----- LOOP	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
DBB1212-HW-3C SUR	P-LUG/H21	ISI-DBB-121-2-H		RCIC	502003	03/26/92	Y	NRI
DBB1212-HW-3D SUR	P-LUG/H21	ISI-DBB-121-2-H		RCIC	502003	03/26/92	Y	NRI
DBB1212-HW-3E SUR	P-PLT/H21	ISI-DBB-121-2-H		RCIC	502003	03/26/92	Y	NRI
DBB1212-HW-3F SUR	P-PLT/H21	ISI-DBB-121-2-H		RCIC	502003	03/26/92	Y	NRI
DBB1212-HW-3G SUR	P-PLT/H21	ISI-DBB-121-2-H		RCIC	502003	03/26/92	Y	NRI
DBB1212-HW-3H SUR	P-PLT/H21	ISI-DBB-121-2-H		RCIC	502003	03/26/92	Y	NRI
HBB1012-HW-4 SUR	P-SUP/H2	ISI-HBB-101-2-H		RCIC	502019	03/13/92	Y	NRI
GBB1041-HW-1A SUR	P-LUG/H5	ISI-GBB-104-1-H		RHR A	492023	03/12/92	Y	NRI
GBB1041-HW-1B SUR	P-LUG/H5	ISI-GBB-104-1-H		RHR A	492023	03/12/92	Y	NRI
GBB1041-HW-1C SUR	P-LUG/H5	ISI-GBB-104-1-H		RHR A	492023	03/12/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-C

ITEM: C3.40

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
GBB1041-HW-1D SUR	P-LUG/H5	ISI-GBB-104-1-H		RHR A	492023	03/12/92	Y	NRI
GBB1041-HW-2A SUR	P-LUG/H5	ISI-GBB-104-1-H		RHR A	492023	03/12/92	Y	NRI
GBB1041-HW-2B SUR	P-LUG/H5	ISI-GBB-104-1-H		RHR A	492023	03/12/92	Y	NRI
GBB1041-HW-2C SUR	P-LUG/H5	ISI-GBB-104-1-H		RHR A	492023	03/12/92	Y	NRI
GBB1041-HW-2D SUR	P-LUG/H5	ISI-GBB-104-1-H		RHR A	492023	03/12/92	Y	NRI
GBB1043-HW-2A SUR	P-LUG/H23	ISI-GBB-104-3-H		RHR B	492065	03/12/92	Y	NRI
GBB1043-HW-2B SUR	P-LUG/H23	ISI-GBB-104-3-H		RHR B	492065	03/12/92	Y	NRI
GBB1043-HW-2C SUR	P-LUG/H23	ISI-GBB-104-3-H		RHR B	492065	03/12/92	Y	NRI
GBB1043-HW-2D SUR	P-LUG/H23	ISI-GBB-104-3-H		RHR B	492065	03/12/92	Y	NRI
GBB1043-HW-6A SUR	P-LUG/H23	ISI-GBB-104-3-H		RHR B	492065	03/12/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-C

ITEM: C3.40

CID -----	DESC -----	ISI ISO -----	CAL BLOCK -----	SYSTEM -----	EXAM NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
GBB1043-HW-6B SUR	P-LUG/H23	ISI-GBB-104-3-H		RHR B	492065	03/12/92	Y	NRI
GBB1043-HW-6C SUR	P-LUG/H23	ISI-GBB-104-3-H		RHR B	492065	03/12/92	Y	NRI
GBB1043-HW-6D SUR	P-LUG/H23	ISI-GBB-104-3-H		RHR B	492065	03/12/92	Y	NRI
GBB1061-HW-5A SUR	P-LUG/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-5B SUR	P-LUG/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-5C SUR	P-LUG/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-5D SUR	P-LUG/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-5E SUR	P-LUG/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-5F SUR	P-LUG/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-5H SUR	P-LUG/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-C

ITEM: C3.40

CID ---	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
GBB1061-HW-5J SUR	P-LUG/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-6A SUR	PLT-P/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-6B SUR	PLT-P/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-6C SUR	PLT-P/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-6D SUR	PLT-P/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-6E SUR	PLT-P/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-6F SUR	PLT-P/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-6G SUR	PLT-P/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1061-HW-6H SUR	PLT-P/H5	ISI-GBB-106-1-H		RHR A	492024	03/12/92	Y	NRI
GBB1062-HW-14A SUR	P-LUG/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-C

ITEM: C3.40

<u>CID</u>	<u>DESC</u>	<u>ISI</u> <u>ISO</u>	<u>CAL</u> <u>BLOCK</u>	<u>SYSTEM</u>	<u>EXAM</u> <u>NO</u>	<u>ANII</u> <u>SIGN-OFF</u>	<u>PROGRAM</u> <u>CREDIT</u>	<u>INDICATION</u>
<u>EXAM TYPE</u>				<u>LOOP</u>	<u>NCR NO</u>			<u>RESOLUTION</u>
GBB1062-HW-14B SUR	P-LUG/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1062-HW-14C SUR	P-LUG/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1062-HW-14D SUR	P-LUG/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1062-HW-14E SUR	P-LUG/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1062-HW-14F SUR	P-LUG/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1062-HW-14G SUR	P-LUG/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1062-HW-14H SUR	P-LUG/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1062-HW-14I SUR	PLT-P/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1062-HW-14J SUR	PLT-P/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1062-HW-14K SUR	PLT-P/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-C

ITEM: C3.40

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM LOOP	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION RESOLUTION -----
GBB1062-HW-14L SUR	PLT-P/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1062-HW-14M SUR	PLT-P/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1062-HW-14N SUR	PLT-P/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1062-HW-14O SUR	PLT-P/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1062-HW-14P SUR	PLT-P/H14	ISI-GBB-106-2-H		RHR B	492025	04/15/92	Y	NRI
GBB1092-HW-4A SUR	PLT-P/H26	ISI-GBB-109-2-H		RHR A	492067	03/30/92	Y	NRI
GBB1092-HW-4B SUR	PLT-P/H26	ISI-GBB-109-2-H		RHR A	492067	03/30/92	Y	NRI
GBB1092-HW-4C SUR	PLT-P/H26	ISI-GBB-109-2-H		RHR A	492067	03/30/92	Y	NRI
HBB1203-HW-1A SUR	P-PLT/H25	ISI-HBB-120-3-H		RHR A	492027	03/12/92	Y	NRI
HBB1203-HW-1B SUR	P-PLT/H25	ISI-HBB-120-3-H		RHR A	492027	03/12/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-C

ITEM: C3.40

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
HBB1203-HW-1C SUR	P-PLT/H25	ISI-HBB-120-3-H		RHR A	492027	03/12/92	Y	NRI
HBB1203-HW-1D SUR	P-PLT/H25	ISI-HBB-120-3-H		RHR A	492027	03/12/92	Y	NRI
TALLY ITEM C3.40	92							
TALLY CDECAT C-C	95							

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-F

ITEM: C5.11

CID ----- EXAM TYPE	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
HBB1081-2-B SUR	P-E	ISI-HBB-108-1		HPCI	522006	03/12/92	Y	NRI
HBB1082-FW-4 SUR	E-V	ISI-HBB-108-2		HPCI	522007	03/13/92	Y	NRI
HBB1082-FW-5 SUR	V-FH	ISI-HBB-108-2		HPCI	522008	03/13/92	Y	NRI
HBB1012-1-A SUR	P-CP	ISI-HBB-101-2		RCIC	502004	03/13/92	Y	NRI
HBB1012-2A-E SUR	P-E	ISI-HBB-101-2		RCIC	502005	03/13/92	Y	NRI
HBB1012-2C-A SUR	FL-P	ISI-HBB-101-2		RCIC	502006	03/13/92	Y	NRI
HBB1101-FW-5 SUR	E-T	ISI-HBB-110-1		RHR	492028	04/12/92	Y	NRI
HBB1101-5-F SUR	RED-FL	ISI-HBB-110-1		RHR A	492029	04/02/92	Y	NRI
HBB1203-FW-9 SUR	P-FL	ISI-HBB-120-3		RHR A	492030	03/26/92	Y	NRI
HBB1203-1B-B1 SUR	P-E	ISI-HBB-120-3		RHR A	492031	03/12/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-F ITEM: C5.11

CID	DESC	ISI	CAL	SYSTEM	EXAM	ANII	PROGRAM	INDICATION
---	---	---	BLOCK	---	NO	SIGN-OFF	CREDIT	---
EXAM TYPE				LOOP	NCR NO			RESOLUTION
-----				---	-----			-----
TALLY ITEM C5.11	10							

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-F

ITEM: C5.21

CID ---	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
DBB1052-2-A VOL	E-P	ISI-DBB-105-2	P-63	MS	832035	03/30/92	Y	NRI
DBB1052-2-A SUR	E-P	ISI-DBB-105-2		MS	832036	03/30/92	Y	NRI
DBB1052-3-C VOL	T-P	ISI-DBB-105-2	P-34	MS	832037	04/18/92	Y	NRI
DBB1052-3-C SUR	T-P	ISI-DBB-105-2		MS	832038	04/11/92	Y	NRI
DBB1052-3-M VOL	RESINT-P	ISI-DBB-105-2	P-63	MS	832039 92-106	04/21/92	Y	NRI
DBB1052-3-M SUR	RESINT-P	ISI-DBB-105-2		MS	832040 92-106	05/20/92	Y	LINEAR REPAIR
DBB1211-FW-4 VOL	V-P	ISI-DBB-121-1	P-18	RCIC	502007	03/14/92	Y	I.D. GEOMETRY ACCPT
DBB1211-FW-4 SUR	V-P	ISI-DBB-121-1		RCIC	502008	03/20/92	Y	NRI
DBB1211-FW-8 VOL	E-V	ISI-DBB-121-1	P-18	RCIC	502009	03/16/92	Y	NRI
DBB1211-FW-8 SUR	E-V	ISI-DBB-121-1		RCIC	502010	03/13/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-F

ITEM: C5.21

CID ---- EXAM TYPE	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
DBB1213-FW-5 VOL	P-E	ISI-DBB-121-3	P-18	RCIC	502001	03/16/92	Y	NRI
DBB1213-FW-5 SUR	P-E	ISI-DBB-121-3		RCIC	502011	03/16/92	Y	NRI
GBB1061-FW-5 SUR	V-P	ISI-GBB-106-1		RHR A	492032	03/12/92	Y	NRI
GBB1061-FW-5 VOL	V-P	ISI-GBB-106-1	P-62	RHR A	492033	03/20/92	Y	NRI
GBB1061-FW-7 VOL	P-FL	ISI-GBB-106-1	P-62	RHR A	492034	03/16/92	Y	NRI
GBB1061-FW-7 SUR	P-FL	ISI-GBB-106-1		RHR A	492035	03/12/92	Y	NRI
GBB1061-3-A VOL	E-P	ISI-GBB-106-1	P-62	RHR A	492036 92-051	04/02/92	Y	NRI
GBB1061-3-A SUR	E-P	ISI-GBB-106-1		RHR A	492037 92-051	04/24/92	Y	LINEAR REPAIR
GBB1151-1-A VOL	E-P	ISI-GBB-115-1	P-62	RHR B	492038	03/12/92	Y	NRI
GBB1151-1-A SUR	E-P	ISI-GBB-115-1		RHR B	492039	03/07/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-F

ITEM: C5.21

CID ----	DESC ----	ISI ISO ---	CAL BLOCK ----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
GBB1161-FW-1 VOL	NOZ-RED	ISI-GBB-116-1	P-62	RHR A	492040	03/16/92	Y	NRI
GBB1161-FW-1 SUR	NOZ-RED	ISI-GBB-116-1		RHR A	492041	03/12/92	Y	NRI

TALLY ITEM C5.21 22

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-F

ITEM: C5.31

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
GBB1092-1-E SUR	P-SWOL	ISI-GBB-109-2		RHR A	492042	03/30/92	Y	NRI

TALLY ITEM C5.31 1
TALLY CDECAT C-F 33

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-F*

ITEM: C5.11

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
GBB1014-8-A SUR	P-FL	ISI-GBB-101-4		CS B	512007	04/11/92	Y	NRI
HBB1042-4-B SUR	E-FL	ISI-HBB-104-2		CS B	512008	04/12/92	Y	NRI
HBB1042-5F-C SUR	P-E	ISI-HBB-104-2		CS B	512009	04/12/92	Y	NRI
HBB1091-2A-D SUR	E-P	ISI-HBB-109-1		HPCI	522009	03/26/92	Y	NRI
VBB1011-1-A SUR	FL-E	ISI-VBB-101-1		HPCI	522010	03/12/92	Y	NRI

TALLY ITEM C5.11 5



SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-F*

ITEM: C5.21

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP ---	NCR NO -----			RESOLUTION -----
DBB1201-3-D VOL	P-E	ISI-DBB-120-1	P-40	HPCI	522023	03/16/92	Y	NRI
DBB1201-3-D SUR	P-E	ISI-DBB-120-1		HPCI	522024	03/13/92	Y	NRI
EBB1021-FW-2 VOL	E-P	ISI-EBB-102-1	P-39	HPCI	522012	03/20/92	Y	NRI
EBB1021-FW-2 SUR	E-P	ISI-EBB-102-1		HPCI	522011	03/16/92	Y	NRI
EBB1021-FW-4 VOL	P-FL	ISI-EBB-102-1	P-39	HPCI	522013	04/16/92	Y	POROSITY ACCPT
EBB1021-FW-4 SUR	P-FL	ISI-EBB-102-1		HPCI	522014	03/12/92	Y	NRI

TALLY ITEM C5.21 6

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-F*

ITEM: C5.22

CID ----	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
DBB1191-2A-F VOL	TEE SEAM	ISI-DBB-119-1	P-73	HPCI	522002	04/11/92	Y	NRI
DBB1191-2A-F SUR	TEE SEAM	ISI-DBB-119-1		HPCI	522015	04/12/92	Y	NRI

TALLY ITEM C5.22 2
TALLY CDECAT C-F* 13

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: C-G ITEM: C6.10

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
1P206A-361-4-6 SUR	E-FL	ISI-C198635		CS A	512010	03/07/92	Y	NRI
1P202A-361-13-L SUR	SEAM	C-198634/RHR PUMP		RHR A	492066	04/02/92	Y	REL REQUEST
TALLY ITEM C6.10	2							
TALLY CDECAT C-G	2							

:

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: D-B

ITEM: D2.20

CID ---	DESC ---	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
HRC0093-H021IA VT-3	H21/5 INT ATT	ISI-HRC-9-3-H		ESW A	542001	03/30/92	Y	NRI
HRC1011-H001IA VT-3	H1/5 INT ATT	ISI-HRC-101-1-H		ESW B	542002	04/03/92	Y	NRI
HRC1012-H20-IA VT-3	PLT/H20-5	ISI-HRC-101-2-H		ESW B	542003	04/05/92	Y	NRI
HRC1101-H4-IA VT-3	LUG/H4-1	ISI-HRC-110-1-H		ESW B	542004	04/05/92	Y	NRI
HRC3302-H1-IA VT-3	LUG/H1-4	ISI-HRC-3302-H		ESW C	542005	04/11/92	Y	NRI

TALLY ITEM D2.20 5

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: D-B

ITEM: D2.40

CID ----	DESC ----	ISI ISO ----	CAL BLOCK -----	SYSTEM -----	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP ----	NCR NO -----			RESOLUTION -----
GBC10109-H320IA VT-3	H320/1 INT ATT	ISI-GBC-101-9-H		MS	832041	04/16/92	Y	NRI
GBC10111-H166IA VT-3	H166/1 INT ATT	ISI-GBC-101-11-H		MS	832072	04/16/92	Y	NRI
GBC10111-H173IA VT-3	H173/8INT ATT	ISI-GBC-101-11-H		MS	832069	03/20/92	Y	NRI
GBC10115-H119IA VT-3	H119/8 INT ATT	ISI-GBC-101-15-H		MS	832070	04/16/92	Y	NRI

TALLY ITEM D2.40 4

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: D-B

ITEM: D3.30

CID	DESC	ISI ISO	CAL BLOCK	SYSTEM	EXAM NO	ANII SIGN-OFF	PROGRAM CREDIT	INDICATION
EXAM TYPE				LOOP	NCR NO			RESOLUTION
GBC10114-H221IA VT-3	H221/8 INT ATT	ISI-GBC-101-14-H		MS	832071	04/24/92	Y	NRI

TALLY ITEM D3.30 1
TALLY CDECAT D-B 10

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: F-PMP

ITEM: F-HIP

CID ----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM -----	EXAM NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
1P-204(MAIN) VT-3	ANCHOR BOLTS	ISI-EBB-102-1		HPCI	522016	03/16/92	Y	NRI
1P-209(800ST) VT-3	ANCHOR BOLTS	ISI-HBB-107-1		HPCI	522017	04/12/92	Y	NRI

TALLY ITEM F-HIP 2

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: F-PMP ITEM: F-RCP

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
RWS1002-H45 VT-3	RIGID SUP	ISI-VRR-B31-2-H		RR B	642062	04/01/92	Y	NRI

TALLY ITEM F-RCP 1

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: F-PMP ITEM: F-RHP

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
1P-202A VT-3	ANCHOR BOLTS	ISI-HBB-110-1		RHR A	492043	03/20/92	Y	NRI

TALLY ITEM F-RHP 1
 TALLY CDECAT F-PMP 4

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: F-TRB

ITEM: F-HIT

CID ---	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
1S-211 VT-3	ANCHOR BOLTS	ISI-HBB-114-1		HPCI	522018	03/16/92	Y	NRI

TALLY ITEM F-HIT 1

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: F-TRB

ITEM: F-RIT

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
1S-212 VT-3	ANCHOR BOLTS	ISI-HBB-101-2		RCIC	502012	03/16/92	Y	NRI

TALLY ITEM F-RIT 1
TALLY CDECAT F-TRB 2

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: F-VSL ITEM: F-RPV

CID ----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
1S-401 VT-3	SKIRT	ISI-C-205755		RPV-E	622091	04/27/92	Y	NRI

TALLY ITEM F-RPV 1
 TALLY CDECAT F-VSL 1

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: NCHOR

ITEM: F-ANCH

CID --- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
HBB1041-H-X206A VT-3	ANCHOR	ISI-HBB-104-1-H		CS A	512011	03/07/92	Y	NRI
HRC0093-H21 VT-3	ANCHOR	ISI-HRC-9-3-H		ESW A	542006	03/30/92	Y	NRI
HRC1011-H1 VT-3	ANCHOR	ISI-HRC-101-1-H		ESW B	542007	04/03/92	Y	NRI
HRC1101-H04 VT-3	ANCHOR	ISI-HRC-110-1-H		ESW B	542008	04/05/92	Y	NRI
HBB1082-H-X210 VT-3	ANCHOR	ISI-HBB-108-2-H		HPCI	522019	03/12/92	Y	NRI
HBB1091-H10 VT-3	ANCHOR	ISI-HBB-109-1-H		HPCI	522020	04/12/92	Y	NRI
GBC10111-HX400L VT-3	ANCHOR	ISI-GBC-101-11-H		MS	832042	03/20/92	Y	NRI
GBC1016-H-X400F VT-3	ANCHOR	ISI-GBC-101-6-H		MS	832043	03/20/92	Y	NRI
VNBB212-H-X7A VT-3	FH-PEN	ISI-VNB-B21-2-H		MS	832044	03/20/92	Y	NRI
DBB1212-H14 VT-3	ANCHOR	ISI-DBB-121-2-H		RCIC	502013	03/13/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
 LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: NCHOR

ITEM: F-ANCH

CID ----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM -----	EXAM NO ----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
HBB1011-H-X215 VT-3	ANCHOR	ISI-HBB-101-1-H		RCIC	502014	03/13/92	Y	NRI
GBB1062-H16 VT-3	ANCHOR	ISI-GBB-106-2-H		RHR B	492044	03/12/92	Y	NRI
GBB1092-H8 VT-3	ANCHOR	ISI-GBB-109-2-H		RHR A	492045	03/12/92	Y	NRI
HBB1104-H-X203D VT-3	ANCHOR	ISI-HBB-110-4-H		RHR B	492046	03/30/92	Y	NRI

TALLY ITEM F-ANCH 14
 TALLY CDECAT NCHOR 14

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: RIGID

ITEM: F-RIGD

CID --- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
VBB1021-H11 VT-3	RIG SUP	ISI-VBB-102-1-H		CRD	552001	03/20/92	Y	NRI
GBB1012-H26 VT-3	GUIDE	ISI-GBB-101-2-H		CS A	512012	03/07/92	Y	NRI
GBB1014-H4 VT-3	RIG HANG	ISI-GBB-101-4-H		CS B	512013	04/12/92	Y	NRI
GBB1032-H10 VT-3	SWAY ST	ISI-GBB-103-2-H		CS A	512014	03/12/92	Y	NRI
HRC0031-H44 VT-3	RIG SUP	ISI-HRC-3-1-H		ESW A	542009	04/28/92	Y	NRI
HRC0033-H01 VT-3	GUIDE	ISI-HRC-3-3-H		ESW A	542010	03/30/92	Y	NRI
HRC0072-H13 VT-3	RIG HANG	ISI-HRC-7-2-H		ESW B	542011	04/05/92	Y	NRI
HRC0093-H26 VT-3	GUIDE	ISI-HRC-9-3-H		ESW B	542012	04/28/92	Y	NRI
HRC0113-H08 VT-3	RIG SUP	ISI-HRC-11-3-H		ESW A	542013	03/30/92	Y	NRI
HRC1011-H02 VT-3	RIG HANG	ISI-HRC-101-1-H		ESW B	542014	04/05/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: RIGID ITEM: F-RIGD

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ----	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
HRC1052-H18 VT-3	RIG SUP	ISI-HRC-105-2-H		ESW A	542015	04/05/92	Y	NRI
HRC1081-H01 VT-3	RIG SUP	ISI-HRC-108-1-H		ESW A	542016	03/26/92	Y	NRI
HRC1101-H02 VT-3	RIG SUP	ISI-HRC-110-1-H		ESW B	542017	04/12/92	Y	NRI
HRC3300-H2 VT-3	SWAY ST	ISI-HRC-3300-H		ESW A	542020	05/08/92	Y	VISUAL ACCP
HRC3302-H1 VT-3	RIG SUP	ISI-HRC-3302-H		ESW C	542021	04/11/92	Y	NRI
HCC1031-H34 VT-3	SWAY ST	ISI-HCC-103-1-H		FPC	542019	03/07/92	Y	NRI
DBB1041-H19 VT-3	WHIP RESTRAINT	ISI-DBB-104-1-H		MS	832045	03/16/92	Y	NRI
DBB1041-H8 VT-3	SWAY ST	ISI-DBB-104-1-H		MS	092-92 92-130	05/20/92	Y	VISUAL REWORK
GBC10104-H258 VT-3	SWAY ST	ISI-GBC-101-4-H		MS	832046	04/11/92	Y	NRI
GBC10109-H251 VT-3	SWAY ST	ISI-GBC-101-9-H		MS	832047	04/11/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: RIGID ITEM: F-RIGD

CID --- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
GBC10111-H174 VT-3	SWAY ST	ISI-GBC-101-11-H		MS	832048	03/20/92	Y	NRI
DBB1211-H4 VT-3	SWAY ST	ISI-DBB-121-1-H		RCIC	502015	03/16/92	Y	NRI
HBB1012-H6 VT-3	RIG HANG	ISI-HBB-101-2-H		RCIC	502016	03/13/92	Y	NRI
GBB1092-H6 VT-3	SWAY ST	ISI-GBB-109-2-H		RHR A	492047	03/12/92	Y	NRI
GBB1131-H1 VT-3	SWAY ST	ISI-GBB-113-1-H		RHR A	492048	3/12/920	Y	NRI
HRC00253-H14 VT-3	RIG SUP	ISI-HRC-2-53-H		RHR B	162001	04/12/92	Y	NRI
HRC1123-H18 VT-3	RIG SUP	ISI-HRC-112-3-H		RHR A	162002	03/20/92	Y	NRI

TALLY ITEM F-RIGD 27
TALLY CDECAT RIGID 27

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: SNUB

ITEM: F-VT34

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
GBB1011-H33 VT-3	SNUBMECH	ISI-GBB-101-1-H		CS A	512015	03/07/92	Y	NRI
GBB1011-H33 VT-4	SNUBMECH	ISI-GBB-101-1-H		CS A	512015	03/07/92	Y	NRI
HRC1051-H13 VT-3	SNUBMECH	ISI-HRC-105-1-H		ESW A	542018 92-088	04/24/92	Y	VISUAL ACCP
HRC1051-H13 VT-4	SNUBMECH	ISI-HRC-105-1-H		ESW A	542018	04/24/92	Y	NRI
DBB1202-H2 VT-3	SNUBMECH	ISI-DBB-120-2-H		HPCI	522021	03/12/92	Y	NRI
DBB1202-H2 VT-4	SNUBMECH	ISI-DBB-120-2-H		HPCI	522021	03/12/92	Y	NRI
DBB1041-H15 VT-3	SNUBMECH	ISI-DBB-104-1-H		MS	832049	05/20/92	Y	NRI
DBB1041-H15 VT-4	SNUBMECH	ISI-DBB-104-1-H		MS	832049 92-055	05/20/92	Y	VISUAL ACCP
DBB1041-H16 VT-3	SNUBMECH	ISI-DBB-104-1-H		MS	832050	03/22/92	Y	NRI
DBB1041-H16 VT-4	SNUBMECH	ISI-DBB-104-1-H		MS	832050	03/22/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: SNUB

ITEM: F-VT34

CID ---	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM -----	EXAM NO ---	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION -----
EXAM TYPE -----				LOOP -----	NCR NO -----			RESOLUTION -----
DBB1051-H2 VT-3	SNUBMECH	ISI-DBB-105-1-H		MS	832051 92-048	05/20/92	Y	VISUAL REWORK
DBB1051-H2 VT-4	SNUBMECH	ISI-DBB-105-1-H		MS	832051	05/20/92	Y	NRI
GBC10103-H272 VT-3	SNUBMECH	ISI-GBC-101-3-H		MS	832052	04/16/92	Y	NRI
GBC10103-H272 VT-4	SNUBMECH	ISI-GBC-101-3-H		MS	832052	04/16/92	Y	NRI
GBC10104-H281 VT-3	SNUBMECH	ISI-GBC-101-4-H		MS	832053 92-108	05/06/92	Y	VISUAL REWORK
GBC10104-H281 VT-4	SNUBMECH	ISI-GBC-101-4-H		MS	832053	05/06/92	Y	NRI
GBC10105-H231 VT-3	SNUBMECH	ISI-GBC-101-5-H		MS	832054	04/11/92	Y	NRI
GBC10105-H231 VT-4	SNUBMECH	ISI-GBC-101-5-H		MS	832054	04/11/92	Y	NRI
GBC10108-H247 VT-3	SNUBMECH	ISI-GBC-101-8-H		MS	832055	04/16/92	Y	NRI
GBC10108-H247 VT-4	SNUBMECH	ISI-GBC-101-8-H		MS	832055	04/16/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: SNUB

ITEM: F-VT34

<u>CID</u> ----- EXAM TYPE	<u>DESC</u> -----	<u>ISI</u> <u>ISO</u> ----	<u>CAL</u> <u>BLOCK</u> -----	<u>SYSTEM</u> ----- LOOP	<u>EXAM</u> <u>NO</u> ----- NCR NO	<u>ANII</u> <u>SIGN-OFF</u> -----	<u>PROGRAM</u> <u>CREDIT</u> -----	<u>INDICATION</u> ----- RESOLUTION
GBC10109-H255 VT-3	SNUBMECH	ISI-GBC-101-9-H		MS	832056	03/20/92	Y	NRI
GBC10109-H255 VT-4	SNUBMECH	ISI-GBC-101-9-H		MS	832056	03/20/92	Y	NRI
GBC10109-H276 VT-3	SNUBMECH	ISI-GBC-101-9-H		MS	832057	04/16/92	Y	NRI
GBC10109-H276 VT-4	SNUBMECH	ISI-GBC-101-9-H		MS	832057	04/16/92	Y	NRI
GBC10111-H165 VT-3	SNUBMECH	ISI-GBC-101-11-H		MS	832058	03/20/92	Y	NRI
GBC10111-H165 VT-4	SNUBMECH	ISI-GBC-101-11-H		MS	832058	03/20/92	Y	NRI
MST0221-H36 VT-3	SNUBMECH	ISI-VNB-B21-1-H		MS	832059	03/30/92	Y	NRI
MST0221-H36 VT-4	SNUBMECH	ISI-VNB-B21-1-H		MS	832059	03/30/92	Y	NRI
MST0221-H50 VT-3	SNUBMECH	ISI-VNB-B21-1-H		MS	832060	04/11/92	Y	NRI
MST0221-H50 VT-4	SNUBMECH	ISI-VNB-B21-1-H		MS	832060	04/11/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: SNUB

ITEM: F-VT34

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
DCA1112-H14 VT-3	SNUBMECH	ISI-DCA-111-2-H		RHR A	492049 92-073	05/20/92	Y	VISUAL REWORK
DCA1112-H14 VT-4	SNUBMECH	ISI-DCA-111-2-H		RHR A	492049	05/20/92	Y	NRI
GBB1041-H8 VT-3	SNUBMECH	ISI-GBB-104-1-H		RHR A	492068	03/12/92	Y	NRI
GBB1041-H8 VT-4	SNUBMECH	ISI-GBB-104-1-H		RHR A	492068	03/12/92	Y	NRI
GBB1062-H26 VT-3	SNUBMECH	ISI-GBB-106-2-H		RHR B	492050	03/07/92	Y	NRI
GBB1062-H26 VT-4	SNUBMECH	ISI-GBB-106-2-H		RHR B	492050	03/07/92	Y	NRI
GBB1072-H40 VT-3	SNUBMECH	ISI-GBB-107-2-H		RHR B	492051	03/30/92	Y	NRI
GBB1072-H40 VT-4	SNUBMECH	ISI-GBB-107-2-H		RHR B	492051	03/30/92	Y	NRI
GBB1091-H29 VT-3	SNUBMECH	ISI-GBB-109-1-H		RHR B	492052	03/07/92	Y	NRI
GBB1091-H29 VT-4	SNUBMECH	ISI-GBB-109-1-H		RHR B	492052	03/07/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: SNUB

ITEM: F-VT34

CID --- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
GBB1092-H25 VT-3	SNUBMECH	ISI-GBB-109-2-H		RHR A	492053	03/12/92	Y	NRI
GBB1092-H25 VT-4	SNUBMECH	ISI-GBB-109-2-H		RHR A	492053	03/12/92	Y	NRI
HBB1101-H3 VT-3	SNUBMECH	ISI-HBB-110-1-H		RHR A	492054	04/02/92	Y	NRI
HBB1101-H3 VT-4	SNUBMECH	ISI-HBB-110-1-H		RHR A	492054	04/02/92	Y	NRI
HBB1104-H35 VT-3	SNUBMECH	ISI-HBB-110-4-H		RHR B	492055	04/02/92	Y	NRI
HBB1104-H35 VT-4	SNUBMECH	ISI-HBB-110-4-H		RHR B	492055	04/02/92	Y	NRI
RWS1001-H12 VT-3	SNUBMECH	ISI-VRR-B31-1-H		RR A	642063	03/30/92	Y	NRI
RWS1001-H12 VT-4	SNUBMECH	ISI-VRR-B31-1-H		RR A	642063	03/30/92	Y	NRI
RWS1001-H30 VT-3	SNUBMECH	ISI-VRR-B31-1-H		RR A	642064	03/30/92	Y	NRI
RWS1001-H30 VT-4	SNUBMECH	ISI-VRR-B31-1-H		RR A	642064	03/30/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: SNUB

ITEM: F-VT34

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
RWS1001-H40 VT-3	SNUBMECH	ISI-VRR-B31-1-H		RR A	642065	03/30/92	Y	NRI
RWS1001-H40 VT-4	SNUBMECH	ISI-VRR-B31-1-H		RR A	642065	03/30/92	Y	NRI
RWS1002-H26 VT-3	SNUBMECH	ISI-VRR-B31-2-H		RR B	642066 92-096	04/24/92	Y	VISUAL ACCPT
RWS1002-H26 VT-4	SNUBMECH	ISI-VRR-B31-2-H		RR B	642066	04/24/92	Y	NRI
RWS1002-H32 VT-3	SNUBMECH	ISI-VRR-B31-2-H		RR B	642067	04/01/92	Y	NRI
RWS1002-H32 VT-4	SNUBMECH	ISI-VRR-B31-2-H		RR B	642067	04/01/92	Y	NRI

TALLY ITEM F-VT34 56
TALLY CDECAT SNUB 56

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: SPRNG

ITEM: F-SPR

CID ---- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
DBB1131-H2 VT-3	SPRST	ISI-DBB-113-1-H		CS A	512016 92-033	04/24/92	Y	VISUAL ACCP
DBB1131-H2 VT-4	SPRST	ISI-DBB-113-1-H		CS A	512016 92-033	04/24/92	Y	VISUAL ACCP
HBB1041-H4 VT-3	SPRST	ISI-HBB-104-1-H		CS A	512017	03/07/92	Y	NRI
HBB1041-H4 VT-4	SPRST	ISI-HBB-104-1-H		CS A	512017	03/07/92	Y	NRI
DLA1042-H2 VT-3	VAR SUP	ISI-DLA-104-2-H		FW B	452017	03/20/92	Y	NRI
DLA1042-H2 VT-4	VAR SUP	ISI-DLA-104-2-H		FW B	452017	03/20/92	Y	NRI
DBB1141-H1 VT-3	SPRST	ISI-DBB-114-1-H		HPCI	522022	05/06/92	Y	NRI
DBB1141-H1 VT-4	SPRST	ISI-DBB-114-1-H		HPCI	522022 92-056	05/06/92	Y	VISUAL ACCP
DBB1051-H3 VT-3	VAR SUP	ISI-DBB-105-1-H		MS	832061	05/20/92	Y	NRI
DBB1051-H3 VT-4	VAR SUP	ISI-DBB-105-1-H		MS	832061 92-047	05/20/92	Y	VISUAL REWORK

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: SPRNG

ITEM: F-SPR

CID ---- EXAM TYPE	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
GBC10103-H319 VT-3	VAR SUP	ISI-GBC-101-3-H		MS	832063	05/08/92	Y	NRI
GBC10103-H319 VT-4	VAR SUP	ISI-GBC-101-3-H		MS	832063 92-120	05/08/92	Y	VISUAL ACCP
GBC10103-H44 VT-3	SPRST	ISI-GBC-101-3-H		MS	92-131	04/23/92	Y	NRI
GBC10103-H44 VT-4	SPRST	ISI-GBC-101-3-H		MS	92-131	04/23/92	Y	NRI
GBC10107-H38 VT-3	SPRST	ISI-GBC-101-7-H		MS	832064	03/20/92	Y	NRI
GBC10107-H38 VT-4	SPRST	ISI-GBC-101-7-H		MS	832064	03/20/92	Y	NRI
GBC10109-H320 VT-3	VAR SUP	ISI-GBC-101-9-H		MS	832065	04/24/92	Y	NRI
GBC10109-H320 VT-4	VAR SUP	ISI-GBC-101-9-H		MS	832065	04/24/92	Y	NRI
MST0221-H10 VT-3	VAR SUP	ISI-VNB-B21-1-H		MS	832066	04/16/92	Y	NRI
MST0221-H10 VT-4	VAR SUP	ISI-VNB-B21-1-H		MS	832066	04/16/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: SPRNG

ITEM: F-SPR

CID ----- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP -----	EXAM NO ----- NCR NO -----	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
MST0221-H6 VT-3	VAR SUP	ISI-VNB-B21-1-H		MS	832067 92-123	05/06/92	Y	VISUAL REWORK
MST0221-H6 VT-4	VAR SUP	ISI-VNB-B21-1-H		MS	832067 92-123	05/06/92	Y	VISUAL REWORK
DCA1111-H2 VT-3	SPRST	ISI-DCA-111-1-H		RHR A	492056	05/06/92	Y	NRI
DCA1111-H2 VT-4	SPRST	ISI-DCA-111-1-H		RHR A	492056 92-075	05/06/92	Y	VISUAL ACCP
DCA1112-H7 VT-3	CONST SUP	ISI-DCA-111-2-H		RHR A	492057	03/30/92	Y	NRI
DCA1112-H7 VT-4	CONST SUP	ISI-DCA-111-2-H		RHR A	492057	03/30/92	Y	NRI
GBB1042-H1 VT-3	SPRST	ISI-GBB-104-2-H		RHR A	492058	05/06/92	Y	NRI
GBB1042-H1 VT-4	SPRST	ISI-GBB-104-2-H		RHR A	492058 92-057	05/06/92	Y	VISUAL ACCP
GBB1062-H20 VT-3	VAR SUP	ISI-GBB-106-2-H		RHR B	492059	03/07/92	Y	NRI
GBB1062-H20 VT-4	VAR SUP	ISI-GBB-106-2-H		RHR B	492059	03/07/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: SPRNG

ITEM: F-SPR

CID ---	DESC ----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION
GBB1072-H14 VT-3	VAR SUP	ISI-GBB-107-2-H		RHR B	492060	04/02/92	Y	NRI
GBB1072-H14 VT-4	VAR SUP	ISI-GBB-107-2-H		RHR B	492060	04/02/92	Y	NRI
GBB1091-H16 VT-3	VAR SUP	ISI-GBB-109-1-H		RHR B	492061	03/07/92	Y	NRI
GBB1091-H16 VT-4	VAR SUP	ISI-GBB-109-1-H		RHR B	492061	03/07/92	Y	NRI
GBB1092-H3 VT-3	SPRST	ISI-GBB-109-2-H		RHR A	492062	04/24/92	Y	NRI
GBB1092-H3 VT-4	SPRST	ISI-GBB-109-2-H		RHR A	492062 92-036	04/24/92	Y	VISUAL REWORK
HBB1101-H5 VT-3	VAR SUP	ISI-HBB-110-1-H		RHR A	492063	04/16/92	Y	NRI
HBB1101-H5 VT-4	VAR SUP	ISI-HBB-110-1-H		RHR A	492063	04/16/92	Y	NRI
HBB1103-H24 VT-3	VAR SUP	ISI-HBB-110-3-H		RHR A	492021	04/16/92	Y	NRI
HBB1103-H24 VT-4	VAR SUP	ISI-HBB-110-3-H		RHR A	492021	04/16/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: SPRNG

ITEM: F-SPR

CID --- EXAM TYPE -----	DESC -----	ISI ISO ---	CAL BLOCK -----	SYSTEM ----- LOOP	EXAM NO ----- NCR NO	ANII SIGN-OFF -----	PROGRAM CREDIT -----	INDICATION ----- RESOLUTION -----
HRC1123-H17 VT-3	VAR SUP	ISI-HRC-112-3-H		RHRSW A	162003	03/20/92	Y	NRI
HRC1123-H17 VT-4	VAR SUP	ISI-HRC-112-3-H		RHRSW A	162003	03/20/92	Y	NRI
RWS1001-HA6 VT-3	CONST SUP	ISI-VRR-B31-1-H		RR A	642068 92-074	05/08/92	Y	VISUAL REWORK
RWS1001-HA6 VT-4	CONST SUP	ISI-VRR-B31-1-H		RR A	642068	05/08/92	Y	NRI
RWS1002-HB4 VT-3	VAR SUP	ISI-VRR-B31-2-H		RR B	642069	04/01/92	Y	NRI
RWS1002-HB4 VT-4	VAR SUP	ISI-VRR-B31-2-H		RR B	642069	04/01/92	Y	NRI
DBA1012-H18 VT-3	VAR SUP	ISI-DBA-101-2-H		RWCU	612018	04/03/92	Y	NRI
DBA1012-H18 VT-4	VAR SUP	ISI-DBA-101-2-H		RWCU	612018	04/03/92	Y	NRI
SPDCA1022-H21 VT-3	CONST SUP	ISI-SP-DCA-102-2-H		RWCU	612019	04/05/92	Y	NRI
SPDCA1022-H21 VT-4	CONST SUP	ISI-SP-DCA-102-2-H		RWCU	612019	04/05/92	Y	NRI

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
LIST OF EXAMS - SIXTH REFUELING OUTAGE

OUTAGE SUMMARY REPORT - SORTED BY CODE CATEGORY AND ITEM - - AS OF: 07/24/92

CODE CATEGORY: SPRNG

ITEM: F-SPR

CID	DESC	ISI ISO	CAL BLOCK	SYSTEM	EXAM NO	ANII SIGN-OFF	PROGRAM CREDIT	INDICATION
EXAM TYPE				LOOP	NCR NO			RESOLUTION
SPDCA1064-H24 VT-3	VAR SUP	ISI-SP-DCA-106-4-H		SBLC	532004	04/02/92	Y	NRI
SPDCA1064-H24 VT-4	VAR SUP	ISI-SP-DCA-106-4-H		SBLC	532004	04/02/92	Y	NRI

TALLY ITEM F-SPR 52
TALLY CDECAT SPRNG 52

TOTAL: 889

***SNUBBER FUNCTIONAL TESTING
LISTING***

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBA 101H 8 RWCU SUCT.INSIDE CONT.	03577	3	C	92-085	03/26/92	919	PASS	C/S AF 3.5 AR 2 3/4	04/01/92
DBA 101H 9 RWCU SUCT.INSIDE CONT.	03594	3	C		03/26/92 PP 3'-10 1/2"	1124	PASS	C/S AF 1 AR 1	04/01/92
DBA 101H 10 RWCU SUCT.INSIDE CONT.	03570	3	C		03/26/92 PP 4'-7 3/8"	1055	PASS	C/S AF 2.75 AR 2.75	04/01/92
DBA 101H 15 RWCU SUCT.INSIDE CONT.	19514	3	C		03/26/92 PP 4'-7 1/2"	1	PASS	C/S AF 2 1/2 AR 2 1/2	04/01/92
DBA 101H 19 RWCU SUCT.INSIDE CONT.	04583	3	C		03/25/92	2205	PASS	C/S AF 3 AR 3	03/30/92
DBA 101H 20 RWCU SUCT.INSIDE CONT.	19392	3	C	92-085	03/25/92	2133	PASS	C/S AF 2 1/2 AR 2 1/2	03/30/92
DBA 101H 21 RWCU SUCT.INSIDE CONT.	04571	3	C		03/25/92	2332	PASS	C/S AF 2 AR 2	03/30/92
DBA 101H 35 RWCU SUCT.INSIDE CONT.	04144	3			X PP 3'-4 1/4"	0			X
DBA 101H 36 RWCU SUCT.INSIDE CONT.	05254	3			X PP 2'-10 1/2"	0			X
DBA 101H 40 RWCU SUCT.INSIDE CONT.	00108	.05	S		03/28/92 PP 2'-11"	819	PASS	C/S AF 3 15/16 AR 3 15/16	04/01/92
DBA 101H 46 RWCU SUCT.INSIDE CONT.	20788	1			03/13/92 PP 5'-1 7/8"	922	PASS	C/S AF 2" AR 2"	05/09/92
DBA 101H 47A RWCU SUCT.INSIDE CONT.	00318	3L			X PP 3'-8 3/8"	0			X
DBA 101H 47B RWCU SUCT.INSIDE CONT.	00317	3L			X PP 3'-8 1/2"	0			X

LEGEND

X OR V = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBA 102H 6 HPCI STM SUPPLY INSIDE	00101	.12			X PP 5'-2"	0			X
DBA 102H 7 HPCI STM SUPPLY INSIDE	00102	.12			X PP 3'-6 1/2"	0			X
DBA 102H 8 HPCI STM SUPPLY INSIDE	02760	35			04/16/92 1029 CLMP RMVD,P/P6'-7" C/S AF 1 1/2 AR 1 1/2	PASS			Z
DBA 102H 9 HPCI STM SUPPLY INSIDE	04115	35			04/06/92 1519 CLMP RMVD,P/P-4'6" C/S AF 3 1/4 AR 3 1/4	PASS			Z
DBA 102H 10 HPCI STM SUPPLY INSIDE	01361	35			X PP 6'-9 1/2"	0			X
DBA 102H 11 HPCI STM SUPPLY INSIDE	02561	35	S		03/26/92 2100 CLAMP REMOVED,P/P-4'0"	PASS	C/S AF 3 AR 3		Z
DBA 102H 12 HPCI STM SUPPLY INSIDE	03234	35			X	0			X
DBA 102H 13 HPCI STM SUPPLY INSIDE	04106	35			04/10/92 825 CLAMP REMOVED	PASS	C/S AF 1 3/4 AR 1 3/4		Z
DBA 105H 4A RCIC STM SUPPLY INSIDE	02815	10			X	0			X
DBA 105H 4B RCIC STM SUPPLY INSIDE	12267	10			X	0			X
DBA 105H 6A RCIC STM SUPPLY INSIDE	06827	3			X	0			X
DBA 105H 6B RCIC STM SUPPLY INSIDE	06826	3			X	0			X
DBA 105H 7 RCIC STM SUPPLY INSIDE	03180	10			X PP 3'-2 1/4"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBA 105H 8 RCIC STM SUPPLY INSIDE	04616	10	F		03/24/92 P/P-4'11"	1346	PASS C/S AF 2 1/2 AR 2 1/2		Z
DBA 105H 9 RCIC STM SUPPLY INSIDE	14775	10	S		03/24/92 P/P-3'2"	1442	PASS C/S AF 4 1/4 AR 4 1/4		Z
DBA 105H 10 RCIC STM SUPPLY INSIDE	02160	10			03/24/92 P/P-3'0"	1452	PASS C/S AF 2 1/2 AR 2 1/2		Z
DBA 105H 11 RCIC STM SUPPLY INSIDE	14430	10			X	0			X
DBA 105H 13 RCIC STM SUPPLY INSIDE	14428	10	S		03/25/92	849	PASS C/S AF 3 AR 3		04/01/92
DBA 105H 16 RCIC STM SUPPLY INSIDE	00105	.05			X PP 2'-11 3/4"	0			X
DBA 105H 17 RCIC STM SUPPLY INSIDE	00106	.05			X PP 3'-3 1/2"	0			X
DBA 108H 1 MAIN STM LINE DRNS INSIDE CONT	06573	3			03/25/92	1124	PASS CHANG/STRUT,P/P-3'6"C/S AF 3 5/8 AR3 5/8		Z
DBA 108H 2 MAIN STM LINE DRNS INSIDE CONT	06571	3			X	0			X
DBA 108H 3 MAIN STM LINE DRNS INSIDE CONT	06574	3	S		03/23/92	1550	PASS CHNGTOSTRT,P/P-3'6"C/S AF 2 1/4 AR 2 1/4		Z
DBA 108H 5 MAIN STM LINE DRNS INSIDE CONT	19565	3			X	0			X
DBA 108H 6 MAIN STM LINE DRNS INSIDE CONT	06584	3	S		03/23/92	1648	PASS CHANGED TO STRUT C/S AF 2 1/2" AR 2 1/2"		Z
DBA 108H 8 MAIN STM LINE DRNS INSIDE CONT	04282	10	S		03/24/92	1405	PASS CHNG TO STRT P/P-3'0" C/S AF 2 AR 1 1/2		Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBA 108H 9	04277	10		92-085	03/24/92	1621	PASS		Z
MAIN STM LINE DRNS INSIDE CONT					CHNG TO STRT,P/P-4'11"			C/S AF 2 1/2 AR 1	
DBA 108H 10	04606	3	F		03/25/92	1019	PASS		Z
MAIN STM LINE DRNS INSIDE CONT								C/S AF 3 AR 3	
DBA 108H 12	06588	3	S		03/23/92	1422	PASS		Z
MAIN STM LINE DRNS INSIDE CONT					P/P-4'0"			C/S AF 2 3/4" AR 2 3/4"	
DBA 108H 15	06796	3			03/25/92	924	PASS		Z
MAIN STM LINE DRNS INSIDE CONT								C/S AF 3 AR 3	
DBA 108H 17	06801	3			X	0			X
MAIN STM LINE DRNS INSIDE CONT					PP 3'-10 3/4"				
DBA 108H 19	03483	3			04/02/92	1357	PASS		Z
MAIN STM LINE DRNS INSIDE CONT					CHANGED TO STRUT			C/S AF 2.5 AR 2.5	
DBA 108H 20	14181	10			X	0			X
MAIN STM LINE DRNS INSIDE CONT									
DBA 108H 21	23020	1/4			03/20/92	22	PASS		Z
MAIN STM LINE DRNS INSIDE CONT								C/S AF 2 1/2 AR 2 1/2	
DBB 101H 3	01366	35			X	0			X
MAIN STEAM OUTSIDE CONT					PP 3'-11"				
DBB 101H 5A	00372	10			X	0			X
MAIN STEAM OUTSIDE CONT					PP 4'-7 1/2"				
DBB 101H 5B	00373	10			X	0			X
MAIN STEAM OUTSIDE CONT					PP 4'-7 1/2"				
DBB 101H 8A	00588	35			X	0			X
MAIN STEAM OUTSIDE CONT									
DBB 101H 8B	07406	35			X	0			X
MAIN STEAM OUTSIDE CONT									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBB 101H 10A MAIN STEAM OUTSIDE CONT	00670	100	F	92-045	03/14/92 PP 5'-10 3/4"	819	DEGRADE	00670 C/S AF 3.5 AR 3.5	03/20/92
DBB 101H 10B MAIN STEAM OUTSIDE CONT	02026	100	S	92-071 92-045	03/14/92 PP 5'-10 3/4"	859	PASS	C/S AF 4.5 AR 4.5	03/20/92
DBB 101H 12 MAIN STEAM OUTSIDE CONT	08706	10			X	0			X
DBB 101H 13 MAIN STEAM OUTSIDE CONT	02027	100	R	92-054	03/16/92 NCR 92-054	1055	PASS	C/S AF 4 15/16 AR 4 15/16	04/29/92
DBB 102H 4A MAIN STEAM OUTSIDE CONT	14781	10			X	0			X
DBB 102H 4B MAIN STEAM OUTSIDE CONT	14758	10			X	0			X
DBB 102H 7A MAIN STEAM OUTSIDE CONT	00589	35			X	0			X
DBB 102H 7B MAIN STEAM OUTSIDE CONT	00579	35			X	0			X
DBB 102H 9A MAIN STEAM OUTSIDE CONT	00380	10		92-157	X PP 4'-6 3/4"	0		04609-78 INTRNL TORQUE BROKE PER ENG	05/07/92
DBB 102H 9B MAIN STEAM OUTSIDE CONT	00379	10			X PP4'-6 3/4"	0			X
DBB 102H 10 MAIN STEAM OUTSIDE CONT	03088	35			X	0			X
DBB 102H 12A MAIN STEAM OUTSIDE CONT	01529	35		92-150	X PP 6'-9 5/8"	0			X
DBB 102H 12B MAIN STEAM OUTSIDE CONT	01520	35			X PP 6'-10 1/8"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBB 102H 13A	01263	100			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 102H 13B	01265	100			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 102H 15	00378	10			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 102H 17	01646	100	R	92-045	03/14/92	1316	PASS		04/29/92
MAIN STEAM OUTSIDE CONT					PP 6'-1 1/2"		C/S AF 4 3/8 AR 4 3/8		
DBB 103H 4A	00954	10			X		0		X
MAIN STEAM OUTSIDE CONT					PP 4' 7 3/4"				
DBB 103H 4B	14204	10			X		0		X
MAIN STEAM OUTSIDE CONT					PP 4'-7 3/4"				
DBB 103H 7A	00583	35			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 103H 7B	00573	35			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 103H 8A	02861	3			X		0		X
MAIN STEAM OUTSIDE CONT					PP 4'-9 5/8"				
DBB 103H 8B	19582	3			X		0		X
MAIN STEAM OUTSIDE CONT					PP 4'-9 5/8"				
DBB 103H 10A	08628	35			X		0		X
MAIN STEAM OUTSIDE CONT					PP 4'-8 1/4"				
DBB 103H 10B	08635	35			X		0		X
MAIN STEAM OUTSIDE CONT					PP 4'-8 1/4"				
DBB 103H 12A	01266	100			X		0		X
MAIN STEAM OUTSIDE CONT									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBB 103H 12B	01264	100			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 103H 13A	01391	35			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 103H 13B	01394	35			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 103H 15	14772	10			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 104H 3	00321	35L			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 104H 5A	04566	10			X		0		X
MAIN STEAM OUTSIDE CONT					PP 3'-11 1/2"				
DBB 104H 5B	04256	10			X		0		X
MAIN STEAM OUTSIDE CONT					PP 3'-11 5/16"				
DBB 104H 7A	01247	35			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 104H 7B	00590	35			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 104H 9	00392	10			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 104H 10	02504	10			X		0		X
MAIN STEAM OUTSIDE CONT									
DBB 104H 12A	01499	35			X		0		X
MAIN STEAM OUTSIDE CONT.									
DBB 104H 12B	01497	35			X		0		X
MAIN STEAM OUTSIDE CONT.									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBB 104H 13A MAIN STEAM OUTSIDE CONT.	01535	35			X		0		X
DBB 104H 13B MAIN STEAM OUTSIDE CONT.	01532	35			X		0		X
DBB 104H 15 MAIN STEAM OUTSIDE CONT.	00108	3L	F	92-055	03/10/92	1056	PASS	C/S AF 5.5 AR 5.5	03/19/92
DBB 104H 16A MAIN STEAM OUTSIDE CONT.	08291	10			X		0		X
DBB 104H 16B MAIN STEAM OUTSIDE CONT.	14409	10			X		0		X
DBB 104H 18 MAIN STEAM OUTSIDE CONT.	02422	100	F	92-045	03/14/92 PP 6'-2"	1105	PASS	C/S AF 4 5/8 AR 4 5/8	03/19/92
DBB 105H 2 BYPASS STM EFFECTING MN STM	00364	100		92-048	X		0		X
DBB 105H 5 BYPASS STM EFFECTING MN STM	00400	10L			X		0		X
DBB 105H 9 BYPASS STM EFFCTING BYPASS STM	03036	35			X PP 6'-8 1/2"		0		X
DBB 107H 1 DIV I LPCI/SDC RHR	04570	10			X PP 3'-7 3/4"		0		X
DBB 107H 2A DIV I LPCI/SDC RHR	02551	35			X		0		X
DBB 107H 2B DIV I LPCI/SDC RHR	02554	35			X		0		X
DBB 107H 6 DIV I LPCI/SDC RHR	03246	35			X		0		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBB 107H 8A DIV II LPCI/SDC RHR	06025	35			X	0			X
DBB 107H 8B DIV II LPCI/SDC RHR	06027	35			X	0			X
DBB 107H 9A DIV II LPCI/SDC RHR	02600	35			X	0			X
DBB 107H 9B DIV II LPCI/SDC RHR	02596	35			X	0			X
DBB 107H 13 DIV II LPCI/SDC RHR	00367	100			X	0			X
DBB 109H 7 RCIC STM SUPPLY OUTSIDE	17232	1			X	0			X
					PP 2'-10 15/16"				
DBB 109H 12 RCIC STM SUPPLY OUTSIDE	00127	1L			X	0			X
DBB 109H 15 RCIC STM SUPPLY OUTSIDE	00135	1L			X	0			X
DBB 109H 16 RCIC STM SUPPLY OUTSIDE	07330	3			X	0			X
					PP 5'-11 3/16"				
DBB 109H 17 RCIC STM SUPPLY OUTSIDE	07167	3			03/31/92	1448	PASS		04/07/92
							C/S AF 1 1/8 AR 1 1/8		
DBB 109H 18 RCIC STM SUPPLY OUTSIDE	07166	3			03/31/92	1513	PASS		04/07/92
							C/S AF 1 1/8 AR 1 1/8		
DBB 109H 21 RCIC STM SUPPLY OUTSIDE	00139	.05			X	0			X
					PP 3'-3"				
DBB 109H 22 RCIC STM SUPPLY OUTSIDE	00104	.05			X	0			X
					PP 3'-3"				

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBB 109H 24 RCIC STM SUPPLY OUTSIDE	12203	1			X PP 2'-2 1/4"	0			X
DBB 109H 25 RCIC STM SUPPLY OUTSIDE	02805	3			X PP 1'-7 3/8"	0			X
DBB 109H 26A RCIC STM SUPPLY OUTSIDE	28837	1/4			X PP 1'-9 3/4"	0			X
DBB 109H 26B RCIC STM SUPPLY OUTSIDE	28980	1/4			X PP 1'-9 3/4"	0			X
DBB 114H 3 HPCI STM SUPPLY OUTSIDE	02808	35			X PP 6'-4"	0			X
DBB 114H 4 HPCI STM SUPPLY OUTSIDE	02826	10			X	0			X
DBB 114H 10 HPCI STM SUPPLY OUTSIDE	02644	3			X PP 4'-0 1/8"	0			X
DBB 114H 25 HPCI STM SUPPLY OUTSIDE	00104	.12			X PP 3'-7 1/4"	0			X
DBB 114H 26 HPCI STM SUPPLY OUTSIDE	00103	.12			X PP 3'-7 1/4"	0			X
DBB 114H 27 HPCI STM SUPPLY OUTSIDE	00105	.12			X	0			X
DBB 114H 28 HPCI STM SUPPLY OUTSIDE	00107	.05			X	0			X
DBB 114H 29 HPCI STM SUPPLY OUTSIDE	02061	1			X PP 2'-10 1/4"	0			X
DBB 117H 2 HPCI PUMP DSCH	14193	10			X PP 4'-4"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID SYSTEM DESC	SERIAL	SIZE	ORIGIN	NCR NUM NCR NUM	TEST DATE MEMO	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
DBB 117H 5 HPCI PUMP DSCH	08707	10			X		0		X
DBB 117H 8 HPCI PUMP DSCH	08708	10			X		0		X
DBB 120H 2 HPCI PUMP DSCH	03218	35			X		0		X
DBB 120H 3 HPCI PUMP DSCH	13664	10			X PP 5'-7 3/4"		0		X
DBB 120H 8 HPCI PUMP DSCH	04358	10			X		0		X
DBB 120H 17A HPCI PUMP DSCH	02825	3			X PP 2'-7 1/4"		0		X
DBB 120H 17B HPCI PUMP DSCH	02824	3			X PP 2'-7 1/4"		0		X
DBB 120H 18 HPCI PUMP DSCH	08292	10			X		0		X
DBB 120H 19 HPCI PUMP DSCH	03475	10			X PP 3'-9"		0		X
DBB 120H 21 HPCI PUMP DSCH	07533	10			X PP 5'-1/2"		0		X
DBB 120H 22 HPCI PUMP DSCH	03226	35			X		0		X
DBB 120H 23 HPCI PUMP DSCH	07528	35			X		0		X
DBB 120H 24 HPCI PUMP DSCH	06960	35			X		0		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBB 120H 25 HPCI PUMP DSCH	02965	35			X PP 3'-9 5/8"	0			X
DBB 120H 27 HPCI PUMP DSCH	03483	35			X	0			X
DBB 120H 28 HPCI PUMP DSCH	14774	10			X	0			X
DBB 120H 29 HPCI PUMP DSCH	14792	10			X PP 3'-7 1/8"	0			X
DBB 121H 19 RCIC PUMP DSCH	02168	3			X	0			X
DBB 122H 1 RWCU RETURN EFFECTING FW	06816	3			X	0			X
DBB 122H 3 RWCU RETURN EFFECTING FW	07336	3			X	0			X
DBB 122H 24 RWCU RETURN NONEFFECTING FW	14789	10			X	0			X
DBB 122H 28A RWCU RETURN NONEFFECTING FW	00288	3L			X	0			X
DBB 122H 28B RWCU RETURN NONEFFECTING FW	00289	3L			X	0			X
DBC 101H 14 RWCU SUCT OUTSIDE CONT	02802	3	S		03/19/92 PP 5'-3 1/2"	822	PASS	C/S AF 2.5 AR 2.5	03/20/92
DBC 101H 17 RWCU SUCT OUTSIDE CONT	00360	3L			X	0			X
DBC 101H 18 RWCU SUCT OUTSIDE CONT	17222	1	S		03/19/92 PP 1'-10 1/2"	1034	PASS	C/S AF 1.5 AR 1.5	03/20/92

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 H = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBC 102H 17 RWCU RETURN NONEFFECTING FW	03626	1	S		03/19/92 PP 4'-11"	1300	PASS	C/S AF 1.5 AR 1.5	03/20/92
DBD 101H 36A FW RFP 'C' DISCHARGE	01185	35			X	0			X
DBD 101H 36B FW RFP 'C' DISCHARGE	01170	35			X	0			X
DBD 101H 38 FW RFP 'C' DISCHARGE	08605	35			X PP 4'-9 3/4"	0			X
DBD 101H 40 FW RFP 'C' DISCHARGE	01177	35			X	0			X
DBD 101H 41 FW COMMON DISCHARGE	00149	100			X PP 14'-5 1/4"	0			X
DBD 101H 46 FW RFP 'A' DISCHARGE	08638	35			X PP 8'-3 1/4"	0			X
DBD 101H 48 FW RFP 'A' DISCHARGE	13396	10			X	0			X
DBD 101H 52 FW RFP 'B' DISCHARGE	02798	35			X PP 5'-7 1/8"	0			X
DBD 101H 53A FW RFP 'B' DISCHARGE	08632	35			X PP 6'-4 7/8"	0			X
DBD 101H 53B FW RFP 'B' DISCHARGE	08633	35			X PP 6'-4 1/2"	0			X
DBD 101H 58 FW RFP 'B' DISCHARGE	02593	35			X PP 5'-5 1/8"	0			X
DBD 101H 59A FW RFP 'B' DISCHARGE	02132	3			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBD 101H 59B FW RFP 'B' DISCHARGE	02109	3			X		0		X
DBD 101H 61A FW RFP 'C' DISCHARGE	01514	35			X PP 6'-2 3/4"		0		X
DBD 101H 61B FW RFP 'C' DISCHARGE	01515	35			X PP 6'-2 3/4"		0		X
DBD 101H 62A FW RFP 'C' DISCHARGE	00453	100			X		0		X
DBD 101H 62B FW RFP 'C' DISCHARGE	00274	100			X		0		X
DBD 101H 63A FW RFP 'B' DISCHARGE	13765	10			X		0		X
DBD 101H 63B FW RFP 'B' DISCHARGE	01220	10			X PP 3'-1 5/8"		0		X
DBD 101H 65 FW RFP 'B' DISCHARGE	01170	10			X		0		X
DBD 101H 66 FW RFP 'A' DISCHARGE	00389	10			X PP 4'-10 3/4"		0		X
DBD 101H 68A FW RFP 'A' DISCHARGE	02583	35			X PP 5'-3 1/2"		0		X
DBD 101H 68B FW RFP 'A' DISCHARGE	02572	35			X PP 4'-1 1/2"		0		X
DBD 101H 69 FW RFP 'A' DISCHARGE	00900	35			X PP 5'-11"		0		X
DBD 101H 74A FW RFP 'A' DISCHARGE	01230	35			X PP 6'-1 1/2"		0		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 H = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBD 101H 74B FW RFP 'A' DISCHARGE	01269	35			X PP 8'-2 5/16"	0			X
DBD 101H 75 FW RFP 'A' DISCHARGE	06932	35			X	0			X
DBD 101H 94 FW COMMON DISCHARGE	08622	35			X PP 9'-6"	0			X
DBD 105H 3A FW COMMON DISCHARGE	06026	35			X PP 8'-6 1/8"	0			X
DBD 105H 3B FW COMMON DISCHARGE	02636	35			X PP 4'-10 5/8"	0			X
DBD 105H 7 FW COMMON DISCHARGE	08623	35			X PP 5'-3"	0			X
DBD 105H 10 FW COMMON DISCHARGE	01169	10			X PP 3'-1"	0			X
DBD 105H 11A FW COMMON DISCHARGE	01153	10			X	0			X
DBD 105H 11B FW COMMON DISCHARGE	01157	10			X	0			X
DBD 105H 13 FW COMMON DISCHARGE	16845	1			X PP 2'-3"	0			X
DBD 105H 16A FW COMMON DISCHARGE	08557	10			X	0			X
DBD 105H 16B FW COMMON DISCHARGE	14785	10			X	0			X
DBD 105H 17 FW COMMON DISCHARGE	02510	1			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DBD 105H 18 FW COMMON DISCHARGE	21559	1			X PP 2'-9 1/2"	0			X
DBD 106H 2 FW COMMON DISCHARGE	01370	35			X	0			X
DBD 106H 3 FW COMMON DISCHARGE	09451	35			X PP 6'-2 1/4"	0			X
DBD 106H 4 FW TURB BLDG	00307	3L			X PP 3'-10 1/2"	0			X
DBD 106H 5A FW TURB BLDG	02110	10			X PP 4"-6 1/2"	0			X
DBD 106H 5B FW TURB BLDG	08486	10			X PP 4'-7 1/4"	0			X
DCA 102H 2A RECIRC/RWCU COMMON SUCT.	06818	3			03/28/92	1801	PASS C/S AF 1 3/4 AR 1 3/4		Z
DCA 102H 2B RECIRC/RWCU COMMON SUCT.	06817	3			X DCA102H2A	0	ELIMINATED PP 1'-10 1/4"		X
DCA 102H 3 RECIRC/RWCU COMMON SUCT.	06583	3		92-089	03/29/92	239	FAIL C/S AF 2 AR 2	07227-79	04/07/92
DCA 102H 4A RECIRC/RWCU COMMON SUCT.	06797	3		92-089	03/28/92 P/P-2'8"	1112	PASS C/S AF 1 5/8 AR 1 5/8		Z
DCA 102H 4B RECIRC/RWCU COMMON SUCT.	25302	3		92-089	03/28/92 P/P-2'8"	1138	PASS C/S AF 3 AR 3		Z
DCA 102H 6 RECIRC/RWCU DIV 1 SUCT	03649	3	S		03/21/92 P/P-5'0"	735	PASS C/S AF 2 AR 2		Z
DCA 102H 7 RECIRC/RWCU DIV 1 SUCT.	03640	3	R	92-061	03/18/92 PP 3'-8 1/4"	1556	PASS C/S AF 2 7/8 AR 2 7/8		03/20/92

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DCA 102H 9A RECIRC/RWCU DIV 1 SUCT	04569	3	S		03/20/92	1347	PASS	C/S AF 3 AR 3	Z
DCA 102H 9B RECIRC/RWCU DIV 1 SUCT.	06799	3	S		03/20/92	900	PASS	C/S AF 2 AR 2	Z
DCA 103H 10 RWCU SUCT INSIDE CONT.	06794	3	S		03/31/92 WA#Y10869	849	PASS	C/S AF 2.75 AR 2.75	04/07/92
DCA 107H 7 CORE SPRAY 'A' LOOP DISCH	06942	35			X	0			X
DCA 107H 12 CORE SPRAY 'B' LOOP DISCH	02602	35			X PP 4'-4 1/2"	0			X
DCA 107H 15 CORE SPRAY 'A' LOOP DISCH	03230	35			X	0			X
DCA 107H 16 CORE SPRAY 'B' LOOP DISCH	00919	35			X	0			X
DCA 108H 4 COMMON LPCI/SDC RECIRC	01303	35			X	0			X
DCA 108H 5 COMMON LPCI/SDC RECIRC	01329	35			X PP 6'-8 3/4"	0			X
DCA 108H 6 COMMON LPCI/SDC RECIRC	02579	35			X PP 6'-8 3/8"	0			X
DCA 108H 7 COMMON LPCI/SDC RECIRC	01325	35			X PP 8'-5 1/2"	0			X
DCA 108H 8 COMMON LPCI/SDC RECIRC	00574	100			03/30/92	916	PASS	C/S AF 1 1/2 AR 1 1/2	Z
DCA 108H 9 COMMON LPCI/SDC RECIRC	00399	100			03/30/92	821	DEGRADE	C/S AF 3 1/8 AR 3 1/8	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DCA 108H 10 COMMON LPCI/SDC RECIRC	01233	35			04/03/92 P/P-4'8"	818	PASS		Z
DCA 108H 11 COMMON LPCI/SDC RECIRC	02610	35			03/28/92 P/P-5'1"	1312	PASS	C/S AF 2 3/4	Z AR 3
DCA 108H 12 COMMON LPCI/SDC RECIRC	01291	35			03/30/92 P/P-5'0"	744	PASS	C/S AF 4	Z AR 4
DCA 109H 6 CORE SPRAY 'A' LOOP DISCH	00915	35			X PP 4'-1/2"	0			X
DCA 109H 7 CORE SPRAY 'A' LOOP DISCH	00914	35			X PP 6'-5 3/4"	0			X
DCA 109H 9 CORE SPRAY 'B' LOOP DISCH	00887	35			X PP 4'-0"	0			X
DCA 109H 10 CORE SPRAY 'B' LOOP DISCH	00882	35			X PP 6'-4 3/8"	0			X
DCA 110H 9 DIV I LPCI/SDC RECIRC	02624	35		92-085	03/20/92 CLAMP REMOVED,P/P-6'0"	911	PASS	C/S AF 1"	Z AR 1"
DCA 110H 10 DIV I LPCI/SDC RECIRC	01355	35			X	0			X
DCA 110H 11 DIV I LPCI/SDC RECIRC	01297	35			03/22/92 CLMP RMVD,P/P-8'6"	1028	PASS	C/S AF 3.25	Z AR 3.25
DCA 110H 12 DIV I LPCI/SDC RECIRC	01498	35		92-085	03/2/192 CLMP RMVD,P/P-4'8"	842	PASS	C/S AF 2"	Z AR 2"
DCA 110H 13 DIV I LPCI/SDC RECIRC	02555	35			03/21/92 CLAMP REMOVED	812	PASS	C/S AF 2 1/2"	Z AR 2 1/2"
DCA 110H 14 DIV I LPCI/SDC RECIRC	02585	35		92-085	03/21/92 CLAMP REMOVED,P/P-6'10"	1333	PASS	C/SAF2 3/BAR	Z 1/2"

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DCA 110H 15 COMMON LPCI/SDC RECIRC	01636	100			04/04/92	1451	PASS	C/S AF 3.5 AR 3.5	Z
DCA 110H 16 COMMON LPCI/SDC RECIRC	01640	100			03/28/92	1409	PASS	C/S AF 2 3/4 AR 3	Z
DCA 110H 17 COMMON LPCI/SDC RECIRC	01329	100			03/25/92	1925	PASS	CLMP REMVD,P/P-4'8"C/S AF 2 1/4 AR 2 1/4	Z
DCA 110H 18 COMMON LPCI/SDC RECIRC	02850	35			03/25/92	1631	PASS	CLMPREMVD,P/P-7'11"C/S AF 2 1/2 AR 2 1/2	Z
DCA 110H 19 COMMON LPCI/SDC RECIRC	01266	35			X	0			X
DCA 110H 20 COMMON LPCI/SDC RECIRC	01341	35			X	0			X
DCA 110H 21 COMMON LPCI/SDC RECIRC	01359	35			X	0			X
DCA 110H 22 COMMON LPCI/SDC RECIRC	02580	35			03/28/92	2157	PASS	C/S AF 3 3/4 AR 3 3/4	Z
DCA 110H 23 COMMON LPCI/SDC RECIRC	02662	35			03/28/92	1537	PASS	C/S AF 3 1/2 AR 3 1/2	Z
DCA 110H 24 COMMON LPCI/SDC RECIRC	02603	35			03/28/92	1010	PASS	CLAMP REMOVED,P/P-6'10"C/S AF 3.5 AR 3.5	Z
DCA 110H 25 COMMON LPCI/SDC RECIRC	01265	35			03/28/92	2120	PASS	CLAMP REMOVED,P/P-3'10" C/S AF 3 AR 3	Z
DCA 110H 26 COMMON LPCI/SDC RECIRC	11027	35			X	0			X
DCA 110H 27 COMMON LPCI/SDC RECIRC	02568	35			03/26/92	1823	PASS	CLMP REMVD,P/P-5'0"C/S AF 3 1/2 AR 3 1/2	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DCA 110H 29	01330	100			X		0		X
DIV I LPCI/SDC RECIRC					PP 8'-0"				
DCA 110H 30	02607	35			X		0		X
DIV I LPCI/SDC RECIRC					PP 9'-9 1/16"				
DCA 110H 31	00765	100			03/26/92	841	PASS		Z
DIV I LPCI/SDC RECIRC					CLAMP REMOVED, P/P-6'2"			C/S AF 3 AR 3	
DCA 110H 32	01145	100	F		03/16/92	1749	PASS		03/19/92
DIV I LPCI/SDC RECIRC								C/S AF 1 1/2 AR 1 1/2	
DCA 110H 33	00187	100			03/23/92	817	PASS		Z
DIV I LPCI/SDC RECIRC					CLMP RMVD, P/P-9'4", C/S			AF 2 3/8 AR 2 3/8	
DCA 110H 34	01295	35			03/25/92	803	PASS		Z
DIV I LPCI/SDC RECIRC					CLAMP REMOVED, P/P-6'6"			C/S AF 3 AR 3	
DCA 110H 35	02592	35			03/19/92	1324	PASS		Z
DIV I LPCI/SDC RECIRC					CLAMP REMOVED			C/S AF 3" AR 3"	
DCA 110H 36	11019	35			03/21/92	1132	PASS		Z
DIV I LPCI/SDC RECIRC					CLAMP REMOVED, P/P-5'3", C/S			AF, AR 2 3/4"	
DCA 111H 8A	03656	3			03/20/92	1257	PASS		Z
RHR HEAD SPRAY SPIDER					WA#Y10873, CLMP REMVD			C/S AF 1.5 AR 1.5	
DCA 111H 8B	25283	3			03/20/92	1018	PASS		Z
RHR HEAD SPRAY SPIDER					WA#Y10873, CLMP REMOVED			C/S AF, AR 1.25	
DCA 111H 9	19484	10			03/20/92	1042	PASS	01164-77	04/26/92
RHR HEAD SPRAY SPIDER					USE SZ 10FRM DCA111H37B			C/SAF, AR1.5WAS 3	
DCA 111H 11	13670	10		92-085	03/19/92	2118	PASS		04/26/92
RHR HEAD SPRAY SPIDER					PP 4'-1/4"			C/S AF 2 AR 2	
DCA 111H 12	02498	10		92-121	X		0		X
RHR HEAD SPRAY									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DCA 111H 14 RHR HEAD SPRAY	03438	10		92-073	X	0			X
DCA 111H 15 RHR HEAD SPRAY	02820	10	S		04/02/92	1447	DEGRADE		Z
							CLAMP RMVED, P/P-3'9"	C/S AF 3.75 AR 3.75	
DCA 111H 16 RHR HEAD SPRAY	02542	10			04/02/92	947	PASS		Z
							CLAMP REMOVED	C/S AF 4 AR 4	
DCA 111H 17 RHR HEAD SPRAY	13425	10		92-110	04/02/92	1142	PASS		Z
							CLAMP REMOVED	C/S AF 4 AR 4	
DCA 111H 18 RHR HEAD SPRAY	12946	10	R		04/02/92	1044	PASS		Z
							CLAMP REMOVED	C/S AF 2.5 AR 2.5	
DCA 111H 19 RHR HEAD SPRAY	02534	10			04/02/92	1424	PASS		Z
							CLAMP REMOVED	C/S AF 2.25 AR 2.25	
DCA 111H 20 RHR HEAD SPRAY	02477	10	R		04/04/92	955	PASS		Z
							CHNG TO STRTS, P/P-4'-2"	C/S AF 3.25 AR 3	
DCA 111H 21 RHR HEAD SPRAY	02501	10	R		03/13/92	1058	PASS		Z
							C/S AF 1 1/2"	AR 1 1/2"	
DCA 111H 22 RHR HEAD SPRAY	02545	10			04/02/92	1120	PASS		Z
								C/S AF 1.25 AR 1.25	
DCA 111H 23 RHR HEAD SPRAY	04585	10			04/04/92	831	PASS		Z
							CHNG TO STRUT, P/P-3'10"	C/S AF 2 AR 1.5	
DCA 111H 24 RHR HEAD SPRAY	04586	10			04/04/92	754	PASS		Z
							REPLC W/ STRT, P/P-3'3"	C/S AF 2.25 AR 2.5	
DCA 111H 25 RHR HEAD SPRAY	04587	10			03/13/92	1003	PASS		Z
							P/P-3'4"	C/S AF 2 3/4" AR 2 3/4"	
DCA 111H 26 RHR HEAD SPRAY	04589	10			03/13/92	1032	PASS		Z
							P/P-3'0"	C/S AF 2 1/2" AR 2 1/2"	

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DCA 111H 28 RHR HEAD SPRAY	19548	3			03/13/92	1144	PASS C/S AF 2 1/2" AR 2 1/2"		Z
DCA 111H 29 RHR HEAD SPRAY	04581	10			X	0			X
					PP 4'-5 7/8"				
DCA 111H 36 RHR HEAD SPRAY	06800	3			04/05/92	748	PASS CNG TO STR, PP-4'11" C/S AF 1 1/4 AR 1 1/4		Z
DCA 111H 37A RHR HEAD SPRAY SPIDER	00962	10			03/19/92	2005	PASS 37B ELIMINATED C/S AF 2 1/4 AR 2 1/4		04/20/92
DCA 111H 37B RHR HEAD SPRAY SPIDER	01164	10			03/19/92	1937	PASS SNUBBER, CLAMP ON DCA111H9 C/S AF, AR1 1/2		Z
DCA 111H 38A RHR HEAD SPRAY	02499	10			04/10/92	1448	PASS CHANGE TO SWAY STRUT C/S AF 4.5 AR 4.5		Z
DCA 111H 38B RHR HEAD SPRAY	19559	3			04/10/92	1307	PASS CHANGE TO SWAY STRUT C/S AF 3 AR 3		Z
DCA 111H 39A RHR HEAD SPRAY	06807	3			04/10/92	1331	PASS CHANGE TO SWAY STRUT C/S AF 2.25 AR 2.25		Z
DCA 111H 39B RHR HEAD SPRAY	06806	3			04/10/92	1358	PASS C/S AF 1.5 AR 1.5		Z
DCA 111H 40 RHR HEAD SPRAY	06802	3			X	0			X
DCA 111H 41 RHR HEAD SPRAY	00953	10			04/02/92	1306	PASS CLP RMVD, P/P-5'11" C/S AF 3.75 AR 3.75		Z
DCA 141H 1 DIV I LPCI/SDC RECIRC	04268	10			03/21/92	906	PASS P/P-4'6" C/S AF 2 AR 2		Z
DCA 141H 2 DIV I LPCI/SDC RECIRC	04609	10			03/23/92	859	PASS P/P-3'11" C/S AF 3 AR 3		Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DCA 141H 3 DIV 1 LPCI/SDC RECIRC	12943	10			03/23/92	1021	PASS	C/S AF 2 AR 2	Z
DCA 141H 4 DIV 1 LPCI/SDC RECIRC	04279	10		92-085	03/23/92 P/P-4'10"	816	PASS	C/S AF 2.25 AR 2.75	Z
DCA 142H 1 COMMON LPCI/SDC RECIRC	12276	10			03/31/92 P/P-4'6"	1016	PASS	C/S AF 2 AR 2	Z
DCA 142H 2 COMMON LPCI/SDC RECIRC	04264	10			03/31/92 P/P-3'4"	801	PASS	C/S AF 3 AR 3	Z
DCA 142H 3 COMMON LPCI/SDC RECIRC	08696	10			03/28/92 CLAMP REMOVED, P/P-4'8"	1940	DEGRADE	C/S AF 1 AR 1	Z
DCA 142H 4 COMMON LPCI/SDC RECIRC	04281	10	R		03/28/92 WA#Y10871, CLMP RMVDC/S	1837	PASS	AF 3 5/8 AR 3 5/8	Z
DLA 101H 1 FW INSIDE CONT 'A' LOOP	04109	35			04/13/92	822	PASS	C/S AF 2 1/2 AR 2 1/2	Z
DLA 101H 4 FW INSIDE CONT 'A' LOOP	01574	100			X PP 5'-8 1/2"	0			X
DLA 102H 2 FW INSIDE CONT 'A' LOOP	03236	35			X	0			X
DLA 102H 6 FW INSIDE CONT 'A' LOOP	01794	100			04/15/92 P/P-10'4"	832	FAIL	C/S AF 4 1/4 AR 4 1/4	Z
DLA 102H 7 FW INSIDE CONT 'A' LOOP	03061	35			03/27/92 P/P-6'8"	1331	PASS	C/S AF 2 AR 2	Z
DLA 102H 8A FW INSIDE CONT 'A' LOOP	01618	100	S	92-062	03/27/92 P/P-6'11"	1424	PASS	C/S AF 2 1/4 AR 2	Z
DLA 102H 8B FW INSIDE CONT 'A' LOOP	00536	100	S	92-062 92-045	03/18/92 PP 4'-11 5/8"	900	PASS	C/S AF 3 1/4" AR 3 1/4"	03/23/92

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DLA 102H 9A FW INSIDE CONT 'A' LOOP	02739	35	S	92-045	03/20/92 PP 8'-3 3/4"	737	PASS	C/S AF 2" AR 2"	03/23/92
DLA 102H 9B FW INSIDE CONT 'A' LOOP	00796	35	S		03/28/92	1037	PASS	C/S AF 2 AR 2	Z
DLA 102H 10 FW INSIDE CONT 'A' LOOP	09486	35			04/10/92	858	PASS	C/S AF 1 3/4 AR 1 3/4	Z
DLA 102H 11 FW INSIDE CONT 'A' LOOP	02756	35			X PP 5'-7 3/8"	0			X
DLA 102H 12 FW INSIDE CONT 'A' LOOP	09446	35			X PP 4'-6"	0			X
DLA 102H 13 FW INSIDE CONT 'A' LOOP	01172	35			03/27/92	903	PASS	C/S AF 4 1/8 AR 4 1/8	Z
DLA 102H 14 FW INSIDE CONT 'A' LOOP	01356	35			X PP 5'-9 1/8"	0			X
DLA 102H 15 FW INSIDE CONT 'A' LOOP	01096	100			03/17/92 P/P-5'5"	1315	PASS	C/S AF 2 1/2" AR 2 1/2"	Z
DLA 103H 3 FW INSIDE CONT 'B' LOOP	12623	35			04/13/92	1109	PASS	C/S AF 3 AR 3	Z
DLA 103H 4 FW INSIDE CONT 'B' LOOP	02353	100			X PP 5'-6 1/2"	0			X
DLA 104H 5 FW INSIDE CONT 'B' LOOP	06937	35			04/13/92	1148	PASS	C/S AF 5 1/4 AR 4 1/2	Z
DLA 104H 6 FW INSIDE CONT 'B' LOOP	02391	100	F	92-045	03/20/92 PP 10'-1/4"	1308	PASS	C/S AF 3 1/8" AR 3 1/8"	03/25/92
DLA 104H 7 FW INSIDE CONT 'B' LOOP	03636	35			04/15/92 P/P-5'10"	1602	PASS	C/S AF 2 3/4 AR 2 3/4	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
DLA 104H 8A FW INSIDE CONT 'B' LOOP	02395	100	R		04/15/92	1026	PASS		Z
					CLAMP REMOVED, P/P-7'0"			C/S AF 3	AR 3
DLA 104H 8B FW INSIDE CONT 'B' LOOP	00541	100	S	92-045	03/19/92	1552	PASS		03/25/92
					CLMP RMVD, PP 5'-0", C/S AF 2 1/2			AR 2 1/2	
DLA 104H 9A FW INSIDE CONT 'B' LOOP	11017	35	S	92-045	03/19/92	1020	PASS		03/25/92
					CLAMP REMOVED 8'-5" C/S AF 2 1/2			AR 2 1/2	
DLA 104H 9B FW INSIDE CONT 'B' LOOP	01182	35	S		04/07/92	821	PASS		Z
					P/P-7'1", CLMP RMVD C/S AF 2 1/4			AR 2 1/4	
DLA 104H 10 FW INSIDE CONT 'B' LOOP	02849	35			04/09/92	1135	PASS		Z
								C/S AF 1 1/2	AR 1 1/2
DLA 104H 11 FW INSIDE CONT 'B' LOOP	01167	35			X		0		X
					PP 5'-0"				
DLA 104H 12 FW INSIDE CONT 'B' LOOP	02635	35			X		0		X
					PP 4'-4 1/4"				
DLA 104H 13 FW INSIDE CONT 'B' LOOP	01187	35			04/09/92	1107	PASS		Z
					CLAMP REMOVED			C/S AF 3.25	AR 3.25
DLA 104H 14 FW INSIDE CONT 'B' LOOP	01350	35			X		0		X
					PP 3'-10 3/4"				
DLA 104H 15 FW INSIDE CONT 'B' LOOP	02030	100			04/15/92	1108	PASS		Z
					WA#Y10874, CMP RMVD, PPS'2" C/S AF, AR 2 1/2				
EBB 102H 4 HPCI PUMP DSCH	13435	1/2			X		0		X
					PP 3'-2 1/2"				
EBB 102H 14 HPCI PUMP DSCH	02616	1			X		0		X
EBB 102H 15 HPCI PUMP DSCH	03476	10			X		0		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 H = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
EBB 102H 23 HPCI PUMP DSCH	04592	1			X		0		X
EBD 102H 2A BYPASS STM EFCTING BYPASS VLVS	02166	3			X PP 2'-11 5/8"		0		X
EBD 102H 2B BYPASS STM EFCTING BYPASS VLVS	02164	3			X PP 2'-11 7/16"		0		X
EBD 102H 7 BYPASS STM EFCTING BYPASS VLVS	02822	10			X PP 5'-8 3/8"		0		X
EBD 102H 8A BYPASS STM EFCTING BYPASS VLVS	01174	35			X PP 4'-3 5/8"		0		X
EBD 102H 8B BYPASS STM EFCTING BYPASS VLVS	01173	35			X PP 4'-4 1/8"		0		X
EBD 102H 10 BYPASS STM EFCTING BYPASS VLVS	01313	35			X PP 9'-2 1/2"		0		X
EBD 102H 12A BYPASS STM EFCTING BYPASS VLVS	02137	3			X PP 2'-11"		0		X
EBD 102H 12B BYPASS STM EFCTING BYPASS VLVS	02144	3			X PP 2'-11"		0		X
EBD 102H 18A BYPASS STM EFCTING BYPASS VLVS	00624	35			X		0		X
EBD 102H 18B BYPASS STM EFCTING BYPASS VLVS	00631	35			X		0		X
EBD 102H 20 BYPASS STM EFCTING BYPASS VLVS	01314	35			X PP 9'-4 1/4"		0		X
EBD 102H 22A BYPASS STM EFCTING BYPASS VLVS	02185	3			X PP 2'-11 3/4"		0		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
EBD 102H 228	02189	3			X		0		X
BYPASS STM EFCTING	BYPASS VLVS				PP 2'-11 3/4"				
EBD 102H 29	06951	35			X		0		X
BYPASS STM EFCTING	BYPASS VLVS								
EBD 102H 30	02081	10			X		0		X
BYPASS STM EFCTING	BYPASS VLVS								
EBD 102H 31A	00577	35			X		0		X
BYPASS STM EFCTING	BYPASS VLVS				PP 4'-1/4"				
EBD 102H 31B	00580	35			X		0		X
BYPASS STM EFCTING	BYPASS VLVS				PP 4'-1/4"				
EBD 102H 32	01305	35			X		0		X
BYPASS STM EFCTING	BYPASS VLVS				PP 9'-1 7/16"				
EBD 102H 35	01317	35	S	92-045	03/18/92	1326	PASS		03/21/92
BYPASS STM EFCTING	BYPASS VLVS				PP 8'-5 1/4"		C/S AF 2 7/8 AR 2 7/8		
EBD 102H 36A	00960	10			X		0		X
BYPASS STM EFCTING	BYPASS VLVS				PP 3'-2 1/4"				
EBD 102H 36B	00959	10			X		0		X
BYPASS STM EFCTING	BYPASS VLVS				PP 3'-3"				
EBD 102H 38	01322	35			X		0		X
BYPASS STM EFCTING	BYPASS VLVS				PP 4'-10 7/8"				
EBD 102H 39	04584	10			X		0		X
BYPASS STM EFCTING	BYPASS VLVS								
EBD 102H 45	02789	10			X		0		X
BYPASS STM EFCTING	BYPASS VLVS								
EBD 102H 48A	02657	35			X		0		X
BYPASS STM EFCTING	BYPASS VLVS								

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
EBD 102H 48B BYPASS STM EFCTING BYPASS VLVS	02656	35			X	0			X
EBD 102H 52 BYPASS STM EFCTING BYPASS VLVS	02663	35			X PP 9'-2"	0			X
EBD 102H 53A BYPASS STM EFCTING BYPASS VLVS	00636	35			X PP 3'-11 3/4"	0			X
EBD 102H 53B BYPASS STM EFCTING BYPASS VLVS	00626	35			X PP 3'-11 3/4"	0			X
EBD 102H 55A BYPASS STM EFCTING BYPASS VLVS	00805	35			X	0			X
EBD 102H 55B BYPASS STM EFCTING BYPASS VLVS	00804	35		92-084	X	0			X
EBD 102H 62A BYPASS STM EFCTING BYPASS VLVS	06791	3			X PP 3'-3"	0			X
EBD 102H 62B BYPASS STM EFCTING BYPASS VLVS	06793	3			X PP 3'-3"	0			X
EBD 102H 65A BYPASS STM EFCTING BYPASS VLVS	00272	3L			X	0			X
EBD 102H 65B BYPASS STM EFCTING BYPASS VLVS	00273	3L			X	0			X
EBD 102H 66A BYPASS STM EFCTING BYPASS VLVS	00317	10L			X	0			X
EBD 102H 66B BYPASS STM EFCTING BYPASS VLVS	00316	10L			X	0			X
EBD 102H 67 BYPASS STM EFCTING BYPASS VLVS	02737	3	S		03/18/92	800	PASS C/S AF 2 3/8 AR 2 3/8		03/21/92

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
EBD 109H 1	02153	1			X		0		X
AIR RMVL/CONDS EFFECTING T.S.									
EBD 109H 2	00110	1L			X		0		X
AIR RMVL/CONDS EFFECTING T.S.									
EBD 109H 4	19566	3			X		0		X
AIR RMVL/CONDS EFFECTING T.S.									
FBD 110H 15	03519	3			X		0		X
RFPT EFFECTING MN STM					PP 5'-5 5/8"				
EBD 110H 16	13758	10			X		0		X
RFPT EFFECTING MN STM									
EBD 110H 17	03783	3			X		0		X
RFPT EFFECTING MN STM					PP 5'-6 1/8"				
EBD 110H 18	04592	10			X		0		X
RFPT EFFECTING MN STM					PP 2'-9 9/16"				
EBD 113H 2A	06803	3			X		0		X
SSE EFFECTING MN STM									
EBD 113H 2B	00168	3L			X		0		X
SSE EFFECEING MN STM					PP 5'-9 1/2"				
EBD 113H 4	00169	3L			X		0		X
SSE EFFECTING MN STM									
EBD 113H 5	06440	3			X		0		X
SSE EFFECTING MN STM					PP 3'-1 7/8"				
EBD 113H 6	12200	1			X		0		X
SSE EFFECTING MN STM					PP 2'-7 3/8"				
EBD 113H 7	02569	35		92-141	X		0		X
SSE EFFECTING MN STM					PP 4'-10 1/8"				

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
EBD 113H 9 SSE EFFECTING MN STM	00348	3		92-141	X		0		X
EBD 114H 36 MN STM LINE DRN OUTSIDE CONT	02085	10			X		0		X
GBB 101H 17 CORE SPRAY 'B' LOOP DISCH	02520	1			X		0		X
GBB 101H 33 CORE SPRAY 'A' LOOP DISCH	08612	35			X		0		X
GBB 101H 37A CORE SPRAY 'A' LOOP DISCH	13679	10			X		0		X
GBB 101H 37B CORE SPRAY 'A' LOOP DISCH	02128	10			X		0		X
GBB 101H 38 CORE SPRAY 'A' LOOP DISCH	01619	1			X	PP 2'-9 5/8"	0		X
GBB 101H 39 CORE SPRAY 'A' LOOP DISCH	03597	1			X	PP 2'-10 7/8"	0		X
GBB 101H 40 CORE SPRAY 'B' LOOP DISCH	01636	1			X	PP 2'-2 15/16"	0		X
GBB 101H 41 CORE SPRAY 'B' LOOP DISCH	03794	1			X	PP 2'-2 15/16"	0		X
GBB 101H 42 CORE SPRAY 'A' LOOP DISCH	04580	10			X		0		X
GBB 102H 23 CORE SPRAY 'B' LOOP DISCH	04030	3			X	PP 6'-1 1/2"	0		X
GBB 104H 3 DIV I LPCI/SDC RHR	01517	35			X	PP 5'-10"	0		X

LEGEND

\bar{X} OR \bar{V} = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBB 104H 8 DIV I LPCI.SDC RHR	00552	100			X PP 5'-10 1/8"	0			X
GBB 104H 13 DIV I LPCI/SDC RHR	01097	100			X PP 5'-9 1/8"	0			X
GBB 104H 21 DIV II LPCI/SDC RHR	01490	35			X PP 5'-9 1/2"	0			X
GBB 104H 26 DIV II LPCI/SDC RHR	01378	35			X PP 6'-1 1/2"	0			X
GBB 104H 31 DIV II LPCI/SDC RHR	08646	35			X PP 4'-2"	0			X
GBB 104H 40 DIV II LPCI/SDC RHR	04582	10			X	0			X
GBB 104H 47 DIV I LPCI/SDC RHR	02055	10			X	0			X
GBB 106H 9 DIV I LPCI/SDC RHR	08631	35			X	0			X
GBB 106H 18 DIV II LPCI/SDC RHR	02552	35			X	0			X
GBB 106H 25 DIV I LPCI/SDC RHR	02011	100			X PP 5'-9 1/8"	0			X
GBB 106H 26 DIV II LPCI/SDC RHR	01095	100			X	0			X
GBB 106H 36A DIV I LPCI/SDC RHR	02127	10			X	0			X
GBB 106H 36B DIV I LPCI/SDC RHR	02134	10			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBB 107H 1A DIV II LPCI/SDC RHR	25275	3	R		03/26/92 PP 3'-1"	1019	PASS	C/S AF 2.25 AR 2.25	04/01/92
GBB 107H 1B DIV II LPCI/SDC RHR	19475	3	F		03/26/92 PP 3'-1 1/4"	953	PASS	C/S AF 1 5/8 AR 1.5	04/01/92
GBB 107H 6 DIV II LPCI/SDC RHR	12962	10			X	0			X
GBB 107H 7A DIV II LPCI/SDC RHR	25309	3			X PP 2'-7 1/2"	0			X
GBB 107H 7B DIV II LPCI/SDC RHR	25263	3			X PP 2'-7 5/8"	0			X
GBB 107H 12 DIV II LPCI/SDC RHR	01150	10			X	0			X
GBB 107H 15A DIV II LPCI/SDC RHR	19576	3			X	0			X
GBB 107H 15B DIV II LPCI/SDC RHR	07024	3			X	0			X
GBB 107H 17 DIV II LPCI/SDC RHR	12944	10			X	0			X
GBB 107H 31 DIV I LPCI/SDC RHR	19513	3	F		03/20/92 PP 2'-10"	748	PASS	C/S AF 3 AR 3	03/23/92
GBB 107H 40A DIV II LPCI/SDC RHR	08695	10			X	0			X
GBB 107H 40B DIV II LPCI/SDC RHR	08710	10			X	0			X
GBB 107H 41 DIV II LPCI/SDC RHR	03210	35			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBB 108H 3 DIV I LPCI/SDC RHR	02422	1			X PP 2'-6 1/4"		0		X
GBB 109H 11 DIV I LPCI/SDC RHR	08223	10			X PULLED BY NORM		0		03/23/92
GBB 109H 17 DIV II LPCI/SDC RHR	06578	3			X PP 2'-3 1/4"		0		X
GBB 109H 24 DIV I LPCI/SDC RHR	03564	3			X PP 4'-11 1/4"		0		X
GBB 109H 25 DIV I LPCI/SDC RHR	03580	3			X PP 3'-7 1/4"		0		X
GBB 109H 29 DIV II LPCI/SDC RHR	00889	35			X PP 3'-4"		0		X
GBB 109H 30 DIV II LPCI/SDC RHR	03198	35			X		0		X
GBB 109H 32 DIV II LPCI/SDC RHR	10890	35			X PP 3'-11"		0		X
GBB 109H 33A DIV II LPCI/SDC RHR	03220	35			X		0		X
GBB 109H 33B DIV II LPCI/SDC RHR	03475	35			X		0		X
GBB 109H 35 DIV I LPCI/SDC RHR	12949	10			X		0		X
GBB 109H 36 DIV I LPCI/SDC RHR	13669	10			X		0		X
GBB 109H 37 DIV I LPCI/SDC RHR	04600	10			03/18/92 PP 4'-1 7/8"	925	PASS		03/23/92 C/S AF 3 AR 3

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBB 109H 38 DIV I LPCI/SDC RHR	25301	3			03/18/92 PP 2'-6 3/8"	854	PASS	25301 C/S AF 2.5 AR 2.5	03/23/92
GBB 109H 39 DIV II LPCI/SDC RHR	12183	1			X PP 2'-2 1/2"	0			X
GBB 109H 40 DIV II LPCI/SDC RHR	17225	1			X	0			X
GBB 111H 4 DIV I LPCI/SDC RHR	18565	1	F		03/18/92	1309	PASS	C/S AF 2.25 AR 2.25	03/24/92
GBB 111H 8 DIV II LPCI/SDC RHR	19556	3			X	0			X
GBB 112H 22 DIV II LPCI/SDC RHR	06813	3			X PP 4'-3"	0			X
GBB 112H 23 DIV II LPCI/SDC RHR	17218	1			X PP 4'-4 3/4"	0			X
GBB 112H 24 DIV II LPCI/SDC RHR	06579	3			X PP 4'-11"	0			X
GBB 113H 2 DIV I LPCI/SDC RHR	05002	1	F		03/17/92 PP 2'-9 9/16"	1018	PASS	C/S AF 2 AR 2	03/20/92
GBB 114H 1 DIV I LPCI/SDC RHR	03574	3			X PP 3'-6 3/8"	0			X
GBB 114H 3 DIV I LPCI/SDC RHR	14385	1/2			X PP 2'-1"	0			X
GBB 115H 3 DIV I LPCI/SDC RHR	01302	35			X	0			X
GBB 115H 15A DIV II LPCI/SDC RHR	11025	35			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBB 115H 15B DIV II LPCI/SDC RHR	06961	35			X	0			X
GBB 118H 13 DIV I LPCI/SDC RHR	19532	3	F		03/18/92 PP 3'-5/8"	825	PASS	C/S AF 2.5 AR 2.5	03/20/92
GBB 118H 24A DIV II LPCI/SDC RHR	08703	10			X	0			X
GBB 118H 24B DIV II LPCI/SDC RHR	14768	10			X	0			X
GBC 101H 100 MAIN STEAM 'D' LINE IN CONT	02767	35			04/13/92	747	PASS	C/S AF 2 3/4 AR 2 3/4	Z
GBC 101H 101 MAIN STEAM 'D' LINE IN CONT	02611	35			04/04/92 P/P-5'6"	1117	PASS	C/S AF 2 1/2 AR 2 1/2	Z
GBC 101H 102 MAIN STEAM 'D' LINE IN CONT	03765	35			X	0			X
GBC 101H 103 MAIN STEAM 'D' LINE IN CONT	00933	35	S		03/26/92	2139	PASS	C/S AF 4 3/4 AR 4 3/4	Z
GBC 101H 105 MAIN STEAM 'D' LINE IN CONT	02609	35			04/04/92 P/P-7'9"	1349	PASS	C/S AF 3 AR 3	Z
GBC 101H 106 MAIN STEAM 'D' LINE IN CONT	02617	35			04/04/92 P/P-8'11"	1423	PASS	C/S AF 3 AR 3	Z
GBC 101H 107 MAIN STEAM 'D' LINE IN CONT	01544	35	S	92-087 92-045	03/15/92 PP 7'-0"	850	PASS	C/S AF 3 AR 3	03/20/92
GBC 101H 108 MAIN STEAM 'C' LINE IN CONT	01308	35			03/16/92 P/P-3'9"	1316	PASS	C/S AF 3" AR 3"	Z
GBC 101H 109 MAIN STEAM 'C' LINE IN CONT	01537	35			03/16/92 P/P-6'6"	1935	PASS	C/S AF 3 AR 3	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBC 101H 110 MAIN STEAM 'C' LINE IN CONT	01257	35			03/14/92	2149	PASS CHANGED TO STRUT	C/S AF 2 3/4 AR 2 3/4	Z
GBC 101H 111 MAIN STEAM 'C' LINE IN CONT	02578	35			03/15/92	1105	PASS CHNG TO STRT,PP-8'5"	C/S AF 3 1/2 AR3 1/2	Z
GBC 101H 112 MAIN STEAM 'C' LINE IN CONT	01504	35			03/14/92	2059	PASS P/P-4'10"	C/S AF 2 1/2 AR 2 1/2	Z
GBC 101H 115 MAIN STEAM 'C' LINE IN CONT	01489	35	S	92-045	03/15/92	1431	PASS PP 3'- 11 1/4"	C/S AF 3 1/2 AR 3 1/2	04/03/92
GBC 101H 116 MAIN STEAM 'C' LINE IN CONT	01534	35			X	0	P/P 5'-3 3/4"		X
GBC 101H 117 MAIN STEAM 'C' LINE IN CONT	01384	35			03/14/92	1913	PASS P/P-5'6"	C/S AF 2 AR 2	Z
GBC 101H 119A MAIN STEAM 'C' LINE IN CONT	00911	35			X	0	P/P 5'7 1/2"		X
GBC 101H 119B MAIN STEAM 'C' LINE IN CONT	00916	35			X	0	P/P 5'6 3/8"		X
GBC 101H 120 MAIN STEAM 'C' LINE IN CONT	01250	35	S		03/15/92	1554	PASS C/S AF 3 1/2 AR 3 1/2		04/03/92
GBC 101H 121 MAIN STEAM 'C' LINE IN CONT	01237	35			03/16/92	1403	PASS C/S AF 2 1/2" AR 2 1/2"		Z
GBC 101H 122 MAIN STEAM 'C' LINE IN CONT	09442	35			X	0			X
GBC 101H 125A MAIN STEAM 'C' LINE IN CONT	00910	35			X	0	P/P 7'1 3/4"		X
GBC 101H 125B MAIN STEAM 'C' LINE IN CONT	00879	35			X	0	P/P 7'1 3/4"		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBC 101H 126 MAIN STEAM 'C' LINE IN CONT	01241	35			03/15/92 CHANGED TO	1907 STRUT	PASS C/S	AF 2 5/8 AR 2 5/8	Z
GBC 101H 128 MAIN STEAM 'C' LINE IN CONT	11021	35			03/15/92	1828	PASS C/S	AF 2 1/8 AR 2 1/8	Z
GBC 101H 129 MAIN STEAM 'C' LINE IN CONT	00883	35			03/15/92 CHANGED TO	1159 STRUT, P/P-5'8"	PASS C/S	AF 3 AR 3	Z
GBC 101H 130 MAIN STEAM 'A' LINE IN CONT	00920	35			03/31/92 P/P-4'7"	822	PASS C/S	AF 2 1/2 AR 2 1/2	Z
GBC 101H 131 MAIN STEAM 'A' LINE IN CONT	00921	35			03/31/92 CNG TO STRT, PP-5'5"	1022	PASS C/S	AF 2 1/4 AR 2 1/4	Z
GBC 101H 132 MAIN STEAM 'A' LINE IN CONT	00905	35	S		03/28/92 CNG TO STRT, P/P-6'1"	1337	PASS C/S	AF 2 3/4 AR 2 3/4	Z
GBC 101H 134 MAIN STEAM 'A' LINE IN CONT	00886	35			X	0			X
GBC 101H 135 MAIN STEAM 'A' LINE IN CONT	00908	35			04/10/92 P/P-5'9"	1356	PASS C/S	AF 1 1/4 AR 1 1/4	Z
GBC 101H 136 MAIN STEAM 'A' LINE IN CONT	02837	35			03/31/92 P/P-9'11"	1111	PASS C/S	AF 3 1/2 AR 3 1/2	Z
GBC 101H 137A MAIN STEAM 'A' LINE IN CONT	04579	10	S		03/14/92	1554	PASS C/S	AF 2 3/4 AR 2 3/4	03/16/92
GBC 101H 137B MAIN STEAM 'A' LINE IN CONT	04578	10	S		03/14/92	1632	PASS C/S	AF 1 3/4 AR 1 3/4	03/16/92
GBC 101H 138 MAIN STEAM 'A' LINE IN CONT	02839	35			03/28/92	1505	PASS C/S	AF 3 AR 2 3/4	Z
GBC 101H 139 MAIN STEAM 'A' LINE IN CONT	02838	35			03/28/92 CHANGED TO	1113 STRUT, P/P-4'3"	PASS C/S	AF 3 AR 3	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBC 101H 140 MAIN STEAM 'A' LINE IN CONT	03244	35			03/31/92 CHANGED TO STRUT	1319	PASS	C/S AF 3.25 AR 3.25	Z
GBC 101H 141 MAIN STEAM 'A' LINE IN CONT	00794	35			X P/P 6'0 3/4"	0			X
GBC 101H 142 MAIN STEAM 'A' LINE IN CONT	02604	35			03/29/92 P/P-7'4"	1040	PASS	C/S AF 3.25 AR 3.25	Z
GBC 101H 143A MAIN STEAM 'A' LINE IN CONT	01263	35			X	0			X
GBC 101H 143B MAIN STEAM 'A' LINE IN CONT	01274	35			X	0			X
GBC 101H 144 MAIN STEAM 'A' LINE IN CONT	01235	35			X	0			X
GBC 101H 147 MAIN STEAM 'D' LINE IN CONT	01236	35	S	92-045	03/13/92 PP 3'-10 1/4"	836	PASS	C/S AF 2 1/2" AR 2 1/2"	03/20/92
GBC 101H 148 MAIN STEAM 'D' LINE IN CONT	01248	35			X	0			X
GBC 101H 151 MAIN STEAM 'D' LINE IN CONT	01541	35			04/14/92 CHNG TO STRT, P/P-7'	759	PASS	C/S AF 3 1/4 AR 3 1/4	Z
GBC 101H 152 MAIN STEAM 'D' LINE IN CONT	00880	35			04/15/92 CNG TO STRT, PP-5'10"	1345	PASS	C/S AF 2 3/4 AR 2 3/4	Z
GBC 101H 153 MAIN STEAM 'D' LINE IN CONT	01536	35			04/10/92 P/P-4'0"	1453	PASS	C/S AF 2 1/2 AR 2 1/2	Z
GBC 101H 154 MAIN STEAM 'D' LINE IN CONT	02746	35			X	0			X
GBC 101H 155 MAIN STEAM 'D' LINE IN CONT	01512	35			04/10/92 CHANGED TO STRUT, P/P-3'7"	1109	PASS	C/S AF 3 AR 3	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBC 101H 156 MAIN STEAM 'D' LINE IN CONT	08644	35			04/10/92 CHANGED TO	1140	PASS STRUT, P/P-5'8"	C/S AF 3 AR 3	Z
GBC 101H 157 MAIN STEAM 'D' LINE IN CONT	00904	35			X PP 7'-5"	0			X
GBC 101H 158 MAIN STEAM 'D' LINE IN CONT	00925	35			03/20/92 CHANGED TO	1059	PASS STRUT	C/S AF 3" AR 3"	Z
GBC 101H 159 MAIN STEAM 'D' LINE IN CONT	01240	35			04/16/92 CHANGED TO	1403	PASS STRUT	C/S AF 3 AR 2 3/4	Z
GBC 101H 160 MAIN STEAM 'D' LINE IN CONT	01243	35			04/04/92	1308	DEGRADE	C/S AF 2 AR 2	Z
GBC 101H 162 MAIN STEAM 'D' LINE IN CONT	02834	35			X PP 4'-6"	0			X
GBC 101H 163 MAIN STEAM 'D' LINE IN CONT	01246	35			X	0			X
GBC 101H 164 MAIN STEAM 'C' LINE IN CONT	01261	35	S		03/25/92 REPET SPIK, PP3'8"	249	PASS C/S AF 2 1/2 AR 2 1/2		Z
GBC 101H 165 MAIN STEAM 'C' LINE IN CONT	02755	35			X	0			X
GBC 101H 166 MAIN STEAM 'C' LINE IN CONT	00877	35	S	92-045	03/15/92 PP 6'-1"	812	PASS	C/S AF 3 AR 3	04/03/92
GBC 101H 167 MAIN STEAM 'C' LINE IN CONT	01296	35			03/25/92 CHANGED TO	1823	PASS STRUT	C/S AF 2 AR 2	Z
GBC 101H 168 MAIN STEAM 'C' LINE IN CONT	12622	35			X	0			X
GBC 101H 169 MAIN STEAM 'C' LINE IN CONT	00881	35		92-085	03/25/92 P/P-4'8"	1638	PASS C/S AF 2 3/8 AR 3 1/8		Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBC 101H 170 MAIN STEAM 'C' LINE IN CONT	11020	35	F		03/26/92	1139	PASS		Z
					CHNG TO STRT PP-7'11" C/S AF,AR,2 3/4"				
GBC 101H 173A MAIN STEAM 'C' LINE IN CONT	01496	35			03/25/92	1116	PASS		Z
					CHANG/STRUT,P/P-6'6" C/S AF 2 AR 2				
GBC 101H 173B MAIN STEAM 'C' LINE IN CONT	01388	35			03/25/92	1142	PASS		Z
					CHANG/STRUT,P/P-6'6", C/S AF 2 1/8 AR 2				
GBC 101H 175 MAIN STEAM 'C' LINE IN CONT	00890	35		92-085	03/25/92	1046	PASS		Z
					CHANG/STRUT,P/P-6'9",CS AF3 1/8 AR2 1/2				
GBC 101H 177 MAIN STEAM 'C' LINE IN CONT	01299	35			03/25/92	1253	PASS		Z
					CHANGED TO STRUT C/S AF 3 3/4" AR 3 3/4"				
GBC 101H 178 MAIN STEAM 'D' LINE IN CONT	02651	35			04/03/92	827	PASS		Z
					C/S AF 4 AR 4				
GBC 101H 180 MAIN STEAM 'D' LINE IN CONT	01495	35			X	0			X
GBC 101H 181 MAIN STEAM 'D' LINE IN CONT	01393	35			X	0			X
					PP 5'-5 1/2"				
GBC 101H 182 MAIN STEAM 'D' LINE IN CONT	01502	35	S		03/26/92	2222	PASS		Z
					CHANGED TO STRUT C/S AF 3 AR 3				
GBC 101H 183 MAIN STEAM 'D' LINE IN CONT	01525	35			X	0			X
GBC 101H 186A MAIN STEAM 'D' LINE IN CONT	00901	35			03/25/92	904	PASS		Z
					CHANG/STRUT,P/P-5'1" C/S AF 4 AR 4				
GBC 101H 186B MAIN STEAM 'D' LINE IN CONT	00909	35		92-085	03/18/92	1048	PASS		Z
					CHANGED TO STRUT,P/P-5'1"C/S AF,AR 1 3/4				
GBC 101H 187 MAIN STEAM 'D' LINE IN CONT	01523	35			X	0			X
					PP 4'-11 5/16"				

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBC 101H 188 MAIN STEAM 'D' LINE IN CONT	02743	35		92-085	03/22/92 P/P-7'7"	928	PASS C/S	AF 3 1/2" AR 1/8"	Z
GBC 101H 189 MAIN STEAM 'D' LINE IN CONT	00912	35			03/22/92 P/P-5'9"	847	PASS C/S	AF 3.5 AR 3.5	Z
GBC 101H 190 MAIN STEAM 'B' LINE IN CONT	01383	35			04/10/92 P/P-4'4"	1307	PASS C/S	AF 2 1/2 AR 2 1/2	Z
GBC 101H 191 MAIN STEAM 'B' LINE IN CONT	01530	35			04/13/92 CNG TO STRT, PP-4'5"	1414	PASS C/S	AF 3 1/4 AR 3 1/4	Z
GBC 101H 192 MAIN STEAM 'B' LINE IN CONT	01533	35			04/10/92 CLAMP REMOVED, P/P-4'7"	1422	PASS C/S	AF 3 AR 3	Z
GBC 101H 193 MAIN STEAM 'B' LINE IN CONT	06933	35			X PP 6'-10"	0			X
GBC 101H 194 MAIN STEAM 'B' LINE IN CONT	01385	35			04/07/92	757	PASS C/S	AF 4.25 AR 4.25	Z
GBC 101H 195 MAIN STEAM 'B' LINE IN CONT	01161	35		92-085	03/17/92 P/P-6'6"	1131	PASS C/S	AF 1 1/2" AR 1 1/2"	Z
GBC 101H 196 MAIN STEAM 'B' LINE IN CONT	01290	35			X	0			X
GBC 101H 197 MAIN STEAM 'B' LINE IN CONT	01358	35			X PP 4'-5 1/4"	0			X
GBC 101H 198 MAIN STEAM 'B' LINE IN CONT	01242	35			04/04/92 CHANGED TO STRUT	834	PASS C/S	AF 2 3/4 AR 2 3/4	Z
GBC 101H 199 MAIN STEAM 'B' LINE IN CONT	02674	35			04/06/92 CHG TO STRT, PP-4'7"	1356	PASS C/S	AF 2 1/4 AR 2 1/4	Z
GBC 101H 200 MAIN STEAM 'B' LINE IN CONT	02671	35	S	92-085	03/26/92 P/P-6'7"	1640	PASS C/S	AF 3 1/2" AR 2 1/2"	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBC 101H 202 MAIN STEAM 'B' LINE IN CONT	04098	35			04/10/92	1010	PASS		Z
					CLAMP REMOVED			C/S AF 2	AR 2
GBC 101H 203 MAIN STEAM 'B' LINE IN CONT	06964	35			X	0			X
GBC 101H 204 MAIN STEAM 'B' LINE IN CONT	01360	35			03/26/92	1255	PASS		Z
					CHNG TO STRUT, P/P-6'7"			C/S AF 2	AR 2
GBC 101H 206 MAIN STEAM 'B' LINE IN CONT	01256	35			03/16/92	1610	PASS		Z
					CHANGED TO STRUT			C/S AF 2 3/4"	AR 2 3/4"
GBC 101H 208 MAIN STEAM 'B' LINE IN CONT	01298	35			03/17/92	800	FAIL		Z
					CHANGE TO STRUT P/P3'-9"			C/S AF, AR 3	1/4
GBC 101H 209 MAIN STEAM 'B' LINE IN CONT	01292	35			03/16/92	1445	PASS		Z
					CHANGED TO STRUT			C/S AF 3 1/2"	AR 3 1/2"
GBC 101H 210 MAIN STEAM 'B' LINE IN CONT	01154	35			04/07/92	855	PASS		Z
					CLAMP REMOVED, P/P-5'6"			C/S AF 1 1/2	AR 1
GBC 101H 211 MAIN STEAM 'B' LINE IN CONT	01155	35			04/10/92	1042	PASS		Z
					CLMP RMVD, P/P-4'2"			C/S AF 1 1/4	AR 1 1/4
GBC 101H 212 MAIN STEAM 'B' LINE IN CONT	01231	35			X	0			X
					PP 3'-11 1/16"				
GBC 101H 213 MAIN STEAM 'B' LINE IN CONT	02577	35			04/14/92	1357	PASS		Z
					P/P-3'9"			C/S AF 3	AR 3
GBC 101H 214 MAIN STEAM 'B' LINE IN CONT	02753	35			04/07/92	746	PASS		Z
					P/P-7'7"			C/S AF 3	AR 3
GBC 101H 215 MAIN STEAM 'B' LINE IN CONT	08620	35			04/06/92	1429	PASS		Z
					CHN TOSTRT, PP-3'11"			C/S AF 2 3/4	AR 2 3/4
GBC 101H 216 MAIN STEAM 'B' LINE IN CONT	01371	35			04/17/92	750	PASS		Z
					CHANGED TO STRUT, P/P-3'3"			C/S AF 3	AR 3

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBC 101H 217 MAIN STEAM 'B' LINE IN CONT	01176	35			X PP 4'-2"	0			X
GBC 101H 218 MAIN STEAM 'B' LINE IN CONT	06945	35			X	0			X
GBC 101H 219A MAIN STEAM 'B' LINE IN CONT	01180	35			X PP 7'-1 1/2"	0			X
GBC 101H 219B MAIN STEAM 'B' LINE IN CONT	01189	35			X PP 7'-1 1/2"	0			X
GBC 101H 220A MAIN STEAM 'B' LINE IN CONT	02658	35			X PP 5'-11 3/16"	0			X
GBC 101H 220B MAIN STEAM 'B' LINE IN CONT	02664	35			X PP 6'-10"	0			X
GBC 101H 221A MAIN STEAM 'B' LINE IN CONT	03726	35			X P/P 7'4 7/8"	0			X
GBC 101H 221B MAIN STEAM 'B' LINE IN CONT	01181	35			X P/P 6' 1 1/8"	0			X
GBC 101H 225 MAIN STEAM 'A' LINE IN CONT	08643	35	S	92-045	03/14/92 P/P5'-11 1/2"	1406	PASS	C/S AF 2" AR 2"	03/19/92
GBC 101H 226 MAIN STEAM 'A' LINE IN CONT	09465	35	F		03/31/92 P/P-5'7"	857	PASS	C/S AF 1 1/2 AR 1 1/2	Z
GBC 101H 228 MAIN STEAM 'B' LINE IN CONT	02678	35			03/17/92	900	PASS	C/S AF 2" AR 2"	Z
GBC 101H 230 MAIN STEAM 'A' LINE IN CONT	01522	35			04/14/92 CLAMP REMOVED, P/P-6'7"	922	PASS	C/S AF 3 AR 3	Z
GBC 101H 231 MAIN STEAM 'A' LINE IN CONT	01338	35			X P/P 4'9 7/8"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBC 101H 232 MAIN STEAM 'A' LINE IN CONT	01507	35			X P/P-7'2 1/2"	0			X
GBC 101H 233 MAIN STEAM 'A' LINE IN CONT	01332	35			X	0			X
GBC 101H 234 MAIN STEAM 'A' LINE IN CONT	08645	35			04/16/92 CHANGED TO STRUT	1341	PASS C/S AF 1 1/2 AR 1 1/2		Z
GBC 101H 237A MAIN STEAM 'A' LINE IN CONT	01357	35			X P/P 7'0 3/4"	0			X
GBC 101H 237B MAIN STEAM 'A' LINE IN CONT	08618	35			X P/P 6'2 13/16"	0			X
GBC 101H 238 MAIN STEAM 'A' LINE IN CONT	01264	35			03/15/92 CHANGED TO STRUT, P/P-4'0"	1350	PASS C/S AF 3 AR 3		Z
GBC 101H 239 MAIN STEAM 'A' LINE IN CONT	03496	35			04/16/92 CLAMP REMOVED, P/P-7'6"	824	PASS C/S AF 3 AR 3		Z
GBC 101H 240 MAIN STEAM 'A' LINE IN CONT	01258	35			04/16/92 CHANGED TO STRUT	1336	PASS C/S AF 3 AR 1/2		Z
GBC 101H 241 MAIN STEAM 'A' LINE IN CONT	01234	35			04/16/92 CHANGE TO STRUT	1147	PASS C/S AF 1 1/4 AR 1 1/4		Z
GBC 101H 242 MAIN STEAM 'D' LINE IN CONT	01380	35			X	0			X
GBC 101H 244A MAIN STEAM 'D' LINE IN CONT	01262	35			04/16/92 CHANGE TO STRUT, P/P-6'10"	736	PASS C/S AF 3 AR 3		Z
GBC 101H 244B MAIN STEAM 'D' LINE IN CONT	01259	35			04/15/92 CNG TO STRT, PP-4'5" C/S AF 2 1/2 AR 2 1/2	1429	DEGRADE		Z
GBC 101H 245 MAIN STEAM 'D' LINE IN CONT	01382	35	S		03/26/92 P/P-4'1"	1906	PASS C/S AF 3 AR 3		Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBC 101H 246 MAIN STEAM 'D' LINE IN CONT	01491	35			04/14/92 P/P-7'9"	727	PASS C/S AF 2 1/2 AR 2 1/2		Z
GBC 101H 247 MAIN STEAM 'D' LINE IN CONT	08648	35			03/18/92 VLV WK P/P6'5"	1413	PASS C/S AF 2 1/2" AR 2 1/2"		04/07/92
GBC 101H 248 MAIN STEAM 'D' LINE IN CONT	01191	35			04/13/92 CHANGE TO STRUT	918	PASS C/S AF 3 1/2 AR 3 1/2		Z
GBC 101H 252 MAIN STEAM 'A' LINE IN CONT	01327	35			04/14/92 P/P-5'1"	1306	PASS C/S AF 3 1/4 AR 3 1/4		Z
GBC 101H 253 MAIN STEAM 'A' LINE IN CONT	01267	35			X P/P 4' 5 1/4"	0			X
GBC 101H 254A MAIN STEAM 'A' LINE IN CONT	01353	35			X P/P 7' 0 7/8"	0			X
GBC 101H 254B MAIN STEAM 'A' LINE IN CONT	03182	35			X P/P 7'1"	0			X
GBC 101H 255 MAIN STEAM 'A' LINE IN CONT	01343	35			X	0			X
GBC 101H 256 MAIN STEAM 'A' LINE IN CONT	02742	35			04/13/92 CHANGE TO STRUT	943	PASS C/S AF 2 1/2 AR 2 1/2		Z
GBC 101H 257 MAIN STEAM 'A' LINE IN CONT	01331	35			04/15/92 CNG TO STRT, PP-5'6"	1530	PASS C/S AF 2 1/2 AR 2 1/2		Z
GBC 101H 262 MAIN STEAM 'A' LINE IN CONT	01505	35		92-131	X P/P 8' 2 5/8"	0			X
GBC 101H 263 MAIN STEAM 'A' LINE IN CONT	01513	35			04/13/92	1312	PASS C/S AF 3 1/2 AR 3 1/2		Z
GBC 101H 264 MAIN STEAM 'A' LINE IN CONT	01509	35			04/14/92 P/P-8'1"	1051	DEGRADE C/S AF 2 AR 2		Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBC 101H 265 MAIN STEAM 'A' LINE IN CONT	01389	35	S	92-045	03/14/92	1446	PASS P/P 4'2 1/4"	C/S AF 3 1/8" AR 3 1/8"	03/19/92
GBC 101H 266A MAIN STEAM 'A' LINE IN CONT	01349	35			04/13/92	1341	PASS CHANGE TO STRUT, P/P-9'5"	C/S AF 3 AR 3	Z
GBC 101H 266B MAIN STEAM 'A' LINE IN CONT	01368	35			04/14/92	832	PASS CHANGE TO STRUT, P/P-9'5"	C/S AF 3 AR 3	Z
GBC 101H 267 MAIN STEAM 'A' LINE IN CONT	01379	35			04/14/92	855	PASS CNG TO STRT, PP-4'11C/S AF 3 1/4	AR 3 1/4	Z
GBC 101H 268 MAIN STEAM 'A' LINE IN CONT	01531	35			04/09/92	1038	PASS P/P-7'8"	C/S AF 3 AR 3	Z
GBC 101H 271 MAIN STEAM 'A' LINE IN CONT	03497	35			04/10/92	744	PASS	C/S AF 4 AR 4	Z
GBC 101H 272 MAIN STEAM 'A' LINE IN CONT	06967	35			X	0			X
GBC 101H 273 MAIN STEAM 'A' LINE IN CONT	02632	35		92-131	X	0			X
GBC 101H 274 MAIN STEAM 'A' LINE IN CONT	02614	35			04/09/92	846	PASS	C/S AF 3.5 AR 3.5	Z
GBC 101H 275 MAIN STEAM 'A' LINE IN CONT	02676	35			04/09/92	812	PASS	C/S AF 3.5 AR 3.5	Z
GBC 101H 276 MAIN STEAM 'A' LINE IN CONT	03243	35	S		03/17/92	1043	PASS C/S AF 4 1/2"	AR 4 1/2"	03/19/92
GBC 101H 277A MAIN STEAM 'B' LINE IN CONT	03188	35	S		03/24/92	828	PASS C/S AF 1.25 AR 1.25		Z
GBC 101H 277B MAIN STEAM 'B' LINE IN CONT	06962	35	S		03/18/92	1119	PASS C/S AF 2 1/2" AR 2 1/2"		03/21/92

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBC 101H 278 MAIN STEAM 'A' LINE IN CONT	04128	35			03/28/92	1435	PASS		Z
					CNG TO STRT,P/P-7'5C/S AF 2 1/2 AR 2 1/2				
GBC 101H 279 MAIN STEAM 'A' LINE IN CONT	03645	35			03/29/92	850	PASS		Z
					CNG TO STRT,P/P-7'11"C/S AF 3 3/8 AR 3.5				
GBC 101H 281 MAIN STEAM 'D' LINE IN CONT	03261	35		92-108	X	0			X
GBC 101H 282 MAIN STEAM 'A' LINE IN CONT	01501	35	S		03/28/92	1144	PASS		Z
					CNG TO STRUT,P/P-5'9"C/S AF 3.25 AR 3.25				
GBC 101H 301 MAIN STEAM 'C' LINE IN CONT	14794	10	S		03/26/92	1636	PASS		Z
					CHANGE TO STRUT C/S AF 2 1/2 AR 2 1/2				
GBC 101H 316A MAIN STEAM 'C' LINE IN CONT	01186	35			04/16/92	1437	PASS		Z
					CNG TO STRT,PP-3'10C/S AF 2 1/2 AR 2 1/2				
GBC 101H 316B MAIN STEAM 'C' LINE IN CONT	02574	35			04/16/92	1508	PASS		Z
					CNG TO STRT,PP-3'10C/S AF 2 1/2 AR 2 1/2				
GBC 101H 318A MAIN STEAM 'C' LINE IN CONT	00383	10	S		03/15/92	20	PASS		04/03/92
					P/P 4'1 9/16" C/S AF 3 1/2 AR 3 1/2				
GBC 101H 318B MAIN STEAM 'C' LINE IN CONT	13666	10	S		03/14/92	2353	PASS		04/03/92
					P/P 4'1 9/16" C/S AF 3 5/8 AR 3 5/8				
GBC 101H 330 MAIN STEAM 'D' LINE IN CONT	06965	35			04/16/92	1120	PASS		Z
					CHANGE TO STRUT C/S AF 3 1/2 AR 3 1/2				
GBC 101H 331 MAIN STEAM 'D' LINE IN CONT	06949	35			04/09/92	1344	PASS		Z
					CHANGE TO STRUT C/S AF 2 1/2 AR 2 1/2				
GBC 101H 332 MAIN STEAM 'D' LINE IN CONT	06950	35			X	0			X
GBC 101H 333 MAIN STEAM 'C' LINE IN CONT	06963	35			04/13/92	809	PASS		Z
					C/S AF 3.25 AR 3.25				

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
GBC 105H 5A DIV I LPCI/SDC RHR	02155	3			X P/P 2'8 3/8"	0			X
GBC 105H 5B DIV I LPCI/SDC RHR	02145	3			X P/P 2'8 3/8"	0			X
GBD 122H 5 FW COMMON DISCH	00276	10L			X	0			X
HBB 101H 2 RCIC STM EXHAUST	07404	35	S	92-045	03/10/92 PP 3'-11 1/8"	1457	PASS	C/S AF 3" AR 3"	03/11/92
HBB 101H 4 RCIC STM EXHAUST	16755	1			X	0			X
HBB 101H 10A RCIC STM EXHAUST	12204	1			X PP 5'-1"	0			X
HBB 101H 10B RCIC STM EXHAUST	12206	1			X PP 5'-1 1/2"	0			X
HBB 103H 3 RCIC LARGE PIPE SUCTION	05007	1			X	0			X
HBB 104H 10 CORE SPRAY 'A' LOOP SUCT	26083	1			X PP 3'-9 1/2"	0			X
HBB 104H 11 CORE SPRAY 'A' LOOP SUCT	03571	3			X	0			X
HBB 104H 12 CS'B'LOOP SUCT & HPCI LP SUCT.	02429	1			X PP 3'-5 1/2"	0			X
HBB 104H 13 CS'B'LOOP SUCT & HPCI LP SUCT.	02098	10			X PP 4'-6 3/4"	0			X
HBB 104H 16 CS'B'LOOP SUCT & HPCI LP SUCT.	06069	3			X PP 4'-8 5/8"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HBB 104H 27 CORE SPRAY 'A' LOOP SUCT	14453	1/2	F		03/11/92 PP 5'-7 7/8"	827	PASS C/S AF 1 1/2" AR 1 1/2"		03/12/92
HBB 104H 30 CORE SPRAY 'A' LOOP SUCT	21564	1	F		03/11/92	908	PASS C/S AF 2" AR 2"		03/12/92
HBB 104H 34 CS'B'LOOP SUCT & HPCI LP SUCT	02123	10			X	0			X
HBB 104H 35 CS'B'LOOP SUCT & HPCI LP SUCT.	09489	35			X PP 6'-3 1/4"	0			X
HBB 104H 39A CS'B'LOOP SUCT & HPCI LP SUCT.	11101	10			X PP 3'-2 3/8"	0			X
HBB 104H 39B CS'B'LOOP SUCT & HPCI LP SUCT.	04266	10			X PP 3'-2 3/8"	0			X
HBB 107H 2A CS'B'LOOP SUCT & HPCI LP SUCT.	00374	10			X PP 3'-1 9/16"	0			X
HBB 107H 2B CS'B'LOOP SUCT & HPCI LP SUCT.	03110	35			X PP 3'-4 1/2"	0			X
HBB 107H 4 CS'B'LOOP SUCT & HPCI LP SUCT.	08308	10			X	0			X
HBB 108H 1 HPCI STM EXHAUST	04850	10			X	0			X
HBB 108H 2 HPCI STM EXHAUST	08609	35			X PP 5'-6 1/2"	0			X
HBB 108H 7 HPCI STM EXHAUST	21107	1/4			X	0			X
HBB 108H 8 HPCI STM EXHAUST	12205	1			X PP 5'-8 5/16"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 H = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID SYSTEM DESC	SERIAL	SIZE	ORIGIN	NCR NUM NCR NUM	TEST DATE MEMO	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
HBB 108H 11 HPCI STM EXHAUST	08608	35			X PP 4'-5/8"	0			X
HBB 108H 12A HPCI STM EXHAUST	01327	100			X PP 6'-2"	0			X
HBB 108H 12B HPCI STM EXHAUST	01326	100			X PP 6'-2"	0			X
HBB 109H 6 CS'B'LOOP SUCT & HPCI LP SUCT.	02807	35			X PP 4'-4 3/16"	0			X
HBB 109H 7 CS'B'LOOP SUCT & HPCI LP SUCT.	02093	10			X PP 4'-9"	0			X
HBB 110H 3 RHR PUMP SUCT IMPACTING	00572	100			X	0			X
HBB 110H 12 RHR PUMP SUCT IMPACTING	01098	100			X PP 4'-3 1/2"	0			X
HBB 110H 21 RHR PUMP SUCT IMPACTING	01143	100			X	0			X
HBB 110H 27 RHR PUMP SUCT IMPACTING	00945	100			X	0			X
HBB 110H 32 RHR PUMP SUCT IMPACTING	06070	3			X PP 3'-4 1/2"	0			X
HBB 110H 33 RHR PUMP SUCT IMPACTING	04605	10	F		03/26/92 PP 3'-2 3/4"	1256	PASS		04/01/92
HBB 110H 35 RHR PUMP SUCT IMPACTING	04606	10			X PP 3'-4 5/8"	0		C/S AF 3.25 AR 3.25	X
HBB 110H 36 RHR PUMP SUCT IMPACTING	07536	35			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HBB 110H 37 RHR PUMP SUCT IMPACTING	07524	35			X		0		X
HBB 110H 38 RHR PUMP SUCT IMPACTING	04607	10			X PP 3'-5"		0		X
HBB 110H 39 RHR PUMP SUCT IMPACTING	03067	35			X PP 5'-7 11/16"		0		X
HBB 110H 42 RHR PUMP SUCT IMPACTING	01641	100			X		0		X
HBB 110H 43 RHR PUMP SUCT IMPACTING	03221	35			X PP 4'-5 1/4"		0		X
HBB 110H 44A RHR PUMP SUCT IMPACTING	08613	35			X PP 8'-6 1/4"		0		X
HBB 110H 44B RHR PUMP SUCT IMPACTING	08614	35			X PP 8'-6 1/4"		0		X
HBB 110H 45 RHR PUMP SUCT IMPACTING	03206	35			X		0		X
HBB 110H 47 RHR PUMP SUCT IMPACTING	00557	100			X		0		X
HBB 110H 50 RHR PUMP SUCT IMPACTING	12222	10			X		0		X
HBB 111H 5 RHR PUMP SUCT IMPACTING	04608	10			X		0		X
HBB 111H 11 RHR PUMP SUCT IMPACTING	12270	10			X		0		X
HBB 111H 12 RHR PUMP SUCT IMPACTING	03426	1			X PP 2'-6 3/4"		0		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE



UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HBB 111H 15 RHR PUMP SUCT IMPACTING	02423	1			X PP 2'-5 5/8"	0			X
HBB 111H 23 RHR PUMP SUCT IMPACTING	09266	10			X	0			X
HBB 111H 29A RHR PUMP SUCT IMPACTING	07538	35			X	0			X
HBB 111H 29B RHR PUMP SUCT IMPACTING	01328	100			X P/P 8'0 3/8"	0			X
HBB 111H 30 RHR PUMP SUCT IMPACTING	03482	35			X	0			X
HBB 111H 31A RHR PUMP SUCT IMPACTING	08603	35			X PP 4'-11"	0			X
HBB 111H 31B RHR PUMP SUCT IMPACTING	08604	35			X PP 4'-7 1/4"	0			X
HBB 111H 32A RHR PUMP SUCT IMPACTING	01347	35			X PP 3'-5"	0			X
HBB 111H 32B RHR PUMP SUCT IMPACTING	01319	35			X PP 5'-7/8"	0			X
HBB 111H 33A RHR PUMP SUCT IMPACTING	00968	35			X PP 4'-4 3/8"	0			X
HBB 111H 33B RHR PUMP SUCT IMPACTING	02642	35			X	0			X
HBB 111H 34 RHR PUMP SUCT IMPACTING	03256	35			X	0			X
HBB 111H 37 RHR COMMON IMPACTING	04272	10			X PP 5'-5 3/4"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HBB 113H RCIC LARGE PIPE SUCTION	4 03018	1			X PP 2'-3 3/8"	0			X
HBB 116H CAC PURGE	1 13424	1/2			X	0			X
HBB 118H CAC PURGE	7 08606	35			X PP 8'-5 3/4"	0			X
HBB 118H CAC PURGE	8 08637	35			X PP 6'-11 1/2"	0			X
HBB 118H CAC PURGE	9 06934	35			X	0			X
HBB 118H CAC PURGE	10 02096	10	S		03/10/92	1005	PASS	C/S AF 2.25 AR 2.25	03/12/92
HBB 118H CAC PURGE	11 03197	35			X	0			X
HBB 118H CAC PURGE	12 03200	35			X	0			X
HBB 118H CAC PURGE	13 06941	35			X	0			X
HBB 118H CAC PURGE	14A 00854	3	S		03/10/92 PP 2'-6 3/4"	1413	PASS	C/S AF 2.25 AR 2.25	03/12/92
HBB 118H CAC PURGE	14B 00852	3	S		03/10/92 PP 3'-2 5/8"	1450	PASS	C/S AF 2.25 AR 2.25	03/12/92
HBB 118H CAC PURGE	15 01216	10	S		03/10/92	1504	PASS	C/S AF 2.75 AR 2.75	03/12/92
HBB 118H CAC PURGE	16 01278	3			X PP 5'-1 1/2"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID SYSTEM DESC	SERIAL	SIZE	ORIGIN	NCR NUM NCR NUM	TEST DATE MEMO	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
HBB 118H 17 CAC PURGE	08319	10			X PP 5'-7 7/8"	0			X
HBB 118H 18 CAC PURGE	14786	10	S		03/10/92 PP 3'-2 3/16"	1519	PASS	C/S AF 3 AR 3	03/12/92
HBB 118H 19 CAC PURGE	02184	10			X	0			X
HBB 118H 20 CAC PURGE	04275	10			X PP 5'-4 1/4"	0			X
HBB 118H 21A CAC PURGE	13420	1/2			X	0			X
HBB 118H 21B CAC PURGE	13399	1/2			X	0			X
HBB 118H 22 CAC PURGE	12223	10			X	0			X
HBB 118H 23 CAC PURGE	17223	1	S		03/10/92	1052	PASS	C/S AF 1 1/4" AR 1 1/4"	03/12/92
HBB 118H 25 CAC PURGE	12277	10			X	0			X
HBB 118H 26 CAC PURGE	14793	10			X	0			X
HBB 125H 2 RBCW 'A' LOOP COOLING CONT	03281	1/4			03/18/92 P/P-1'9"	158	FAIL	C/S AF 1 3/4 AR 1 3/4	Z
HBB 126H 2 RBCW 'A' LOOP COOLING CONT	13460	1/2		92-080	03/24/92	22	PASS	C/S AF 1 3/8 AR 0	Z
HBC 4H 1 DIESEL GEN A	01688	1			X P/P-2'3"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HBC 4H 6 DIESEL GEN A	03185	35			X		0		X
HBC 5H 5A DIESEL GEN A	00323	10L			X		0		X
HBC 5H 5B DIESEL GEN A	00319	10L			X		0		X
HBC 5H 6A DIESEL GEN A	04270	10			X P/P-4'3"		0		X
HBC 5H 6B DIESEL GEN A	04278	10			X P/P-4'3"		0		X
HBC 5H 9 DIESEL GEN A	19502	3			X		0		X
HBC 5H 10A DIESEL GEN A	02474	3			X P/P-3'6"		0		X
HBC 5H 10B DIESEL GEN A	21558	1			X P/P-3'5"		0		X
HBC 5H 17 DIESEL GEN A	19446	3			X		0		X
HBC 5H 18 DIESEL GEN A	19463	3			X P/P-3'8"		0		X
HBC 5H 20A DIESEL GEN A	00219	3L			X P/P-5'3"		0		X
HBC 5H 20B DIESEL GEN A	00222	3L			X P/P-5'3"		0		X
HBC 5H 22 DIESEL GEN A	19449	3			X PP 3'-8 1/8"		0		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID ----- SYSTEM DESC -----	SERIAL -----	SIZE -----	ORIGIN -----	NCR NUM ----- NCR NUM -----	TEST DATE ----- MEMO -----	TEST TIME	PASS FAIL	REPLACED S/NUM -----	REINSTALLED DATE -----
HBC 5H 23 DIESEL GEN A	19468	3			X P/P-3'8"	0			X
HBC 7H 1 DIESEL GEN B	05421	1			X P/P-3'6"	0			X
HBC 7H 6 DIESEL GEN B	07535	35			X	0			X
HBC 8H 2 DIESEL GEN B	19504	3			X PP 4'-8 3/8"	0			X
HBC 8H 5A DIESEL GEN B	00318	10L			X	0			X
HBC 8H 5B DIESEL GEN B	00398	10L			X	0			X
HBC 8H 7 DIESEL GEN B	03073	3			X	0			X
HBC 8H 9A DIESEL GEN B	19553	3			X	0			X
HBC 8H 9B DIESEL GEN B	19551	3			X	0			X
HBC 8H 15 DIESEL GEN B	19571	3			X P/P-3'11"	0			X
HBC 8H 17A DIESEL GEN B	19510	3			X P/P-4'5"	0			X
HBC 8H 17B DIESEL GEN B	19555	3			X P/P-4'5"	0			X
HBC 8H 20 DIESEL GEN B	02478	3			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID ----- SYSTEM DESC -----	SERIAL -----	SIZE -----	ORIGIN -----	NCR NUM ----- NCR NUM -----	TEST DATE ----- MEMO -----	TEST TIME -----	PASS FAIL -----	REPLACED S/NUM -----	REINSTALLED DATE -----
HBC 9H 1 DIESEL GEN C	05423	1			X P/P-2'2"	0			X
HBC 9H 6 DIESEL GEN C	03211	35			X	0			X
HBC 11H 2 DIESEL GEN C	08629	35			X P/P-4'1"	0			X
HBC 11H 4A DIESEL GEN C	08630	35			X P/P-4'2"	0			X
HBC 11H 4B DIESEL GEN C	01348	35			X P/P-4'2"	0			X
HBC 11H 5A DIESEL GEN C	19549	3			X P/P-4'5"	0			X
HBC 11H 5B DIESEL GEN C	19498	3			X P/P-4'5"	0			X
HBC 11H 8 DIESEL GEN C	04060	3			X	0			X
HBC 11H 10A DIESEL GEN C	19561	3			X	0			X
HBC 11H 10B DIESEL GEN C	19570	3			X	0			X
HBC 11H 15 DIESEL GEN C	19448	3			X	0			X
HBC 11H 16 DIESEL GEN C	03556	3			X P/P-3'9"	0			X
HBC 11H 17A DIESEL GEN C	19499	3			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID SYSTEM DESC	SERIAL	SIZE	ORIGIN	NCR NUM NCR NUM	TEST DATE MEMO	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
HBC 11H 17B DIESEL GEN C	19519	3			X		0		X
HBC 12H 4 DIESEL GEN D	01920	1			X		0		X
HBC 12H 6 DIESEL GEN D	02750	35			X		0		X
HBC 13H 2 DIESEL GEN D	00388	10			X PP 4'-4 3/8"		0		X
HBC 13H 4 DIESEL GEN D	06955	35			X		0		X
HBC 13H 6A DIESEL GEN D	07210	3			X PP 4'-3 1/4"		0		X
HBC 13H 6B DIESEL GEN D	04609	3			X PP 4'-3 1/4"		0		X
HBC 13H 9 DIESEL GEN D	19557	3			X		0		X
HBC 13H 11A DIESEL GEN D	00677	3			X		0		X
HBC 13H 11B DIESEL GEN D	06576	3			X		0		X
HBC 13H 16 DIESEL GEN D	02665	35			X P/P-4'5"		0		X
HBC 13H 18 DIESEL GEN D	19554	3			X P/P-3'10"		0		X
HBC 13H 19A DIESEL GEN D	00220	3L			X		0		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HBC 13H 19B DIESEL GEN D	00216	3L			X		0		X
HBC 117H 2 RHR COMMON IMPACTING	04583	10			X		0		X
HBC 117H 7 RHR COMMON IMPACTING	06812	3			X PP 2'-7 1/2"		0		X
HBC 117H 8 RHR COMMON IMPACTING	20804	1			X PP 2'-7 1/8"		0		X
HBC 117H 9 RHR COMMON IMPACTING	14390	1/2			X PP 2'-9 1/8"		0		X
HBC 117H 10 RHR COMMON IMPACTING	00105	1L			X PP 4'-3/4"		0		X
HBC3300H 2A DIESEL GEN E	07000	3			X CHANGE TO STRUT		0		X
HBC3300H 2B DIESEL GEN E	06890	3			X		0		X
HBC3300H 8 DIESEL GEN E	06978	3			X CHANGE TO STRUT		0		X
HBC3302H 5 DIESEL GEN E	22816	1			X		0		X
HBC3302H 6 DIESEL GEN E	22813	1			X PP 2'-1 1/4"		0		X
HBC3303H 4 DIESEL GEN E	07074	3			X CHANGE TO SPRING CAN		0		X
HBD 101H 1 MOIST SEP PIPING	03089	35	S	92-045 92-044	03/12/92 PP 6'-1 3/8"	1512	PASS C/S AF 2 1/2" AR 2 1/2"		03/19/92

I GEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HBD 101H 3 MOIST SEP PIPING	01288	3			03/28/92 PP 4'-5 3/4"	1029	PASS	C/S AF 2 AR 2	04/26/92
HBD 101H 4 MOIST SEP PIPING	01277	3	S		03/10/92 PP 4'-5 3/4"	836	PASS	C/S AF 2.5 AR 2.5	03/12/92
HBD 101H 5 MOIST SEP PIPING	00446	3			X PP 4'-11 1/2"	0			X
HBD 101H 6 MOIST SEP PIPING	01225	10			X PP 2'-9 1/4"	0			X
HBD 101H 8 MOIST SEP PIPING	04283	35			X PP 8'-1/4"	0			X
HBD 101H 10A MOIST SEP PIPING	04254	10			X PP 5'-4 15/16"	0			X
HBD 101H 10B MOIST SEP PIPING	04257	10			X PP 5'-4 5/16"	0			X
HBD 101H 11 MOIST SEP PIPING	04937	3			X PP 4'-5 1/4"	0			X
HBD 101H 12A MOIST SEP PIPING	07096	3			X PP 4'-2 3/8"	0			X
HBD 101H 12B MOIST SEP PIPING	07095	3			X PP 4'-2 3/8"	0			X
HBD 101H 14A MOIST SEP PIPING	01287	10			X	0			X
HBD 101H 14B MOIST SEP PIPING	01249	10			X	0			X
HBD 101H 16A MOIST SEP PIPING	01242	10			X PP 6'-2 1/4"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HBD 101H 16B MOIST SEP PIPING	01221	10			X PP 3'-11 5/8"	0			X
HBD 101H 17 MOIST SEP PIPING	00452	3			X PP 4'-10"	0			X
HBD 101H 18 MOIST SEP PIPING	05841	1			X PP 5'-5"	0			X
HBD 103H 1A MOIST SEP PIPING	04351	10	S		03/10/92 PP 5'-9"	904	PASS	C/S AF 3.25 AR 3.25	03/12/92
HBD 103H 1B MOIST SEP PIPING	04347	10	S		03/10/92 PP 5'-8 5/8"	937	PASS	C/S AF 3.25 AR 3.25	03/12/92
HBD 103H 3A MOIST SEP PIPING	00233	1			X PP 3'-8"	0			X
HBD 103H 3B MOIST SEP PIPING	00234	1			X PP 3'-8"	0			X
HBD 103H 6A MOIST SEP PIPING	01277	10			X PP 3'-6"	0			X
HBD 103H 6B MOIST SEP PIPING	01274	10			X PP 3'-6"	0			X
HBD 103H 8A MOIST SEP PIPING	01388	1			X PP 3'-9 11/16"	0			X
HBD 103H 8B MOIST SEP PIPING	01346	1			X PP 3'-9 11/16"	0			X
HBD 103H 11A MOIST SEP PIPING	04346	10			X PP 5'-8"	0			X
HBD 103H 11B MOIST SEP PIPING	04346	10			X PP 5'-8"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HBD 103H 13A MOIST SEP PIPING	00232	1	S		03/10/92 PP 3'-8 1/2"	921	PASS	C/S AF 1 5/8" AR 1 5/8"	03/12/92
HBD 103H 13B MOIST SEP PIPING	18790	1	R		03/10/92 PP 3'-8 1/2"	836	PASS	C/S AF 2" AR 2"	03/12/92
HBD 188H 3 RBCW'A'LOOP COOLING CONT	02860	1			03/21/92	315	PASS	C/S AF 1 1/2 AR 1 1/2	Z
HBD 188H 4 RBCW'A'LOOP COOLING CONT	03145	1			03/21/92	253	PASS	C/S AF 1 1/2 AR 1 1/2	Z
HBD 188H 5 RBCW'A'LOOP COOLING CONT	03498	1			03/18/92	1422	PASS	C/S AF 2 AR 2	Z
HBD 188H 7 RBCW'A'LOOP COOLING CONT	07289	1			03/20/92	233	PASS	C/S AF 2 AR 2	Z
HBD 188H 8A RBCW'A'LOOP COOLING CONT	10742	1/2			03/20/92	257	PASS	C/S AF 1 AR 1	Z
HBD 188H 8B RBCW'A'LOOP COOLING CONT	13946	1/2			03/18/92 P/P-2'6"	2203	PASS	C/S AF 1 1/4 AR 1 1/4	Z
HBD 188H 11A RBCW'A'LOOP COOLING CONT	00399	10L			03/21/92 P/P-5'3"	1118	PASS	C/S AF 3.25 AR 3.25	Z
HBD 188H 11B RBCW'A'LOOP COOLING CONT	00238	10L			03/21/92 P/P-4'2"	1014	PASS	C/S AF 3.25 AR 3.25	Z
HBD 188H 12 RBCW'A'LOOP COOLING CONT	17234	1			03/19/92	1641	PASS	C/S AF 2 AR 2	Z
HBD 188H 14A RBCW'A'LOOP COOLING CONT	12961	1/2			03/22/92	1551	PASS	C/S AF 1 AR 1	Z
HBD 188H 14B RBCW'A'LOOP COOLING CONT	12977	1/2			03/22/92	2041	PASS	C/S AF 3/4 AR 3/4	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HBD 188H 15A RBCW'A'LOOP COOLING CONT	14381	1/2	S		03/22/92	1618	PASS	C/S AF 1.5 AR 1.5	Z
HBD 188H 15B RBCW'A'LOOP COOLING CONT	14386	1/2	S		03/20/92	1744	PASS	P/P-1'6"USE ON SPDBA112H41 C/S AF 1 AR 1	Z
HBD 188H 16 RBCW'A'LOOP COOLING CONT	14395	1/2			03/20/92	126	PASS	C/S AF 1 AR 1	Z
HBD 189H 2 RBCW'A'LOOP COOLING CONT	02602	1/2		92-080	03/24/92	52	PASS	C/S AF 1" AR 0	Z
HBD 189H 3 RBCW'A'LOOP COOLING CONT	29317	1/4	S		03/23/92	1258	PASS	C/S AF 1 1/2" AR 1 1/2"	Z
HBD 189H 5 RBCW'A'LOOP COOLING CONT	06810	3			03/19/92	1549	PASS	C/S AF 2 AR 2	Z
HBD 189H 6 RBCW'A'LOOP COOLING CONT	22923	1/4			03/18/92	2329	PASS	C/S AF 2 3/4 AR 2 3/4	Z
HBD 189H 7 RBCW'A' LOOP COOLING CONT	23352	1/4	S	92-085	03/18/92	2112	DEGRADE	C/S AF 1 3/4" AR 1 3/4"	Z
HBD 189H 8 RBCW'A'LOOP COOLING CONT	06798	3		92-080	03/24/92	221	PASS	C/S AF 2 AR 0	Z
HBD 189H 9 RBCW'A'LOOP COOLING CONT	02437	1			03/23/92	245	PASS	C/S AF 1 AR 1	Z
HBD1039H 1 RBCW'B'LOOP COOLING CONT	12181	1	F		04/06/92	1258	PASS	USEONSPDBA105H2001,PP-3'8"C/S AF2.5,2.25	Z
HBD1039H 2 RBCW'B'LOOP COOLING CONT	06581	3			04/05/92	811	PASS	C/S AF 2.5 AR 2.5	Z
HBD1039H 3 RBCW'B'LOOP COOLING CONT	06582	3			04/06/92	1408	PASS	CHN TO STRT,P/P-3'11"C/S AF 2.5 AR 2.5	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HBD1039H 7 RBCW'B'LOOP COOLING CONT	17228	1			04/06/92	1338	PASS	C/S AF 1.75 AR 2.25	Z
HBD1039H 11 RBCW'B'LOOP COOLING CONT	17211	1/2			04/05/92	822	PASS	C/S AF 1 AR 1	Z
HBD1039H 12 RBCW'B'LOOP COOLING CONT	12960	1/2			04/05/92	805	PASS	C/S AF 1 1/2 AR 1 1/2	Z
HBD1040H 3 RBCW'B'LOOP COOLING CONT	02403	1			04/08/92 CHANGED TO STRUT, P/P-2'5"	832	PASS	C/S AF 2 AR 2	Z
HBD1040H 9 RBCW'B'LOOP COOLING CONT	28862	1/4			03/22/92	1356	PASS	C/S AF 2.25 AR 2.25	Z
HBD1040H 10 RBCW'B'LOOP COOLING CONT	13050	1/4	F		03/23/92	2314	PASS	C/S AF 1 3/4 AR 1 3/4	Z
HBD1053H 47 RBCW'A'LOOP COOLING CONT	13411	1/2			X PP 1'-10 3/8"	0			X
HBD3300H 3 DIESEL GEN E	22821	1			X	0			X
HCB 102H 4 CS'B'LOOP SUCT & HPCI LP SUCT.	06939	35			X	0			X
HCB 103H 6A CS'B'LOOP SUCT & HPCI LP SUCT.	00963	10	R		04/02/92	854	PASS	C/S AF 2 5/8 AR 2 5/8	04/06/92
HCB 103H 6B CS'B'LOOP SUCT & HPCI LP SUCT.	02194	10	F		04/02/92	751	FAIL	04279-78 C/S AF 2.75 AR 2.75	04/06/92
HCB 104H 7 RCIC LARGE PIPE SUCTION	14393	1/2			X	0			X
HCC 106H 10A RHR COMMON IMPACTING	08700	10			X PP 4'-7 3/8"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HCC 106H 10B RHR COMMON IMPACTING	08697	10			X PP 4'-7 3/8"	0			X
HCD 112H 21 RHR COMMON IMPACTING	03873	1/2			X PP 4'-10 5/8"	0			X
HCD 112H 22 RHR COMMON IMPACTING	10726	1/2			X PP 1'-10 5/8"	0			X
HCD 115H 14A CORE SPRAY 'A' LOOP SUCT	06954	35			X	0			X
HCD 115H 14B CORE SPRAY 'A' LOOP SUCT	06938	35			X	0			X
HRC 2H 9 ESW/RHR SW LOOP B RETURN	00457	1			X	0			X
HRC 2H 20 ESW/RHR SW LOOP B RETURN	17220	1			X	0			X
HRC 2H 22 ESW/RHR SW LOOP B RETURN	03484	1			X	0			X
HRC 2H 26 ESW/RHR SW LOOP B RETURN	19501	3			X	0			X
HRC 13H 15 ESW U1 B LOOP	08317	10			X	0			X
HRC 14H 18 ESW U1 B LOOP	12201	1			X	0			X
HRC 14H 19 ESW 'B' LOOP ISOLABLE PIPE	04575	3			X	0			X
HRC 14H 20 ESW 'B' LOOP ISOLABLE PIPE	03134	1			X PP 2'-9 1/2"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HRC 17H 4	26081	1			X-		0		X
ESW 'A' LOOP	ISOLABLE PIPE				PP 3'-11"				
HRC 17H 5	18578	1			X		0		X
ESW 'A' LOOP	ISOLABLE PIPE				PP 3'-9"				
HRC 17H 6	17217	1			X		0		X
ESW 'A' LOOP	ISOLABLE PIPE				PP 4'-4 3/4"				
HRC 22H 7	04255	10			X		0		X
ESW 'B' LOOP	ISOLABLE PIPE				PP 3'-3 3/4"				
HRC 22H 16	18573	1			X		0		X
ESW 'B' LOOP	ISOLABLE PIPE								
HRC 22H 18	18557	1			X		0		X
ESW 'B' LOOP	ISOLABLE PIPE								
HRC 102H 7A	00230	1			X		0		X
ESW UNIT 1&2 'A' LOOP					PP 2'-3 1/4"				
HRC 102H 7B	00231	1			X		0		X
ESW UNIT 1&2 'A' LOOP					PP 2'-3 1/4"				
HRC 105H 13A	05003	1			X		0		X
ESW/RHRSW UNIT 1&2 'A' LOOP					PP 4'-4 1/4"				
HRC 105H 13B	18839	1		92-088	X		0		X
ESW/RHRSW UNIT 1&2 'A' LOOP					PP 4'-4 1/4"				
HRC 123H 15	27958	1/4			X		0		X
ESW U1 B LOOP					PP 4'-10 5/8"				
HRC 123H 16	17218	1/2			X		0		X
ESW UNIT 1&2 'A' LOOP					PP 3'-1/4"				
HRC 124H 8	20796	1			X		0		X
ESW U1 B LOOP					PP 4'-1 1/8"				

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
HRC 131H 1 ESW U1 B LOOP	02263	1/2			X		0		X
JRD 32H 2 ESW/RHR SW LOOP B RETURN	17235	1			X		0		X
JRD 32H 4 ESW/RHR SW LOOP B RETURN	21563	1			X		0		X
JRD 107H 14 TBCCW ESW U1&2 A&B LOOP	08222	10			X		0		X
JRD 107H 15 TBCCW ESW U1&2 A&B LOOP	13403	10			X		0		X
JRD 128H 17 RBCCW ESW U1&2 A&B LOOP	18576	1	F		04/04/92 PP 5'-3/8"	1455	PASS	C/S AF 2 AR 2	04/06/92
JRD 128H 18 RWCCW ESW U1&2 A&B LOOP	17216	1			X PP 3'-4 7/16"		0		X
JRD 128H 19A RBCCW ESW U1&2 A&B LOOP	01655	1			X		0		X
JRD 128H 19B RBCCW ESW U1&2 A&B LOOP	06723	3			X		0		X
JRD 128H 22A RBCCW ESW U1&2 A&B LOOP	12409	10			X		0		X
JRD 128H 22B RBCCW ESW U1&2 A&B LOOP	13407	10			X		0		X
JRD 128H 23 RBCCW ESW U1&2 A&B LOOP	01234	10			X		0		X
JRD 128H 24 RBCCW ESW U1&2 A&B LOOP	08610	35			X PP 5'-1 3/8"		0		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
JRD 129H 16A ESW U1 B LOOP	28854	1/4			X		0		X
JRD 129H 16B ESW U1 B LOOP	28855	1/4			X		0		X
JRD 129H 19 ESW U1 A LOOP	07532	10			X PP 4'-1/2"		0		X
JRD 129H 20A ESW U1 A LOOP	13789	10			X		0		X
JRD 129H 20B ESW U1 A LOOP	08701	10			X		0		X
JRD 129H 23 ESW U1 A LOOP	20840	1	F		03/17/92 PP 4'-5 1/2"	1053	DEGRADE	20840 C/S AF 1 7/8 AR 1 7/8	03/18/92
JRD 129H 24A ESW U1 A LOOP	14776	10			X PP 3'-2 3/8"		0		X
JRD 129H 24B ESW U1 A LOOP	13377	10			X PP 3'-2 3/8"		0		X
MSL 100H 1 MAIN TURB STEAM	01508	35	S		03/10/92	1408	PASS C/S AF 1 3/4" AR 1 3/4"		03/19/92
MSL 100H 2 MAIN TURB STEAM	01638	100	R	92-045	03/14/92 PP7'-6 1/4"	1355	PASS RETEST/QC 3/16 C/S AF,AR 2.25		03/19/92
MSL 100H 3 MAIN TURB STEAM	09515	35	S	92-045	03/13/92 PP 8'-8 3/4"	1358	PASS C/S AF 2.5 AR 2.5		03/19/92
MSL 100H 5A MAIN TURB STEAM	02573	10	R		03/10/92 PP 3'-3"	1719	PASS C/S AF 4.25 AR 4.25		03/19/92
MSL 100H 5B MAIN TURB STEAM	14780	10	R		03/10/92 PP 3'-3"	1545	PASS C/S AF 3 5/8" AR 3/5/8"		03/19/92

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID ----- SYSTEM DESC	SERIAL -----	SIZE ----	ORIGIN -----	NCR NUM ----- NCR NUM -----	TEST DATE ----- MEMO -----	TEST TIME -----	PASS FAIL -----	REPLACED S/NUM -----	REINSTALLED DATE -----
MSL 100H 6A MAIN TURB STEAM	02570	10	R		03/10/92 PP 3'-4"	1612	PASS	C/S AF 1.5" AR 1.5"	03/19/92
MSL 100H 6B MAIN TURB STEAM	02569	10	R		03/10/92 PP 3'-4"	1641	PASS	C/S AF 2 AR 2	03/19/92
MSL 100H 7 MAIN TURB STEAM	06943	35	F	92-045	03/12/92 PP 5'-9 1/4"	1552	PASS	C/S AF 4 1/8" AR 4 1/8"	03/13/92
MSL 100H 9A MAIN TURB STEAM	08611	35	S	92-045 92-040	03/13/92 PP 5'-3"	1114	PASS	C/S AF 2.25 AR 2.25	03/19/92
MSL 100H 9B MAIN TURB STEAM	02396	100	R		03/10/92	1542	FAIL	02396 C/S AF 2 1/2" AR 2 1/2"	03/19/92
MSL 100H 10A MAIN TURB STEAM	06952	35	R	92-045	03/12/92 PP 7'-11 7/16"	1558	PASS	C/S AF 2 3/4" AR 2 3/4"	03/19/92
MSL 100H 10B MAIN TURB STEAM	02582	35	R	92-045	03/13/92 PP 10'-7/16"	1055	FAIL	01294-78 C/S AF 2 AR 2	03/19/92
MSL 100H 11A MAIN TURB STEAM	02421	100	R		03/11/92	727	FAIL	01637-82 C/S AF 3 1/2" AR 3 1/2"	03/19/92
MSL 100H 11B MAIN TURB STEAM	02400	100	R		03/10/92	1706	PASS	C/S AF 3 1/2" AR 3 1/2"	03/19/92
MST 22H 11 MAIN STEAM 'D' LINE IN CONT	04094	35			X	0			X
MST 22H 12 MAIN STEAM 'D' LINE IN CONT	03642	35			X PP 7'-1/4"	0			X
MST 22H 13 MAIN STEAM 'D' LINE IN CONT	03634	35			04/16/92 P/P-7'0"	850	PASS	C/S AF 3 AR 3	Z
MST 22H 14 MAIN STEAM 'D' LINE IN CONT	03266	35			03/14/92 Z23109-MSV,P/P-7'9"	1457	PASS	C/S AF 1 1/4 AR 1 1/4	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
MST 22H 15 MAIN STEAM 'C' LINE IN CONT	03175	35			04/16/92 P/P-7'2"	918	PASS	C/S AF 3 AR 3	Z
MST 22H 16 MAIN STEAM 'C' LINE IN CONT	03265	35			X PP 6'-11"	0			X
MST 22H 17 MAIN STEAM 'D' LINE IN CONT	00188	100			X PP-7'1"	0			X
MST 22H 18 MAIN STEAM 'D' LINE IN CONT	00123	100			04/16/92	1540	PASS C/S AF 3 1/4 AR 3 1/4		Z
MST 22H 19 MAIN STEAM 'C' LINE IN CONT	04095	35			X	0			X
MST 22H 20 MAIN STEAM 'D' LINE IN CONT	03178	35			X PP 5'-10 1/2"	0			X
MST 22H 21 MAIN STEAM 'B' LINE IN CONT	01801	100			03/20/92	1426	PASS C/S AF 2 3/4" AR 2 3/4"		Z
MST 22H 22 MAIN STEAM 'B' LINE IN CONT	00576	100			X	0			X
MST 22H 24 MAIN STEAM 'B' LINE IN CONT	08641	35		92-085	03/15/92 PP 10'-4"	925	PASS C/S AF 4 1/2 AR 4 1/2		04/14/92
MST 22H 25 MAIN STEAM 'B' LINE IN CONT	04102	35			03/20/92	1131	PASS C/S AF 3 1/2" AR 3 1/2"		Z
MST 22H 26 MAIN STEAM 'B' LINE IN CONT	03179	35			03/24/92 P/P-7'2"	740	PASS C/S AF 2 5/8 AR 2		Z
MST 22H 27 MAIN STEAM 'B' LINE IN CONT	03264	35			X PP 6'-4 5/8"	0			X
MST 22H 28 MAIN STEAM 'B' LINE IN CONT	04118	35			03/21/92	735	PASS C/S AF 3 1/2" AR 3 1/2"		Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
MST 22H 29 MAIN STEAM 'A' LINE IN CONT	03263	35			X PP-7'-1 1/4"	0			X
MST 22H 30 MAIN STEAM 'A' LINE IN CONT	03267	35			X PP 7'-5 5/8"	0			X
MST 22H 31 MAIN STEAM 'A' LINE IN CONT	03371	35			03/14/92 C23012REWORKPP7'-3 1/2	1819	PASS -3 1/2 C/S AF,AR 3 1/2		04/14/92
MST 22H 32 MAIN STEAM 'A' LINE IN CONT	04103	35			X	0			X
MST 22H 33 MAIN STEAM 'A' LINE IN CONT	02414	100	F		04/15/92	1302	PASS C/S AF 4 1/4 AR 4 1/4		Z
MST 22H 34 MAIN STEAM 'A' LINE IN CONT	01332	100			04/15/92 P/P-7'2"	742	PASS C/S AF 3 5/8 AR 3 5/8		Z
MST 22H 35 MAIN STEAM 'A' LINE IN CONT	06969	35			X PP 7'-1/2"	0			X
MST 22H 36A MAIN STEAM 'D' LINE IN CONT	04101	35			X	0			X
MST 22H 36B MAIN STEAM 'D' LINE IN CONT	04108	35			X	0			X
MST 22H 37 MAIN STEAM 'D' LINE IN CONT	02025	100			X	0			X
MST 22H 38 MAIN STEAM 'D' LINE IN CONT	01799	100			X PP 4'-5 1/8"	0			X
MST 22H 39 MAIN STEAM 'C' LINE IN CONT	03373	35			X PP 4'-6 1/2"	0			X
MST 22H 40 MAIN STEAM 'C' LINE IN CONT	03374	35			04/16/92 P/P-6'6"	1052	PASS C/S AF 1 1/4 AR 1 1/4		Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
MST 22H 41	04125	35			X		0		X
MAIN STEAM 'C' LINE IN CONT									
MST 22H 42A	04090	35			X		0		X
MAIN STEAM 'A' LINE IN CONT									
MST 22H 42B	09525	35			X		0		X
MAIN STEAM 'A' LINE IN CONT									
MST 22H 44	04124	35			X		0		X
MAIN STEAM 'C' LINE IN CONT									
MST 22H 45	04117	35			04/13/92	853	PASS		Z
MAIN STEAM 'C' LINE IN CONT								C/S AF 3	AR 3
MST 22H 46	03375	35			04/15/92	1701	PASS		Z
MAIN STEAM 'A' LINE IN CONT					P/P-4'2"			C/S AF N/A	AR 2
MST 22H 47	04091	35			X		0		X
MAIN STEAM 'A' LINE IN CONT									
MST 22H 48	00566	100			X		0		X
MAIN STEAM 'B' LINE IN CONT									
MST 22H 49	03376	35			03/19/92	1642	PASS		Z
MAIN STEAM 'B' LINE IN CONT					P/P-4'0"			C/S AF 1 5/8"	AR 1 5/8"
MST 22H 50	03377	35			03/14/92	1628	PASS		04/14/92
MAIN STEAM 'C' LINE IN CONT					PP 10'-2"			C/S AF 2 1/2"	AR 2 1/2"
RWS 100H 1	03173	35			03/21/92	1407	PASS		Z
DIV I LPCI/SDC RECIRC					P/P-6'10"			C/S AF 2 1/2"	AR 2 1/2"
RWS 100H 2	03289	35		92-085	03/21/92	1604	PASS		Z
DIV I LPCI/SDC RECIRC					P/P-6'10"			C/S AF 2 1/2"	AR 1"
RWS 100H 3	03367	35	R		03/31/92	1336	PASS		Z
COMMON LPCI/SDC RECIRC					P/P-6'9"			C/S AF 2 3/4	AR 2 3/4

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
RWS 100H 4 COMMON LPCI/SDC RECIRC	03368	35	R		03/31/92 P/P-4'8"	736	PASS	C/S AF 3 1/4 AR 3 1/4	Z
RWS 100H 5 DIV I LPCI/SDC RECIRC	04112	35			03/22/92 CLAMP REMOVED	1152	PASS	C/S AF 2.5 AR 2.5	Z
RWS 100H 6 DIV I LPCI/SDC RECIRC	03725	35		92-085	03/22/92 CLAMP REMOVD,P/P-4'0"	1112	PASS	C/S AF3.25 AR 2 3/4	Z
RWS 100H 7 COMMON LPCI/SDC RECIRC	03718	35			04/04/92 CLAMP REMOVED	812	PASS	C/S AF 1 1/2 AR 1 1/2	Z
RWS 100H 8 COMMON LPCI/SDC RECIRC	03760	35			04/04/92 CLAMP REMOVED	900	PASS	C/S AF 4 AR 4	Z
RWS 100H 9 COMMON LPCI/SDC RECIRC	03638	35			04/09/92 P/P-4'10"	741	PASS	C/S AF 3 AR 3	Z
RWS 100H 10 COMMON LPCI/SDC RECIRC	03189	35			03/31/92	1102	FAIL	C/S AF 2.5 AR 2.5	Z
RWS 100H 11 DIV I LPCI/SDC RECIRC	03369	35			03/20/92 P/P-4'7"	825	PASS	C/S AF 2 1/2" AR 2 1/2"	Z
RWS 100H 12 DIV I LPCI/SDC RECIRC	03484	35			X	0			X
RWS 100H 13 COMMON LPCI/SDC RECIRC	03370	35			X P/P 8'2"	0			X
RWS 100H 14 COMMON LPCI/SDC RECIRC	04111	35			04/03/92	832	PASS	C/S AF 4 AR 4	Z
RWS 100H 15 DIV I LPCI/SDC RECIRC	04114	35			03/18/92 CLAMP REMOVED	1547	PASS	C/S AF 3 1/4" AR 3 1/4"	Z
RWS 100H 16 DIV I LPCI/SDC RECIRC	03720	35			03/18/92 CLAMP REMOVED	1341	PASS	C/S AF 3" AR 3"	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
RWS 100H 17 COMMON LPCI/SDC RECIRC	11028	35			04/04/92 CLAMP REMOVED	1034	PASS	C/S AF 2.5 AR 2.5	Z
RWS 100H 18 COMMON LPCI/SDC RECIRC	03762	35			04/04/92 CLAMP REMOVED	738	PASS	C/S AF 3 3/4 AR 3 3/4	Z
RWS 100H 19 DIV I LPCI/SDC RECIRC	03709	35			03/19/92	1358	PASS	C/S AF 3" AR 3"	Z
RWS 100H 20 DIV I LPCI/SDC RECIRC	03761	35			03/20/92	939	PASS	C/S AF 3 1/2" AR 3 1/2"	Z
RWS 100H 21 DIV I LPCI/SDC RECIRC	03711	35			03/18/92	1312	PASS	C/S AF 3 1/4" AR 3 1/4"	Z
RWS 100H 22 DIV I LPCI/SDC RECIRC	10539	35			03/21/92 P/P-7'2"	1029	PASS	C/S AF 3" AR 3"	Z
RWS 100H 23 COMMON LPCI/SDC RECIRC	02670	35			04/03/92	754	PASS	C/S AF 2.5 AR 3.5	Z
RWS 100H 24 COMMON LPCI/SDC RECIRC	03724	35			03/31/92 P/P-4'3"	1401	PASS	C/S AF 2 7/8 AR 2 7/8	Z
RWS 100H 25A DIV I LPCI/SDC RECIRC	04110	35			X	0			X
RWS 100H 25B DIV I LPCI/SDC RECIRC	04092	35			X	0			X
RWS 100H 26A COMMON LPCI/SDC RECIRC	04105	35		92-096	X	0			X
RWS 100H 26B COMMON LPCI/SDC RECIRC	04093	35		92-096	X	0			X
RWS 100H 27A DIV I LPCI/SDC RECIRC	08607	35		92-085	03/21/92 P/P-6'10"	1249	PASS	C/S AF 2 1/2" AR 2 1/2"	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
RWS 100H 27B DIV I LPCI/SDC RECIRC	03172	35			03/21/92 P/P-6'10"	1101	PASS C/S AF 3 1/2"	AR 3 1/2"	Z
RWS 100H 28A COMMON LPCI/SDC RECIRC	03248	35			03/31/92 CLAMP REMOVED,P/P-7'2"	1410	PASS C/S AF 4	AR 4	Z
RWS 100H 28B COMMON LPCI/SDC RECIRC	02591	35			04/07/92 P/P-7'5"	847	PASS C/S AF 3.5	AR 3.5	Z
RWS 100H 29 DIV I LPCI/SDC RECIRC	04090	35			X	0			X
RWS 100H 30 DIV I LPCI/SDC RECIRC	04116	35			X	0			X
RWS 100H 31 COMMON LPCI/SDC RECIRC	04123	35			X WA#Y10871	0			X
RWS 100H 32 COMMON LPCI/SDC RECIRC	04126	35			X	0			X
RWS 100H 33 DIV I LPCI/SDC RECIRC	03678	35	S	92-045	03/19/92 P/P 4'10"	1510	PASS WA Y10872	CS AF 3",CS AR 3"	03/29/92
RWS 100H 34 DIV I LPCI/SDC RECIRC	03745	35	S	92-045	03/19/92 P/P 5-2 1/2"	1432	PASS WA Y10872	CS AF,AR 2 1/2"	03/29/92
RWS 100H 35 COMMON LPSI/SDC RECIRC	03763	35			X	0			X
RWS 100H 36 COMMON LPSI/SDC RECIRC	03481	35			X	0			X
RWS 100H 37 COMMON LPSI/SDC RECIRC	03641	35	R		03/31/92 WA#Y10871,P/P-5'11"	1300	PASS C/S AF 2 1/4	AR 2 1/4	Z
RWS 100H 38 COMMON LPCI/SDC RECIRC	04107	35	R		04/02/92 WA#Y10871	1549	PASS C/S AF 3	AR 3	04/07/92

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
RWS 100H 39 DIV I LPCI/SDC RECIRC	03639	35		92-059	03/18/92 P/P-7'10"	1623	PASS C/S AF 4 1/2" AR 4 1/2"		Z
RWS 100H 40 DIV I LPCI/SDC RECIRC	03227	35			X	0			X
RWS 100H 41 COMMON LPCI/SDC RECIRC	01591	100			X P/P 7'3 3/4"	0			X
RWS 100H 42 COMMON LPSI/SDC RECIRC	00634	100			X P/P 5'11 5/8"	0			X
RWS 100H 44 COMMON LPSI/SDC RECIRC	00189	100	F	92-085 92-045	03/26/92 P/P6'-3/4"	1052	PASS C/S AF 2 1/2 AR 3 3/4"		04/01/92
RWS 100H 46 DIV I LPCI/SDC RECIRC	01290	100	F	92-059 92-045	03/18/92 WASH INSPTPERWAS14268,PP7'-1"C/S AF,AR 2	734	PASS		03/20/92
RWS 100H 47 DIV I LPCI/SDC RECIRC	02394	100	F	92-059 92-045	03/18/92 WASHINSPTWAS14268,PP 5'-6 3/4"C/S AF,AR5	815	PASS		03/20/92
RWS 100H 49 DIV I LPCI/SDC RECIRC	01118	100			X P/P 6' 1 1/2"	0			X
SPDBA 102H2000 HPCI STM SUPPLY OUTSIDE	28777	1/4			X P/P 2' 3 1/4"	0			X
SPDBA 102H2001 HPCI STM SUPPLY INSIDE	18580	1	S		03/16/92	251	PASS C/S AF 1 1/2 AR 1 1/2"		Z
SPDBA 102H2003 HPCI STM SUPPLY INSIDE	13452	1/2			03/16/92	844	PASS C/S AF 1 1/2" AR 1 1/2"		Z
SPDBA 102H2018 HPCI STM SUPPLY INSIDE	02824	1			03/16/92 CHANGE TO STRUT	229	PASS C/S AF 1 1/2 AR 1 1/2"		Z
SPDBA 102H2019 HPCI STM SUPPLY INSIDE	02409	1			03/16/92 CHANGE TO STRUT	157	PASS C/S AF 1 3/4 AR 1 3/4"		Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDBA 103H2000 FW COMMON DISCHARGE	12967	1/2			X	0			X
SPDBA 105H2000 RCIC STM SUPPLY INSIDE	13054	1/4			04/09/92	1446	PASS	C/S AF 2	Z AR 2
SPDBA 105H2001 RCIC STM SUPPLY INSIDE	13969	1			04/16/92	806	PASS	12181-80 CNGTOSZ1/USEHBD1039H1PP3'1 3/4C/S 1 1/4	04/27/92
SPDBA 105H2002 RCIC STM SUPPLY INSIDE	23586	1/4			03/16/92 P/P-2'4"	49	PASS	C/S AF 1 3/4 AR 1 3/4	Z AR 1 3/4
SPDBA 107H2000 FW COMMON DISCHARGE	13970	1/2			X	0			X
SPDBA 108H 1 MAIN STEAM DRNS INSIDE CONT	03870	1/2			03/24/92	2148	PASS	C/S AF 1 3/8 AR 1 3/8	Z AR 1 3/8
SPDBA 108H 3 MAIN STEAM DRNS INSIDE CONT	27877	1/4			03/24/92	2327	PASS	C/S AF 2	Z AR 2
SPDBA 108H 4 MAIN STEAM DRNS INSIDE CONT	10733	1/2	F		03/22/92	1709	PASS	C/S AF 1	Z AR 1
SPDBA 108H 6 MAIN STEAM DRNS INSIDE CONT	03871	1/2			X	0			X
SPDBA 109H2000 MAIN STEAM DRNS INSIDE CONT	29173	1/4			03/24/92	2350	PASS	C/S AF 2	Z AR 2
SPDBA 110H 22 MAIN STEAM DRNS INSIDE CONT	13456	1/2			03/22/92	1835	PASS	C/S AF 1	Z AR 1
SPDBA 111H 3 MAIN STEAM DRNS INSIDE CONT	28810	1/4	S		03/23/92 P/P-1'11"	2225	PASS	C/S AF 2	Z AR 2
SPDBA 111H2000 MAIN STEAM DRNS INSIDE CONT	28879	1/4			03/23/92	2009	PASS	C/S AF 1 1/2 AR 1 1/2	Z AR 1 1/2

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDBA 112H 2 HEAD VENT IN CONT	12179	1			03/14/92	940	PASS		Z
					USE CLMP ON SPDBA112H26			C/S AF, AR 1 1/2"	
SPDBA 112H 5 HEAD VENT IN CONT	10725	1/2			03/14/92	236	PASS		Z
								C/S AF 1 1/2 AR 1 1/2	
SPDBA 112H 11 HEAD VENT IN CONT	06838	3			X	0			X
SPDBA 112H 12 HEAD VENT IN CONT	09925	1/2			03/14/92	759	PASS		Z
								C/S AF 1 1/2" AR 1 1/2"	
SPDBA 112H 15A VESSEL SPIDER	04990	1			03/20/92	1545	PASS		Z
								C/S AF 1.5 AR 1.5	
SPDBA 112H 15B VESSEL SPIDER	04988	1			03/20/92	1630	PASS		Z
								C/S AF 1.25 AR 1.25	
SPDBA 112H 17 VESSEL SPIDER	06674	1/2		92-085	03/19/92	2358	PASS		04/26/92
								C/S AF 3/4 AR 3/4	
SPDBA 112H 18 VESSEL SPIDER	23387	1			03/20/92	416	PASS		Z
								C/S AF 2.5 AR 2.5	
SPDBA 112H 20 HEAD VENT IN CONT	16409	1/4	S		03/24/92	2054	PASS		Z
								C/S AF 1 1/2 AR 1 1/2	
SPDBA 112H 22 HEAD VENT IN CONT	13936	1/2			X	0			X
					P/P 2'8 5/8"				
SPDBA 112H 24 HEAD VENT IN CONT	18577	1			03/25/92	152	PASS		Z
					CHANGE TO STRUT			C/S AF 2 AR 2	
SPDBA 112H 26 HEAD VENT IN CONT	09945	1/2	F		03/25/92	1548	PASS		Z
					CNGTOSTRT, CLMPFMH2, PP3'-6"			C/S AF, AR 1 1/2	
SPDBA 112H 28 VESSEL SPIDER	09922	1			03/22/92	1906	PASS	04991-78	04/16/92
					SNB, CLMP FM SPDBA112H29			C/S AF, AR 1 3/8	

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDBA 112H 29 VESSEL SPIDER	04991	1		92-085	03/19/92	2220	PASS	C/S AF,AR 1 1/4"	Z
SPDBA 112H 31 VESSEL SPIDER	09923	1/2	S		03/22/92	1506	PASS	C/S AF 7/8 AR 7/8	Z
SPDBA 112H 33 VESSEL SPIDER	12178	1		92-085	03/20/92	1442	PASS	C/S AF 1.75 AR 1.75	Z
SPDBA 112H 34 VESSEL SPIDER	07227	3			03/20/92	1139	PASS	C/S AF 2.5 AR 2.5	Z
SPDBA 112H 35 VESSEL SPIDER	06842	3		92-085	03/20/92	952	PASS	C/S AF 2 5/8 AR 2 5/8	Z
SPDBA 112H 36 VESSEL SPIDER	05014	1			03/20/92	1617	PASS	C/S AF 1 AR 1	Z
SPDBA 112H 37 VESSEL SPIDER	06843	3			03/20/92	1118	PASS	C/S AF 2.75 AR 2.75	Z
SPDBA 112H 39 VESSEL SPIDER	28923	1/4	S		03/20/92	213	PASS	C/S AF 2 3/4 AR 2 3/4	Z
SPDBA 112H 40 VESSEL SPIDER	05015	1		92-085	03/20/92	1505	PASS	C/S AF 3 AR 3	Z
SPDBA 112H 41 VESSEL SPIDER	01047	1/2			03/20/92	20	PASS	14386-82 REPLW/SNBRHBD188H15B(307)C/S AF,AR 1 1/4	03/30/92
SPDBA 112H 42 VESSEL SPIDER	05016	1	S		03/19/92	2148	PASS	C/S AF,AR 3 5/8"	Z
SPDBA 112H 43 VESSEL SPIDER	06844	3			03/20/92	1320	PASS	C/S AF 2 AR 2	Z
SPDBA 112H 45 VESSEL SPIDER	02223	3			04/10/92	1125	PASS	C/S AF 3 AR 3	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDBA 112H 46 VESSEL SPIDER	06845	1			04/09/92	859	PASS	21572-00	04/26/92
					SNUB&CLMP FRM SPDCA102H11BPP1'-8"C/S 3.5				
SPDBA 112H 50 VESSEL SPIDER	23047	1/4			X		0		X
					MODIFY PER PCN92-0382				
SPDBA 112H2000 HEAD VENT IN CONT	18551	1	S		03/14/92	922	PASS	C/S AF 2" AR 2"	Z
SPDBA 114H2000 MAIN STEAM LEAKAGE CONTROL	18563	1			X		0		X
SPDBA 114H2001 MAIN STEAM LEAKAGE CONTROL	16852	1			X		0		X
					P/P 2'8 1/8"				
SPDBA 114H2002 MAIN STEAM LEAKAGE CONTROL	13963	1/2			X		0		X
SPDBA 115H 3 MAIN STEAM LEAKAGE CONTROL	13955	1/2			X		0		X
SPDBA 115H 4 MAIN STEAM LEAKAGE CONTROL	22909	1/4			X		0		X
SPDBA 117H 3 MAIN STEAM LEAKAGE CONTROL	05006	1			X		0		X
SPDBA 117H2000 MAIN STEAM LEAKAGE CONTROL	13939	1/2			X		0		X
SPDBA 119H 3 MAIN STEAM 'C' LINE IN CONT	28886	1/4			03/22/92	259	PASS	C/S AF 1 3/4 AR 1 3/4	Z
					CHANGE TO STRUT				
SPDBA 119H 4 MAIN STEAM 'C' LINE IN CONT	13070	1/4	S		03/13/92	1510	PASS	C/S AF 1 3/4" AR 1 3/4"	Z
					P/P-1'9"				
SPDBA 119H2000 MAIN STEAM 'C' LINE IN CONT	27946	1/4			03/13/92	121	PASS	C/S AF 2 1/4 AR 2 1/4	Z
					P/P-4'5"				

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDBA 120H 4 MAIN STEAM 'B' LINE IN CONT	13051	1/4			X		0		X
SPDBA 120H 5 MAIN STEAM 'B' LINE IN CONT	10952	1/4	S		03/21/92	1855	PASS C/S AF 1 1/2 AR 1 1/2		Z
SPDBA 120H2000 MAIN STEAM 'D' LINE IN CONT	27866	1/4	S		03/18/92 P/P-4'5"	1850	PASS C/S AF 2 1/4 AR 2 1/4		Z
SPDBA 120H2003 MAIN STEAM 'B' LINE IN CONT	17235	1/2	S		03/20/92 P/P-1'9"	1808	PASS C/S AF 1 AR 1		Z
SPDBB 107H2005 DIV I LPCI/SDC RHR	21121	1/4			X P/P 2'11 15/16"		0		X
SPDBB 107H2006 DIV I LPCI/SDC RHR	06330	1/4			X		0		X
SPDBB 107H2007 DIV I LPCI/SDC RHR	10745	1/2			X		0		X
SPDBB 107H2009 DIV I LPCI/SDC RHR	13403	1/2			X		0		X
SPDBB 108H 34 MAIN STEAM LEAKAGE CONTROL	28984	1/4			X P/P 2'0 3/4"		0		X
SPDBB 108H 41 MAIN STEAM LEAKAGE CONTROL	18556	1			X P/P 3'6 1/2"		0		X
SPDBB 108H2007 MAIN STEAM LEAKAGE CONTROL	12184	1			X P/P 2'11 3/8"		0		X
SPDBB 108H2008 MAIN STEAM LEAKAGE CONTROL	17243	1/2			X		0		X
SPDBB 108H2009 MAIN STEAM LEAKAGE CONTROL	18568	1			X		0		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDBB 108H2010	29012	1/4			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPDBB 108H2011	18574	1			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPDBB 108H2012	13472	1/2			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPDBB 109H 9	07233	3			X		0		X
RCIC STM SUPPLY OUTSIDE									
SPDBB 109H 11	03566	3			X		0		X
RCIC STM SUPPLY OUTSIDE					P/P 2'8 5/8"				
SPDBB 109H2000A	22969	1/4			X		0		X
RCIC STM SUPPLY OUTSIDE									
SPDBB 109H2000B	23014	1/4			X		0		X
RCIC STM SUPPLY OUTSIDE									
SPDBB 109H2002	21150	1/4			X		0		X
RCIC STM SUPPLY OUTSIDE									
SPDBB 109H2003	22968	1/4			X		0		X
RCIC STM SUPPLY OUTSIDE									
SPDBB 109H2004	12969	1/2			X		0		X
RCIC STM SUPPLY OUTSIDE									
SPDBB 109H2006	23049	1/4			X		0		X
RCIC STM SUPPLY OUTSIDE					P/P2'1 7/16"				
SPDBB 109H2011	23030	1/4			X		0		X
RCIC STM SUPPLY OUTSIDE									
SPDBB 109H2013	23027	1/4			X		0		X
RCIC STM SUPPLY OUTSIDE									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDBB 114H2001	17239	1/2			X		0		X
HPCI STM SUPPLY OUTSIDE									
SPDBB 114H2003	21135	1/4			X		0		X
HPCI STM SUPPLY OUTSIDE									
SPDBB 114H2009	00100	3L			X		0		X
HPCI STM SUPPLY OUTSIDE									
SPDBB 121H2012	23566	1/4			X		0		X
RCIC PUMP DSCH									
SPDBB 123H 3	05009	1			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPDBB 123H4000	14380	1/2			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPDBB 123H4001	09721	1/4			X		0		X
MAIN STEAM LEAKAGE CONTROL					P/P2'3 9/16"				
SPDBB 124H 2	06828	3			X		0		X
MAIN STEAM LEAKAGE CONTROL					P/P 4'9"				
SPDBB 124H 4	05008	1			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPDBB 125H 3	05010	1			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPDBB 125H 4	05011	1			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPDBB 126H 2	13466	1/2			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPDBB 126H2015A	13971	1/2			X		0		X
MAIN STEAM LEAKAGE CONTROL									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDBB 126H2015B	13972	1/2			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPDBB 126H2016	23024	1/4			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPDBB 126H2017	13964	1/2			X		0		X
MAIN STEAM LEAKAGE CONTROL					P/P1'4 3/4"				
SPDBC 101H 2	06064	3	S		03/19/92	1327	PASS		03/20/92
RWCU SUCT OUTSIDE CONT								C/S AF 2.5 AR 2.5	
SPDBC 101H2011	12186	1			X		0		X
RWCU SUCT OUTSIDE CONT									
SPDBD 107H2000	03604	1			03/17/92	910	PASS		04/16/92
HPCI STM SUPPLY OUTSIDE					P/P 2'3 3/4"			C/S AF 1 15/16 AR 1 15/16	
SPDBD 107H2001	13438	1/2			X		0		X
HPCI STM SUPPLY OUTSIDE					P/P4'10 7/16"				
SPDBD 113H 5	03877	1/2			X		0		X
RCIC STM SUPPLY OUTSIDE									
SPDCA 101H 8	13924	1/2			X		0		X
VESSEL FLANGE LEAKOFF									
SPDCA 101H 15	23041	1/4	C		03/24/92	1750	FAIL	28859-82	03/27/92
VESSEL FLANGE LEAKOFF								C/S AF 2 1/4 AR 2 1/4	
SPDCA 101H2001	06251	1/4	CF		03/24/92	1838	PASS		03/27/92
VESSEL FLANGE LEAKOFF								C/S AF 2 1/4 AR 2 1/4	
SPDCA 101H2002	21567	1	C		03/24/92	1853	PASS		03/27/92
VESSEL FLANGE LEAKOFF								C/S AF 1 AR 1	
SPDCA 102H 10A	06821	3			X		0		X
RECIRC/RWCU COMMON SUCT									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 102H RECIRC/RWCU	10B 06822 COMMON SUCT	3			X	0			X
SPDCA 102H RECIRC/RWCU	11A 21572 COMMON SUCT	1			03/31/92	2145	PASS		Z
					SNB ON SPDBA112H46			C/S AF 1	1/4
SPDCA 102H RECIRC/RWCU	11B 21566 COMMON SUCT	1			03/31/92	2112	DEGRADE		Z
					CLMP RMVD, P/P-1'11"			C/S AF 1 1/4 AR 1 1/4	
SPDCA 102H RECIRC/RWCU	13A 18549 DIV I SUCT	1	F		03/17/92	105	PASS		03/20/92
					P/P 1'10 3/4"			C/S AF 1 1/4 AR 1 1/4	
SPDCA 102H RECIRC/RWCU	13B 18559 DIV I SUCT	1	F		03/17/92	207	PASS		03/20/92
					P/P2'0 3/8"			C/S AF 1 1/4 AR 1 1/4	
SPDCA 102H RECIRC/RWCU	14A 18588 DIV 1 SUCT	1		92-085	03/19/92	1459	PASS		Z
					P/P-2'4"			C/S AF .5 AR .5	
SPDCA 102H RECIRC/RWCU	14B 02414 DIV 1 SUCT	1			03/19/92	1417	DEGRADE		Z
					P/P-1'8"			C/S AF 1 AR 1	
SPDCA 102H RECIRC/RWCU	19 12947 DIV 1 SUCT	10			03/18/92	1626	PASS		Z
								C/S AF 2 7/8 AR 2 7/8	
SPDCA 102H RECIRC/RWCU	20 03430 DIV I SUCT	1			X	0			X
SPDCA 102H RECIRC/RWCU	22 19563 DIV I SUCT	3			03/20/92	830	PASS		Z
					P/P-2'8"			C/S AF 1.5 AR 1.5	
SPDCA 102H2000A RECIRC/RWCU	18585 COMMON SUCT	1			03/29/92	806	PASS		Z
					WA#Y10871, CLMP RMVD, PP-2'1C/S			AF, AR 1.5	
SPDCA 102H2000B RECIRC/RWCU	18582 COMMON SUCT	1			03/29/92	318	PASS		Z
					WAY10871, CLMP RMVD, PP-2'4"			C/S AF 1 AR 1	
SPDCA 102H2001 RECIRC/RWCU	09941 COMMON SUCT	1/2			X	0			X
					RETURN FOR REINSTALLATION				

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 107H 2 CORE SPRAY 'B' LOOP DISCH	28941	1/4			X P/P 2'0 3/8"	0			X
SPDCA 107H 6 CORE SPRAY 'A' LOOP DISCH	13122	1/4			X P/P 2'3 1/4"	0			X
SPDCA 107H2002 CORE SPRAY 'A' LOOP DISCH	22883	1/4			X P/P 2'8 7/16"	0			X
SPDCA 107H2003 CORE SPRAY 'A' LOOP DISCH	28979	1/4			X P/P 3'8 5/8"	0			X
SPDCA 107H2004 CORE SPRAY 'B' LOOP DISCH	22963	1/4			X	0			X
SPDCA 107H2006 CORE SPRAY 'B' LOOP DISCH	22884	1/4			X	0			X
SPDCA 107H2007 CORE SPRAY 'B' LOOP DISCH	22885	1/4			X	0			X
SPDCA 108H2013 RHR/RECIRC S.P. NONIMPACTING	04657	3			03/25/92	1058	PASS	C/S AF 3 AR 3	Z
SPDCA 108H2014 RHR/RECIRC S.P. NONIMPACTING	04618	3			03/26/92	35	PASS	CLMP REMVD, P/P-5'1"C/S AF 2 3/8 AR 2 3/8	Z
SPDCA 108H2015 RHR/RECIRC S.P. NONIMPACTING	18586	1	S		03/24/92	2032	PASS	CLAMP REMOVED C/S AF 2 AR 2	Z
SPDCA 108H2016 RHR/RECIRC S.P. NONIMPACTING	02419	1	S		03/24/92	1921	PASS	CLAMP REMOVED C/S AF 1 1/2 AR 1 1/2	Z
SPDCA 110H 2 RHR/RECIRC S.P. NONIMPACTING	13455	1/2			X P/P 3'6"	0			X
SPDCA 110H 4 RHR/RECIRC S.P. NONIMPACTING	17224	1			X P/P 2'9 3/8"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 110H2008 RHR/RECIRC S.P. NONIMPACTING	05592	1/2			X P/P 4'6 15/16"	0			X
SPDCA 110H2012 RHR/RECIRC S.P. NONIMPACTING	02813	1			03/17/92	313	PASS C/S AF 2 1/4 AR 2 1/4		03/27/92
SPDCA 110H2014 RHR NON-IMPACTING BULK	03116	3			X	0			X
SPDCA 116H 1 RECIRC NONIMPACTING B LOOP	06326	1/4	R		03/27/92	41	PASS C/S AF 2 AR 2		Z
SPDCA 116H 2 RECIRC NONIMPACTING B LOOP	05132	1/4	R		03/27/92 P/P-2'0"	1056	PASS C/S AF 1 1/4 AR 1 1/4		Z
SPDCA 116H 5 RECIRC NONIMPACTING B LOOP	13469	1/2			03/27/92 CHANGED TO A STURT	247	PASS C/S AF 1 1/8 AR 1 1/8		Z
SPDCA 116H 6 RECIRC NONIMPACTING B LOOP	23353	1/4	F		03/27/92 P/P-3'8"	914	PASS C/S AF 1 3/4 AR 1 3/4		Z
SPDCA 116H2001 RECIRC NONIMPACTING B LOOP	29015	1/4			03/27/92	126	FAIL C/S AF 2 1/2 AR 2 1/2		Z
SPDCA 117H 2 RECIRC NONIMPACTING B LOOP	28019	1/4			03/27/92 P/P-3'7"	838	PASS C/S AF 1 1/2 AR 1 1/2		Z
SPDCA 117H 13 RECIRC NONIMPACTING B LOOP	18830	1			03/27/92	437	PASS C/S AF 1.5 AR 1.5		Z
SPDCA 117H 14 RECIRC NONIMPACTING B LOOP	13470	1/2			X P/P 1'6 3/8"	0			X
SPDCA 117H 16 RECIRC NONIMPACTING B LOOP	04104	1/4			03/27/92	11	FAIL C/S AF 1 1/2 AR 1 1/2		Z
SPDCA 117H2003 RECIRC NONIMPACTING B LOOP	13965	1/2			03/27/92	805	PASS C/S AF 1 AR 1		Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 117H2004 RECIRC NONIMPACTING B LOOP	09937	1/2			03/27/92	305	PASS C/S AF 1 1/4 AR 1 1/4		Z
SPDCA 118H 27 RECIRC NONIMPACTING A LOOP	23046	1/4			03/20/92	3	PASS C/S AF 2 AR 2		Z
SPDCA 118H 31 RECIRC NONIMPACTING A LOOP	16379	1/4	S		03/23/92 P/P-2'0"	1135	PASS C/S AF 2" AR 2"		Z
SPDCA 118H2011 RECIRC NONIMPACTING A LOOP	27975	1/4	S		03/23/92 P/P-3'2"	1044	PASS C/S AF 2 1/2" AR 2 1/2"		Z
SPDCA 119H 31 RECIRC NONIMPACTING A LOOP	06239	1/4	S		03/20/92	1640	PASS C/S AF 1 5/8 AR 1 5/8		Z
SPDCA 119H2000 RECIRC NONIMPACTING A LOOP	06246	1/4	S		03/17/92	2010	PASS C/S AF 1 3/4 AR 1 3/4		Z
SPDCA 119H2003 RECIRC NONIMPACTING A LOOP	28765	1/4			03/18/92	231	PASS C/S AF 2 1/4 AR 2 1/4		Z
SPDCA 119H2004 RECIRC NONIMPACTING A LOOP	22938	1/4	S		03/17/92	2139	PASS C/S AF 2 1/4 AR 2 1/4		Z
SPDCA 119H2005 RECIRC NONIMPACTING A LOOP	22961	1/4	S		03/17/92	2202	PASS C/S AF 1 1/2 AR 1 1/2		Z
SPDCA 119H2009 RECIRC NONIMPACTING A LOOP	22927	1/4			03/18/92 P/P-3'3"	1924	PASS C/S AF 1 1/4 AR 1 1/4		Z
SPDCA 119H2011 RECIRC NONIMPACTING A LOOP	13923	1/2			03/18/92 P/P-2'1"	11	PASS C/S AF 2 AR 2		Z
SPDCA 119H2012 RECIRC NONIMPACTING A LOOP	14374	1/2	S		03/19/92 P/P-2'8"	242	PASS C/S AF 1 AR 1		Z
SPDCA 120H2006 RECIRC NONIMPACTING B LOOP	23573	1/4			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 121H 24	27840	1/4		92-079	03/23/92 P/P-4'5"	904	DEGRADE		Z
RECIRC NONIMPACTING B LOOP								C/S AF 3/4" AR 3/4"	
SPDCA 121H 35	06310	1/4			03/22/92	2108	PASS		Z
RECIRC NONIMPACTING B LOOP								C/S AF 2 3/4 AR 2 3/4	
SPDCA 121H 36	22951	1/4			03/23/92	143	PASS		Z
RECIRC NONIMPACTING B LOOP								C/S AF 2 AR 2	
SPDCA 121H2002	23000	1/4			X	0			X
RECIRC NONIMPACTING B LOOP									
SPDCA 121H2003	28964	1/4			X	0			X
RECIRC NONIMPACTING B LOOP					P/P 2'6"				
SPDCA 121H2004	27953	1/4			X	0			X
RECIRC NONIMPACTING B LOOP									
SPDCA 121H2014	09940	1/2			03/23/92 P/P-1'8"	1353	PASS		Z
RECIRC NONIMPACTING B LOOP								C/S AF 1 1/4" AR 1 1/4"	
SPDCA 121H2016	13960	1/2			03/22/92	2013	PASS		Z
RECIRC NONIMPACTING B LOOP								C/S AF 1 1/4 AR 1 1/4	
SPDCA 124H 8	09742	1/4			03/15/92	1317	FAIL		Z
HPCI STM SUPPLY INSIDE								C/S AF 2 1/4 AR 2 1/4	
SPDCA 124H2005	27972	1/4			03/12/92	2145	PASS		Z
HPCI STM SUPPLY INSIDE								C/S AF N/A AR 1 7/8	
SPDCA 124H2006	21069	1/4			03/12/92 P/P-2'3"	2213	PASS		Z
HPCI STM SUPPLY INSIDE								C/S AF N/A AR 2	
SPDCA 124H2008	21074	1/4			03/12/92	1821	PASS		Z
HPCI STM SUPPLY INSIDE								C/S AF N/A AR 2 1/8	
SPDCA 126H 38	06254	1/4			04/02/92	1108	PASS		Z
RHR/RECIRC S.P.NONIMPACTING								C/S AF 2 1/4 AR 2 1/4	

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 126H 39 RHR/RECIRC S.P.NONIMPACTING	23569	1/4			04/02/92 P/P-4'7"	852	DEGRADE	C/S AF 2 AR 2	Z
SPDCA 126H 40 RHR/RECIRC S.P.NONIMPACTING	06255	1/4			04/02/92	1141	PASS	C/S AF 2 AR 2	Z
SPDCA 126H 48 RHR/RECIRC S.P.NONIMPACTING	10915	1/4			04/02/92	1342	PASS C/S AF 2 1/4 AR 2 1/4		Z
SPDCA 126H 50 RHR/RECIRC S.P.NONIMPACTING	06329	1/4			04/02/92	1124	PASS C/S AF 2 1/4 AR 2 1/4		Z
SPDCA 126H 54 RHR/RECIRC S.P.NONIMPACTING	06277	1/4			04/02/92	1322	PASS C/S AF 1 1/2 AR 1 1/2		Z
SPDCA 126H 55 RHR/RECIRC S.P.NONIMPACTING	28970	1/4			04/02/92 P/P-4'6"	919	FAIL C/S AF 2 1/2 AR 2 1/2		Z
SPDCA 126H 63 RHR/RECIRC S.P.NONIMPACTING	35514	1/4			04/01/92 P/P-2'6"	1609	PASS C/S AF 1 3/4 AR 1 3/4		Z
SPDCA 126H 64 RHR/RECIRC S.P.NONIMPACTING	16416	1/4			03/31/92	1802	PASS C/S AF 1 5/8 AR 1 5/8		Z
SPDCA 126H 73 RHR/RECIRC S.P.NONIMPACTING	16424	1/4			03/31/92	2008	PASS C/S AF 1 3/8 AR 1 3/8		Z
SPDCA 126H 74 RHR/RECIRC S.P.NONIMPACTING	16425	1/4			04/02/92 P/P-2'8"	735	PASS C/S AF 2 1/2 AR 2 1/2		Z
SPDCA 126H 83 RHR/RECIRC S.P.NONIMPACTING	10942	1/4			03/31/92	2025	PASS C/S AF 3/4 AR 3/4		Z
SPDCA 126H2001 RHR/RECIRC S.P.NONIMPACTING	28760	1/4			X	0			X
SPDCA 126H2002 RHR/RECIRC S.P.NONIMPACTING	16395	1/4			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 126H2008 RHR/RECIRC S.P.NONIMPACTING	16427	1/4			03/31/92	144	PASS	C/S AF 0 AR 0	Z
SPDCA 126H2010 RHR/RECIRC S.P.NONIMPACTING	16384	1/4			03/31/92 P/P-2'8"	238	PASS	C/S AF 1 7/8 AR 1 7/8	Z
SPDCA 126H2011 RHR/RECIRC S.P.NONIMPACTING	16417	1/4			04/01/92	1458	PASS	C/S AF 1 3/4 AR 1 3/4	Z
SPDCA 126H2012 RHR/RECIRC S.P.NONIMPACTING	28856	1/4			03/30/92	2105	PASS	C/S AF 1 5/8 AR 1 5/8	Z
SPDCA 126H2013 RHR/RECIRC S.P.NONIMPACTING	16419	1/4	F		03/31/92	2318	PASS	C/S AF 1 3/4 AR 1 3/4	Z
SPDCA 126H2014 RHR/RECIRC S.P.NONIMPACTING	13116	1/4			03/31/92	116	PASS	C/S AF 2 AR 2	Z
SPDCA 126H2021 RHR/RECIRC S.P.NONIMPACTING	13099	1/4			03/31/92	1844	PASS	C/S AF 2 AR 2	Z
SPDCA 126H2029 RHR/RECIRC S.P.NONIMPACTING	06274	1/4			X	0			X
SPDCA 126H2033 RHR/RECIRC S.P.NONIMPACTING	21148	1/4			04/02/92	1555	PASS	C/S AF 2 1/4 AR 2 1/4	Z
SPDCA 126H2034 RHR/RECIRC S.P.NONIMPACTING	13433	1/2			03/31/92	2050	PASS	C/S AF 1 1/4 AR 1 1/4	Z
SPDCA 126H2035 RHR/RECIRC S.P.NONIMPACTING	22875	1/4			03/31/92	1823	PASS	C/S AF 2 AR 2	Z
SPDCA 126H2036 RHR/RECIRC S.P.NONIMPACTING	22866	1/4			04/02/92 CHNGTO STRT, PP-2'7"	1619	PASS	C/S AF 1 1/4 AR 1 1/4	Z
SPDCA 126H2037 RHR/RECIRC S.P.NONIMPACTING	23547	1/4			04/02/92	1207	PASS	C/S AF 1 1/2 AR 1 1/2	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 126H2041	22876	1/4			04/02/92	1513	PASS		Z
RHR/RECIRC S.P.NONIMPACTING							C/S AF 1 1/2 AR 1 1/2		
SPDCA 126H2043	28732	1/4			04/02/92	1052	PASS		Z
RHR/RECIRC S.P.NONIMPACTING							C/S AF 2 1/2 AR 2 1/2		
SPDCA 126H2047	22965	1/4			04/02/92	1035	PASS		Z
RHR/RECIRC S.P.NONIMPACTING							C/S AF 2 1/4 AR 2 1/4		
SPDCA 127H 47	10914	1/4	S		03/21/92	1758	PASS		Z
MAIN STEAM 'B' INSIDE CONT							C/S AF 1 1/2 AR 1 1/2		
SPDCA 127H 51	05130	1/4	S		03/21/92	2020	PASS		Z
MAIN STEAM 'B' INSIDE CONT							C/S AF 1 3/4 AR 1 3/4		
SPDCA 127H 61	27978	1/4	S		03/17/92	251	PASS		Z
MAIN STEAM 'D' INSIDE CONT					P/P-3'2"		C/S AF 1 3/4 AR 1 3/4		
SPDCA 127H 62	23591	1/4			03/16/92	2146	PASS		Z
MAIN STEAM 'D' INSIDE CONT							C/S AF 2 1/4 AR 2 1/4		
SPDCA 127H 66	21132	1/4			03/17/92	40	PASS		Z
MAIN STEAM 'D' INSIDE CONT							C/S AF 2 1/4 AR 2 1/4		
SPDCA 127H 92	04088	1/4			03/16/92	912	PASS		Z
MAIN STEAM 'C' INSIDE CONT							C/S AF 1.5 AR 1.5		
SPDCA 127H 93	04080	1/4			03/16/92	849	PASS		Z
MAIN STEAM 'C' INSIDE CONT							C/S AF 2 1/4 AR 2 1/4		
SPDCA 127H 146	28864	1/4			03/20/92	2334	PASS		Z
MAIN STEAM 'A' INSIDE CONT							C/S AF 2 AR 2		
SPDCA 127H 148	13057	1/4			03/18/92	2138	PASS		Z
MAIN STEAM 'A' INSIDE CONT					P/P-2'7"		C/S AF 2 1/4 AR 2 1/4		
SPDCA 127H 151	10904	1/4			03/12/92	2013	PASS		Z
MAIN STEAM 'D' INSIDE CONT							C/S AF N/A AR 1 3/4		

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 127H 154 MAIN STEAM 'D' INSIDE CONT	27966	1/4			03/12/92	1901	PASS	C/S AF N/A AR 2"	Z
SPDCA 127H 155 MAIN STEAM 'D' INSIDE CONT	13105	1/4			03/12/92 P/P-3'9"	2334	FAIL	C/S AF N/A AR 2 1/4"	Z
SPDCA 127H 156 MAIN STEAM 'D' INSIDE CONT	04191	1/4			X	0			X
SPDCA 127H 158 MAIN STEAM 'A' INSIDE CONT	13437	1/2			03/16/92	812	PASS	C/S AF 1" AR 1"	Z
SPDCA 127H 161 MAIN STEAM 'D' INSIDE CONT	23571	1/4			X P/P 3'1 3/8"	0			X
SPDCA 127H 162 MAIN STEAM 'D' INSIDE CONT	27859	1/4			03/18/92 P/P-3'11"	1912	FAIL	C/S AF 2 AR 2	Z
SPDCA 127H 172 MAIN STEAM 'C' INSIDE CONT	09735	1/4			03/13/92 P/P-2'5"	55	PASS	C/S AF 1 3/4 AR 1 3/4	Z
SPDCA 127H 174 MAIN STEAM 'C' INSIDE CONT	13061	1/4			03/12/92	1938	PASS	C/S AF N/A AR 2 3/4	Z
SPDCA 127H 175 MAIN STEAM 'C' INSIDE CONT	13062	1/4			03/12/92 P/P-3'7"	2246	FAIL	C/S AF N/A AR 2 1/4	Z
SPDCA 127H 178 MAIN STEAM 'A' INSIDE CONT	28977	1/4			03/20/92	2052	PASS	C/S AF 2 1/2 AR 2 1/2	Z
SPDCA 127H2010 MAIN STEAM 'A' INSIDE CONT	13938	1/2			03/20/92	104	PASS	C/S AF 1 1/4 AR 1 1/4	Z
SPDCA 127H2012 MAIN STEAM 'A' INSIDE CONT	27861	1/4			03/16/92	1421	PASS	C/S AF 2.5 AR 2.5	Z
SPDCA 127H2015 MAIN STEAM 'A' INSIDE CONT	21127	1/4			03/16/92 P/P-1'11"	1455	PASS	C/S AF 2 1/8 AR 2 1/8	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 127H2036 MAIN STEAM 'D' INSIDE CONT	13092	1/4			03/16/92	2210	PASS C/S AF 1 3/4 AR 1 3/4		Z
SPDCA 127H2045 MAIN STEAM 'B' INSIDE CONT	13094	1/4			03/20/92	2036	PASS C/S AF 2 1/2 AR 2 1/2		Z
SPDCA 127H2047 MAIN STEAM 'B' INSIDE CONT	16387	1/4			03/18/92 P/P-2'3"	48	PASS C/S AF 1 3/4 AR 1 3/4		Z
SPDCA 127H2049 MAIN STEAM 'B' INSIDE CONT	21068	1/4		X		0			X
SPDCA 127H2051 MAIN STEAM 'D' INSIDE CONT	13091	1/4			03/17/92	21	PASS C/S AF 2 1/4 AR 2 1/4		Z
SPDCA 127H2054 MAIN STEAM 'B' INSIDE CONT	22940	1/4			03/21/92 CHANGE TO STRUT	1728	PASS C/S AF 1 1/2 AR 1 1/2		Z
SPDCA 127H2056 MAIN STEAM 'B' INSIDE CONT	13065	1/4			03/23/92 CHNG TO STRUT P/P 2'-2"	1111	PASS C/S AF, AR 1 3/4"		Z
SPDCA 127H2058 MAIN STEAM 'B' INSIDE CONT	13066	1/4			03/21/92 CHANGE TO STRUT	2321	PASS C/S AF 2 1/4 AR 2 1/4		Z
SPDCA 127H2065 MAIN STEAM 'C' INSIDE CONT	13101	1/4			03/13/92	2313	PASS C/S AF 2 AR 2		Z
SPDCA 127H2070 MAIN STEAM 'D' INSIDE CONT	27950	1/4			03/13/92	310	PASS C/S AF N/A AR 1 3/4		Z
SPDCA 127H2075 MAIN STEAM 'D' INSIDE CONT	22906	1/4			03/13/92 P/P-2'1"	338	PASS C/S AF N/A AR 2		Z
SPDCA 127H2076 MAIN STEAM 'D' INSIDE CONT	06244	1/4			03/16/92	2357	PASS C/S AF 2 AR 2		Z
SPDCA 127H2078 MAIN STEAM 'A' INSIDE CONT	22928	1/4			03/14/92	831	PASS C/S AF 2 1/8" AR 2 1/8"		Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 127H2019 MAIN STEAM 'A'	22929 INSIDE CONT	1/4			03/14/92	841	PASS	C/S AF, 1" AR 1"	Z
SPDCA 127H2082 MAIN STEAM 'A'	13434 INSIDE CONT	1/2	S		03/16/92	849	PASS	C/S AF 1 AR 1	Z
SPDCA 127H2084 MAIN STEAM 'B'	27855 INSIDE CONT	1/4			03/21/92	2135	PASS	C/S AF 2 AR 2	Z
SPDCA 127H2085 MAIN STEAM 'B'	05082 INSIDE CONT	1/4			03/21/92	2048	PASS	C/S AF 2 1/2 AR 2 1/2	Z
SPDCA 127H2088 MAIN STEAM 'B'	22872 INSIDE CONT	1/4			03/21/92	1823	PASS	C/S AF 2 1/8 AR 2 1/8	Z
SPDCA 127H2092 MAIN STEAM 'B'	28747 INSIDE CONT	1/4			03/21/92	2107	PASS	C/S AF 1 3/4 AR 1 3/4	Z
SPDCA 127H2094 MAIN STEAM 'A'	13962 INSIDE CONT	1/2	S		03/20/92	158	PASS	C/S AF 1 AR 1	Z
SPDCA 127H2100 MAIN STEAM 'B'	13141 INSIDE CONT	1/4			03/19/92 P/P-2'10"	307	PASS	C/S AF 1 3/4 AR 1 3/4	Z
SPDCA 127H2101 MAIN STEAM 'B'	22986 INSIDE CONT	1/4			03/20/92	1925	PASS	C/S AF 1 1/2 AR 1 1/2	Z
SPDCA 127H2104 MAIN STEAM 'B'	22899 INSIDE CONT	1/4	S		03/20/92	2105	PASS	C/S AF 1 1/4 AR 1 1/4	Z
SPDCA 127H2105 MAIN STEAM 'B'	22900 INSIDE CONT	1/4			03/20/92	2111	PASS	C/S AF 1 1/2 AR 1 1/2	Z
SPDCA 127H2106 MAIN STEAM 'B'	21153 INSIDE CONT	1/4			03/20/92	1832	PASS	C/S AF 2 AR 2	Z
SPDCA 127H2109 MAIN STEAM 'A'	09722 INSIDE CONT	1/4			03/20/92	1903	PASS	C/S AF 1 1/4 AR 1 1/4	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 127H2112 MAIN STEAM 'A' INSIDE CONT	14383	1/4			03/20/92	2258	PASS	C/S AF 2 AR 2	Z
SPDCA 128H 50 MAIN STEAM 'C' INSIDE CONT	23544	1/4	S		03/22/92	15	PASS	C/S AF 2 AR 2	Z
SPDCA 128H 84 MAIN STEAM 'C' INSIDE CONT	10934	1/4	S		03/13/92	1742	PASS	C/S AF 1 3/4 AR 1 3/4	Z
SPDCA 128H 86 MAIN STEAM 'C' INSIDE CONT	10935	1/4			03/13/92	1607	PASS	C/S AF 2" AR 2"	Z
SPDCA 128H 96 MAIN STEAM 'B' INSIDE CONT	13055	1/4			03/13/92	2030	PASS	C/S AF 1 1/2 AR 1 1/2	Z
SPDCA 128H 97 MAIN STEAM 'B' INSIDE CONT	06307	1/4			03/13/92	2054	PASS	C/S AF 2 AR 2	Z
SPDCA 128H 98 MAIN STEAM 'B' INSIDE CONT	06301	1/4			03/13/92	1902	FAIL	C/S AF 1 1/2 AR 1 1/2	Z
SPDCA 128H 99 MAIN STEAM 'B' INSIDE CONT	13056	1/4		X		0			X
SPDCA 128H 110 MAIN STEAM 'C' INSIDE CONT	10937	1/4			03/23/92	2345	PASS	C/S AF 2 1/4 AR 2 1/4	Z
SPDCA 128H 114 MAIN STEAM 'D' INSIDE CONT	28812	1/4			04/01/92	1438	PASS	C/S AF 2 AR 2	Z
SPDCA 128H 117 MAIN STEAM 'D' INSIDE CONT	29319	1/4			04/01/92	1359	FAIL	C/S AF 2 1/2 AR 2 1/2	Z
SPDCA 128H 124 MAIN STEAM 'D' INSIDE CONT	28881	1/4			03/13/92	2211	PASS	C/S AF 1 3/4 AR 1 3/4	Z
SPDCA 128H 125 MAIN STEAM 'D' INSIDE CONT	27854	1/4			03/13/92	2140	PASS	C/S AF 2 1/2 AR 2 1/2	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 128H 127 MAIN STEAM 'D'	23359 INSIDE CONT	1/4			X	0			X
SPDCA 128H 130 MAIN STEAM 'A'	05161 INSIDE CONT	1/4			04/02/92	1639	DEGRADE		Z
					CHNG TO STRT PP3'	0"	C/S AF 2 1/2 AR 2 1/2		
SPDCA 128H 131 MAIN STEAM 'A'	13103 INSIDE CONT	1/4			04/02/92	1443	PASS		Z
							C/S AF 2 1/2 AR 2 1/2		
SPDCA 128H 136 MAIN STEAM 'A'	27922 INSIDE CONT	1/4			03/22/92	142	PASS		Z
							C/S AF 2 AR 2		
SPDCA 128H 138 MAIN STEAM 'A'	10948 INSIDE CONT	1/4			X	0			X
SPDCA 128H2016 MAIN STEAM 'A'	27965 INSIDE CONT	1/4			04/09/92	1522	PASS		Z
							C/S AF 2 1/2 AR 2 1/2		
SPDCA 128H2018 MAIN STEAM 'A'	14425 INSIDE CONT	1/4			03/22/92	1424	PASS		Z
							C/S AF 2.25 AR 2.25		
SPDCA 128H2019 MAIN STEAM 'C'	14344 INSIDE CONT	1/4			03/15/92	1041	PASS		Z
					CHANGE TO STRUT		C/S AF 2 1/4 AR 2 1/4		
SPDCA 128H2023 MAIN STEAM 'B'	13100 INSIDE CONT	1/4			03/13/92	1855	PASS		Z
							C/S AF 1 3/4 AR 1 3/4		
SPDCA 128H2025 MAIN STEAM 'B'	23545 INSIDE CONT	1/4			03/23/92	56	PASS		Z
							C/S AF 1 3/4 AR 1 3/4		
SPDCA 128H2026 MAIN STEAM 'B'	28009 INSIDE CONT	1/4			03/22/92	2114	PASS		Z
							C/S AF 1 3/4 AR 1 3/4		
SPDCA 128H2027 MAIN STEAM 'B'	13077 INSIDE CONT	1/4			04/10/92	811	PASS		Z
							C/S AF 1.75 AR 1.75		
SPDCA 128H2030 MAIN STEAM 'B'	22997 INSIDE CONT	1/4			04/13/92	1325	FAIL		Z
					P/P-3'5"		C/S AF 2 AR 2		

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 128H2031 MAIN STEAM 'B' INSIDE CONT	14374	1/4			04/14/92 P/P-3'1"	801	FAIL	C/S AF 2.25 AR 2.25	Z
SPDCA 128H2032 MAIN STEAM 'B' INSIDE CONT	13081	1/4			X	0			X
SPDCA 128H2033 MAIN STEAM 'B' INSIDE CONT	23590	1/4			04/10/92 CHANGE TO STRUT	836	PASS	C/S AF 2 AR 2	Z
SPDCA 128H2061 MAIN STEAM 'C' INSIDE CONT	13931	1/2			X P/P 1'10 5/8"	0			X
SPDCA 128H2062 MAIN STEAM 'C' INSIDE CONT	22912	1/4		92-127	03/15/92	1112	FAIL	C/S AF 1 1/4 AR 1 1/4	Z
SPDCA 128H2068 MAIN STEAM 'C' INSIDE CONT	03477	1			03/23/92	216	PASS	C/S AF 2 1/2 AR 2 1/2	Z
SPDCA 129H 3 RCIC STM SUPPLY INSIDE	22914	1/4			04/09/92 CHANGE TO STRUT	1524	PASS	C/S AF 2 AR 2	Z
SPDCA 129H 4 RCIC STM SUPPLY INSIDE	04640	1/4	S		03/24/92 CHANGE TO STRUT	1046	PASS	C/S AF 2 AR 2	Z
SPDCA 129H 7 RCIC STM SUPPLY INSIDE	13140	1/4			04/08/92 CHANGE TO STRUT	1526	PASS	C/S AF 2 AR 2	Z
SPDCA 129H 8 RCIC STM SUPPLY INSIDE	04072	1/4	S		03/24/92	1025	PASS	C/S AF 1.5 AR 1.5	Z
SPDCA 129H2002 RCIC STM SUPPLY INSIDE	27949	1/4			04/09/92 CHANGE TO STRUT	736	PASS	C/S AF 2 AR 2	Z
SPDCA 129H2007 RCIC STM SUPPLY INSIDE	23355	1/4			04/09/92 P/P-1'10"	1440	PASS	C/S AF 2 AR 2	Z
SPDCA 129H2011 RCIC STM SUPPLY INSIDE	04684	1/4			04/09/92 CHANGE TO STRUT	1549	PASS	C/S AF 1.5 AR 1.5	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 129H2014 RCIC STM SUPPLY INSIDE	13934	1/2			04/09/92	806	PASS C/S AF 1 1/2 AR 1 1/2		Z
SPDCA 130H 2 RCIC STM SUPPLY INSIDE	23358	1/4			04/14/92 P/P-2'11"	1032	PASS C/S AF 1.75 AR 1.75		Z
SPDCA 130H 29 RCIC STM SUPPLY INSIDE	23548	1/4	S		03/24/92 CHNG TO STRUT,P/P-3'8"	1110	PASS C/S AF 1.5 AR 1.5		Z
SPDCA 130H 33 RCIC STM SUPPLY INSIDE	28939	1/4			04/09/92 CHANGE TO STRUT	1502	PASS C/S AF 2 AR 2		Z
SPDCA 130H 36 RCIC STM SUPPLY INSIDE	06273	1/4	S		03/24/92	925	PASS C/S AF 2 AR 2		Z
SPDCA 130H 38 RCIC STM SUPPLY INSIDE	28865	1/4			04/09/92	1541	PASS C/S AF 1 1/2 AR 1 1/2		Z
SPDCA 130H2000 RCIC STM SUPPLY INSIDE	22892	1/4			04/09/92	1603	PASS C/S AF 2 1/4 AR 2 1/4		Z
SPDCA 130H2001 RCIC STM SUPPLY INSIDE	13463	1/2	S		03/24/92	1001	PASS C/S AF 1 1/2" AR 1.25"		Z
SPDCA 130H2002 RCIC STM SUPPLY INSIDE	28884	1/4			04/14/92 P/P-3'5"	907	PASS C/S AF 2 AR 2		Z
SPDCA 130H2003 RCIC STM SUPPLY INSIDE	28916	1/4			04/14/92 P/P-2'4"	1256	PASS C/S AF 2 AR 2		Z
SPDCA 130H2004 RCIC STM SUPPLY INSIDE	22917	1/4			04/14/92 P/P-3'5"	1105	PASS C/S AF 2 AR 2		Z
SPDCA 131H 5 CORE SPRAY 'A' LOOP DISCH	13083	1/4			X	0			X
SPDCA 131H 14 CORE SPRAY 'A' LOOP DISCH	10926	1/4			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 H = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 131H 19 CORE SPRAY 'A' LOOP DISCH	16396	1/4			X		0		X
SPDCA 131H 21 CORE SPRAY 'A' LOOP DISCH	23554	1/4			X		0		X
SPDCA 131H2001 CORE SPRAY 'B' LOOP DISCH	13108	1/4			X		0		X
SPDCA 131H2003 CORE SPRAY 'B' LOOP DISCH	23008	1/4			X		0		X
SPDCA 131H2005 CORE SPRAY 'B' LOOP DISCH	23025	1/4			X P/P 3'8 1/4"		0		X
SPDCA 131H2008 CORE SPRAY 'B' LOOP DISCH	13087	1/4			X		0		X
SPDCA 131H2009 CORE SPRAY 'B' LOOP DISCH	13088	1/4			X		0		X
SPDCA 131H2020 CORE SPRAY 'B' LOOP DISCH	28858	1/4			X		0		X
SPDCA 131H2025 CORE SPRAY 'B' LOOP DISCH	06291	1/4			X		0		X
SPDCA 131H2031 CORE SPRAY 'B' LOOP DISCH	06238	1/4			X		0		X
SPDCA 131H2037 CORE SPRAY 'A' LOOP DISCH	29018	1/4			X		0		X
SPDCA 131H2039 CORE SPRAY 'A' LOOP DISCH	22881	1/4			X		0		X
SPDCA 131H2040 CORE SPRAY 'B' LOOP DISCH	28936	1/4			X		0		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 131H2042	21136	1/4			X	0			X
CORE SPRAY 'B' LOOP DISCH					P/P 2' 2 3/4"				
SPDCA 131H2043	21142	1/4			X	0			X
CORE SPRAY 'B' LOOP DISCH					P/P 3'7 7/16"				
SPDCA 131H2044	21157	1/4			X	0			X
CORE SPRAY 'B' LOOP DISCH					P/P 5'0"				
SPDCA 132H 1	29314	1/4			X	0			X
HPCI STM SUPPLY INSIDE									
SPDCA 132H 2	27967	1/4	S		03/15/92	1131	PASS		Z
HPCI STM SUPPLY INSIDE								C/S AF 2 AR 2	
SPDCA 132H 23	06278	1/4	S		03/15/92	2354	PASS		Z
HPCI STM SUPPLY INSIDE								C/S AF 2 1/4 AR 2 1/4	
SPDCA 132H 24	28917	1/4			03/16/92	22	PASS		Z
HPCI STM SUPPLY INSIDE								C/S AF 1 1/2 AR 1 1/2	
SPDCA 132H2002	22879	1/4			03/15/92	311	PASS		Z
HPCI STM SUPPLY INSIDE								C/S AF 1 3/4 AR 1 3/4	
SPDCA 132H2003	21124	1/4			03/15/92	249	PASS		Z
HPCI STM SUPPLY INSIDE								C/S AF 2 1/8 AF 2 1/8	
SPDCA 132H2007	21091	1/4			03/15/92	2135	PASS		Z
HPCI STM SUPPLY INSIDE								C/S AF 2 1/8 AR 2 1/8	
SPDCA 132H2008	28813	1/4			03/15/92	2156	PASS		Z
HPCI STM SUPPLY INSIDE								C/S AF 2 AR 2	
SPDCA 132H2010	06276	1/4			03/15/92	1447	DEGRADE		Z
HPCI STM SUPPLY INSIDE								C/S AF 1 7/8 AR 1 7/8	
SPDCA 132H2011	16429	1/4			03/15/92	1359	PASS		Z
HPCI STM SUPPLY INSIDE								C/S AF 1 5/8 AR 1 5/8	

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 132H2013 HPCI STM SUPPLY INSIDE	14347	1/4			03/15/92	1418	PASS		Z C/S AF 2 AR 2
SPDCA 133H2001 RWCU SUCT INSIDE CONT	27954	1/4		X		0			X
SPDCA 134H2012A RWCU SUCT INSIDE CONT	16362	1/4		X		0			X
SPDCA 134H2012B RWCU SUCT INSIDE CONT	16361	1/4		X		0			X
SPDCA 135H2001A UNDER VESSEL NONIMPACTING	13414	1/2		X		0			X
SPDCA 135H2001B UNDER VESSEL NONIMPACTING	13415	1/2		X		0			X
SPDCA 135H2002 UNDER VESSEL NONIMPACTING	23039	1/4		X		0			X
SPDCA 136H 29 JET PP DIV I IMPACTING	16393	1/4		X		0			X
SPDCA 136H2005 JET PP DIV I IMPACTING	28736	1/4		X		0			X
SPDCA 136H2010A JET PP DIV I IMPACTING	28722	1/4		X		0			X
SPDCA 136H2010B JET PP DIV I IMPACTING	22945	1/4		X		0			X
SPDCA 136H2021 JET PP DIV II IMPACTING	09934	1/2		X		0			X
SPDCA 136H2027 JET PP NONIMPACTING	13967	1/2		X		0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 136H2035	22873	1/4			X		0		X
JET PP DIV II IMPACTING									
SPDCA 136H2042	29014	1/4			X		0		X
JET PP DIV II IMPACTING									
SPDCA 136H2043	09728	1/4			X		0		X
JET PP DIV II IMPACTING									
SPDCA 136H2047	13933	1/2			X		0		X
JET PP DIV I IMPACTING									
SPDCA 136H2048	13932	1/2			X		0		X
JET PP DIV I IMPACTING									
SPDCA 136H2059	13947	1/2			X		0		X
JET PP DIV II IMPACTING									
SPDCA 137H 4	28857	1/4	C		03/31/92	1728	FAIL		Z
1C004 LOW PRESS ECCS IMPACT					P/P-1'7"		C/S AF 1 3/4 AR 1 3/4		
SPDCA 137H 5	28746	1/4	C		04/01/92	821	FAIL		Z
1C004 LOW PRESS ECCS IMPACT					P/P-2'8"		C/S AF 2.25 AR 2		
SPDCA 137H 6	16413	1/4	CF		04/01/92	737	PASS		Z
1C004 LOW PRESS ECCS IMPACT					P/P-2'1"		C/S AF 1.75 AR 1.75		
SPDCA 137H 16	21110	1/4	C		04/09/92	826	PASS		Z
1C005 LOW PRESS ECCS IMPACT					P/P-1'5"		C/S AF 1 1/2 AR 1 1/2		
SPDCA 137H 19	28738	1/4	C		04/08/92	1507	PASS		Z
1C005 LOW PRESS ECCS IMPACT							C/S AF 3 3/8 AR 3 3/8		
SPDCA 137H 20	23552	1/4	CF		04/09/92	909	FAIL		Z
1C005 LOW PRESS ECCS IMPACT					P/P-2'3"		C/S AF 1 1/2 AR 1 1/2		
SPDCA 138H 2	16439	1/4	C		04/09/92	934	PASS		Z
1C005 NOIMPCT TO LOW PRES ECCS					P/P-2'11"		C/S AF 2 3/4 AR 2 3/4		

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 138H 4 1C005 NOIMPCT TO LOW PRES ECCS	28728	1/4	C		04/08/92	1432	PASS C/S AF 2 1/2 AR 2 1/2		Z
SPDCA 138H 14 1C004 NOIMPCT TO LOW PRES ECCS	28788	1/4	C		04/04/92 P/P-2'1"	1057	PASS C/S AF 1 3/4 AR 1 3/4		Z
SPDCA 138H 15 C1004 NOIMPCT TO LOW PRES ECCS	28860	1/4	C		04/04/92 P/P-2'4"	1038	PASS C/S AF 1 1/2 AR 1 1/2		Z
SPDCA 138H 16 1C004 NOIMPCT TO LOW PRES ECCS	27970	1/4	C		04/04/92 P/P-2'6"	1019	PASS C/S AF 2 1/2 AR 2 1/2		Z
SPDCA 138H 21 1C005 NOIMPCT TO LOW PRES ECCS	28720	1/4	C		04/08/92	1452	PASS C/S AF 2 AR 2		Z
SPDCA 138H 22 1C005 NOIMPCT TO LOW PRES ECCS	29019	1/4			04/08/92	1309	PASS C/S AF 2 1/2 AR 2 1/2		Z
SPDCA 138H 23 C1055 NOIMPCT TO LOW PRES ECCS	06259	1/4			04/08/92	1250	PASS C/S AF 1 1/4 AR 1 1/4		Z
SPDCA 138H 24 1C005 NOIMPCT TO LOW PRES ECCS	06319	1/4			04/08/92	1333	PASS C/S AF 1 3/4 AR 1 3/4		Z
SPDCA 138H 25 1C005 NOIMPCT LOW PRES TO ECCS	27960	1/4	F		04/08/92	1412	PASS C/S AF 2 5/8 AR 2 5/8		Z
SPDCA 138H2001 1C004 NOIMPCT TO LOW PRES ECCS	22981	1/4			03/30/92	2045	PASS C/S AF 2 AR 2		Z
SPDCA 138H2003 1C005 NOIMPCT TO LOW PRES ECCS	23012	1/4			04/08/92	1354	PASS C/S AF 1 3/4 AR 1 3/4		Z
SPDCA 139H 14 SBLC INSIDE CONT	28861	1/4			X	0			X
SPDCA 140H 14 1C005 LOW PRESS ECCS IMPACT	27856	1/4	C		04/06/92 P/P-2'6"	1334	PASS C/S AF 2 AR 2		Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 140H 16 1C004 LOW PRESS ECCS IMPACT	28737	1/4	C		03/30/92	2001	PASS		Z
								C/S AF 3 AR 3	
SPDCA 140H 18 1C004 LOW PRESS ECCS IMPACT	22982	1/4			03/30/92	2126	PASS		Z
								C/S AF 1 3/4 AR 1 3/4	
SPDCA 140H2000 1C005 LOW PRESS ECCS IMPACT	21141	1/4			04/06/92 P/P-2'7"	1316	PASS		Z
								C/S AF 1 3/4 AR 1 3/4	
SPDCA 143H2001 RECIRC NONIMPACTING B LOOP	21144	1/4			X P/P 2'4"	0			X
SPDCA 143H2006 RECIRC NONIMPACTING B LOOP	17231	1			X P/P 2'2 7/8"	0			X
SPDCA 143H2011 RECIRC NONIMPACTING B LOOP	28978	1/4			X P/P 3'11 1/4"	0			X
SPDCA 143H2012 RECIRC NONIMPACTING B LOOP	18393	1			X P/P 4'10 1/2"	0			X
SPDCA 144H 5 JET PP NONIMPACTING	06288	1/4			X	0			X
SPDCA 144H 9 JET PP NONIMPACTING	05600	1/2			X	0			X
SPDCA 144H 28 JET PP NONIMPACTING	23357	1/4			X	0			X
SPDCA 144H 53 JET PP NONIMPACTING	16380	1/4			X	0			X
SPDCA 144H 55 JET PP NONIMPACTING	27963	1/4			X	0			X
SPDCA 144H 87 JET PP NONIMPACTING	14354	1/4			X P/P 1'10 1/2"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 144H 105 JET PP NONIMPACTING	09701	1/4			X P/P 2'4 3/4"	0			X
SPDCA 144H 142 JET PP NONIMPACTING	16392	1/4			X	0			X
SPDCA 144H 144 JET PP NONIMPACTING	16391	1/4			X	0			X
SPDCA 144H 148 JET PP NONIMPACTING	29008	1/4			X	0			X
SPDCA 144H 150 JET PP NONIMPACTING	27959	1/4			X	0			X
SPDCA 144H2021A JET PP NONIMPACTING	16377	1/4			X	0			X
SPDCA 144H2021B JET PP NONIMPACTING	16378	1/4			X	0			X
SPDCA 144H2027 JET PP NONIMPACTING	09747	1/4			X	0			X
SPDCA 144H2034 JET PP NONIMPACTING	13112	1/4			X	0			X
SPDCA 144H2036A JET PP NONIMPACTING	10753	1/2			X	0			X
SPDCA 144H2036B JET PP NONIMPACTING	10747	1/2			X	0			X
SPDCA 144H2042 JET PP NONIMPACTING	05603	1/2			X	0			X
SPDCA 144H2049 JET PP NONIMPACTING	06669	1/2			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 144H2053 JET PP NONIMPACTING	21151	1/4			X P/P 5'0 15/16"	0			X
SPDCA 144H2057 JET PP NONIMPACTING	13966	1/2			X	0			X
SPDCA 144H2074 JET PP NONIMPACTING	23010	1/4			X	0			X
SPDCA 144H2076 JET PP NONIMPACTING	20960	1/4			X	0			X
SPDCA 144H2077 JET PP NONIMPACTING	28018	1/4			X	0			X
SPDCA 144H2078 JET PP NONIMPACTING	21112	1/4			X	0			X
SPDCA 144H2080 JET PP NONIMPACTING	21130	1/4			X	0			X
SPDCA 144H2084 JET PP NONIMPACTING	13080	1/4			X	0			X
SPDCA 144H2085 JET PP NONIMPACTING	10740	1/2			X	0			X
SPDCA 144H2087 JET PP NONIMPACTING	01619	1/2			X	0			X
SPDCA 144H2091 JET PP NONIMPACTING	09938	1/2			X	0			X
SPDCA 144H2094 JET PP NONIMPACTING	29010	1/4			X	0			X
SPDCA 144H2101 JET PP NONIMPACTING	28783	1/4			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 144H2102 JET PP NONIMPACTING	06295	1/4			X		0		X
SPDCA 144H2105 JET PP NONIMPACTING	13447	1/2			X		0		X
SPDCA 144H2108 JET PP NONIMPACTING	22904	1/4			X		0		X
SPDCA 144H2116 JET PP NONIMPACTING	13451	1/2			X P/P 2'0 1/2"		0		X
SPDCA 144H2118 JET PP NONIMPACTING	13937	1/2			X		0		X
SPDCA 144H2122 JET PP NONIMPACTING	14388	1/2			X P/P 1'11 1/2"		0		X
SPDCA 144H2125 JET PP NONIMPACTING	13454	1/2			X		0		X
SPDCA 144H2127 JET PP NONIMPACTING	13449	1/2			X P/P 2'4 1/2"		0		X
SPDCA 144H2129 JET PP NONIMPACTING	13453	1/2			X		0		X
SPDCA 144H2133 JET PP NONIMPACTING	13474	1/2			X P/P 2'6 1/2"		0		X
SPDCA 144H2136 JET PP NONIMPACTING	13925	1/2			X		0		X
SPDCA 144H2137 JET PP NONIMPACTING	27947	1/4			X		0		X
SPDCA 144H2141 JET PP NONIMPACTING	13956	1/2			X		0		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 144H2143 JET PP NONIMPACTING	13448	1/2			X P/P 2'6 5/8"	0			X
SPDCA 144H2145 JET PP NONIMPACTING	13954	1/2			X	0			X
SPDCA 144H2149 JET PP NONIMPACTING	13413	1/2			X P/P 1'9 3/4"	0			X
SPDCA 144H2150 JET PP NONIMPACTING	13927	1/2			X	0			X
SPDCA 144H2155 JET PP NONIMPACTING	13476	1/2			X	0			X
SPDCA 144H2156 JET PP NONIMPACTING	13442	1/2			X P/P 2'10 1/8"	0			X
SPDCA 144H2161 JET PP NONIMPACTING	13464	1/2			X P/P 2'6 3/8"	0			X
SPDCA 144H2163A JET PP NONIMPACTING	13405	1/2			X P/P 2'8"	0			X
SPDCA 144H2163B JET PP NONIMPACTING	13406	1/2			X P/P 2'8"	0			X
SPDCA 144H2164A JET PP NONIMPACTING	13427	1/2			X	0			X
SPDCA 144H2164B JET PP NONIMPACTING	13425	1/2			X	0			X
SPDCA 144H2166 JET PP NONIMPACTING	13458	1/2			X P/P 2'2 3/4"	0			X
SPDCA 144H2171 JET PP NONIMPACTING	13928	1/2			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 144H2172 JET PP NONIMPACTING	13459	1/2			X		0		X
SPDCA 144H2173 JET PP NONIMPACTING	13465	1/2			X	P/P 2'6 9/16"	0		X
SPDCA 144H2175 JET PP NONIMPACTING	13477	1/2			X		0		X
SPDCA 144H2176 JET PP NONIMPACTING	13441	1/2			X		0		X
SPDCA 144H2178 JET PP NONIMPACTING	13926	1/2			X		0		X
SPDCA 144H2179 JET PP NONIMPACTING	13929	1/2			X	P/P 1'6 3/4"	0		X
SPDCA 144H2220 JET PP NONIMPACTING	23601	1/4			X	P/P 1'8 7/8"	0		X
SPDCA 144H2221 JET PP NONIMPACTING	13445	1/2			X		0-		X
SPDCA 144H2223 JET PP NONIMPACTING	23029	1/4		Y10226	X	P/P 2'3 3/4"	0		X
SPDCA 145H 5 HEAD VENT IN CONT	14328	1/4	S		03/14/92	2336	PASS CLAMP REMOVED	C/S AF 2 1/4 AR 2 1/4	Z
SPDCA 145H 13 VESSEL SPIDER	09730	1/4			04/10/92	730	PASS CHANGE TO SWAY STRUT	C/S AF 2.5 AR 2.5	Z
SPDCA 145H 17 VESSEL SPIDER	06668	1/2	S		03/22/92	1811	PASS CLAMP REMOVED	C/S AF 1 3/4 AR 1 3/4	Z
SPDCA 145H 18 VESSEL SPIDER	13063	1/4			03/20/92	50	PASS CLAMP REMOVED	C/S AF 1 1/2 AR 1 1/2	Z

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 145H 49 VESSEL SPIDER	05013	1			X		0		X
SPDCA 145H 52 VESSEL SPIDER	27955	1/4			X		0		X
					P/P 1'11 11/16"				
SPDCA 145H 55 VESSEL SPIDER	27944	1/4	S		03/23/92	1330	PASS		Z
					CLMP REMVD	P/P-1'7"C/S	AF 1 1/2	AR 1 1/2	
SPDCA 145H 56 VESSEL SPIDER	27948	1/4	S		03/23/92	934	PASS		Z
					CLMP RMVD	P/P-3'11"C/S	AF 1 5/8	AR 1 5/8	
SPDCA 146H 4 MAIN STEAM LEAKAGE CONTROL	16411	1/4			X		0		X
SPDCA 147H 7 MAIN STEAM LEAKAGE CONTROL	13102	1/4			X		0		X
SPDCA 147H 12 MAIN STEAM LEAKAGE CONTROL	13046	1/4			X		0		X
SPDCA 148H2007 MAIN STEAM LEAKAGE CONTROL	13945	1/2			X		0		X
SPDCA 148H2008 MAIN STEAM LEAKAGE CONTROL	03868	1/2			X		0		X
SPDCA 148H2009 MAIN STEAM LEAKAGE CONTROL	13950	1/2			X		0		X
SPDCA 148H2010 MAIN STEAM LEAKAGE CONTROL	13949	1/2			X		0		X
SPDCA 149H2003 MAIN STEAM LEAKAGE CONTROL	22889	1/4			X		0		X
					P/P 3'0 13/16"				
SPDCA 149H2004 MAIN STEAM LEAKAGE CONTROL	13468	1/2			X		0		X
					P/P10"				

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCA 149H2006	22895	1/4			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPDCB 101H 26	28940	1/4			X		0		X
SBLC OUTSIDE CONT					P/P 2'4 1/2"				
SPDCB 101H 46	16436	1/4			X		0		X
SBLC OUTSIDE CONT									
SPDCB 105H 3	14361	1/4	S		03/18/92	103	PASS		Z
RECIRC NONIMPACTING A LOOP								C/S AF 2 AR 2	
SPDCB 105H 5	14362	1/4	S		03/18/92	44	PASS		Z
RECIRC NONIMPACTING A LOOP								C/S AF 1 1/2 AR 1 1/2	
SPDCB 105H 8	14363	1/4			03/18/92	22	PASS		Z
RECIRC NONIMPACTING A LOOP								C/S AF 1 1/2 AR 1 1/2	
SPDCB 105H 10	13131	1/4	F		03/17/92	2239	PASS		Z
RECIRC NONIMPACTING A LOOP								C/S AF 2 AR 2	
SPDCB 105H 11A	14370	1/4		92-078	03/20/92	1619	PASS		Z
RECIRC NONIMPACTING A LOOP								C/S AF 1 1/2 AR 1 1/2	
SPDCB 105H 11B	14367	1/4			03/20/92	1602	PASS		Z
RECIRC NONIMPACTING A LOOP								C/S AF 1 3/4 AR 1 3/4	
SPDCB 105H 12	14368	1/4			03/17/92	1950	PASS		Z
RECIRC NONIMPACTING A LOOP								C/S AF 1 1/2 AR 1 1/2	
SPDCB 105H2000	28859	1/4			03/18/92	2	PASS		Z
RECIRC NONIMPACTING A LOOP								C/S AF 1 1/2 AR 1 1/2	
SPDCB 105H2001	21088	1/4			03/18/92	1824	DEGRADE		Z
RECIRC NONIMPACTING A LOOP					P/P-4'9"			C/S AF 2 AR 2	
SPDCB 105H2003	14365	1/4			03/17/92	2116	PASS		Z
RECIRC NONIMPACTING A LOOP								C/S AF 1 1/2 AR 1 1/2	

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCB 105H2006 RECIRC NONIMPACTING A LOOP	22903	1/4			03/17/92	1925	PASS C/S AF 2 1/4 AR 2 1/4		Z
SPDCB 106H 20 RECIRC NONIMPACTING B LOOP	29316	1/4			04/02/92 P/P-2'1"	758	PASS C/S AF 1 3/4 AR 1 3/4		Z
SPDCB 106H 21 RECIRC NONIMPACTING B LOOP	22905	1/4			04/01/92	1541	PASS C/S AF 1 1/2 AR 1 1/2		Z
SPDCB 106H2013 RECIRC NONIMPACTING B LOOP	23588	1/4			04/01/92	1520	PASS C/S AF 1 1/4 AR 1 1/4		Z
SPDCB 106H2014 RECIRC NONIMPACTING B LOOP	13047	1/4			04/01/92	1445	PASS C/S AF 2.25 AR 2.25		Z
SPDCB 106H2018 RECIRC NONIMPACTING B LOOP	28792	1/4			04/01/92	1544	PASS C/S AF 2 AR 2		Z
SPDCB 106H2020 RECIRC NONIMPACTING B LOOP	05056	1/4			04/02/92	1405	PASS C/S AF 2 AR 2		Z
SPDCB 106H2022 RECIRC NONIMPACTING B LOOP	04725	1/4			X	0			X
SPDCB 106H2027 RECIRC NONIMPACTING B LOOP	22934	1/4			04/01/92	1510	PASS C/S AF 2.5 AR 2.5		Z
SPDCB 106H2028 RECIRC NONIMPACTING B LOOP	14373	1/2			04/02/92 P/P-1'8"	819	PASS C/S AF 3/4 AR 3/4		Z
SPDCB 108H2015 RECIRC NONIMPACTING B LOOP	18581	1			X P/P 1'9 3/4"	0			X
SPDCB 111H2011 RECIRC NONIMPACTING A LOOP	18552	1			X P/P 2'11 1/2"	0			X
SPDCB 111H2012 RECIRC NONIMPACTING A LOOP	16408	1/4			X P/P 3'1 1/4"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCB 112H 50	06241	1/4			04/06/92	746	PASS		Z
1C005 LOW PRESS ECCS IMPACT							C/S AF 1 3/4 AR 1 3/4		
SPDCB 112H2003	23599	1/4		X		0			X
1C005 LOW PRESS ECCS IMPACT					P/P 3'0"				
SPDCB 112H2014	13942	1/2		X		0			X
1C005 LOW PRESS ECCS IMPACT									
SPDCB 112H2026	13098	1/4			04/05/92	1004	PASS		Z
1C005 NOIMPCT TO LOW PRES ECCS							C/S AF 2 AR 2		
SPDCB 112H2041	10906	1/4			03/30/92	2148	PASS		Z
1C004 NOIMPCT TO LOW PRES ECCS							C/S AF 2 1/2 AR 2 1/2		
SPDCB 112H2044	23584	1/4			03/31/92	14	PASS		Z
1C004 NOIMPCT LOW PRES ECCS							C/S AF 1 3/4 AR 1 3/4		
SPDCB 112H2046	16423	1/4			04/06/92	829	PASS		Z
1C005 LOW PRESS ECCS IMPACT					P/P-2'8"			C/S AF 2 AR 2	
SPDCB 112H2048	04208	1/4			04/06/92	807	PASS		Z
1C005 RACK IMPCT LOW PRES ECCS								C/S AF 2 AR 2	
SPDCB 112H2071	22911	1/4			03/31/92	211	PASS		Z
1C004 NOIMPCT LOW PRES ECCS					P/P-2'6"			C/S AF 2 AR 2	
SPDCB 112H2075	22910	1/4			03/30/92	1840	PASS		Z
1C004 NOIMPCT LOW PRES ECCS							C/S AF 1 3/4 AR 1 3/4		
SPDCB 112H2089	27863	1/4		X		0			X
JET PP DIV II IMPACTING									
SPDCB 112H2094	22861	1/4		X		0			X
JET PMP DIV 1 IMPACTING									
SPDCB 112H2098	20958	1/4		X		0			X
JET PP DIV II IMPACTING									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPDCB 120H2001	06321	1/4		92-078	03/22/92	1330	PASS	C/S AF .75 AR .75	Z
RECIRC NONIMPACTING A LOOP									
SPDCB 120H2002	13957	1/2	R		03/22/92	1650	PASS	C/S AF .75 AR .75	Z
RECIRC NONIMPACTING A LOOP									
SPDCB 120H2003	14409	1/4			03/21/92	2348	PASS	C/S AF 1 1/2 AR 1 1/2	Z
RECIRC NONIMPACTING A LOOP									
SPDCB 120H2008	14410	1/4			03/22/92	224	PASS	C/S AF 2 1/4 AR 2 1/4	Z
RECIRC NONIMPACTING A LOOP									
SPDCB 121H 9	29318	1/4			X	0			X
RECIRC NONIMPACTING B LOOP									
SPDCB 121H 10	14415	1/4			03/23/92	2352	PASS	C/S AF 1 1/2 AR 1 1/2	Z
RECIRC NONIMPACTING B LOOP					P/P-3'3"				
SPDCB 121H2001	14329	1/4			03/23/92	1843	FAIL	C/S AF 2 1/4 AR 2 1/4	Z
RECIRC NONIMPACTING B LOOP									
SPDCB 121H2003	14330	1/4			03/23/92	2134	PASS	C/S AF 1 3/4 AR 1 3/4	Z
RECIRC NONIMPACTING B LOOP									
SPDCB 121H2008	22941	1/4			03/23/92	2103	PASS	C/S AF 2 3/4 AR 2 3/4	Z
RECIRC NONIMPACTING B LOOP									
SPDCB 121H2009	00120	1L	F		03/24/92	1546	PASS	C/S AF 2 1/2 AR 2 1/2	Z
RECIRC NONIMPACTING B LOOP					P/P-3'7"				
SPEBD 114H2011	05606	1/2			X	0			X
HPCI STM SUPPLY OUTSIDE									
SPGGB 101H2002	09935	1/2			X	0			X
CORE SPRAY 'A' LOOP DISCH									
SPGGB 101H2022	05004	1			X	0			X
CORE SPRAY 'A' LOOP DISCH									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPG88 104H2011 DIV I LPCI/SDC RHR	09725	1/4			X	0			X
SPG88 104H2013 DIV I LPCI/SDC RHR	06242	1/4			03/17/92 PUMP MOD	842	PASS C/S AF 2 1/6 AR 2 1/6		03/24/92
SPG88 104H2018 DIV I LPCI/SDC RHR	05078	1/4			03/17/92 PMP MOD, P/P4'6 7/16"	1304	PASS CS AF & AR 2 1/16"		03/24/92
SPG88 105H 15 DIV II LPCI/SDC RHR	13959	1/2			X	0			X
SPG88 105H2009 DIV II LPCI/SDC RHR	22860	1/4			X	0			X
SPG88 105H2010 DIV II LPCI/SDC RHR	13428	1/2			X P/P 3'0 15/16"	0			X
SPG88 105H2018 DIV I LPCI/SDC RHR	20825	1			X	0			X
SPG88 105H2019 DIV I LPCI/SDC RHR	13446	1/2			X	0			X
SPG88 105H2026 DIV I LPCI/SDC RHR	06240	1/4			X	0			X
SPG88 105H2037 DIV I LPCI/SDC RHR	19505	3			X P/P 3'2 3/8"	0			X
SPG88 106H 2 DIV I LPCI/SDC RHR	23059	1/4			X	0			X
SPG88 106H 5 DIV I LPCI/SDC RHR	27924	1/4			X	0			X
SPG88 106H 6 DIV I LPCI/SDC RHR	21147	1/4			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPGBB 106H 8	04321	1/4			X		0		X
DIV II LPCI/SDC RHR					P/P 3'0 1/8"				
SPGBB 106H 11	17238	1/2			X		0		X
DIV II LPCI/SDC RHR									
SPGBB 106H 12	23058	1/4			X		0		X
DIV II LPCI/SDC RHR									
SPGBB 110H2015	21066	1/4			X		0		X
DIV I LPCI/SDC RHR									
SPGBB 110H2018	21087	1/4			X		0		X
DIV I LPCI/SDC RHR									
SPGBB 110H2024	21094	1/4			X		0		X
DIV I LPCI/SDC RHR									
SPGBB 114H2001	16433	1/4			X		0		X
DIV I LPCI/SDC RHR									
SPGBB 115H 1	13053	1/4			X		0		X
DIV II LPCI/SDC RHR									
SPGBB 115H2000	22908	1/4			X		0		X
DIV II LPCI/SDC RHR									
SPGBB 115H2001	22932	1/4			X		0		X
DIV II LPCI/SDC RHR									
SPGBB 115H2008	28801	1/4			X		0		X
DIV II LPCI/SDC RHR					P/P 2'0 1/4"				
SPGBB 122H2004	19558	3			X		0		X
DIV I LPCI/SDC RHR					P/P 2'6 1/2"				
SPGBB 122H2006	09932	1/2			X		0		X
DIV I LPCI/SDC RHR									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPG88 122H2012	28934	1/4			X		0		X
DIV II LPCI/SDC RHR					P/P 3'8 1/8"				
SPG88 122H2014	28739	1/4			X		0		X
DIV II LPCI/SDC RHR					P/P 2'10 5/8"				
SPG88 122H2017	06585	3			X		0		X
DIV II LPCI/SDC RHR									
SPG88 131H2007	22880	1/4			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPG88 133H 16	12963	1/2			X		0		X
MAIN STEAM LEAKAGE CONTROL									
SPG88 134H 3	10918	1/4			X		0		X
MAIN STEAM LEAKAGE CONTROL					P/P 2'2 1/2"				
SPH88 108H2004	16781	1			X		0		X
HPCI STM EXHAUST					P/P 2'2 3/8"				
SPH88 120H2003	09944	1/2			X		0		X
DIV I LPCI/SDC RHR									
SPH88 135H 4	28990	1/4			X		0		X
HPCI STM EXHAUST									
SPH88 135H2002	28948	1/4			X		0		X
HPCI STM EXHAUST									
SPH88 135H2005A	21146	1/4			X		0		X
HPCI STM EXHAUST					P/P 2'2 1/8"				
SPH88 135H2005B	23624	1/4			X		0		X
HPCI STM EXHAUST					P/P 2'2 1/8"				
SPH88 135H2007	09703	1/4			X		0		X
HPCI STM EXHAUST					P/P 2'5 3/8"				

LEGEND

X OR V = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 H = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPHBB 135H2008 HPCI STM EXHAUST	21115	1/4			X P/P 1'11 3/8"	0			X
SPHBB 135H2010 HPCI STM EXHAUST	13944	1/2			X	0			X
SPHBB 137H2001 RCIC STM EXHAUST	14389	1/2			X P/P 2'10 7/16"	0			X
SPHBB 137H2003 RCIC STM EXHAUST	21123	1/4			X	0			X
SPHBB 137H2004 RCIC STM EXHAUST	10750	1/2			X	0			X
SPHBC 78H2013 DIESEL GEN C	13430	1/2			X	0			X
SPHBC 78H2014 DIESEL GEN C	04999	1			X	0			X
SPHBC 78H2061 DIESEL GEN B	17214	1/2			X P/P-1'11"	0			X
SPHBC 139H2063 ESW U1 B LOOP	22939	1/4			X	0			X
SPHBD 105H2000 RECIRC NONIMPACTING A LOOP	14366	1/4			03/18/92	256	PASS C/S AF 2 1/2 AR 2 1/2		Z
SPHBD 174H2002 RHR COMMON IMPACTING	13418	1/2			X	0			X
SPHBD 174H2009 DIV 1 LPCI/SDC RHR	17234	1/2			X	0			X
SPHBD 174H2010 DIV 1 LPCI/SDC RHR	13407	1/2			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPHBD 199H2004 RCIC STM EXHAUST	23032	1/4			X P/P 1'8 5/8"	0			X
SPHBD 563H2002 RHR/RECIRC S.P.NONIMPACTING	22999	1/4			X	0			X
SPHBD 563H2004 RHR/RECIRC S.P.NONIMPACTING	23002	1/4			X	0			X
SPHBD1115H2002 RHR/RECIRC S.P.NONIMPACTING	13439	1/2	S		03/24/92	2119	PASS	C/S AF 1 AR 1	Z
SPHBD1115H2003 RHR/RECIRC S.P.NONIMPACTING	28780	1/4			03/25/92 P/P-4'3"	1343	PASS	C/S AF 2 AR 2	Z
SPHBD1115H2009 RHR/RECIRC S.P.NONIMPACTING	22931	1/4			03/25/92	30	PASS	C/S AF 2 AR 2	Z
SPHBD1147H3036 CS CHILLED WATER A LOOP	17228	1/2			X P/P 2'0 3/8"	0			X
SPHBD1148H3034 CS CHILLED WATER B LOOP	13953	1/2			X P/P 3'6 3/8"	0			X
SPHBD1149H3036A CS CHILLED WATER A LOOP	23556	1/4			X P/P 3'0"	0			X
SPHBD1149H3036B CS CHILLED WATER A LOOP	22943	1/4			X P/P 3'0"	0			X
SPHBD1502H2002 DIV I LPCI/SDC RHR	23006	1/4			X	0			X
SPHBD1502H2003 DIV I LPCI/SDC RHR	23007	1/4			X	0			X
SPHBD1503H2004 RHR/RECIRC S.P.NONIMPACTING	14380	1/4			X	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPHBD1503H2006 DIV I LPCI/SDC RHR	22916	1/4	S		03/20/92	1200	PASS	C/S AF 3" AR	03/21/92 3"
SPHBD1530H2001 RHR/RECIRC S.P.NONIMPACTING		1/4			X	0			X
SPHBD1533H2014 DIV I LPCI/SDC RHR	10728	1/2			X	0			X
SPHBD1533H2017 DIV I LPCI/SDC RHR	23589	1/4			X	0			X
SPHBD1534H2000 DIV I LPCI/SDC RHR	14377	1/4			X	0			X
SPHBD1538H2000 HPCI S.P. LEVEL INSTRUMENTATON	28803	1/4			X	0			X
SPHBD1545H2000 RHR/RECIRC S.P.NONIMPACTING	23579	1/4			X	0			X
SPHBD1545H2001 RHR/RECIRC S.P.NONIMPACTING	06285	1/4			X	0			X
SPHBD1545H2002 RHR/RECIRC S.P.NONIMPACTING	06297	1/4			X	0			X
SPHBD1546H2000 DIV I LPCI/SDC RHR	21064	1/4			X	0			X
SPHBD1547H2001 DIV I LPCI/SDC RHR	21077	1/4			X	0			X
SPHBD1548H2001 DIV I LPCI/SDC RHR	23015	1/4			X P/P 2'4 1/4"	0			X
SPHBD1549H2000 DIV I LPCI/SDC RHR	23018	1/4			X P/P 2'6 1/4"	0			X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPHBD3001H2000	10732	1/2			X		0		X
CS CHILLED WATER B LOOP									
SPHBD3003H2004	10925	1/4			X		0		X
CS CHILLED WATER B LOOP									
SPHBD3036H2001	27843	1/4			X		0		X
CS CHILLED WATER A LOOP									
SPHBD3061H2009	18797	1			X		0		X
SBGT A TRAIN					P/P 3'0 5/8"				
SPHBD3061H2011	18807	1			X		0		X
SBGT B TRAIN									
SPHBD5017H2014	22966	1/4			X		0		X
DIV II LPCI/SDC RHR									
SPHBD5018H2000	27945	1/4			X		0		X
DIV II LPCI/SDC RHR					P/P 2'6"				
SPHBD5018H2002	23560	1/4			X		0		X
DIV II LPCI/SDC RHR									
SPHBD5018H2003	23004	1/4			X		0		X
DIV II LPCI/SDC RHR					P/P 2'3 5/8"				
SPHBD5018H2005	23005	1/4			X		0		X
DIV II LPCI/SDC RHR									
SPHBD5018H2009	13398	1/2			X		0		X
DIV II LPCI/SDC RHR					P/P 2'2 1/4"				
SPHBD5025H2004	14377	1/2			X		0		X
RWCU RETURN NONEFFECTING FW					P/P 2'4"				
SPHBD5025H2005	12180	1			X		0		X
RWCU RETURN NONEFFECTING FW									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPHBD5063H2003	16406	1/4			X		0		X
RHR/RECIRC S.P.NONIMPACTING									
SPHBD5063H2009	16407	1/4			X		0		X
RHR/RECIRC S.P.NONIMPACTING									
SPHBD5063H2015	23042	1/4			X		0		X
RHR/RECIRC S.P.NONIMPACTING									
SPHCB 105H2008	23572	1/4			X		0		X
SBLC OUTSIDE CONT									
SPHCB 106H 2	16354	1/4			X		0		X
CAC SAMPLING									
SPHCB 106H 3	16355	1/4			X		0		X
CAC SAMPLING									
SPHCB 109H2012	21104	1/4			X		0		X
CAC SAMPLING					P/P 2'2 1/2"				
SPHCB 121H 2	23003	1/4			X		0		X
CAC SAMPLING					P/P 2'4 1/2"				
SPHCB 121H 5	13073	1/4			X		0		X
CAC SAMPLING									
SPHCB 122H2005	16440	1/4			X		0		X
CAC SAMPLING									
SPHCB 125H 2	13125	1/4	F		03/10/92	952	PASS		03/11/92
CAC SAMPLING					P/P 2'10 11/16"			C/S AF 2" AR 2"	
SPHCB 126H2007	28782	1/4			X		0		X
CAC SAMPLING					P/P 4'6 1/4"				
SPHCB 126H2015	06249	1/4			X		0		X
CAC SAMPLING									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID ----- SYSTEM DESC	SERIAL -----	SIZE -----	ORIGIN -----	NCR NUM ----- NCR NUM -----	TEST DATE ----- MEMO -----	TEST TIME -----	PASS FAIL -----	REPLACED S/NUM -----	REINSTALLED DATE -----
SPHCB 126H2018 CAC SAMPLING	21063	1/4			X		0		X
SPHCB 126H2022 CAC SAMPLING	16356	1/4			X		0		X
SPHCB 126H2024 CAC SAMPLING	22893	1/4			X		0		X
SPHCB 126H2027 CAC SAMPLING	22988	1/4			X		0		X
SPHCB 126H2028 CAC SAMPLING	23043	1/4			X		0		X
SPHCB 126H2030 CAC SAMPLING	16402	1/4			X		0		X
SPHCB 126H2033 CAC SAMPLING	14373	1/4			X		0		X
SPHCB 126H2035 CAC SAMPLING	28933	1/4			X P/P 3'3 11/16"		0		X
SPHCB 126H2525 CAC SAMPLING	14383	1/2			X		0		X
SPHCB 127H2000 CAC SAMPLING	16414	1/4			X		0		X
SPHCB 129H2000 CIG SUCTION & TIP	13417	1/2			X		0		X
SPHCB 138H2001 CAC SAMPLING	21071	1/4			X		0		X
SPHCB 138H2003 CAC SAMPLING	22874	1/4			X		0		X

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPHCB 138H2004 CAC SAMPLING	10752	1/2			X	0			X
SPHCB 139H2004 CAC SAMPLING	06290	1/4			X	0			X
SPHCB 139H2006 CAC SAMPLING	18583	1			X	0			X
SPHCB 142H2000 MAIN STEAM LEAKAGE CONTROL	23036	1/4			X P/P 1'6 7/8"	0			X
SPHCB 153H2001 CAC SAMPLING	28838	1/4			X	0			X
SPHCC 131H2019 MAIN STEAM 'C' LINE IN CONT	29279	1/4	CF	92-087 92-085	03/15/92 P/P 4'3 7/8"	903	FAIL	27972-82 C/S AF 1 AR 1	04/14/92
SPHCC 138H2008 MAIN STEAM 'D' LINE IN CONT	29288	1/4	CF		03/15/92 P/P 4'4"	837	FAIL	21091-81 C/S AF 1 5/8 AR 1 5/8	04/14/92
SPHCC 138H2009 MAIN STEAM 'D' LINE IN CONT	28829	1/4	CF		03/15/92	916	FAIL	14344-80 C/S AF 3 AR 3	04/14/92
SPHCD3063H2005 CHLORINE DETECTION	16372	1/4			03/25/92	2042	FAIL	Z C/S AF 2 AR 2	
SPHRC 11H2000 ESW 'A' LOOP ISOLABLE PIPE	10731	1/2			X	0			X
SPHRC 11H2001 ESW 'A' LOOP ISOLABLE PIPE	13941	1/2			X	0			X
SPHRC 123H2001 ESW U1 B LOOP	13412	1/2			X	0			X
SPHRC 136H1001 RHR SW 'A' LOOP RETURN	21160	1/4	F	92-053	03/17/92	814	PASS	C/S AF 1.5 AR 1.5	03/18/92

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPHRC 136H1005	22947	1/4			X		0		X
RHR SW 'B' LOOP RETURN									
SPHRC 136H2000	22971	1/4			X		0		X
RHR SW 'B' LOOP RETURN									
SPHRC 136H2001	23631	1/4			X		0		X
RHR SW 'B' LOOP RETURN									
SPJBD 188H 12	19503	3			03/14/92	1142	PASS		Z
HEAD VENT IN CONT					CLAMP REMOVED		C/S AF 2 1/2" AR 2 1/2"		
SPJBD 188H2001	13078	1/4			X		0		X
VESSEL FLANGE LEAKOFF									
SPJCD 107H2004	22975	1/4			X		0		X
SBLC OUTSIDE CONT									
SPJCD 114H2004	23011	1/4			X		0		X
CIG/MSIV & NONADS SRV									
SPJCD 115H 113	06324	1/4			X		0		X
CIG/MSIV & NON ADS SRV									
SPJCD 115H2005	23023	1/4			X		0		X
CIG/MSIV & NON ADS SRV									
SPJCD 127H2002	22937	1/4			X		0		X
CIG SUCTION & TIP									
SPXBD 535H2006	28784	1/4			X		0		X
DIV I LPCI/SDC RHR					P/P 2'7 5/8"				
SPXBD 535H2007	10735	1/2			X		0		X
DIV I LPCI/SDC RHR									
SPXBD 535H2008	23575	1/4			X		0		X
DIV I LPCI/SDC RHR									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

UNIT 1 6TH RFO -- SNUBBER FUNCTIONAL EXAMS -- APPENDIX C.1
 AS OF: 07/20/92 TIME: 11.11.32

SNUBBER ID	SERIAL	SIZE	ORIGIN	NCR NUM	TEST DATE	TEST TIME	PASS FAIL	REPLACED S/NUM	REINSTALLED DATE
SYSTEM DESC				NCR NUM	MEMO				
SPXBD 551H2004	23057	1/4			X		0		X
DIV II LPCI/SDC RHR									
TOTAL: 1639									

LEGEND

X OR Y = NOT TESTED, Z = NOT REINSTALLED, S = INITIAL SAMPLE
 N = NCR, F = PREVIOUS FAILURE, B = REBUILT SNUBBER, C = SPECIAL CASE

SNUBBER VISUAL TESTING LISTING



Snubber visual examinations were not performed during the U1-6RIO because of changes to Technical Specification requirements governing snubber visual examinations.

MECHANICAL MAINTENANCE

NIS-2 FORMS

ASME REPAIRS AND REPLACEMENTS

1. INTRODUCTION

This section of the Summary Report contains work performed on ASME Section XI Items identified by Maintenance Work Authorizations (WA's). The scope of work addressed encompasses the period from completion of the Unit 1 Fifth Refuel Outage to the completion of the Unit 1 Sixth Refuel Outage.

2. CODE COMPLIANCE SUMMARY

All work on ASME Section XI items meets the requirements of IWA-4000 (Repairs) and IWA-7000 (Replacements) in Section XI.

3. Maintenance is responsible for conducting repairs and replacements under the WA process and documented on NIS-2 forms. The detailed listing of work performed is summarized below. The NIS-2 forms are attached.

SYSTEM / CLASS	W. A. NUMBER	DESCRIPTION
024 (R-1)	S23196	Seal weld drain plug on oil filter canister.
147 (R-1)	S83497	Machine gasket seating area on manway cover and perform weld build-up.
024A III	S15351	SP-GBC-4-3 Remove drain trap and weld new one into place.
125A III	S23075	PVC-12648 Reworked and replaced internals.
125A III	S23074	PVC-12643 Remove spring housing for disassembly, rework, and tack weld.
149	P12235	Replace RHR cooler 1E217C.
149A II	U13043-U13046	1P202A-1P202D Mechanical RHR pump seals were replaced.
149D II	S05441	PSV-15113 Disc and nozzle were machined.
150B II	P13041	PSE 1D001 Rupture disc was replaced for regular three year PM.
152B II	P13039	PSE 1D003 16" inner rupture disc was replaced with new one.
153A II	H10111	148F004A and 148F004B Fire squib valves were replaced.
155B	S13584, S14338	HCU 26-59 and HCU 30-03 accumulators were replaced.
162A I	S13801	PSV141F013 were machined on two MSRV's.
162A I	H10161-H10177	Replaced MSRV's for periodic testing.
162A I	S14988	Replaced discs, nozzles and one inlet stud.
162A I	H10160	Replaced fourteen nuts and seven studs.
164A I	S05560	Replaced the seal on pump 1P401A.
183A I	S23275	HV-141F028A Stem of MSIV was replaced.
183A I	U03040, U03038	MSIV Packing leakoff piping removed and replaced with a cap.

DESIGN CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that the design changes described in this report conform to the requirements of the National Board Inspection Code.

ASME Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date N/A 19N/A N/A Signed N/A
(name of organization) (authorized representative)

CERTIFICATE OF REVIEW OF DESIGN CHANGE

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of N/A and employed by N/A

N/A of N/A has examined the design change as described in this report and verifies that to the best of his knowledge and belief such change complies with the applicable requirements of the National Board Inspection Code. By signing this certificate, neither the undersigned nor his employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date N/A 19N/A Signed N/A Commissions N/A
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)

CONSTRUCTION CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that all construction and workmanship of repair conform to the National Board Inspection Code.
(repair or alteration)

Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date Dec. 22 1989 Penna., Power & Light Co. Signed [Signature]
(repair or alteration organization) (authorized representative)

CERTIFICATE OF INSPECTION

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of Penna. and employed by Arkwright Mutual Insurance Company of Waltham, MA has inspected the work described in this report on 2/14 1992

and state that to the best of my knowledge and belief this work has been done in accordance with the National Board Inspection Code. By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date 6/9 1992 Signed [Signature] Commissions PA 2459
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)

FACTORY MUTUAL SYSTEM

FORM R-1, REPORT OF WELDED REPAIR OR ALTERATION
as required by the provisions of the National Board Inspection Code

1. Work performed by Owner WA 883497
(name of repair or alteration organization) (P.O. no., job no., etc.)
2. Owner Pennsylvania Power and Light Co.
(name)
Two N. Ninth Street, Allentown, PA 18101
(address)
3. Location of Installation Susquehanna Steam Electric Station
(name)
Berwick, PA 18603
(address)
4. Unit Identification: Water Heater Name of original manufacturer: YUBA
(boiler, pressure vessel)
5. Identifying nos.: 72-H-714-5B 2216 Pa 460977 1E105B 1975
(nr's, serial no.) (original National Board no.) (jurisdiction no.) (other) (year built)
6. Description of work: Machine gasket seating area on manway cover and perform weld build-up.
(use back, separate sheet, or sketch if necessary)

Pressure test, if applied _____ psi

7. Replacement Parts. Attached are Manufacturers' Partial Data Reports properly identified and signed by Authorized Inspectors for the following items of this report:

(name of part, item number, nr's name and identifying stamp)

8. Remarks:

DESIGN CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that the design changes described in this report conform to the requirements of the National Board Inspection Code.

ASME Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date N/A 19N/A Signed N/A
(name of organization) (authorized representative)

CERTIFICATE OF REVIEW OF DESIGN CHANGE

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of N/A and employed by N/A

N/A of N/A has examined the design change as described in this report and verifies that to the best of his knowledge and belief such change complies with the applicable requirements of the National Board Inspection Code. By signing this certificate, neither the undersigned nor his employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date N/A 19N/A Signed N/A Commissions N/A
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)

CONSTRUCTION CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that all construction and workmanship on repair conform to the National Board Inspection Code.
(repair or alteration)

Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date Dec. 22, 1989 Penna., Power & Light Co. Signed [Signature]
(repair or alteration organization) (authorized representative)

CERTIFICATE OF INSPECTION

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of Penna. and employed by Arkwright Mutual Insurance Company of Waltham, MA has inspected the work described in this report on 1-24 19 92

and state that to the best of my knowledge and belief this work has been done in accordance with the National Board Inspection Code. By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date 6/9 19 92 Signed [Signature] Commissions PA 2159
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)
FACTORY MUTUAL SYSTEM

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name

Date July 2, 1992

Two North Ninth St., Allentown, PA 18101
Address

Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name

Unit COMMON

PO Box 467, Berwick, PA 18603
Address

WA# S15351
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name

Type Code Symbol Stamp None

Two North Ninth St., Allentown, PA 18101
Address

Authorization No. N/A

Expiration Date N/A

4. Identification of System 024A III: Diesel Generator and Aux. Systems

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Piping to "B" D/G Drain Trap	ITT Grinnell	N/A	N/A	SP-GBC-43 DT-0343481	1978	Repair	No

7. Description of Work Remove Drain Trap and Weld New One Into Place.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other (Exempt) Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks TESTING: Penetrant test

Applicable Manufacturer's Data Reports to be attached

Drain Trap DT-03434B1 is not code. Weld is code.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SrMal Date July 2, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS

have inspected the components described in this Owner's Report during the period 1-9-92 to 1-28-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. **FACTORY MUTUAL SYSTEM**

D. E. Tillery Commissions NB8845 Pa 2361 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 7 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date May 11, 1992
 Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 WA/S23075
Report Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System 125A III : Primary Containment Instrument Gas

5. (a) Applicable Construction Code III 19 74 Edition, thru W'74 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1" Globe Valve Internals	Target Rock	75KK-403-1	N/A	PCV12848	1979	Replaced	Y
1" Globe Valve Internals	Target Rock	75KK-401-8	N/A	PCV12848	1980	Replacement	Y
1" Globe Valve	Target Rock	75KK-403-1	N/A	PCV12848	1979	Repair	Y

7. Description of Work Valve reworked and internals replaced due to non-repeatable pressure regulation.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Exempt Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this ASME Code, Section XI. REPLACEMENT conforms to the rules of the repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date 6/8, 19 92
Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 5/1/92 to 5/9/92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Inspector's Signature
FACTORY MUTUAL SYSTEM
Commissions NB 7525 PA 2159 NI
National Board, State, Province, and Endorsements

Date 6/9, 19 92

FORM NPV-1 (back)

Mfr. Serial No. N/A

8. Remarks Seat Sleeve, SA-479 316L, S/N 13

Cap, SA-479 316, S/N 6 *Spring Housing, SA-479 316

9. Design conditions 2570 psi 150 °F or valve pressure class N/A (1)
(pressure) (temperature)

10. Cold working pressure N/A psi at 100°F

11. Hydrostatic test 5025 psi Temp. Ambient °F Disk differential test pressure N/A psi

CERTIFICATION OF DESIGN

Design Specification certified by Stephen Gresdo Prof. Eng. state PA Reg. No. 20080-E
 Design Report certified by _____ Prof. Eng. state _____ Reg. No. _____

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III.

N Certificate of Authorization No. 1947 Expires 12-12-92

Date 5/21/90 Name Target Rock Corporation Signed E. Bajada
(N Certificate Holder) (E. Bajada, P.E. Manager)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of New York and employed by Commercial Union Ins. Co. of Boston, Mass. have inspected the pump, or valve, described in this Data Report on 5/22 19 90, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 5/22 19 90
William A. Heland Commissions N. Y. STATE COMMISSION NO. 2288
(Inspector) (Natl Bd., (incl. endorsements) State, Prov. and No.)
 ALSO COMMISSIONED IN PENN., OHIO & CONN.

(1) For manually operated valves only.



PENNSYLVANIA POWER & LIGHT COMPANY
 PH (717) 542-3428

PURCHASE ORDER NO. 8-48454-1

DATE 12/13/88

THIS PURCHASE ORDER NUMBER M
 APPEAR ON ALL PACKAGES, INVOI
 SHIPPING PAPERS AND CORRESPONDE

PURCHASE ORDER
 PURCHASING SECTION COPY
 PAGE 1

SHIP TO

TARGET ROCK CORP
 1966 E BROADHOLLOW RD
 EAST FARMINGDALE NY 11735

PENNSYLVANIA POWER & LIGHT COMPANY
 REF. NO. 8-48454-1
 SUSQUEHANNA SES STOREROOM
 5 MI NE OF BERWICK ON US RT :
 PO BOX 467
 BERWICK PA 18603

ROUTING: UPS-PREPAID OR FRIEDMAN'S EXPRESS - COLLECT

ORDER		DESCRIPTION	PP&L CATALOG OR ITEM NO.	UNIT PRICE
QUANTITY	UNIT			
1	EA	VALVE; PRESSURE REGULATING, FOR: TARGET ROCK 1" REGULATING VALVE, MODEL 75KK-401/GLB, DWG. NO. 75KK-401, REV. G. QUALITY CLASSIFICATION: Q1 ASME CODE CLASS: 3 ***** * DOCUMENTATION REQUIREMENTS * ***** HYDROSTATIC TEST SEAT LEAKAGE TEST LIQUID PENETRANT TEST WALL THICKNESS AND CRITICAL MEASUREMENTS PERFORMANCE TEST MAJOR DEFECT REPAIR REPORT C OF C TO MATL. SPEC. FOR CNP RETAINING ITEMS CERT. OF CONFORMANCE NDI-QA-2.4.7C OR EQUAL ASME CODE DATA REPORT CERTIFIED MATERIAL TEST REPORT FILLER METAL CERTIFIED MATERIAL TEST REPORT A TARGET 75KK401	32528	12,500.00
1	LT	DOCUMENTATION CHARGES; AND/OR SPECIAL ENGINEERING SERVICES; AND/OR PREMIUM HANDLING CHARGES; AND/OR CANCELLATION CHARGES.	199999	1,800.00

CONTINUED

DIRECT PAY PERMIT #132 IS IN EFFECT FOR THIS COMPANY. DO NOT INCLUDE PENNSYLVANIA SALES OR USE TAX.

DATE REQUIRED 9/22/89	F.O.B. POINT OF SHIPMENT	PAYMENT TERMS NET 30 DAYS
PROMISED DELIVERY 09/21/89	SUBJECT 982720	APPROVER: D. G. SUTTON

IMPORTANT NOTICE

This order embodies the entire agreement between the parties, supersedes any prior bids or communications, and is placed subject to the terms and conditions herein stated, including any contained in any documents made a part hereof by the Company by attachment or reference and no agreement or understanding in any way modifying the terms and conditions herein stated shall be binding upon the Company unless acceptance thereof has been signed by its Director, Procurement.
 This order constitutes an offer which shall be deemed accepted by Supplier's acknowledgment (using the acknowledgment copy of this order or any other suitable means of communication), or commencement of work hereunder.

207091


INSTRUCTIONS

1. Mail INVOICES IN TRIPPLICATE to Accounts Payable Section. If freight terms allow for prepaid freight charges, a copy of the freight bill must be furnished with your invoice.
2. Mail ACKNOWLEDGEMENTS to Purchasing Section.
3. Mail above documents to TWO NORTH NINTH STREET, ALLENTOWN, PA 18101.
4. Include PACKING SLIP with each shipment.

Roger A. Inglese

ROGER A. INGLESSE
 DIRECTOR, PROCUREMENT

BUYER
 C J PERLUKE



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name

Date June 30, 1992

 Two North Ninth St., Allentown, PA 18101
Address

Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name

Unit ONE

 PO Box 467, Berwick, PA 18603
Address

 WAF S23074
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name

Type Code Symbol Stamp None

 Two North Ninth St., Allentown, PA 18101
Address

Authorization No. N/A

Expiration Date N/A

4. Identification of System 125A III : Primary Containment Instrument Gas

5. (a) Applicable Construction Code III 19 74 Edition, thru W'74 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1" Globe Valve	Target Rock	75KK-401-1	N/A	PCV-12643	1980	Repair	Yes

7. Description of Work Remove Spring Housing to Allow for Disassembly, Rework, and Tack Weld

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other(Exempt) Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this ASME Code, Section XI. Repair conforms to the rules of the repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed S. S. Lal Date July 2, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-10-92 to 5-9-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

D. E. Tillery Inspector's Signature
FACTORY MUTUAL SYSTEM
Commissions NB8845 Pa 2361 N I
National Board, State, Province, and Endorsements

Date July 7, 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date May 5, 1992
 Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 WA# P12235
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System 149 RHR

5. (a) Applicable Construction Code N/A 19 N/A Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RHR Pump 1C Motor Oil Cooler	G.E.	D80048-001D	N/A	1E217C	N/A	Replaced	No
RHR Pump 1C Motor Oil Cooler	G.E.	D80451-0001D	N/A	1E217C	N/A	Replacement	No

7. Description of Work Replace "C" RHR Cooler

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this ASME Code, Section XI. REPLACEMENT conforms to the rules of the repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date 6/8 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2/10/92 to 5/9/92 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

FACTORY MUTUAL SYSTEM

[Signature]
Inspector's Signature

Commissions NB 7525 PA 2159 NI
National Board, State, Province, and Endorsements

Date 4/9 19 92

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date 6/8 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 1/10/92 to 4/20/92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection. FACTORY MUTUAL SYSTEM

[Signature] Inspector's Signature Commissions NB 7525 PA 2159 NI National Board, State, Province, and Endorsements

Date 6/9 19 92



FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this ASME Code, Section XI. REPAIR conforms to the rules of the repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date 6/8 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS

have inspected the components described in this Owner's Report during the period 4/17/91 to 5/19/92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

FACTORY MUTUAL SYSTEM

[Signature] Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date 6/9 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 6, 1992
Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
WA# P13041
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
Authorization No. N/A
Expiration Date N/A

4. Identification of System 150B II: RCIC

5. (a) Applicable Construction Code III 19 71 Edition, thru S'73 Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Rupture Disc	BS&B	HT#888788	N/A	PSE1D001	1984	Replaced	No
Rupture Disc	BS&B	HT#888788	N/A	PSE1D001	1984	Replacement	No

7. Description of Work Rupture disc was replaced for regular three year PM.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Manufacturer's Data Reports Attached

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this ASME Code, Section XI.

REPLACEMENT
repair or replacement

conforms to the rules of the

Type Code Symbol Stamp

N/A

Certificate of Authorization No.

N/A

Expiration Date

N/A

Signed

[Signature]
Number of Owner's Designations 1 SUPERINTENDENT OF PLANT

Date

6/24

. 19

92

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 1-20-92 to 4-27-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

FACTORY MUTUAL SYSTEM

[Signature]
Inspector's Signature

Commissions

NB 8845 Pa 2361 N.I.
National Board, State, Province, and Endorsements

Date

June 29 19 92



Light
P.O. # 32842-1

SAFETY SYSTEMS

FORM NR-1
DATA REPORT OF RUPTURE DISKS
As Required by the Provisions of the
ASME Code Rules, Section III, Div. 1

1. Manufactured by: BS&B Safety Systems, Inc.
Tulsa, Oklahoma
(Name and address of Manufacturer)

IDENTIFICATION OF RUPTURE DISK

- 2. Type of Style: BV Lot No.: 84090018-1
- 3. Disk Dimensional Characteristics:
Size: 8" Capacity 102485 SCFM Air
- 4. Material Specification: ASTM A167 316 SST
- 5. Drawing No.: N/A
- 6. Burst Pressure: 156.5 PSIG Max. 141.6 PSIG Min.
- 7. Coincident Disk Temperature: 370 Deg F
- 8. Element used in test: Air
- 9. Cyclic Test Results: N/A
(if required)

CERTIFICATION:

10. Place of Test: Tulsa, Oklahoma Date of Test: 10/30/84

WE CERTIFY THE ABOVE DATA TO BE CORRECT AND THAT THESE DISKS
HAVE BEEN MANUFACTURED AND TESTED TO THE REQUIREMENTS OF THE
ASME CODE.

DATE: 10/30/84 ISSUED BY: BS&B Safety Systems, Inc.
APPROVED BY: Jay B. Vance, Quality Control Manager
Jay B. Vance

No. of Pieces Shipped: 20

Actual Burst Test Results: 185 PSIG @ 72 Deg F
148, 150 PSIG @ 370 Deg F

No. 84-2447
RECORD PACKAGE
PAGE 1 OF 1

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name

Date May 6, 1992

Two North Ninth St., Allentown, PA 18101
Address

Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name

Unit ONE

PO Box 467, Berwick, PA 18603
Address

WA# P13039
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name

Type Code Symbol Stamp None

Two North Ninth St., Allentown, PA 18101
Address

Authorization No. N/A

Expiration Date N/A

4. Identification of System 152B II: HPCI

5. (a) Applicable Construction Code III 19 71 Edition, thru s'73 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

8. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Rupture disc	BS&B	HT#888798	N/A	PSE1D003	1984	REPLACED	YES
Rupture disc	BS&B	HT#888798	N/A	PSE1D003	1984	REPLACEMENT	YES

7. Description of Work 16" inner rupture disc was replaced with new one.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM HIS-2 (Back)

9. Remarks

Manufacturer's Data Reports Attached

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this ASME Code, Section XI.

REPLACEMENT conforms to the rules of the repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date 6/8, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 1-20-92 to 4-27-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

FACTORY MUTUAL SYSTEM

[Signature] Commissions NB8845 Pa 2361 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date June 29 19 92



DATA REPORT OF RUPTURE DISKS
As Required by the Provisions of the ASME Code Rules,
Section III, Div. 1

SAFETY SYSTEMS

1. Manufactured by: BS&B Safety Systems, Inc., Tulsa, Oklahoma
(Name and address of Manufacturer)

IDENTIFICATION OF RUPTURE DISK

2. Type or Style No. BV Lot No. 84090025-1

3. Disk Dimensional Characteristics:

Size: 16" Capacity 431,434 SCFM Air

4. Material Specification: ASTM A-167 TY 316 (Stainless Steel)

5. Drawing No. N/A

6. Burst Pressure 166.5 PSIG Max. 150.5 PSIG Min.

7. Coincident Disk Temperature 380 Deg F

8. Element used in tests Air

9. Cyclic Test Results (if required) N/A

CERTIFICATION

10. Place of Test: Tulsa, Oklahoma Date of Test: 10/22/84

We certify the above data to be correct and that these disks have been
manufactured and tested to the requirements of the ASME Code.

SIGNED: BS&B Safety Systems, Inc. BY: D. L. Vavra

DATE: October 22, 1984 D. L. Vavra
Quality Control Manager

No. of Pieces Shipped: 20

Actual Burst Test Results: 183 PSIG @ 72 deg F
160, 157 PSIG @ 380 Deg F

84-2067
4/14

FORM NIS-2 (Back)

9. Remarks Manufacturer's data reports attached

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed S. R. Blay Date July 2, 19 92
Owner or Owner's Designee, Title - SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 4-2-92 to 5-9-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

DE Tilley Commissions NB8845 Pa 2361 N I
Inspector's Signature National Board, State, Province, and Endorsements

Date July 7 19 92

**FORM N-2 N OR N⁺ CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES***

As Required by the Provisions of the ASME Code, Section III, Division 1
Not To Exceed One Day's Production

1. Manufactured and certified by Conax Buffalo Corporation, 2300 Walden Ave., Cheektowaga, NY 14225
(name and address of certificate holder)

2. Manufactured for General Electric Co., 175 Curtner Ave., San Jose, CA 95125
(name and address of purchaser)

3. Location of installation _____
(name and address)

4. Type N-20000 Rev. F 304SST SA479 75 KSI N/A 1991
(drawing no) (natl spec no) (tensile strength) (CRN) (year built)

5. ASME Code, Section III: 77 S77 1 N/A
(edition) (addenda) (class) (Code Case no)

6. Fabricated in accordance with Const. Spec. (Div. 2 only) N/A Revision _____ Date _____
(No)

7. Remarks: Trigger Body Subassembly for explosive actuated valve replacement kit
for standby liquid control system. Para. NB-2121 (b) is applicable to ram.
Pressure tested at 2800 PSI for 10 minutes.

*See Remarks.

8. Nom. thickness (in.) _____ Min. design thickness (in.) _____ Dia. ID (ft. & in.) _____ Length overall (ft. & in.) _____

9. When applicable, Certificate Holders' data reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. In Numerical Order
(1) 3640	3640
(2) 3641	3641
(3) 3642	3642
(4) 3643	3643
(5) 3644 ✓	3644
(6) 3645 ✓	3645
(7) 3646	3646
(8) 3647 ✓	3647
(9) 3648	3648
(10) 3649 ✓	3649
(11) 3650 ✓	3650
(12) 3651	3651
(13) 3652	3652
(14) 3653	3653
(15) 3654	3654
(16) 3655	3655
(17) 3656	3656
(18) 3657	3657
(19) 3658	3658
(20) 3659	3659
(21) 3660	3660
(22) 3661	3661
(23) 3662	3662
(24) 3663	3663
(25) 3664	3664

Part or Appurtenance Serial Number	National Board Number In Numerical Order
(26) _____	
(27) _____	
(28) _____	
(29) _____	
(30) _____	
(31) _____	
(32) _____	
(33) _____	
(34) _____	
(35) _____	
(36) _____	
(37) _____	
(38) _____	
(39) _____	
(40) _____	
(41) _____	
(42) _____	
(43) _____	
(44) _____	
(45) _____	
(46) _____	
(47) _____	
(48) _____	
(49) _____	
(50) _____	

10. Design pressure 1400 psi Temp. 150 °F. Hydro. test pressure *See Remarks. at temp. °F.
(when applicable)

*Supplemental information in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 X 11, (2) information in items 2 and 3 on this data report is included on each sheet, (3) each sheet is numbered and number of sheets is recorded at top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.
16/831

FORM N-2 (back)

CERTIFICATE OF DESIGN

Design specifications certified by Clyde T. Nieh P. E. state CA Reg. no. 15587

Design report* certified by Francis J. Domino P. E. state NY Reg. no. 36832
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Inlet Fittings conform to the rules of construction of the ASME Code, Section III.

ASME Certificate of Authorization no. N-1850 Expires September 2, 1992

Date 7-3-91 Name Conax Buffalo Corporation Signed James G. Schraven
(NPT Certificate Holder) (authorized representative)
James G. Schraven, Q.A. Manager

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or province of New York and employed by H.S.B.I. & I. Co.

of Hartford, CT have inspected these items described in this data report on 7-1-91 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code Section III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 7-3-91 Signed Robert L. Barber Commissions N17784
(Authorized Inspector) (Nat'l Bd (incl. endorsements) state or prov. and no.)

FORM NIS-2 (Back)

9. Remarks

Manufacturer's Data Reports Attached

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NIA

Certificate of Authorization No. NIA Expiration Date NIA

Signed [Signature] Date 6/8, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 10/17/91 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature]
Inspector's Signature

Commissions NB 7525 PA 2159 NI
National Board, State, Province, and Endorsements

Date 6/26, 19 92

1977
 Special Service No. ()
 Manufacturer's Part No. ()
 the following name of the report: ()
 1. Serial No. SA-106-SP-B
 2. Date: ()
 3. Size: Long N/A Seams: ()
 4. No. of Courses: ()
 5. Heads: (a) Material SA-182-F304 (b) Material SA-182-F304
 6. No. of Courses: ()
 7. No. of Courses: ()
 8. Heads: (a) Material SA-182-F304 (b) Material SA-182-F304
 9. No. of Courses: ()
 10. Safety Valve Outlet: Number None Size ()
 11. Nozzles and Inspection Openings: ()
 12. Gas Port: 1 75 Split Flange 30455 1060 None Bolts (4) Botm.
 13. Water Port: 2 97 Split Flange 30455 1300 None Bolts (4) Top
 14. Remarks: Complete Mechanical Assembly with No Welded Joints
 Although a Differential Pressure Exists on each side of the Internal Piston, the Accumulator Cylinder is Hydrostatically tested with the Piston removed. The Hydro-Test pressure is based on the higher design pressure.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.
 Date: 10-21-77 Signed: General Electric Co. by J. P. Williams (Manufacturer) Representative
 "U" Certificate of Authorization No. 10,572 expires June 10, 1978

CERTIFICATE OF SHOP INSPECTION

Vessel made by General Electric Company at Wilmington, N.C.
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of N. Carolina and employed by Dept. of Labor have inspected the pressure vessel described in this Manufacturer's Data Report on 10-21-77 and state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Signed: J. P. Williams Date: 10-21-77 Commission: C-723-PA-1766-0h10 (Inspector) (Natl. Board, State, Province and No.)



FORM U-1A MANUFACTURERS' DATA REPORT FOR PRESSURE VESSEL
 (Alternate Form for Single Chamber, Dimpled and Grooved Pressure Vessels Only)
 As Required by the provisions of the ASME Code, Rules, Section VIII, Division 1

1. Manufactured by General Electric Company - P.O. Box 780, Wilmington, N.C.

2. Manufactured for General Electric

3. Location of installation _____

4. Type Vertical 240 921D593G002 N/A (Year Built) 1977

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1974 and Addenda to S-75 and Code Case Nos. _____

Special Service per UG-120(d) As Per This Data Report - See Remarks Below

Manufacturers' Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: N/A

6. Shell: Mat. SA-106 Gr. B Nom. Thk. .55 in. Allow. In. Diam. 8.70 in. Lgh. 3 ft. 2.38 in.

7. Seams: Long. N/A Seamless r.t. N/A Efficiency _____ % H.T. Temp. _____ F. Time _____ hr

Welding Det. Insp. Log. Book _____ (Spec. Part of Full) No. of Courses _____

8. Heads: (a) Material SA-182-F304 (b) Material SA-182-F304

Location (Top, Bottom, Ends)	Min. Thk.	Cor. Allow.	Crown Radius	Knuckle Radius	Ellipse Ratio	Conical Apex Angle	Flare Radius	Flare Dia.	Side to Pressure (Convex or Concave)
(a) Top	<u>2.5"</u>							<u>7.230</u>	<u>Flathead</u>
(b) Bottom	<u>2.5"</u>							<u>7.230</u>	<u>Flathead</u>

If removable, bolts used (describe other fastenings) 500-13 Bolts-ASME-SA193-87 for Split Flanges (4)

9. Constructed for max. allowable working pressure 2100 psi at max. temp. 400° F. Min. temp. (when less than -20 F) _____ F. Hydrostatic, pneumatic, or combination test pressure 3200 psi.

10. Safety Valve Outlets: Number NONE Size _____ Location _____

11. Nozzles and Inspection Openings:

Purpose (Inlet, Outlet, Drain)	No.	Diag. or Size	Type	Mat.	Nom. Thk.	Reinforcement Mat.	How Attached	Location
<u>Gas Port</u>	<u>1</u>	<u>75"</u>	<u>Split Flng.</u>	<u>30455</u>	<u>1.060</u>	<u>None</u>	<u>Bolts (4)</u>	<u>Bottom</u>
<u>Water Port</u>	<u>1</u>	<u>97"</u>	<u>Split Flng.</u>	<u>30455</u>	<u>1.300</u>	<u>None</u>	<u>Bolts (4)</u>	<u>Top</u>

12. Supports: Skirt No Lugs _____ Legs _____ Other _____ Attached _____

13. Remarks: Complete Mechanical Assembly with No Welded Joints.

Although A Differential Pressure Exists on each side of the Internal Piston, the Accumulator Cylinder is Hydrostatically tested with the Piston removed. The Hydro Test pressure is based on the higher design pressure.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

Date 10-20-77 Signed General Electric Co. by [Signature] (Manufacturer) (Representative)

"U" Certificate of Authorization No. 10,572 expires June 10, 19 78.

CERTIFICATE OF SHOP INSPECTION

Vessel made by General Electric Company at Wilmington, N.C.

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of N. Carolina and employed by Cent of labor have inspected the pressure vessel described in this Manufacturers' Data Report on 10-20 19 77 and state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturers' Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Signed [Signature] (Inspector) Date 10-20-77 Commission No. WC 723, DA WC 755 Ohio (Natl Board, State, Province and No.)

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 8, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 1
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 WAF's S13801
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System 162A I: Reactor Vessel and Aux.

5. (a) Applicable Construction Code III 19 71 Edition, Addenda, 1587.1711 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Main Steam Relief Valve	Crosby	N83790-00-0084	N/A	PSV141F013	1981	Repair	Yes
Main Steam Relief Valve	Crosby	N83790-00-0028	N/A	PSV141F013	1980	Repair	Yes

7. Description of Work Spring washer and adjusting bolt button were machined on two MSR's

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of Exts, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPAIR conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NIA

Certificate of Authorization No. NIA Expiration Date NIA

Signed [Signature] Date 6/8 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 6-29-91 to 4-26-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

FACTORY MUTUAL SYSTEM

[Signature] DE Tilley Inspector's Signature Commissions NB8845 Pa 2361 NJ National Board, State, Province, and Endorsements

Date June 29 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 27, 1992
Sheet 1 of 5

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
WAF's H10161 thru H10177
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp Nona
Authorization No. N/A
Expiration Date N/A

4. Identification of System 162A I: Reactor Vessel and Aux.

5. (a) Applicable Construction Code III 19 71 Edition, N/A Addenda, 1587,1711 Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Main Steam Relief Valve	Crosby	N83790-00-0083	N/A	PSV141F013A	1981	Replaced	Yes
Main Steam Relief Valve	Crosby	N83790-00-0085	N/A	PSV141F013A	1981	Replacement	Yes
Main Steam Relief Valve	Crosby	N83790-00-0112	N/A	PSV141F013B	1981	Replaced	Yes
Main Steam Relief Valve	Crosby	N83790-00-0028	N/A	PSV141F013B	1980	Replacement	Yes
Main Steam Relief Valve	Crosby	N83790-00-0022	N/A	PSV141F013C	1980	Replaced	Yes
Main Steam Relief Valve	Crosby	N83790-00-0088	N/A	PSV141F013C	1981	Replacement	Yes

7. Description of Work Replace MSRVS with reworked/retested MSRVS.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM HIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date 6/18 1992 Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 1-16-91 to 4-26-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

DE Tilley Inspector's Signature Commissions NB8845 Pa 2361 NJ National Board, State, Province, and Endorsements

Date June 29 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 27, 1992

Sheet 2 of 5

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

WAP's H10181 thru H10177
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A


4. Identification of System 162A I: Reactor Vessel and Aux.


5. (a) Applicable Construction Code III 19 71 Edition, N/A Addenda, 1587,1711 Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

Main Steam Relief Valve	Crosby	N83780-00-0088	N/A	PSV141F013D	1981	Replaced	Yes
Main Steam Relief Valve	Crosby	N83780-00-0024	N/A	PSV141F013D	1980	Replacement	Yes
Main Steam Relief Valve	Crosby	N83780-00-0080	N/A	PSV141F013F	1982	Replaced	Yes
Main Steam Relief Valve	Crosby	N83780-00-0025	N/A	PSV141F013F	1980	Replacement	Yes
Main Steam Relief Valve	Crosby	N83780-00-0087	N/A	PSV141F013E	1981	Replaced	Yes
Main Steam Relief Valve	Crosby	N83780-00-0112	N/A	PSV141F013E	1981	Replacement	Yes
Main Steam Relief Valve	Crosby	N83780-00-0092	N/A	PSV141F013G	1981	Replaced	Yes
Main Steam Relief Valve	Crosby	N83780-00-0093	N/A	PSV141F013G	1981	Replacement	Yes
Main Steam Relief Valve	Crosby	N83780-00-0085	N/A	PSV141F013H	1981	Replaced	Yes
Main Steam Relief Valve	Crosby	N83780-00-0031	N/A	PSV141F013H	1980	Replacement	Yes
Main Steam Relief Valve	Crosby	N83780-00-0081	N/A	PSV141F013J	1982	Replaced	Yes





FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date July 1, 1992

Sheet 4 of 5

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

WAF's H10101 thru H10177
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A

4. Identification of System 162A I: Reactor Vessel and Aux.

5. (a) Applicable Construction Code III 19 71 Edition, N/A Addenda, 1587.1711 Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

Main Steam Relief Valve	Crosby	N83780-00-0029	N/A	PSV141F013R	1980	Replaced	Yes
Main Steam Relief Valve	Crosby	N83780-00-0032	N/A	PSV141F013R	1980	Replacement	Yes
Main Steam Relief Valve	Crosby	N83780-00-0019	N/A	PSV141F013S	1980	Replaced	Yes
Main Steam Relief Valve	Crosby	N83780-00-0090	N/A	PSV141F013S	1982	Replacement	Yes
3 Heavy Hex Inlet Nuts	GE	PP&L Cat# 50002	N/A	PSV141F013C	1982	Replaced	No
3 Heavy Hex Inlet Nuts	Crosby	HT# WC3-3	N/A	PSV141F013C	1982	Replacement	No
4 Heavy Hex Inlet Nuts	GE	PP&L Cat# 50002	N/A	PSV141F013J	1982	Replaced	No
4 Heavy Hex Inlet Nut	Crosby	HT# KB4280	N/A	PSV141F013J	1989	Replacement	No
Heavy Hex Inlet Nut	GE	PP&L Cat# 50002	N/A	PSV141F013G	1982	Replaced	No
Heavy Hex Inlet Nut	Crosby	HT# WC3-3	N/A	PSV141F013G	1982	Replacement	No
Heavy Hex Inlet Nut	GE	PP&L Cat# 50002	N/A	PSV141F013M	1982	Replaced	No

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI


1. Owner	<u> Pennsylvania Power & Light Co. </u> <small>Name</small>	Date	<u> May 12, 1992 </u>
	<u> Two North Ninth St., Allentown, PA 18101 </u> <small>Address</small>	Sheet	<u> 5 </u> of <u> 5 </u>
2. Plant	<u> Susquehanna Steam Electric Station </u> <small>Name</small>	Unit	<u> ONE </u>
	<u> PO Box 467, Berwick, PA 18603 </u> <small>Address</small>		<u> WAP's H10181 thru H10177 </u> <small>Repair Organization P.O. No., Job No., etc.</small>
3. Work Performed by	<u> Pennsylvania Power & Light Co. </u> <small>Name</small>	Type Code Symbol Stamp	<u> None </u>
	<u> Two North Ninth St., Allentown, PA 18101 </u> <small>Address</small>	Authorization No.	<u> N/A </u>
		Expiration Date	<u> N/A </u>

4. Identification of System 162A I: Reactor Vessel and Aux.

5: (a) Applicable Construction Code III 19 71 Edition, N/A Addenda, 1587,1711 Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Heavy Hex Inlet Nut	Crosby	HT# WC3-3	N/A	PSV141F013M	1992	Replacement	No
Heavy Hex Inlet Nut	GE	PP&L Cat# 50002	N/A	PSV141F013A	1982	Replaced	No
Heavy Hex Inlet Nut	Crosby	HT# KB4280	N/A	PSV141F013A	1989	Replacement	No
7 Heavy Hex Inlet Nuts	GE	PP&L Cat# 50002	N/A	PSV141F013P	1982	Replaced	No
7 Heavy Hex Inlet Nuts	Crosby	HT# KB4280	N/A	PSV141F013P	1989	Replacement	No
Heavy Hex Inlet Nut	GE	PP&L Cat# 50002	N/A	PSV141F013E	1982	Replaced	No
Heavy Hex Inlet Nut	Crosby	HT# WC3-3	N/A	PSV141F013E	1992	Replacement	No



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 27, 1992

Sheet 1 of 2

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

S14888
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A

4. Identification of System 162A I: Reactor Vessel and Aux.

5. (a) Applicable Construction Code III 19 71 Edition, N/A Addenda, 1587 & 1711 Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Nozzle	Crosby	N93484-37-0040	N/A	PSV-141F013 MSRV 0085	1987	Replaced	No
Nozzle	Crosby	N93184-35-0022	N/A	PSV-141F013 MSRV 0085	1987	Replacement	No
Disc	Crosby	N93185-35-0108	N/A	PSV-141F013 MSRV 0085	1981	Replaced	No
Disc	Crosby	N93185-10-0108	N/A	PSV-141F013 MSRV 0085	1988	Replacement	No
Nozzle	Crosby	N93184-34-0012	N/A	PSV-141F013 MSRV 0091	1988	Replaced	No
Nozzle	Crosby	N93184-37-0038	N/A	PSV-141F013 MSRV 0091	1987	Replacement	No

7. Description of Work Replace Discs, Nozzles, and one inlet stud

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of Ests, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Manufacturer's Data Reports Attached

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. report of replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date 6/8, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 4-3-92 to 5-9-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

FACTORY MUTUAL SYSTEM

D. E. Tilley Commissions NB8845 Pa 2361 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 7 19 92

CROSBY

TABLE 7.1 Valve Serial No. _____

**SAFETY RELIEF VALVE TEST DATA SHEET
MODIFICATION PROGRAM PROCEDURE NO. MP-4400**

Plant: 195971 ET V
Modified Valve Serial No.: _____
Size and Style: 6" N 1576 S BP

Inlet Hydrostatic Tests (Reference Paragraph 7.3)

Nozzle

Nozzle Serial No.: N/A
Test Pressure: _____
Test Duration: _____
Gage No.: _____
Date Calibrated: _____
Bore Diameter (Before Test): _____
Bore Diameter (After Test): _____
Results: _____
Performed By: _____
Signed _____ Dated _____

Crosby: _____
Signed _____ Dated _____
A.N.I.: _____
Signed _____ Dated _____

Disc Insert

Disc Insert Serial No.: 193185-10-0108
Test Pressure: 2370
Test Duration: 15
Gage No.: 462A
Date Calibrated: 1-25-89
Results: Good
Seating Surface I.D. (Before Test): 5.039 5.039 5.039
Parallelism (Before Test): .0005
Seating Surface I.D. (After Test): 5.039 5.029 5.029
Parallelism (After Test): .0005

Performed By: Faggid 1-30-89
Signed _____ Dated _____
Crosby: _____
Signed _____ Dated _____
A.N.I.: _____
Signed _____ Dated _____

NO. 89-0102
RECORD PACK
PAGE 8 OF 8

CROSBY
FINAL DOCUMENTATION
PART DISC (ASSET)
CROSBY S/N 193185-10-0108
HEAT NO. 9102
F.O. 1/30/89
CROSBY

90073221555

CROSBY

9 Crosby Valves & Accessories

WRENTHAM, MASS

QC-220-15

TABLE 7.1 Valve Serial No.: _____

SAFETY RELIEF VALVE TEST DATA SHEET MODIFICATION PROGRAM PROCEDURE NO. MPP-4400

Plant: N28410-9
Modified Valve Serial No.: _____
Size and Style: _____

Inlet Hydrostatic Tests (Reference Paragraph 7.3)

Nozzle

Nozzle Serial No.: N193184-37-0034
Test Pressure: 2370
Test Duration: 15 MIN
Gage No.: 357
Date Calibrated: 7-21-87
Bore Diameter (Before Test): 4.534 4.534 4.534
Bore Diameter (After Test): 4.534 4.534 4.534
Results: Good

Performed By: [Signature] 7-23-87 Dated

Crosby: _____ 7-23-87 Dated
Signed

A.N.I.: _____ N/A Dated
Signed

Disc Insert

Disc Insert Serial No.: N/A
Test Pressure: _____
Test Duration: _____
Gage No.: _____
Date Calibrated: _____
Results: _____
Seating Surface I.D. (Before Test): _____
Parallelism (Before Test): _____
Seating Surface I.D. (After Test): _____
Parallelism (After Test): _____

Performed By: _____ Dated
Signed

Crosby: _____ Dated
Signed

A.N.I.: _____ Dated
Signed

No. 87-1060
RECORD PACKAGE
PAGE 52 OF 73






TABLE 7.1 Valve Serial No.: _____

SAFETY RELIEF VALVE TEST DATA SHEET
MODIFICATION PROGRAM PROCEDURE NO. MPP-4400

Plant: N95971 ET 4
Modified Valve Serial No.: _____
Size and Style: GR10 HB-65-13P

Inlet Hydrostatic Tests (Reference Paragraph 7.3)

Nozzle

Nozzle Serial No.: N/A
Test Pressure: _____
Test Duration: _____
Gage No.: _____
Date Calibrated: _____
Bore Diameter (Before Test): _____
Bore Diameter (After Test): _____
Results: _____

Performed By: _____
Signed _____ Dated _____

Crosby: _____
Signed _____ Dated _____

A.N.I.: _____
Signed _____ Dated _____

Line Insert

Line Insert Serial No.: 5001
Test Pressure: 5.038
Test Duration: _____
Gage No.: _____
Date Calibrated: 1-28-89
Results: GOOD
Seating Surface I.D. (Before Test): 5.038 5.038 5.038
Parallelism (Before Test): .0002
Seating Surface I.D. (After Test): 5.038 5.038 5.038
Parallelism (After Test): .0002


Performed By: F. Fazio 1-28-89
Signed _____ Dated _____

Crosby: _____
Signed _____ Dated _____

A.N.I.: _____
Signed _____ Dated _____

CROSBY
FINAL DOCUMENTATION
PART DIS-INSET
CROSBY S/N N95971-7-011 0112
HEAT NO. 911592
P.O. N9597100 ITEM 014
CUSTOMER P.O. 3-31679-1

NO. 89-0102
RECORD PACKAGE
PAGE 17 OF 23



CROSBY VALVE & GAGE COMPANY
WRENTHAM, MASS

QC-220-15

TABLE 7.1 Valve Serial No.:

SAFETY RELIEF VALVE TEST DATA SHEET
MODIFICATION PROGRAM PROCEDURE NO. MPP-4400

Plant: N85290 17.2
Modified Valve Serial No.: _____
Size and Style: _____

Inlet Hydrostatic Tests (Reference Paragraph 7.3)

Nozzle

Nozzle Serial No.: N/A
Test Pressure: _____
Test Duration: _____
Gage No.: _____
Date Calibrated: _____
Bore Diameter (Before Test): _____
Bore Diameter (After Test): _____
Results: _____

Performed By: _____
Signed Dated

Crosby: _____
Signed Dated

A.N.I.: _____
Signed Dated

Disc Insert

Disc Insert Serial No.: N93185-38-0085 ✓
Test Pressure: 2370 psi
Test Duration: 15 MIN
Gage No.: 462 A
Date Calibrated: 11-24-87
Results: Good
Seating Surface I.D. (Before Test): 5.0385 5.0385 5.0385
Parallelism (Before Test): .0005
Seating Surface I.D. (After Test): 5.0385 5.0385 5.0385
Parallelism (After Test): .0005

Performed By: Robert W. Humbach 11-28-87
Signed Dated


Crosby: _____
Signed Dated

A.N.I.: N/A
Signed Dated



NOV 28 1987





FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.

Date July 2, 1992

 Two North Ninth St., Allentown, PA 18101

Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station

Unit ONE

 PO Box 467, Berwick, PA 18603

 H10180
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.

Type Code Symbol Stamp None

 Two North Ninth St., Allentown, PA 18101

Authorization No. N/A

Expiration Date N/A

4. Identification of System 162A I : Reactor Vessel and Aux.

5. (a) Applicable Construction Code III 19 86 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

Nuts	ITT Grinnell	Ht# LN88	N/A	Head Vent	1979	Replaced	No
Nuts	Hub	Ht# C27729	N/A	Head Vent	1992	Replacement	No

7. Description of Work Replaced fourteen nuts

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Manufacturer's Data Reports Attached

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed St. Mal Date July 2, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 4-27-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

FACTORY MUTUAL SYSTEM

DE Tilley Commissions NB8845 Pa 2361 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 7 19 92

CERTIFICATE OF PERFORMANCE

(Instructions on reverse of this form)

We certify that the listed items shipped and required documentation for same conform to the requirements of the purchase order/release/contract and applicable codes, standards, specifications, and drawings unless otherwise noted below.

- (1) Purchase Order/Release No. or Contract Title: 1-48104-1
- (2) Change Order Notice/Amendment No.: N/A
- (3) Supplier Name: Hub Inc. Energy + Process Div.
- (4) Supplier Address: 2146-B Flintstone Dr. Tucker, Ga. 30084

ITEM IDENTIFICATION

(5) PP&L Order Item No.	(6) PP&L Catalog No.	(7) Quantity Shipped	(8) Description
2	N/A	48 pcs.	1 1/8" - 8 Heavy Hex Nut SA194
			Gr. 7 Htr. C27729 H/c: E2
			MCg: Cardinal

(9) PP&L Approved Exceptions (Attach PP&L Approval Documentation): N/A

(10) J. R. Biffington
Signature (Responsible Supplier Representative)

(11) Q.C. Inspector
(Title)

(12) 3-4-92
Date

HUB INC.

2146 FLINTSTONE DRIVE • TUCKER, GEORGIA 30085 • 404 / 934-3101

MATERIAL CERTIFICATION

CUSTOMER: PENN. POWER & LIGHT (SUSQUEHANNA)
 CUSTOMER P.O. NUMBER: 1-48104-1
 PACKING SLIP NUMBER: 67105EPD (DIRECT SHIPMENT)
 DESCRIPTION: 48 PCS. - 1-1/8"-8 HEAVY HEX NUT SA194 GR.7/
 HT.C27729 H/C:E2 MFG:CIPI ITEM# 2

*SPEC. M-1071, REV.1

*ASME SECTION II, PART A
1989 EDITION THRU 1990 ADDENDA

Based on review of supporting documentation, we hereby certify that to the best of our knowledge and belief, the material described above is in compliance with ASME Section III Class 1, Subsection NB, 1986 EDITION THRU NO ADDENDA of the Boiler and Pressure Vessel Code, your purchase order, and that all required inspections and tests have been performed with satisfactory results.

The material was purchased from a qualified source and is being supplied in accordance with the Energy & Process Div. Quality Systems Certificate (Materials) Number QSC-332 which expires April 28, 1993, meeting NCA-3800.

The provisions of NRC 10CFR21 apply to this order, and no weld repair was performed.

Hub QAM Rev. 12, DTD. 3/22/91.

J.R. Buffington
SIGNED

Q.C. Inspector
TITLE

3-4-92
DATE

cc: Customer file

Attachments: 5

- PIPE • VALVES • FITTINGS •
- STEAM SPECIALTIES •
- ENGINEERED PRODUCTS •

NO. 95-0206
 RECORD PACKAGE
 PAGE 6 OF 10

Cardinal
INDUSTRIAL PRODUCTS INC.



Manufacturer/Distributor of Quality Products
873 WEST OQUENDO • LAS VEGAS, NEVADA 89118-3098
(702) 739-1966 • FAX (702) 739-1960

Cert No: 85434
Cert Date: 3/27/92
C.I. No: 3105
C.I. Item No: 1
Qty. Ordered: 48
Qty. Shipped: 48

Hub, Inc.
Cust. P.O. No: 0067105-EPD
Cust. Item No: 2

Certification for Item: 1 1/8-8 SA194 Gr.7 Heavy Hex Nuts /
Heat #C27729 / Manufacturer's Mark: C / Grade Mark: 7 /
Heat Code: E2 / Supplemental Mark: 2H DH D 4 3 Lines Tag #1-4810

**** THIS IS A CERTIFICATE OF COMPLIANCE ****

Reshipped parts.

Material has been manufactured in accordance with our Quality System Certificate #518 which expires 1/9/93.

Per ASME B & PV Code, Sec.II, Part A, 1989 Edition thru 1990 Addend Sec.III, Class 1, Subsection NB, 1986 Edition. /

Per Customer Specification: M-1071, Rev.1 /

10 CFR 21 & 10 CFR 50 Appendix B apply.

Heat Treat Condition: Quenched & Tempered. /


Charpy specimens prepared per NX-2322.

Magnetic particle per SA614, 1986 Edition, Para.KW. Results are attached.

Visual inspection per CSP 11.002, Rev.7. Results are attached.

No welding was performed on the above material. /

This is to certify that the contents of this report are correct, accurate and that all test results and operations are in compliance with the material specification and the specific requirements of Section designated by the above purchase order.


Lead Quality Assurance Technician

No. 92-0301
RECORD PACKAGE
PAGE 8 OF 10

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date July 2, 1992

Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

H10180
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A

4. Identification of System 162A I: Reactor Vessel and Aux.

5. (a) Applicable Construction Code III 19 83 Edition, thru W'85 Addenda, Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Studs	ITT Grinnell	Ht# LN97	N/A	Head Vent	1979	Replaced	No
Studs	Nova Machine	Ht# 8085354	N/A	Head Vent	1991	Replacement	No

7. Description of Work Replaced seven studs

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Manufacturer's Data Reports Attached

Applicable Manufacturer's Data Reports to be attached

Three horizontal lines for additional remarks.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date July 2, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION


I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 4-29-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

FACTORY MUTUAL SYSTEM

[Signature] Commissions NB8845 Pa 2361 N I
Inspector's Signature National Board, State, Province, and Endorsements

Date July 7 1992



NOVA MACHINE PRODUCTS
 12001 SHELDON RD.
 MIDDLEBURG HTS., OHIO 44130
 (704) 509-5412 • FAX: (704) 509-5412

NOVA TESTING DIVISION
 1000 Westhause Blvd.
 P.O. Box 7054
 Charlotte, North Carolina 28241
 (704) 509-1131 • FAX: (704) 509-5412

To: NOVA MACHINE PRODUCTS
 12001 SHELDON RD.
 MIDDLEBURG HTS., OHIO 44130

Page 1 of 1
 Herron File No. 91090385
 Purchase Order No. 091079
 Shipper No.
 Inspected 9-9-91 Reported 9-9-91

ord: ND-2500 Level: _____ Class: _____ Grade: _____
 dur: ML-240, Rev. 0
 to: _____ Detail Numbers: _____
 by: _____ Total Inspected: 16 Total Rejected: 0

Magnets Penetrant
 Wet Dry Visible
 Fluorescent Fluorescent
 Wet Thickness
 Ultrasonic

QUANTITY	PART NUMBER	DESCRIPTION	RESULTS
16		1-1/8 x 6-1/2 Stud Heat Code: XJ8 Receipt Lot No. 33484029	All Acceptable
30		1-1/8 x 7-1/2 Stud Heat Code: XJ9 Receipt Lot No. 33484030 QA Codes: 100 104	All Acceptable

CUST.: PPL
 P.O.# 146436-1
 S.O.# 12169 ITEM # 2

**NOVA
 QUALITY ASSURANCE
 APPROVED**

INSP. [Signature] DATE: 9/9/91

COMMENTS Process: Longitudinal, Circular, Wet, Fluorescent,
 Continuous, Demag.
 The items were processed per the Herron Testing Labs Quality Program
 Manual dtd. Feb. 1990 as approved by Nova.

No. 91-1217
 RECORD PACKAGE
 PAGE 10 OF 10

By [Signature] Certification SNT-TC-1A Level II
 J. William Smith

The recording of facts, omissions or transcribing statements or errors on this document may be punished as a felony under federal statutes including federal law, Title 18, Chapter 47.
 The foregoing is expressly limited to actions based upon material information, and no responsibility is assumed or implied for any omissions or errors in the course of the contract
 and/or process as suspected to constitute a crime or liable for any purposes other than that.
 This report is considered to be the confidential property of the recipient. Any disclosure or distribution to other persons without the written permission of the sender is strictly prohibited.

HERRON TESTING LABORATORIES, INC.

5405 E. SCHAAF ROAD • CLEVELAND, OHIO 44131

(216) 524-1450 • FAX: (216) 524-1459

"Testing and Analysis Since 1911"

CHARLOTTE DIVISION

1200-E Westinghouse Blvd.

P.O. Box 7564

Charlotte, North Carolina 28241

(704) 588-1131 • FAX: (704) 588-5412

To:

NOVA MACHINE PRODUCTS
18001 SHELDON ROAD
MIDDLETOWN HTS., OH 44130

Page 1 of 1
Herron File No. 91051381
Purchase Order No. 051381
Shipper No.
Date Reported 5/28/91

ATTN: SANDY

SAMPLE DESCRIPTION

1-1/4" Dia. Bar Test PC, Matl. ASME SA-320, ('86)
Gr. L7, Receipt Lot #32959000, ASME Sec. III:
1983-85W NCA, Certified to 10CFR21, per ASME Sec.
III Sub. NB (NB-2300) NP-2200 Rev. 4.

MECHANICAL TESTING

Wideman-Baldwin, Model SI-IC, S/N 1068.
10 mm X 10 mm x 55 mm Charpy V-Notch Impact Bars

Temp. Deg. F.	Impact Strength (Foot Pounds)	Mils Lateral Expansion	% Ductile Fracture Area
+32	1A 56	30	100
	1B 55	31	100
	1C 55	25	100

Location: Mid-Radius Orientation: Longitudinal
Min. Requirement: 25 MILLS, 45 Ft. Lbs.
These items were processed per the Herron Testing Labs Quality
Program Manual dated February 1990 as approved by Nova.

Respectfully submitted,

HERRON TESTING LABORATORIES, INC.

CUST.: PPL
P.O.# 1-46436-1
S.O.# 12169 ITEM # 1

Kristi Krug
Kristi Krug
Supervisor

NOVA
QUALITY ASSUF
APPROVAL
INSP. SAS DATE 6-6-91

KK

FORM NIS-2 (Back)

9. Remarks None

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date 6/5, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 11-30-90 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NB 7525 PA 2159 NI
Inspector's Signature FACTORY MUTUAL SYSTEM
National Board, State, Province, and Endorsements

Date 6/26 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 8, 1992

Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

WAF's U03040, U03038
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A

4. Identification of System 183A I: Main Steam

5. (a) Applicable Construction Code III 19 71 Edition, thru S'71 Addenda, 1535-2 Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

MSIV Leak-off Piping	Atwood-Morrill	5-221	N/A	HV-141F028A	1971	Replaced	No
Cap	Chicago Tube	HT/CH89	N/A	HV-141F028A	1992	Replacement	No
MSIV Leak-off Piping	Atwood-Morrill	7-221	N/A	HV-141F028C	1971	Replaced	No
Cap	Chicago Tube	HT/CH89	N/A	HV-141F028C	1982	Replacement	No

7. Description of Work MSIV Packing leakoff piping removed and replaced with a cap.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Exempt Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date 6/8, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 6/18/90 to 4/14/92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection)

[Signature] Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements
Date 6/9 19 92

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Date 6/8, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 9-19-90 to 3-31-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

FACTORY MUTUAL SYSTEM

Inspector's Signature DE Tillery Commissions NB 8845 Pa 2361 NI National Board, State, Province, and Endorsements

Date June 28, 19 92

***MODIFICATIONS INSTALLATION
GROUP***

NIS-2 FORMS

WORK ABSTRACT

The Modification Installation Group is responsible for preparing Construction Work Authorizations (work packages) for fabrication and installation of design changes in accordance with ASME Section XI. This work is documented on NIS-2 Forms which are submitted herewith.

MODIFICATION INSTALLATION GROUP

Design Change Packages for ASME Section XI (Class 1, 2 and 3) items, installed in Unit 1 since the completion of the Fifth Refueling Outage through completion of the Sixth Refueling Outage are summarized below:

<u>DESIGN CHANGE PACKAGE NUMBER</u>	<u>SYSTEM/CLASS</u>	<u>DESCRIPTION</u>
88-3031	016A III	RHRWS Heat Exchanger Drains
31-9013A,B,C,&D	023B III	Install Diesel Generator Fuel Oil Vents
90-3046B&D	024A III	Replace Tube Bundles in OE507B&D
89-3031	027*	Modify Sample Piping on Auxilliary Boiler, OS101A
89-3031	027*	Modify Sample Piping on Auxilliary Boiler, OS101B
88-3031, 88-3032, 90-3005	054A III	Install New Isolation Valves and Drains for RHRWS Heat Exchanger
90-3088	054A III	Install PSV-01126E
90-3004	072*	Install Welded Studs on Common Offgas Recombiner OS125
88-3041A	114A*	Retube Heat Exchanger 1E-201A
88-3041B	114A*	Retube Heat Exchanger 1E-201B
92-9024	125A III	Modify Pipe Support SP-HCC-138-H28

DESIGN CHANGE
PACKAGE NUMBER

SYSTEM/CLASS

DESCRIPTION

90-3064A	134K*	Install Vent Valve on Condenser 1K206B
90-3058A	134K*	Install Vent Valve on Condenser 1K206A
88-3051A&B, 89-3027, 89-3028	134D III	Modify Piping, Replace Flex Hoses and Core Spray Room Cooler Coils
89-3027, 89-3028	134E III	Modified Piping at HPCI Room Coolers
88-3047A&B	134E III	Replace Flex Hoses and HPCI Room Cooler Coils
88-3045A&B, 89-3027, 89-3028	134F III	Modified Piping, Replace Flex Hoses and RCIC Room Cooler Coils
88-3049A&B, 89-3027, 89-3028	134G III	Modified Piping, Replace Flex Hoses and RHR Room Cooler Coils
90-3108F	134K II	Snubber Reduction
92-9024	145A I	Feedwater Weld Repair
90-3108J	145A I	Snubber Reduction
90-3108F	149G I	Snubber Reduction
91-9080A&B, 86-9080	149G I	Install New Disc in HV151F015A&B
89-9153A, 89-3049A	149A II	Replace RHR Pump Seal Water Piping
90-3108L	149D II	Snubber Reduction
88-3031	149B III	Install RHRSW Heat Exchanger Drain Valves
90-3108I	150B I	Snubber Reduction
91-3019	150B II	Replace HV150F045
91-9082A&B	151A I	Modify HV152F005A&B Valve Discs
90-3108I	152B I	Snubber Reduction
89-9158A	152K II <i>AB</i> <i>for HPCIC</i>	Install Tubing and Valves for PT 15601

**DESIGN CHANGE
PACKAGE NUMBER**

SYSTEM/CLASS

DESCRIPTION

90-3005	154A III	Install ESW Drain Valves
89-3015D, 88-3047A, 89-9153A	154A III	Remove Keepfill Piping, Remove FE11189A,B,C & D
89-3027, 89-3028	154A III	Modify ESW Piping
89-9153C	154A III	Modified ESW Piping to the RHR Pumps
90-3051A	159A II	Install Tubing and Valves for PT-15729A&B
90-3108L	159A II	Snubber Reduction
90-3035C/D	161B II	RWCU Pump Replacement
90-3035C/D	161B III	RWCU Pump Replacement
90-3108I	162A I	Snubber Reduction
90-3108I	162A I	Snubber Reduction
90-3108L	162A I	Snubber Reduction
90-3108J	162A I	Snubber Reduction
90-3108K	162A I	Snubber Reduction
90-3108K	162A II	Snubber Reduction
90-3092	164B I	Remove 1F027B, 1F028B Valves
90-3108F	164B I	Snubber Reduction
90-3108F	164D II	Snubber Reduction
90-3108F	173A II	Snubber Reduction
90-3108I	183A I	Snubber Reduction
90-3108I	183F I	Snubber Reduction
90-3108I	183D III	Snubber Reduction

*Repair of a Section VIII Component (R-1 Form).

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 7 July, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 6
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCPS: 88-3031 SEE PAGE 4 FOR WA'S
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System RESIDUAL HEAT REMOVAL SERVICE WATER SYSTEM 016A, CLASS III
5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components
 SEE PAGE 5 FOR EXCEPTIONS TO CONSTRUCTION CODE.

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
20", 150#, S.S. BUTTERFLY VALVE	JAMESBURY	ND-285990-01B	N/A	1-12-061	1990	REPLACEMENT	YES
1-1/8" X 6" GR.-B6 STUD BOLTS	PP&L	RIR# 91-0421 HEAT# 26574	N/A	1-12-061	1991	REPLACEMENT	NO
1-1/8" GR.-6F HEAVY HEX NUTS	PP&L	RIR# 91-0421 HEAT# 95962	N/A	1-12-061	1991	REPLACEMENT	NO
LARGE PIPE ASSEMBLY	BECHTEL	N/A	N/A	HRC-112-1	1982	REPLACED	YES
LARGE PIPE ASSEMBLY	PP&L	N/A	N/A	HRC-112-1	1991	REPLACEMENT	NO
SMALL PIPE ASSEMBLY	PP&L	N/A	N/A	SP-HRC-112-6	1991	REPLACEMENT	NO

7. Description of Work ADDITION OF ISOLATION VALVE AND VARIOUS VENT & DRAIN VALVES TO RHRSW.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure SEE PAGE 6
 Other Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE DATA REPORT(S) ATTACHED

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed S. J. Ghah Date July 16, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-4-91 to 4-2-91, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date 7-22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 7 July, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 2 of 6
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP'S: 88-3031 SEE PAGE 4 FOR WA'S
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System RESIDUAL HEAT REMOVAL SERVICE WATER SYSTEM 016A, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components
 SEE PAGE 5 FOR EXCEPTIONS TO CONSTRUCTION CODE.

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
3", 150#, C.S., BLIND FLANGE	BECHTEL	N/A	N/A	HRC-114-1-10	1982	REPLACED	YES
LARGE PIPE ASSEMBLY	PP&L	N/A	N/A	HRC-114-1	1991	REPLACEMENT	NO
SMALL PIPE ASSEMBLY	PP&L	N/A	N/A	SP-HRC-114-2	1991	REPLACEMENT	NO
LARGE PIPE ASSEMBLY	BECHTEL	N/A	N/A	HRC-16-6	1982	REPLACED	YES
LARGE PIPE ASSEMBLY	PP&L	N/A	N/A	HRC-16-6	1991	REPLACEMENT	NO
3", 150#, S.S., FLG'D GATE VALVE	ANCHOR DARLING	EB323-1-19	N/A	0-12-063	1990	REPLACEMENT	YES
3", 150#, S.S., FLG'D GATE VALVE	ANCHOR DARLING	EB323-1-20	N/A	1-12-085	1990	REPLACEMENT	YES
1", 1500#, C.S. GLOBE VALVE	YARWAY	7687	N/A	1-12-075	1977	REPLACEMENT	YES
1", 1500#, C.S. GLOBE VALVE	YARWAY	7864	N/A	1-12-086	1977	REPLACEMENT	YES
LARGE PIPE SUPPORT	BECHTEL	N/A	N/A	HRC-112-1	1982	REPLACED	NO
MECHANICAL SHOCK	PACIFIC SCIENTIFIC	17718	N/A	HRC-112-H1	N/A	REPLACED	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date 7 July, 1992
 Sheet 3 of 6

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 DCP'S: 88-3031 SEE PAGE 4 FOR WA'S
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System RESIDUAL HEAT REMOVAL SERVICE WATER SYSTEM 016A, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components
 SEE PAGE 5 FOR EXCEPTIONS TO CONSTRUCTION CODE.

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HRC-113 H2004	1982	REPLACED	YES
MECHANICAL SHOCK	PACIFIC SICIENTIFIC	19534	N/A	SP-HRC-113 H2004	N/A	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HRC-113 H2005	1982	REPLACED	NO
MECHANICAL SHOCK	PACIFIC SICIENTIFIC	06809	N/A	SP-HRC-113 H2005	N/A	REPLACED	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner <u> Pennsylvania Power & Light Co. </u> <small style="margin-left: 100px;">Name</small> <u> Two North Ninth St., Allentown, PA 18101 </u> <small style="margin-left: 100px;">Address</small>	Date <u> 7 July, 1992 </u> Sheet <u> 4 </u> of <u> 6 </u>
2. Plant <u> Susquehanna Steam Electric Station </u> <small style="margin-left: 100px;">Name</small> <u> PO Box 467, Berwick, PA 18603 </u> <small style="margin-left: 100px;">Address</small>	Unit <u> ONE </u> DCPS: 88-3031 SEE PAGE 4 FOR WA'S <small style="margin-left: 100px;">Repair Organization P.O. No., Job No., etc.</small>
3. Work Performed by <u> Pennsylvania Power & Light Co. </u> <small style="margin-left: 100px;">Name</small> <u> Two North Ninth St., Allentown, PA 18101 </u> <small style="margin-left: 100px;">Address</small>	Type Code Symbol Stamp <u> None </u> Authorization No. <u> N/A </u> Expiration Date <u> N/A </u>

4. Identification of System RESIDUAL HEAT REMOVAL SERVICE WATER SYSTEM 016A, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components
 SEE PAGE 5 FOR EXCEPTIONS TO CONSTRUCTION CODE.

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)

WA#s: Description of Work Performed:

- C13095 Shop fabrication of spool pieces; inspect, pack, and testing of valves; and other miscellaneous prep work
- C13097 Installed branch connection and associated components for vent valve assemblies 1-12-075 & 1-12-086.
- C13100 Installed branch connection and associated components for vent & drain valve assemblies 1-12-075, 1-12-085, & 1-12-086.
- C13101 Hanger Load Balance, set new loads, and permanent removal of snubber supports.
- C13102 Installation of new Stainless Steel Butterfly Valve 1-12-061.
- C13103 Installation of new fire hose connection to RHRSW in ESSW Pump House. Valve 0-12-63.

**FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI**

1. Owner Pennsylvania Power & Light Co. Date 7 July, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Shoot 5 of 6
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP'S: 88-3031 SEE PAGE 4 FOR WA'S
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System RESIDUAL HEAT REMOVAL SERVICE WATER SYSTEM 016A, CLASS III
5. (a) Applicable Construction Code III 19 71 Edition, thru W'72' Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components
 SEE PAGE 5 FOR EXCEPTIONS TO CONSTRUCTION CODE.

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)

EXCEPTIONS TO CONSTRUCTION CODE FROM PAGE 1:

<u>VALVE #S:</u>	<u>CODE YEAR & ADDENDA</u>	<u>CODE CASES:</u>
0-12-063	Section III 1971, Winter 1972	1567
1-12-061	Section III 1971, Winter 1972	NONE
1-12-075	Section III 1974, Winter 1974	NONE
1-12-085	Section III 1971, Winter 1972	1567
1-12-086	Section III 1974, Winter 1974	NONE

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 7 July, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 6 of 6
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP'S: 88-3031 SEE PAGE 4 FOR WA'S
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System RESIDUAL HEAT REMOVAL SERVICE WATER SYSTEM 016A, CLASS III
5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components
 SEE PAGE 5 FOR EXCEPTIONS TO CONSTRUCTION CODE.

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)

TESTS CONDUCTED

<u>VALVE #S</u>	<u>TYPE TEST:</u>	<u>PRES:</u>	<u>TEMP:</u>	<u>DOCUMENT:</u>
0-12-063	System Leak	95	50	SE-216-301
1-12-061	Hydrostatic	185	68	SE-116-311
1-12-075	Hydrostatic	185	68	SE-116-311
1-12-085	Hydrostatic	185	68	SE-116-311
1-12-086	Hydrostatic	185	68	SE-116-311
HRC-112	Hydrostatic	185	68	SE-116-311
HRC-114	Hydrostatic	185	68	SE-116-311

91078231059

FORM NO. 1
An Appendix to the Provisions of the ASME Code

1. Manufactured by Neles-Jamesbury, Inc., 640 Lincoln St., Worcester, PA 01605
(Name and Address of Manufacturer)

2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)

3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric
(Name and Address)

4. Pump or Valve Wafer Valve, Nominal Inlet Size 20" Outlet Size 20"
(Inch) (Inch)

	(a) Model No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Mark. Bd. No.	(g) Year Built
(1)	B15L	ND-285990-01	N/A	ND-285990-01	1	N/A	1990
(2)				Rev. B			
(3)							
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

5. *Station, 5mi NE of Berwick on U.S. RT11
(Brief description of service for which equipment was designed)

6. Design Conditions Seat 177 125° Body 275 psi 100° °F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)

7. Cold Working Pressure 275 psi at 100°F.

8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
PZN-2	351 Gr. CF8M	Neles-Jamesbury	Body
PZU-1	351 Gr. CF8M	Stainless Foundry	Disc
(b) Forgings			


(1) For manually operated valves only.

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the end of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the AMI.

ASME

This form (E00037) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

No. 90-1244
 RECORD PACKAGE
 10 of 58



Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
Bonnet Studs HT.#8875009	SA193-87	Texas Bolt Company	
Bonnet Nuts HT.#6014728	SA194-2H	Texas Bolt Company	
(d) Other Parts			
Disc HT.#A326 S/N 65 & 66	SA479-316L	LTV Steel	

8. Hydrostatic test 425 psi.

CERTIFICATION OF DESIGN

Design information on file as Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
 Stress analysis report on file as N/A
 Design specifications certified by D. Sattar (1) Prof. Eng. State PA Reg. No. 019525E
 Stress analysis report certified by N/A (1) Prof. Eng. State _____ Reg. No. _____
 (1) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date 8/21 19 90 Signed Anchor/Darling Valve Co. by R.L. Stannett
(Manufacturer)

Certificate of Authorization No. N1712 expires 4/15/92

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of ~~PROVINCE~~ Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass. have inspected the equipment described in this Data Report on N-1174a 8-21-90 90, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 8-21 19 90

Charles Young Commissions Pennsylvania 2392
(Inspector) (National Board, State, Province and No.)

FORM NPV-1 (back)

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
Bonnet Studs HT. #8875009	SA193-87	Texas Bolt Company	
Bonnet Nuts HT. #6014728	SA194-2H	Texas Bolt Company	
(d) Other Parts			
Disc HT. #A326 S/N 67	SA479-316L	LTV Steel	
Disc HT. #17543 S/N 45	SA240-316L	Jessop Steel Company	

8. Hydrostatic test 425 psi.

CERTIFICATION OF DESIGN

Design information on file at Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
 Stress analysis report on file at N/A
 Design specifications certified by D. Sattar (1) Prof. Eng. State PA Reg. No. 019525E
 Stress analysis report certified by N/A (1) Prof. Eng. State _____ Reg. No. _____
 (1) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date 8/21 19 90 Signed Anchor/Darling Valve Co. by R L Stannert
(Manufacturer)

Certificate of Authorization No. N1712 expires 4/15/92

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of ~~PA~~ Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass. have inspected the equipment described in this Data Report on 4-11 thru 8-21 19 90, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 8-21 19 90

Charles Young (Inspector) Commissions Pennsylvania 2392
(National Board, State, Province and No.)

FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*

As Required by the Provisions of the ASME Code Rules

1. Manufactured by Yarway Corporation, Blue Bell, PA Order No. 60511
(Name & Address of Manufacturer)

2. Manufactured for Bechtel Power Corporation Order No. 9645-4-251
(Name and Address)

3. Owner Mississippi Power and Light Company

4. Location of Plant Port Gibson, Mississippi

5. Pump or Valve Identification Nuclear Service Valves - Serial Numbers
7860 Thru 7866 /
(Brief description of service for which equipment was designed)

(a) Drawing No. 103271-04 Prepared by Yarway Corporation

(b) National Board No. NONE

6. Design Conditions 2350 psi 700 °F or Pressure Class _____ (_____)
(Pressure) (Temperature)

7. The material, design, construction, and workmanship complies with ASME Code Section III, Class 1
 Edition 1974, Addenda Date Winter 1974, Case No. None

	Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings	A8	AMS 5362	Nova/Howmet	Disc
(b) Forgings	R6	SA 105	Cape Ann Tool Co	Body
	YW 684	SA 193-87	Republic Steel	Backseat Bushing

(1) For manually operated valves only.

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2" x 11", (2) information in items 1, 2, 5a and 5b on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

3/75 This form (E00037, may be obtained from the Order Dept., ASME, 345 E. 47 St., New York, N.Y. 10017.

FORM NP-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*

As Required by the Provisions of the ASME Code Rules

1. Manufactured by Yarway Corporation, Blue Bell, PA Order No. 40761
(Name & Address of Manufacturer)

2. Manufactured for Bechtel Power Corporation Order No. 9545-M-251
(Name and Address)

3. Owner Mississippi Power and Light Company

4. Location of Plant Port Gibson, Mississippi

5. Pump or Valve Identification Nuclear Service Valves - Serial Numbers
7684 Thru 7688
(Brief description of service for which equipment was designed)

(a) Drawing No. 103271-04 Prepared by Yarway Corporation

(b) National Board No. None

6. Design Conditions 2350 psi 700 °F or Pressure Class _____
(Pressure) (Temperature)

7. The material, design, construction, and workmanship complies with ASME Code Section III. Class 1
 Edition 1974, Addenda Date Winter 1974, Case No. None

	Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings	A7	AMS 5382	Nova/Howmet	Disc
(b) Forgings	NS	SA 105	Cape Ann Tool Co	Body
	YW 684	SA 193 Gr. B7	Republic Steel	Backseat Bush

(1) For manually operated valves only.

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2" x 11", (2) information in items 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36 on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date June 25, 1992
 Sheet 1 of 3

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 PMR#S 91-9013A, B, C & D/WA#S C13365, C13368, C13515, C13517, C13518, C13520, C13521, C13522, & C13524
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System STANDBY DIESEL GENERATOR FUEL TRANSFER SYSTEM, 023B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
A D/G FUEL OIL FLOWING VENT TUBING	PP&L	N/A	N/A	C-2007	1990	REPLACED	NO
A D/G FUEL OIL FLOWING VENT TUBING	PP&L	N/A	N/A	C-2007	1991	REPLACEMENT	NO
A D/G FUEL OIL HEADER VENT TUBING	PP&L	N/A	N/A	C-2007	1991	REPLACEMENT	NO
A D/G FUEL OIL VENT TUBE SUPPORTS	PP&L	N/A	N/A	C-2007	1991	REPLACEMENT	NO
B D/G FUEL OIL FLOWING VENT TUBING	PP&L	N/A	N/A	C-2008	1990	REPLACED	NO

7. Description of Work AT DIESEL GENERATORS A THRU D, INSTALL A LOOP SEAL TO THE EXISTING FUEL INJECTION PUMP FLOWING VENT LINES AND INSTALL A NEW FUEL SUPPLY HEADER VENT WHICH ALSO CONTAINS A LOOP SEAL

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. AMBIENT °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed S. V. Stal Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 5-15-91 to 7-26-91, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Don D. Paulbury Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date JULY 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 25, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 2 of 3
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR#'S 91-9013A, B, C, & D/WA#'S C13365, C13368,
Address C13515, C13517, C13518, C13520, C13521 & C13524
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System STANDBY DIESEL GENERATOR FUEL TRANSFER SYSTEM, 023B, CLASS III
5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
B D/G FUEL OIL FLOWING VENT TUBING	PP&L	N/A	N/A	C-2008	1991	REPLACEMENT	NO
B D/G FUEL OIL HEADER VENT TUBING	PP&L	N/A	N/A	C-2008	1991	REPLACEMENT	NO
B D/G FUEL OIL VENT TUBE SUPPORTS	PP&L	N/A	N/A	C-2008	1991	REPLACEMENT	NO
C D/G FUEL OIL FLOWING VENT TUBING	PP&L	N/A	N/A	C-2009	1990	REPLACED	NO
C D/G FUEL OIL FLOWING VENT TUBING	PP&L	N/A	N/A	C-2009	1991	REPLACEMENT	NO
C D/G FUEL OIL HEADER VENT TUBING	PP&L	N/A	N/A	C-2009	1991	REPLACEMENT	NO
C D/G FUEL OIL VENT TUBE SUPPORTS	PP&L	N/A	N/A	C-2009	1991	REPLACEMENT	NO
D D/G FUEL OIL FLOWING VENT TUBING	PP&L	N/A	N/A	C-2010	1990	REPLACED	NO
D D/G FUEL OIL FLOWING VENT TUBING	PP&L	N/A	N/A	C-2010	1991	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 25, 1992
Name
- Two North Ninth St., Allentown, PA 18101 Sheet 3 of 3
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
- PO Box 467, Berwick, PA 18603 PMR#'S 91-9013A, B, C, & D/WA#'S C13365, C13368,
Address C13515, C13517, C13518, C13520, C13521 & C13524
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
- Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address
- Expiration Date N/A
4. Identification of System STANDBY DIESEL GENERATOR FUEL TRANSFER SYSTEM, 023B, CLASS III
5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
D D/G FUEL OIL HEADER VENT TUBING	PP&L	N/A	N/A	C-2010	1991	REPLACEMENT	NO
D D/G FUEL OIL VENT TUBE SUPPORTS	PP&L	N/A	N/A	C-2010	1991	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 25, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 1
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR#'S 90-3046B & D/ WA#'S C13920, C13955, & C14158
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System DIESEL GENERATOR AND AUXILIARY SYSTEM, 024A, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
'B' DIESEL JACKET WATER COOLER TUBE BUNDLE	AMERICAN STANDARD	7-20009-01-4	N/A	0E507B	1975	REPLACED	YES
'B' DIESEL JACKET WATER COOLER TUBE BUNDLE	AMERICAN STANDARD	91U98629-01-2	N/A	0E507B	1991	REPLACEMENT	YES
'D' DIESEL JACKET WATER COOLER TUBE BUNDLE	AMERICAN STANDARD	7-20009-01-2	N/A	0E507D	1975	REPLACED	YES
'D' DIESEL JACKET WATER COOLER TUBE BUNDLE	AMERICAN STANDARD	91U98629-01-1	N/A	0E507D	1991	REPLACEMENT	YES
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HRC-9-H2013	1982	REPAIRED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HRC-9-H2015	1982	REPAIRED	NO

7. Description of Work REPLACED TUBE BUNDLE ASSEMBLY AT 'B' & 'D' D/G JACKET WATER COOLERS

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 100 psi Test Temp. AMBIENT °F PER SE-054-301

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks MANUFACTURER'S CODE DATA REPORTS ARE ATTACHED.

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed S. K. Stal Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 10-22-91 to 11-22-91, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David Daubman Commissions NR 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22 19 92

FORM U-2 MANUFACTURER'S PARTIAL DATA REPORT
 A Part of a Pressure Vessel Fabricated by One Manufacturer for Another Manufacturer
 As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

BUNDLE

1. Manufactured and certified by ITT STANDARD, ITT FLUID TECHNOLOGY CORP., 175 Standard Pkwy, Chktg, NY 14227
(Name and address of manufacturer)

2. Manufactured for PENNSYLVANIA POWER & LIGHT, ALLENTOWN, PENNSYLVANIA
(Name and address of purchaser)

3. Location of installation PENNSYLVANIA POWER & LIGHT, BERWICK, PENNSYLVANIA
(Name and address)

4. Type HORIZ.H.E.BUNDLE 91U98629-01-2 THRU 4-108-15-114-003 ----- 1991
(Horiz. or vert., tank) (Mfr's serial No. of Part) (CRN) (Drawing No.) (Mkt. Bd. No.) (Year Built)
01-4 Rev. 1

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE.
 The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1989
Year

A-89 A-90 mt 10/3/91 2/15/91 - -
Addenda (date) Code Case No. Special service per UG-120(d)

6. (a) Drawing prepared by ITT STANDARD (b) Description of part inspected TUBE BUNDLE

7. Postweld heat treatment: Temp. N/A °F Time N/A

Items 8-13 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

8. Shell: NONE NONE NONE NONE NONE
Matl. (Spec. No., Grade) Nom. Thk. (in.) Corr. Allow. (in.) Diam. I.D. (ft & in.) Length (Overall) (ft & in.)

9. Seams: NONE NONE NONE NONE NONE NONE NONE NONE
Long. (Wld., Dbl., Sngl., Lap, Butt) R.T. (Spot or Full) Ell. (%) H.T. Temp. (°F) Time Girth (Wld., Dbl., Sngl., Lap, Butt) R.T. (Spot, Partial, or Full) No. of Courses

10. Heads: (a) Matl. NONE (b) Matl. NONE
(Spec. No., Grade) (Spec. No., Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
NONE	---	---	---	---	---	---	---	---	---
NONE	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) N/A
(Matl., Spec. No., Gr., Size, No.)

11. Type of Jacket NONE Proof Test NONE

12. Jacket Closure NONE If bar, give dimensions NONE
(Describe as ogee & weld, bar, etc.)

13. MAWP NONE psi at max. temp. NONE °F Min. design metal temp. NONE °F at NONE psi.
 Hydro., pneu., or comb. test press. NONE

Items 14 and 15 to be completed for tube sections

14. Tubesheets: SB-688 17.25 .938 NONE BOLTED
Stationary Matl. (Spec. No., Gr.) Diam. (in.) (Subject to pressure) Nom. Thk. (in.) Corr. Allow. (in.) Attach. (Wld., Bolted)
SB-688 15 1.625 NONE PACKED
Roasting Matl. (Spec. No., Gr.) Diam. (in.) Nom. Thk. (in.) Corr. Allow. (in.) Attach.

15. Tubes: SB-676 .625 18 BWG 278 STRAIGHT
Matl. (Spec. No., Gr.) O.D. (in.) Nom. Thk. (in. or Gauge) No. Type (Straight or "U")

Items 16-18 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

16. Shell: NONE NONE NONE NONE NONE
Matl. (Spec. No., Grade) Nom. Thk. (in.) Corr. Allow. (in.) Diam. I.D. (ft & in.) Length (overall) (ft & in.)

17. Seams: NONE NONE NONE NONE NONE NONE NONE NONE
Long. (Wld., Dbl., Sngl., Lap, Butt) R.T. (Spot or Full) Ell. (%) H.T. Temp. (°F) Time Girth (Wld., Dbl., Sngl., Lap, Butt) R.T. (Spot, Partial, or Full) No. of Courses

18. Heads: (a) Matl. NONE (b) Matl. NONE
(Spec. No., Grade) (Spec. No., Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
NONE	---	---	---	---	---	---	---	---	---
NONE	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) NONE
(Matl., Spec. No., Gr., Size, No.)

FORM U-2 MANUFACTURER'S PARTIAL DATA REPORT
A Part of a Pressure Vessel Fabricated by One Manufacturer for Another Manufacturer
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

BUNDLE

Manufactured and certified by ITT STANDARD, ITT FLUID TECHNOLOGY CORP., 175 Standard Pkwy, Chktg, NY 14227
(Name and address of manufacturer)

2. Manufactured for PENNSYLVANIA POWER & LIGHT, ALLENTOWN, PENNSYLVANIA
(Name and address of purchaser)

3. Location of installation PENNSYLVANIA POWER & LIGHT, BERWICK, PENNSYLVANIA
(Name and address)

4. Type HORIZ.H.E.BUNDLE 91U98629-01-1 4-108-15-114-003 ----- 1991
(Horiz. or vert., tank) (Mfg's serial No. of Part) (CRN) (Drawing No.) (Net'l. Bd. No.) (Year Built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE.
 The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1989
Year

A-90
Addenda (date)

-
Code Case No.

-
Special service per UG-120(a)

6. (a) Drawing prepared by ITT STANDARD (b) Description of part inspected TUBE BUNDLE

7. Postweld heat treatment: Temp. N/A °F Time N/A

Items 8-13 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

8. Shell: NONE NONE NONE NONE NONE
Mat'l. (Spec. No., Grade) Norm. Thk. (in.) Corr. Allow. (in.) Diam. I.D. (ft & in.) Length (Overall) (ft & in.)

9. Seams: NONE NONE NONE NONE NONE NONE NONE NONE
Long. (Wld., Dbl., Sngl., Lap, Butt) R.T. (Spot or Full) Eff. (%) H.T. Temp. (°F) Time Girth (Wld., Dbl., Sngl., Lap, Butt) R.T. (Spot, Partial, or Full) No. of Courses

10. Heads: (a) Mat'l. NONE (b) Mat'l. NONE
(Spec. No., Grade) (Spec. No., Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
<u>NONE</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>
<u>NONE</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>

If removable, bolts used (describe other fastenings) N/A
(Mat'l., Spec. No., Gr., Size, No.)

11. Type of Jacket NONE Proof Test NONE

12. Jacket Closure NONE If bar, give dimensions NONE
(Describe as ogee & weld, bar, etc.)

13. MAWP NONE psi at max. temp. NONE °F Min. design metal temp. NONE °F at NONE psi.
 Hydro., pneu., or comb. test press. NONE

Items 14 and 15 to be completed for tube sections

14. Tubesheets: SB-688 17.25 .938 NONE BOLTED
Stationary Mat'l. (Spec. No., Gr.) Diam. (in.) (Subject to pressure) Norm. Thk. (in.) Corr. Allow. (in.) Attach. (Wld., Bolted)
SB-688 15 1.625 NONE PACKED
Floating Mat'l. (Spec. No., Gr.) Diam. (in.) Norm. Thk. (in.) Corr. Allow. (in.) Attach.

15. Tubes: SB-676 .625 18 BWG 278 STRAIGHT
Mat'l. (Spec. No., Gr.) O.D. (in.) Norm. Thk. (in. or Gauge) No. Type (Straight or "U")

Items 16-18 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

16. Shell: NONE NONE NONE NONE NONE
Mat'l. (Spec. No., Grade) Norm. Thk. (in.) Corr. Allow. (in.) Diam. I.D. (ft & in.) Length (Overall) (ft & in.)

17. Seams: NONE NONE NONE NONE NONE NONE NONE NONE
Long. (Wld., Dbl., Sngl., Lap, Butt) R.T. (Spot or Full) Eff. (%) H.T. Temp. (°F) Time Girth (Wld., Dbl., Sngl., Lap, Butt) R.T. (Spot, Partial, or Full) No. of Courses

18. Heads: (a) Mat'l. NONE (b) Mat'l. NONE
(Spec. No., Grade) (Spec. No., Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
<u>NONE</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>
<u>NONE</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>	<u>---</u>

If removable, bolts used (describe other fastenings) NONE
(Mat'l., Spec. No., Gr., Size, No.)

DESIGN CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that the design changes described in this report conform to the requirements of the National Board Inspection Code.

ASME Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date N/A 19 N/A Signed N/A
(name of organization) (authorized representative)

CERTIFICATE OF REVIEW OF DESIGN CHANGE

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of N/A and employed by N/A

N/A of N/A has examined the design change as described in this report and verifies that to the best of his knowledge and belief such change complies with the applicable requirements of the National Board Inspection Code. By signing this certificate, neither the undersigned nor his employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date N/A 19 N/A Signed N/A Commissions N/A
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)

CONSTRUCTION CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that all construction and workmanship on this repair conform to the National Board Inspection Code.
(repair or alteration)

Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date July 16 19 92 Signed SP. Stal
(repair or alteration organization) (authorized representative)

CERTIFICATE OF INSPECTION

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of Penna. and employed by Arkwright Mutual Insurance

Company of Waltham, MA has inspected the work described in this report on July 22 19 92 and state that to the best of my knowledge and belief this work has been done in accordance with the National Board Inspection Code.

By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date JULY 22 19 92 Signed David Daubney Commissions NB 7525 PA 2159 NE
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)

DESIGN CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that the design changes described in this report conform to the requirements of the National Board Inspection Code.

ASME Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date N/A 19 N/A Signed N/A (name of organization) (authorized representative)

CERTIFICATE OF REVIEW OF DESIGN CHANGE

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of N/A and employed by N/A

N/A of N/A has examined the design change as described in this report and verifies that to the best of his knowledge and belief such change complies with the applicable requirements of the National Board Inspection Code. By signing this certificate, neither the undersigned nor his employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date N/A 19 N/A Signed N/A Commissions N/A (Authorized Inspector) (National Board (incl. endorsements), state, prov. and no.)

CONSTRUCTION CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that all construction and workmanship on this repair conform to the National Board Inspection Code.

Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date July 16 19 92 Signed S. H. S. (repair or alteration organization) (authorized representative)

CERTIFICATE OF INSPECTION

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of Penna. and employed by Arkwright Mutual Insurance Company of Waltham, MA has inspected the work described in this report on July 22 19 92

and state that to the best of my knowledge and belief this work has been done in accordance with the National Board Inspection Code. By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date July 22 19 92 Signed [Signature] Commissions NB 7525 PA 2109 NJ (Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date 15 July, 1992
 Sheet 1 of 10

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 DCP'S 88-3031, 88-3032, & 90-3005
 SEE PAGES 6 & 7, FOR LIST OF WA #'S
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System EMERGENCY SERVICE WATER 054A-III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components
 SEE PAGE 8, FOR EXCEPTIONS TO CONSTRUCTION CODE

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
20", 150#, CHECK VALVE	ANCHOR DARLING	E5854-101-1	N/A	2-12-010	1976	REPLACED	YES
20", 150#, CHECK VALVE	ANCHOR DARLING	E5854-100-1	N/A	1-12-010	1979	REPLACED	YES
20", 150#, S.S. BALL VALVE	JAMESBURY	ND260312-01C	N/A	1-12-082	1989	REPLACEMENT	YES
20", 150#, S.S. BALL VALVE	JAMESBURY	ND260312-01B	N/A	2-12-082	1989	REPLACEMENT	YES
20", C. S. SPACER	JAMESBURY	PYJ-4	N/A	1-12-082	1989	REPLACEMENT	YES
20", C. S. SPACER	JAMESBURY	PYJ-3	N/A	2-12-082	1989	REPLACEMENT	YES

7. Description of Work RHR HX ISOLATION VALVES, NEW DRN VALVES & ESW BLDG ISOLATION VALVES

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure SEE PAGES 9 & 10
 Other Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Manufacturer's Data Reports; Forms NPV-1 & N-2, are attached.

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SC Hall Date July 17, 1992
Owner or Owner's Designer, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-1-91 to 4-2-91, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David Daubney Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 3 July, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 2 of 10
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP'S 88-3031, 88-3032, & 90-3005
Address SEE PAGES 6 & 7, FOR LIST OF WA #'S
Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System EMERGENCY SERVICE WATER 054A-III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components
 SEE PAGE 8, FOR EXCEPTIONS TO CONSTRUCTION CODE

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1-1/8" -8, B7, STUD BOLTS	BECHTEL	RIR A264331 HT CD: BS48	N/A	1-12-010	1982	REPLACED	YES
1-1/8" -8, B7, STUD BOLTS	BECHTEL	RIR A328111 HT CD: EC26	N/A	1-12-010	1982	REPLACED	YES
1-1/8" -8, B7, STUD BOLTS	BECHTEL	RIR A225981 HT CD: BS54	N/A	1-12-010	1982	REPLACED	YES
1-1/8" -8, 2H, HEAVY HEX NUTS	BECHTEL	PO# F47912 HT CD: LE24	N/A	1-12-010	1982	REPLACED	YES
1-1/8" -8, X 6-3/4" B7, STUD BOLTS	PP&L	XFR# 5621 HT CD: BG64	N/A	1-12-082	1991	REPLACEMENT	NO
1-1/8" -8, X 9" B7, STUD BOLTS	PP&L	RIR 90-1102 HT# 8095014	N/A	1-12-082	1991	REPLACEMENT	NO
1-1/8" -8, 2H HEAVY HEX NUTS	PP&L	RIR 90-0631 HT CD: QF58	N/A	1-12-082	1991	REPLACEMENT	NO
1-1/8" -8, B7, STUD BOLTS	BECHTEL	PO# F40557 HT CD: KG65	N/A	2-12-010	1982	REPLACED	YES
1-1/8" -8, 2H, HEAVY HEX NUTS	BECHTEL	PO# F40557 HT CD: KG86	N/A	2-12-010	1982	REPLACED	YES
1-1/8" -8, X 6-3/4" B7, STUD BOLTS	PP&L	XFR# 5621 HT CD: BG64	N/A	1-12-082	1991	REPLACEMENT	NO
1-1/8" -8, X 9" B7, STUD BOLTS	PP&L	RIR 90-1102 HT# 8095014	N/A	1-12-082	1991	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 3 July, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 3 of 10
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP'S 88-3031, 88-3032, & 90-3005
Address SEE PAGES 6 & 7, FOR LIST OF WA #'S
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A


4. Identification of System EMERGENCY SERVICE WATER 054A-III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components
 SEE PAGE 8, FOR EXCEPTIONS TO CONSTRUCTION CODE

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

1-1/8" -8, 2H HEAVY HEX NUTS	PP&L	RIR 90-0631 HT CD: QF58	N/A	1-12-082	1991	REPLACEMENT	NO
14", 150#, C.S., BUTTERFLY VALVE	JAMESBURY	ND-36247-02A	N/A	1-11-103	1978	REPLACED	YES
14", 150#, S.S. BUTTERFLY VALVE	C&S	90-1177-02(N)-01	N/A	1-11-103	1990	REPLACEMENT	YES
14", 150#, C.S., BUTTERFLY VALVE	CONTRA-MATICS	87460-1-2	N/A	1-11-187	1980	REPLACED	YES
14", 150#, S.S. BUTTERFLY VALVE	C&S	90-1177-02(N)-02	N/A	1-11-187	1990	REPLACEMENT	YES
LARGE PIPE SUB ASSEMBLY	BECHTEL	NONE	N/A	HRC-101-1	1982	REPLACED	YES
LARGE PIPE SUB ASSEMBLY	PP&L	NONE	N/A	HRC-101-1	1991	REPLACEMENT	NO
LARGE PIPE SUB ASSEMBLY	BECHTEL	NONE	N/A	HRC-106-1	1982	REPLACED	YES
LARGE PIPE SUB ASSEMBLY	PP&L	NONE	N/A	HRC-106-1	1991	REPLACEMENT	NO
12", 150#, C.S., BUTTERFLY VALVE	JAMESBURY	ND-36247-01B	N/A	2-11-103	1977	REPLACED	YES
12", 150#, S.S. BUTTERFLY VALVE	C&S	90-1177-01(N)-01	N/A	2-11-103	1990	REPLACEMENT	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 3 July, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 4 of 10
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP'S 88-3031, 88-3032, & 90-3005
Address SEE PAGES 6 & 7, FOR LIST OF WA #'S
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System EMERGENCY SERVICE WATER 054A-III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components
 SEE PAGE 8, FOR EXCEPTIONS TO CONSTRUCTION CODE

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

12', 150#, C.S., BUTTERFLY VALVE	CONTRAMATICS	87452-1-2	N/A	2-11-190	1979	REPLACED	YES
12', 150#, S.S. BUTTERFLY VALVE	C&S	90-1177-01(N)-02	N/A	2-11-190	1990	REPLACEMENT	YES
LARGE PIPE SUB ASSEMBLY	BECHTEL	NONE	N/A	HRC-201-1	1982	REPLACED	YES
LARGE PIPE SUB ASSEMBLY	PP&L	NONE	N/A	HRC-201-1	1991	REPLACEMENT	NO
LARGE PIPE SUB ASSEMBLY	BECHTEL	NONE	N/A	HRC-206-1	1982	REPLACED	YES
LARGE PIPE SUB ASSEMBLY	PP&L	NONE	N/A	HRC-206-1	1991	REPLACEMENT	NO
2', 150#, S.S. BALL VALVE	JAMESBURY	ND-286829-03L	N/A	1-11-171	1990	REPLACEMENT	YES
2', 150#, S.S. BALL VALVE	JAMESBURY	ND-286829-03T	N/A	2-11-171	1990	REPLACEMENT	YES
2', 150#, S.S. BALL VALVE	JAMESBURY	ND-286829-03S	N/A	2-11-172	1990	REPLACEMENT	YES
SMALL PIPE DRAIN ASSEMBLY	PP&L	NONE	N/A	SP-HRC-106-1	1991	REPLACEMENT	NO
SMALL PIPE DRAIN ASSEMBLY	PP&L	NONE	N/A	SP-HRC-201-2	1991	REPLACEMENT	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 3 July, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 5 of 10
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP'S 88-3031, 88-3032, & 90-3005
Address SEE PAGES 6 & 7, FOR LIST OF WA #'S
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System EMERGENCY SERVICE WATER 054A-III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components
 SEE PAGE 8, FOR EXCEPTIONS TO CONSTRUCTION CODE

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SMALL PIPE DRAIN ASSEMBLY	PP&L	NONE	N/A	SP-HRC-206-2	1991	REPLACEMENT	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner	<u> Pennsylvania Power & Light Co. </u> <small>Name</small>	Date	<u> 3 July, 1992 </u>
	<u> Two North Ninth St., Allentown, PA 18101 </u> <small>Address</small>	Sheet	<u> 6 </u> of <u> 10 </u>
2. Plant	<u> Susquehanna Steam Electric Station </u> <small>Name</small>	Unit	<u> ONE </u>
	<u> PO Box 467, Berwick, PA 18603 </u> <small>Address</small>	<u> DCP'S 88-3031, 88-3032, & 90-3005 </u> <u> SEE PAGES 6 & 7, FOR LIST OF WA #'S </u> <small>Repair Organization P.O. No., Job No., etc.</small>	
3. Work Performed by	<u> Pennsylvania Power & Light Co. </u> <small>Name</small>	Type Code Symbol Stamp	<u> None </u>
	<u> Two North Ninth St., Allentown, PA 18101 </u> <small>Address</small>	Authorization No.	<u> N/A </u>
		Expiration Date	<u> N/A </u>
4. Identification of System	<u> EMERGENCY SERVICE WATER 054A-III </u>		
5. (a) Applicable Construction Code	<u> III </u>	19 <u> 71 </u> Edition,	<u> thru W'72 </u> Addenda, <u> </u> Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements	<u> 19 </u>	<u> 80 thru W'80 </u>	
6. Identification of Components Repaired or Replaced and Replacement Components	<u> SEE PAGE 8, FOR EXCEPTIONS TO CONSTRUCTION CODE </u>		

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)

WA #s: Description of Work Performed:

C04414	Shop fabrication of spool pieces; inspect, pack, and testing of valves; and other miscellaneous prep work
C04410	Installed branch connection and associated components for drain valve assembly 1-11-171, SP-HRC-106-2.
C04412	Hot Tapped 2" drain 1-11-171, SP-HRC-106-2.
C04411	Installed branch connection and associated components for drain valve assemblies 2-11-171, SP-HRC-206-2; & 2-11-172, SP-HRC-201-2.
C04413	Hot Tapped 2" drains 2-11-171, SP-HRC-206-2; & 2-11-172, SP-HRC-201-2.
C13099	Removal of existing Check Valve 1-12-010. Installation of new Stainless Ball Valve 1-12-082, and carbon spacer.

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 3 July, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 7 of 10
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP'S 88-3031, 88-3032, & 90-3005
Address SEE PAGES 6 & 7, FOR LIST OF WA #'S
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System EMERGENCY SERVICE WATER 054A-III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components
SEE PAGE 8, FOR EXCEPTIONS TO CONSTRUCTION CODE

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)

WA[#]s: Description of Work Performed: (Continued)


C13110 Removal of existing Check Valve 2-12-010.
 Instalation of new Stainless Steel Ball Valve 2-12-082, and carbon steel spacer.

C04417 Hanger Load Balance, and set new loads. Unit I pipe support activities.

C04418 Hanger Load Balance, and set new loads. Unit II pipe support activities.

C04415 Change out of building isolation valves 1-11-103 and 1-11-187.

C04416 Change out of building isolation valves 2-11-103 and 2-11-190.



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 3 July, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 8 of 10
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP'S 88-3031, 88-3032, & 90-3005
Address SEE PAGES 6 & 7, FOR LIST OF WA #'S
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System EMERGENCY SERVICE WATER 054A-III
5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components
SEE PAGE 8, FOR EXCEPTIONS TO CONSTRUCTION CODE

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)

EXCEPTIONS TO CONSTRUCTION CODE FROM PAGE 1:

<u>VALVE #S:</u>	<u>CODE YEAR & ADDENDA</u>	<u>CODE CASES:</u>
1-12-082	Section III 1974, No Addenda	NONE
Spacers PYJ-4	Section III 1974, No Addenda	NONE
2-12-082	Section III 1974, No Addenda	NONE
Spacer PYJ-3	Section III 1974, No Addenda	NONE
1-11-103	Section III 1971, Winter 1972	NONE
1-11-187	Section III 1971, Winter 1972	NONE
2-11-103	Section III 1971, Winter 1972	NONE
2-11-190	Section III 1971, Winter 1972	NONE
1-11-171	Section III 1974, Winter 1975	NONE
2-11-171	Section III 1974, Winter 1975	NONE
2-11-172	Section III 1974, Winter 1975	NONE


FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 3 July, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 9 of 10
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP'S 88-3031, 88-3032, & 90-3005
Address SEE PAGES 6 & 7, FOR LIST OF WA #'S
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System EMERGENCY SERVICE WATER 054A-III
5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components
 SEE PAGE 8, FOR EXCEPTIONS TO CONSTRUCTION CODE

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)

TESTS CONDUCTED

<u>VALVE #'S</u>	<u>TYPE TEST:</u>	<u>PRES:</u>	<u>TEMP:</u>	<u>DOCUMENT:</u>
1-12-082	System Leak	95	50	SE-116-301
Spacer PYJ-4	System Leak	95	50	SE-116-301
2-12-082	System Leak	95	50	SE-216-301
Spacer PYJ-3	System Leak	95	50	SE-216-301
1-11-103	System Leak	130	50	SE-054-301
1-11-187	System Leak	130	50	SE-054-301
HRC-101-1	Hydrostatic	195	76	WA# C04415
	System Leak	130	50	SE-054-301
HRC-106-1	Hydrostatic	225	60	WA# C04414
	System Leak	130	50	SE-054-301



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 3 July, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 10 of 10
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP'S 88-3031, 88-3032, & 90-3005
Address SEE PAGES 6 & 7, FOR LIST OF WA #'S
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address
Expiration Date N/A
4. Identification of System EMERGENCY SERVICE WATER 054A-III
5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components
SEE PAGE 8, FOR EXCEPTIONS TO CONSTRUCTION CODE

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)

TESTS CONDUCTED: (CONT'D)

<u>VALVE #'S</u>	<u>TYPE TEST:</u>	<u>PRES:</u>	<u>TEMP:</u>	<u>DOCUMENT:</u>
2-11-103	System Leak	130	50	SE-054-301
2-11-190	System Leak	130	50	SE-054-301
HRC-201-1	Hydrostatic	186	74	WA# C04416
	System Leak	130	50	SE-054-301
HRC-206-1	Hydrostatic	221	56	WA# C04414
	System Leak	130	50	SE-054-301
1-11-171	System Leak	130	50	SE-054-301
2-11-171	System Leak	130	50	SE-054-301
2-11-172	System Leak	130	50	SE-054-301
SP-HRC-201-1	Pneumaticc	195	72	WA# C04411
	System Leak	130	50	SE-054-301
SP-HRC-206-1	Hydrostatic	221	56	WA# C04414
	System Leak	130	50	SE-054-301



B



FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS

As Required by the Provisions of the ASME Code, Sec. I, Div. 1

1. Manufactured by Jamesbury Corp. 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
3. Location of Installation Susquehanna S.E.S., 5 MI. NE of Berwick on RT 11, Berwick, PA 18603
(Name and Address)
4. Pump or Valve Ball Valve Nominal Inlet Size 20 Outlet Size 20
(inch) (inch)

	(n) Model No.	(b) N Certificate Holder's	(c) Canadian	(d) Drawing	(f) Mat'l.	(g) Year
	Series No. or Type	Serial No.	Registration No.	No.	3d. No.	Built
(1)	5150	ND260312-01C	N/A	ND260312-01	3	1989
(2)				Rev. D		
(3)						
(4)						
(5)						
(6)						
(7)						
(8)						
(9)						
(10)						

5. Isolate RHR service water from the RHR heat exchangers
(Brief description of service for which equipment was designed)

6. Design Conditions 177 psi 150 °F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)

7. Cold Working Pressure 275 psi at 100°F.

8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
PYK-1	351 Gr. CFBM	Jamesbury Corp.	Body
PYP-1	351 Gr. CFBM	Jamesbury Corp.	Cap
PZA-1	351 Gr. CFBM	Stainless Foundry	Ball
(b) Forgings			

Handwritten signature and date stamp: 12/10/89

(1) For manually operated valves only. P.O. & L. Doc. No. 45

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the Affil.

900730509



(c) Parting	ASME SA	ASME SA	ASME SA
CG53	193 Gr. B7	Texas Bolt	All Thread Stud
CG54	193 Gr. B7	Texas Bolt	All Thread Stud
CG50	194 Gr. 2H	Texas Bolt	Hex Nut
CG 51	193 Gr. B7	Texas Bolt	Hex Head Cap Screw
(d) Other Parts	ASME SA		
PYR	479 Type 316	Jamesbury Corp.	Stem Retainer

9. Hydrostatic test 425 psi. Disk Differential test pressure N/A psi ND260312-01 C

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. I, Edition 1974.
 Addenda NONE, Code Case No. NONE, Date 1/16/90
 Signed Jamesbury Corp. by Ronald P. Casper
 (In Certificate Holder)
 Our ASME Certificate of Authorization No. N1228 to use the N symbol expires 10-27-90.
 (Date)

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Allentown, PA 18101
 Stress analysis report (Class I only) on file at N/A
 Design specifications certified by (1) Frank James Czysz
 PE State PA Reg. No. 25049-E
 Stress analysis certified by (1) N/A
 PE State N/A Reg. No. N/A
 (1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of NEW YORK and employed by Lubbermen's Mut'l Casualty Co. of Long Grove, ILL have inspected the pump, or valve, described in this Data Report on 1/16 1990, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.
 By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 1/16/90 19 90
[Signature] (Inspector) 1186172 NY2392 (NCCB Ed. State, Prov. and No.)

1/16/90 PAGE 1

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
 As Required by the Provisions of the ASME Code, Section III, Div. 1


1. Manufactured by Jamesbury Corp., 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)
 2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
 3. Location of Installation Susquehanna S.E.S., 5 MI. NE of Berwick on Rt 11, Berwick, PA 18601
(Name and Address)
 4. Pump or Valve Ball Valve Nominal Inlet Size 20 Outlet Size 20
(inch) (inch)

	(a) Model No., Series No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Mat'l. Pd. No.	(g) Year Built
	(1)	5150	ND260312-01B	N/A	ND260312-01	3	N/A
(2)				Rev. D			
(3)							
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

5. Isolate RHR service water from the RHR heat exchangers
(Brief description of service for which equipment was designed)

6. Design Conditions 177 psi 150 °F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)
 7. Cold Working Pressure 275 psi at 100°F.
 8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(n) Castings	ASME SA		
PYK-2	351 Gr. CF8M	Jamesbury Corp.	Body
PYM-1	351 Gr. CF8M	Jamesbury Corp.	Cap
PYT-1	351 Gr. CF8M	Stainless Foundry	Ball
(o) Forgings			



(1) For manually operated valves only. P.O. A.I. Doc. No. 45

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

9000700507

FORM N-2 N OR NP CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL NUCLEAR PARTS AND APPURTENANCES*

As Required by the Provisions of the ASME Code, Section III, Division 1
Not To Exceed One Day's Production

No. 1-1-1

1. Manufactured and certified by Jamesbury Corp., 640 Lincoln St., Worcester, MA 01605
(name and address of certificate holder)
2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(name and address of purchaser)
3. Location of installation Susquehanna S.E.S., 5 MI. NE of Berwick on Rt 11, Berwick, PA 19603
ASME SA SA-508 (name and address)
4. Type 036-9177-22 516 Gr. 70 81400 N/R 1989
(drawing no.) (material spec. no.) (nominal strength) (CRN) (year built)
5. ASME Code, Section III: 1974 NONE 3 NONE
(edition) (addenda) (class) (Code Case no.)
6. Fabricated in accordance with Const. Spec. (Div. 2 only) N/A Revision N/A Date N/A
(No.)
7. Remarks: Spacers to be used with Valve Serial Numbers ND260312-01A, 01B, 01C and 01D

8. Nom. thickness (in.) 3.750 Min. design thickness (in.) 500 Dia. ID (ft. & in.) 18.625 Length overall (ft. & in.) 2.150
9. When applicable, Certificate Holders' data reports are attached for each item of this report:

9 0 1 1 7 2 2

Part or Appurtenance Serial Number	National Board No. In Numerical Order	Part or Appurtenance Serial Number	National Board Number In Numerical Order
(1) PYJ-1		(26)	
(2) PYJ-2		(27)	
(3) PYJ-3		(28)	
(4) PYJ-4		(29)	
(5)		(30)	
(6)		(31)	
(7)		(32)	
(8)		(33)	
(9)		(34)	
(10)		(35)	
(11)		(36)	
(12)		(37)	
(13)		(38)	
(14)		(39)	
(15)		(40)	
(16)		(41)	
(17)		(42)	
(18)		(43)	
(19)		(44)	
(20)		(45)	
(21)		(46)	
(22)		(47)	
(23)		(48)	
(24)		(49)	
(25)		(50)	

IN 90-00000
 RECORD DEPT.
 PAGE 5 OF 9

10. Design pressure 285 psi Temp. 100 °F. Hydro. test pressure 450 PSIG at temp. °F.
P.P. & L. Doc. No. 45 (when applicable)

*Supplemental information in form of lists, sketches or drawings may be used provided (1) also is 8 1/2 X 11, (2) information in items 2 and 3 on this data report is included on each sheet, (3) each sheet is numbered and number of sheets is recorded at top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.
This form (5000) may be used for...

CERTIFICATE OF DESIGN

Design specifications certified by Frank James Czysz P. E. state PA Reg. no. 25049-E
Design report* certified by N/A P. E. state N/A Reg. no. N/A
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Spacers
conform to the rules of construction of the ASME Code, Section III.

ASME Certificate of Authorization no. N1233 Expires 10-2-90
Date 1/16/90 Name Jamesbury Corp. Signed Donald P. Price
(NPT Certificate Holder) (Authorized Representative)


CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or pro-
vince of NEW YORK and employed by Lumbermens Mut'l Casalty Co.
of Long Grove, ILL have inspected these items described in this data report on December 14, 1989, and state that to the
best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code,
Section III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment
described in this data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or
property damage or loss of any kind arising from or connected with this inspection.

Date 1/16/90 Signed [Signature] Commissions NBS4172 "NIC" NY 2592
(Authorized Inspector) (State ID (and endorsement) state or prov. and no.)

P.P. & L. Doc. No. 45



7
2
0
5
1
4

Certificate Holder's Serial No. 90-1177-02(N)-01

8. Design conditions 177 (Disc) psi 125 °F or valve pressure class 150 (1)
(pressure) (temperature)
9. Cold working pressure 275 (Body) psi at 100°F
10. Hydrostatic test 425 psi. Disk differential test pressure 195 psi
11. Remarks: Emergency Water Service
Cover Plate & Gland Flange - Material: SA 479 T 316, Heat: YCE
Hex Head Cap Screw - Material: SA 193 GR. B8M, Heat: AQD
Stud - Material: SA 193 GR. B8M, Heat: ARC
Hex Nut - Material: SA 194 GR. 8M, Heat: AQD

CERTIFICATION OF DESIGN

Design Specification certified by Dale Sattar P.E. State PA Reg. no. PE 019525E
 Design Report certified by N/A P.E. State --- Reg. no. ---

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N-2723 Expires 6/20/92
 Date 11/2/90 Name C&S Valve Company, Tricentric Div. Signed [Signature]
(N Certificate Holder) (authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by *Allendale Mutual Ins. Co. of Norwood, Massachusetts have inspected the pump, or valve, described in this Data Report on Nov. 2, 1990, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

* Factory Mutual System

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11-2-90 Signed [Signature] Commissions 11-10168, ILL 1498, OHIO, PA 3386 N
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) and state or prov. and no.)

(1) For manually operated valves only.

Certificate Holder's Serial No. 90-1177-02(N)-02

8. Design conditions 177 (Disc) psi 125 °F or valve pressure class 150 (1)
(pressure) (temperature)
9. Cold working pressure 275 (Body) psi at 100°F
10. Hydrostatic test 425 psi. Disk differential test pressure 195 psi
11. Remarks: Emergency Water Service
Cover Plate & Gland Flange - Material: SA 479 T 316, Heat: YCE
Hex Head Cap Screw - Material: SA 193 GR. B8M, Heat: AOD
Stud - Material: SA 193 GR. B8M, Heat: ARC
Hex Nut - Material: SA 194 GR. 8M, Heat: AOD

CERTIFICATION OF DESIGN

Design Specification certified by Dale Sattar P.E. State PA Reg. no. PE 019525E
 Design Report certified by N/A P.E. State --- Reg. no. ---

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N-2723 Expires 6/20/92

Date 11/2/90 Name C&S Valve Company, Tricentric Div. Signed [Signature]
(N Certificate Holder) (Authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by * Allendale Mutual Ins. Co. of Norwood, Massachusetts have inspected the pump, or valve, described in this Data Report on Nov. 2, 1990, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

*** Factory Mutual System**

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11-2-90 Signed [Signature] Commissions 1810168 IL 1498, OHIO PA3386N
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) and state or prov. and no.)

(1) For manually operated valves only.

Certificate Holder's Serial No. 90-1177-01(N)-01

8. Design conditions 177 (Disc) psi 125 °F or valve pressure class 150 (1)
(pressure) (temperature)
9. Cold working pressure 275 (Body) psi at 100°F
10. Hydrostatic test 425 psi. Disk differential test pressure 195 psi
11. Remarks: Emergency Water Service
Cover Plate - Material: SA 479 T316, Heat: YCE
Hex Head Cap Screw - Material: SA 193 GR. B8M, Heat: AQD
Gland Flange - Material: SA 479 T316, Heat: KDE
Stud - Material: SA 193 GR. B8M, Heat: ARB
Hex Nut - Material: SA 194 GR. 8M

CERTIFICATION OF DESIGN

Design Specification certified by Dale Sattar P.E. State PA Reg. no. PE 019525E
 Design Report certified by N/A P.E. State --- Reg. no. ---

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N-2723 Expires 6/20/92

Date 11/2/90 Name C&S Valve Company, Tricentric Div. Signed [Signature]
(N Certificate Holder) (authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by * Allendale Mutual Ins. Co. of Norwood, Massachusetts have inspected the pump, or valve, described in this Data Report on Nov. 2, 1990, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

* Factory Mutual System

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11-02-90 Signed [Signature] Commissions NB 10165, IL 1498, OHIO, PA 3365 N
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) and state or prov. and no.)

(1) For manually operated valves only.

Certificate Holder's Serial No. 90-1177-01(N)-02

8. Design conditions 177 (Disc) psi 125 °F or valve pressure class 150 (1)
(pressure) (temperature)
9. Cold working pressure 275 (Body) psi at 100°F
10. Hydrostatic test 425 psi. Disk differential test pressure 195 psi
11. Remarks: Emergency Water Service
Cover Plate - Material: SA 479 T316, Heat: YCE
Hex Head Cap Screw - Material: SA 193 GR. 8M, Heat: AOD
Gland Glange - Material: SA 479 T316, Heat: KDE
Stud - Material: SA 193 GR. 8M, Heat: ARB
Hex Nut - Material SA 194 GR. 8M

CERTIFICATION OF DESIGN

Design Specification certified by Dale Sattar P.E. State PA Reg. no. PE 019525E
 Design Report certified by N/A P.E. State --- Reg. no. ---

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N-2723 Expires 6/20/92

Date 11/2/90 Name C&S Valve Company, Tricentric Div. Signed [Signature]
(N Certificate Holder) (Authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by * Allendale Mutual Ins. Co. of Norwood, Massachusetts have inspected the pump, or valve, described in this Data Report on 7/22/90, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

* Factory Mutual System

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11-2-90 Signed [Signature] Commissions N 10168, IL 1498, OHIO, PA 3386A
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) and state or prov. and no.)

(1) For manually operated valves only.

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NU R PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Neles-Jamesbury, Inc. 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric*
(Name and Address)
4. Pump or Valve Ball Valve Nominal Inlet Size 2" Outlet Size 2"
(inch) (inch)

	(a) Model No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
(1)	6150 ND-286829-03G		N/A	ND286829-03 Rev. A	3	N/A	1990
(2)	6150 ND-286829-03H		N/A	ND286829-03 Rev. A	3	N/A	1990
(3)	6150 ND-286829-03J		N/A	ND286829-03 Rev. A	3	N/A	1990
(4)	6150 ND-286829-03K		N/A	ND286829-03 Rev. A	3	N/A	1990
(5)	6150 ND-286829-03L		N/A	ND286829-03 Rev. A	3	N/A	1990
(6)	6150 ND-286829-03M		N/A	ND286829-03 Rev. A	3	N/A	1990
(7)	6150 ND-286829-03N		N/A	ND286829-03 Rev. A	3	N/A	1990
(8)	6150 ND-286829-03P		N/A	ND286829-03 Rev. A	3	N/A	1990
(9)	6150 ND-286829-03Q		N/A	ND286829-03 Rev. A	3	N/A	1990
(10)							

5. Service Water
(Brief description of service for which equipment was designed)
*Station, 5Mi NE of Berwick on U.S. RT 11
Seat 170 psi Body 275 psi Temperature 150 °F or Valve Pressure Class 150 (1)
6. Design Conditions (Pressure) (Temperature)
7. Cold Working Pressure 275 psi at 100°F.
8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
	ASME SA		
(1)	RAN-7	351 Grade CF3M	Shell Cast Corp. Body
(2)	RAM-5	351 Grade CF3M	Shell Cast Corp. Body
(3)	RAM-12	351 Grade CF3M	Shell Cast Corp. Body
(4)	RAM-9	351 Grade CF3M	Shell Cast Corp. Body
(5)	RAN-3	351 Grade CF3M	Shell Cast Corp. Body
(6)	RAN-8	351 Grade CF3M	Shell Cast Corp. Body
(7)	RAM-14	351 Grade CF3M	Shell Cast Corp. Body
(8)	RAM-3	351 Grade CF3M	Shell Cast Corp. Body
(9)	RAM-16	351 Grade CF3M	Shell Cast Corp. Body

(b) Forgings- Castings			
	ASME SA		
(1)	RAS-28	351 Grade CF3M	Shell Cast Corp. Body Cap
(2)	RAS-27	351 Grade CF3M	Shell Cast Corp. Body Cap
(3)	RAS-6	351 Grade CF3M	Shell Cast Corp. Body Cap
(4)	RAS-37	351 Grade CF3M	Shell Cast Corp. Body Cap
(5)	RAS-11	351 Grade CF3M	Shell Cast Corp. Body Cap
(6)	RAP-4	351 Grade CF3M	Shell Cast Corp. Body Cap
(7)	RAS-19	351 Grade CF3M	Shell Cast Corp. Body Cap
(8)	RAS-42	351 Grade CF3M	Shell Cast Corp. Body Cap
(9)	RAS-12	351 Grade CF3M	Shell Cast Corp. Body Cap

(1) For manually operated valves only.

Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting	ASME SA		
007	193 Gr. B8	Nova Machine	Stud (All Valves)
	ASME SA		
006	194 Gr. 8	Nova Machine	Hex Nut (All Valves)
(d) Other Parts	ASME SA		
RAB	479 TYPE 316	Neles-Jamesbury	Ball (All Valves)

9. Hydrostatic test 425 psi. Disk Differential test pressure ----- psi. ND-286829-03G, 03H, 03J, 03K, 03L, 03M, 03N, 03P, 03Q

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1974.
 Addenda Winter '75, Code Case No. NONE, Date 11/21/90
 Signed Neles-Jamesbury Inc. by [Signature]
(N Certificate holder)
 Our ASME Certificate of Authorization No. N-1228 to use the N symbol expires 12/21/90
(N) Date

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Two N. Ninth St., Allentown,
 Stress analysis report (Class T only) on file at N/A

Design specifications certified by (1) Dale Sattar
 PE State PA Reg. No. PE 019525E
 Stress analysis certified by (1) N/A
 PE State N/A Reg. No. N/A

(1) Signature not required. List name only.

PA 18101

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of MASS and employed by: Protection Mutual
 of Norwood, Mass have inspected the pump, or valve, described in this Data Report on DEC 11 1990, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12-11 1990
[Signature] Commissions MA-1301 PAWC 338E
(Inspector) (Net) Bd., State, Prov. and No.)

FORM NPV-1 N CERTIF : HOLDERS' DATA REPORT FOR NU R PUMPS OR VALVES*
 As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Neles-Jamesbury, Inc. 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)

2. Manufactured for Pennsylvania Power & Light Co., Two Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)

3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric*
(Name and Address)

4. Pump or Valve Ball Valve . Nominal Inlet Size 2" Outlet Size 2"
(inch) (inch)

	(a) Model No., Series No or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No	(e) Class	(f) Nat'l. Bd No.	(g) Year Built
(1)	6150	ND-286829-03R	N/A	ND286829-03 Rev.A3		N/A	1990
(2)	6150	ND-286829-03S	N/A	ND286829-03 Rev. A 3		N/A	1990
(3)	6150	ND-286829-03T	N/A	ND286829-03 Rev. A 3		N/A	1990
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

5. Service Water
(Brief description of service for which equipment was designed)
*Station, 5Mi NE of Berwick on U.S. RT 11.

6. Design Conditions Seat 170 150
Body 275 100 psi 150 °F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)


7. Cold Working Pressure 275 psi at 100°F.

8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
(1) RAM-2	351 Grade CF3M	Shell Cast Corp.	Body
(2) RAM-6	351 Grade CF3M	Shell Cast Corp.	Body
(3) RAM-4	351 Grade CF3M	Shell Cast Corp.	Body
(1) RAS-10	351 Grade CF3M	Shell Cast Corp.	Cap
(2) RAR-2	351 Grade CF3M	Shell Cast Corp.	Cap
(3) RAS-22	351 Grade CF3M	Shell Cast Corp.	Cap
(b) Forgings			

(1) For manually operated valves only.

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.



Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting	ASME SA		
007	193 Gr. B8	Nova Machine	Stud (All Valve..)
	ASME SA		
006	194 Gr. 8	Nova Machine	Hex Nut (All Valves)
(d) Other Parts	ASME SA		
RAB	479 TYPE 316	Neles-Jamesbury	Ball (All Valves)

9. Hydrostatic test 425 psi. Disk Differential test pressure ----- psi. ND- 286829-03R,03S,03T

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1974.
 Addenda Winter '75 (Date), Code Case No NONE, Date 11/21/90
 Signed Neles-Jamesbury Inc. by Ronald P. Parker
(In Certificate Holder)
 Our ASME Certificate of Authorization No. N-1228 to use the N symbol expires 12/21/90
(Date)

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Two N. Ninth St., Allentown,
 Stress analysis report (Class T-only) on file at N/A

Design specifications certified by (1) Dale Sattar
 PE State PA Reg. No. PE 019525E
 Stress analysis certified by (1) N/A
 PE State N/A Reg. No. N/A

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of MASS and employed by Protection Mutual of Norwood, Mass have inspected the pump, or valve, described in this Data Report on DEC 11 19 90, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12-11-90
[Signature] (Inspector) Commissions MA-1301 PAUC 3385
(Nat'l Bd., State, Prov. and No.)

PA. 16.

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 26, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 2
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name PMR# 90-3088 / WAW'S U13017, C13321, C13322
PO Box 467, Berwick, PA 18603 Repair Organization P.O. No., Job No., etc.
Address
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System EMERGENCY SERVICE WATER SYSTEM, 054, CLASS III
5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No).
PRESSURE RELIEF VALVE	ANDERSON GREENWOOD	N26654	N/A	PSV-01126E	1991	REPLACEMENT	YES
LARGE PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	HRC-3302-3	1990	REPLACED	NO
LARGE PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	HRC-3302-3	1991	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-3302-4	1991	REPLACEMENT	NO
LARGE PIPE SUPPORT	PP&L	N/A	N/A	HRC-3302-H10	1990	REPLACED	NO
LARGE PIPE SUPPORT	PP&L	N/A	N/A	HRC-3302-H10	1991	REPLACEMENT	NO

7. Description of Work INSTALL A 1" PRESSURE RELIEF LINE FOR THE ESW PIPING ON THE 'E' DIESEL GENERATOR SIDE OF THE ESW ISOLATION VALVES'
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 190 psi Test Temp. AMBIENT °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE DATA REPORT(S) ATTACHED

Applicable Manufacturer's Data Reports to be attached

APPLICABLE CONSTRUCTION CODE FOR NEW RELIEF VALVE IS ASME SECTION III, 1986 EDITION

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed S. Sytsal Date July 16, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 6-18-91 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.


David Paulding Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date JULY 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 26, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 2 of 2
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR# 90-3088 / WA#'S U13017, C13321, C13322
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System EMERGENCY SERVICE WATER SYSTEM, 054A, CLASS III
5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SMALL PIPE SUPPORT	PP&L	N/A	N/A	SP-HRC-3302-H4	1991	REPLACEMENT	NO
SMALL PIPE SUPPORT	PP&L	N/A	N/A	SP-HRC-3302-H5	1991	REPLACEMENT	NO



FORM NV-1 CERTIFICATE HOLDERS DATA REPORT FOR PRESSURE OR VACUUM RELIEF VALVES*
As Required by the Provisions of the ASME Code, Section III, Division 1 Pg. 1 of 2

- Manufactured and certified by Anderson Greenwood & Co. 8950 Greenbriar, Stafford, TX 77477
(Name and address of NV Certificate Holder)
- Manufactured for Pennsylvania Power & Light Co., Two N. 9th Street, Allentown, PA 18101
(Name and address of Purchaser)
- Location of Installation: Susquehanna Power Station, 5 Mi. NE of Berwick on US RT. 11, Berwick, PA 18603
(Name and address)
- Valve 81PFS408A08ALG-N3 Office size 1/4 Nom. inlet size 1.00 Outlet size 1.00
(Model no., unless N/A) (in.) (in.) (in.)
- ASME Code, Section III, Division 1: 1986 None 3 N/A
(Edition) (Edition) (Edition) (Code Case no.)
- Type Spring 165 Fixed 709F 425 100
(Type) (Test pressure, psig) (Setdown, psig) (Nominal design temp., °F) (Hydro. test. pres. limit) (in.)
- Identification N26654 N/A N06-1051 Rev. D N/A 1991
(Cert. Holder's serial no.) (CRN) (Marking No.) (Part. Ed. no.) (Rev. date)
- Control ring settings N/A CBOM N06-1051-024 Rev. A
- Pressure retaining items:

	Serial No. or Identification	Mat'l. Spec., Including Type or Grade	Tensile Strength
Body	BZ	SA351-CF8M	70
Bonnet or yoke	Sleeve 6011	SA479-316	75
Support foot	Collar 6035	SA479-316	75
Nozzle	Flg. Inlt. 614TNE	SA182-F316	75
Orifice	Flg. Out. 614TNE	SA182-F316	75
Spring/washer	Guide 29772	SA479-316	75
Adjusting Screws	N/A	N/A	N/A
Spindle	30763	SA479-316	75
Spring	N/A	N/A	N/A
Bolting	05-1007-197	SA193-B8M	75
Other items			

10. Relieving capacity 17.5 GPM 10% overpressure as certified by the National Board 1-22-91
(Steam or fluid, lb/hr) (psig) (date)

11. Remarks:

CERTIFICATION OF DESIGN

Design Specification certified by Donald M. Papa P.E. State TX Reg. no. 35992
Design Report certified by N/A P.E. State N/A Reg. no. N/A

CERTIFICATE OF COMPLIANCE


We certify that the statements made in this report are correct and that this valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

NV Certificate of Authorization No. N-2825 Expires 9-10-93

Date 8/29/91 Name Anderson Greenwood & Co. signed Joseph A. Parks
(NV Certificate Holder) (Authorized representative)

* Supplemental information in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

NO. 2119
RECORD PACKAGE
PAGE 1 OF 15



210 10 1279 33
P.O. 1-22471-1

PAGE 2


FORM NO. 1 CERTIFICATE HOLDERS DATA REPORT FOR PRESSURE OR VACUUM RELIEF VALVES
As Required by the Provisions of the ASME Code, Section III, Division 1
Certificate Holder's Serial No. N26654

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Massachusetts and TX and MA of Boston, MA have inspected the valve described in this Data Report on 8/25/91 and state that to the best of my knowledge and belief, the Certificate Holder has constructed this valve in accordance with the ASME Code, Section III, Division 1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 8/25/91 Signature [Signature] Commission NB # 9015 N 98 TX # 1056

RECORD PACKET
PAGE 2



DESIGN CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that the design changes described in this report conform to the requirements of the National Board Inspection Code.

ASME Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date N/A 19 N/A N/A Signed N/A
(name of organization) (authorized representative)

CERTIFICATE OF REVIEW OF DESIGN CHANGE

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of N/A and employed by N/A of N/A has examined the design change as described in this report and verifies that to the best of his knowledge and belief such change complies with the applicable requirements of the National Board Inspection Code. By signing this certificate, neither the undersigned nor his employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date N/A 19 N/A Signed N/A Commissions N/A
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)

CONSTRUCTION CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that all construction and workmanship on this repair conform to the National Board Inspection Code.
(repair or alteration)

Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date July 16 19 92 Penna. Power & Light Co. Signed S. J. Lal
(repair or alteration organization) (authorized representative)

CERTIFICATE OF INSPECTION

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of Penna. and employed by Arkwright Mutual Insurance Company of Waltham, MA has inspected the work described in this report on July 22 19 92 and state that to the best of my knowledge and belief this work has been done in accordance with the National Board Inspection Code. By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date July 22 19 92 Signed [Signature] Commissions NB 7525 PA 2159 NJ
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)

FORM R-1, REPORT OF WELDED REPAIR OR ALTERATION
as required by the provisions of the National Board Inspection Code

1. Work performed by Owner DCP 88-3041A
WA C03926
(Name of repair or alteration organization) (P.O. no., job no., etc.)

2. Owner Pennsylvania Power and Light Co.
(Name) (Address)
Two N. Ninth Street, Allentown, PA 18101
(Address)

3. Location of installation Susquehanna Steam Electric Station
(Name) (Address)
Berwick, PA 18603
(Address)

4. Unit identification: Heat Exch. (Boiler, pressure vessel) Name of original manufacturer Struthers-Wells Equip. I.D.

5. Identifying nos.: 06-31764-1 1738 PA469333 1E-201A 1975
(N.B.I. serial no.) (original National Board no.) (jurisdiction no.) (other) (year built)

6. Description of work: Re-tubed Heat Exchanger by Removing Existing Cu-Ni Tubes and
Installing New AL-6XN Tubes.
(Use back, separate sheet, or sketch if necessary)

Hydro. WA=C03927 Pressure test, if applied 230 psi

7. Replacement Parts: Attached are Manufacturers' Partial Data Reports properly identified and signed by Authorized Inspectors for the following items of this report:

N/A

8. Remarks: Unit 1 RBCCW "A"

DESIGN CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that the design changes described in this report conform to the requirements of the National Board Inspection Code.

ASME Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date N/A 19 N/A N/A Signed N/A
(name of organization) (authorized representative)

CERTIFICATE OF REVIEW OF DESIGN CHANGE

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of N/A and employed by N/A

N/A of N/A has examined the design change as described in this report and verifies that to the best of his knowledge and belief such change complies with the applicable requirements of the National Board Inspection Code. By signing this certificate, neither the undersigned nor his employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date N/A 19 N/A Signed N/A Commissions N/A
(Authorized Inspector) (National Board (incl. endorsements, state, prov. and no.)

CONSTRUCTION CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that all construction and workmanship repair conform to the National Board Inspection Code.
(repair or alteration)

Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date July 16 19 92 Penna., Power & Light Co. Signed S.K. Stal
(repair or alteration organization) (authorized representative)

CERTIFICATE OF INSPECTION

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of Penna. and employed by Arkwright Mutual Insurance Company of Walcham, MA has inspected the work described in this report on JULY 22 19 92

and state that to the best of my knowledge and belief this work has been done in accordance with the National Board Inspection Code. By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date JULY 22 19 92 Signed [Signature] Commissions NR 7525 PA 2159 NE
(Authorized Inspector) (National Board (incl. endorsements, state, prov. and no.)

DESIGN CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that the design changes described in this report conform to the requirements of the National Board Inspection Code.

ASME Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date N/A 19N/A N/A Signed N/A
(name of organization) (authorized representative)

CERTIFICATE OF REVIEW OF DESIGN CHANGE

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of N/A and employed by N/A

N/A of N/A has examined the design change as described in this report and verifies that to the best of his knowledge and belief such change complies with the applicable requirements of the National Board Inspection Code. By signing this certificate, neither the undersigned nor his employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date N/A 19N/A Signed N/A Commissions N/A
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)

CONSTRUCTION CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that all construction and workmanship repair conform to the National Board Inspection Code.
(repair or alterations)

Certificate of Authorization no. N/A to use the N/A symbol expires N/A 19 N/A

Date July 16 1992 Penna., Power & Light Co. Signed S. V. Slad
(repair or alteration organization) (authorized representative)

CERTIFICATE OF INSPECTION

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of Penna. and employed by Arkwright Mutual Insurance

Company of Waltham, MA has inspected the work described in this report on July 22 1992

and state that to the best of my knowledge and belief this work has been done in accordance with the National Board Inspection Code. By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date July 22 1992 Signed Bill Paullany Commissions NB 2525 PA 2159 NE
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date JUNE 26, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 1
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PPL PMR #92-9024, WA #C23209
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System CONTAINMENT INSTRUMENT GAS SYSTEM 125 CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru w/72 Addenda, n/a Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru w/80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HCC-138-H28	1982	Replaced	no
PIPE SUPPORT	PP&L	N/A	N/A	SP-HCC-138-H28	1992	Replacement	no

7. Description of Work Pipe support temporarily removed and reinstalled as per IDCN #1

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in Items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed 810 Waj Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 4-11-92 to 4-17-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David Daullany Commissions NB 7525 PA 2159 NJ
Inspector's Signature National Board, State, Province, and Endorsements

Date JULY 22 19 92

1. Work performed by Pennsylvania Power and Light PMR# 90-3064A/ WA# C13640
(name of repair or alteration organization) (P.O. no., job no., etc.)
Two North Ninth Street, Allentown, Pa. 18101
(address)

2. Owner Pennsylvania Power and Light
(name)
Two North Ninth Street, Allentown, Pa. 18101
(address)

3. Location of installation Susquehanna Steam Electric Station
(name)
P.O. Box 467, Berwick, Pa. 18603
(address)

4. Unit identification: CONDENSER Name of original manufacturer _____
(boiler, pressure vessel)

5. Identifying nos.: 700205 129861 N/A 1K206B 1976
(mfr's serial no.) (original National Board no.) (jurisdiction no.) (other) (year built)

6. Description of work: MODIFY EXISTING 1/4" NPT CONDENSER WATER BOX VENT CONNECTION TO A 3/4" NPT
(use back, separate sheet, or sketch if necessary)
VENT CONNECTION TO ALLEVIATE CLOGGING PROBLEMS WITH ORIGINAL CONFIGURATION.

Pressure test, if applied N/A psi

7. Replacement Parts. Attached are Manufacturers' Partial Data Reports properly identified and signed by Authorized Inspectors for the following items of this report
NONE
(name of part, item number, mfr's name and identifying stamp)

8. Remarks: INSERVICE LEAK TEST PERFORMED BY WA# C13644 FOLLOWING RETURN TO SERVICE, WITH NO LEAKAGE OBSERVED.

DESIGN CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that the design changes described in this report conform to the requirements of the National Board Inspection Code.

ASME Certificate of Authorization no. N/A to use the N/A symbol expires N/A, 19

Date _____, 19____ Signed _____ N/A
(name of organization) (authorized representative)

CERTIFICATE OF REVIEW OF DESIGN CHANGE

The undersigned, holding a valid Commission issued by the National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of N/A and employed by N/A of N/A has examined the design change as described in this report and verifies that to the best of his knowledge and belief such change complies with the applicable requirements of the National Board Inspection Code. By signing this certificate, neither the undersigned nor his employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date _____, 19____ Signed _____ N/A Commissions _____ N/A

(Authorized Inspector)

(National Board (incl. endorsements), state, prov., and no.)

CONSTRUCTION CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that all construction and workmanship on this REPAIR conform to the National Board Inspection Code.

(repair or alteration)

Certificate of Authorization no. N/A to use the N/A symbol expires N/A, 19

Date July 16, 1992 PENNSYLVANIA POWER & LIGHT CO Signed SK May

(name of alteration organization)

(authorized representative)

CERTIFICATE OF INSPECTION

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASS. has inspected the work described in this report on July 22, 1992 and state that to the best of my knowledge and belief this work has been done in accordance with the National Board Inspection Code.

By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date July 22, 1992 Signed [Signature] Commissions NB 7525 PA 2159 NI
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)

1. Work performed by Pennsylvania Power and Light PMR# 90-3058A/ WA# C13564
(name of repair or alteration organization) (P.O. no., job no., etc.)
Two North Ninth Street, Allentown, Pa. 18101
(address)

2. Owner Pennsylvania Power and Light
(name)
Two North Ninth Street, Allentown, Pa. 18101
(address)

3. Location of installation Susquehanna Steam Electric Station
(name)
P.O. Box 467, Berwick, Pa. 18603
(address)

4. Unit Identification: CONDENSER Name of original manufacturer _____
(boiler, pressure vessel)

5. Identifying nos.: 700202 129736 N/A 1K206A 1976
(mfr's serial no.) (original National Board no.) (jurisdiction no.) (other) (year built)

6. Description of work: MODIFY EXISTING 1/4" NPT CONDENSER WATER BOX VENT CONNECTION TO A 3/4" NPT
(use back, separate sheet, or sketch if necessary)

VENT CONNECTION TO ALLEVIATE CLOGGING PROBLEMS WITH ORIGINAL CONFIGURATION.

Pressure test, if applied N/A psi

7. Replacement Parts. Attached are Manufacturers' Partial Data Reports properly identified and signed by Authorized Inspectors for the following items of this report
NONE

(name of part, item number, mfr's name and identifying stamp)

8. Remarks: INSERVICE LEAK TEST PERFORMED BY WA# C13635 FOLLOWING RETURN TO SERVICE, WITH NO LEAKAGE OBSERVED.

DESIGN CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that the design changes described in this report conform to the requirements of the National Board Inspection Code.

ASME Certificate of Authorization no. N/A to use the N/A symbol expires N/A, 19

Date _____, 19____ Signed _____ N/A
(name of organization) (authorized representative)

CERTIFICATE OF REVIEW OF DESIGN CHANGE

The undersigned, holding a valid Commission issued by the National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of N/A and employed by N/A of N/A has examined the design change as described in this report and verifies that to the best of his knowledge and belief such change complies with the applicable requirements of the National Board Inspection Code. By signing this certificate, neither the undersigned nor his employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date _____, 19____ Signed _____ N/A Commissions _____ N/A

(Authorized Inspector)

(National Board (incl. endorsements), state, prov., and no.)

CONSTRUCTION CERTIFICATION

The undersigned certifies that the statements made in this report are correct and that all construction and workmanship on this REPAIR (repair or alteration) conform to the National Board Inspection Code.

Certificate of Authorization no. N/A to use the N/A symbol expires N/A, 19

Date July 16, 1992 PENNSYLVANIA POWER & LIGHT CO Signed [Signature]
(name of alteration organization) (authorized representative)

CERTIFICATE OF INSPECTION

The undersigned, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the state or province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASS. has inspected the work described in this report on JULY 22, 1992 and state that to the best of my knowledge and belief this work has been done in accordance with the National Board Inspection Code.

By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection, except such liability as may be provided in a policy of insurance which the undersigned's insurance company may issue upon said object and then only in accordance with the terms of said policy.

Date July 22, 1992 Signed [Signature] Commissions NB 7525 PA 2159 NI
(Authorized Inspector) (National Board (incl. endorsements), state, prov., and no.)

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 15, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 1 of 6
Address
 2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.
 3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System CORE SPRAY PUMP ROOM COOLING SYSTEM 134D CLASS III
 5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
ROOM COOLER FLEX HOSES (2)	ANAMET	N/A	N/A	1E-231A SUPPLY	87	REPLACED	NO
ROOM COOLER FLEX HOSES (2)	ANAMET	N/A	N/A	1E-231A SUPPLY	90	REPLACEMENT	NO
ROOM COOLER FLEX HOSES (2)	ANAMET	N/A	N/A	1E-231C SUPPLY	87	REPLACED	NO
ROOM COOLER FLEX HOSES (2)	ANAMET	N/A	N/A	1E-231C SUPPLY	90	REPLACEMENT	NO
ROOM COOLER FLEX HOSES (2)	ANAMET	N/A	N/A	1E-231B RETURN	87	REPLACED	NO
ROOM COOLER FLEX HOSES (2)	ANAMET	N/A	N/A	1E-231B RETURN	90	REPLACEMENT	NO

7. Description of Work Replaced coils & ESW flex hoses, and modified ESW piping @ Core Spray Room Coolers
 8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure ←COILS(125@57°F/135@55°F)
 Other Pressure 194 / 195 psi Test Temp. 74 / 76 °F (LOOP "A" / LOOP "B")

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE DATA REPORTS ATTACHED.

Applicable Manufacturer's Data Reports to be attached

DCP's 88-3051A & B, 89-3027, 89-3028 WA's C13576 C13577 C13707 C13708 C13709 C13710

Appl. codes: Hoses = ANSI B31.1 1973 Coils = ASME VIII 1986 with Code Case 1997-2 Piping =

ASME III 1971 W72 with Code Case N316 Valves = ASME III 1974 (no addenda)

WA's (cont'd.): C13572 C13573 C13578 C13579

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. _____ N/A Expiration Date _____ N/A

Signed *SRM* Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 9-10-91 to 3-23-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Dail Daullany Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 15, 1992
Name
- Two North Ninth St., Allentown, PA 18101 Sheet 2 of 6
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
- PO Box 467, Berwick, PA 18603 SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
- Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System CORE SPRAY PUMP ROOM COOLING SYSTEM 134D CLASS III
5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
ROOM COOLER FLEX HOSES (2)	ANAMET	N/A	N/A	1E-231D SUPPLY	87	REPLACED	NO
ROOM COOLER FLEX HOSES (2)	ANAMET	N/A	N/A	1E-231D SUPPLY	90	REPLACEMENT	NO
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-231A BOTTOM	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-231A TOP	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	900633	N/A	1E-231A BOTTOM	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	900632	N/A	1E-231A TOP	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-231C BOTTOM	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-231C TOP	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	900635	N/A	1E-231C BOTTOM	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	900634	N/A	1E-231C TOP	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-231B BOTTOM	74	REPLACED	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 15, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 3 of 6
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System CORE SPRAY PUMP ROOM COOLING SYSTEM 134D CLASS III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-231B TOP	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	900637	N/A	1E-231B BOTTOM	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	900636	N/A	1E-231B TOP	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-231D BOTTOM	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-231D TOP	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	900639	N/A	1E-231D BOTTOM	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	900638	N/A	1E-231D TOP	90	REPLACEMENT	YES
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HRC-122-H4	82	REPLACED (DELETED)	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HRC-126-H2013	82	REPLACED (DELETED)	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HRC-126-H2514	82	REPLACED (DELETED)	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-121-1	82	REPLACED	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992
 Sheet 4 of 6

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System CORE SPRAY PUMP ROOM COOLING SYSTEM 134D CLASS III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-121-1	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-121-2	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-121-2	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-122-1	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-122-1	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-122-2	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-122-2	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-125-1	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-125-1	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-125-2	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-125-2	92	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 15, 1992
Name
Two North Ninth St., Allentown, PA 18101 Address
Sheet 5 of 6
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 Address
SEE REMARKS
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Address
Authorization No. N/A
Expiration Date N/A
4. Identification of System CORE SPRAY PUMP ROOM COOLING SYSTEM 134D CLASS III
5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-126-1	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-126-1	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-126-2	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-126-2	92	REPLACEMENT	NO
1/2" GLOBE VALVE	YARWAY	A0083	N/A	1RV-FP-11158A	77	REPLACED	YES
1/2" GLOBE VALVE	YARWAY	A0082	N/A	2RV-FP-11158A	77	REPLACED	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01A	N/A	1RV-FP-11158A	92	REPLACEMENT	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01B	N/A	2RV-FP-11158A	92	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	9958	N/A	1RV-FP-11158B	77	REPLACED	YES
1/2" GLOBE VALVE	YARWAY	9959	N/A	2RV-FP-11158B	77	REPLACED	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01N	N/A	1RV-FP-11158B	92	REPLACEMENT	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 15, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 6 of 6
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System CORE SPRAY PUMP ROOM COOLING SYSTEM 134D CLASS III
5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01P	N/A	2RV-FP-11158B	92	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	9938	N/A	1RV-FP-11158C	77	REPLACED	YES
1/2" GLOBE VALVE	YARWAY	9964	N/A	2RV-FP-11158C	77	REPLACED	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01C	N/A	1RV-FP-11158C	92	REPLACEMENT	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01D	N/A	2RV-FP-11158C	92	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	9934	N/A	1RV-FP-11158D	77	REPLACED	YES
1/2" GLOBE VALVE	YARWAY	9945	N/A	2RV-FP-11158D	77	REPLACED	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01R	N/A	1RV-FP-11158D	92	REPLACEMENT	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01S	N/A	2RV-FP-11158D	92	REPLACEMENT	YES



FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

2. Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3. Location of Installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4. Type Heat Exchanger 900633 -- BM-R-15,N-R-4 -- 1990
(Name or ref. to standard) (Manufacturer's No.) (CAN) (Drawing) (Mater. Id. No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Year

-- 1997-2 --
ASME Code (in) Code Case No. Special service per UG 120(c)

Items 6-11 incl to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" -- 0'-7.5" 1'-7 1/2"
Mater. (Spec. No. Grade) Nom. Thk. (in) Corr. Allow. (in) O.D. I.D. (in & in) Length (Overall) (in & in)

7. Seams: -- -- -- -- --
Long. (Det., Insp.) R.T. (Spot or Full) Eff. (in) M.T. Temp. (°F)

-- -- -- -- --
Time Grm. (Det., Insp.) R.T. (Spot, Partial, or Full) No. of Courses

8. Heads: (a) Mater. -- (Spec. No. Grade) (b) Mater. -- (Spec. No. Grade)

	Location (Top Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flt Diameter	Side to Pressure (Convex or Concave)
(a)	--	--	--	--	--	--	--	--	--	--
(b)	--	--	--	--	--	--	--	--	--	--

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8
(Mater. Spec. No. Gr. Size No.)

9. Type of Jacket -- Proof Test --

10. Jacket Closure -- If bar, give dimensions -- If bolted, describe or sketch --
(Describe as edge & weld, bar, etc.)

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi.
Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 7.5" .75" -- Bolted
Stationary Mater. (Spec. No. Gr.) Diam. (in) (Subject to pressure) Nom. Thk. (in) Corr. Allow. (in) Attach. (Welded, Bolted)

-- -- -- -- --
Floating Mater. (Spec. No. Gr.) Diam. (in) Nom. Thk. (in) Corr. Allow. (in) Attach

13. Tubes SB-676, Class 2 .625" .049" 50 Straight
Mater. (Spec. No. Gr.) O.D. (in) Nom. Thk. (in or Gauge) Number Type (Straight or "U")

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: -- -- -- -- --
Mater. (Spec. No. Grade) Nom. Thk. (in) Corr. Allow. (in) O.D. I.D. (in & in) Length (Overall) (in & in)

15. Seams: -- -- -- -- --
Long. (Det., Insp.) R.T. (Spot or Full) Eff. (in) M.T. Temp. (°F)

-- -- -- -- --
Time Grm. (Det., Insp.) R.T. (Spot, Partial, or Full) No. of Courses

16. Heads: (a) Mater. -- (Spec. No. Grade) (b) Mater. -- (Spec. No. Grade)

	Location (Top Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flt Diameter	Side to Pressure (Convex or Concave)
(a)										
(b)										

If removable, bolts used (describe other fastenings) --
(Mater. Spec. No. Gr. Size No.)

17. MAWP -- psi at max. temp. -- °F. Min. design metal temp. -- °F at -- psi.
Hydro., pneu., or comb. test press. -- psi.

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	diam.," or Size	Type	Mat.	Wt. Thk.	Reinforcement Mat.	How Attached	Location	
INLET	1	2"	IPS	W/N FLG	SA-182,T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"		W/N FLG	SA-182,T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"		THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	2	1 1/8"		THD PLUG	SA-479	3000LB	N/R	THREADED	END

19. Supports: Skirt No Lugs -- Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report _____
(Name of part, item number, mfg.'s name and identifying stamp)

TR-2893 (1) Mark: BFCO Item# 34, PO# 8-43433-1, Item 5, DCP# 88-3051A, For CS Pump Room
120 PC/Adjustax, Coil Tag No. 1E231A, Unit Cooler 1V211A, Furnished on 89326794
(74S-4885)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9 1992
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed Barry DeHart
(Manufacturer) (Inspector)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance

of Norwood, Massachusetts have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 21, 1990, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6/29/90 Signed [Signature] Commissions VA 682 PANCO3567
(Authorized Inspector) (National Board, State, Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19_____
 Date _____ Co. name _____
(Assembler that certified and constructed field assembly) (By Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as date items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (National Board, State, Province and No.)

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
 (Name and address of manufacturer)

2. Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
 (Name and address of purchaser)

3. Location of Installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
 (Name and address)

4. Type Heat Exchanger 900632 --- BM-R-15,N-R-4 --- 1990
 (Name or term, tank) (Mfg. serial No.) (CRN) (Drawing) (Mat'l. No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
 Year

--- 1997-2 ---
 Addenda (Refs) Code Case No. Special services per UG 120(d)

Items 6-11 incl to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" --- 0'-7.5" 1'-7 1/2"
 (Mat'l. Spec No., Grade) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))

7. Seams: --- --- --- --- ---
 Long (Dbl., Sngl.) R.T. (Spot or Full) EN (ft) H.T. Temp. (°F)

--- --- --- --- ---
 Type Girth (Dbl., Sngl.) R.T. (Spot, Partial, or Full) No. of Courses

8. Heads: (a) Mat'l. --- (Spec. No., Grade) (b) Mat'l. --- (Spec. No., Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	---	---	---	---	---	---	---	---	---
(b)	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8
(Matl. Spec No., Gr., Size No)

9. Type of Jacket --- Proof Test ---

10. Jacket Closure --- (Describe as ogee & weld, bar, etc) If bar, give dimensions --- If bolted, describe or sketch ---

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi
 Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 7.5" .75" --- Bolted
 Stationary Mat'l. (Spec No., Gr.) (Diam. (in)) (Subject to pressure) (Nom. Thk. (in)) (Corr. Allow. (in)) Attach (Welded, Bolted)

--- --- --- --- ---
 Floating Mat'l. (Spec No., Gr.) (Diam. (in)) (Nom. Thk. (in)) (Corr. Allow. (in)) Attach

13. Tubes: SB-676, Class 2 .625" .049" 50 Straight
 Mat'l. (Spec No., Gr.) (OD (in)) (Nom. Thk. (in or Gauge)) (Number) Type (Straight or 'U')

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: --- --- --- --- ---
 Mat'l. (Spec No., Grade) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))

15. Seams: --- --- --- --- ---
 Long (Dbl., Sngl.) R.T. (Spot or Full) EN (ft) H.T. Temp. (°F)

--- --- --- --- ---
 Type Girth (Dbl., Sngl.) R.T. (Spot, Partial, or Full) No. of Courses

16. Heads: (a) Mat'l. --- (Spec. No., Grade) (b) Mat'l. --- (Spec. No., Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)									
(b)									

If removable, bolts used (describe other fastenings) ---
(Matl. Spec No., Gr., Size No)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- psi
 Hydro., pneu., or comb. test press. --- psi.

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet Outlet, Drain etc)	No	Dim. or Size	Type	Mat.	Nom. Thk.	Reinforcement Mat	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182,T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182,T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	2	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19. Supports: Skirt No Lugs -- Legs -- Other --- Attached ---
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: TR-2892 (1) Mark: BFCO Item# 33, PO# 8-43433-1, Item 5, DCP# 88-3051A, For CS Pump Room 120 PC/Adjustax, Coil Tag No. 1E231A, Unit Cooler 1V211A, Furnished on 89326793 (74S-4885)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 19 92
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed Barry Allhart
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance of Norwood, Massachusetts

have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 20, 19 90, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 6/29/90 Signed [Signature] Commissions VA 682, PAWC03567
(Authorized Inspector) (*Factory Mutual System (Not) Board, State, Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19_____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (By Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____ of _____

have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ Signed _____ Commissions _____
(Authorized Inspector) (Not) Board (incl endorsements), State, Prov. and No. 1

1E-231C BOT.

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

NOI-QA-2.47 L
OSR #45

Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

2. Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3. Location of Installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4. Type Heat Exchanger 900635 --- BM-R-15,N-R-4 --- 1990
(Name or type, term) (Mfr's serial No.) (CRN) (Drawing) (Inst. No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Year

--- 1997-2 ---
Addenda (Title) Code Case No. Special service per UG-120(d)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" --- 0'-7.5" 1'-7 1/2"
(Matl. (Spec. No., Grade)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

7. Seams: --- --- --- --- ---
(Long. (Det., Sngl.)) (R.T. (Spot or Full)) (SH (ft.)) (N.T. Temp. (°F))
--- --- --- --- ---
(Time) (Diam. (Det., Sngl.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

8. Heads: (a) Matl. --- (Spec. No., Grade) (b) Matl. --- (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	---	---	---	---	---	---	---	---	---	---
(b)	---	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8
(Matl. Spec. No., Gr. Size No.)

9. Type of Jacket --- Proof Test ---

10. Jacket Closure --- If bar, give dimensions --- If bolted, describe or sketch ---
(Describe as edge & weld, bar, etc.)

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi
Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 7.5" .75" --- Bolted
(Stationary Matl. (Spec. No., Gr.)) (Diam. (in.) (Subject to pressure)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Attach (Welded, Bolted))
--- --- --- --- ---
(Floating Matl. (Spec. No., Gr.)) (Diam. (in.)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Attach)

13. Tubes: SB-676, Class 2 .625" .049" 50 Straight
(Matl. (Spec. No., Gr.)) (O.D. (in.)) (Nom. Thk. (in. or Gauge)) (Number) (Type (Straight or "U"))

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: --- --- --- --- ---
(Matl. (Spec. No., Grade)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

15. Seams: --- --- --- --- ---
(Long. (Det., Sngl.)) (R.T. (Spot or Full)) (SH (ft.)) (N.T. Temp. (°F))
--- --- --- --- ---
(Time) (Diam. (Det., Sngl.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

16. Heads: (a) Matl. --- (Spec. No., Grade) (b) Matl. --- (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)										
(b)										

If removable, bolts used (describe other fastenings) ---
(Matl. Spec. No., Gr. Size No.)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- psi
Hydro., pneu., or comb. test press. --- psi.

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diag. or Size	Type	Matl.	Wt. Tol.	Reformation Mtd	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	2	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19. Supports: Skirt No Lugs -- Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number, mfg. name and identifying stamp)

TR-2895 (1) Mark: BFCO Item# 36, PO# 8-43433-1, Item 5, DCP# 88, 3051A For CS Pump Roc 120 PC/Adjustax, Coil Tag No. 1E231C, Unit Cooler 1V211C, Furnished on 89326796 (74S-4885)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 19 92
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed [Signature]
(Manufacturer) (Inspector)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance of Norwood, Massachusetts

have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 20, 19 90, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 6/29/90 Signed [Signature] Commissions VA 482, PAWCA3567
(Authorized Inspector) *Factory Mutual System (Not Boilers, State Province and No 1)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19 _____
 Date _____ Co. Name _____ Signed _____
(Assembler that certified and constructed field assembly) (Inspector)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ Signed _____ Commissions _____
(Authorized Inspector) (Not Boilers, State Province and No 1)

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

2. Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3. Location of Installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4. Type Heat Exchanger 900634 -- BM-R-15, N-R-4 -- 1990
(Type or form, code) (Mfr's serial No.) (CRN) (Drawing) (Heat Ex No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Year

-- 1997-2 --
Addenda (date) Code Case No. Special orders per UG 120(d)

Items 6-11 incl to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell SA-240, T-316L 1.5" -- 0'-7.5" 1'-7 1/2"
Mat'l Spec No Grade) Nom. Thk (in) Corr Allow (in) Diam ID (ft & in) Length (Overall) (ft & in)

7. Seams: -- -- -- -- --
Long (Dbl, Sngl) R.T. (Spot or Full) EN (%) H.T. Temp. (°F)

-- -- -- -- --
Time Girth (Dbl, Sngl) R.T. (Spot, Partial, or Full) No of Courses

8. Heads: (a) Mat'l. -- (b) Mat'l. --
(Spec No, Grade) (Spec No, Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	--	--	--	--	--	--	--	--	--
(b)	--	--	--	--	--	--	--	--	--

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8;
(Mat'l. Spec No. Gr. Size No)

9. Type of Jacket Proof Test

10. Jacket Closure --- If bar, give dimensions --- If bolted, describe or sketch ---
(Describe as edges & weld, bar, etc)

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi.
 Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 7.5" .75" --- Bolted
Stationary Mat'l (Spec. No. Gr.) Diam (in) (Subject to pressure) Nom. Thk (in) Corr. Allow (in) Attach (Welded, Bolted)

--- --- --- --- ---
Floating Mat'l (Spec. No. Gr.) Diam. (in.) Nom. Thk. (in.) Corr. Allow. (in.) Attach

13. Tubes: SB-676, Class 2 .625" .049" 50 Straight
Mat'l (Spec No. Gr.) OD (in) Nom Thk (in or Gauge) Number Type (Straight or "U")

Items 14-17 incl to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: --- --- --- --- ---
Mat'l (Spec No, Grade) Nom. Thk. (in) Corr Allow (in) Diam ID. (ft & in) Length (Overall) (ft & in)

15. Seams: --- --- --- --- ---
Long (Dbl, Sngl) R.T. (Spot or Full) EN (%) H.T. Temp. (°F)

--- --- --- --- ---
Time Girth (Dbl, Sngl) R.T. (Spot, Partial, or Full) No of Courses

16. Heads: (a) Mat'l. --- (b) Mat'l. ---
(Spec. No, Grade) (Spec No, Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)									
(b)									

If removable, bolts used (describe other fastenings) ---
(Mat'l. Spec No. Gr. Size No)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- psi.
 Hydro., pneu., or comb. test press. --- psi.

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Dim. or Size	Type	Matl.	Nom. Thk.	Reinforcement Matl.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182,T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182,T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	2	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19. Supports: Skirt No Lugs -- Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number, mfg's name and identifying stamp)

TR-2894 (1) Mark: BFCO Item# 35, PO# 8-43433-1, Item 5, DCP# 88 3051A, For CS Pump Roo
120 PC/Adjustax, Coil Tag No. 1E231C, Unit Cooler 1V211C Furnished on 89326795
(74S-4885)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 1992
 Date JUNE 29, 1990 Co. name Aerofin Corporation signed Bary J. Hart
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance

of Norwood, Massachusetts have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 18, 1990, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6/29/90 Signed [Signature] Commissions VA 682, PAWCO3567
(Authorized Inspector) *Factory Mutual System (N.B. Board Code, State, Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19____.

Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (By Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (N.B. Board Code, State, Province and No.)

1E-231B BOT.

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

NDI-QA-24.7 0
DSR #45

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3. Location of Installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4. Type Heat Exchanger 900637 BM-R-15, N-R-4 1990
(Name or term used) (Mfg's serial No.) (CRN) (Drawing) (Shell No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1, 1986
Year

--- 1997-2 ---
Address listed Code Case No. Special services per UG 120(a)

Items 6-11 incl to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell SA-240, T-316L 1.5" --- 0'-7.5" 1'-7 1/2"
(Mat. Spec. No. Grade) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (in & in)) (Length (Overall) (in & in))

7. Seams: --- --- --- --- ---
(Long. (Dbl. Enpl)) (R.T. (Spot or Full)) (Eff. (%)) (H.T. Temp. (°F))

--- --- --- --- ---
(Time) (Girth (Dbl. Enpl)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

8. Heads: (a) Matl. --- (Spec. No. Grade) (b) Matl. --- (Spec. No. Grade)

	Location (Top Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	---	---	---	---	---	---	---	---	---	---
(b)	---	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8M
(Matl. Spec. No., Gr., Size No.)

Type of Jacket --- Proof Test ---

10. Jacket Closure --- If bar, give dimensions --- If bolted, describe or sketch. (Describe as edge & weld, bar, etc.)

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi.
Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 7.5" .75" --- Bolted
(Stationary Matl. (Spec. No., Gr.)) (Diam. (in) (Subject to pressure)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach (Welded, Bolted))

--- --- --- --- ---
(Floating Matl. (Spec. No., Gr.)) (Diam. (in)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach)

13. Tubes: SB-676, Class 2 .625" .049" 50 Straight
(Matl. (Spec. No., Gr.)) (O.D. (in)) (Nom. Thk. (in or Gauge)) (Number) (Type (Straight or "U"))

Items 14-17 incl to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: --- --- --- --- ---
(Matl. (Spec. No. Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (in & in)) (Length (Overall) (in & in))

15. Seams: --- --- --- --- ---
(Long. (Dbl. Enpl)) (R.T. (Spot or Full)) (Eff. (%)) (H.T. Temp. (°F))

--- --- --- --- ---
(Time) (Girth (Dbl. Enpl)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

16. Heads: (a) Matl. --- (Spec. No., Grade) (b) Matl. --- (Spec. No., Grade)

	Location (Top Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)										

If removable, bolts used (describe other fastenings) ---
(Matl. Spec. No., Gr., Size No.)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- psi.
Hydro., pneu., or comb. test press. --- psi.

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	diam. or Size	Type	Mark	Wt. Lbs.	Reattachment Mkt.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182.T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182.T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	2	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19 Supports: Skirt No Legs -- Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20 Remarks, Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number, mfg's name and identifying stamp)

TR-2897 (1) Mark: BFCO Item# 38 PO# 8-43433-1, Item 5 DCP# 88 3051B For CS Pump Room
120 PC/Adjustax, Coil Tag No. 1E231B, Unit Cooler 1V211B, Furnished on 89326798
(74S-4885)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 1992
 Date 7-11-90 Co. name Aerofin Corporation Signed [Signature]
(Manufacturer) (Inspector)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance of Norwood, Massachusetts

have inspected the pressure vessel described in this Manufacturer's Data Report on JULY-11-, 1990, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 7-12-90 Signed [Signature] Commissions VA 682 PAWC33567
(Authorized Inspector) (National Board State Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19_____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (By Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (National Board State Province and No.)

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3 Location of Installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4 Type Heat Exchanger 900636 --- BM-R-15,N-R-4 --- 1990
(Mark or con. desc.) (Mfg. or ord. No.) (CRN) (Design) (Shell No.) (Year built)

6. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986

--- 1997-2 ---
(Address lines) (Code Case No) (Special services per UG 120(d))

Items 6-11 incl to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell SA-240, T-316L 1.5" --- 0'-7.5" 1'-7 1/2"
(Matl. (Spec No. Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))

7. Seams: --- --- --- --- ---
(Long. (Dbl., Enpl)) (R.T. (Spot or Full)) (EN (ft)) (H.T. Temp. (°F))
--- --- --- --- ---
(Time) (Grn. (Dbl., Enpl)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

8. Heads: (a) Matl. --- (Spec No., Grade) (b) Matl. --- (Spec No., Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Coneical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	---	---	---	---	---	---	---	---	---
(b)	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8M
(Matl., Spec No., Gr., Size No.)

J. Type of Jacket --- Proof Test ---

10. Jacket Closure --- If bar, give dimensions --- If bolted, describe or sketch. (Describe as edge & weld, bar, etc.)

11 MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi. Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 7.5" .75" --- Bolted
(Stationary Matl. (Spec No., Gr.)) (Diam. (in)) (Subject to pressure) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach (Welded, Bolted, etc.))
--- --- --- --- ---
(Floating Matl. (Spec No., Gr.)) (Diam. (in)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach)

13. Tubes: SB-676, Class 2 .625" .049" 50 Straight
(Matl. (Spec No., Gr.)) (O.D. (in)) (Nom. Thk. (in or Gauge)) (Number) (Type (Straight or "U"))

Items 14-17 incl to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: --- --- --- --- ---
(Matl. (Spec No., Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))

15. Seams: --- --- --- --- ---
(Long. (Dbl., Enpl)) (R.T. (Spot or Full)) (EN (ft)) (H.T. Temp. (°F))
--- --- --- --- ---
(Time) (Grn. (Dbl., Enpl)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

16. Heads: (a) Matl. --- (Spec No., Grade) (b) Matl. --- (Spec No., Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Coneical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)

If removable, bolts used (describe other fastenings) --- (Matl., Spec No., Gr., Size No.)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- psi. Hydro., pneu., or comb. test press. --- psi.

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diam. or Size	Type	Matl.	Wgt. Tht.	Reinforcement Mtd.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	2	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19. Supports: Skirt No Lugs -- Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: TR-2896 (1) Mark: BFCO Item# 37, PO# 8-43433-1, Item 5 DCP# 88, 3051B For CS Pump Room 120 PC/Adjustax, Coil Tag No. 1E231B, Unit Cooler 1V211B, Furnished on 8/3/97 (74S-4885)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.
 "U" Certificate of Authorization No. 2916 expires December 9, 19 92
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed [Signature]
(Manufacturer)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance of Norwood, Massachusetts have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 21, 19 90, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 6/29/90 Signed [Signature] Commissions VA 682 BWC03567
(Authorized Inspector) *Factory Mutual System (N.B. Board State Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.
 "U" Certificate of Authorization No. _____ expires _____, 19 ____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (By Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____ of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ Signed _____ Commissions _____
(Authorized Inspector) (N.B. Board and/or endorsement) State Prov. and No.)

1E-231D BOT.

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

NOI-QA-24.7
OSR #45.

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3. Location of installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4. Type Heat Exchanger 900639 -- BM-R-15,N-R-4 -- 1990
(Name or type, code) (Mfg.'s serial No.) (CAN) (Drawing) (Date of No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Year

-- 1997-2 --
Addenda listed Code Case No. Special services per UG 120(d)

Items 6-11 incl to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" -- 0'-7.5" 1'-7 1/2"
(Matl. Spec. No. Grade) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (in & in)) (Length (Overall) (in & in))

7. Seams: -- -- -- -- --
(Long. IDW, Supt.) (R.T. (Spot or Full)) (SH (in)) (H.T. Temp. (°F))

-- -- -- -- --
(Time) (Diam. IDW, Supt.) (R.T. (Spot, Partial, or Full)) (No. of Courses)

8. Heads: (a) Matl. -- (b) Matl. --
(Spec. No. Grade) (Spec. No. Grade)

	Location (Top Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	--	--	--	--	--	--	--	--	--	--
(b)	--	--	--	--	--	--	--	--	--	--

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8M
(Matl. Spec. No. Gr. Size No.)

9. Type of Jacket Proof Test

10. Jacket Closure --- (Describe as edge & weld, bar, etc.) If bar, give dimensions --- If bolted, describe or sketch.

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi
Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubeends: SB-688 7.5" .75" --- Bolted
(Stationary Matl. (Spec. No., Gr.)) (Diam. (in) (Subject to pressure)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach (Welded, Bolted))

--- --- --- --- ---
(Floating Matl. (Spec. No., Gr.)) (Diam. (in)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach)

13. Tubes: SB-676, Class 2 .625" .049" 50 Straight
(Matl. (Spec. No., Gr.)) (O.D. (in)) (Nom. Thk. (in or Gauge)) (Number) (Type (Straight or 'U'))

Items 14-17 incl to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: --- --- --- --- ---
(Matl. (Spec. No., Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (in & in)) (Length (Overall) (in & in))

15. Seams: --- --- --- --- ---
(Long. IDW, Supt.) (R.T. (Spot or Full)) (SH (in)) (H.T. Temp. (°F))

--- --- --- --- ---
(Time) (Diam. IDW, Supt.) (R.T. (Spot, Partial, or Full)) (No. of Courses)

16. Heads: (a) Matl. --- (b) Matl. ---
(Spec. No., Grade) (Spec. No., Grade)

	Location (Top Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)										
(b)										

If removable, bolts used (describe other fastenings) ---
(Matl. Spec. No., Gr., Size, No.)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- psi
Hydro., pneu., or comb. test press. --- psi.

64

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diam. or Size	Type	Mark	Nom. Tht.	Reinforcement Met.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182,T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182,T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	2	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19. Supports: Skirt No Legs -- Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number, mfg's name and identifying stamp)

TR-2899 (1) Mark: BFCO Item# 40, PO# 8-43433-1, Item 5, DCP# 88-3051R, For CS Pump Room 120 PC/Adjustax, Coil Tag No. 1E231D, Unit Cooler 1V211D Furnished on 89326800 (74S-4885).

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 19 92
 Date JULY 3, 1990 Co. name Aerofin Corporation Signed [Signature]
(Manufacturer) (Inspector)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance of Norwood, Massachusetts

have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 29, 19 90, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 7/3/90 Signed [Signature] Commissions VA 682 PAWCO3567
(Authorized Inspector) (National Board, State, Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19 ____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (By Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ Signed _____ Commissions _____
(Authorized Inspector) (National Board (and endorsement) State, Prov. and No.)

NDI-QA-2.4.7
DSR #45

1E-231D TOP

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by: Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

Manufactured for: Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3. Location of Installation: Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4. Type: Heat Exchanger 900638 --- BM-R-15, N-R-4 --- 1990
(Name or con. code) (Mfg. serial No.) (CAN) (Drawing) (Shell ID No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Yes

--- 1997-2 ---
(Addenda letter) (Code Case No.) (Special service per UG-120(d))

Items 6-11 incl to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" --- 0'-7.5" 1'-7 1/2"
(Matl. (Spec. No., Grade)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

7. Seams: --- --- --- --- ---
(Long. (Dbl., Enpl.)) (R.T. (Spot or Full)) (EN (in.)) (H.T. Temp. (°F))

--- --- --- --- ---
(Time) (Girth (Dbl., Enpl.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

8. Heads: (a) Matl. --- (Spec. No., Grade) (b) Matl. --- (Spec. No., Grade)

	Location (Top, Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flar Diameter	Side to Pressure (Convex or Concave)
(a)	---	---	---	---	---	---	---	---	---	---
(b)	---	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8M
(Matl., Spec. No., Gr., Size No.)

9. Type of Jacket --- Proof Test ---

10. Jacket Closure --- If bar, give dimensions --- If bolted, describe or sketch ---
(Describe as edge & weld, bar, etc.)

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi
Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 7.5" .75" --- Bolted
(Stationary Matl. (Spec. No., Gr.)) (Diam. (in.) (Subject to pressure)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Attach (Welded, Bolted))

--- --- --- --- ---
(Floating Matl. (Spec. No., Gr.)) (Diam. (in.)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Attach)

13. Tubes: SB-676, Class 2 .625" .049" 50 Straight
(Matl. (Spec. No., Gr.)) (OD (in.)) (Nom. Thk. (in. or Gauge)) (Number) (Type (Straight or "U"))

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: --- --- --- --- ---
(Matl. (Spec. No., Grade)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

15. Seams: --- --- --- --- ---
(Long. (Dbl., Enpl.)) (R.T. (Spot or Full)) (EN (in.)) (H.T. Temp. (°F))

--- --- --- --- ---
(Time) (Girth (Dbl., Enpl.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

16. Heads: (a) Matl. --- (Spec. No., Grade) (b) Matl. --- (Spec. No., Grade)

	Location (Top, Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flar Diameter	Side to Pressure (Convex or Concave)
(a)										
(b)										

If removable, bolts used (describe other fastenings) ---
(Matl., Spec. No., Gr., Size No.)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- psi
Hydro., pneu., or comb. test press. --- psi.

62

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Size or Size	Type	Matl.	Wt. Lbs.	Reinforcement Mts.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	2	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19. Supports: Skirt No Lugs -- Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number, mfg. name and identifying stamp)

TR-2898 (1) Mark: BFCO Item# 39 PO# 8-43433-1, Item 5 DCP# 88-3051B For CS Pump Room
120 PC/Adjustax, Coil Tag No. 1E231D, Unit Cooler 1V211D, Furnished on 89326799
(74S-4885)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 1992
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed [Signature]
(Manufacturer) (Registered)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance

of Norwood, Massachusetts have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 18, 1990, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6/29/90 Signed [Signature] Commissions VA 682 PAWCO3567
(Authorized Inspector) (*Factory Mutual System) (N.B. Board State Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19_____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (By Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (N.B. Board State Province and No.)

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section VIII, Div. 1

1. Manufactured by Neles-Jamesbury, Inc., 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric *
(Name and Address)
4. Pump or Valve Ball Valve Nominal Inlet Size 1/2" Outlet Size 1/2"
(inch) (inch)

(a) Model No. Series No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Std. No.	(g) Year Built
(1) 4CB	NC-334123-01A	N/A	NC-334123-01 Rev.C	2	N/A	1992
(2) 4CB	NC-334123-01B	N/A	NC-334123-01 Rev.C	2	N/A	1992
(3) 4CB	NC-334123-01C	N/A	NC-334123-01 Rev.C	2	N/A	1992
(4) 4CB	NC-334123-01D	N/A	NC-334123-01 Rev.C	2	N/A	1992
(5) 4CB	NC-334123-01E	N/A	NC-334123-01 Rev.C	2	N/A	1992
(6) 4CB	NC-334123-01F	N/A	NC-334123-01 Rev.C	2	N/A	1992
(7) 4CB	NC-334123-01G	N/A	NC-334123-01 Rev.C	2	N/A	1992
(8) 4CB	NC-334123-01H	N/A	NC-334123-01 Rev.C	2	N/A	1992
(9)						
(10)						

5. Emergency Service Water
(Brief description of service for which equipment was designed)
- *Station, 5Mi NE of Berwick on U.S. RT11
6. Design Conditions Seat 177 125°
Body 275 100° psi 150 °F or Valve Pressure Class (1)
(Pressure) (Temperature)
7. Cold Working Pressure 275 psi at 100°F.
8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings	ASME-SA		
(1) RHD -5	351 Gr. CF8M	Southern Tool	Body
(2) RHD -48	351 Gr. CF8M	Southern Tool	Body
(3) RHD -32	351 Gr. CF8M	Southern Tool	Body
(4) RHD -17	351 Gr. CF8M	Southern Tool	Body
(5) RHD -55	351 Gr. CF8M	Southern Tool	Body
(6) RHD -38	351 Gr. CF8M	Southern Tool	Body
(7) RHD -53	351 Gr. CF8M	Southern Tool	Body
(8) RHD -4	351 Gr. CF8M	Southern Tool	Body
(1) RHD -9 & -13	351 Gr. CF3M	Southern Tool	Caps
(2) RHD -6 & -79	351 Gr. CF3M	Southern Tool	Caps
(3) RHD -33 & -36	351 Gr. CF3M	Southern Tool	Caps
(4) RHD -61 & -70	351 Gr. CF3M	Southern Tool	Caps
(5) RHD -112 & -155	351 Gr. CF3M	Southern Tool	Caps
(6) RHD -1 & -166	351 Gr. CF3M	Southern Tool	Caps
(7) RHD -14 & -73	351 Gr. CF3M	Southern Tool	Caps
(8) RHD -42 & -81	351 Gr. CF3M	Southern Tool	Caps

For manually operated valves only.

PP & L Doc No. 45

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2" x 11", (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting	ASME-SA		
9E0947	194 Gr. 8	Nova Machine	Hex Nut (all valves)
9E0947	193 Gr. B8	Nova Machine	Hex HD. Cap
			*(all valves)
(d) Other Parts	ASME-SA		
RET	479 Type 316	Neles-Jamesbury	Ball (all valves)

9. Hydrostatic test 425 psi. Disk Differential test pressure _____ psi. NC-334123-01A, 01B, 01C, 01D, 01E, 01F, 01G, 01H

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1974.

Addenda NONE (Date), Code Case No. NONE Date 7 Feb 92

Signed Neles-Jamesbury, Inc. by Ronald O. Parker
(N Certificate Holder)

Our ASME Certificate of Authorization No. N-1228 to use the N symbol expires Oct. 27, 1993
(N) (Date)

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Two North Ninth St., Allentown
Stress analysis report (Class T only) on file at N/A PA 18101

Design specifications certified by (1) Dale Stattar
PE State PA Reg. No. PE 019525E

Stress analysis certified by (1) N/A
PE State N/A Reg. No. N/A

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of MASS and employed by Protection Mutual of Norwood, Massachusetts have inspected the pump, or valve, described in this Data Report on 2-7 19 92, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-7 19 92 Commissions MA # 1287 PAUC # 2757
R. H. Taylor (Inspector) (Nat'l Bd., State, Prov. and No.)
Factory Mutual Systems

FORM NPV-1 N CERTIFICA' HOLDERS' DATA REPORT FOR NUCLE PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section VIII, Div. 1

1. Manufactured by Neles-Jamesbury, Inc., 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric *
(Name and Address)
4. Pump or Valve Ball Valve . Nominal Inlet Size 1/2" Outlet Size 1/2"
(inch) (inch)

	(a) Model No. Series No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Std. No.	(g) Year Built
(1)	4CB	NC-334123-01J	N/A	NC-334123-01 Rev.C	2	N/A	1992
(2)	4CB	NC-334123-01K	N/A	NC-334123-01 Rev.C	2	N/A	1992
(3)	4CB	NC-334123-01L	N/A	NC-334123-01 Rev.C	2	N/A	1992
(4)	4CB	NC-334123-01M	N/A	NC-334123-01 Rev.C	2	N/A	1992
(5)	4CB	NC-334123-01N	N/A	NC-334123-01 Rev.C	2	N/A	1992
(6)	4CB	NC-334123-01P	N/A	NC-334123-01 Rev.C	2	N/A	1992
(7)	4CB	NC-334123-01R	N/A	NC-334123-01 Rev.C	2	N/A	1992
(8)	4CB	NC-334123-01S	N/A	NC-334123-01 Rev.C	2	N/A	1992
(9)							
(10)							

5. Emergency Service Water
(Brief description of service for which equipment was designed)

*Station, 5Mi NE of Berwick on U.S. RT11

6. Design Conditions Seat 177 125°
Body 275 100° °F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)
7. Cold Working Pressure 275 psi at 100°F.
8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
ASME-SA			
(1) RHD -30	351 Gr. CF8M	Southern Tool	Body
(2) RHD -19	351 Gr. CF8M	Southern Tool	Body
(3) RHD -15	351 Gr. CF8M	Southern Tool	Body
(4) RHD -61	351 Gr. CF8M	Southern Tool	Body
(5) RHD -74	351 Gr. CF8M	Southern Tool	Body
(6) RHD -57	351 Gr. CF8M	Southern Tool	Body
(7) RHD -69	351 Gr. CF8M	Southern Tool	Body
(8) RHD -73	351 Gr. CF8M	Southern Tool	Body
(b) Covers			
ASME-SA			
(1) RHS -17 & -41	351 Gr. CF3M	Southern Tool	Caps
(2) RHS -12 & -105	351 Gr. CF3M	Southern Tool	Caps
(3) RHS -20 & -119	351 Gr. CF3M	Southern Tool	Caps
(4) RHS -5 & -23	351 Gr. CF3M	Southern Tool	Caps
(5) RHS -34 & -82	351 Gr. CF3M	Southern Tool	Caps
(6) RHS -16 & -83	351 Gr. CF3M	Southern Tool	Caps
(7) RHS -10 & -31	351 Gr. CF3M	Southern Tool	Caps
(8) RHS -11 & -15	351 Gr. CF3M	Southern Tool	Caps

(1) For manually operated valves only.

PP4, Doc No 45

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name

Date June 15, 1992

 Two North Ninth St., Allentown, PA 18101
Address

Sheet 1 of 3

2. Plant Susquehanna Steam Electric Station
Name

Unit ONE

 PO Box 467, Berwick, PA 18603
Address

 DCP'S 89-3027 & 89-3028 WA'S C13578 C13579
WA'S C13574 C13580 C13572 C13573
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name

Type Code Symbol Stamp None

 Two North Ninth St., Allentown, PA 18101
Address

Authorization No. N/A

Expiration Date N/A

4. Identification of System HPCI PUMP ROOM COOLING SYSTEM 134E III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HRC-118-H4002	82	REPLACED (DELETED)	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-117-2	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-117-2	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-118-2	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-118-2	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-119-3	86	REPLACED	YES

7. Description of Work MODIFIED ESW PIPING AT HPCI PUMP ROOM COOLERS

8. Tests Conducted: Hydrostatic Pneumatic Other Nominal Operating Pressure Pressure 194 / 195 psi Test Temp. 74 / 66 °F (LOOP "A" / LOOP "B")

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE DATA REPORTS ATTACHED

Applicable Manufacturer's Data Reports to be attached

APPL. CODES: Piping = ASME III 1971 thru W'72 addenda with Code Case N316

Valves = ASME III 1974 (no addenda)

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed *SKUal* Date July 16 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 10-23-92 to 4-5-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

John J. Daubney Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992
 Sheet 2 of 3

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 DCP'S 89-3027 & 89-3028 WA'S C13578 C13579
 WA'S C13574 C13580 C13572 C13573
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System HPCI PUMP ROOM COOLING SYSTEM 134E III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-119-3	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-120-1	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-120-1	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-120-3	86	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-120-3	92	REPLACEMENT	NO
2" BALL VALVE (boundary change)	NELES-JAMESBURY	ND-328996-01N	N/A	1-11-117	92	REPLACEMENT (from 154A III)	YES
2" GLOBE VALVE (boundary change)	VOGT	39-215095	N/A	1-11-150	85	REPLACED (to 154A III)	YES
1/2" GLOBE VALVE	YARWAY	9935	N/A	1RV-FP-11174A	77	REPLACED	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01E	N/A	1RV-FP-11174A	92	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	9947	N/A	2RV-FP-11174A	77	REPLACED	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01F	N/A	2RV-FP-11174A	92	REPLACEMENT	YES

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992
 Sheet 3 of 3

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
 DCP'S 89-3027 & 89-3028 WA'S C13578 C13579
 WA'S C13574 C13580 C13572 C13573
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System HPCI PUMP ROOM COOLING SYSTEM 134E III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1/2" GLOBE VALVE	YARWAY	9932	N/A	1RV-FP-11174B	77	REPLACED	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01T	N/A	1RV-FP-11174B	92	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	9930	N/A	2RV-FP-11174B	77	REPLACED	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01U	N/A	2RV-FP-11174B	92	REPLACEMENT	YES



FORM NPV-1-N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section VIII, Div. 1

1. Manufactured by Neles-Jamesbury, Inc., 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)

2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)

3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric
(Name and Address)

4. Pump or Valve Ball Valve Nominal Inlet Size 2 Outlet Size 2
(Inch) (Inch)

(a) Model No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) NPTL Ed. No.	(g) Year Built
(1) R21	ND-328996-01J	N/A	ND-328996-01Rev. D	3	N/A	1992
(2) R21	ND-328996-01K	N/A	ND-328996-01Rev. D	3	N/A	1992
(3) R21	ND-328996-01M	N/A	ND-328996-01Rev. D	3	N/A	1992
(4) R21	ND-328996-01N	N/A	ND-328996-01Rev. D	3	N/A	1992
(5)						
(6) R21	ND-328996-01P	N/A	ND-328996-01Rev. D	3	N/A	1992
(7) R21	ND-328996-01R	N/A	ND-328996-01Rev. D	3	N/A	1992
(8) R21	ND-328996-01S	N/A	ND-328996-01Rev. D	3	N/A	1992
(9)						
(10)						

5. Emergency Service Water System
*Station, 5MI NE of Berwick on U.S. Mill
(Brief description of service for which equipment was designed)

6. Design Conditions Seat 177 1980
Body 275 1000 psi or Valve Pressure Class 150 (1)
(Proposed) (Temperature)

7. Cold Working Pressure 275 psi at 100°F.

8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Comments
(a) Castings			
	ASME-SA		
(1) RHV-1	351 Gr. CF8M	Pennsylvania Steel	Body
(2) RHV-6	351 Gr. CF8M	Pennsylvania Steel	Body
(3) RHW-5	351 Gr. CF8M	Pennsylvania Steel	Body
(4) RHT-1	351 Gr. CF8M	Pennsylvania Steel	Body
(5)			
(6) RHV-2	351 Gr. CF8M	Pennsylvania Steel	Body
(7) RHW-6	351 Gr. CF8M	Pennsylvania Steel	Body
(8) RHT-3	351 Gr. CF8M	Pennsylvania Steel	Body
(b) Forgings			
	ASME-SA		
(1) RKA-14	351 Gr. CF8M	Southern Tool	Segment
(2) RKA-21	351 Gr. CF8M	Southern Tool	Segment
(3) RKA-29	351 Gr. CF8M	Southern Tool	Segment
(4) RKA-1	351 Gr. CF8M	Southern Tool	Segment
(5)			
(6) RKA-15	351 Gr. CF8M	Southern Tool	Segment
(7) RKA-31	351 Gr. CF8M	Southern Tool	Segment
(8) RKA-27	351 Gr. CF8M	Southern Tool	Segment

No. 015-01551
RECORD PACKAGE
PAGE 10 OF 93

(1) For manually operated valves only.

*Supplemental information in the form of test sketches, or drawings may be used provided (1) also to 94 or 95, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of the form, and (4) each additional sheet shall be signed by the Certificate Holder and the ASME.

FORM NPV-1 (Back)

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting	ASME-SA		
8078476	193 Grade B7	Nova Machine	Hex Hd. Cap Screw (All Valves)
(d) Other Parts	ASME-SA		
(1) RKK-8	240 Type 316	Jessop Steel Co.	End Plate
(2) RKK-12	240 Type 316	Jessop Steel Co.	End Plate
(3) RKK-16	240 Type 316	Jessop Steel Co.	End Plate
(4) RKK-1	240 Type 316	Jessop Steel Co.	End Plate
(5)			
(6) RKK-9	240 Type 316	Jessop Steel Co.	End Plate
(7) RKK-18	240 Type 316	Jessop Steel Co.	End Plate
(8) RKK-14	240 Type 316	Jessop Steel Co.	End Plate

8. Hydraulic test 425 psi. Disk Differential test pressure _____ psi. HD-328996-01J, 01K, 01M, 01N, 01P, 01R, 01S

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1974.

Addenda None, Code Case No. None, Date 24 Feb 92

Signed Neles-Jamesbury, Inc. by Donald P. Parker

Our ASME Certificate of Authorization No. N-1228 to use the N symbol expires Oct. 27, 1993

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Two North Ninth St., Allentown
 Stress analysis report (Class T only) on file at PA 08101

Design specifications certified by (1) Frank J. Czysz

PE State PA Reg. No. PE-0250-49E

Stress analysis certified by (1) N/A

PE State N/A Reg. No. N/A

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the Engineer in Charge of Massachusetts and employed by Protection Mutual of Northwood, Massachusetts have inspected the pump, or valve, described in this Data Report on 2-26 1992, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-27 1992

NO. 95-0251
 RECORD PACKAGE
 PAGE 11

Factory Mutual Systems

(Part 52, Form, Prev. and Rev.)

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section VIII, Div. 1

1. Manufactured by Neles-Jamesbury, Inc., 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric *
(Name and Address)
4. Pump or Valve Ball Valve Nominal Inlet Size 1/2" Outlet Size 1/2"
(inch) (inch)

	(a) Model No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
	(1)	4CB	NC-334123-01A	N/A	NC-334123-01 Rev. C	2	N/A
(2)	4CB	NC-334123-01B	N/A	NC-334123-01 Rev. C	2	N/A	1992
(3)	4CB	NC-334123-01C	N/A	NC-334123-01 Rev. C	2	N/A	1992
(4)	4CB	NC-334123-01D	N/A	NC-334123-01 Rev. C	2	N/A	1992
(5)	4CB	NC-334123-01E	N/A	NC-334123-01 Rev. C	2	N/A	1992
(6)	4CB	NC-334123-01F	N/A	NC-334123-01 Rev. C	2	N/A	1992
(7)	4CB	NC-334123-01G	N/A	NC-334123-01 Rev. C	2	N/A	1992
(8)	4CB	NC-334123-01H	N/A	NC-334123-01 Rev. C	2	N/A	1992
(9)							
(10)							

5. Emergency Service Water
(Brief description of service for which equipment was designed)
- *Station, 5Mi NE of Berwick on U.S. RT11
6. Design Conditions Seat 177 125°
Body 275 100° psi 150 °F or Valve Pressure Class (1)
7. Cold Working Pressure 275 psi at 100°F.
8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
ASME-SA			
(1) RHD -5	351 Gr. CF8M	Southern Tool	Body
(2) RHD -48	351 Gr. CF8M	Southern Tool	Body
(3) RHD -32	351 Gr. CF8M	Southern Tool	Body
(4) RHD -17	351 Gr. CF8M	Southern Tool	Body
(5) RHD -55	351 Gr. CF8M	Southern Tool	Body
(6) RHD -38	351 Gr. CF8M	Southern Tool	Body
(7) RHD -53	351 Gr. CF8M	Southern Tool	Body
(8) RHD -4	351 Gr. CF8M	Southern Tool	Body
(b) Castings			
ASME-SA			
(1) RHS -9 & -13	351 Gr. CF3M	Southern Tool	Caps
(2) RHS -6 & -79	351 Gr. CF3M	Southern Tool	Caps
(3) RHS -33 & -36	351 Gr. CF3M	Southern Tool	Caps
(4) RHS -61 & -70	351 Gr. CF3M	Southern Tool	Caps
(5) RHS -112 & -155	351 Gr. CF3M	Southern Tool	Caps
(6) RHS -1 & -166	351 Gr. CF3M	Southern Tool	Caps
(7) RHS -14 & -73	351 Gr. CF3M	Southern Tool	Caps
(8) RHS -42 & -81	351 Gr. CF3M	Southern Tool	Caps

.. For manually operated valves only.

PP & L Doc No. 45

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section I, Div. 1

1. Manufactured by Neles-Jamesbury, Inc., 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric *
(Name and Address)
4. Pump or Valve Ball Valve . Nominal Inlet Size 1/2" (inch) Outlet Size 1/2" (inch)

(a) Model No. Series No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No	(e) Class	(f) Nat'l. Bd No.	(g) Year Built
(1)	4CB	NC-334123-01 T	N/A NC-334123-01 Rev.C	2	N/A	1992
(2)	4CB	NC-334123-01 U	N/A NC-334123-01 Rev.C	2	N/A	1992
(3)	4CB	NC-334123-01 W	N/A NC-334123-01 Rev.C	2	N/A	1992
(4)	4CB	NC-334123-01 X	N/A NC-334123-01 Rev.C	2	N/A	1992
(5)	4CB	NC-334123-01 Y	N/A NC-334123-01 Rev.C	2	N/A	1992
(6)	4CB	NC-334123-01 Z	N/A NC-334123-01 Rev.C	2	N/A	1992
(7)	4CB	NC-334123-01 AA	N/A NC-334123-01 Rev.C	2	N/A	1992
(8)	4CB	NC-334123-01 AB	N/A NC-334123-01 Rev.C	2	N/A	1992
(9)						
(10)						

5. Emergency Service Water
(Brief description of service for which equipment was designed)
- *Station, 5Mi NE of Berwick on U.S. RT11

6. Design Conditions Seat 177 125°
Body 275 100° *F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)
7. Cold Working Pressure 275 psi at 100°F.
8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
	ASME-SA		
(1)	RHD -36	351 Gr. CF8M	Southern Tool Body
(2)	RHD -76	351 Gr. CF8M	Southern Tool Body
(3)	RHD -35	351 Gr. CF8M	Southern Tool Body
(4)	RHD -62	351 Gr. CF8M	Southern Tool Body
(5)	RHD -28	351 Gr. CF8M	Southern Tool Body
(6)	RHD -68	351 Gr. CF8M	Southern Tool Body
(7)	RHD -44	351 Gr. CF8M	Southern Tool Body
(8)	RHD -24	351 Gr. CF8M	Southern Tool Body
(b) Castings			
	ASME-SA		
(1)	RHS -8 & -35	351 Gr. CF3M	Southern Tool Caps
(2)	RHS -25 & -26	351 Gr. CF3M	Southern Tool Caps
(3)	RHS -4 & -32	351 Gr. CF3M	Southern Tool Caps
(4)	RHS -7 & -28	351 Gr. CF3M	Southern Tool Caps
(5)	RHS -38 & -39	351 Gr. CF3M	Southern Tool Caps
(6)	RHS -40 & -56	351 Gr. CF3M	Southern Tool Caps
(7)	RHS -3 & -104	351 Gr. CF3M	Southern Tool Caps
(8)	RHS -18 & -37	351 Gr. CF3M	Southern Tool Caps

(1) For manually operated valves only.

PP&L Doc No. 45

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting	ASME-SA		
9E0947	194 Gr. 8	Nova Machine	Hex Nut (a)
9E0947	193 Gr. B8	Nova Machine	Hex HD. Cap
			*(all valves)
(d) Other Parts	ASME-SA		
RET	479 Type 316	Neles-Jamesbury	Ball (all valves)

9. Hydrostatic test 425 psi. Disk Differential test pressure _____ psi. NC-334123-01T, 01U, 01W, 01X, 01Y, 01Z, 01AA, 01AB

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1974
 Addenda NONE (Date), Code Case No. NONE Date 7 Feb. 92
 Signed Neles-Jamesbury, Inc. by Dwight Parker (N. Certificate holder)
 Our ASME Certificate of Authorization No. N-1228 to use the N symbol expires Oct. 27, 1993 (Date)

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Two North Ninth St., Allentown
 Stress analysis report (Class T only) on file at N/A PA 18101
 Design specifications certified by (1) Dale Stattar
 PE State PA Reg. No. PE 019525E
 Stress analysis certified by (1) N/A
 PE State N/A Reg. No. N/A
 (1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of MASS and employed by Protection Mutual of Norwood, Massachusetts have inspected the pump, or valve, described in this Data Report on 2-7 19 92, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.
 By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 2-7 19 92 [Signature] (Inspector)
 Commissions MA #1287 PAWC #2757
 (N.B. Bd., State, Prov. and No.)
 P.P.S. Doc. No. 45

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 13, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 2
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP's 88-3047 A & B / WA's C13472 & C13440
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A

4. Identification of System Reactor Building H & V System System 134E Class III

5. (a) Applicable Construction See Remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

Room Cooler Flex Hose	Anamet	N/A	N/A	1E229A Supply Hose	'87	Replaced	No
Room Cooler Flex Hose	Anamet	N/A	N/A	1E229A Supply Hose	'90	Replacement	No
Room Cooler Flex Hose	Anamet	N/A	N/A	1E229B Supply Hose	'87	Replaced	No
Room Cooler Flex Hose	Anamet	N/A	N/A	1E229B Supply Hose	'90	Replacement	No
HPCI Room Cooler Coil	Aerofin	N/A	N/A	1E229A	'74	Replaced	No
HPCI Room Cooler Coil	Aerofin	900612	N/A	1E229A	'90	Replacement	Yes

7. Description of Work Replace the cooling coils and the ESW Supply flex hoses at HPCI Room Coolers 1V-209 A & B

8. Tests Conducted: Other Pneumatic Nominal Operating Pressure Pressure 120 psi Test Temp. 73 (A) / 60 (B) °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE DATA REPORT(S) ATTACHED

Applicable Manufacturer's Data Reports to be attached

Applicable Construction Code: ASME VIII 1986 Edition , Code Case 1997-2 (Coils)

ANSI B31.1 1973 (Hoses)

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and REPLACEMENT conforms to the rules of the
 this repair or replacement
 ASME Code, Section XI.

Type Code Symbol N/A
 Stamp

Certificate of Authorization N/A Expiration N/A
 No. Date

Signed S. M. A. Date July 16, 1992
 Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
 or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO.
 of WALTHAM, MASSACHUSETTS have inspected the components
 described
 in this Owner's Report during the period 10-23-92 to 4-5-92, and state that
 to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in
 this

Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
 examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
 shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with
 this
 inspection.

D. J. Daulton Commissions NB 7525 PA 2159 NI
 Inspector's Signature National Board, State, Province, and

DATE JULY / 22 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date May 13, 1992
 Sheet 2 of 2

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
DCP's 88-3047 A & B / WA's C13472 & C13440
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol None
 Authorization N/A
 Expiration Date N/A

4. Identification of System Reactor Building H & V System System 134E Class III

5. (a) Applicable Construction See Remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
HPCI Room Cooler Coil	Aerofin	N/A	N/A	1E229B	'74	Replaced	No
HPCI Room Cooler Coil	Aerofin	900613	N/A	1E229B	'90	Replacement	Yes



FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

NOI-QA-2.4.7
DSR #45

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3. Location of Installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4. Type Heat Exchanger 900612 -- BM-R-15, N-R-4 -- 1990
(Name or type, tank) (Mfr's serial No.) (CRN) (Drawing) (Mfr's Id. No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1. 1986
Year

-- 1997-2 --
Addenda (Mfr's) Code Case No. Special service per UG 120(d)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell SA-240, T-316L 1.5" -- 0'-7.5" 2'-9 1/2"
(Matl. Spec. No., Grade) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

7. Seams: -- -- -- --
Long (Dw., Sngl.) R.T. (Spot or Full) Ell. (ft.) H.T. Temp. (°F)
-- -- -- --
Time Girth (Dw., Sngl.) R.T. (Spot, Partial, or Full) No. of Courses

8. Heads: (a) Matl. -- (Spec. No., Grade) (b) Matl. -- (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	--	--	--	--	--	--	--	--	--	--
(b)	--	--	--	--	--	--	--	--	--	--

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8
(Matl. Spec. No., Gr., Size No.)

9. Type of Jacket -- Proof Test --

10. Jacket Closure -- If bar, give dimensions -- If bolted, describe or sketch. (Describe as open & weld, bar, etc.)

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi. Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 7.5" .75" -- Bolted
(Stationary Matl. (Spec. No., Gr.)) (Diam. (in.) (Subject to pressure)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) Attach (Welded Bolted)

-- -- -- -- --
(Floating Matl. (Spec. No., Gr.)) (Diam. (in.)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) Attach

13. Tubes: SB-676, Class 2 .625" .049" 90 Straight
(Matl. (Spec. No., Gr.)) (O.D. (in.)) (Nom. Thk. (in. or Gauge)) (Number) Type (Straight or U)

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: -- -- -- -- --
(Matl. (Spec. No., Grade)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

15. Seams: -- -- -- --
Long (Dw., Sngl.) R.T. (Spot or Full) Ell. (ft.) H.T. Temp. (°F)
-- -- -- --
Time Girth (Dw., Sngl.) R.T. (Spot, Partial, or Full) No. of Courses

16. Heads: (a) Matl. -- (Spec. No., Grade) (b) Matl. -- (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)										
(b)										

If removable, bolts used (describe other fastenings) --
(Matl. Spec. No., Gr., Size No.)

17. MAWP -- psi at max. temp. -- °F. Min. design metal temp. -- °F at -- psi. Hydro., pneu., or comb. test press. -- psi.

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings

Purpose (Inlet Outlet Drain etc.)	No.	Dim. or Size	Type	Matl.	Spec. Thk.	Reinforcement Meth.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	3	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19. Supports: Skirt No Lugs --- Legs --- Other --- Attached ---
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number, mfg's name and identifying stamp)
IR-2872 () Mark: BECO Item #13, PO # 88-43433-1, For HPCI Pump Room, 75 PC/Adjustax, Coil Tag # 1E229A, Unit Cooler 1V209A, Furnished on 89326773(74S-4883), Item #3 DCP No. 86-2047

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.
 "U" Certificate of Authorization No. 2916 expires December 9, 1992
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed Berry Wheat
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance of Norwood, Massachusetts have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 18, 1990, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 6/29/90 Signed [Signature] Commissions VA 682 PAWCO3567
(Authorized Inspector) *Factory Mutual System (Not Bonded, State, Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.
 "U" Certificate of Authorization No. _____ expires _____, 19_____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (By Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____ of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ Signed _____ Commissions _____
(Authorized Inspector) (Not Bonded, State, Province and No.)

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

NPI-QA-2.4.7 C
DSR #45

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

2. Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3. Location of installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4. Type Heat Exchanger 900613 -- BM-R-15,N-R-4 -- 1990
(Name or code, title) (Mfg. serial No.) (CRN) (Drawing) (Shell No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Year

-- 1997-2 --
Addenda (Ref.) Code Case No. Special permits per UG 120(c)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" -- 0'-7.5" 2'-9 1/2"
(Matl. (Spec. No., Grade)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

7. Seams: -- -- -- -- --
(Long. (Del., Eng.)) (R.T. (Spot or Full)) (EH (ft.)) (H.T. Temp. (°F))
-- -- -- -- --
(Time) (Girth (Del., Eng.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

8. Heads: (a) Matl. -- (Spec. No., Grade) (b) Matl. -- (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	--	--	--	--	--	--	--	--	--	--
(b)	--	--	--	--	--	--	--	--	--	--

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8
(Matl. Spec. No., Gr. Size No.)

9. Type of Jacket Proof Test

10. Jacket Closure Proof Test If bar, give dimensions Proof Test If bolted, describe or sketch.

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi
Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 7.5" .75" -- Bolted
(Stationary Matl. (Spec. No., Gr.)) (Diam. (in.) (Subject to pressure)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Attach (Welded Bolted))
SB-688 7.5" .75" -- Bolted
(Floating Matl. (Spec. No., Gr.)) (Diam. (in.)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Attach)

13. Tubes: SB-676, Class 2 .625" .049" 90 Straight
(Matl. (Spec. No., Gr.)) (O.D. (in.)) (Nom. Thk. (in. or Gauge)) (Number) (Type (Straight or "U"))

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: -- -- -- -- --
(Matl. (Spec. No., Grade)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

15. Seams: -- -- -- -- --
(Long. (Del., Eng.)) (R.T. (Spot or Full)) (EH (ft.)) (H.T. Temp. (°F))
-- -- -- -- --
(Time) (Girth (Del., Eng.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

16. Heads: (a) Matl. -- (Spec. No., Grade) (b) Matl. -- (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	--	--	--	--	--	--	--	--	--	--
(b)	--	--	--	--	--	--	--	--	--	--

If removable, bolts used (describe other fastenings) Proof Test
(Matl. Spec. No., Gr., Size No.)

17. MAWP Proof Test psi at max. temp. Proof Test °F. Min. design metal temp. Proof Test °F at Proof Test psi.
Hydro., pneu., or comb. test press. Proof Test psi.

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	diam. or Size	Type	Matl.	Wt. Lbs.	Reattachment Meth.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	3	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19. Supports: Skirt No Lug --- Legs --- Other --- Attached ---
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number, mfg's name and identifying stamp)

TR-2873 (1) Mark: - BECO Item #14, PO # 88-43433-1, For HPCI Pump Room, 75 PC/Adjustay, Coil Tag No. 1E229B, Unit Cooler 1V209B, Furnished on 89326774(74S-4883), Item #3 DCP No. 88-3047

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 19 92
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed [Signature]
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance

of Norwood, Massachusetts have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 20, 19 90, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6/29/90 Signed [Signature] Commissions VA 682, PAWCO3567
(Authorized Inspector) *Factory Mutual System (Not a Board State Province and No)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19 _____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (R Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (Not a Board Local endorsement, State Prov. and No)

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date July 20, 1992
Sheet 1 of 4

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
Authorization No. N/A
Expiration Date N/A

4. Identification of System RCIC PUMP ROOM COOLING System 134F Class III

5. (a) Applicable Construction Code See Remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Room Cooler Flex Hoses (2)	Anamet	N/A	N/A	1E-228A (supply and return)	1987	replaced	No
Room Cooler Flex Hoses (2)	Anamet	N/A	N/A	1E-228A (supply and return)	1990	replacement	No
Room Cooler Flex Hoses (2)	Anamet	N/A	N/A	1E-228B (supply and return)	1987	replaced	No
Room Cooler Flex Hoses (2)	Anamet	N/A	N/A	1E-228B (supply and return)	1990	replacement	No
Room Cooler Coil	Aerofin	N/A	N/A	1E-228A	1974	replaced	No
Room Cooler Coil	Aerofin	900608	N/A	1E-228A	1990	replacement	Yes

7. Description of Work Replaced coils & flex hoses, and modified ESW piping at RCIC Pump Room Coolers.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure ←Coils (120 psi @ 60°F)
Other Pressure 194 / 195 psi Test Temp. 74 / 66 °F (LOOP "A" / LOOP "B")

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Construction Codes are as follows: flex hoses - ANSI B31.1 1973 Edition No Addenda,
Applicable Manufacturer's Data Reports to be attached
cooling coils - ASME VIII 1986 Edition No Addenda with Code Case 1997-2, piping - ASME III 1971 W72
with Code Case N316. valves - ASME III 1974 (no addenda). Code data reports are attached.
DCP's = 88-3045A & B, 89-3027, 89-3028

WA'S = C13381, C13382, C13575, C13582, C13572, C13573, C13578, C13579

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A _____

Signed EKStal Date July 21, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of
WALTHAM, MASSACHUSETTS have inspected the components described
in this Owner's Report during the period 6-5-91 to 3-23-92, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection

David Buller Commissions NB 7525 PA 2159 NJ
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name

Date June 15, 1992

 Two North Ninth St., Allentown, PA 18101
Address

Sheet 2 of 4

2. Plant Susquehanna Steam Electric Station
Name

Unit ONE

 PO Box 467, Berwick, PA 18603
Address

 SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name

Type Code Symbol Stamp None

 Two North Ninth St., Allentown, PA 18101
Address

Authorization No. N/A

Expiration Date N/A

4. Identification of System RCIC PUMP ROOM COOLING System 134F Class III

5. (a) Applicable Construction Code See Remarks 19 Edition, Addenda, Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

Room Cooler Coil	Aerofin	N/A	N/A	1E-228B	1974	replaced	No
Room Cooler Coil	Aerofin	900609	N/A	1E-228B	1990	replacement	Yes
Pipe Support	Bechtel	N/A	N/A	SP-HRC-118-H2002	1982	replaced (deleted)	No
Small Pipe Sub-assembly	Bechtel	N/A	N/A	SP-HRC-117-1	1982	replaced	Yes
Small Pipe Sub-assembly	PP&L	N/A	N/A	SP-HRC-117-1	1992	replacement	No
Small Pipe Sub-assembly	Bechtel	N/A	N/A	SP-HRC-118-1	1982	replaced	Yes
Small Pipe Sub-assembly	PP&L	N/A	N/A	SP-HRC-118-1	1992	replacement	No
Small Pipe Sub-assembly	Bechtel	N/A	N/A	SP-HRC-119-5	1982	replaced	Yes
Small Pipe Sub-assembly	PP&L	N/A	N/A	SP-HRC-119-5	1992	replacement	No
Small Pipe Sub-assembly	Bechtel	N/A	N/A	SP-HRC-120-2	1982	replaced	Yes
Small Pipe Sub-assembly	PP&L	N/A	N/A	SP-HRC-120-2	1992	replacement	No

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992

Sheet 3 of 4

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE

 SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A


Expiration Date N/A

4. Identification of System RCIC PUMP ROOM COOLING System 134F Class III

5. (a) Applicable Construction Code See Remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Small Pipe Sub-assembly	Bechtel	N/A	N/A	SP-HRC-120-5	1982	replaced	Yes
Small Pipe Sub-assembly	PP&L	N/A	N/A	SP-HRC-120-5	1992	replacement	No
2" Ball Valve (boundary change)	Neles-Jamesbury	ND-328996-01F	N/A	1-11-121	1992	replacement (from 154A III)	Yes
2" Globe Valve (boundary change)	Vogt	36-215095	N/A	1-11-151	1985	replaced (to 154A III)	Yes
1/2" Globe Valve	Yarway	9918	N/A	1RV-FP-11178A	1977	replaced	Yes
1/2" Ball Valve	Neles-Jamesbury	NC-334123-01G	N/A	1RV-FP-11178A	1992	replacement	Yes
1/2" Globe Valve	Yarway	9921	N/A	2RV-FP-11178A	1977	replaced	Yes
1/2" Ball Valve	Neles-Jamesbury	NC-334123-01H	N/A	2RV-FP-11178A	1992	replacement	Yes
1/2" Globe Valve	Yarway	9931	N/A	1RV-FP-11178B	1977	replaced	Yes
1/2" Ball Valve	Neles-Jamesbury	NC-334123-01W	N/A	1RV-FP-11178B	1992	replacement	Yes
1/2" Globe Valve	Yarway	9965	N/A	2RV-FP-11178B	1977	replaced	Yes



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992

Sheet 4 of 4

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A


Expiration Date N/A

4. Identification of System RCIC PUMP ROOM COOLING System 134F Class III

5. (a) Applicable Construction Code See Remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1/2" Ball Valve	Neles-Jamesbury	NC-334123-01X	N/A	2RV-FP-11178B	1992	replacement	Yes



FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

NOI-QA-247
OSR #45

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)
Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)
3. Location of installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)
4. Type Heat Exchanger 900608 BM-R-15,N-R-4 1990
(Material, shell) (Mfg. name No.) (CRN) (Drawing) (Mfg. No.) (Year built)
5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
1997-2
(ASME Code) (Code Case No.) (Special Order per UG 120(d))

Items 6-11 incl to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers
6. Shell: SA-240, T-316L 1.5" 0'-10" 1'-9 1/2"
(Matl. (Spec. No., Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))
7. Seams: --- --- --- ---
(Long. (Dbl., Sngl.)) (RT. (Spot or Full)) (SH (ft)) (HT. Temp. (°F))
(Time) (Gr. (Dbl., Sngl.)) (RT. (Spot, Partial, or Full)) (No. of Courses)

8. Heads: (a) Matl. --- (Spec. No., Grade) (b) Matl. --- (Spec. No., Grade)

	Location (Top Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	---	---	---	---	---	---	---	---	---	---
(b)	---	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. 8BM; with 5/8" nuts of SA-194 Gr. 8
(Matl. Spec. No., Gr., Size No.)

9. Type of Jacket --- Proof Test ---
10. Jacket Closure --- If burr, give dimensions --- If bolted, describe or sketch ---
(Describe as edges & weld, bar, etc.)
11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi.
Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections
12. Tubesheets: SB-688 10" .75" Bolted
(Stationary Matl. (Spec. No., Gr.)) (Diam. (in) (Subject to pressure)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach. (Welded, Bolted))
--- --- --- ---
(Floating Matl. (Spec. No., Gr.)) (Diam. (in)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach.)

13. Tubes: SB-676, Class 2 .625" .049" 66 Straight
(Matl. (Spec. No., Gr.)) (O.D. (in)) (Nom. Thk. (in or Gauge)) (Number) (Type (Straight or U))

Items 14-17 incl to be completed for inner chambers of jacketed vessels or channels of heat exchangers
14. Shell: --- --- --- --- ---
(Matl. (Spec. No., Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))
15. Seams: --- --- --- ---
(Long. (Dbl., Sngl.)) (RT. (Spot or Full)) (SH (ft)) (HT. Temp. (°F))
(Time) (Gr. (Dbl., Sngl.)) (RT. (Spot, Partial, or Full)) (No. of Courses)

16. Heads: (a) Matl. --- (Spec. No., Grade) (b) Matl. --- (Spec. No., Grade)

	Location (Top Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	---	---	---	---	---	---	---	---	---	---
(b)	---	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) ---
(Matl. Spec. No., Gr., Size No.)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- psi.
Hydro., pneu., or comb. test press. --- psi.

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Size or Size	Type	Mat.	Wgt. Tol.	Reinforcement Mat.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
VENTS	2	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	4	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19 Supports: Skirt No Lugs --- Legs --- Other --- Attached ---
(Yes or No) (No) (Yes) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number, size, name and identifying stamp)

TR-2868 (1) Mark: BFCO Item #9, PO# 8-43433-1, Item 2, DCP# 88-3045, For RCIC Pump Room, 60 PC/Adjustax, Coil Tag# 1E228A Unit Cooler 1V208A, Furnished on 89326769, (74S-4880)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 19 92
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed Barry Alford
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance

of Norwood, Massachusetts have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 21, 19 90, and state that, to the best of my knowledge and belief, the Manufacturer has constructed the

pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6/28/90 Signed [Signature] Commissions VA 682 Pwcc03567
(Authorized Inspector) (*Factory Mutual System) (National Board, State, Provincial and No. 1)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19 _____
 Date _____ Co. name _____
(A number that certified and constructed field assembly) (Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as Data Items _____, not included in the

certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (National Board and endorsement) State, Provincial and No. 1

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

NDI-QA-2.4.7
OSR #45

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3. Location of installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4. Type Heat Exchanger 900609 --- BM-R-15,N-R-4 --- 1990
(Name or type) (Mfg. serial No.) (CRN) (Drawing) (Mfg. Bd. No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Year

--- 1997-2 ---
Addenda (Date) Code Case No. Special orders per UG 120(a)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" --- 0'-10" 1'-9 1/2"
(Matl. Spec. No., Grade) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

7. Seams: --- --- --- --- ---
(Long. IDW., Spt.) (R.T. (Spot or Full)) (EN (in)) (M.T. Temp. (°F))

--- --- --- --- ---
(Time) (Grth IDW., Spt.) (R.T. (Spot, Partial, or Full)) (No. of Courses)

8. Heads: (a) Matl. --- (Spec. No., Grade) (b) Matl. --- (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	---	---	---	---	---	---	---	---	---	---
(b)	---	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8
(Matl., Spec. No., Gr., Size, No.)

Type of Jacket --- Proof Test ---

10. Jacket Closure --- If bar, give dimensions --- If bolted, describe or sketch. (Describe as edge & weld, bar, etc.)

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi
Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tube sheets: SB-688 10" .75" --- Bolted
(Stationary Matl. (Spec. No., Gr.)) (Diam. (in) (Subject to pressure)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach (Welded Bolted))

--- --- --- --- ---
(Floating Matl. (Spec. No., Gr.)) (Diam. (in)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach)

13. Tubes: SB-676, Class 2 .625" .049" 66 Straight
(Matl. (Spec. No., Gr.)) (OD (in)) (Nom. Thk. (in or Gauger)) (Number) (Type: Straight or U)

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: --- --- --- --- ---
(Matl. (Spec. No., Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

15. Seams: --- --- --- --- ---
(Long. IDW., Spt.) (R.T. (Spot or Full)) (EN (in)) (M.T. Temp. (°F))

--- --- --- --- ---
(Time) (Grth IDW., Spt.) (R.T. (Spot, Partial, or Full)) (No. of Courses)

16. Heads: (a) Matl. --- (Spec. No., Grade) (b) Matl. --- (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)										
(b)										

If removable, bolts used (describe other fastenings) ---
(Matl., Spec. No., Gr., Size, No.)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- psi
Hydro., pneu., or comb. test press. --- psi.

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diame. or Size	Type	Matl.	Wt. Lbs.	Reinforcement Matl.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
VENTS	2	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	4	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19 Supports: Skirt No Lugs -- Legs -- Other -- Attached --
(Yes or No) (No) (No) (Describe) (Where and how)

20 Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report.

TR-28 69 (1) Mark: BFCO Item # 1Q PO# 8-43433-1, Item 2, DCP# 88-3045, For RCIC Pump Room, 60 PC/Adjustax, Coil Tag# 1E228B Unit Cooler 1V208B, Furnished on 89326770, (74S-4880)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 1992
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed [Signature]
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance

of Norwood, Massachusetts have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 21, 1990, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6/29/90 Signed [Signature] Commissions VA 682, PAWCO3567
(Authorized Inspector) (*Factory Mutual System) (Not Board State, Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19_____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (By Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (Not Board State, Province and No.)

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Neles-Jamesbury, Inc., 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric *
(Name and Address)
4. Pump or Valve Ball Valve Nominal Inlet Size 1/2" Outlet Size 1/2"
(inch) (inch)

	(a) Model No. Series No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No	(e) Class	(f) Nat'l. Bd No.	(g) Year Built
(1)	4CB	NC-334123-01 T	N/A	NC-334123-01 Rev.C	2	N/A	1992
(2)	4CB	NC-334123-01 U	N/A	NC-334123-01 Rev.C	2	N/A	1992
(3)	4CB	NC-334123-01 W	N/A	NC-334123-01 Rev.C	2	N/A	1992
(4)	4CB	NC-334123-01 X	N/A	NC-334123-01 Rev.C	2	N/A	1992
(5)	4CB	NC-334123-01 Y	N/A	NC-334123-01 Rev.C	2	N/A	1992
(6)	4CB	NC-334123-01 Z	N/A	NC-334123-01 Rev.C	2	N/A	1992
(7)	4CB	NC-334123-01 AA	N/A	NC-334123-01 Rev.C	2	N/A	1992
(8)	4CB	NC-334123-01 AB	N/A	NC-334123-01 Rev.C	2	N/A	1992
(9)							
(10)							

5. Emergency Service Water
*Ref (description of service for which equipment was designed)
*Station, 5Mi NE of Berwick on U.S. RT11
6. Design Conditions Seat 177 125°
Body 275 100° psi °F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)
7. Cold Working Pressure 2.75 psi at 100°F.
8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
(1) RHD -36	ASME-SA 351 Gr. CF8M	Southern Tool	Body
(2) RHD -76	351 Gr. CF8M	Southern Tool	Body
(3) RHD -35	351 Gr. CF8M	Southern Tool	Body
(4) RHD -62	351 Gr. CF8M	Southern Tool	Body
(5) RHD -28	351 Gr. CF8M	Southern Tool	Body
(6) RHD -68	351 Gr. CF8M	Southern Tool	Body
(7) RHD -44	351 Gr. CF8M	Southern Tool	Body
(8) RHD -24	351 Gr. CF8M	Southern Tool	Body
(b) Castings			
(1) RHS -8 & -35	ASME-SA 351 Gr. CF3M	Southern Tool	Caps
(2) RHS -25 & -26	351 Gr. CF3M	Southern Tool	Caps
(3) RHS -4 & -32	351 Gr. CF3M	Southern Tool	Caps
(4) RHS -7 & -28	351 Gr. CF3M	Southern Tool	Caps
(5) RHS -38 & -39	351 Gr. CF3M	Southern Tool	Caps
(6) RHS -40 & -56	351 Gr. CF3M	Southern Tool	Caps
(7) RHS -3 & -104	351 Gr. CF3M	Southern Tool	Caps
(8) RHS -18 & -37	351 Gr. CF3M	Southern Tool	Caps

(1) For manually operated valves only.

PPSL Doc No. 45

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting	ASME-SA		
9E0947	194 Gr. 8	Nova Machine	Hex Nut (all)
9E0947	193 Gr. 8B	Nova Machine	Hex HD. Cap
			*(all valves)
(d) Other Parts	ASME-SA		
RET	479 Type 316	Neles-Jamesbury	Ball (all valves)

9. Hydrostatic test 425 psi. Disk Differential test pressure _____ psi. NC-334123-01T, 01U, 01W, 01X, 01Y, 01Z, 01AA, 01AB

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1974
 Addenda NONE (Date), Code Case No. NONE Date 7 Feb. 92
 Signed Neles-Jamesbury, Inc. by Dwight Parker (N. Certificate Holder)
 Our ASME Certificate of Authorization No. N-1228 to use the N symbol expires Oct. 27, 1993 (Date)

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Two North Ninth St., Allentown
 Stress analysis report (Class T-only) on file at N/A PA 18101
 Design specifications certified by (1) Dale Stattar
 PE State PA Reg. No. PE 019525E
 Stress analysis certified by (1) N/A
 PE State N/A Reg. No. N/A
 (1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of MASS and employed by Protection Mutual of Norwood, Massachusetts have inspected the pump, or valve, described in this Data Report on 2-7 19 92, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-7 19 92
[Signature]
 (Inspector) Commissions MA #1287 PAWC #2757
 (NUT Bd., State, Prov. and No.)
 PPL Doc No: 45

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
 As Required by the Provisions of the ASME Code, Section VIII, Div. 1

1. Manufactured by Neles-Jamesbury, Inc., 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric *
(Name and Address)
4. Pump or Valve Ball Valve Nominal Inlet Size 1/2" Outlet Size 1/2"
(inch) (inch)

(a) Model No. Series No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built	
(1)	4CB	NC-334123-01A	N/A	NC-334123-01 Rev.C	2	N/A	1992
(2)	4CB	NC-334123-01B	N/A	NC-334123-01 Rev.C	2	N/A	1992
(3)	4CB	NC-334123-01C	N/A	NC-334123-01 Rev.C	2	N/A	1992
(4)	4CB	NC-334123-01D	N/A	NC-334123-01 Rev.C	2	N/A	1992
(5)	4CB	NC-334123-01E	N/A	NC-334123-01 Rev.C	2	N/A	1992
(6)	4CB	NC-334123-01F	N/A	NC-334123-01 Rev.C	2	N/A	1992
(7)	4CB	NC-334123-01G	N/A	NC-334123-01 Rev.C	2	N/A	1992
(8)	4CB	NC-334123-01H	N/A	NC-334123-01 Rev.C	2	N/A	1992
(9)							
(10)							

5. Emergency Service Water
(Brief description of service for which equipment was designed)
*Station, 5Mi NE of Berwick on U.S. RT11
6. Design Conditions Seat 177 125° Body 275 100° psi °F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)
7. Cold Working Pressure 275 psi at 100°F.
8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings ASME-SA			
(1) RHD -5	351 Gr. CF8M	Southern Tool	Body
(2) RHD -48	351 Gr. CF8M	Southern Tool	Body
(3) RHD -32	351 Gr. CF8M	Southern Tool	Body
(4) RHD -17	351 Gr. CF8M	Southern Tool	Body
(5) RHD -55	351 Gr. CF8M	Southern Tool	Body
(6) RHD -38	351 Gr. CF8M	Southern Tool	Body
(7) RHD -53	351 Gr. CF8M	Southern Tool	Body
(8) RHD -4	351 Gr. CF8M	Southern Tool	Body
(b) Covers ASME-SA			
(1) RHS -9 & -13	351 Gr. CF3M	Southern Tool	Caps
(2) RHS -6 & -79	351 Gr. CF3M	Southern Tool	Caps
(3) RHS -33 & -36	351 Gr. CF3M	Southern Tool	Caps
(4) RHS -61 & -70	351 Gr. CF3M	Southern Tool	Caps
(5) RHS -112 & -155	351 Gr. CF3M	Southern Tool	Caps
(6) RHS -1 & -166	351 Gr. CF3M	Southern Tool	Caps
(7) RHS -14 & -73	351 Gr. CF3M	Southern Tool	Caps
(8) RHS -42 & -81	351 Gr. CF3M	Southern Tool	Caps

For manually operated valves only.

PP & L Doc No. 45

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting	ASME-SA		
9E0947	194 Gr. 8	Nova Machine	Hex Nut (all valves)
9E0947	193 Gr. B8	Nova Machine	Hex HD. Cap * *(all valves)
(d) Other Parts	ASME-SA		
RET	479 Type 316	Neles-Jamesbury	Ball (all valves)

9. Hydrostatic test 425 psi. Disk Differential test pressure _____ psi. NC-334123-01A, 01B, 01C, 01D, 01E, 01F, 01G, 01H

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1974.

Addenda NONE (Date), Code Case No. NONE, Date 7 Feb 92

Signed Neles-Jamesbury, Inc. by Danilo P. Becker
(N Certificate Holder)

Our ASME Certificate of Authorization No. N-1228 to use the N symbol expires Oct. 27, 1993
(N) (Date)

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Two North Ninth St., Allentown PA 18101

Stress analysis report (Class T only) on file at N/A

Design specifications certified by (1) Dale Stattar
PE State PA Reg. No. PE 019525E

Stress analysis certified by (1) N/A
PE State N/A Reg. No. N/A

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of MAS and employed by Protection Mutual of Norwood, Massachusetts have inspected the pump, or valve, described in this Data Report on 2-7 19 92, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-7 19 92 Commissions MA # 1287 PAWC # 2757
[Signature] (Inspector) (NBT Bd. State. Prev. and No.)

PP/LDC NO: 45

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES
As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Neles-Jamesbury, Inc., 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)

2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)

3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric *
(Name and Address)

4. Pump or Valve Ball Valve . Nominal Inlet Size 2 (inch) . Outlet Size 2 (inch)

(a) Model No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Start. Dt. No.	(g) Year Built
(1) R21	ND-328996-01A	N/A	ND-328996-01Rev. D	3	N/A	1992
(2) R21	ND-328996-01B	N/A	ND-328996-01Rev. D	3	N/A	1992
(3)						
(4)						
(5) R21	ND-328996-01E	N/A	ND-328996-01Rev. D	3	N/A	1992
(6) R21	ND-328996-01F	N/A	ND-328996-01Rev. D	3	N/A	1992
(7) R21	ND-328996-01G	N/A	ND-328996-01Rev. D	3	N/A	1992
(8)						
(9)						
(10)						

5. Emergency Service Water System
(Brief description of service for which equipment was designed)
*Station, 5MI NE of Berwick on U.S. RT11

6. Design Conditions Seat 177 1980 °F or Valve Pressure Class 150 (1)
Body 275 1000 °F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)

7. Cold Working Pressure 275 psi at 100°F.

8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
	ASME-SA		
(1)	RHJ-5 351 Gr. CF8M	Pennsylvania Steel	Body
(2)	RHV-5 351 Gr. CF8M	Pennsylvania Steel	Body
(3)			
(4)			
(5)	RHT-2 351 Gr. CF8M	Pennsylvania Steel	Body
(6)	RHV-4 351 Gr. CF8M	Pennsylvania Steel	Body
(7)	RHU-6 351 Gr. CF8M	Pennsylvania Steel	Body
(b) Forgings			
	ASME-SA		
(1)	KKA-7 351 Gr. CF8M	Southern Tool	Segment
(2)	KKA-19 351 Gr. CF8M	Southern Tool	Segment
(3)			Segment
(4)			
(5)	351 Gr. CF8M	Southern Tool	Segment
(6)	KKA-16 351 Gr. CF8M	Southern Tool	Segment
(7)	KKA-13 351 Gr. CF8M	Southern Tool	Segment

(1) For manually operated valves only.

NO RECORD PACKAGE PAGE 2 OF 3

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) such is not in excess of 10% of the information in items 1 through 4 on this Data Report is included on each sheet, (2) each sheet is numbered and the number of sheets is recorded on the top of this form, and (3) each additional sheet shall be signed by the Certificate Holder and the ASME.

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
8078476	ASME-SA 193 Grade B7	Nova Machine	Hex Hd. Cap Screw (All Valves)
(d) Other Parts			
(1) RKK-6	ASME-SA 240 Type 316	Jessop Steel Co.	End Plate
(2) RKK-11	240 Type 316	Jessop Steel Co.	End Plate
(3)			
(4)			
(5) RKK-2	240 Type 316	Jessop Steel Co.	End Plate
(6) RKK-10	240 Type 316	Jessop Steel Co.	End Plate
(7) RKK-7	240 Type 316	Jessop Steel Co.	End Plate

8. Hydrostatic test 425 psi. Disk Differential test pressure _____ psi. ND-328996-01A, 01B, 01E, 01F, 01G.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1974.
 Addenda None, Code Case No. None, Date 24 Feb 92
 Signed Neles-Jamesbury, Inc. by Donald P. Parker
 Our ASME Certificate of Authorization No. N-1228 to use the N symbol expires Oct. 27, 1993

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Two North Ninth St., Allentown
 Stress analysis report (Class T only) on file at PA 08101
 Design specifications certified by (1) Frank J. Ceyez
 PE State PA Reg. No. PE-0250-49E
 Stress analysis certified by (1) N/A
 PE State PA Reg. No. N/A
 (1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors
 State or Province of Massachusetts and employed by Protection Mutual
 of Worwood, Massachusetts have inspected the pump, or valve, described in this Data Report on
2-26 19 92, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.
 By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 2-27 19 92
[Signature]
 (Inspector)
 No. 95-022
 RECORD PACKAGE
 PAGE 1
 Factory Mutual Systems
1414-1301
 (Part No., Date, Prev. and No.)

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992
 Sheet 1 of 7

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
 SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System RHR PUMP ROOM COOLING SYSTEM 134G CLASS III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
ROOM COOLER FLEX HOSES (4)	ANAMET	N/A	N/A	1E-230A SUP. AND RETURN	87	REPLACED	NO
ROOM COOLER FLEX HOSES (4)	ANAMET	N/A	N/A	1E-230A SUP. AND RETURN	90	REPLACEMENT	NO
ROOM COOLER FLEX HOSES (2)	ANAMET	N/A	N/A	1E-230C SUP.	87	REPLACED	NO
ROOM COOLER FLEX HOSES (2)	ANAMET	N/A	N/A	1E-230C SUP.	90	REPLACEMENT	NO
ROOM COOLER FLEX HOSES (4)	ANAMET	N/A	N/A	1E-230B SUP. AND RETURN	87	REPLACED	NO
ROOM COOLER FLEX HOSES (4)	ANAMET	N/A	N/A	1E-230B SUP. AND RETURN	90	REPLACEMENT	NO

7. Description of Work Replaced coils & ESW flex hoses, and modified ESW piping at RHR Pump Room Coolers.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure ← COILS(125@57°F/135@55°F)
 Other Pressure 194 / 195 psi Test Temp. 74 / 66 °F (LOOP "A" / LOOP "B")

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE DATA REPORTS ATTACHED.

Applicable Manufacturer's Data Reports to be attached

DCP's 88-3049A & B, 89-3027, 89-3028 WA's C13548 C13549 C13550 C13551 C13577 C13583

Appl. codes: Hoses = ANSI B31.1 1973 Coils = ASME VIII 1986 with Code Case 1997-2 Piping =

ASME III 1971 W72 with Code Case N316 Valves = ASME III 1974 (no addenda)

WA's (cont'd): C13572 C13573 C13578 C13579

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and This REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed, [Signature] Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 8-6-91 to 4-5-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NB 7525 PA 2159
Inspector's Signature National Board, State, Province, and Endorsements

Date JULY 22 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992

Sheet 2 of 7

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A


Expiration Date N/A

4. Identification of System RHR PUMP ROOM COOLING SYSTEM 134G CLASS III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
ROOM COOLER FLEX HOSES (4)	ANAMET	N/A	N/A	1E-230D SUP. AND RETURN	87	REPLACED	NO
ROOM COOLER FLEX HOSES (4)	ANAMET	N/A	N/A	1E-230D SUP. AND RETURN	90	REPLACEMENT	NO
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-230A BOTTOM	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-230A TOP	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	900617	N/A	1E-230A BOTTOM	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	900616	N/A	1E-230A TOP	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-230C BOTTOM	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-230C TOP	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	900619	N/A	1E-230C BOTTOM	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	900618	N/A	1E-230C TOP	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-230B BOTTOM	74	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992

Sheet 3 of 7

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE

 SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A


4. Identification of System RHR PUMP ROOM COOLING SYSTEM 134G CLASS III


5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-230B TOP	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	900621	N/A	1E-230B BOTTOM	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	900620	N/A	1E-230B TOP	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-230D BOTTOM	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	N/A	N/A	1E-230D TOP	74	REPLACED	NO
ROOM COOLER COIL	AEROFIN	900623	N/A	1E-230D BOTTOM	90	REPLACEMENT	YES
ROOM COOLER COIL	AEROFIN	900622	N/A	1E-230D TOP	90	REPLACEMENT	YES
PIPE SUPPORT	BECHTEL	N/A	N/A	HRC-126-H1	82	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	HRC-126-H1	92	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	HRC-126-H2	82	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	HRC-126-H2	92	REPLACEMENT	NO





FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992

Sheet 5 of 7

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A


4. Identification of System RHR PUMP ROOM COOLING SYSTEM 134G CLASS III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

LARGE PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	HRC-127-1	92	REPLACEMENT	NO
LARGE PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	HRC-130-1	82	REPLACED	YES
LARGE PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	HRC-130-1	92	REPLACEMENT	NO
LARGE PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	HRC-131-1	82	REPLACED	YES
LARGE PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	HRC-131-1	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-124-6	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-124-6	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-126-4	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-126-4	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-127-1	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-127-1	92	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992
 Sheet 6 of 7

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A


4. Identification of System RHR PUMP ROOM COOLING SYSTEM 134G CLASS III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-131-2	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-131-2	92	REPLACEMENT	NO
1/2" GLOBE VALVE	YARWAY	9941	N/A	1RV-FP-11182A	77	REPLACED	YES
1/2" GLOBE VALVE	YARWAY	9940	N/A	2RV-FP-11182A	77	REPLACED	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01J	N/A	1RV-FP-11182A	92	REPLACEMENT	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01K	N/A	2RV-FP-11182A	92	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	9952	N/A	1RV-FP-11182B	77	REPLACED	YES
1/2" GLOBE VALVE	YARWAY	9943	N/A	2RV-FP-11182B	77	REPLACED	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01Y	N/A	1RV-FP-11182B	92	REPLACEMENT	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01Z	N/A	2RV-FP-11182B	92	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	9961	N/A	1RV-FP-11182C	77	REPLACED	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992
 Sheet 7 of 7

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System RHR PUMP ROOM COOLING SYSTEM 134G CLASS III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1/2" GLOBE VALVE	YARWAY	9922	N/A	2RV-FP-11182C	77	REPLACED	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01AA	N/A	1RV-FP-11182C	92	REPLACEMENT	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01AB	N/A	2RV-FP-11182C	92	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	9911	N/A	1RV-FP-11182D	77	REPLACED	YES
1/2" GLOBE VALVE	YARWAY	9944	N/A	2RV-FP-11182D	77	REPLACED	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01L	N/A	1RV-FP-11182D	92	REPLACEMENT	YES
1/2" BALL VALVE	NELES-JAMESBURY	NC-334123-01M	N/A	2RV-FP-11182D	92	REPLACEMENT	YES
1" GLOBE VALVE	YARWAY	6068	N/A	RV-PP-11182A	76	REPLACED (DELETED)	YES



1E-230A BOT.

NOI-QA-2.4.7 C

DSR #45.

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)
2. Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)
3. Location of installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)
4. Type Heat Exchanger 900617 --- BM-R-15,N-R-4 --- 1990
(Mark or cert. label) (Mfr's or cert. No.) (CRN) (Drawing) (Mfr's Br. No.) (Year built)
5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Year
- 1997-2 ---
Addenda (ref.) Code Case No. Special service per UG-120(a)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" --- 0'-10" 2'-8"
(Matl. (Spec. No., Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))
7. Seams: --- --- --- --- ---
(Long. (Del., Enpl.)) (R.T. (Spot or Full)) (EIT (ft)) (H.T. Temp. (°F))
--- --- --- --- ---
(Time) (Grm. (Del., Enpl.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)
8. Heads: (a) Matl. --- (b) Matl. ---
(Spec. No., Grade) (Spec. No., Grade)

	Location (Top Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	---	---	---	---	---	---	---	---	---	---
(b)	---	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8M
(Matl. Spec. No., Gr. Size No.)

9. Type of Jacket --- Proof Test ---
10. Jacket Closure --- If bar, give dimensions --- If bolted, describe or sketch. ---
(Describe as edge & weld, bar, etc.)
11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi.
Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 10" .75" --- Bolted
(Stationary Matl. (Spec. No., Gr.)) (Diam. (in) (Subject to pressure)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach (Welded Bolted))
--- --- --- --- ---
(Floating Matl. (Spec. No., Gr.)) (Diam. (in)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach)
13. Tubes: SB-676, Class 2 .625" .049" 96 Straight
(Matl. (Spec. No., Gr.)) (O.D. (in)) (Nom. Thk. (in or Gauge)) (Number) (Type (Straight or "U"))

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: --- --- --- --- ---
(Matl. (Spec. No., Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))
15. Seams: --- --- --- --- ---
(Long. (Del., Enpl.)) (R.T. (Spot or Full)) (EIT (ft)) (H.T. Temp. (°F))
--- --- --- --- ---
(Time) (Grm. (Del., Enpl.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)
16. Heads: (a) Matl. --- (b) Matl. ---
(Spec. No., Grade) (Spec. No., Grade)

	Location (Top Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)										
(b)										

If removable, bolts used (describe other fastenings) ---
(Matl. Spec. No., Gr. Size No.)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- psi.
Hydro., pneu., or comb. test press. --- psi.

36

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diem. or Size	Type	Matl.	Wt. Tol.	Reinforcement Mtd.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	3	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19 Supports: Skirt No Lugs -- Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: TR-2877 (1) Mark: BFCO Item 18, PO# 8-43433-1, Item 4, DCP# 88-3049A, For RHR Pump Room 250 PC/Adjustax, Coil Tag# 1E230A, Unit Cooler 1V210A, Furnished on 89326778, (74S-4878)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.
 "U" Certificate of Authorization No. 2916 expires December 9, 1992
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed [Signature]
(Manufacturer) (Registered Co.)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance of Norwood, Massachusetts have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 22, 1990, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 6/29/90 Signed [Signature] Commissions VA 682, BWC03567
(Authorized Inspector) (*Factory Mutual System (Nat'l Board, State, Province and No))

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.
 "U" Certificate of Authorization No. _____ expires _____, 19_____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (By Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____ of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ Signed _____ Commissions _____
(Authorized Inspector) (Nat'l Board that endorses me: State, Prov. and No.)

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

NDI-QA-2.4.7
OSR #45

Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

2. Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3. Location of installation: Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4. Type: Heat Exchanger 900616 BM-R-15,N-R-4 1990
(Name, or type, tank) (Mfg's serial No.) (CRN) (Drawing) (Mater. No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Year

1997-2
Address (Serial) Code Case No. Special service per UG 120(d)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" 0'-10" 2'-8"
(Mater. Spec. No., Grade) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))

7. Seams: --- --- --- --- ---
(Long. (Dbl., Enfl.)) (R.T. (Spot or Full)) (Eff. (ft)) (M.T. Temp. (°F))
--- --- --- --- ---
(Type) (Girth (Dbl., Enfl.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

8. Heads: (a) Mater. --- (Spec. No., Grade) (b) Mater. --- (Spec. No., Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	---	---	---	---	---	---	---	---	---
(b)	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. A
(Mater. Spec. No., Gr., Size No.)

9. Type of Jacket --- Proof Test ---

10. Jacket Closure --- (Describe as open & weld, bar, etc.) If bar, give dimensions --- If bolted, describe or sketch ---

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 ps
Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 10" .75" --- Bolted
(Stationary Mater. (Spec. No., Gr.)) (Diam. (in)) (Subject to pressure) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach (Welded Bolted))
--- --- --- --- ---
(Floating Mater. (Spec. No., Gr.)) (Diam. (in)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach)

13. Tubes: SB-676, Class 2 .625" .049" 96 Straight
(Mater. (Spec. No., Gr.)) (OD (in)) (Nom. Thk. (in or Gauge)) (Number) (Type (Straight or "U"))

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: --- --- --- --- ---
(Mater. (Spec. No., Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))

15. Seams: --- --- --- --- ---
(Long. (Dbl., Enfl.)) (R.T. (Spot or Full)) (Eff. (ft)) (M.T. Temp. (°F))
--- --- --- --- ---
(Type) (Girth (Dbl., Enfl.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

16. Heads: (a) Mater. --- (Spec. No., Grade) (b) Mater. --- (Spec. No., Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	---	---	---	---	---	---	---	---	---
(b)	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) ---
(Mater. Spec. No., Gr., Size No.)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- ps
Hydro., pneu., or comb. test press. --- psi.

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diam. or Size	Type	Matl.	Wt. Lbs.	Reinforcement Matl.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	3	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19. Supports: Skirt No Lugs -- Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number, mfg's name and identifying stamp)

TR-2876 (1) Mark: BECO Item 17, PO# 8-43433-1, Item 4, DCP# 88-3049A, For RHR Pump Room 250 PC/Adjustax, Coil Tag# 1E230A, Unit Cooler 1V210A, Furnished on 89326777, (74S-4878)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 1992
 Date JUNE 29/1990 Co. name Aerofin Corporation Signed Barry J. Hart
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance of Norwood, Massachusetts

have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 22, 1990, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 6/29/90 Signed [Signature] Commissions VA 687, Bwco 3567
(Authorized Inspector) (*Factory Mutual System (Natl. Board State Province and No.))

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19_____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as date items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ Signed _____ Commissions _____
(Authorized Inspector) (Natl. Board State Province and No. 1)

1E-230C BOT.

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

NOI-QA-2.4.7
DSR #45.

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3. Location of Installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4. Type Heat Exchanger 900619 BM-R-15,N-R-4 1990
(HORIZ. OR VERT. TANK) (Mfg's serial No.) (CRN) (Drawing) (Inst. No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Year

1997-2
Addenda Items) Code Case No. Special orders per UG 120(d)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" 0'-10" 2'-8"
(Matl. (Spec No., Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))

7. Seams: --- --- --- ---
(Long. (Dbl., Sngl.)) (R.T. (Spot or Full)) (SH (ft)) (M.T. Temp. (°F))
--- --- --- ---
(Type) (Diam. (Dbl., Sngl.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

8. Heads: (a) Matl. --- (Spec. No., Grade) (b) Matl. --- (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	---	---	---	---	---	---	---	---	---	---
(b)	---	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8M
(Matl., Spec No., Gr., Size No.)

9. Type of Jacket --- Proof Test ---

10. Jacket Closure --- (Describe as edges & weld, bar, etc.) If bar, give dimensions --- If bolted, describe or sketch ---

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi.
Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 10" .75" --- Bolted
(Stationary Matl. (Spec No., Gr.)) (Diam. (in) (Subject to pressure)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach (Welded, Bolted))

--- --- --- --- ---
(Floating Matl. (Spec No., Gr.)) (Diam. (in)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach)

13. Tubes: SB-676, Class 2 .625" .049" 96 Straight
(Matl. (Spec No., Gr.)) (OD (in)) (Nom. Thk. (in or Gauge)) (Number) (Type (Straight or "U"))

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: --- --- --- --- ---
(Matl. (Spec No., Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))

15. Seams: --- --- --- ---
(Long. (Dbl., Sngl.)) (R.T. (Spot or Full)) (SH (ft)) (M.T. Temp. (°F))
--- --- --- ---
(Type) (Diam. (Dbl., Sngl.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

16. Heads: (a) Matl. --- (Spec. No., Grade) (b) Matl. --- (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)										
(b)										

If removable, bolts used (describe other fastenings) ---
(Matl., Spec No., Gr., Size No.)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- psi.
Hydro., pneu., or comb. test press. --- psi.

40

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Dim. or Size	Type	Matl.	Nom. Thk.	Reinforcement Meth.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	3	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19. Supports: Skirt No Lugs -- Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number, mfg's name and identifying stamp)

TR-2879 (1) Mark: BECO Item 20, PO# 8-43433-1, Item 4, DCP# 88-3049A. For RHR Pump Room 250 PC/Adjustax, Coil Tag# 1E230C, Unit Cooler 1V210C, Furnished on 89326780. (74S-4878)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 19 92
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed [Signature]
(Manufacturer) (Manufacturer)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance of Norwood, Massachusetts

have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 21, 19 90, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 6/18/90 Signed [Signature] Commissions VA 682, PAUC 03, S67
(Authorized Inspector) *Factory Mutual System (NBT Board, State, Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19 _____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ Signed _____ Commissions _____
(Authorized Inspector) (NBT Board and endorsement State, Province and No.)

41

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)
2. Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)
3. Location of Installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)
4. Type Heat Exchanger 900618 --- BM-R-15,N-R-4 --- 1990
(Mark or code, 1982) (Mfg's serial No.) (CA#) (Drawing) (Mater. No.) (Year built)
5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Year
- 1997-2 ---
Appendix Idents) Code Case No. Special service per UG-120(d)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" --- 0'-10" 2'-8"
(Mater. Spec. No., Grade) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))
7. Seams: --- --- --- --- ---
(Long. (Dbl., Sngl.)) (R.T. (Spot or Full)) (Eff. (%)) (H.T. Temp. (°F))
- --- --- --- ---
(Type) (Diam. (Dbl., Sngl.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)
8. Heads: (a) Mater. --- (Spec. No., Grade) (b) Mater. --- (Spec. No., Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	---	---	---	---	---	---	---	---	---
(b)	---	---	---	---	---	---	---	---	---

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8A
(Mater. Spec. No., Gr., Size No.)

9. Type of Jacket --- Proof Test ---
10. Jacket Closure --- If bar, give dimensions --- If bolted, describe or sketch. (Describe as edge & weld bar, etc.)
11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi. Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 10" .75" --- Bolted
(Stationary Mater. (Spec. No., Gr.)) (Diam. (in) (Subject to pressure)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach (Welded Bolted))
- --- --- --- ---
(Floating Mater. (Spec. No., Gr.)) (Diam. (in)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Attach)
13. Tubes: SB-676, Class 2 .625" .049" 96 Straight
(Mater. (Spec. No., Gr.)) (OD (in)) (Nom. Thk. (in or Gauge)) (Number) (Type (Straight or 'U'))

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: --- --- --- --- ---
(Mater. (Spec. No., Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft & in)) (Length (Overall) (ft & in))
15. Seams: --- --- --- --- ---
(Long. (Dbl., Sngl.)) (R.T. (Spot or Full)) (Eff. (%)) (H.T. Temp. (°F))
- --- --- --- ---
(Type) (Diam. (Dbl., Sngl.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)
16. Heads: (a) Mater. --- (Spec. No., Grade) (b) Mater. --- (Spec. No., Grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)									

If removable, bolts used (describe other fastenings) ---
(Mater. Spec. No., Gr., Size No.)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- psi. Hydro., pneu., or comb. test press. --- psi.

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diam. or Size	Type	Matl.	Wt. Lbs.	Reference Matl.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182,T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182,T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	3	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19 Supports: Skirt No Lugs --- Legs --- Other --- Attached ---
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number, mfg. name and identifying stamp)

TR-2878 (1) Mark: BECO Item 19 PO# 8-43433-1, Item 4, DCP# 88-3049A, For RHR Pump Room 250 PC/Adjustax, Coil Tag# 1E230C, Unit Cooler 1V210C, Furnished on 89326779.

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 19 92
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed [Signature]
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance of Norwood, Massachusetts

have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 21, 19 90, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 6/29/90 Signed [Signature] Commissions VA 682, PAUC03567
(Authorized Inspector) *Factory Mutual System (Not Board State Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19 _____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (By Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ Signed _____ Commissions _____
(Authorized Inspector) (Not Board Unit endorsement) State Prov. and No.)

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3. Location of Installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4. Type Heat Exchanger 900621 -- BM-R-15,N-R-4 -- 1990
(Material or part, model) (Design or serial No.) (CRN) (Drawing) (Mater. Id. No.) (Year built)

6. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Year

-- 1997-2 --
Addenda (list) Code Case No. Special services per UG 130(d)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" -- 0'-10" 2'-8"
(Matl. (Spec. No., Grade)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

7. Seams: -- -- -- -- --
(Long. I.D. (Inch.)) (R.T. (Spot or Full)) (ft. (ft.)) (H.T. Temp. (°F))

-- -- -- -- --
(Type) (Grth. I.D. (Inch.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

8. Heads: (a) Matl. -- (Spec. No., Grade) (b) Matl. -- (Spec. No., Grade)

	Location (Top, Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	--	--	--	--	--	--	--	--	--	--
(b)	--	--	--	--	--	--	--	--	--	--

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. B
(Matl., Spec. No., Gr., Size No.)

9. Type of Jacket Proof Test

10. Jacket Closure --- If bar, give dimensions --- If bolted, describe or sketch
(Describe as ogee & weld, bar, etc.)

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi
Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 10" .75" -- Bolted
(Stationary Matl. (Spec. No., Gr.)) (Diam. (in.)) (Subject to pressure) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Attach (Welded Bolted))

--- --- --- --- ---
(Floating Matl. (Spec. No., Gr.)) (Diam. (in.)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Attach)

13. Tubes: SB-676, Class 2 .625" .049" 96 Straight
(Matl. (Spec. No., Gr.)) (OD (in.)) (Nom. Thk. (in. or Gauge)) (Number) (Type (Straight or "U"))

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: --- --- --- --- ---
(Matl. (Spec. No., Grade)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

15. Seams: --- --- --- --- ---
(Long. I.D. (Inch.)) (R.T. (Spot or Full)) (ft. (ft.)) (H.T. Temp. (°F))

--- --- --- --- ---
(Type) (Grth. I.D. (Inch.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

16. Heads: (a) Matl. --- (Spec. No., Grade) (b) Matl. --- (Spec. No., Grade)

	Location (Top, Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)										

If removable, bolts used (describe other fastenings) ---
(Matl., Spec. No., Gr., Size No.)

17. MAWP --- psi at max. temp. --- °F. Min. design metal temp. --- °F at --- psi
Hydro., pneu., or comb. test press. --- psi.

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Di. or Size	Type	Mat.	Nom. Wt.	Reinforcement Mod.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182,T-316L	150LB	N/R	WELDED	END
OUTLET	1	2" IPS	W/N FLG	SA-182,T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	3	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19. Supports: Skirt No Lugs -- Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report:

TR-2881 (1) Mark: BFCO Item 22 PO# 8-43433-1, Item 4, DCP# 88-3049B, For RHR Pump Room 250 PC/Ajustax, Coil Tag# 1E230B, Unit Cooler 1V210B, Furnished on 89326782. (74S-4877)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 19 92
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed [Signature]
(Manufacturer) (Inspector)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance

of Norwood, Massachusetts have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 23, 19 90, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employee makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any person injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 6/29/90 Signed [Signature] Commissions VA 682, PAWCO3567
(Authorized Inspector) (*Factory Mutual System (NBBP Board Rules, Paragraph 404))

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19 _____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (By Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any person injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ Signed _____ Commissions _____
(Authorized Inspector) (NBBP Board Rules, Paragraph 404) (State Proc. and No.)

45

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)
Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)
3. Location of Installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)
4. Type Heat Exchanger 900620 -- BM-R-15,N-R-4 -- 1990
(Material, Unit) (Mfg's serial No.) (CRN) (Drawing) (Mfg. Ref. No.) (Year built)
5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Year
-- 1997-2 --
Addenda Items) Code Case No. Special Services per UG-120(d)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" -- 0'-10" 2'-8"
(Matl. (Spec. No., Grade)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))
7. Seams: -- -- -- -- --
(Long. (Del., Eng'l)) (R.T. (Spot or Full)) (Eff. (ft.)) (H.T. Temp. (°F))
-- -- -- -- --
(Time) (Girth (Del., Eng'l)) (R.T. (Spot, Partial, or Full)) (No. of Courses)
8. Heads: (a) Matl. -- (Spec. No., Grade) (b) Matl. -- (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	--	--	--	--	--	--	--	--	--	--
(b)	--	--	--	--	--	--	--	--	--	--

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8
(Matl. Spec. No., Gr., Size No.)

9. Type of Jacket -- Proof Test --
10. Jacket Closure -- If bar, give dimensions -- If bolted, describe or sketch.
(Describe as ogee & weld, bar, etc.)
11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi.
Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 10" .75" -- Bolted
(Stationary Matl. (Spec. No., Gr.)) (Diam. (in.) (Subject to pressure)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Attach (Welded Bolted))
-- -- -- -- Attach
(Floating Matl. (Spec. No., Gr.)) (Diam. (in.)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Attach)
13. Tubes: SB-676, Class 2 .625" .049" 96 Straight
(Matl. (Spec. No., Gr.)) (O.D. (in.)) (Nom. Thk. (in. or Gauge)) (Number) (Type (Straight or U))

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: -- -- -- -- --
(Matl. (Spec. No., Grade)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))
15. Seams: -- -- -- -- --
(Long. (Del., Eng'l)) (R.T. (Spot or Full)) (Eff. (ft.)) (H.T. Temp. (°F))
-- -- -- -- --
(Time) (Girth (Del., Eng'l)) (R.T. (Spot, Partial, or Full)) (No. of Courses)
16. Heads: (a) Matl. -- (Spec. No., Grade) (b) Matl. -- (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)										
(b)										

If removable, bolts used (describe other fastenings) --
(Matl. Spec. No., Gr., Size No.)

17. MAWP -- psi at max. temp. -- °F. Min. design metal temp. -- °F at -- psi.
Hydro., pneu., or comb. test press. -- psi.

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Size or Size	Type	Matl.	Nom. Thk.	Reinforcement Mtd.	How Attached	Location
INLET	1	2" IPS	W/N FLG	SA-182, T-316L	150LR	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182, T-316L	150LR	N/R	WELDED	END
VENTS	1	1-1/8"	THD PLUG	SA-479	3000LR	N/R	THREADED	END
DRAINS	3	1-1/8"	THD PLUG	SA-479	3000LR	N/R	THREADED	END

19. Supports: Skirt No Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number, mfg. name and identifying stamp)

TR-2880 (1) Mark: BECO Item 21 PO# 8-43433-1, Item 4, DCP# 88-3049B, For RHR Pump Room 250 PC/Adjustax, Coil Tag# 1E230B, Unit Cooler 1V210B, Furnished on 89326781, (74S-4877)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 1992
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed Barn [Signature]
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance of Norwood, Massachusetts

have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 23, 1990, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6/29/90 Signed [Signature] Commissions VA 682, PAUC03567
(Authorized Inspector) *Factory Mutual System (National Board State, Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19_____
 Date _____ Co. name _____ Signed _____
(Manufacturer that certified and constructed field assembly) (Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (National Board State, Province and No.)

1E-230D BOT.

NOI-QA-247

OSR #45

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

- 1. Manufactured and certified by: Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
2. Manufactured for: Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
3. Location of Installation: Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
4. Type: Heat Exchanger, 900623, BM-R-15,N-R-4, 1990
5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1, 1986
1997-2

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

- 6. Shell: SA-240, T-316L, 1.5", 0'-10", 2'-8"
7. Seams: Long (Det. Smp), R.T. (Spot or Full), Eff. (N), H.T. Temp. (°F)
8. Heads: (a) Matl., (b) Matl., (Spec No. Grade)

Table with 10 columns: Location (Top, Bottom, Ends), Minimum Thickness, Corrosion Allowance, Crown Radius, Knuckle Radius, Elliptical Ratio, Conical Apex Angle, Hemispherical Radius, Flat Diameter, Side to Pressure (Convex or Concave). Rows (a) and (b) are mostly blank.

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8M

- 9. Type of Jacket: Proof Test:
10. Jacket Closure: If bolted, describe or sketch.
11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi Hydro., pneu., or comb. test press.: 285 psi.

Items 12 and 13 to be completed for tube sections

- 12. Tubesheets: SB-688, 10", .75", Bolted
13. Tubes: SB-676, Class 2, .625", .049", 96, Straight

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

- 14. Shell: Matl. (Spec. No., Grade), Nom. Thk. (in), Corr. Allow. (in), Diam. I.D. (in & in), Length (Overall) (in & in)
15. Seams: Long (Det. Smp), R.T. (Spot or Full), Eff. (N), H.T. Temp. (°F)
16. Heads: (a) Matl., (b) Matl., (Spec. No., Grade)

Table with 10 columns: Location (Top, Bottom, Ends), Minimum Thickness, Corrosion Allowance, Crown Radius, Knuckle Radius, Elliptical Ratio, Conical Apex Angle, Hemispherical Radius, Flat Diameter, Side to Pressure (Convex or Concave). Row (b) is mostly blank.

If removable, bolts used (describe other fastenings) (Matl. Spec No., Gr., Size, No)

- 17. MAWP psi at max. temp. °F. Min. design metal temp. °F at psi Hydro., pneu., or comb. test press. psi.

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Dim. or Size	Type	Matl.	Nom. Thk.	Reinforcement Mbr.	How Attached	Locat.
INLET	1	2" IPS	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	3	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19 Supports: Skirt No Lugs -- Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number, mfg's name and identifying stamp)

TR-2883 (1) Mark: BFCO Item 24 PO# 8-43433-1, Item 4, DCP# 88-3049B. For RHR Pump Room 250 PC/Adjustax, Coil Tag# 1E230D, Unit Cooler 1V230D. Furnished on 89326784. (74S-8877)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 19 92
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed [Signature]
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance

of Norwood, Massachusetts have inspected the pressure vessel described in this Manufacturer's Data Report on JUNE 23, 19 90, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6/29/90 Signed [Signature] Commissions VA 682 PAWCO35674
(Authorized Inspector) *Factory Mutual System (Nat'l Board/State, Province and No.)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19 ____
 Date _____ Co. name _____ Signed _____
(Assembler that certified and constructed field assembly) (By Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (Nat'l Board/State, Province and No.)

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

NOI-QA-2.47
DSR #45

1. Manufactured and certified by Aerofin Corporation, 4621 Murray Place, Lynchburg, VA 24502
(Name and address of manufacturer)

2. Manufactured for Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address of purchaser)

3. Location of installation Pennsylvania Power & Light Company, Susquehanna Station, Berwick, PA
(Name and address)

4. Type Heat Exchanger 900622 -- BM-R-15,N-R-4 -- 1990
(Name or code, shell) (Mfg's serial No.) (CAN) (Drawing) (Part No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1986
Yes

-- 1997-2 --
Addenda (date) Code Case No. Special service per UG-120(d)

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers

6. Shell: SA-240, T-316L 1.5" -- 0'-10" 2'-8"
(Matl. (Spec. No., Grade)) (Nom. Thk. (in)) (Corr. Allow. (in)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

7. Seams: -- -- -- -- --
(Long. (Det., Segt.)) (R.T. (Spot or Full)) (Eff. (%)) (H.T. Temp. (°F))
-- -- -- -- --
(Time) (Circ. (Det., Segt.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

8. Heads: (a) Matl. -- (Spec. No., Grade) (b) Matl. -- (Spec. No., Grade)

	Location (Top, Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	--	--	--	--	--	--	--	--	--	--
(b)	--	--	--	--	--	--	--	--	--	--

If removable, bolts used (describe other fastenings) 5/8" studs of SA-193 Gr. B8M; with 5/8" nuts of SA-194 Gr. 8
(Matl., Spec. No., Gr., Size No.)

9. Type of Jacket -- Proof Test --

10. Jacket Closure -- If bar, give dimensions -- If bolted, describe or sketch. (Describe as edges & weld, bar, etc.)

11. MAWP 190 psi at max. temp. 130 °F. Min. design metal temp. 33 °F at 190 psi Hydro., pneu., or comb. test press. 285 psi.

Items 12 and 13 to be completed for tube sections

12. Tubesheets: SB-688 10" .75" -- Bolted
(Stationary Matl. (Spec. No., Gr.)) (Diam. (in.) (Subject to pressure)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Attach (Welded, Bolted))
-- -- -- -- --
(Floating Matl. (Spec. No., Gr.)) (Diam. (in.)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Attach)

13. Tubes: SB-676, Class 2 .625" .049" 96 Straight
(Matl. (Spec. No., Gr.)) (O.D. (in.)) (Nom. Thk. (In. or Gauge)) (Number) (Type (Straight or "U"))

Items 14-17 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers

14. Shell: -- -- -- -- --
(Matl. (Spec. No., Grade)) (Nom. Thk. (in.)) (Corr. Allow. (in.)) (Diam. I.D. (ft. & in.)) (Length (Overall) (ft. & in.))

15. Seams: -- -- -- -- --
(Long. (Det., Segt.)) (R.T. (Spot or Full)) (Eff. (%)) (H.T. Temp. (°F))
-- -- -- -- --
(Time) (Circ. (Det., Segt.)) (R.T. (Spot, Partial, or Full)) (No. of Courses)

16. Heads: (a) Matl. -- (Spec. No., Grade) (b) Matl. -- (Spec. No., Grade)

	Location (Top, Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)										
(b)										

If removable, bolts used (describe other fastenings) --
(Matl., Spec. No., Gr., Size No.)

17. MAWP -- psi at max. temp. -- °F. Min. design metal temp. -- °F at -- psi Hydro., pneu., or comb. test press. -- psi.

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diame. or Size	Type	Matl.	Wt. Lbs.	Reinforcement Mtd.	How Attached	Location
INLET	:	2" IPS	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
OUTLET	1	2"	W/N FLG	SA-182, T-316L	150LB	N/R	WELDED	END
VENTS	1	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END
DRAINS	3	1 1/8"	THD PLUG	SA-479	3000LB	N/R	THREADED	END

19. Supports: Skirt No Lugs -- Legs -- Other -- Attached --
(Yes or no) (No) (No) (Describe) (Where and how)

20. Remarks: Manufacturer's Partial Date Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: _____
(Name of part, item number or p/n name and identifying stamp)

TR-2882 (1) Mark: BECO Item 23 PO# 8-43433-1, Item 4, DCP# 88-3049R, For RHR Pump Room 250 PC/Adjustax, Coil Tag# 1E230D, Unit Cooler 1V210D, Furnished on 89326783, (74S-4877)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 2916 expires December 9, 19 92.
 Date JUNE 29, 1990 Co. name Aerofin Corporation Signed Bary Robert
(Manufacturer) (Inspector)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by Aerofin Corporation at Lynchburg, VA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Virginia and employed by *Allendale Mutual Insurance

of Norwood, Massachusetts have inspected the pressure vessel described in this Manufacturer's Date Report on JUNE 23, 19 90, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Date Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6/29/90 Signed [Signature] Commissions VA 682 PAWC 03567
(Authorized Inspector) (National Board State Province and No 1)
 *Factory Mutual System

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19 _____.
 Date _____ Co. name _____
(Assembler that certified and constructed field assembly) (Inspector)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Date Report with the described pressure vessel and state that parts referred to as date items _____, not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Date Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (National Board State Province and No 1)

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section I, Div. 1

1. Manufactured by Neles-Jamesbury, Inc., 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric *
(Name and Address)
4. Pump or Valve Ball Valve . Nominal Inlet Size 1/2" Outlet Size 1/2"
(inch) (inch)

	(a) Model No., Series No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Std No.	(g) Year Built
	(1)	4CB	NC-334123-01 T	N/A	NC-334123-01 Rev.C	2	N/A
(2)	4CB	NC-334123-01 U	N/A	NC-334123-01 Rev.C	2	N/A	1992
(3)	4CB	NC-334123-01 W	N/A	NC-334123-01 Rev.C	2	N/A	1992
(4)	4CB	NC-334123-01 X	N/A	NC-334123-01 Rev.C	2	N/A	1992
(5)	4CB	NC-334123-01 Y	N/A	NC-334123-01 Rev.C	2	N/A	1992
(6)	4CB	NC-334123-01 Z	N/A	NC-334123-01 Rev.C	2	N/A	1992
(7)	4CB	NC-334123-01 AA	N/A	NC-334123-01 Rev.C	2	N/A	1992
(8)	4CB	NC-334123-01 AB	N/A	NC-334123-01 Rev.C	2	N/A	1992
(9)							
(10)							

5. Emergency Service Water
(Brief description of service for which equipment was designed)
- *Station, 5Mi NE of Berwick on U.S. RT11

6. Design Conditions Seat 177 125°
Body 275 100° °F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)

7. Cold Working Pressure 275 - psi at 100°F.

8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
ASME-SA			
(1) RHD -36	351 Gr. CF8M	Southern Tool	Body
(2) RHD -76	351 Gr. CF8M	Southern Tool	Body
(3) RHD -35	351 Gr. CF8M	Southern Tool	Body
(4) RHD -62	351 Gr. CF8M	Southern Tool	Body
(5) RHD -28	351 Gr. CF8M	Southern Tool	Body
(6) RHD -68	351 Gr. CF8M	Southern Tool	Body
(7) RHD -44	351 Gr. CF8M	Southern Tool	Body
(8) RHD -24	351 Gr. CF8M	Southern Tool	Body
(b) Castings			
ASME-SA			
(1) RHS -8 & -35	351 Gr. CF3M	Southern Tool	Caps
(2) RHS -25 & -26	351 Gr. CF3M	Southern Tool	Caps
(3) RHS -4 & -32	351 Gr. CF3M	Southern Tool	Caps
(4) RHS -7 & -28	351 Gr. CF3M	Southern Tool	Caps
(5) RHS -38 & -39	351 Gr. CF3M	Southern Tool	Caps
(6) RHS -40 & -56	351 Gr. CF3M	Southern Tool	Caps
(7) RHS -3 & -104	351 Gr. CF3M	Southern Tool	Caps
(8) RHS -18 & -37	351 Gr. CF3M	Southern Tool	Caps

(1) For manually operated valves only.

PPSL Doc No. 45

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting	ASME-SA		
9E0947	194 Gr. 8	Nova Machine	Hex Nut (all)
9E0947	193 Gr. B8	Nova Machine	Hex HD. Cap
			*(all valves)
(d) Other Parts	ASME-SA		
RET	479 Type 316	Neles-Jamesbury	Ball (all valves)

9. Hydrostatic test 425 psi. Disk Differential test pressure _____ psi. NC-334123-01T, 01U, 01W, 01X, 01Y, 01Z, 01AA, 01AB

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1974
 Addenda NONE (Date) _____, Code Case No. NONE Date 7 Feb. 92
 Signed Neles-Jamesbury, Inc. by Donald Parker
 (N. Certificate Holder)
 Our ASME Certificate of Authorization No. N-1228 to use the N symbol expires Oct. 27, 1993
 (Date)

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Two North Ninth St., Allentown PA 18101
 Stress analysis report (Class T-only) on file at N/A
 Design specifications certified by (1) Dale Stattar
 PE State PA Reg. No. PE 019525E
 Stress analysis certified by (1) N/A
 PE State N/A Reg. No. N/A
 (1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of MASS and employed by Protection Mutual of Norwood, Massachusetts have inspected the pump, or valve, described in this Data Report on 2-7 19 92, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.
 By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 2-7 19 92 [Signature] Commissions YMA #1287 PAWC #2757
 (Inspector) (Natl Bd., State, Prov. and No.)
 PPTC Doc No. 45

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEONIC PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section VIII, Div. 1

1. Manufactured by Neles-Jamesbury, Inc., 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric *
(Name and Address)
4. Pump or Valve Ball Valve Nominal Inlet Size 1/2" Outlet Size 1/2"
(inch) (inch)

	(a) Model No. Series No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
(1)	4CB	NC-334123-01J	N/A	NC-334123-01 Rev. C	2	N/A	1992
(2)	4CB	NC-334123-01K	N/A	NC-334123-01 Rev. C	2	N/A	1992
(3)	4CB	NC-334123-01L	N/A	NC-334123-01 Rev. C	2	N/A	1992
(4)	4CB	NC-334123-01M	N/A	NC-334123-01 Rev. C	2	N/A	1992
(5)	4CB	NC-334123-01N	N/A	NC-334123-01 Rev. C	2	N/A	1992
(6)	4CB	NC-334123-01P	N/A	NC-334123-01 Rev. C	2	N/A	1992
(7)	4CB	NC-334123-01R	N/A	NC-334123-01 Rev. C	2	N/A	1992
(8)	4CB	NC-334123-01S	N/A	NC-334123-01 Rev. C	2	N/A	1992
(9)							
(10)							

5. Emergency Service Water
(Brief description of service for which equipment was designed)
*Station, 5Mi NE of Berwick on U.S. RT11
6. Design Conditions Seat 177 125°
Body 275 100° psi 150 °F or Valve Pressure Class (1)
(Pressure) (Temperature)
7. Cold Working Pressure 275 psi at 100°F.
8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
ASME-SA			
(1) RHD -30	351 Gr. CF8M	Southern Tool	Body
(2) RHD -19	351 Gr. CF8M	Southern Tool	Body
(3) RHD -15	351 Gr. CF8M	Southern Tool	Body
(4) RHD -61	351 Gr. CF8M	Southern Tool	Body
(5) RHD -74	351 Gr. CF8M	Southern Tool	Body
(6) RHD -57	351 Gr. CF8M	Southern Tool	Body
(7) RHD -69	351 Gr. CF8M	Southern Tool	Body
(8) RHD -73	351 Gr. CF8M	Southern Tool	Body
(b) Castings			
ASME-SA			
(1) RHS -17 & -41	351 Gr. CF3M	Southern Tool	Caps
(2) RHS -12 & -105	351 Gr. CF3M	Southern Tool	Caps
(3) RHS -20 & -119	351 Gr. CF3M	Southern Tool	Caps
(4) RHS -5 & -23	351 Gr. CF3M	Southern Tool	Caps
(5) RHS -34 & -82	351 Gr. CF3M	Southern Tool	Caps
(6) RHS -16 & -83	351 Gr. CF3M	Southern Tool	Caps
(7) RHS -10 & -31	351 Gr. CF3M	Southern Tool	Caps
(8) RHS -11 & -15	351 Gr. CF3M	Southern Tool	Caps

(1) For manually operated valves only.

PP/4 Doc No 45

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

134KII

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 7
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13894, C13895, C13896, C13897
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System REACTOR RECIRCULATION SYSTEM 134K CLASS II
5. (a) Applicable Construction Code See Remark 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-188-H3	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02860	N/A	HBD-188-H3	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-188-H4	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03145	N/A	HBD-188-H4	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-188-H5	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03498	N/A	HBD-188-H5	1978	REPLACED	N/A

7. Description of Work Remove Snubbers and Pipe Supports and Modify Pipe Supports
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure No Testing Required
Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Applicable Construction Codes: For Pipe Supports -ASME III 1971 Edition thru Winter 1972
Applicable Manufacturer's Data Reports to be attached

Addenda: for Snubbers - ASME III 1977 Edition thru Summer 1979 Addenda. Code Case N-411 & N-122

Snubber Reduction per Calculations SR-1039, SR-1040, SR-1042 and SR-1043.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SWal Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-27-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.


David Danellany Commissions NB 7525 PA 2159 NE
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 2 of 7
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13894, C13895, C13896, C13897
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System REACTOR RECIRCULATION SYSTEM 134K CLASS II
5. (a) Applicable Construction Code See Remark 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-188-H7	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	07289	N/A	HBD-188-H7	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-188-H8	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	10742	N/A	HBD-188-H8A	1980	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	13946	N/A	HBD-188-H8B	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-188-H11	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00399	N/A	HBD-188-H11A	1980	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	00238	N/A	HBD-188-H11B	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-188-H12	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	17234	N/A	HBD-188-H12	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-188-H14	1982	REPLACED	NO



134KII

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 3 of 7
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13894, C13895, C13896, C13897
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 134K CLASS II

5. (a) Applicable Construction Code See Remark 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	12961	N/A	HBD-188-H14A	1981	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	12977	N/A	HBD-188-H14B	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-188-H15	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14381	N/A	HBD-188-H15A	1982	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	14386	N/A	HBD-188-H15B	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-188-H16	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14395	N/A	HBD-188-H16	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBB-125-H2	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03281	N/A	HBB-125-H2	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBB-126-H2	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13460	N/A	HBB-126-H2	1981	REPLACED	N/A




134KII

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 4 of 7
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13894, C13895, C13896, C13897
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System REACTOR RECIRCULATION SYSTEM 134K CLASS II
5. (a) Applicable Construction Code See Remark 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80
6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-189-H2	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02602	N/A	HBD-189-H2	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-189-H3	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	23917	N/A	HBD-189-H3	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-189-H5	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06810	N/A	HBD-189-H5	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-189-H6	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22923	N/A	HBD-189-H6	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-189-H7	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22352	N/A	HBD-189-H7	1984	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-189-H8	1982	REPLACED	NO



**FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI**

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
- Two North Ninth St., Allentown, PA 18101 Sheet 5 of 7
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
- PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13894, C13895, C13896, C13897
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
- Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address
- Expiration Date N/A
4. Identification of System REACTOR RECIRCULATION SYSTEM 134K CLASS II
5. (a) Applicable Construction Code See Remark 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	06798	N/A	HBD-189-H8	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-189-H9	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02437	N/A	HBD-189-H9	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-1039-H1	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	12181	N/A	HBD-1039-H1	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-1039-H2	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06581	N/A	HBD-1039-H2	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-1039-H3	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06582	N/A	HBD-1039-H3	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-1039-H4	1982	REPLACED	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-1039-H7	1982	REPLACED	NO




134KII

**FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI**

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
- Two North Ninth St., Allentown, PA 18101 Sheet 6 of 7
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
- PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13894, C13895, C13896, C13897
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
- Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address
- Expiration Date N/A
4. Identification of System REACTOR RECIRCULATION SYSTEM 134K CLASS II
5. (a) Applicable Construction Code See Remark 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	17728	N/A	HBD-1039-H7	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-1039-H11	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	17211	N/A	HBD-1039-H11	1983	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-1039-H12	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	12960	N/A	HBD-1039-H12	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-1040-H9	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28862	N/A	HBD-1040-H9	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-1040-H10	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13050	N/A	HBD-1040-H10	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-1040-H1	1982	REPLACED	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-1040-H2	1982	REPLACED	NO



**FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI**

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 21, 1992

Sheet 7 of 7

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

DCP 90-3108F WA C13894, C13895, C13896, C13897
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 134K CLASS II

5. (a) Applicable Construction Code See Remark 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	HBD-188-H9	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	HBD-188-H9	1992	REPLACEMENT	NO
MECH. SNUBBER	BECHTEL	02403	N/A	HBD-1040-H3	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	HBD-1040-H3	1992	REPLACEMENT	NO

7
H

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 5 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 2
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108J, WA C13807, C13808
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR FEEDWATER SYSTEM 145A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S 79' Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-104-H2000	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-104-H2000	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-101-H1	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04109-78	N/A	DLA-101-H1	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-103-H3	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	12623-85	N/A	DLA-103-H3	1986	REPLACED	N/A

7. Description of Work SNUBBER REDUCTION PROJECT

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure NO TESTING REQUIRED
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks INCLUDES PIPING CALC. # SR-876 & SR-880

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed Struhal Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 1-9-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David Daullany Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 5 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 2 of 2
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108J, WA C13807, C13808
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR FEEDWATER SYSTEM 145A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S 79' Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-106-H2000	1982	REPLACED	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date JUNE 26, 1992
Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
PPL, PMR #92-9024, WA #C23208
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
Authorization No. N/A
Expiration Date N/A

4. Identification of System REACTOR FEEDWATER SYSTEM 145, CLASS 1

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SPOOL	BECHTEL	N/A	N/A	DLA-102-1 FW15	1982	REPAIRED	YES

7. Description of Work PERFORMED 360 DEGREE WELD BUILDUP ADJACENT TO FW 15

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks EVALUATION : ASME SECT 111,1977 EDITION THRU SUMMER 1979

Applicable Manufacturer's Data Reports to be attached

CODE CASE N411,CALC. SRO-876-1

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPAIR conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SKILLAL Date July 16, 19 92

Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 4-12-92 to 4-17-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David D. Sullivan Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date JULY 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 18, 1992

Sheet 1 of 9

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
90-3108F WA C13907, C13908, C13909, C13913, C13914
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A

4. Identification of System RESIDUAL HEAT REMOVAL SYSTEM 149G CLASS 1

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-108-H2015	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	18586	N/A	SP-DCA-108-H2015	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-108-H2016	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02419	N/A	SP-DCA-108-H2016	1976	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HBD-1115-H2002	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13439	N/A	SP-HBD-1115-H2002	1981	REPLACED	N/A

7. Description of Work REMOVE SNUBBERS / NO REPLACEMENT--MODIFY SUPPORTS

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure No Testing Required
 Other Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Applicable Construction Codes:for Snubbers - ASME III 1977 Edition thru Summer 1979 Addenda.

CODE CASE N-411 & N-122.

CALC. # SR-5801, SR-5802, SR-5803, SR-950A, SR-950B

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed *S. Mat* Date July 16, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-26-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Paul Daubman Commissions NB 7525 PA 2159 NE
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 18, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 2 of 9
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 90-3108F WA C13907, C13908, C13909, C13913,
Address C13914
Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System RESIDUAL HEAT REMOVAL SYSTEM 149G CLASS 1

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W/80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HBD-1115-H2003	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28780	N/A	SP-HBD-1115-H2003	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HBD-1115-H2009	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22931	N/A	SP-HBD-1115-H2009	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2036	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22866	N/A	SP-DCA-126-H2036	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-126-H2036	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H38	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06254	N/A	SP-DCA-126-H38	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H39	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	23569	N/A	SP-DCA-126-H39	1981	REPLACED	N/A



149GI

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 18, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 3 of 9
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 90-3108F WA C13907, C13908, C13909, C13913,
Address C13914
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System RESIDUAL HEAT REMOVAL SYSTEM 149G CLASS 1
5. (a) Applicable Construction Code see remarks 19 . Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H40	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06255	N/A	SP-DCA-126-H40	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H48	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	10915	N/A	SP-DCA-126-H48	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H50	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06329	N/A	SP-DCA-126-H50	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H54	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06277	N/A	SP-DCA-126-H54	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H55	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28970	N/A	SP-DCA-126-H55	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2033	1982	REPLACED	NO

6
7

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name

Date May 18, 1992

 Two North Ninth St., Allentown, PA 18101
Address

Sheet 4 of 9

2. Plant Susquehanna Steam Electric Station
Name

Unit ONE

 PO Box 467, Berwick, PA 18603
Address

 90-3108F WA C13907, C13908, C13909, C13913, C13914
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name

Type Code Symbol Stamp None

 Two North Ninth St., Allentown, PA 18101
Address

Authorization No. N/A


Expiration Date N/A

4. Identification of System RESIDUAL HEAT REMOVAL SYSTEM 149G CLASS 1

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	21148	N/A	SP-DCA-126-H2033	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2037	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	23547	N/A	SP-DCA-126-H2037	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2041	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22876	N/A	SP-DCA-126-H2041	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2043	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28732	N/A	SP-DCA-126-H2043	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2047	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22965	N/A	SP-DCA-126-H2047	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H9	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02624	N/A	DCA-110-H9	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 18, 1992
 Sheet 5 of 9

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
90-3108F WA C13907, C13908, C13909, C13913,
C13914
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A


4. Identification of System RESIDUAL HEAT REMOVAL SYSTEM 149G CLASS 1

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H11	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01297	N/A	DCA-110-H11	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H12	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01498	N/A	DCA-110-H12	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H13	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02555	N/A	DCA-110-H13	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H14	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02585	N/A	DCA-110-H14	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H31	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00765	N/A	DCA-110-H31	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H33	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 18, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 6 of 9
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 90-3108F WA C13907, C13908, C13909, C13913,
Address C13914
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System RESIDUAL HEAT REMOVAL SYSTEM 149G CLASS 1

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	00187	N/A	DCA-110-H33	1988	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H34	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01295	N/A	DCA-110-H34	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H35	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02592	N/A	DCA-110-H35	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H36	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	11019	N/A	DCA-110-H36	1983	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H5	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCA-110-H5	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H6	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCA-110-H6	1992	REPLACEMENT	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 18, 1992
 Sheet 7 of 9

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
90-3108F WA C13907, C13908, C13909, C13913,
C13914
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System RESIDUAL HEAT REMOVAL SYSTEM 149G CLASS 1

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H26	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCA-110-H26	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H1	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCA-110-H1	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H15	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01636	N/A	DCA-110-H15	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H16	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01640	N/A	DCA-110-H16	1973	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H17	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01329	N/A	DCA-110-H17	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H18	1982	REPLACED	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI


1. Owner Pennsylvania Power & Light Co. Date May 18, 1992
Name
- Two North Ninth St., Allentown, PA 18101 Sheet 8 of 9
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
- PO Box 467, Berwick, PA 18603 90-3108F WA C13907, C13908, C13909, C13913,
Address C13914
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
- Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address
- Expiration Date N/A
4. Identification of System RESIDUAL HEAT REMOVAL SYSTEM 149G CLASS 1
5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements '19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	02850	N/A	DCA-110-H18	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H22	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02580	N/A	DCA-110-H22	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H23	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02662	N/A	DCA-110-H23	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H24	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02603	N/A	DCA-110-H24	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H25	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01265	N/A	DCA-110-H25	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-110-H27	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02568	N/A	DCA-110-H27	1978	REPLACED	N/A

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 18, 1992
Name
- Two North Ninth St., Allentown, PA 18101 Sheet 9 of 9
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
- PO Box 467, Berwick, PA 18603 90-3108F WA C13907, C13908, C13909, C13913,
Address C13914
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
- Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address
- Expiration Date N/A
4. Identification of System RESIDUAL HEAT REMOVAL SYSTEM 149G CLASS 1
5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-108-H6	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCA-108-H6	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-108-H10	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01233	N/A	DCA-108-H10	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-108-H11	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02610	N/A	DCA-108-H11	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-108-H12	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01291	N/A	DCA-108-H12	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 15, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 2
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR 91-9080A, PMR 91-9080B, PMR 86-9080,
Address WAs U13059, U23003
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System RESIDUAL HEAT REMOVAL, SYSTEM 149G, CLASS I

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, NA Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
24" - 900# VALVE DISC	ANCHOR DARLING	*K3501 SEE REMARKS	N/A	HV-151F015B	1988	REPLACED	YES
24" - 900# VALVE DISC	ANCHOR DARLING	*K3501	N/A	HV-151F015B	1992	REPAIR	YES
24" - 900# VALVE DISC	ANCHOR DARLING	*K3501	N/A	HV-151F015B	1992	REPLACEMENT	YES
24" - 900# VALVE DISC	ANCHOR DARLING	17	N/A	HV-151F015A	1976	REPLACED	YES
24" - 900# VALVE DISC	ANCHOR DARLING	J1269	N/A	HV-151F015A	1992	REPLACEMENT	YES
24" - 900# VALVE BODY	ANCHOR DARLING	16	N/A	HV-151F015A	1976	REPAIR	YES

7. Description of Work Replaced valve disc and installed wear strips. Drilled 1/8" hole in valve disc.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure SE-159-031/032
 Other Pressure 1022 psi Test Temp. 141 °F SE-149-201/202

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE DATA REPORT ATTACHED.

Applicable Manufacturer's Data Reports to be attached

EXISTING DISC FOR VLV HV-151F015B WAS REINSTALLED AFTER DRILLING OF 1/8" PRESSURE RELIEF HOLE. REPAIR CONSISTED OF INSTALLING A SEAL PLUG OVER A BROKEN DRILL BIT

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. _____ N/A Expiration Date _____ N/A

Signed [Signature] Date July 20, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-14-92 to 3-28-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NB 7525 PA 269 NBT
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992

Sheet 2 of 2

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE

PMR 91-9080A, PMR 91-9080B, PMR 86-9080,
 WAs U13059, U23003
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A


Expiration Date N/A

4. Identification of System RESIDUAL HEAT REMOVAL, SYSTEM 149G, CLASS I

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, NA Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
LEAKOFF PLUG ON 24" GATE VALVE	ANCHOR DARLING	NA	N/A	HV-151F015A	NA	REPLACED	NO
LEAKOFF PLUG ON 24" GATE VALVE	ENERGY STEEL	HEAT CODE CJG	N/A	HV-151F015A	1992	REPLACEMENT	NO



FORM N-1 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCE

As required by the Provisions of the ASME Code, Section III, Div. 1

Author/Darling Valve Co., 701 Fifth St., Allentown, Pa. 18104
 Pennsylvania Power & Light Co., 1111 Locust Hill, Allentown, Pa. 18104
 Drawing No. B12143
 (b) Description of Part Inspected Disc, Heat No. V9608
 (c) Applicable ASME Code Section III, Edition 1971, Addenda date Wnt '72, Case No. N/S
 3. Remarks 24"-900#-FW Gate
 A/DY S.O. P-C513-1
 Note: No Disc Hydro Performed

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III. (The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenance is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)


Date 3/8 1988 Signed Anchor/Darling Valve Co. By B. Krusei
 Certificate of Authorization Expires 4/15/89 Certificate of Authorization No. N1713

CERTIFICATION OF DESIGN FOR APPURTENANCE (when applicable)
 Design information on file at _____
 Stress analysis report on file at _____
 Design specifications certified by _____ Prof. Eng. State _____ Reg. No. _____
 Stress analysis report certified by _____ Prof. Eng. State _____ Reg. No. _____

CERTIFICATE OF SHOP INSPECTION
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of ~~Massachusetts~~ Pennsylvania and employed by Commercial Union Insurance Company of Boston, Mass. have inspected the part of a pressure vessel described in this Partial Data Report on 3-9-88 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 3-9 1988
 Charles Valting Commission Pennsylvania 2392
 No. 88-1377
 CASE 4 OF 44

* Supplemental sheets on form N-10, sheets of drawings may be used provided (1) size is 8 1/2" x 11", (2) information on sheet 1-3 on this form report is repeated on each sheet, and (3) each sheet is numbered and number of sheets is printed on sheet 1-3 "Number".

1137220



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 29, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 1 of 2
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 PMR 89-9153A WAs C13698, C13699, C13700,
Address C13701, C13702 and DCP 89-3049A WA C13505
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address
 Expiration Date N/A

4. Identification of System RESIDUAL HEAT REMOVAL, SYSTEM 149A, CLASS II

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, NA Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PUMP 1P-202A / SEAL PIPING	INGERSOLL RAND	573308* SEE REMARKS	NA	FF 61862 SHT 1	1973	REPLACED	YES
PUMP 1P-202A / SEAL PIPING	PPL	573308	NA	FF 61862 SHT 1	1992	REPLACEMENT	NO
PUMP 1P-202B / SEAL PIPING	INGERSOLL RAND	573309	NA	FF61862 SHT 1	1973	REPLACED	YES
PUMP 1P-202B / SEAL PIPING	PPL	573309	NA	FF61862 SHT 1	1992	REPLACEMENT	NO
PUMP 1P-202C / SEAL PIPING	INGERSOLL RAND	573310	NA	FF61862 SHT 1	1973	REPLACED	YES
PUMP 1P-202C / SEAL PIPING	PPL	573310	NA	FF61862 SHT 1	1992	REPLACEMENT	NO

7. Description of Work REPLACE SEAL PIPING FOR RHR PUMPS 1P-202A,B,C AND D AND MODIFY SUPPORT

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure *A' 320 / *B' 280 psi Test Temp. *75° / 75° °F *A' LOOP AND *B' LOOP

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks SERIAL NUMBERS SHOWN ARE FOR PUMP ASSEMBLIES: 1P-202A, 1P-202B, 1P-202C AND
Applicable Manufacturer's Data Reports to be attached
1P-202D, WHICH INCLUDED THE SEAL PIPING.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed S. S. Lal Date July 16, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO.
of WALTHAM, MASSACHUSETTS have inspected the components described
in this Owner's Report during the period 8-14-91 to 4-9-92, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

John J. Daulany Commissions NB 7525 PA 2159 NE
Inspector's Signature National Board, State, Province, and Endorsements

Date July 23 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 29, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 2 of 2
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 PMR 89-9153A WAs C13698, C13699, C13700,
C13701, C13702 and DCP 89-3049A WA C13505
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System RESIDUAL HEAT REMOVAL, SYSTEM 149A, CLASS II

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, NA Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PUMP 1P-202D / SEAL PIPING	INGERSOLL RAND	573311	NA	FF61862 SHT 1	1973	REPLACED	YES
PUMP 1P-202D / SEAL PIPING	PPL	573311	NA	FF61862 SHT 1	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBB-110-H27	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	GBB-110-H27	1992	REPLACEMENT	NO



.. ..
.. ..

3
0

2

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date 6 July, 1992

Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

DCP 88-3031
 WA #S: C13097, C13100, & C13101
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A

4. Identification of System Residual Heat Removal System 149B III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, 1567* Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
3', 150#, S.S. FLG'D GATE VALVE	ANCHOR DARLING	EB323-1-18	N/A	1-12-084	1990	REPLACEMENT	YES
LARGE PIPE DRAIN ASSEMBLY	PP&L	NONE	N/A	HRC-112-1	1991	REPLACEMENT	NO
LARGE PIPE SUPPORT	BECHTEL	NONE	N/A	HBD-1125-H8	1982	REPLACED	NO
MECHANICAL SHOCK	PACIFIC SCIENTIFIC	17222	N/A	HBD-1125-H8	N/A	REPLACED	NO

* CODE CASE 1567 IS FOR VALVE 1-12-084

7. Description of Work Addition of new 3" drain to RHRSW HX inlet header & permanent removal of snubber.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 185 psi Test Temp. 68 °F SE-116-311

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE DATA REPORT(S) ATTACHED

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed *SK Hat* Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT


CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-20-91 to 14-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David Daubney Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 1992



FORM NPV-1 (back)

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
Bonnet Studs HT #8875009	SA193-B7	Texas Bolt Company	
Bonnet Nuts HT #6014728	SA194-2H	Texas Bolt Company	
(d) Other Parts			
Disc HT. #A326 S/N 63 & 64	SA479-316L	LTV Steel	

8. Hydrostatic test 425 psi.

CERTIFICATION OF DESIGN

Design information on file at Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
 Stress analysis report on file at N/A
 Design specifications certified by D. Sattar (1) Prof. Eng. State PA Reg. No. 019525E
 Stress analysis report certified by N/A (1) Prof. Eng. State _____ Reg. No. _____
 (1) Signature not required. List name only.

We certify that the statements made in this report are correct.


Date 8/21 19 90 signed Anchor/Darling Valve Co. by R.L. Stannett
(Manufacturer)
 Certificate of Authorization No. N1712 expires 4/15/92

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of ~~PA~~ Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass. have inspected the equipment described in this Data Report on 4-1172-8-21 19 90, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.
 By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 8-21 19 90

Charles Young (Inspector) Commissions Pennsylvania 2392
(National Board, State, Province and No.)



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date May 12, 1992
 Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 PMR 90-3108L / WA C23224
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System RESIDUAL HEAT REMOVAL SYSTEM 149D CLASS II

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	DCB-102-H2	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCB-102-H2	1992	REPLACEMENT	NO

7. Description of Work SNUBBER REDUCTION PROGRAM UNIT 1

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure NO TESTING REQUIRED
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CALCULATION SR-885

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SKILLIAN Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 4-22-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David D. Sullivan Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 1992

**FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI**

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date May 15, 1992
 Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 DCP#90-31081 WA#s C13835 & C14118
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System RCIC PUMP-TURBINE SYSTEM 150B CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-105-H2001	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13969-81	N/A	SP-DBA-105-H2001	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-105-H2001	1992	REPLACEMENT	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	12181-80	N/A	SP-DBA-105-H2001	1980	REPLACEMENT	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-105-H2002	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	23586-81	N/A	SP-DBA-105-H2002	1981	REPLACED	N/A

7. Description of Work SNUBBER REDUCTION PROJECT

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure No Testing Required
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE CASE# N-122, N-319, & N-411

Applicable Manufacturer's Data Reports to be attached

CALC#SR-951-1 & 5857

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SKUAT Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-13-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Clair Daubney Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date JULY 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date July 17, 1992

Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE

 PMR#91-3019 WA#C13978 & C13980
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A

4. Identification of System R.C.I.C. TURBINE - PUMP SYSTEM 150B CLASS II

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, - Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
VALVE BODY	ANCHOR DARLING	E848	N/A	HV150F045	1976	REPLACED	YES
VALVE BODY	ANCHOR DARLING	U3894	N/A	HV150F045	1988	REPLACEMENT	YES
DISC	ANCHOR DARLING	E855	N/A	HV150F045	1976	REPLACED	NO
DISC	ANCHOR DARLING	1	N/A	HV150F045	1992	REPLACEMENT	YES
GASKET RETAINING RING	ANCHOR DARLING	HT.# 244079	N/A	HV150F045	1976	REPLACED	NO
GASKET RETAINING RING	ANCHOR DARLING	HT.# L01816	N/A	HV150F045	1988	REPLACEMENT	NO

7. Description of Work Replaced Valve Body, Disc, & Gasket Retaining Ring on HV150F045(PMR#91-3019)

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 1580 psl Test Temp. 69 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE DATA REPORT(S) ATTACHED

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed S. S. Lal Date July 20, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 1-23-92 to 4-24-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Clair Daullany Commissions NB 2525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 1992

1
2
3
4

14
15
16



Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
	N/A		
(d) Other Parts			
Gasket Retaining Ring Ht. 244079	SA106-B	Keystone Tubular Service Corp.	

8. Hydrostatic test 3250 psi.

CERTIFICATION OF DESIGN

Design information on file at Bechtel Corp., Box 3965, San Francisco, Calif. 94119
 Stress analysis report on file at N/A Class 2
 Design specifications certified by Frederick C. A. Dowsett (1) Prof. Eng. State Pa. Reg. No. 19854-E
 Stress analysis report certified by N/A Class 2 (1) Prof. Eng. State _____ Reg. No. _____
 (1) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date 3/19 19 76 Signed Anchor/Darling Valve Co. R. L. Stannert
 (Manufacturer) R. L. Stannert

Certificate of Authorization No. N779 expires 3-4-77

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of ~~Massachusetts~~ Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass. have inspected the equipment described in this Data Report on 3-21-76 3-22 19 76, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 3-22 19 76


Russell E. Montgomery Commissions Pennsylvania WC972
 (Inspector) (National Board, State, Province and No.)
Russell E. Montgomery

1028

128

Printed in U.S.A. (6/72)

This form (E37) is obtainable from the ASME, 345 E. 47th St., New York, N.Y. 10017



FORM N-2 NPT CERTIFICATE HOLDER DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. 1

1. (a) Manufactured by Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
(Name and address of NPT Certificate Holder)

(b) Manufactured for Pennsylvania Power & Light Co., 2 N. 9th St., Allentown, PA 18101
(Name and address of N Certificate Holder for completed nuclear component)

2. Identification-Certificate Holder's Serial No. of Part S/N U3894 Nat'l Bd. No. N/A

(a) Constructed According to Drawing No. D12798 Drawing Prepared by Anchor/Darling Valve Compa

(b) Description of Part Inspected Body, Heat No. 4745A SA216-WCB

(c) Applicable ASME Code Section III, Edition 1971, Addenda date Wnt '72, Case No. N/A Class 2

3. Remarks 4"-900#-Globe
(Brief description of service for which component was designed)
A/DV Shop Order P-D456-1

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III.
(The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Date 5/9 19 88 Signed Anchor/Darling Valve Co. By R. L. Starnett
(NPT Certificate Holder)

Certificate of Authorization Expires -4/15/89 Certificate of Authorization No. N1713

CERTIFICATION OF DESIGN FOR APPURTENANCE (when applicable)

Design information on file at _____

Stress analysis report on file at _____

Design specifications certified by _____ Prof. Eng. State _____ Reg. No. _____

Stress analysis report certified by _____ Prof. Eng. State _____ Reg. No. _____

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of ~~XXXXXX~~ Pennsylvania and employed by Commercial Union Insurance Company of Boston, Mass. have inspected the part of a pressure vessel described in this Partial Data Report on 2-23-88 thru 5-9-88 19 88 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certifiacn, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.


Date 5-9 19 88

Charles Young Commissions Pennsylvania 2392
National Board, State, Province and No.

No. 88-0035
RECORD PACKAGE
PAGE 5 OF 55

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2" x 11", (2) information on items 1-3 on this sheet is attached on each sheet, and (3) each sheet is numbered and number of sheets is furnished to rule 2. "Reference".

8 9 0 2 7 2 3 0 4 0 2



8 9 1 1 1 1 1 5 4 8

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*

As required by the Provision of the ASME Code Rules, Section III, Div. 1

- 1. (a) Manufactured by Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
(Name and address of NPT Certificate Holder)
- (b) Manufactured for Pennsylvania Power & Light Co., 2 N. 9th St., Allentown, PA 18101
(Name and address of N Certificate Holder for completed nuclear component)
- 2. Identification-Certificate Holder's Serial No. of Part N/A Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No. C12270 Drawing Prepared by Anchor/Darling Valve Company
- (b) Description of Part Inspected Gasket Retaining Ring, Heat No. L01816 SA106-B
- (c) Applicable ASME Codes Section III, Edition 1971, Addenda date Wnt '72, Case No. N/A Class 2
- 3. Remarks: 4"-900#-Globe
(Brief description of service for which component was designed)
A/DV S.O. P-D364-4

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III. (The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Date 4/4 19 88 Signed Anchor/Darling Valve Co. By R L Starnett
(NPT Certificate Holder)
Certificate of Authorization Expires 4/15/89 Certificate of Authorization No. N1713

CERTIFICATION OF DESIGN FOR APPURTENANCE (when applicable)

Design information on file as _____

Stress analysis report on file as _____

Design specifications certified by _____ Prof. Eng. State _____ Reg. No. _____

Stress analysis report certified by _____ Prof. Eng. State _____ Reg. No. _____

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of ~~XXXXXX~~ Pennsylvania and employed by Commercial Union Insurance Company of Boston, Mass. have inspected the part of a pressure vessel described in this Partial Data Report on 2-10-88 4-4-88 1988 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.


By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4-4 19 88

Charles Young Commissions Pennsylvania 2392
National Board, State, Province and No.

No. 88-05
 RECORD PACKAGE
 PAGE 10 OF 2

*Supplemental sheets in form of data, sketches or drawings may be used provided (1) size is 8 1/2" x 11", (2) information on items 1-2 on this Data Report is repeated on each sheet, and (3) each sheet is clearly and legibly numbered in pencil at the top & "Bottom".



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*

As required by the Provision of the ASME Code Rules, Section III, Div. 1

1. (a) Manufactured by Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
(Name and address of NPT Certificate Holder)
- (b) Manufactured for Pennsylvania Power & Light Company, 2 N. 9th St., Allentown, PA 18101
(Name and address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holder's Serial No. of Part S/N - 1 / Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No. C23507 Drawing Prepared by Anchor/Darling Valve Company
- (b) Description of Part Inspected Disc, Heat No. A204A / SA105
- (c) Applicable ASME Codes: Section III, Edition 1971, Addenda date Wnt '72, Case No. --- Class 2
3. Remarks: 4"-900#-Globe
(Brief description of service for which component was designed)

A/DV Shop Order E-T094-1

Reference to Disc Subassembly Drawing B65666

Note: No Disc Hydro Performed

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III.
 (The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Date 1/10 1992 Signed Anchor/Darling Valve Co. By R. S. Stannett
(NPT Certificate Holder)

Certificate of Authorization Expires 4/15/92 Certificate of Authorization No. N1713

CERTIFICATION OF DESIGN FOR APPURTENANCE (when applicable)

Design information on file at _____

Stress analysis report on file at _____

Design specifications certified by _____ Prof. Eng. State _____ Reg. No. _____

Stress analysis report certified by _____ Prof. Eng. State _____ Reg. No. _____

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Pennsylvania and employed by Commercial Union Insurance Company of Boston, Mass. have inspected the part of a pressure vessel described in this


Partial Data Report on 11-12-91 / 1-10-92 1992, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 1-10 1992

Charles Young
 Charles Young
 Commissions Pennsylvania 2392
National Board, State, Province and No.

*Supplemental sheets in form of data, sketches or drawings may be used provided (1) size is 4 1/4" x 11", (2) information in items 1-1 on this Data Report is entered on each sheet, and (3) each sheet is numbered and number of sheets is reported in item 2, "Remarks".



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 15, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 1 of 1
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 PMR 91-9082A,91-9082B WAS C23026, C23025
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System CORE SPRAY. SYSTEM 151A, CLASS I

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, NA Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
12" VALVE DISC	ANCHOR DARLING	*E738	N/A	HV-152-F005A	1975	REPLACED	YES
12" VALVE DISC	ANCHOR DARLING	E738	N/A	HV-152-F005A	1992	REPLACEMENT	YES
12" VALVE DISC	ANCHOR DARLING	*E737	N/A	HV-152-F005B	1976	REPLACED	YES
12" VALVE DISC	ANCHOR DARLING	E737	N/A	HV-152-F005B	1992	REPLACEMENT	YES

7. Description of Work DRILL 1/8" DIA. HOLE IN VALVE DISC

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure SE-159-034 / 035
 Other Pressure 1000 psi Test Temp. 141 °F SE-151-201 / 202

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks EXISTING DISCs FOR HV152F005A AND HV152F005B WERE REINSTALLED AFTER
Applicable Manufacturer's Data Reports to be attached
DRILLING OF 1/8" PRESSURE RELIEF HOLES.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed 810 J Lal Date July 20, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of
WALTHAM, MASSACHUSETTS have inspected the components described
in this Owner's Report during the period 2-14-92 to 4-30-92, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

David Doubling Commissions NB 7525 PA 2159 NJ
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 13, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 1 of 2
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP#90-31081 WA# C13834
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address
Expiration Date N/A

4. Identification of System HPCI TURBINE & AUX. 152B CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-102-H2001	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	18580-81	N/A	SP-DBA-102-H2001	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-102-H2018	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	02824-78	N/A	SP-DBA-102-H2018	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-102-H2018	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-102-H2019	1982	REPLACED	NO

7. Description of Work SNUBBER REDUCTION PROJECT

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure No Testing Required
Other Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE CASE#s N-122, N-319, & N-411.

Applicable Manufacturer's Data Reports to be attached

CALC. #SR-5856

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp

N/A

Certificate of Authorization No.

N/A

Expiration Date

N/A

Signed

[Signature]
Owner or Owners Designee, Title SUPERINTENDENT OF PLANT

Date

July 16, 1992

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-13-92 to 4-3-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature]
Inspector's Signature

Commissions

NB 7525 PA 2159 NI
National Board, State, Province, and Endorsements

Date July 22 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 13, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 2 of 2
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP#90-31081 WA# C13834
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System HPCI TURBINE & AUX. 152B CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PCAIFIC SCIENTIFIC	02409-77	N/A	SP-DBA-102-H2019	1977	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-102-H2019	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date July 16, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 1
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 89-9158A- C13474 AND C13475
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System HIGH PRESSURE COOLANT INJECTION SYSTEM 152 CLASS II

5. (a) Applicable Construction Code III 19 71 Edition, thru W72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
VALVE	ANDERSON GREENWOOD	N83034	2063	IC-PT-15601-TEST	1991	REPLACEMENT	YES
VALVE	ANDERSON GREENWOOD	N83035	2064	IC-PT-15601	1991	REPLACEMENT	YES
VALVE	ANDERSON GREENWOOD	N83036	2065	OP1-PT-15601	1991	REPLACEMENT	YES
VALVE	ANDERSON GREENWOOD	N83037	2066	1-DRAIN-PT-15601	1991	REPLACEMENT	YES
TUBING	PP&L	N/A	N/A	JD-28-1-5	1992	REPLACEMENT	NO
PIPE	PP&L	N/A	N/A	SP-DBB-114-1	1992	REPLACEMENT	NO

7. Description of Work INSTALL HPCI STOP VALVE BALANCE CHAMBER TRANSMITTER

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 1540 psi Test Temp. 59 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE DATA REPORT(S) ATTACHED

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. _____ N/A Expiration Date _____ N/A

Signed SK Slad Date July 17, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 6-14-91 to 7-15-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David Daubney Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date JUL 22 19 92

9A0EBK UJHT 2S0E87

1. Manufactured and certified by ANDERSON, GREENWOOD & CO., 3950 GREENRIAR, STAFFORD, TX, 77477

2. Manufactured for PENNSYLVANIA POWER & LIGHT CO., TWO NORTH NINTH STREET, ALLENTOWN, PA 18101

3. Location of installation SUSQUEHANNA STEAM ELECTRIC STATION, 5 MILES NE OF BERMICK ON US RT 11, BERMICK, PA 18603

4. Model No., Series No., or Type H7HS-3TC-N Drawing H06-0025-002 Rev. (D) CRN N.A.

5. ASME Code, Section III, Division 1: 1983 S-85 2 N.A.


6. Pump or valve VALVE Nominal inlet size 3/8 Outlet size 3/8

7. Material: Body SA479-316 Bonnet SA479-316 Gasket A276-316(BALL) Bolting N.A.

9121020210

(a) Cert. Holder's Serial No.	(b) Serial No.	(c) Serial No.	(d) Serial No.	(e) Serial No.
N83025	2054	A934-19	A667	13405
N83026	2055	A934-20	A667	13405
N83027	2056	A934-55	A667	13405
N83028	2057	A934-58	A667	13405
N83029	2058	A934-01	A667	13405
N83030	2059	A934-15	A667	13405
N83031	2060	A934-42	A667	13405
N83032	2061	A934-37	A667	13405
N83033	2062	A934-46	A667	13405
N83034	2063	A934-25	A667	13405
N83035	2064	A934-26	A667	13405
N83036	2065	A934-52	A667	13405
N83037	2066	A934-24	A667	13405
N83038	2067	A934-39	A667	13405
N83039	2068	A934-38	A667	13405
N83040	2069	A934-54	A667	13405
N83041	2070	A934-68	A667	13405
N83042	2071	A934-70	A667	13405
N83043	2072	A934-29	A667	13405
N83044	2073	A934-58	A667	13405
N83045	2074	A934-107	A667	13405
N83046	2075	A934-29	A667	13405
N83047	2076	A934-14	A667	13405
N83048	2077	A934-70	A667	13405
N83049	2078	A934-66	A667	13405

* Supplemental information in form of test, sketches, or drawings may be used provided (1) also to 6% of 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NO. 1
 PREPARED BY THE PROVISIONS OF THE ASME CODE, SECTION III, DIVISION 1
 CERTIFICATE HOLDER'S SERIAL NO. 64088N THRU N3049

1. Design conditions _____ 3460 _____ psi _____ 800 _____ °F or valve pressure class _____ 2500# _____ (1)

2. Cold working pressure _____ 6000 _____ psi _____ 1000 _____ °F

10. Hydrostatic test _____ 9000 _____ psi _____ 6000 _____ psi

11. Remarks: _____

CERTIFICATION OF DESIGN

Design Specification certified by PAUL D. MARINSHAW P.E. State TX Reg. no. 49874
 Design Report certified by N-A P.E. State N-A Reg. no. N-A

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N-2823 Expires 9-10-93

Date 6-28-91 Name ANDERSON, GREENWOOD AND CO. Signed [Signature]
(N Certificate Holder) (Authorized representative)

CERTIFICATE OF INSPECTION


I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of TEXAS and employed by G.I.C. of BOSTON, MA have inspected the pump, or valve, described in this Data Report on 6-28-91 and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the competence described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind, arising from or connected with this inspection.

Date 6-28-91 Signed Sharon Hall Commission No. NB88257 - TX 1425
(Authorized Inspector) (Part 2E, Subpart 2E.1, and Code of Laws of Texas)

(1) For manually operated valves only.

9121020211



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 18, 1992
Name
Two North Ninth St., Allentown, PA 18101
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603
Address

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101
Address

4. Identification of System Emergency Service Water System 154A Class III

5. (a) Applicable Construction Code III 19 71 Edition, W '72 Addenda, NA Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

1" Check Valve	Yarway	A4726	N/A	1-10-112	1978	Replaced	Yes
Pipe Support	Bechtel	N/A	N/A	SP-HRC-110-H2012	N/A	Replaced	No
Pipe Support	Bechtel	N/A	N/A	SP-JRD-128-H2	N/A	Replaced	No
Pipe Support	Bechtel	N/A	N/A	SP-JRD-128-H2017	N/A	Replaced	No
1" Sch. XXS Pipe	Bechtel	N/A	N/A	SP-HRC-110-6	N/A	Replaced	No
1" S.W. Pipe Cap	PP&L	N/A	N/A	HRC-110	N/A	Replacement	No

7. Description of Work Cut and cap to remove a section of 1" HRC-110 ESW Keepfill piping. (SEE REMARKS)

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Under SE-054-301
 Other Pressure 130 psi Test Temp. 50 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks DCP 89-3015D,88-3047A ,89-9153A / WAs C04034,C13442,C13698,C13703,C13704,

Applicable Manufacturer's Data Reports to be attached

C13705,C13706

(# 7) DESCRIPTION OF WORK: INSTALL BLIND (PANCAKE) INSERTS TO REPLACE RS 11189A,B,C,D

AND FE 11189A,B,C,D

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 11-6-90 to 4-2-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NB 7525 PA 2159 NE
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 18, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 2 of 3
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A


4. Identification of System Emergency Service Water System 154A Class III

5. (a) Applicable Construction Code III 19 71 Edition, W '72 Addenda, NA Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pipe Support	Bechtel	N/A	N/A	SP-HRC-120-H2003	N/A	Replaced	No
RS 11189A	Bechtel	NA	NA	SP-HRC-126-5	NA	REPLACED	NO
BLIND (PANCAKE) INSERTS	PPL	NA	NA	SP-HRC-126-5	1992	REPLACEMENT	NO
FE 11189A	VICKERY-SIMMS	NA	NA	SP-HRC-127-2	NA	REPLACED	NO
BLIND (PANCAKE) INSERTS	PPL	NA	NA	SP-HRC-127-2	1992	REPLACEMENT	NO
RS 11189B	BECHTEL	NA	NA	SP-HRC-123-2	NA	REPLACED	NO
BLIND (PANCAKE) INSERTS	PPL	NA	NA	SP-HRC-123-2	1992	REPLACEMENT	NO
FE 11189B	VICKERY-SIMMS	NA	NA	SP-HRC-124-2	NA	REPLACED	NO
BLIND (PANCAKE) INSERTS	PPL	NA	NA	SP-HRC-124-2	1992	REPLACEMENT	NO
RS 11189C	NA	NA	NA	SP-HRC-130-1	NA	REPLACED	NO
BLIND (PANCAKE) INSERTS	PPL	NA	NA	SP-HRC-130-1	1992	REPLACEMENT	NO





FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 6 July, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 1
Address
 2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3005
Address WA'S: C04410 & C04412
Repair Organization P.O. No., Job No., etc.
 3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System EMERGENCY SERVICE WATER 154A-III
 5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
LARGE PIPE SUB ASSEMBLY	PP&L	NONE	N/A	HRC-101-1	1991	REPLACEMENT	NO
SMALL PIPE DRAIN ASSEMBLY	PP&L	NONE	N/A	SP-HRC-101-2	1991	REPLACEMENT	NO
2", 150#, S.S. BALL VALVE	JAMESBURY	ND-286829-03H	N/A	1-11-172	1990	REPLACEMENT	YES

5.a, (cont'd): CONSTRUCTION CODE FOR VALVE 1-11-172 IS:
 ASME SECTION III, 1974 EDTION THRU WINTER 1975 ADDENDA.

7. Description of Work INSTALLATION OF NEW ESW SUPPLY HEADER 2" DRAIN
 8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 195 psi Test Temp. 68 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Manufacturer's Data Report; Form NPV-1, is attached.

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed S. J. Slatt Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-1-91 to 2-15-91, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer make any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David Daubney Commissions NB 7525 PA2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date JULY 22 19 92

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NU R PUMPS OR V
As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Neles-Jamesbury, Inc. 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two Ninth St., Allentown, PA
(Name and Address of Purchaser or Owner)
3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electr
(Name and Address)
4. Pump or Valve Ball Valve Nominal Inlet Size 2" Outlet Size (inch)


	(a) Model No.	(b) N Certificate Holder's	(c) Canadian	(d) Drawing	(e) Class	(f) Nat'l.
	Series No	Serial	Registration	No.		Bd. No.
	or Type	No.	No.			
(1)	6150 ND-286829-03G	N/A	ND286829-03 Rev. A	3	N/A	
(2)	6150 ND-286829-03H	N/A	ND286829-03 Rev. A	3	N/A	
(3)	6150 ND-286829-03J	N/A	ND286829-03 Rev. A	3	N/A	
(4)	6150 ND-286829-03K	N/A	ND286829-03 Rev. A	3	N/A	
(5)	6150 ND-286829-03L	N/A	ND286829-03 Rev. A	3	N/A	
(6)	6150 ND-286829-03M	N/A	ND286829-03 Rev. A	3	N/A	
(7)	6150 ND-286829-03N	N/A	ND286829-03 Rev. A	3	N/A	
(8)	6150 ND-286829-03P	N/A	ND286829-03 Rev. A	3	N/A	
(9)	6150 ND-286829-03Q	N/A	ND286829-03 Rev. A	3	N/A	
(10)						

5. Service Water
(Brief description of service for which equipment was designed)
*Station, 5 Mi NE of Berwick on U.S. RT 11
- Design Conditions Seat 170 150
Body 275 100 150
(Pressure) (Temperature) °F or Valve Pressure Class
7. Cold Working Pressure 275 psi at 100°F.
8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
	ASME SA		
(1) RAN-7	351 Grade CF3M	Shell Cast Corp.	Body
(2) RAM-5	351 Grade CF3M	Shell Cast Corp.	Body
(3) RAM-12	351 Grade CF3M	Shell Cast Corp.	Body
(4) RAM-9	351 Grade CF3M	Shell Cast Corp.	Body
(5) RAN-3	351 Grade CF3M	Shell Cast Corp.	Body
(6) RAN-8	351 Grade CF3M	Shell Cast Corp.	Body
(7) RAM-14	351 Grade CF3M	Shell Cast Corp.	Body
(8) RAM-3	351 Grade CF3M	Shell Cast Corp.	Body
(9) RAM-16	351 Grade CF3M	Shell Cast Corp.	Body
(b) Forgings- Castings			
	ASME SA		
(1) RAS-28	351 Grade CF3M	Shell Cast Corp.	Body Cap
(2) RAS-27	351 Grade CF3M	Shell Cast Corp.	Body Cap
(3) RAS-6	351 Grade CF3M	Shell Cast Corp.	Body Cap
(4) RAS-37	351 Grade CF3M	Shell Cast Corp.	Body Cap
(5) RAS-11	351 Grade CF3M	Shell Cast Corp.	Body Cap
(6) RAP-4	351 Grade CF3M	Shell Cast Corp.	Body Cap
(7) RAS-19	351 Grade CF3M	Shell Cast Corp.	Body Cap
(8) RAS-42	351 Grade CF3M	Shell Cast Corp.	Body Cap
(9) RAS-12	351 Grade CF3M	Shell Cast Corp.	Body Cap

(1) For manually operated valves only.

Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.



Mark No.	Material Spec. No.	Manufacturer	
(c) Bolting	ASME SA		
007	193 Gr. B8	Nova Machine	S
	ASME SA		
006	194 Gr. 8	Nova Machine	He:
(d) Other Parts	ASME SA		
RAB	479 TYPE 316	Neles-Jamesbury	Bal

9. Hydrostatic test 425 psi. Disk Differential test pressure ----- psi. ND-286829-03G, 03H, 03N, 03P,

CERTIFICATE OF COMPLIANCE


We certify that the statements made in this report are correct and that this pump, or valve, conform construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1 Addenda Winter '75 (Date), Code Case No. NONE, Date 11 Dec 90
 Signed Neles-Jamesbury Inc. by Daniel P. Parker (N Certificate holder)
 Our ASME Certificate of Authorization No. N-1228 to use the N symbol expires (N)

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Two N. Ninth St.,
 Stress analysis report (Class I only) on file at N/A
 Design specifications certified by (1) Dale Sattar
 PE State PA Reg. No. PE 019525E
 Stress analysis certified by (1) N/A
 PE State N/A Reg. No. N/A
 (1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessels and the State or Province of MASS and employed by Protection Mutual of Norwood, Mass have inspected the pump, or valve, described in this Data Report on DEC 11 19 90, and state that to the best of my knowledge and belief, the N Certificate Holder constructed this pump, or valve, in accordance with the ASME Code, Section III.
 By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, for the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be held liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 12-11 19 90
[Signature] (Inspector) Commissions MA-1301 PAWC 333 (Natl Bd., State, Prov. and No.)



**FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI**

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992
Sheet 1 of 10

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
DCP: 89-3027, 89-3028 WA: C13574, C13575,
C13576, C13577, C13580, C13581, C13582, CONT'D.
= Air Organization PO No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
Authorization No. N/A
Expiration Date N/A

4. Identification of System EMERGENCY SERVICE WATER SYSTEM 154A CLASS III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
LARGE PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	HRC-123-1	82	REPLACED	YES
LARGE PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	HRC-123-1	92	REPLACEMENT	NO
LARGE PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	HRC-123-2	82	REPLACED	YES
LARGE PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	HRC-123-2	92	REPLACEMENT	NO
LARGE PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	HRC-124-1	82	REPLACED	YES
LARGE PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	HRC-124-1	92	REPLACEMENT	NO

7. Description of Work MODIFIED ESW SUPPLY AND RETURN LINES TO ECCS AND RCIC ROOM COOLERS.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure 194 / 195 psi Test Temp. 74 / 66 °F (LOOP "A" / LOOP "B")

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE DATA REPORT(S) ATTACHED

Applicable Manufacturer's Data Reports to be attached

WA's (cont'd.): C13583, C13572, C13573, C13578, C13579

APPL. CODES: Piping = ASME III 1971 thru W'72 addenda with Code Case N316 Valves = ASME III
1974 W'75 addenda, and ASME III 1974 (no addenda)

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed *St. Mal* Date July 17, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 7-5-91 to 4-5-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.


John Daullany Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 15, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 2 of 10
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP: 89-3027, 89-3028 WA: C13574, C13575,
Address C13576, C13577, C13580, C13581, C13582, CONT'D.
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address
Expiration Date N/A
4. Identification of System EMERGENCY SERVICE WATER SYSTEM 154A CLASS III
5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
LARGE PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	HRC-126-1	82	REPLACED	YES
LARGE PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	HRC-126-1	92	REPLACEMENT	NO
LARGE PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	HRC-127-1	82	REPLACED	YES
LARGE PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	HRC-127-1	92	REPLACEMENT	NO
LARGE PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	HRC-130-1	82	REPLACED	YES
LARGE PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	HRC-130-1	92	REPLACEMENT	NO
LARGE PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	HRC-131-1	82	REPLACED	YES
LARGE PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	HRC-131-1	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-117-1	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-117-1	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-117-2	82	REPLACED	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992

Sheet 3 of 10

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE

DCP: 89-3027, 89-3028 WA: C13574, C13575, C13576, C13577, C13580, C13581, C13582, CONT'D.
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A


Expiration Date N/A

4. Identification of System EMERGENCY SERVICE WATER SYSTEM 154A CLASS III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-117-2	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-118-1	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-118-1	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-118-2	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-118-2	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-119-3	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-119-3	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-119-5	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-119-5	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-120-3	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-120-3	92	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 15, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 4 of 10
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP: 89-3027, 89-3028 WA: C13574, C13575,
Address C13576, C13577, C13580, C13581, C13582, CONT'D.
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System EMERGENCY SERVICE WATER SYSTEM 154A CLASS III
5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-120-5	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-120-5	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-121-1	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-121-1	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-121-2	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-121-2	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-122-1	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-122-1	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-122-2	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-122-2	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-125-1	82	REPLACED	YES

... ..

...

...




... ..

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 15, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 5 of 10
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP: 89-3027, 89-3028 WA: C13574, C13575,
Address C13576, C13577, C13580, C13581, C13582, CONT'D.
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System EMERGENCY SERVICE WATER SYSTEM 154A CLASS III
5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-125-1	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-125-2	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-125-2	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-126-1	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-126-1	92	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-126-2	82	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-126-2	92	REPLACEMENT	NO
2" GLOBE VALVE	YARWAY	5706	N/A	1-11-108	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01A	N/A	1-11-108	91	REPLACEMENT	YES
2" GLOBE VALVE	YARWAY	5744	N/A	1-11-109	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-328996-01J	N/A	1-11-109	92	REPLACEMENT	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date July 15, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 6 of 10
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP: 89-3027, 89-3028 WA: C13574, C13575,
Address C13576, C13577, C13580, C13581, C13582, CONT'D.
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System EMERGENCY SERVICE WATER SYSTEM 154A CLASS III
5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2" GLOBE VALVE	YARWAY	5764	N/A	1-11-110	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01B	N/A	1-11-110	91	REPLACEMENT	YES
2" GLOBE VALVE	YARWAY	5697	N/A	1-11-111	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-328996-01K	N/A	1-11-111	92	REPLACEMENT	YES
2" GLOBE VALVE	YARWAY	5760	N/A	1-11-114	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01C	N/A	1-11-114	91	REPLACEMENT	YES
2" GLOBE VALVE	YARWAY	5759	N/A	1-11-115	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-328996-01M	N/A	1-11-115	92	REPLACEMENT	YES
2" GLOBE VALVE	YARWAY	5767	N/A	1-11-116	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01E	N/A	1-11-116	91	REPLACEMENT	YES
2" GLOBE VALVE (boundary change)	YARWAY	5708	N/A	1-11-117	76	REPLACED (TO 134E III)	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 15, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 7 of 10
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP: 89-3027, 89-3028 WA: C13574, C13575,
Address C13576, C13577, C13580, C13581, C13582, CONT'D.
Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System EMERGENCY SERVICE WATER SYSTEM 154A CLASS III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2" GLOBE VALVE	YARWAY	5723	N/A	1-11-118	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01G	N/A	1-11-118	91	REPLACEMENT	YES
2" GLOBE VALVE	YARWAY	5704	N/A	1-11-119	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-328996-01P	N/A	1-11-119	92	REPLACEMENT	YES
2" GLOBE VALVE	YARWAY	5751	N/A	1-11-120	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01H	N/A	1-11-120	91	REPLACEMENT	YES
2" GLOBE VALVE (boundary change)	YARWAY	5735	N/A	1-11-121	76	REPLACED (TO 134F III)	YES
2" GLOBE VALVE	YARWAY	5717	N/A	1-11-122	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01J	N/A	1-11-122	91	REPLACEMENT	YES
2" GLOBE VALVE	YARWAY	5705	N/A	1-11-123	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-328996-01R	N/A	1-11-123	92	REPLACEMENT	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 15, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 8 of 10
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP: 89-3027, 89-3028 WA: C13574, C13575,
Address C13576, C13577, C13580, C13581, C13582, CONT'D.
Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System EMERGENCY SERVICE WATER SYSTEM 154A CLASS III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2" GLOBE VALVE	YARWAY	5768	N/A	1-11-124	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01K	N/A	1-11-124	91	REPLACEMENT	YES
2" GLOBE VALVE	YARWAY	5712	N/A	1-11-125	76	REPLACED	YES
2" BALL VALVE	NELES-JAMESBURY	ND-328996-01S	N/A	1-11-125	92	REPLACEMENT	YES
3" BUTTERFLY VALVE	JAMESBURY	ND-21305-08-A	N/A	1-11-126A	76	REPLACED	YES
3" BALL VALVE	NELES-JAMESBURY	ND-288249-02A	N/A	1-11-126A	91	REPLACEMENT	YES
3" BUTTERFLY VALVE	JAMESBURY	ND-21305-08-E	N/A	1-11-126B	77	REPLACED	YES
3" BALL VALVE	NELES-JAMESBURY	ND-288249-02B	N/A	1-11-126B	91	REPLACEMENT	YES
3" BUTTERFLY VALVE	JAMESBURY	ND-21305-08-C	N/A	1-11-126C	76	REPLACED	YES
3" BALL VALVE	NELES-JAMESBURY	ND-288249-02C	N/A	1-11-126C	91	REPLACEMENT	YES
3" BUTTERFLY VALVE	JAMESBURY	ND-21305-08-D	N/A	1-11-126D	76	REPLACED	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 15, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 9 of 10
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP: 89-3027, 89-3028 WA: C13574, C13575,
Address C13576, C13577, C13580, C13581, C13582, CONT'D.
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System EMERGENCY SERVICE WATER SYSTEM 154A CLASS III
5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
3" BALL VALVE	NELES-JAMESBURY	ND-288249-02D	N/A	1-11-126D	91	REPLACEMENT	YES
2" BALL VALVE (boundary change)	NELES-JAMESBURY	ND-288249-01F	N/A	1-11-150	91	REPLACEMENT (from 134E III)	YES
2" BALL VALVE (boundary change)	NELES-JAMESBURY	ND-288249-01D	N/A	1-11-151	91	REPLACEMENT (from 134F III)	YES
3" BALL VALVE	NELES-JAMESBURY	ND-288249-02E	N/A	1-11-158A	91	REPLACEMENT (NEW)	YES
3" BALL VALVE	NELES-JAMESBURY	ND-288249-02F	N/A	1-11-158B	91	REPLACEMENT (NEW)	YES
3" BALL VALVE	NELES-JAMESBURY	ND-288249-02G	N/A	1-11-158C	91	REPLACEMENT (NEW)	YES
3" BALL VALVE	NELES-JAMESBURY	ND-288249-02H	N/A	1-11-158D	91	REPLACEMENT (NEW)	YES
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01L	N/A	1-11-159	91	REPLACEMENT (NEW)	YES
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01M	N/A	1-11-160	91	REPLACEMENT (NEW)	YES
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01N	N/A	1-11-161	91	REPLACEMENT (NEW)	YES
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01P	N/A	1-11-162	91	REPLACEMENT (NEW)	YES



**FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI**

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date June 15, 1992
Sheet 10 of 10

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
DCP: 89-3027, 89-3028 WA: C13574, C13575,
C13576, C13577, C13580, C13581, C13582, CONT'D.
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
Authorization No. N/A
Expiration Date N/A

4. Identification of System EMERGENCY SERVICE WATER SYSTEM 154A CLASS III

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01Q	N/A	1-11-163	91	REPLACEMENT (NEW)	YES
2" BALL VALVE	NELES-JAMESBURY	ND-288249-01R	N/A	1-11-164	91	REPLACEMENT (NEW)	YES



FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Neles-Jamesbury, Inc. 640 Lincoln St., Worcester, MA 01605
(Name and Address of N. Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric
(Name and Address)
4. Pump or Valve Ball Valve Nominal Inlet Size 2 Outlet Size 2
(inches) (inches)

	(a) Model No. Series No or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No	(e) Class	(f) Nat'l. Std No.	(g) Year Built
(1)	6150	ND-288249-01A	N/A	ND-288249-01	Rev. A 3	N/A	1991
(2)	6150	ND-288249-01B	N/A	ND-288249-01	Rev. A 3	N/A	1991
(3)	6150	ND-288249-01C	N/A	ND-288249-01	Rev. A 3	N/A	1991
(4)	6150	ND-288249-01D	N/A	ND-288249-01	Rev. A 3	N/A	1991
(5)	6150	ND-288249-01E	N/A	ND-288249-01	Rev. A 3	N/A	1991
(6)	6150	ND-288249-01F	N/A	ND-288249-01	Rev. A 3	N/A	1991
(7)	6150	ND-288249-01G	N/A	ND-288249-01	Rev. A 3	N/A	1991
(8)	6150	ND-288249-01H	N/A	ND-288249-01	Rev. A 3	N/A	1991
(9)	6150	ND-288249-01J	N/A	ND-288249-01	Rev. A 3	N/A	1991
(10)	6150	ND-288249-01K	N/A	ND-288249-01	Rev. A 3	N/A	1991

5. Emergency Water Service
(Brief description of service for which equipment was designed)
*Station, 5 1/2 mi NE of Warwick on U.S. RT 11
Seat 177 125
6. Design Conditions Body 275 psi 100 °F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)
Std Working Pressure 275 psi at 100°F.
6. Pressure Retaining Pieces

	Mart No.	Material Spec No ASME-SA	Manufacturer	Remarks
(1)	(a) Castings RAL-21	351 Gr. CF3M	Shellcast Corp.	Body
(2)	RAN-6	351 Gr. CF3M	Shellcast Corp.	Body
(3)	RAN-5	351 Gr. CF3M	Shellcast Corp.	Body
(4)	RAL-27	351 Gr. CF3M	Shellcast Corp.	Body
(5)	RAL-29	351 Gr. CF3M	Shellcast Corp.	Body
(6)	RAL-19	351 Gr. CF3M	Shellcast Corp.	Body
(7)	RAL-7	351 Gr. CF3M	Shellcast Corp.	Body
(8)	RAN-1	351 Gr. CF3M	Shellcast Corp.	Body
(9)	RAL-17	351 Gr. CF3M	Shellcast Corp.	Body
(10)	RAL-6	351 Gr. CF3M	Shellcast Corp.	Body
(1)	RAS-24	351 Gr. CF3M	Shellcast Corp.	Cap
(2)	(b) Forgings RAS-39	351 Gr. CF3M	Shellcast Corp.	Cap
(3)	RAP-1	351 Gr. CF3M	Shellcast Corp.	Cap
(4)	RAP-3	351 Gr. CF3M	Shellcast Corp.	Cap
(5)	RAP-2	351 Gr. CF3M	Shellcast Corp.	Cap
(6)	RAS-36	351 Gr. CF3M	Shellcast Corp.	Cap
(7)	RAR-1	351 Gr. CF3M	Shellcast Corp.	Cap
(8)	RAR-5	351 Gr. CF3M	Shellcast Corp.	Cap
(9)	RAR-4	351 Gr. CF3M	Shellcast Corp.	Cap
(10)	RAS-18	351 Gr. CF3M	Shellcast Corp.	Cap

(1) For manually operated valves only.

P.P. & L. Doc No. 45

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

Part No	Material Spec. No	Manufacturer	Remarks
(c) Bolting			
	ASME-SA		
007	193 Gr. B8	Nova Machine	Stud (All Valves)
006	194 Gr. 8	Nova Machine	Nut (All Valves)
(d) Other Parts			
	ASME-SA		
RAT	479 TYPE 316	Neles-Jamesbury	Ball (All Valves)

Hydrostatic test 425 psi. Disk Differential test pressure ----- psi ND-288249-01A Thru 01H, 01J, 01K

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components Section III, Div. 1, Edition 1974.

Addenda Winter - 75 Code Case No NONE Date 9/27/91

Signed Neles-Jamesbury Inc. by Gerald P. Menard
(In Certificate holder)

Our ASME Certificate of Authorization No N-1226 to use the N symbol expires 10/27/93
(Date)

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Tw: N. Ninth St., Allentown,

Stress analysis report (Class I only) on file at N/A

Design specifications certified by (1) Dale Sattar

PE State PA Reg No PE 019525E

Stress analysis certified by (1) N/A

PE State N/A Reg No N/A

(1) Signature not required List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of MASS and employed by Protection Mutual of Norwood, Mass have inspected the pump, or valve, described in this Data Report on Jan 9 19 91, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Jan 9 19 91
M. S. Thibault (Inspector) Commissions MA1207 PA 2758
(Name, State, Prov. and No.)

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Neles-Jamesbury, Inc. 640 Lincoln St., Worcester; MA 01605
(Name and Address of N Certificate Holder)
 Manufactured for Pennsylvania Power & Light Co., Two Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
 3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric
(Name and Address)
 4. Pump or Valve Ball Valve Nominal Inlet Size 2 Outlet Size 2
(inch) (inch)

	(a) Model No.	(b) N Certificate Holder's	(c) Canadian	(d) Drawing	(e) Class	(f) Nat'l.	(g) Year
	Series No	Serial	Registration	No		Ed No.	Built
	or Type	No.	No	No			
(1)	6150	ND-288249-01 L.	N/A	ND-288249-01	Rev. A 3	N/A	1991
(2)	6150	ND-288249-01 M.	N/A	ND-288249-01	Rev. A 3	N/A	1991
(3)	6150	ND-288249-01 N.	N/A	ND-288249-01	Rev. A 3	N/A	1991
(4)	6150	ND-288249-01 P.	N/A	ND-288249-01	Rev. A 3	N/A	1991
(5)	6150	ND-288249-01 Q.	N/A	ND-288249-01	Rev. A 3	N/A	1991
(6)	6150	ND-288249-01 R.	N/A	ND-288249-01	Rev. A 3	N/A	1991
(7)	6150	ND-288249-01 S.	N/A	ND-288249-01	Rev. A 3	N/A	1991
(8)	6150	ND-288249-01 T.	N/A	ND-288249-01	Rev. A 3	N/A	1991
(9)	6150	ND-288249-01 U.	N/A	ND-288249-01	Rev. A 3	N/A	1991
(10)	6150	ND-288249-01 V.	N/A	ND-288249-01	Rev. A 3	N/A	1991

5. Emergency Water Service
(Brief description of service for which equipment was designed)
*Station, 5 Mi NE of Berwick on U.S. RT 11.

6. Design Conditions Seat 177 125
Body 275 100 °F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)
 - Cold Working Pressure 275 psi at 100°F.
 Pressure Retaining Pieces

	Mark No.	Material Spec No ASME-SA	Manufacturer	Remarks
(1)	(a) Castings RAM-8	351 Gr. CF3M	Shellcast Corp.,	Body
(2)	RAL-5	351 Gr. CF3M	Shellcast Corp.	Body
(3)	RAL-11	351 Gr. CF3M	Shellcast Corp.	Body
(4)	RAL-33	351 Gr. CF3M	Shellcast Corp.	Body
(5)	RAL-13	351 Gr. CF3M	Shellcast Corp.	Body
(6)	RAM-13	351 Gr. CF3M	Shellcast Corp.	Body
(7)	RAL-22	351 Gr. CF3M	Shellcast Corp.	Body
(8)	RAL-2	351 Gr. CF3M	Shellcast Corp.	Body
(9)	RAL-4	351 Gr. CF3M	Shellcast Corp.	Body
(10)	RAL-16	351 Gr. CF3M	Shellcast Corp.	Body
(1)	RAS-23	351 Gr. CF3M	Shellcast Corp.	Cap
(2)	(b) Forgings RAS-25	351 Gr. CF3M	Shellcast Corp.	Cap
(3)	RAS-21	351 Gr. CF3M	Shellcast Corp.	Cap
(4)	RAR-6	351 Gr. CF3M	Shellcast Corp.	Cap
(5)	RAS-14	351 Gr. CF3M	Shellcast Corp.	Cap
(6)	RAS-40	351 Gr. CF3M	Shellcast Corp.	Cap
(7)	RAS-26	351 Gr. CF3M	Shellcast Corp.	Cap
(8)	RAS-41	351 Gr. CF3M	Shellcast Corp.	Cap
(9)	RAS-33	351 Gr. CF3M	Shellcast Corp.	Cap
(10)	RAR-8	351 Gr. CF3M	Shellcast Corp.	Cap

(1) For manually operated valves only.

P.P. & L. Doc No. 45

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

Mark No	Material Spec. No	Manufacturer	Remarks
(c) <u>Bolting</u>	ASME-SA		
<u>007</u>	<u>193 Gr. B 8</u>	<u>Nova Machine</u>	<u>Stud (All Valves)</u>
<u>006</u>	<u>194 Gr. 8</u>	<u>Nova Machine</u>	<u>Nut (All Valves)</u>
(d) <u>Other Parts</u>	ASME-SA		
<u>RAT</u>	<u>479 TYPE 316</u>	<u>Neles-Jamesbury</u>	<u>Ball (All Valves)</u>

9 Hydrostatic test 425 psi. Disk Differential test pressure ----- psi. ND-288249-01L Thru 01P, 01Q Thru 01V

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components Section III, Div. 1, Edition 1974.
 Addenda Winter - 75, Code Case No NDNE, Date 7 27 1991
 Signed Neles-Jamesbury Inc. by Gerald P. Menard
(In Certificate Holder)
 Our ASME Certificate of Authorization No N-122E to use the N symbol expires 10/27/93
(N) Date:

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Two N. Ninth St., Allentown,
 Stress analysis report (Class I only) on file at N/A

Design specifications certified by (1) Dale Sattar
 PE State PA Reg No PE 019525E
 Stress analysis certified by (1) N/A
 PE State N/A Reg No N/A

(1) Signature not required List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of MASS and employed by Protection Mutual of Norwood, Mass have inspected the pump, or valve, described in this Data Report on JAN 9 1991, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Factory Mutual System

Date JAN 9 1991
M. J. [Signature] Commissions MA 1207 PA 275E
(Inspector) (Net Bd. State, Prov and No)

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES
As Required by the Provisions of the ASME Code, Section Div. 1

1. Manufactured by Neles-Jamesbury, Inc. 640 Lincoln St., Worcester, MA 01615
(Name and Address of N Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two N. Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric *
(Name and Address)
4. Pump or Valve Ball Valve Nominal Inlet Size 3 Outlet Size 3
(inch) (inch)

	(a) Model No. Series No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
(1)	6150	ND288249-02 A	N/A	ND-288249-02Rev.A	3	N/A	1991
(2)	6150	ND288249-02 B	N/A	ND-288249-02Rev.A	3	N/A	1991
(3)	6150	ND288249-02 C	N/A	ND-288249-02Rev.A	3	N/A	1991
(4)	6150	ND288249-02 D	N/A	ND-288249-02Rev.A	3	N/A	1991
(5)	6150	ND288249-02 E	N/A	ND-288249-02Rev.A	3	N/A	1991
(6)	6150	ND288249-02 F	N/A	ND-288249-02Rev.A	3	N/A	1991
(7)	6150	ND288249-02 G	N/A	ND-288249-02Rev.A	3	N/A	1991
(8)	6150	ND288249-02 H	N/A	ND-288249-02Rev.A	3	N/A	1991
(9)							
(10)							

5. Emergency Water Service

*Station, 5M1 NE of Berwick on U.S. Rt. 11
(Brief description of service for which equipment was designed)

6. Design Conditions Seat 177 125oF
Body 275 100 psi °F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)

7. Cold Working Pressure 275 psi at 100°F.

8. Pressure Retaining Pieces

	Mark No.	Material Spec. No.	Manufacturer	Remarks
(1)	(a) Castings RCJ-7	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Body
(2)	RCJ-15	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Body
(3)	RCJ-17	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Body
(4)	RCH-1	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Body
(5)	RCJ-14	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Body
(6)	RCJ-13	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Body
(7)	RCH-3	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Body
(8)	RCJ-11	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Body
(1)	RCK-11	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Cap
(2)	(b) Forgings- RCK-6	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Cap
(3)	RCK-24	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Cap
(4)	RCK-18	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Cap
(5)	RCK-21	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Cap
(6)	RCK-16	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Cap
(7)	RCK-12	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Cap
(8)	RCK-9	ASME SA 351 Gr. CF3M	Neles-Jamesbury	Cap

or manually operated valves only.

P.P. & L. DOC. NO. 45

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

Mark No	Material Spec. No.	Manufacturer	Remarks
(c) Bolting	ASME - SA		
QP5	193 Gr. B8	Nova Machine	Stud (All Valves)
QQ1	194 Gr. 8	Nova Machine	Nut (All Valves)
(d) Other Parts	ASME - SA		
PZW	479 TYPE 316	Neles-Jamesbury	Ball (All Valves)

9. Hydrostatic test 425 psi. Disk Differential test pressure ----- psi. ND-288249-02A, 02B, 02C, 02D, 02E, 02F, 02G, 02H.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1974.
 Addenda Winter - 75, Code Case No. NONE. Date 25 APRIL 91.
 Signed Neles-Jamesbury, Inc. by Ronald P. Parker
(N Certificate Holder)
 Our ASME Certificate of Authorization No. N-1228 to use the N symbol expires 10/27/93.
(Date)

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Two N. Ninth St., Allentown, PA 181C
 Stress analysis report (Class I only) on file at N/A

Design specifications certified by (1) Dale Sattar
 PE State PA Reg. No. PE 019525E
 Stress analysis certified by (1) N/A
 PE State N/A Reg. No. N/A

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Massachusetts and employed by Protection Mutual of Norwood, MA have inspected the pump, or valve, described in this Data Report on April 25 19 91, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4-25 19 91
Ronald P. Parker (Inspector) Commissions MA-1418
(Natl. Bd., State, Prov. and No.)

Factory Mutual SystemsTM

FORM NPV-1-N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Neles-Jamesbury, Inc., 640 Lincoln St., Worcester, MA 01605
(Name and Address of N Certificate Holder)
2. Manufactured for Pennsylvania Power & Light Co., Two North Ninth St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
3. Location of Installation Pennsylvania Power & Light Co., Susquehanna Steam Electric
(Name and Address)
4. Pump or Valve Ball Valve Nominal Inlet Size 2 Outlet Size 2
(Inch) (Inch)

(a) Model No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Mark. Ed. No.	(g) Year Built
(1) R21	ND-328996-01J	N/A	ND-328996-01Rev. D	3	N/A	1992
(2) R21	ND-328996-01K	N/A	ND-328996-01Rev. D	3	N/A	1992
(3) R21	ND-328996-01M	N/A	ND-328996-01Rev. D	3	N/A	1992
(4) R21	ND-328996-01N	N/A	ND-328996-01Rev. D	3	N/A	1992
(5)						
(6) R21	ND-328996-01P	N/A	ND-328996-01Rev. D	3	N/A	1992
(7) R21	ND-328996-01R	N/A	ND-328996-01Rev. D	3	N/A	1992
(8) R21	ND-328996-01S	N/A	ND-328996-01Rev. D	3	N/A	1992
(9)						
(10)						

5. Emergency Service Water System
(General description of service for which equipment was designed)
*Station, 5MI NE of Berwick on U.S. Mill

6. Design Conditions Seat 177 1980
Body 275 100° °F or Valve Pressure Class 150 (1)
(Pressure) (Temperature)
7. Code Working Pressure 275 psi at 100°F.
8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Comments
(a) Castings			
	ASME-SA		
(1) RHV-1	351 Gr. CF8M	Pennsylvania Steel	Body
(2) RHV-6	351 Gr. CF8M	Pennsylvania Steel	Body
(3) RHV-5	351 Gr. CF8M	Pennsylvania Steel	Body
(4) RHT-1	351 Gr. CF8M	Pennsylvania Steel	Body
(5)			
(6) RHV-2	351 Gr. CF8M	Pennsylvania Steel	Body
(7) RHV-6	351 Gr. CF8M	Pennsylvania Steel	Body
(8) RHV-3	351 Gr. CF8M	Pennsylvania Steel	Body
(b) Forgings			
	ASME-SA		
(1) RKA-14	351 Gr. CF8M	Southern Tool	Segment
(2) RKA-21	351 Gr. CF8M	Southern Tool	Segment
(3) RKA-29	351 Gr. CF8M	Southern Tool	Segment
(4) RKA-1	351 Gr. CF8M	Southern Tool	Segment
(5)			
(6) RKA-15	351 Gr. CF8M	Southern Tool	Segment
(7) RKA-31	351 Gr. CF8M	Southern Tool	Segment
(8) RKA-27	351 Gr. CF8M	Southern Tool	Segment

NO. 01-0151
RECORD PACKAGE
PAGE 10 OF 93

(1) For manually operated valves only.

*Supplemental information in the form of "iss. sketches, or drawings may be used provided they also include a title block information in Form 1 through 4 on this Data Report is included on each sheet, the each sheet is numbered and the number of sheets is recorded at the top of this form, and (d) each additional sheet shall be signed by the Certificate Holder and the ASME.

FORM NPV-1 (Back)

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting	ASME-SA		
8078476	193 Grade B7	Nova Machine	Hex Hd. Cap Screw (All Valves)
(d) Other Parts	ASME-SA		
(1) RKK-8	240 Type 316	Jessop Steel Co.	End Plate
(2) RKK-12	240 Type 316	Jessop Steel Co.	End Plate
(3) RKK-16	240 Type 316	Jessop Steel Co.	End Plate
(4) RKK-1	240 Type 316	Jessop Steel Co.	End Plate
(5)			
(6) RKK-9	240 Type 316	Jessop Steel Co.	End Plate
(7) RKK-18	240 Type 316	Jessop Steel Co.	End Plate
(8) RKK-14	240 Type 316	Jessop Steel Co.	End Plate

9. Hydraulic test 425 psi. Disk Differential test pressure _____ psi. MD-328996-01J, 01K, 01M, 01N, 01P, 01R, 01S

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. 1, Edition 1974.

Addenda None Code Case No. None Date 24 Feb 93

Signed Neles-Jamesbury, Inc. by Donald P. Parker

(in Certificate Holder's Name)

Our ASME Certificate of Authorization No. N-1228 to use the N symbol expires Oct. 27, 1993

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Co., Two North Ninth St., Allentown PA 08101

Stress analysis report (Class T-only) on file at _____

Design specifications certified by (1) Frank J. Cxyz

PE State PA Reg. No. PE-0250-49E

Stress analysis certified by (1) N/A

PE State N/A Reg. No. N/A

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Massachusetts and employed by Protection Mutual of Norwood, Massachusetts have inspected the pump, or valve, described in this Data Report on 2-26 1993, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-27 1993

Factory Mutual Systems

(Part of Data, Form, and No.)

NO. 42-0151
RECORD PACKAGE
PAGE 1 of 1

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 25, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 1 of 3
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 PMR# 89-9153C / WA#S C13916 THRU C13919
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System EMERGENCY SERVICE WATER, SYSTEM 154A, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HBC-139-1	1982	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HBC-139-1	1992	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HBC-139-3	1982	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HBC-139-3	1992	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HBC-139-4	1982	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HBC-139-4	1992	REPLACEMENT	NO

7. Description of Work ADDED FLANGES TO THE EXISTING ESW SUPPLY AND RETURN LINES TO THE RHR PUMPS A THRU D

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure SEE REMARKS psi Test Temp. SEE REMARKS °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks LOOP 'A' HYDRO: 194 PSIG, 74.8° F; LOOP 'B' HYDRO: 195 PSIG, 66.0° F

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SKILLAL Date July 16, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 1-27-92 to 4-9-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David Daulberry Commissions NB 7525 PA 2159 NE
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 25, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 2 of 3
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 PMR# 89-9153C / WA#S C13916 THRU C13919
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A


4. Identification of System EMERGENCY SERVICE WATER, SYSTEM 154A, CLASS III


5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HBC-140-1	1982	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HBC-140-1	1992	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HBC-140-2	1982	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HBC-140-2	1992	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HBC-140-4	1982	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HBC-140-4	1992	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-123-1	1982	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-123-1	1992	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-123-7	1982	REPLACED	YES
SMALL PIPE SUB-ASSEMBLY	PP&L	N/A	N/A	SP-HRC-123-7	1992	REPLACEMENT	NO
SMALL PIPE SUB-ASSEMBLY	BECHTEL	N/A	N/A	SP-HRC-124-1	1982	REPLACED	YES





FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 12, 1992

Sheet 1 of 1

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

PMR 90-3108L / WA C23170
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A

4. Identification of System PRIMARY CONTAINMENT SYSTEM 159A CLASS II

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
CONTAINMENT LINER PLATE	CHICAGO BRIDGE & IRON	PA. SPECIAL PV4665	N/A	PA. I.D. N° 469479	1976	REPAIR	NO

7. Description of Work SNUBBER REDUCTION PROJECT UNIT 1 ADDED STIFFENERS

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure NO TESTING REQUIRED
Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CIVIL CALCULATION EF-C-DMG-151

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPAIR conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SKLAL Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 3-11-92 to 4-25-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David Doulling Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date July 16, 1992
 Sheet 1 of 2

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 90-3051A - C13456, C13457, C13458, C13459
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System SUPPRESSION POOL AND AUXILIARY SYSTEM 159A CLASS II

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72. Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
VALVE	ANDERSON GREENWOOD	N83025	2054	OP1-PT-15729A	1991	REPLACEMENT	YES
VALVE	ANDERSON GREENWOOD	N83028	2057	1-DRAIN-PT-15729A	1991	REPLACEMENT	YES
5 VALVE MANIFOLD	ANDERSON GREENWOOD	N14978	N/A	IC1-PT-15729A IC1-PT-15729A-EQ	1991	REPLACEMENT	YES
TUBING	PP&L	N/A	N/A	JD-27-1-2A	1982 1992	REPLACE REPLACEMENT	NO
VALVE	ANDERSON GREENWOOD	N83026	2055	1-DRAIN-PT-15729B	1991	REPLACEMENT	YES
VALVE	ANDERSON GREENWOOD	N83027	2056	OP1-PT-15729B	1991	REPLACEMENT	YES

7. Description of Work INSTALL SUPPRESSION POOL DIV I AND DIV II PRESSURE TRANSMITTERS

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 72 psi Test Temp. AMBIENT °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE DATA REPORT(S) ATTACHED

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SK Hall Date July 17, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 6-21-91 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David Doullany Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date JULY 22 19 92

**FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI**

1. Owner Pennsylvania Power & Light Co. Date July 16, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 2 of 2
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 90-3051A - C13456, C13457, C13458, C13459
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System SUPPRESSION POOL AND AUXILIARY SYSTEM 159A CLASS II

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72. Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
5 VALVE MANIFOLD	ANDERSON GREENWOOD	N14981	N/A	IC1-PT-15729B IC1-PT-15729B-EQ	1991	REPLACEMENT	YES
TUBING	PP&L	N/A	N/A	JD-25-1-3B	1982 1992	REPLACE REPLACEMENT	NO




FORM NPV-1 CERTIFICATE HOLDER'S DATA REPORT FOR VALVE PUMPS
 Required by the Provisions of the ASME Code, Section III, Division 1
 Pg. 1 of 2

1. Manufactured and certified by ANDERSON, GREENWOOD & CO., 3950 GREENBRIAR, STAFFORD, TX. 77477
 2. Manufactured for PENNSYLVANIA POWER & LIGHT CO., TWO NORTH NINTH STREET, ALLENTOWN, PA 18101
 3. Location of installation SUSQUEHANNA STEAM ELECTRIC STATION, 5 MILES NE OF BERWICK ON US RT 11, BERWICK, PA 18603
 4. Model No., Series No., or Type HZHS-3TC-N Drawing K06-G025-002 Rev. ① CPM N/A
 5. ASME Code, Section III, Division 1: 1983 S-85 2 N/A
 6. Pump or valve VALVE Nominal inlet size 3/8 Outlet size 3/8
 7. Material: Body SA479-316 Bonnet SA479-316 Cast A276-316(BALL) Boring N/A

913103010

(a) Cert. Holder's Serial No.	(b) Mater. Board No.	(c) Body Series No.	(d) Bonnet Serial No.	(e) Disk Serial No.
N83025	2054	A934-19	A667	13405
N83026	2055	A934-71	A667	13405
N83027	2056	A934-56	A667	13405
N83028	2057	A934-68	A668	13405
N83029	2058	A934-03	A667	13405
N83030	2059	A934-16	A667	13405
N83031	2060	A934-42	A667	13405
N83032	2061	A934-37	A667	13405
N83033	2062	A934-46	A667	13405
N83034	2063	A934-25	A667	13405
N83035	2064	A934-26	A667	13405
N83036	2065	A934-52	A667	13405
N83037	2066	A934-24	A667	13405
N83038	2067	A934-39	A667	13405
N83039	2068	A934-36	A667	13405
N83040	2069	A934-54	A667	13405
N83041	2070	A934-98	A667	13405
N83042	2071	A934-20	A667	13405
N83043	2072	A934-49	A667	13405
N83044	2073	A934-58	A667	13405
N83045	2074	A934-10	A667	13405
N83046	2075	A934-29	A667	13405
N83047	2076	A934-14	A668	13405
N83048	2077	A934-70	A667	13405
N83049	2078	A934-66	A667	13405

* Supplemental information in form of text, sketches, or drawings may be used provided (1) also is 6 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of the form.



ASME B31.3
Certificate Holder's Serial No. 133025 THRU 1183049

8. Design conditions 3460 psi 800 °F or valve pressure class 2500# (1)
9. Cold working pressure 6000 psi at 100°F
10. Hydrostatic test 9000 psi; Disk differential test pressure 6600 psi
11. Remarks: _____

CERTIFICATE OF DESIGN

Design Specification certified by PAUL D. MARINSHAW P.E. State TX Reg. no. 49874
Design Report certified by N-A P.E. State N-A Reg. no. N-A

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.
N Certificate of Authorization No. N-2823 Expires 9-10-93

Date 6-28-91 Name ANDERSON, GREENWOOD AND CO. Signed [Signature]
(N Certificate Holder) (Authorized representative)

CERTIFICATE OF INSPECTION


I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TEXAS and employed by C.U.I.C.
of BOSTON, MA have inspected the pump, or valve, described in this Data Report on 6-28-91 and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.


By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6-28-91 Signed Sharon Hall Commission No. 1138954 TX 1425
(Authorized Inspector) (Not. St. and undersigned) and state of prov. and no.)

(1) For manually operated valves only.

1120201616





FURN NPV-1 (back)

Part No.	Material Spec. No.	Manufacturer	Remarks
(c) Rollings	N/A		
(d) Other Parts			
NO2-8264-002	SA479-316	Gulfalloy	Pipe plug 1/8"
NO2-8264-004	SA479-316	Gulfalloy	Pipe plug 1/8"
NO2-2583-002	SA479-316	AGCO	Bonnet
NO2-8247-501	SA479-316	AGCO	Body
NO2-1519-002	SA213-316	AGCO	Tube
NO2-8274-001	A276-316	Ultraspherics	Ball

A. Hydrostatic test 5400 psi.

CERTIFICATION OF DESIGN

Design information on file at Anderson, Greenwood & Company
 Stress analysis report on file at N/A
 Design specifications certified by Lawrence S. Loomer (I) Prof. Eng. State PA Reg. No. 19875-E
 Stress analysis report certified by N/A (I) Prof. Eng. State N/A Reg. No. N/A
 (I) Signature not required. List name only.


We certify that the statements made in this report are correct.

Date 6/24 1982 Signed Anderson, Greenwood By Joseph A. Pascho
(Manufacturer) & Co.
 Certificate of Authorization No. 2203 expires 8/4/84

CERTIFICATE OF SIOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Texas and employed by C.U.I.C. of Boston, Mass. have inspected the equipment described in this Data Report on June 24 1982, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6-24 1982
Mattew V. Pollock Commission Tx. 1037 PE-W WC # 2825
(Inspector) (National Board, State, Province and No.) 1053 exp



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 7 July, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 3
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR 90-3035C/D WA# C14085, C14086
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS II.
5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1" GLOBE VALVE	BORG WARNER	15326	N/A	144F008A	1976	REPLACED	YES
1" GLOBE VALVE	BORG WARNER	15298	N/A	144F008B	1976	REPLACED	YES
1" GLOBE VALVE	BORG WARNER	15399	N/A	144F009A	1976	REPLACED	YES
1" GLOBE VALVE	BORG WARNER	15403	N/A	144F009B	1976	REPLACED	YES
1" GLOBE VALVE	BORG WARNER	851W1204	N/A	144F010A	1987	REPLACED	YES
1" GLOBE VALVE	BORG WARNER	851W1208	N/A	144F010B	1987	REPLACED	YES

7. Description of Work REMOVAL OF PIPING, VALVES, AND HANGERS. REPLACEMENT UNDER 161B III
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Manufacturer's Data Reports; Forms NPV-1 are attached.

Applicable Manufacturer's Data Reports to be attached

These valves were all permanently removed from 161B-II, and are now added to 161B-III.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed *SK Stal* Date July 16, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 3-7-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

D. J. Daull Commissions NB 7525 PA 2159 NE
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date 6 July, 1992

Sheet 2 of 3

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

PMR 90-3035C/D WA# C14085, C14086
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A


Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS II.

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1" GLOBE VALVE	BORG WARNER	15397	N/A	144F011A	1976	REPLACED	YES
1" GLOBE VALVE	BORG WARNER	851W1205	N/A	144F011B	1987	REPLACED	YES
SMALL PIPE ASSEMBLY	BECHTEL	N/A	N/A	SP-DCB-124-1	1982	REPLACED	YES
SMALL PIPE ASSEMBLY	BECHTEL	N/A	N/A	SP-DCB-124-2	1982	REPLACED	YES
SMALL PIPE ASSEMBLY	BECHTEL	N/A	N/A	SP-DCB-124-3	1982	REPLACED	YES
SMALL PIPE ASSEMBLY	BECHTEL	N/A	N/A	SP-DCB-124-4	1982	REPLACED	YES
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-124 H-2000	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-124 H-2001	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-124 H-2002	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-124 H-2003	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-124 H-2004	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date 2 July, 1992
 Sheet 3 of 3

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 PMR 90-3035C/D WA# C14085, C14086
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS II.

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-124 H-2005	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-124 H-2006	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-124 H-2007	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-124 H-2008	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-124 H-2009	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP DCB-124 H-2010	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date 15 July, 1992

Sheet 1 of 14

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

PMR 90-3035C/D * SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components
SEE PAGE 13 FOR EXCEPTIONS TO CONSTRUCTION CODE

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

9

4" GATE VALVE	ANCHOR DARLING	E5853-109-4	N/A	144F043A	1976	REPLACED	YES
4" GATE VALVE	ANCHOR DARLING	ET044-3-1	N/A	144F043A	1992	REPLACEMENT	YES
4" GATE VALVE	ANCHOR DARLING	E5853-109-2	N/A	144F043B	1976	REPLACED	YES
4" GATE VALVE	ANCHOR DARLING	ET044-3-2	N/A	144F043B	1992	REPLACEMENT	YES
4" GATE VALVE	ANCHOR DARLING	E5853-109-3	N/A	144F005A	1976	REPLACED	YES
4" GATE VALVE	ANCHOR DARLING	ET044-3-3	N/A	144F005A	1992	REPLACEMENT	YES

7. Description of Work REPLACEMENT OF PUMPS, VALVES, AND PIPING FOR THE RWCU SYSTEM.

8. Tests Conducted: * Hydrostatic Pneumatic Nominal Operating Pressure * SEE PAGE 14 *
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CODE DATA REPORT(S) ATTACHED

Applicable Manufacturers Data Reports to be attached

WA# C14071, C14072, C14089, C14090, C14091, C14092, C14097, C14098, C14100, C14103, C23060.

CODE DATA REPORTS NOT REQ'D FOR PUMPS 1P221A / B (CASE, MOTOR, & HEAT EXCHANGER

VALVE 144F012A REPAIRED BY ANCHOR DARLING VIA SERVICE ORDER S-14829-5

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SK Hall Date July 17, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 1-20-92 to 4-21-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David Doulbany Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date July 6, 1992
Sheet 2 of 14

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
PMR 90-3035C/D * SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
Authorization No. N/A
Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
4" GATE VALVE	ANCHOR DARLING	E5853-109-1	N/A	144F005B	1976	REPLACED	YES
4" GATE VALVE	ANCHOR DARLING	ET044-3-4	N/A	144F005B	1992	REPLACEMENT	YES
3" CHECK VALVE	ANCHOR DARLING	E5853-88-2	N/A	144F012A	1975	REPLACED	YES
3" CHECK VALVE	ANCHOR DARLING	EB378-1-1	N/A	144F012A	1990	REPLACEMENT	YES
3" CHECK VALVE	ANCHOR DARLING	EB378-1-1	N/A	144F012A	1990	REPAIRED	YES
3" CHECK VALVE	ANCHOR DARLING	E5853-88-1	N/A	144F012B	1975	REPLACED	YES
3" CHECK VALVE	ANCHOR DARLING	ET044-1-1	N/A	144F012B	1992	REPLACEMENT	YES
3" GATE VALVE	ANCHOR DARLING	E5853-95-2	N/A	144F013A	1975	REPLACED	YES
3" GATE VALVE	ANCHOR DARLING	ET044-2-1	N/A	144F013A	1992	REPLACEMENT	YES
3" GATE VALVE	ANCHOR DARLING	E5853-95-1	N/A	144F013B	1975	REPLACED	YES
3" GATE VALVE	ANCHOR DARLING	ET044-2-3	N/A	144F013B	1992	REPLACEMENT	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date July 6, 1992
 Sheet 3 of 14

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
PMR 90-3035C/D * SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2" GLOBE VALVE	YARWAY	5777	N/A	144014A	1976	REPLACED	YES
2" GLOBE VALVE	YARWAY	C2784	N/A	144014A	1992	REPLACEMENT	YES
2" GLOBE VALVE	YARWAY	5774	N/A	144014B	1976	REPLACED	YES
2" GLOBE VALVE	YARWAY	C2787	N/A	144014B	1992	REPLACEMENT	YES
2" GLOBE VALVE	YARWAY	5778	N/A	144015A	1976	REPLACED	YES
2" GLOBE VALVE	YARWAY	C2785	N/A	144015A	1992	REPLACEMENT	YES
2" GLOBE VALVE	YARWAY	5770	N/A	144015B	1976	REPLACED	YES
2" GLOBE VALVE	YARWAY	C2786	N/A	144015B	1992	REPLACEMENT	YES
1" GLOBE VALVE	YARWAY	6094	N/A	144804	1976	REPLACED	YES
1" GLOBE VALVE	YARWAY	C2765	N/A	144804	1992	REPLACEMENT	YES
1" GLOBE VALVE	YARWAY	6029	N/A	144805	1976	REPLACED	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date July 15, 1992

Sheet 4 of 14

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

PMR 90-3035C/D * SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A


Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1" GLOBE VALVE	YARWAY	C2760	N/A	144805	1992	REPLACEMENT	YES
1" GLOBE VALVE	YARWAY	6100	N/A	144806	1976	REPLACED	YES
1/2" GLOBE VALVE	YARWAY	B6468	N/A	144806	1982	REPLACEMENT	YES
1" GLOBE VALVE	YARWAY	6112	N/A	144807	1976	REPLACED	YES
1/2" GLOBE VALVE	YARWAY	A8355	N/A	144807	1979	REPLACEMENT	YES
1" GLOBE VALVE	YARWAY	6331	N/A	144808	1976	REPLACED	YES
1" GLOBE VALVE	YARWAY	C2769	N/A	144808	1992	REPLACEMENT	YES
1" GLOBE VALVE	YARWAY	6132	N/A	144809	1976	REPLACED	YES
1" GLOBE VALVE	YARWAY	C2766	N/A	144809	1992	REPLACEMENT	YES
1" GLOBE VALVE	YARWAY	6095	N/A	1RV-PP-14407A	1976	REPLACED	YES
1" GLOBE VALVE	YARWAY	6385	N/A	2RV-PP-14407A	1976	REPLACED	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date July 6, 1992
Sheet 5 of 14

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 PMR 90-3035C/D * SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
Authorization No. N/A
Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1" GLOBE VALVE	YARWAY	6273	N/A	1RV-PP-14407B	1976	REPLACED	YES
1" GLOBE VALVE	YARWAY	6108	N/A	2RV-PP-14407B	1976	REPLACED	YES
1" GLOBE VALVE	YARWAY	6251	N/A	1RV-PP-14408A	1976	REPLACED	YES
1" GLOBE VALVE	YARWAY	5838	N/A	2RV-PP-14408A	1976	REPLACED	YES
1" GLOBE VALVE	YARWAY	6106	N/A	1RV-PP-14408B	1976	REPLACED	YES
1" GLOBE VALVE	YARWAY	6284	N/A	2RV-PP-14408B	1976	REPLACED	YES
1" ANGLE VALVE	YARWAY	N/A	N/A	144022A	N/A	REPLACEMENT	NO
1" ANGLE VALVE	YARWAY	N/A	N/A	144022B	N/A	REPLACEMENT	NO
1/2" GLOBE VALVE	YARWAY	B6475	N/A	144028	1982	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	B6464	N/A	144029	1982	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	B6461	N/A	144030	1982	REPLACEMENT	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date July 6, 1992
Sheet 6 of 14

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 PMR 90-3035C/D * SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
Authorization No. N/A
Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1/2" GLOBE VALVE	YARWAY	A8409	N/A	144031	1979	REPLACEMENT	YES
1/2" CHECK VALVE	EDWARD	64 AEN	N/A	144027	1992	REPLACEMENT	YES
1/2" CHECK VALVE	EDWARD	65 AEN	N/A	144032	1992	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	C2793	N/A	144F010A	1992	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	C2794	N/A	144F010B	1992	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	C2792	N/A	144F011A	1992	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	C2795	N/A	144F011B	1992	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	A1086	N/A	144F009B	1977	REPLACEMENT	YES
1/2" GLOBE VALVE	YARWAY	A8410	N/A	144F008B	1979	REPLACEMENT	YES
LARGE PIPE SUBASSEMBLY	BECHTEL	N/A	N/A	DBC-101-1	1982	REPLACED	YES
LARGE PIPE SUBASSEMBLY	PP&L	N/A	N/A	DBC-101-1	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date July 6, 1992
Sheet 7 of 14

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 PMR 90-3035C/D * SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
Authorization No. N/A
Expiration Date N/A


4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

LARGE PIPE SUBASSEMBLY	BECHTEL	N/A	N/A	DBC-102-1	1982	REPLACED	YES
LARGE PIPE SUBASSEMBLY	PP&L	N/A	N/A	DBC102-1	1992	REPLACEMENT	NO
SMALL PIPE SUBASSEMBLY	BECHTEL	N/A	N/A	SP-DBC-101-1	1982	REPLACED	YES
SMALL PIPE SUBASSEMBLY	BECHTEL	N/A	N/A	SP-DBC-101-2	1982	REPLACED	YES
SMALL PIPE SUBASSEMBLY	BECHTEL	N/A	N/A	SP-DBC-101-3	1982	REPLACED	YES
SMALL PIPE SUBASSEMBLY	PP&L	N/A	N/A	SP-DBC-101-3	1992	REPLACEMENT	NO
SMALL PIPE SUBASSEMBLY	BECHTEL	N/A	N/A	SP-DBC-102-5	1982	REPLACED	YES
SMALL PIPE SUBASSEMBLY	PP&L	N/A	N/A	SP-DBC-102-5	1992	REPLACEMENT	NO
SMALL PIPE SUBASSEMBLY	BECHTEL	N/A	N/A	SP-DBC-102-7	1982	REPLACED	YES
SMALL PIPE SUBASSEMBLY	PP&L	N/A	N/A	SP-DBC-113-1	1992	REPLACEMENT	NO
SMALL PIPE SUBASSEMBLY	BECHTEL	N/A	N/A	FCI-M-195	1982	REPLACED	YES



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date July 6, 1992

Sheet 8 of 14

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE

 PMR 90-3035C/D * SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A


Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SMALL PIPE SUBASSEMBLY	PP&L	N/A	N/A	SP-XBD-104-1	1992	REPLACEMENT	NO
SMALL PIPE SUBASSEMBLY	PP&L	N/A	N/A	SP-XBD-106-1	1992	REPLACEMENT	NO
SMALL PIPE SUBASSEMBLY	PP&L	N/A	N/A	SP-XBD-108-1	1992	REPLACEMENT	NO
SMALL PIPE SUBASSEMBLY	PP&L	N/A	N/A	SP-XBD-111-1	1992	REPLACEMENT	NO
SMALL PIPE SUBASSEMBLY	PP&L	N/A	N/A	SP-XBD-112-1	1992	REPLACEMENT	NO
SMALL PIPE SUBASSEMBLY	PP&L	N/A	N/A	SP-CCC-103-1	1992	REPLACEMENT	NO
SMALL PIPE SUBASSEMBLY	PP&L	N/A	N/A	SP-CCC-115-1	1992	REPLACEMENT	NO
LARGE PIPE SUPPORT	BECHTEL	N/A	N/A	DBC-101-H2	1982	REPLACED	NO
LARGE PIPE SUPPORT	BECHTEL	N/A	N/A	DBC-101-H3	1982	REPLACED	NO
LARGE PIPE SUPPORT	BECHTEL	N/A	N/A	DBC-101-H4	1982	REPLACED	NO
LARGE PIPE SUPPORT ROD & CLAMP	BECHTEL	N/A	N/A	DBC-101-H7	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date July 6, 1992
 Sheet 9 of 14

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
PMR 90-3035C/D * SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

LARGE PIPE SUPPORT ROD & CLAMP	PP&L	N/A	N/A	DBC-101-H7	1992	REPLACEMENT	NO
LARGE PIPE SUPPORT	BECHTEL	N/A	N/A	DBC-101-H8	1982	REPLACED	NO
LARGE PIPE SUPPORT	BECHTEL	N/A	N/A	DBC-101-H9	1982	REPLACED	NO
LARGE PIPE SUPPORT	BECHTEL	N/A	N/A	DBC-101-H10	1982	REPLACED	NO
LARGE PIPE SUPPORT	PP&L	N/A	N/A	DBC-101-H21	1992	REPLACEMENT	NO
LARGE PIPE SUPPORT	PP&L	N/A	N/A	DBC-101-H22	1992	REPLACEMENT	NO
LARGE PIPE SUPPORT	BECHTEL	N/A	N/A	DBC-102-H6	1982	REPLACED	NO
LARGE PIPE SUPPORT	BECHTEL	N/A	N/A	DBC-102-H7	1982	REPLACED	NO
LARGE PIPE SUPPORT	BECHTEL	N/A	N/A	DBC-102-H10	1982	REPLACED	NO
LARGE PIPE SUPPORT	BECHTEL	N/A	N/A	DBC-102-H12	1982	REPLACED	NO
LARGE PIPE SUPPORT	BECHTEL	N/A	N/A	DBC-102-H14	1982	REPLACED	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date July 6, 1992
 Sheet 10 of 14

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
PMR 90-3035C/D * SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
LARGE PIPE SUPPORT	BECHTEL	N/A	N/A	DBC-102-H15	1982	REPLACED	NO
LARGE PIPE SUPPORT	PP&L	N/A	N/A	DBC-102-H22	1992	REPLACEMENT	NO
LARGE PIPE SUPPORT	PP&L	N/A	N/A	DBC-102-H23	1992	REPLACEMENT	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBC-101-H4	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBC-101-H5	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBC-101-H6	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBC-101-H8	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBC-101-H9	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBC-102-H5	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBC-102-H6	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBC-102-H7	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date July 6, 1992

Sheet 11 of 14

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE

 PMR 90-3035C/D * SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A


Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBC-102-H8	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBC-102-H9	1982	REPLACED	NO
SMALL PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBC-102-H10	1982	REPLACED	NO
SMALL PIPE SUPPORT	PP&L	N/A	N/A	SP-DBC-111-H1	1992	REPLACEMENT	NO
PUMP	UNION	284155	N/A	1P221A	1972	REPLACED	NO
*PUMP CASE	HAYWOOD TYLER	U12H91820	N/A	1P221A	1992	REPLACEMENT	NO
*PUMP MOTOR	HAYWOOD TYLER	U12H91820	N/A	1P221A	1992	REPLACEMENT	NO
*HEAT EXCHANGER	HAYWOOD TYLER	U12H91820	N/A	1E239A	1992	REPLACEMENT	NO
PUMP	UNION	284156	N/A	1P221B	1972	REPLACED	NO
*PUMP CASE	HAYWOOD TYLER	U12H91821	N/A	1P221B	1992	REPLACEMENT	NO
*PUMP MOTOR	HAYWOOD TYLER	U12H91821	N/A	1P221B	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date July 6, 1992
Sheet 12 of 14

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 PMR 90-3035C/D * SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
Authorization No. N/A
Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
*HEAT EXCHANGER	HAYWOOD TYLER	U12H91821	N/A	1P221B	1992	REPLACEMENT	NO
3/8" X .065 WALL TUBING	BECHTEL	N/A	N/A	JD-28-5-1C	1982	REPLACED	YES
3/8" X .065 WALL TUBING	PP&L	N/A	N/A	JD-28-5-1C	1992	REPLACEMENT	NO
3/8" X .065 WALL TUBING	BECHTEL	N/A	N/A	JD-28-5-1D	1982	REPLACED	YES
3/8" X .065 WALL TUBING	PP&L	N/A	N/A	JD-28-5-1D	1992	REPLACEMENT	NO
3/8" X .065 WALL TUBING	BECHTEL	N/A	N/A	JD-28-5-1N	1982	REPLACED	YES
3/8" X .065 WALL TUBING	PP&L	N/A	N/A	JD-28-5-1N	1992	REPLACEMENT	NO
3/8" X .065 WALL TUBING	BECHTEL	N/A	N/A	JD-28-5-1P	1982	REPLACED	YES
3/8" X .065 WALL TUBING	PP&L	N/A	N/A	JD-28-5-1P	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner <u> Pennsylvania Power & Light Co. </u> <small style="margin-left: 100px;">Name</small>	Date <u> July 6, 1992 </u>
<u> Two North Ninth St., Allentown, PA 18101 </u> <small style="margin-left: 100px;">Address</small>	Sheet <u> 13 </u> of <u> 14 </u>
2. Plant <u> Susquehanna Steam Electric Station </u> <small style="margin-left: 100px;">Name</small>	Unit <u> ONE </u>
<u> PO Box 467, Berwick, PA 18603 </u> <small style="margin-left: 100px;">Address</small>	<u> PMR 90-3035C/D * SEE REMARKS </u> <small style="margin-left: 100px;">Repair Organization P.O. No., Job No., etc.</small>
3. Work Performed by <u> Pennsylvania Power & Light Co. </u> <small style="margin-left: 100px;">Name</small>	Type Code Symbol Stamp <u> None </u>
<u> Two North Ninth St., Allentown, PA 18101 </u> <small style="margin-left: 100px;">Address</small>	Authorization No. <u> N/A </u>
	Expiration Date <u> N/A </u>

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)

SECTION 5A CONT'D - CONSTRUCTION CODE

PUMPS:

DRAFT VERSION DATED NOVEMBER 1968, OF THE ASME CODE.

LARGE VALVES: (EXCEPT 144F012A)


ASME SECTION III, 1971 EDITION, THRU WINTER 72 ADDENDA; CODE CASE 1516-1 & 1534.

VALVE 144F012A:

ASME SECTION III, 1971 EDITION, THRU WINTER 72 ADDENDA; CODE CASE 1516-1 & 1567.

VALVES 2" AND UNDER:

ASME SECTION III, 1974 EDITION, THRU WINTER 74 ADDENDA



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date July 6, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 14 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 PMR 90-3035C/D * SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR WATER CLEAN UP SYSTEM, 161B, CLASS III

5. (a) Applicable Construction Code III 19 71 Edition, thru W'72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)

SECTION 8 CONT'D - TESTS CONDUCTED

WA# C14098 "A" PUMP LOCALIZED HYDROSTATIC TEST :

PUMP CASE AND PIPING	PRESSURE	1840	PSI	TEST TEMP	63.5F.
PURGE SKID PIPING	PRESSURE	1900	PSI	TEST TEMP	69 F.
HEAT EXCHANGER PIPING	PRESSURE	1860	PSI	TEST TEMP	72F.

WA# C14097 " B" PUMP LOCALIZED HYDROSTATIC TEST:


PUMP CASE AND PIPING	PRESSURE	1830	PSI	TEST TEMP	63F.
PURGE SKID PIPING	PRESSURE	1900	PSI	TEST TEMP	68.5F.
HEAT EXCHANGER PIPING	PRESSURE	1840	PSI	TEST TEMP	68F.

WA# C14100 A AND B PUMP SYSTEM TEST: (TP - 161 - 025)

SUCTION SIDE	PRESSURE	1580	PSI	TEST TEMP	72F.
DISCHARGE SIDE	PRESSURE	1840	PSI	TEST TEMP	68.4F.

WAC14103 IN SERVICE LEAK INSPECTION:

PRESSURE	1200	PSI	TEST TEMP	484 F.
----------	------	-----	-----------	--------



FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES

As Required by the Provisions of the ASME Code Rules

1. Manufactured by Anchor/Darling Valve Company
701 First Street, Williamsport, PA 17701 Order No. ET044
(Name & Address of Manufacturer)

2. Manufactured for Pennsylvania Power & Light Company
2 N. 9th Street, Allentown, PA 18101 Order No. 1-34708-1
(Name and Address)

3. Owner Pennsylvania Power & Light Company

4. Location of Plant Susquehanna 5 Mi. E Berwick on US Rt. 11, P.O. Box 467, Berwick, PA 18603

5. ~~XXXX~~ Valve Identification E-T044-3-1 ✓

4"-900#-FW Gate Valve w/20" Impactor Handwheel
(Brief description of service for which equipment was designed)

(a) Drawing No. W9123596 R/A ✓ Prepared by Anchor/Darling Valve Company

(b) National Board No. N/A

6. Design Conditions 2160 psi 100 °F
(Pressure) (Temperature)

7. The material, design, construction, and workmanship complies with ASME Code Section III. Class 3

Edition 1971, Addenda Date Winter 1972 ✓, Case No. 1516-1, 1534

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
<u>Body HT. #V5008</u> ✓ <u>S/N 7</u> ✓	<u>SA216-WCB</u> ✓	<u>CMI Quaker Alloy, Inc.</u>	
<u>Disc HT. #T8962</u> ✓ <u>S/N 7</u> ✓	<u>SA216-WCB</u> ✓	<u>CMI Quaker Alloy, Inc.</u>	
(b) Forgings			
<u>Bonnet HT. #A115</u> ✓ <u>S/N 7</u> ✓	<u>SA105</u> ✓	<u>Copperweld Steel Company</u>	

FORM NPV-1 (back)

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting N/A			
(d) Other Parts			
Gasket Retaining Ring HT. #801A04540	SA515-70	Mills Alloy Steel Company	

8. Hydrostatic test 3250 psi.

CERTIFICATION OF DESIGN

Design information on file at Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
 Stress analysis report on file at N/A
 Design specifications certified by R. V. Parekh (1) Prof. Eng. State PA Reg. No. 29882
 Stress analysis report certified by N/A (1) Prof. Eng. State _____ Reg. No. _____
 (1) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date 2-14 19 92 Signed Anchor/Darling Valve Co. By R. L. Stannett
(Manufacturer)

Certificate of Authorization No. N1712 expires 4/15/92

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of ~~Delaware~~ Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass. have inspected the equipment described in this Data Report on 10-14-91 to 2-6 1992, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-6 19 92

Charles Young
(Inspector) Commissions Pennsylvania 2392
(National Board, State, Province and No.)

FORM NPV-1 MANUFACTURERS DATA REPORT FOR NUCLEAR PIPES OR VALVES

As Required by the Provisions of the ASME Code Rules

(c) Being
N/A

1. Manufactured by **Anchor/Darling Valve Company**
 701 First Street, Williamsport, PA 17701 Order No. **ET044**

2. Manufactured for **Pennsylvania Power & Light Company**
 2 N. 9th Street, Allentown, PA 18101 Order No. **1-34708-1**

3. Owner **Pennsylvania Power & Light Company**

4. Location of Plant **Susquehanna 5 Mi. E Berwick on US Rt. 11, P.O. Box 467, Berwick, PA 18603**

5. Name of Valve Identification **E-T044-3-2**

4"-900#-FW Gate Valve w/20" Impactor Handwheel

(Brief description of service for which equipment was designed)

03SE

(a) Drawing No. **M9123596 R/A** **Anchor/Darling Valve Company**

(b) National Board No. **Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701**

6. Design Conditions **AS 2160** **100**


7. The material, design, construction, and workmanship complies with ASME Code Section III, Class **3**.

Edition **1971**, Addenda Date **Winter 1972**, Case No. **1516-1, 1534**

Part No.	Material	Manufacturer	Remarks
(a) Castings			
Body HT. #V5008 S/N 6	SA216-WCB	CHI-Quaker Alloy, Inc.	
Disc HT. #T8962 S/N 1	SA216-WCB	CHI Quaker Alloy, Inc.	
(b) Forgings			
Bonnet HT. #A115 S/N 6	SA105	Copperweld Steel Company	

9 2 0 5 0 6 0 5 0 2 6

NO. 95-0152
 RECORD PACKAGE
 PAGE 2 OF 20



FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES

(c) Setting:	As furnished by the provisions of the ASME Code Rules	
	N/A	
1. Manufactured by:	Anchor/Darling Valve Company	
	701 First Street, Williamsport, PA 17701	
2. Manufactured for:	Pennsylvania Power & Light Company	
	S. W. 28th Street, Allentown, PA 18101	
(d) Other Parts:	Name and Address	
	Gasket Retaining Ring	
	SA515-70 Hill Alloy Steel Company	
	HT #801A04540	
	Pennsylvania Power & Light Company	
	2020 Harrison St. Mt. E. Betwick on US Rt. 11, P.O. Box 404, Betwick, PA 17003	
	E-1044-2	
	A-900-FH Gate Valve W/30" Impactor Hardware	

3. Hydrostatic test: 3250 psi

CERTIFICATION OF DESIGN

Design information on file at: Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701

Stress analysis report on file at: N/A

Design specifications certified by: R. V. Parakh 001 (1) Prof. Reg. State PA Reg. No. 29882-E

Stress analysis report certified by: N/A (1) Prof. Reg. State PA Reg. No.

(1) Signatures required. List name only: Anchor/Darling Valve Co.

We certify that the statements made in this report are correct.

Date: 2/4 19 92 Signed: Anchor/Darling Valve Co. by R.L. Hammett

Certificate of Authorization No. N1712 expires 4/15/92

CERTIFICATE OF SHOP INSPECTION


I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass. have inspected the equipment described in this Data Report on 2-4-92 and state that on the basis of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date: 2-6 19 92

Charles Young Commission Pennsylvania-2392
(Inspector) (National Board, State, Province and No.)

7 2 0 5 0 2 0 5 2 7



FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES

As Required by the Provisions of the ASME Code Rules

1. Manufactured by Anchor/Darling Valve Company
701 First Street, Williamsport, PA 17701 Order No. ET044
(Name & Address of Manufacturer)

2. Manufactured for Pennsylvania Power & Light Company
2 N. 9th Street, Allentown, PA 18101 Order No. 1-34708-1
(Name and Address)

3. Owner Pennsylvania Power & Light Company

4. Location of Plant Susquehanna 5 Mi. E Berwick on US Rt. 11, P.O. Box 467, Berwick, PA 18603

5. ~~XXXX~~ Valve Identification E-T044-3-3

4"-900#-FW Gate Valve w/20" Impactor Handwheel
(Brief description of service for which equipment was designed)

(a) Drawing No. W9123596 R/A Prepared by Anchor/Darling Valve Company

(b) National Board No. N/A

6. Design Conditions 2160 psi 100 °F
(Pressure) (Temperature)

7. The material, design, construction, and workmanship complies with ASME Code Section III. Class 3

Edition 1971, Addenda Date Winter 1972, Case No. 1516-1, 1534

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
<u>Body HT. #V5011</u> <u>S/N 3</u>	<u>SA216-WCB</u>	<u>CMI Quaker Alloy, Inc.</u>	
<u>Disc HT. #T5806</u> <u>S/N U6178</u>	<u>SA216-WCB</u>	<u>CMI Quaker Alloy, Inc.</u>	
(b) Forgings			
<u>Bonnet HT. #A115</u> <u>S/N 3</u>	<u>SA105</u>	<u>Copperweld Steel Company</u>	

FORM NPV-1 (back)

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
N/A			
(d) Other Parts			
Gasket Retaining Ring	SA515-70	Mills Alloy Steel Company	
HT. #801A04540			

8. Hydrostatic test 3250 psi.

CERTIFICATION OF DESIGN

Design information on file at Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
 Stress analysis report on file at N/A
 Design specifications certified by R. V. Parekh (1) Prof. Eng. State PA Reg. No. 2988
 Stress analysis report certified by N/A (1) Prof. Eng. State _____ Reg. No. _____
 (1) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date 215 19 92 Signed Anchor/Darling Valve Co. By R. L. Starnett
(Manufacturer)

Certificate of Authorization No. N1712 expires 4/15/92

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of ~~Massachusetts~~ Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass. have inspected the equipment described in this Data Report on 2-6-92, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-6 19 92

Charles Young (Inspector) _____ Commissions Pennsylvania 2392
(National Board, State, Province and No.)

FORM NPV-1 MANUFACTURER'S DATA SHEET FOR NUCLEAR PUMPS OR VALVES

As Required by the Provisions of the ASME Code Rules

1. Manufactured by: Anchor/Darling Valve Company
701 First Street, Millersport, PA 17701
 Order No. E1044

2. Manufactured for: Pennsylvania Power & Light Company
2 N. 9th Street, Allentown, PA 18101
 Order No. I-34708-1

3. Owner: Pennsylvania Power & Light Company

4. Location of Plant: Susquehanna 5 Rt. E., Berwick on US Rt. 11, P.O. Box 1070, Berwick, PA 18603

5. PXXXXX Valve Identification: E-T044-3-A

4"-900#-FW Gate Valve w/20" Impactor Handwheel
(Enter description of service for which equipment was designed)

(a) Drawing No. W9123596 R/A Prepared by Anchor/Darling Valve Company

(b) National Board No. N/A CERTIFICATION OF DESIGN

6. Design Conditions: 2160 (Pressure) AS (Temperature)

7. The material, design, construction, and workmanship complies with ASME Code Section III, Class 3
 Edition 1971, Addenda Date Winter 1972, Case No. 1516-1-1534

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) <u>Body HT. # V5011</u> S/N <u>2</u>	<u>SA216-WCB</u>	<u>CHI Quaker Alloy, Inc.</u>	
<u>Disc HT. # T8962</u> S/N <u>5</u>	<u>SA216-WCB</u>	<u>CHI Quaker Alloy, Inc.</u>	
(b) <u>Bonnet HT. # A115</u> S/N <u>1</u>	<u>SA105</u>	<u>Copperweld Steel Company</u>	

No. 92-0155
 RECORD PACKAGE
 PAGE 11 of 50

9 2 0 5 0 3 2 0 4 2 6

As Required by the Provisions of the ASME Code Rules

Part No.	Manufacturer	Material
(c) Babbit	Anchor/Darling Valve Company	
N/A	701 First Street, Williamsport, PA 17701	
(d) Other Parts		
Gasket Retaining Ring	SA515-70 Hills Alloy Steel Company	

8. Hydrostatic test 3250 V-0522 Anchor/Darling Valve Company Produced by AIR 892326 RIA

CERTIFICATION OF DESIGN

Design information on file at Anchor/Darling Valve Company, 701 First St., Williamsport, PA 17701
 Stress analysis report on file at N/A
 Design specifications certified by R. V. Parekh (1) Prof. Eng. State PA Reg. No. 29882-E
 Stress analysis report certified by N/A (1) Prof. Eng. State _____ Reg. No. _____
 (1) Signature not required. This same only.

We certify that the statements made in this report are correct.

Date 2-15 19 92 signed Anchor/Darling Valve Company R. L. Stammert
 Certificate of Authorization No. N1712 expires 4/15/92

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Province of Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass. have inspected the equipment described in this Data Report on 2-15-92 and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.
 By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-6 19 92

Charles Young Commissioner Pennsylvania 2392
 (National Board, State, Province and No.)

9 2 0 5 0 3 0 4 2 7

FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES

As Required by the Provisions of the ASME Code Rules

- 1. Manufactured by: Anchor/Darling Valve Company
701 First Street, Williamsport, PA 17701
Order No. EB378
- 2. Manufactured for: Pennsylvania Power & Light Company
2-N. 9th St., Allentown, PA 18101
Order No. 0511991-1
- 3. Owner: Pennsylvania Power & Light Company
- 4. Location of Plant: 5 Miles NE of Berwick on U.S. Rt. 11, P.O. Box 467, Berwick, PA 18603
- 5. ~~XXXX~~ Valve Identification: EB378-1-1

3"-900#-Tilt Disc Check Valve

(Brief description of service for which equipment was designed)

- (a) Drawing No. W9023204 R/- Prepared by Anchor/Darling Valve Company
- (b) National Board No. N/A
- 6. Design Conditions: 2160 psi 100 °F
- 7. The material, design, construction, and workmanship complies with ASME Code Section III, Class 2
- Edition 1971 Addenda Date Winter 1972 Case No. 1516-1, 1567

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
Body HT. #D9358 S/N U5623	SA216-WCB	Quaker Alloy	
Disc HT. #R6829 S/N U5614	SA216-WCB	Quaker Alloy	
(b) Forgings			
Bonnet HT. #8897880 S/N 1	SA105	LTV Steel	
Gasket Retaining Ring HT. #A090	SA105	Copperweld Steel	Company
Hinge Pin Cover HT. #AB172 S/N 1 & 2	SA105	Lenape Forge, Inc.	

No. 91-1128
RECORD PACKAGE
PAGE 8 OF 9

(c) Bolting			
Hinge Pin Cover Studs	SA194-2H	HOB, INC.	COMPANY
HT. #8875009			
Hinge Pin Cover Nuts	SA194-2H	HOB, INC.	
HT. #KC8972			
(d) Other Parts			
N/A			

B. Hydrostatic test 3250 psi.

CERTIFICATION OF DESIGN

Design information on file at Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701

Stress analysis report on file at N/A

Design specifications certified by R. V. Parekh (1) Prof. Eng. State PA Reg. No. 29882-E

Stress analysis report certified by N/A (1) Prof. Eng. State PA Reg. No. 29882-E

(1) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date 11-27 1990 Signed Anchor/Darling Valve Co. By R. L. Starnett
(Manufacturer)

Certificate of Authorization No. N1712 expires 4/15/92

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass. have inspected the equipment described in this Data Report on 3-714-1120 1990 and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11-28 1990

Charles Young
(Inspector)
Charles Young
Commissions Pennsylvania 2392
(National Board, State, Province and No.)

Anchor/Darling

Valve Company WILLIAMSPORT, PA 17701

FORM QAS-14-1 SUPPLEMENTAL DATA REPORT FOR NUCLEAR VALVES OR PARTS

1. Work performed by Anchor/Darling Valve Company RT049-1
701 First Street, Williamsport, PA 17701 (Shop Order No.)
2. Owner Pennsylvania Power & Light Co., 2 N. 9th St., Allentown, PA 18101
(Name and Address)
3. Name of Nuclear Power Plant Susquehanna Steam Electric Station
4. Address of Nuclear Power Plant P.O. Box 467, Berwick, PA 18603
5. a: Identification of Component Repaired or Replacement Component N/A
b: Name of Manufacturer (if different from Line 1) ---
c: Identifying Nos. EB378-1-1 ---- 1990
(Mfr.'s Serial No.) (Nat'l Id. No.) (Other) (Year Built)
6. Applicable Edition of Section III of ASME Code 19 71 Addenda Winter 1972 Code Case 1516-1, 1567
7. Description of Work Valve was returned for modification to graphite pressure seal
(Use of additional sheet(s) or sketch(es) is acceptable if properly identified)
gasket including re-testing of valve. Reference Drawing W9023204 Rev. A

CERTIFICATE OF COMPLIANCE


We certify that the statements made in this report are correct and this repair or replacement conforms to Section III of the ASME Code. Signed R. L. Stannett Quality Engineer
(Authorized Representative of Repair Organization) (Title)
12/11, 19 91. Our ASME Certificate of Authorization No. N1712 to use the N symbol
(Date)
expires 4/15/92.

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors, employed by Commercial Union Insurance Company of Boston, Mass. have inspected the repair or replacement described in this Report on 12-10-91 19 91 and state that to the best of my knowledge and belief, this repair or replacement has been made or constructed in accordance with Section III of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12-11-91 Charles Young Commissions Pennsylvania 2392
(Inspector) (State or Providence, Nat'l Board)
Charles Young

No. 91-1685
RECORD PACKAGE
PAGE 9 OF 9



FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES

As Required by the Provisions of the ASME Code Rules

1. Manufactured by Anchor/Darling Valve Company
701 First Street, Williamsport, PA 17701
 (Name & Address of Manufacturer)

2. Manufactured for Pennsylvania Power & Light Company
2 N. 9th Street, Allentown, PA 18101
 (Name and Address) Order No. 1-34708-1

3. Owner Pennsylvania Power & Light Company

4. Location of Plant Susquehanna 5 MI. E Berwick on US Rt. 11, P.O. Box 467, Berwick, PA 18603

5. Valve Identification E-T044-1-1
3"-900#-Tilt Disc Check Valve
 (Brief description of service for which equipment was designed)

(a) Drawing No. H9023204 R/A Prepared by Anchor/Darling Valve Company

(b) National Board No. N/A

6. Design Conditions 2160 psi 100 °F
 (Pressure) (Temperature)

The material, design, construction, and workmanship complies with ASME Code Section III, Class 2

Edition 1971, Addenda Date Winter 1972, Case No. 1516-1, 1534

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
Body HT. #T8913 S/N U6256	SA216-WCB	CMI Quaker Alloy, Inc.	
Disc HT. #S1443 S/N U6175	SA216-WCB	CMI Quaker Alloy, Inc.	
(b) Forgings			
Bonnet HT. #A580 S/N 2	SA105	Copperweld Steel Company	
Gasket Retaining Ring HT. #A631 S/N 2	SA105	Copperweld Steel Company	
Hinge Pin Cover HT. #A580 S/N 3 & 4	SA105	Copperweld Steel Company	

No. 05-0132
 RECORD PACKAGE
 PAGE 11 OF 509

9 2 0 5 0 3 0 1 7 0

FORM 1 (Rev. 1-1-71)

MANUFACTURERS DATA REPORT FOR NUCLEAR PUMPS OR VALVES

(c) Bolting	Material Spec. No.	Manufacturer	Remarks
Hinge Pin Cover Studs HT-48875009	SA193-B7	Texas Bolt Company	
Hinge Pin Cover Nuts HT-46014728	SA194-B7	Texas Bolt Company	
(d) Other Parts			
N/A			

8. Hydrostatic test 3250 psi.

CERTIFICATION OF DESIGN

Design information on file at Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
 Stress analysis report on file at N/A
 Design specifications certified by R. V. Parekh (1) Prof. Eng. State PA Reg. No. 29882-E
 Stress analysis report certified by N/A (1) Prof. Eng. State _____ Reg. No. _____
 (1) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date 2-16 19 92 Signed Anchor/Darling Valve Co. By R. S. Starnett
 Certificate of Authorization No. N1712 expires 4/15/92

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass. have inspected the equipment described in this Data Report on 2-7-92 and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-7 19 92

Charles Young (Inspector)
 Pennsylvania 2392
 (National Board, State, Province, and No.)

9 2 0 5 0 2 0 1 7 1

FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES

As Required by the Provisions of the ASME Code Rules

ASME (c)

1. Manufactured by Anchor/Darling Valve Company
 701 First Street, Williamsport, PA 17701 Order No. ET044
(Name & Address of Manufacturer)
2. Manufactured for Pennsylvania Power & Light Company
 2 N. 9th Street, Allentown, PA 18101 Order No. 1-34708-1
(Name and Address)
3. Owner Pennsylvania Power & Light Company
4. Location of Plant Susquehanna 5 Mt. E Berwick on US Rt. 11, P.O. Box 467, Berwick, PA 18603
5. ~~Mark~~ Valve Identification E-T044-2-1

3"-900#-FW Gate Valve w/16" Impactor Handwheel

(Brief description of service for which equipment was designed)

(a) Drawing No. H9123595 R/A Anchor/Darling Valve Company

(b) National Board No. N/A Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701

6. Design Conditions 2160 100
(Pressure) (Temperature)
7. The material, design, construction, and workmanship complies with ASME Code Section III, Class 3
 Edition 1971, Addenda Date Winter 1972, Case Nos. 1516-1, 1534

Mark No.	Material Spec. Mark	Manufacturer	Remarks
(a) Castings			
Body HT. #V5021 S/N 6	SA216-WCB	CHI-Quaker Alloy, Inc.	
Disc HT. # S1278 S/N U6177	SA216-WCB	CHI Quaker Alloy, Inc.	
(b) Forgings			
Bonnet HT. #A206A S/N 37	SA105	Copperweld Steel Company	
Gasket Retaining Ring HT. # A631	SA105	Copperweld Steel Company	

9 2 0 5 0 3 2 0 0 5 3

No. 95-0133
 RECORD PACKAGE
 PAGE 52 OF 52A

MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			As dictated by the provisions of the ASME Code Rules
N/A			
(d) Other Parts			
N/A			

8. Hydrostatic test 3250 psi.

CERTIFICATION OF DESIGN

Design information on file at Anchor/Darling Valve Co., 701 First St., Williamsport, PA, 17701

Stress analysis report on file at N/A

Design specifications certified by R. V. Parekh (1) Prof. Eng. State PA Reg. No. 29882-E

Stress analysis report certified by N/A (1) Prof. Eng. State _____ Reg. No. _____

(1) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date 2/6 19 92 Signed Anchor/Darling Valve Co. By R. L. Stannett
(Manufacturer)

Certificate of Authorization No. N1712 expires 4/15/92

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass. have inspected the equipment described in this Data Report on 2-7-92 and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-7 19 92

Charles Young (Inspector) Commissions Pennsylvania 2392
(National Board, State, Province and No.)

7
0
0
5
0
9

FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES

As Required by the Provisions of the ASME Code Rules

ASME (b)
VII

1. Manufactured by Anchor/Darling Valve Company
701 First Street, Williamsport, PA 17701 Order No. ET044
(Name & Address of Manufacturer)

2. Manufactured for Pennsylvania Power & Light Company
2 N. 9th Street, Allentown, PA 18101 Order No. I-34708-1
(Name & Address)

3. Owner Pennsylvania Power & Light Company

4. Location of Plant Susquehanna 5-Mt. E Berwick on US Rt. 11, P.O. Box 467, Berwick, PA 18603

5. ~~XXXX~~ Valve Identification E-T044-2-3
3"-900#-FW Gate Valve w/16" Impactor Handwheel
(Brief description of service for which equipment was designed)

(a) Drawing No. W9123595 R/A Prepared by Anchor/Darling Valve Company

(b) National Board No. N/A

6. Design Conditions 2160 psi 100 deg F
(Pressure) (Temperature)

The material, design, construction, and workmanship complies with ASME Code Section III, Class 3.

Edition 1971, Addenda Date Winter 1972, Case No. 1516-1, 1534

Mark No.	Material	Manufacturer	Remarks
(a) Castings			
Body HT. # <u>V5017</u> S/N <u>1</u>	<u>SA216-WCB</u>	<u>CMI Quaker Alloy, Inc.</u>	
Disc HT. # <u>T8921</u> S/N <u>1</u>	<u>SA216-WCB</u>	<u>CMI Quaker Alloy, Inc.</u>	
(b) Forgings			
Bonnet HT. # <u>A206A</u> S/N <u>39</u>	<u>SA105</u>	<u>Copperweld Steel Company</u>	
Gasket Retaining Ring HT. # <u>A631</u>	<u>SA105</u>	<u>Copperweld Steel Company</u>	

No. 95-0132
 RECORD PACKAGE
 PAGE 104 OF 109

Printed in U.S.A. (7/77)

920500112

FORM NP-1 MANUFACTURERS DATA REPORT FOR NUCLEAR PUMPS OR VALVES

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting N/A	As dictated by the provisions of the ASME Code Rules		
		Anchor/Darling Valve Company	
		701 First St., Williamsport, PA 17701	
		Professional Power & Light Company	
		5131 3rd Street, Allentown, PA 18101	
(d) Other Parts N/A			

6. Hydrostatic test 3250 psi.

CERTIFICATION OF DESIGN

Design information on file at Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701

Stress analysis report on file at N/A

Design specifications certified by R. V. Parekh (1) Prof. Eng. State PA Reg. No. 29882

Stress analysis report certified by N/A (1) Prof. Eng. State _____ Reg. No. _____

(1) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date 2-16 19 92 Signed Anchor/Darling Valve Co. By R. L. Starnett
(Manufacturer)

Certificate of Authorization No. N1712 expires 4/15/92


CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass. have inspected the equipment described in this Data Report on 10-22910-2-79-92 and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-7 19 92

Charles Young
(Inspector) Commissions Pennsylvania 2392
(National Board, State, Province and No.)



- 1. Manufactured by Yarway Corporation, Norristown & Narcissa Rds., Blue Bell, PA 19422
(Name and Address of N Certificate Holder)
- 2. Manufactured for Pennsylvania Power & Light Co., Two N. 9th St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
- 3. Location of Installation Susquehanna SES, Berwick, PA 18603
(Name and Address)
- 4. Pump or Valve valve Nominal Inlet Size 2 (inch) Outlet Size -2 (inch)

(a) Model No., (b) N Certificate Holder's (c) Canadian
 Series No. Serial Registration (d) Drawing (f) Nat'l. (g) Year
 or Type No. No. No. (e) Class Bd. No. Built

(8)

(1)	5615B-SA105	C2784	-	111082/None	1	-	1992
(2)		through					
(3)		C2791					
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

5. Nuclear Service Globe Valves
 (Brief description of service for which equipment was designed)

6. Design Conditions - (Pressure) psi - (Temperature) °F or Valve Pressure Class 1500 (1)

7. Cold Working Pressure 3600 psi at 100°F.

8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
NI	AMS 5385E	Southern Tool, Inc.	DISC
(b) Forgings			
E64	ASME SA105	Endicott Forging & Mfg. Co., Inc.	Body

(1) For manually operated valves only.

Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2"x11"; (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

FORM NPV-1 (Back)

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
N/A			
(d) Other Parts			
9210	ASME SA182 GR. F6a Class 2	Atlas Steels	Backseat Bushing

9. Hydrostatic test 5400 psi. Disk Differential test pressure 3960 psi.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. I., Edition 1974
 Addenda W1974 (Date), Code Case No. -, Date 2/28/92
 Signed Yarway Corporation by F. W. Peszka
 (N Certificate Holder)
 Our ASME Certificate of Authorization No. N2449 to use the N symbol expires 11/14/92
 (N) (Date)

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Company
 Stress analysis report (Class 1 only) on file at Pennsylvania Power & Light Company
 Design specifications certified by (1) John R. Schmiedel, Richard O. Schlueter, Sidney A. Copland
 PE State PA, PA, PA Reg. No. 19370E, 26382E, 19877E
 Stress analysis certified by (1) George J. Paptzun
 PE State PA Reg. No. PE-034809-E
 (1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance of Norwood, MA** have inspected the pump, or valve, described in this Data Report on FEB. 28 19 92, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 ** Factory Mutual System

Date FEB. 28 19 92
William R. Rogers III (Inspector) Commissions NB7980 PA 2204 NIBSIS
 (Nat'l Bd., State, Prov. and No.)

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*

As Required by the Provisions of the ASME Code, Section III, Div. 1

SHOP ORDER 01195

REGISTER 16252

1. Manufactured by Yarway Corporation, Norristown & Narcissa Rds., Blue Bell, PA 19422
(Name and Address of N Certificate Holder)
2. Manufactured for Penna. Power & Light Co., Two N. 9th St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
- Location of Installation Susquehanna SES, Berwick, PA 18603
(Name and Address)
4. Pump or Valve Valve . Nominal Inlet Size 1 (inch) Outlet Size 1 (inch)

(a) Model No., (b) N Certificate Holder's (c) Canadian
 Series No. Serial Registration (d) Drawing (f) Nat'l. (g) Year
 or Type No. No. No. No. (e) Class Bd. No. Built

(24)

(1)	5615B-SA105	C2760	-	111082/None	1	-	1992
(2)		through					
(3)		C2783					
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

5. Nuclear Service Globe Valves

(Brief description of service for which equipment was designed)

6. Design Conditions - (Pressure) psi - (Temperature) °F or Valve Pressure Class 1500 (1)

7. Cold Working Pressure 3600 psi at 100°F.
 Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
G90	AMS 5385E	Southern Tool, Inc.	Disc
(b) Forgings			
E87	ASME SA105	Endicott Forging & Mfg. Co., Inc.	Body

(1) For manually operated valves only.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
N/A			
(d) Other Parts			
4345	ASME SA182 Gr. F6a Class 2	Atlas Steels	Backseat Bushing

9. Hydrostatic test 5400 psi. Disk Differential test pressure 3960 psi.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components. Section III, Div. I., Edition 1974

Addenda W1974 (Date), Code Case No. -, Date 2/28/92

Signed Yarway Corporation (N Certificate Holder) by F. W. Peszka
F. W. Peszka

Our ASME Certificate of Authorization No. N2449 to use the N (N) symbol expires 11/14/92 (Date)

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Company

Stress analysis report (Class 1 only) on file at Pennsylvania Power & Light Company

Design specifications certified by (1) John R. Schmiedel, Richard O. Schlueter, Sidney A. Copland

PE State PA, PA, PA Reg. No. 19370E, 26382E, 19877E

Stress analysis certified by (1) George J. Paptzun

PE State PA Reg. No. PE-034809-E

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance of Norwood, MA ** have inspected the pump, or valve, described in this Data Report on FEB 28 19 92, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

**Factory Mutual System

Date FEB 28 19 92
William R. Rogers III (Inspector) Commissions NB7980 PA2204 NIBSIS
(Nat'l Bd., State, Prov. and No.)

FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*

RECORD COPY

governed by the Provisions of the ASME Code Rules

P.O. # 20237

1. Manufactured by YARWAY CORPORATION, BLUE-BELL, PA. 19422 Order No. 52561
(Name & Address of Manufacturer)
2. Manufactured for BECHTEL POWER CORPORATION Order No. 8856-P-15-A
(Name and Address)
3. Owner PENNSYLVANIA POWER & LIGHT COMPANY
4. Location of Plant 5 MILES N. E. OF BERWICK, PA. ON ROUTE 11 NORTH
5. Pump or Valve Identification NUCLEAR SERVICE LINE VALVES SIZE - 1/2"
SERIAL NUMBER (S) B6454 THRU B6468
(Brief description of service for which equipment was designed)
6. (a) Drawing No. 045111 Prepared by YARWAY CORPORATION
7. (b) National Board No. NONE
8. Design Conditions _____ psi _____ °F or Pressure Class 1500 PSI (1)
(Pressure) (Temperature)
9. The material, design, construction, and workmanship complies with ASME Code Section III. Class 2
10. Edition 1974, Addenda Date WINTER 1974, Case No. _____

	Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings	D5 /	AMS 5385 /	NOVA/HOWMET CORPORATION	DISC
(b) Forgings	LS /	SA105 /	CAPE ANN TOOL COMPANY	BODY
	7029 /	SA182 F6A	ATLAS STEELS	BACKSEAT BUSHING
			298	3485

(1) For manually operated valves only.

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) also is 8 1/2" x 11", (2) information in items 1, 2, 3a and 5b on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

FORM NPV-1-N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES
As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by EDWARD VALVES, INC., 1900 S. SAUNDERS ST., RALEIGH, NC 27603
(Name and Address of N Certificate Holder)
2. Manufactured for PENNSYLVANIA POWER & LIGHT CO., P.O. BOX 417, BERWICK, PA 18603
(Name and Address of Purchaser or Owner)
3. Location of Installation: SUSQUEHANNA SE'S, BERWICK, PA 18603
(Name and Address)
4. Pump or Valve VALVE Nominal Inlet Size 1/2 Outlet Size 1/2
(inches) (inches)

(a) Model No., (b) N Certificate Holder's, (c) Canadian

	Series No. or Type	Serial No.	Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l Bd. No.	(g) Year Built
(1)	B36224 F3ILLT3	G2AEN	NA	D91-22725-01	3	N/A	1992
(2)	↓	G3AEN	↓	↓	↓	↓	↓
(3)	↓	G4AEN	↓	↓	↓	↓	↓
(4)	B36224 F3ILLT3	G5AEN	N/A	D91-22725-01	3	N/A	1992
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

5. 1/2" CHECK VALVE
(Brief description of service for which equipment was designed) SO.36-22725

6. Design Conditions 1450 psi (800 °F or Valve Pressure Class 1500) (1)

7. Cold Working Pressure 2570 psi at 100°F.

8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
<u>AL</u>	<u>A56 GR 1 / A732GR 21</u>	<u>CONSOLIDATED CAST</u>	<u>DISK QTY 4</u>
(b) Forgings			
<u>STEEL</u>	<u>SA182 GR F316L</u>	<u>TRINITY FORGE</u>	<u>BODY QTY 4</u>
<u>23275-201</u>	<u>SA479 T316L</u>	<u>COULTER STEEL</u>	<u>COVER QTY 4</u>

(1) For manually operated valves only.
* Supplemental sheets in form of lists, sketches or drawings may be provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

No. 95-0117
RECORD PACKAGE
PAGE 0 OF 2



5

9202289

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*

REGISTER 16252 As Required by the Provisions of the ASME Code, Section III, Div. 1 SHOP ORDER 01200

1. Manufactured by Yarway Corporation, Norristown & Narcissa Rds., Blue Bell, PA 19422
(Name and Address of N Certificate Holder)
 2. Manufactured for Penna. Power & Light Co., Two N. 9th St., Allentown, PA 18101
(Name and Address of Purchaser or Owner)
 3. Location of Installation Susquehanna SES, Berwick, PA 18603
(Name and Address)
 4. Pump or Valve Valve Nominal Inlet Size 1/2 Outlet Size 1/2
(inch) (inch)

(a) Model No., (b) N Certificate Holder's (c) Canadian
 Series No. Serial Registration (d) Drawing (f) Nat'l. (g) Year
 or Type No. No. No. No. (e) Class Bd. No. Built

(8) (1) 5615B-F316 C2792 - 111081/None 1 - 1992
 (2) through
 (3) C2799
 (4) _____
 (5) _____
 (6) _____
 (7) _____
 (8) _____
 (9) _____
 (10) _____

5. Nuclear Service Globe Valves
(Brief description of service for which equipment was designed)

6. Design Conditions _____ psi _____ °F or Valve Pressure Class 1500 (1)
(Pressure) (Temperature)

7. Cold Working Pressure 3600 psi at 100°F.
 Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
J91	AMS 5385E	Southern Tool, Inc.	Disc
(b) Forgings			
BC	ASME SA182 GR. F316	Cape Ann Tool Co.	Body

For manually operated valves only.

Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
N/A			
(d) Other Parts			
6089	ASME SA564 GR. 630	E. M. Jorgensen/ Armco Steel Corp.	Backseat Bushing

9. Hydrostatic test 5400 psi. Disk Differential test pressure 3960 psi.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components. Section III, Div. I., Edition 1974

Addenda W1974 (Date), Code Case No. -, Date 2/28/92

Signed Yarway Corporation (N Certificate Holder) by F. W. Peszka

Our ASME Certificate of Authorization No. N2449 to use the N (N) symbol expires 11/14/92 (Date)

CERTIFICATION OF DESIGN

Design information on file at Pennsylvania Power & Light Company

Stress analysis report (Class 1 only) on file at Pennsylvania Power & Light Company

Design specifications certified by (1) John R. Schmiedel, Richard O. Schlueter, Sidney A. Copland

PE State PA, PA, PA Reg. No. 19370E, 26382E, 19877E

Stress analysis certified by (1) George J. Paptzun

PE State PA Reg. No. PE-034809-E

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance of Norwood, MA** have inspected the pump, or valve, described in this Data Report on FEB 28 19 92, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

**Factory Mutual System

Date FEB 28 19 92

William R. Regester (Inspector) Commissions NB7980 PA2204 NEBS IS (Nat'l Bd., State, Prov. and No.)



FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*

CORRECTED COPY**

As Required by the Provisions of the ASME Code Rules

P.O. 85592

1. Manufactured by YARWAY CORPORATION, BLUE BELL, PA. 19422 Order No. 59052
(Name & Address of Manufacturer)
2. Manufactured for BECHTEL POWER CORPORATION Order No. 8856-P-15-A
(Name and Address)
3. Owner PENNSYLVANIA POWER & LIGHT COMPANY
4. Location of Plant 5 MILES N. E. OF BERWICK, PA. ON ROUTE 11 NORTH
5. Pump or Valve Location NUCLEAR SERVICE LINE VALVES, 2" AND SMALLER
 SERIAL NUMBER(S) A1086 THRU A1110
(Brief description of service for which equipment was designed)

(a) Drawing No. 045111 REV. D** Prepared by YARWAY CORPORATION

(b) National Board No. NONE

6. Design Conditions _____ psi _____ °F or Pressure Class 1500 psi (1)
(Pressure) (Temperature)

7. The material, design, construction, and workmanship complies with ASME Code Section III. Class 2
 Edition 1974, Addenda Date WINTER 1974, Case No. ----

	Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings	A9 & B1	AMS 5582	NOVA HOMET	DISC
(b) Forgings	R9	SA105	CAPE ANN TOOL COMPANY	BODY
	YW 794	SA182 F6	AL TECH STEEL	BACKSEAT BUSHING
			298	1547

(1) For manually operated valves only.

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2" x 11", (2) information in items 1, 2, 3a and 5b on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

630071240

RECORD COPY

10/13/80

	Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting	None			
(d) Other Parts	None			

RECORD COPY

63003712341

B. Hydrostatic test 5400 psi.

CERTIFICATION OF DESIGN

Design information on file at Bechtel Power Corp.
 Stress analysis report on file at Not Required
 Design specifications certified by John R. Schmiedel (I) Prof. Eng. State Pa. Reg. No. 19870
 Stress analysis report certified by Not Required (I) Prof. Eng. State _____ Reg. No. _____
 (I) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date September 27, 1977 Signed Yarway Corp. By W. A. Volger
(Manufacturer)
 Certificate of Authorization No. N899 expires October 28, 1977

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Province of Pennsylvania and employed by Philadelphia Manufacturers Mutual of Philadelphia, Pa. have inspected the equipment described in this Data Report on September 27, 1977, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.
 By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date September 27, 1977

David L. Daullary Commission NB 7525 PA 2159
(Inspector)
(National Board, State, Province and No.)

*Part of the Factory Mutual System

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 14, 1992
Name
Two North Ninth St., Allentown, PA 18101
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603
Address DCP#90-31081 WA#'s SEE REMARKS SECTION
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101
Address Authorization No. N/A
 Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-102-H2003	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13452-81	N/A	SP-DBA-102-H2003	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-102-H2003	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-105-H2000	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13054-80	N/A	SP-DBA-105-H2000	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-108-H1	1982	REPLACED	NO

7. Description of Work SNUBBER REDUCTION PROJECT

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure No Testing Required
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks WA#'s C13816, C13817, C13834, C13836, C13837, C13838, C13839, C13840, C13841, C13842,

Applicable Manufacturer's Data Reports to be attached

C13843, C14118, C14119, C23012, & C23042.

CALC.#'s SR-1024, 5518-2, 5856, 5858, 5859, 5860, 5861, 5862, 5863, 5864, & 5865.

CODE CASE#'s N-122, N-319, & N-411.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed S. J. Skelton Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 3-12-92 to 4-30-92 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the work. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Inspector's Signature Corr ns NB 7525 PA 2159 NE
National Board, State, Province, and Endorsements

Date July 22, 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 14, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 2 of 11
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79' Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stampod (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	03870-78	N/A	SP-DBA-108-H1	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-108-H2	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-108-H2	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-108-H3	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27877-82	N/A	SP-DBA-108-H3	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-108-H4	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	10733-80	N/A	SP-DBA-108-H4	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-109-H2000	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	29173-82	N/A	SP-DBA-109-H2000	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-109-H2002	1982	REPLACED	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-110-H22	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 14, 1992
Name

Two North Ninth St., Allentown, PA 18101 Sheet 3 of 11
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name

PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#'s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name


Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13456-81	N/A	SP-DBA-110-H22	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-111-H3	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28810-82	N/A	SP-DBA-111-H3	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-111-H2000	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28879-82	N/A	SP-DBA-111-H2000	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H1	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-112-H1	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H20	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	16409-80	N/A	SP-DBA-112-H20	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H21	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-112-H21	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 14, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 4 of 11
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H24	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	18577-81	N/A	SP-DBA-112-H24	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-112-H24	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H26	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	09945-80	N/A	SP-DBA-112-H26	1980	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-112-H26	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-124-H8	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	09742-79	N/A	SP-DCA-124-H8	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-124-H2005	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27972-82	N/A	SP-DCA-124-H2005	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-124-H2006	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI


1. Owner Pennsylvania Power & Light Co. Date May 14, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 5 of 11
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I
5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	21069-81	N/A	SP-DCA-124-H2006	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-124-H2008	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	21074-81	N/A	SP-DCA-124-H2008	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-129-H3	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22914-81	N/A	SP-DCA-129-H3	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-129-H3	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-129-H4	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	04640-78	N/A	SP-DCA-129-H4	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-129-H4	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-129-H7	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13140-80	N/A	SP-DCA-129-H7	1980	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 14, 1992
Name

 Two North Ninth St., Allentown, PA 18101 Sheet 6 of 11
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name

 PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name

 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address


Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-129-H7	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-129-H8	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	04072-78	N/A	SP-DCA-129-H8	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-129-H2002	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27949-82	N/A	SP-DCA-129-H2002	1982	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-129-H2002	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-129-H2007	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	23355-81	N/A	SP-DCA-129-H2007	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-129-H2011	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	04684-78	N/A	SP-DCA-129-H2011	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-129-H2011	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 14, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 7 of 11
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#'s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-129-H2014	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13934-81	N/A	SP-DCA-129-H2014	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-130-H1	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-130-H1	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-130-H2	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	23358-81	N/A	SP-DCA-130-H2	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-130-H29	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	23548-81	N/A	SP-DCA-130-H29	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-130-H29	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-130-H33	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28939-82	N/A	SP-DCA-130-H33	1982	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 14, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 8 of 11
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#'s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-130-H33	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-130-H35	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-130-H35	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-130-H36	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	06273-78	N/A	SP-DCA-130-H36	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-130-H38	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28865-82	N/A	SP-DCA-130-H38	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-130-H2000	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22892-81	N/A	SP-DCA-130-H2000	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-130-H2001	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13463-81	N/A	SP-DCA-130-H2001	1981	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 14, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 9 of 11
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#'s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-130-H2002	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28884-82	N/A	SP-DCA-130-H2002	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-130-H2003	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28916-82	N/A	SP-DCA-130-H2003	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-130-H2004	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22917-81	N/A	SP-DCA-130-H2004	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-132-H2	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27967-82	N/A	SP-DCA-132-H2	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-132-H23	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	06278-78	N/A	SP-DCA-132-H23	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-132-H24	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 14, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 10 of 11
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#'s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79' Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28917-82	N/A	SP-DCA-132-H24	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-132-H2002	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22879-81	N/A	SP-DCA-132-H2002	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-132-H2003	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	21124-81	N/A	SP-DCA-132-H2003	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-130-H2007	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	21091-81	N/A	SP-DCA-132-H2007	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-132-H2008	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28813-82	N/A	SP-DCA-132-H2008	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-132-H2010	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	06276-78	N/A	SP-DCA-132-H2010	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 14, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 11 of 11
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#'s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-132-H2011	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	16429-80	N/A	SP-DCA-132-H2011	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-132-H2013	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	14347-80	N/A	SP-DCA-132-H2013	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H152	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-127-H152	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 11 MAY, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 1 of 7
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108I, WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H15	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03175-78	N/A	MST-022-H15	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H40	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03374-78	N/A	MST-022-H40	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H45	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04117-79	N/A	MST-022-H45	1979	REPLACED	N/A

7. Description of Work SNUBBER REDUCTION PROJECT

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure NO TESTING REQUIRED
 Other Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks WA #s C13844, C13846, C14121, C14123, C14125, C14127, C13817, C14119, C14118,

Applicable Manufacturer's Data Reports to be attached

C23012, & C23213.

CALC. #s SR 951-1, 951-2, 952, 953, & 1024; AND CALC. # EL-C-SNU-076.

CODE CASE #s N-122, N-319, & N-411

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp

N/A

Certificate of Authorization No.

N/A

Expiration Date

N/A

Signed

S. J. J. J.

Date

July 16, 1992

Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-12-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David J. J. J.
Inspector's Signature

Commissions

NB 7525 PA 2159 NI
National Board, State, Province, and Endorsements

Date JULY 22, 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 11 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603
Address DCP 90-31081, WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101
Address Authorization No. N/A
 Expiration Date N/A


4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79. Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-102-H8	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02760-78	N/A	DBA-102-H8	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-102-H9	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04115-79B	N/A	DBA-102-H9	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-102-H11	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02561-78	N/A	DBA-102-H11	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-102-H13	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04106-79	N/A	DBA-102-H13	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-105-H8	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04616-78	N/A	DBA-105-H8	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-105-H9	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 11 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603
Address DCP 90-31081, WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101
Address Authorization No. N/A
 Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79. Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	14775-83	N/A	DBA-105-H9	1983	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-105-H10	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02160-77	N/A	DBA-105-H10	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H13	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03634-78	N/A	MST-022-H13	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H14	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03266-78	N/A	MST-022-H14	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H18	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00123-76	N/A	MST-022-H18	1976	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H21	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01801-83	N/A	MST-022-H21	1983	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 11 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 4 of 7
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108I, WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H25	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04102-79	N/A	MST-022-H25	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H26	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03179-78	N/A	MST-022-H26	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H28	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04118-79	N/A	MST-022-H28	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H49	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03376-78	N/A	MST-022-H49	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H33	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02414-90	N/A	MST-022-H33	1990	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H34	1982	REPLACED	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 11 MAY, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 5 of 7
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-31081, WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	01332-82	N/A	MST-022-H34	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H46	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03375-78	N/A	MST-022-H46	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-108-H7	1982	REPLACED	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-108-H10	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04606-78	N/A	DBA-108-H10	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-108-H12	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06588-78	N/A	DBA-108-H12	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-108-H15	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06796-78	N/A	DBA-108-H15	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-108-H21	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 11 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603
Address DCP 90-31081, WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101
Address Authorization No. N/A
 Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	23020-81	N/A	DBA-108-H21	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-108-H6	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06584-78	N/A	DBA-108-H6	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DBA-108-H6	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-108-H8	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04282-78	N/A	DBA-108-H8	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DBA-108-H8	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-108-H9	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04277-78	N/A	DBA-108-H9	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DBA-108-H9	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H17	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 11 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 7 of 7
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-31081, WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79. Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PP&L	N/A	N/A	MST-022-H17	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H20	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	MST-022-H20	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	MST-022-H31	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	MST-022-H31	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-102-H5	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DBA-102-H5	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 12, 1992
 Sheet 1 of 14

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H28	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	19548-81	N/A	DCA-111-H28	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H25	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04587-78	N/A	DCA-111-H25	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H26	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04589-78	N/A	DCA-111-H26	1978	REPLACED	N/A

7. Description of Work SNUBBER REDUCTION PROJECT UNIT 1

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure NO TESTING REQUIRED
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks WA C31813, WA C13814, WA C13815, WA C14128, WA C14145, WA C14168, WA C14169,

Applicable Manufacturer's Data Reports to be attached

WA C14170, WA C14171, WA C14172, WA C23169

CALCULATIONS: SR-885, & SR-5518-1

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed S. J. Stal Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-10-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Paul Doullany Commissions NB 7525 PA 2159 NE
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Peninsylvania Power & Light Co. Date May 12, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 2 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H21	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02501-77	N/A	DCA-111-H21	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H22	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02545-77	N/A	DCA-111-H22	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H41	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00935-77	N/A	DCA-111-H41	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H18	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	12946-82	N/A	DCA-111-H18	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H19	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02534-77	N/A	DCA-111-H19	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H16	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 12, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 3 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	02542-77	N/A	DCA-111-H16	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H17	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13425-82	N/A	DCA-111-H17	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H15	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02820-77	N/A	DCA-111-H15	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H15	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04990-78	N/A	(A)SP-DBA-112-H15	1978	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	04988-78	N/AN/A	(B)SP-DBA-112-H15	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H29	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04991-78	N/A	SP-DBA-112-H29	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-112-H18	1990	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 12, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 4 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	23387-83	N/A	SP-DBA-112-H18	1983	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H31	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	09923-80	N/A	SP-DBA-112-H31	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H33	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	12178-80	N/A	SP-DBA-112-H33	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H36	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	05014-78	N/A	SP-DBA-112-H36	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H35	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06842-78	N/A	SP-DBA-112-H35	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H34	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	07227-79	N/A	SP-DBA-112-H34	1979	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 12, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 5 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H37	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06843-78	N/A	SP-DBA-112-H37	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H39	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28923-82	N/A	SP-DBA-112-H39	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H40	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	05015-78	N/A	SP-DBA-112-H40	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H42	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	05016-78	N/A	SP-DBA-112-H42	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H43	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06844-78	N/A	SP-DBA-112-H43	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H45	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 12, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 6 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	02223-77	N/A	SP-DBA-112-H45	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-145-H17	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06668-79	N/A	SP-DCA-145-H17	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-145-H18	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13063-80	N/A	SP-DCA-145-H18	1980	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-145-H55	1985	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	27944-82	N/A	SP-DCA-145-H55	1982	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-145-H56	1985	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	27948-82	N/A	SP-DCA-145-H56	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H5	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	10725-80	N/A	SP-DBA-112-H5	1980	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 12, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 7 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H2	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	12179-80	N/A	SP-DBA-112-H2	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H2000	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	18551-81	N/A	SP-DBA-112-H2000	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H12	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	09925-80	N/A	SP-DBA-112-H12	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-JBD-188-H12	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	19503-81	N/A	SP-JBD-188-H12	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-145-H67	1985	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-145-H5	1985	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14328-80	N/A	SP-DCA-145-H5	1980	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 12, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 8 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H13	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-112-H13	1992	REPLACEMENT	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H23	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04585-78	N/A	DCA-111-H23	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H23	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H20	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02477-77	N/A	DCA-111-H20	1977	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H20	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H36	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06800-78	N/A	DCA-111-H36	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H36	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 12, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 9 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H24	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04586-78	N/A	DCA-111-H24	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H24	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H38	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02499-77	N/A	(A) DCA-111-H38	1977	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	19559-81	N/A	(B) DCA-111-H38	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H38	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H4	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H4	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H33	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H33	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 12, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 10 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H6	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H6	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H37	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01164-77	N/A	DCA-111-H37(B)	1977	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H37	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H7	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H7	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H28	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	09922-80	N/A	SP-DBA-112-H28	1980	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-112-H28	1992	REPLACEMENT	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04991-78	N/A	SP-DBA-112-H28	1978	REPLACEMENT	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 12, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 11 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H46	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06845-78	N/A	SP-DBA-112-H46	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-112-H46	1992	REPLACEMENT	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	21572-82	N/A	SP-DBA-112-H46	1982	REPLACEMENT	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-145-H13	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	09730-79	N/A	SP-DCA-145-H13	1979	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-145-H13	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H16	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-112-H16	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H8	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03656-77	N/A	(A) DCA-111-H8	1977	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 12, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 12 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH SNUBBER	PACIFIC SCIENTIFIC	25283-82	N/A	(B) DCA-111-H8	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H9	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	19484-81	N/A	DCA-111-H9	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H9	1992	REPLACEMENT	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01164-77	N/A	DCA-111-H9	1977	REPLACEMENT	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H14	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-112-H14	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-145-H10	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-145-H10	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-145-H58	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-145-H58	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 12, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 13 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H39	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06807-78	N/A	(A) DCA-111-H39	1978	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	06806-78	N/A	(B) DCA-111-H39	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H39	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H2	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H2	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-111-H40	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCA-111-H40	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H41	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01047-77	N/A	SP-DBA-112-H41	1977	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-112-H41	1992	REPLACEMENT	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 12, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 14 of 14
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 PMR 90-3108L / SEE REMARKS FOR WA Nos.
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	14386-82	N/A	SP-DBA-112-H41	1982	REPLACEMENT	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-112-H50	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-112-H50	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date 5 MAY, 1992
 Sheet 1 of 4

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
DCP 90-3108J, WA C13807, C13808, C23220
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S 79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-104-H11	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DLA-104-H11	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-102-H6	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01794-83	N/A	DLA-102-H6	1983	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-102-H7	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03061-78	N/A	DLA-102-H7	1978	REPLACED	N/A

7. Description of Work SNUBBER REDUCTION PROJECT

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure NO TESTING REQUIRED
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks INCLUDES PIPING CALC. # SR-876 & SR-880

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SR Seal Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 1-9-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.


David Daulaway Commissions NB 7525 PA 2159 NE
Inspector's Signature National Board, State, Province, and Endorsements

Date JUL 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 5 MAY, 1992
Name
- Two North Ninth St., Allentown, PA 18101 Sheet 2 of 4
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
- PO Box 467, Berwick, PA 18603 DCP 90-3108J, WA C13807, C13808, C23220
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
- Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address
- Expiration Date N/A
4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I
5. (a) Applicable Construction Code III 19 77 Edition, thru S 79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-102-H8A	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01618-82	N/A	DLA-102-H8A	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-102-H9B	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00796-77	N/A	DLA-102-H9B	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-102-H10	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	09486-82	N/A	DLA-102-H10	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-102-H13	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01172-77	N/A	DLA-102-H13	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-102-H15	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01096-81B	N/A	DLA-102-H15	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-104-H5	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner	<u>Pennsylvania Power & Light Co.</u> <small>Name</small>	Date	<u>5 MAY, 1992</u>
	<u>Two North Ninth St., Allentown, PA 18101</u> <small>Address</small>	Sheet	<u>3</u> of <u>4</u>
2. Plant	<u>Susquehanna Steam Electric Station</u> <small>Name</small>	Unit	<u>ONE</u>
	<u>PO Box 467, Berwick, PA 18603</u> <small>Address</small>		<u>DCP 90-3108J, WA C13807, C13808, C23220</u> <small>Repair Organization P.O. No., Job No., etc.</small>
3. Work Performed by	<u>Pennsylvania Power & Light Co.</u> <small>Name</small>	Type Code Symbol Stamp	<u>None</u>
	<u>Two North Ninth St., Allentown, PA 18101</u> <small>Address</small>	Authorization No.	<u>N/A</u>
		Expiration Date	<u>N/A</u>
4. Identification of System	<u>REACTOR VESSEL SYSTEM 162A CLASS I</u>		
5. (a) Applicable Construction Code	<u>III</u>	19 <u>77</u> Edition,	<u>thru S 79</u> Addenda, <u>N-411</u> Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements	<u>19</u>	<u>80 thru W'80</u>	
6. Identification of Components Repaired or Replaced and Replacement Components			

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	06937-80	N/A	DLA-104-H5	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-104-H7	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03636-78	N/A	DLA-104-H7	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-104-H8A	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02395-89	N/A	DLA-104-H8A	1989	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-104-H9B	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01182-77	N/A	DLA-104-H9B	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-104-H10	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02849-78	N/A	DLA-104-H10	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-104-H12	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DLA-104-H12	1992	REPLACEMENT	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 5 MAY, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 4 of 4
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108J, WA C13807, C13808, C23220
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S 79 Addenda, N-411 Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-104-H13	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01187-77	N/A	DLA-104-H13	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DLA-104-H15	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02030-83	N/A	DLA-104-H15	1983	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 6, 1992
 Sheet 1 of 5

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
90-3108K / SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S*79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W*80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-138-H2001	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22981-81	N/A	SP-DCA-138-H2001	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-140-H16	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28737-82	N/A	SP-DCA-140-H16	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-140-H18	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22982-81	N/A	SP-DCA-140-H18	1981	REPLACED	N/A

7. Description of Work SNUBBER REDUCTION PROJECT

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure NO TESTING REQUIRED
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Snubber reduction per Calcs SR-5487, SR-5488, SR-5510, SR-5511, SR-5512, SR-5513, SR-5971

Applicable Manufacturer's Data Reports to be attached

WA C13803, WA C13804, WA C13805, WA C13806, WA C23171, & WA C23199

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SR Slap Date July 16 .1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 1-10-92 to 7-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Dail Daulany Commissions NB 7525 PA 2159 NE
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 6, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 2 of 5
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 90-3108K / SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S*79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-137-H6	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	16413-80	N/A	SP-DCA-137-H6	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-137-H5	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28746-82	N/A	SP-DCA-137-H5	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-137-H4	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28857-82	N/A	SP-DCA-137-H4	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-137-H10	1982	REPLACED	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-137-H13	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-137-H13	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-137-H20	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	23552-81	N/A	SP-DCA-137-H20	1981	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 6, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 3 of 5
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 90-3108K / SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S*79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-137-H19	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28738-82	N/A	SP-DCA-137-H19	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-137-H16	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	21110-81	N/A	SP-DCA-137-H16	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-140-H14	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	27856-82	N/A	SP-DCA-140-H14	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-140-H2000	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	21141-81	N/A	SP-DCA-140-H2000	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-138-H2	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	16439-80	N/A	SP-DCA-138-H2	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-138-H4	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 6, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 4 of 5
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 90-3108K / SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S*79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W*80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	28728-82	N/A	SP-DCA-138-H4	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-138-H21	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28720-82	N/A	SP-DCA-138-H21	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-138-H22	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	29019-82	N/A	SP-DCA-138-H22	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-138-H23	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06259-78	N/A	SP-DCA-138-H23	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-138-H2003	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	23012-81	N/A	SP-DCA-138-H2003	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-138-H24	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06319-78	N/A	SP-DCA-138-H24	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 6, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 5 of 5
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 90-3108K / SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS I

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-138-H25	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	27960-82	N/A	SP-DCA-138-H25	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-138-H14	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28788-82	N/A	SP-DCA-138-H14	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-138-H15	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28860-82	N/A	SP-DCA-138-H15	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-138-H16	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	27970-82	N/A	SP-DCA-138-H16	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-137-H22	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-137-H22	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 6, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 3
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 90-3108K/WA C13802, WA C13803, WA C23172
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS II

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-112-H2046	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	16423-80	N/A	SP-DCB-112-H2046	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-112-H2048	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04208-78	N/A	SP-DCB-112-H2048	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-112-H50	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06241-78	N/A	SP-DCB-112-H50	1978	REPLACED	N/A

7. Description of Work SNUBBER REDUCTION

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure NO TESTING REQUIRED
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Snubber reduction per Calculations SR-5961, SR-5962 and SR-5971

Applicable Manufacturers Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. N/A Expiration Date N/A

Signed SK Lal Date July 20 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 1-10-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.


Clair Chubb Commissions NB 7525 PA 2159
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 6, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 2 of 3
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 90-3108K / WA C13802, WA C13803, WA C23172
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS II
5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-112-H2071	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22911-81	N/A	SP-DCB-112-H2071	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-112-H2044	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	23584-81	N/A	SP-DCB-112-H2044	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-112-H2041	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	10906-79	N/A	SP-DCB-112-H2041	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-112-H2075	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22910-81	N/A	SP-DCB-112-H2075	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-112-H2026	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13098-80	N/A	SP-DCB-112-H2026	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-112-H28	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date July 17, 1992
 Sheet 3 of 3

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
90-3108K / WA C13802, WA C13803, WA
C23172 Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol None
 Authorization N/A
 Expiration Date N/A

4. Identification of System REACTOR VESSEL SYSTEM 162A CLASS II

5. (a) Applicable Construction III 19 77 Edition, thru S'79 Addenda, N-411 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCB-112-H28	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date June 3, 1992
Name
Two North Ninth St., Allentown, PA 18101
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603
Address
DCP 90-3092 WA C13848
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101
Address
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System REACTOR RECIRC SYSTEM 164B CLASS I

5. (a) Applicable Construction Code III 19 71 Edition, thru W72 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W81

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-150-H2010	1982	REPLACED	NO
VALVE	BORG WARNER	19478	N/A	1FO27B	1976	REPLACED	YES
VALVE	BORG WARNER	19463	N/A	1FO28B	1976	REPLACED	YES
PIPE CAP	PP&L	N/A	N/A	SP-DCA-150-1	1992	REPLACEMENT	NO

7. Description of Work ELIMINATE DRAIN VALVES AND SUPPORT

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure SE-100-002
 Other Pressure 1023 psi Test Temp. 155 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be attached

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SK Mal Date July 16 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 11-17-91 to 4-16-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David Doullany Commissions NB 2525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date JULY 22 1992

164BI

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 1 of 20
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I

5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-118-H27	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	23046	N/A	SP-DCA-118-H27	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-118-H31	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	16379	N/A	SP-DCA-118-H31	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-118-H2011	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	27975	N/A	SP-DCA-118-H2011	1982	REPLACED	N/A

7. Description of Work REMOVE SNUBBER / NO REPLACEMENT--MODIFY SUPPORTS

8. Tests Conducted: Other Pneumatic Nominal Operating Pressure No Testing Required
 Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Applicable Construction Codes:for Snubbers - ASME III 1977 Edition thru Summer 1979 Addenda.

CODE CASE N-411 & N-122.

WA C13904, C13906, C13907, C13910, C13913, C13914

CALC. # SR-5801, SR-5585, SR-5586,SR-5483, SR-5485, SR-5496, SR-5808, SR-950A, SR-950B

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A _____

Certificate of Authorization No. N/A Expiration Date N/A

Signed Sy Stal Date July 16, 19 92
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-27-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

D. D. Daubney Commissions NB 7525 PA 269
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 2 of 20
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I

5. (a) Applicable Construction see remarks 19 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-119-H31	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06239	N/A	SP-DCA-119-H31	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-119-H2000	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06246	N/A	SP-DCA-119-H2000	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-119-H2003	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28765	N/A	SP-DCA-119-H2003	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-119-H2004	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22938	N/A	SP-DCA-119-H2004	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-119-H2005	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22961	N/A	SP-DCA-119-H2005	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-119-H2009	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 3 of 20
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I


5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

MECH. SNUBBER	PACIFIC SCIENTIFIC	22927	N/A	SP-DCA-119-H2009	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-119-H2011	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13923	N/A	SP-DCA-119-H2011	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-119-H2012	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14374	N/A	SP-DCA-119-H2012	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-121-H24	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	27840	N/A	SP-DCA-121-H24	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-121-H35	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06310	N/A	SP-DCA-121-H35	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-121-H36	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22951	N/A	SP-DCA-121-H36	1981	REPLACED	N/A




164BI

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 4 of 20
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A
4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I
5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
19
6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-121-H2014	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	09940	N/A	SP-DCA-121-H2014	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-121-H2016	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13960	N/A	SP-DCA-121-H2016	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-116-H1	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06326	N/A	SP-DCA-116-H1	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-116-H2	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	05132	N/A	SP-DCA-116-H2	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-116-H6	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	23353	N/A	SP-DCA-116-H6	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-116-H2001	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
- Two North Ninth St., Allentown, PA 18101 Sheet 5 of 20
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
- PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
- Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address
- Expiration Date N/A
4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I
5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	29015	N/A	SP-DCA-116-H2001	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-116-H5	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13469	N/A	SP-DCA-116-H5	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-116-H5	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-117-H2	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28019	N/A	SP-DCA-117-H2	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-117-H13	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	18830	N/A	SP-DCA-117-H13	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-117-H16	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04104	N/A	SP-DCA-117-H16	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-117-H2003	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 6 of 20
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I


5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80

19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	13965	N/A	SP-DCA-117-H2003	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-117-H2004	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	09937	N/A	SP-DCA-117-H2004	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-117-H5	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-117-H5	1992	REPLACEMENT	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-108-H2013	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04657	N/A	SP-DCA-108-H2013	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-108-H2014	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04618	N/A	SP-DCA-108-H2014	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H63	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	35514	N/A	SP-DCA-126-H63	1983	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 7 of 20
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I

5. (a) Applicable Construction see remarks 19 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H64	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	16416	N/A	SP-DCA-126-H64	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H73	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	16424	N/A	SP-DCA-126-H73	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H74	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	16425	N/A	SP-DCA-126-H74	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H83	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	10942	N/A	SP-DCA-126-H83	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2008	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	16427	N/A	SP-DCA-126-H2008	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2010	1982	REPLACED	NO




164BI

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
- Two North Ninth St., Allentown, PA 18101 Sheet 8 of 20
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
- PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
- Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address
- Expiration Date N/A
4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I
5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
19
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	16384	N/A	SP-DCA-126-H2010	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2011	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	16417	N/A	SP-DCA-126-H2011	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2012	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28856	N/A	SP-DCA-126-H2012	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2013	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	16419	N/A	SP-DCA-126-H2013	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2014	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13116	N/A	SP-DCA-126-H2014	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2021	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13099	N/A	SP-DCA-126-H2021	1980	REPLACED	N/A




164BI

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 9 of 20
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS
Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A
4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I
5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
19
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2034	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13433	N/A	SP-DCA-126-H2034	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H2035	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22875	N/A	SP-DCA-126-H2035	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-126-H71	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-126-H71	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-102-H14	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	18588	N/A	SP-DCA-102-H14A	1981	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	02414	N/A	SP-DCA-102-H14B	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-102-H19	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	12947	N/A	SP-DCA-102-H19	1982	REPLACED	N/A



164BI

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 10 of 20
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I

5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-102-H22	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	19563	N/A	SP-DCA-102-H22	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-102-H6	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03649	N/A	DCA-102-H6	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-102-H9	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04569	N/A	DCA-102-H9A	1978	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	06799	N/A	DCA-102-H9B	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-141-H1	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04268	N/A	DCA-141-H1	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-141-H2	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04609	N/A	DCA-141-H2	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 11 of 20
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A


4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I

5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------


PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-141-H3	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	12943	N/A	DCA-141-H3	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-141-H4	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04279	N/A	DCA-141-H4	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H1	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03173	N/A	RWS-100-H1	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H2	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03289	N/A	RWS-100-H2	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H5	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04112	N/A	RWS-100-H5	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H6	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 12 of 20
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A
4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I
5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	03725	N/A	RWS-100-H6	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H11	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03369	N/A	RWS-100-H11	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H15	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04114	N/A	RWS-100-H15	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H16	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03720	N/A	RWS-100-H16	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H19	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03709	N/A	RWS-100-H19	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H20	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03761	N/A	RWS-100-H20	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 21, 1992

Sheet 13 of 20

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

DCP 90-3108F WA C13898, C13899, C13900,
SEE REMARKS Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol None

Authorization N/A

Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I


5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H21	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03711	N/A	RWS-100-H21	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H22	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	10539	N/A	RWS-100-H22	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H27	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03172	N/A	RWS-100-H27A	1981	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	08607	N/A	RWS-100-H27B	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H39	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03639	N/A	RWS-100-H39	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H29	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	RWS-100-H29	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date May 21, 1992

Sheet 14 of 20

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE

 DCP 90-3108F WA C13898, C13899, C13900,
SEE REMARKS
Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol None

Authorization N/A

Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I


5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80

19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H30	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	RWS-100-H30	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H34	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	RWS-100-H34	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-102-H17	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCA-102-H17	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H31	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	RWS-100-H31	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H35	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	RWS-100-H35	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-102-H2002	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name

Two North Ninth St., Allentown, PA 18101 Sheet 15 of 20
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name

PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name

Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address

Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I


5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80

19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-102-H2002	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-102-H2	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06818	N/A	DCA-102-H2A	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DCA-102-H2	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-102-H4	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06797	N/A	DCA-102-H4A	1978	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	25302	N/A	DCA-102-H4B	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-108-H8	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00574	N/A	DCA-108-H8	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-108-H9	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00399	N/A	DCA-108-H9	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 16 of 20
Address


2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS
Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I
5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------


PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-142-H1	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	12276	N/A	DCA-142-H1	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-142-H2	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04264	N/A	DCA-142-H2	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-142-H3	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	08696	N/A	DCA-142-H3	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-142-H4	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04281	N/A	DCA-142-H4	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-102-H11	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	21566	N/A	SP-DCA-102-H11A	1982	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	21572	N/A	SP-DCA-102-H11B	1982	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
- Two North Ninth St., Allentown, PA 18101 Sheet 17 of 20
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
- PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
- Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address
- Expiration Date N/A
4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I
5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-102-H2000	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	18585	N/A	SP-DCA-102-H2000A	1981	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	18582	N/A	SP-DCA-102-H2000B	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H3	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03367	N/A	RWS-100-H3	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H4	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03368	N/A	RWS-100-H4	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H7	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03718	N/A	RWS-100-H7	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H8	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03760	N/A	RWS-100-H8	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 18 of 20
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Number, Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I

5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H9	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03638	N/A	RWS-100-H9	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H10	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03189	N/A	RWS-100-H10	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H14	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04111	N/A	RWS-100-H14	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H17	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	11028	N/A	RWS-100-H17	1983	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H18	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03762	N/A	RWS-100-H18	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H23	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 19 of 20
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I

5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	02670	N/A	RWS-100-H23	1978	REPLACED	N/A ¹⁹⁸²
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H24	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03724	N/A	RWS-100-H24	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H28	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03248	N/A	RWS-100-H28A	1978	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	02591	N/A	RWS-100-H28B	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H37	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03641	N/A	RWS-100-H37	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H38	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	RWS-100-H38	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	RWS-100-H38	1982	REPLACED	NO

164BI

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 21, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 20 of 20
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13898, C13899, C13900,
Address SEE REMARKS
Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol None
Name
Two North Ninth St., Allentown, PA 18101 Authorization N/A
Address Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 164B CLASS I

5. (a) Applicable Construction see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PP&L	N/A	N/A	RWS-100-H38	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DCA-108-H2	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	DCA-108-H2	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-102-H2001	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-102-H2001	1992	REPLACEMENT	NO



**FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI**

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date May 19, 1992
 Sheet 1 of 7

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 DCP 90-3108F WA C13901, C13902, C13911, C13912
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System Reactor Recirculation System 164D Class I

5. (a) Applicable Construction Code see remark 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-106-H20	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	29316	N/A	SP-DCB-106-H20	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-106-H21	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22905	N/A	SP-DCB-106-H21	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-106-H2013	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	23588	N/A	SP-DCB-106-H2013	1981	REPLACED	N/A

7. Description of Work Remove Snubber / No Replacement

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure No Testing Required
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Applicable Construction Codes:for Snubbers - ASME III 1977 Edition thru Summer 1979

CODE CASE N-411 & N-122.

CALC. SR-5947-1, SR-5507, SR-5529, SR-5948-1

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SK Seal Date July 16, 19 92
Owner or Owner's Designee Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-26-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Neil Daubney Commissions NB 7525 PA 2159 NE
Inspector's Signature National Board, State, Province, and Endorsements

Date JULY 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 19, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 2 of 7
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13901, C13902, C13911,
Address C13912
Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System Reactor Recirculation System 164D Class I

5. (a) Applicable Construction Code see remark 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-106-H2014	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13047	N/A	SP-DCB-106-H2014	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-106-H2018	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28792	N/A	SP-DCB-106-H2018	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-106-H2020	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	05056	N/A	SP-DCB-106-H2020	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-106-H2027	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22934	N/A	SP-DCB-106-H2027	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-106-H2028	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14373	N/A	SP-DCB-106-H2028	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-105-H3	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 19, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 3 of 7
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13901, C13902, C13911,
Address C13912
Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System Reactor Recirculation System 164D Class I

5. (a) Applicable Construction Code see remark 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	14361	N/A	SP-DCB-105-H3	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-105-H5	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14362	N/A	SP-DCB-105-H5	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-105-H8	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14363	N/A	SP-DCB-105-H8	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-105-H10	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13131	N/A	SP-DCB-105-H10	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-105-H11	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14370	N/A	SP-DCB-105-H11A	1980	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	14367	N/A	SP-DCB-105-H11B	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-105-H12	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 19, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 4 of 7
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13901, C13902, C13911, C13912
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System Reactor Recirculation System 164D Class I

5. (a) Applicable Construction Code see remark 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	14368	N/A	SP-DCB-105-H12	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-105-H2000	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	28859	N/A	SP-DCB-105-H2000	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-105-H2001	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	21088	N/A	SP-DCB-105-H2001	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-105-H2003	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14365	N/A	SP-DCB-105-H2003	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-105-H2006	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22903	N/A	SP-DCB-105-H2006	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HBD-105-H2000	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14366	N/A	SP-HBD-105-H2000	1980	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 19, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 5 of 7
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13901, C13902, C13911,
Address C13912
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System Reactor Recirculation System 164D Class I
5. (a) Applicable Construction Code see remark 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-106-H2025	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCB-106-H2025	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-105-H9	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCB-105-H9	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-120-H2007	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCB-120-H2007	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-120-H2001	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06321	N/A	SP-DCB-120-H2001	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-120-H2002	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	13957	N/A	SP-DCB-120-H2002	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-120-H2003	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 19, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 6 of 7
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13901, C13902, C13911, C13912
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System Reactor Recirculation System 164D Class I

5. (a) Applicable Construction Code see remark 19 Edition, Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	14409	N/A	SP-DCB-120-H2003	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-120-H2008	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14410	N/A	SP-DCB-120-H2008	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-121-H2002	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCB-121-H2002	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-121-H10	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14415	N/A	SP-DCB-121-H10	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-121-H2001	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14329	N/A	SP-DCB-121-H2001	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-121-H2003	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14330	N/A	SP-DCB-121-H2003	1980	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 19, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 7 of 7
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108F WA C13901, C13902, C13911,
Address C13912
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System Reactor Recirculation System 164D Class I
5. (a) Applicable Construction Code see remark 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-121-H2008	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	22941	N/A	SP-DCB-121-H2008	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCB-121-H2009	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00120	N/A	SP-DCB-121-H2009	1977	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 18, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 1 of 1
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108F, WA C13896
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System REACTOR RECIRCULATION SYSTEM 173A CLASS II

5. (a) Applicable Construction Code see remarks 19 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-HCB-138-H4	1982	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-HCB-138-H4	1992	REPLACEMENT	N/A

7. Description of Work ADD STIFFNERS TO EXISTING SUPPORT

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure No Testing Required
 Other Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Applicable Construction Codes: For Pipe Supports -ASME III 1971 Edition thru Winter 1972

Applicable Manufacturer's Data Reports to be attached

Addenda: for Snubbers - ASME III 1977 Edition thru Summer 1979 Addenda. Code Case N-411 & N122

CALC. SR-1042

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SIC Hall Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 3-10-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

David Daubney Commissions NB 7525 PA 2159 NE
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 11 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603
Address DCP 90-3108; WA #'s C13817 & C14119
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101
Address Authorization No. N/A
 Expiration Date N/A

4. Identification of System MAIN STEAM SYSTEM 183A CLASS 1

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-108-H4	1982	REPLACED	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-108-H1	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06573-78	N/A	DBA-108-H1	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DBA-108-H1	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-108-H3	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06574-78	N/A	DBA-108-H3	1978	REPLACED	N/A

7. Description of Work SNUBBER REDUCTION PROJECT

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure NO TESTING REQUIRED
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks CALC. # SR-1024

Applicable Manufacturer's Data Reports to be attached

CODE CASE #'s N-122, N-319, & N-411

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date July 16, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of WALTHAM, MASSACHUSETTS have inspected the components described in this Owner's Report during the period 2-13-92 to 4-30-92, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date JULY 22 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date 11 MAY, 1992

Sheet 2 of 2

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

DCP 90-3108I; WA #'s C13817 & C14119
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A


Expiration Date N/A

4. Identification of System MAIN STEAM SYSTEM 183A CLASS 1

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PP&L	N/A	N/A	DBA-108-H3	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	DBA-108-H19	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03483-77	N/A	DBA-108-H19	1977	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	DBA-108-H19	1992	REPLACEMENT	NO



FORM NIS-2 (Back)

9. Remarks WA#s C13818, C13819, C13820, C13821, C13822, C13823, C13824, C13825, C13826, C13827,
Applicable Manufacturer's Data Reports to be attached
C13828, C13829, C13830, C13831, C13832, C13833, C23012, & C23213.
CALC#s SR5696S, 5696, 5697S, 5697, 5698S, 5698, 5699S, 5699, 5700S, 5700, 5701S, 5701, 5702S, 5702, 5703S
5704S, 5705S, 5705, 5706S, 5706, 5707S, 5707, 5708S, 5708, 5709S, 5709, 5710S, 5710, 5711S, & 5711.

CODE CASE#s N-122, N-319, & N-411.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date July 21, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of
WALTHAM, MASSACHUSETTS have inspected the components described
in this Owner's Report during the period 2-11-92 to 4-30-92, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

[Signature] Commissions NB 7525 PA 2159 NI
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 26, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 2 of 17
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#'s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I

III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-119-H2000	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27946-82	N/A	SP-DBA-119-H2000	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-120-H5	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	10952-79	N/A	SP-DBA-120-H5	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-120-H2000	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27866-82	N/A	SP-DBA-120-H2000	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-120-H2003	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC	17235-83	N/A	SP-DBA-120-H2003	1983	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H47	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	10914-79	N/A	SP-DCA-127-H47	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H51	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 26, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 3 of 17
Address


2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I
III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	05130-78	N/A	SP-DCA-127-H51	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H61	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27978-82	N/A	SP-DCA-127-H61	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H62	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	23591-81	N/A	SP-DCA-127-H62	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H66	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	21132-81	N/A	SP-DCA-127-H66	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H92	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	04088-78	N/A	SP-DCA-127-H92	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H93	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	04080-78	N/A	SP-DCA-127-H93	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 26, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 4 of 17
Address


2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I
 III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H146	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28864-82	N/A	SP-DCA-127-H146	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H148	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13057-80	N/A	SP-DCA-127-H148	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H151	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	10904-79	N/A	SP-DCA-127-H151	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H154	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27966-82	N/A	SP-DCA-127-H154	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H155	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13105-80	N/A	SP-DCA-127-H155	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H158	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date July 15, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 5 of 17
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I

III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13437-81	N/A	SP-DCA-127-H158	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H162	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27859-82	N/A	SP-DCA-127-H162	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H172	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	09735-79	N/A	SP-DCA-127-H172	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H174	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13061-80	N/A	SP-DCA-127-H174	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H175	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13062-80	N/A	SP-DCA-127-H175	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H178	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28977-82	N/A	SP-DCA-127-H178	1982	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 26, 1992
Name

Two North Ninth St., Allentown, PA 18101 Sheet 6 of 17
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name

PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name

Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address


Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I

III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2010	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13938-81	N/A	SP-DCA-127-H2010	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2012	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27861-82	N/A	SP-DCA-127-H2012	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2015	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	21127-81	N/A	SP-DCA-127-H2015	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2036	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13092-80	N/A	SP-DCA-127-H2036	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2045	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13094-80	N/A	SP-DCA-127-H2045	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2047	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 26, 1992
Name
Two North Ninth St., Allentown, PA 18101
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603
Address DCP#90-31081 WA#s SEE REMARKS SECTION
Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101
Address Authorization No. N/A
 Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I

III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	16387-80	N/A	SP-DCA-127-H2047	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2051	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13091-80	N/A	SP-DCA-127-H2051	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2054	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22940-81	N/A	SP-DCA-127-H2054	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-127-H2054	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2056	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13065-80	N/A	SP-DCA-127-H2056	1980	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-127-H2056	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2057	1982	REPLACED	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2058	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 26, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 8 of 17
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I

 III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13066-80	N/A	SP-DCA-127-H2058	1980	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-127-H2058	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2065	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13101-80	N/A	SP-DCA-127-H2065	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2070	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27950-82	N/A	SP-DCA-127-H2070	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2075	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22906-81	N/A	SP-DCA-127-H2075	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2076	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	06244-78	N/A	SP-DCA-127-H2076	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2078	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date May 26, 1992

Sheet 9 of 17

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

DCP#90-31081 WA#s SEE REMARKS SECTION
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A


Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I

III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22928-81	N/A	SP-DCA-127-H2078	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2079	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22929-81	N/A	SP-DCA-127-H2079	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2082	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13434-81	N/A	SP-DCA-127-H2082	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2083	1982	REPLACED	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2084	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27855-82	N/A	SP-DCA-127-H2084	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2085	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	05082-78	N/A	SP-DCA-127-H2085	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2092	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 26, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 10 of 17
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#'s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I

 III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28747-82	N/A	SP-DCA-127-H2092	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2088	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22872-81	N/A	SP-DCA-127-H2088	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2094	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28747-82	N/A	SP-DCA-127-H2094	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2100	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13141-80	N/A	SP-DCA-127-H2100	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2101	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22986-81	N/A	SP-DCA-127-H2101	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2104	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22899-81	N/A	SP-DCA-127-H2104	1981	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 26, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 11 of 17
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#'s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I

 III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2105	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22900-81	N/A	SP-DCA-127-H2105	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2106	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	21153-81	N/A	SP-DCA-127-H2106	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2109	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	09722-79	N/A	SP-DCA-127-H2109	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-127-H2112	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27861-82	N/A	SP-DCA-127-H2112	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H50	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	23544-81	N/A	SP-DCA-128-H50	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H84	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 26, 1992
Name
Two North Ninth St., Allentown, PA 18101
Address


2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603
Address DCP#90-31081 WA#'s SEE REMARKS SECTION
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101
Address Authorization No. N/A
 Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I
III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	10934-79	N/A	SP-DCA-128-H84	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H86	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	10935-79	N/A	SP-DCA-128-H86	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H96	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13055-80	N/A	SP-DCA-128-H96	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H97	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	06307-78	N/A	SP-DCA-128-H97	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H98	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	06301-78	N/A	SP-DCA-128-H98	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H110	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	10937-79	N/A	SP-DCA-128-H110	1979	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 26, 1992
Name

Two North Ninth St., Allentown, PA 18101 Sheet 13 of 17
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name

PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name

Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address


Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I

III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H114	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28812-82	N/A	SP-DCA-128-H114	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H116	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-128-H116	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H117	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	29319-82	N/A	SP-DCA-128-H117	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H124	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28881-82	N/A	SP-DCA-128-H124	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H125	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27854-82	N/A	SP-DCA-128-H125	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H130	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 26, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 14 of 17
Address


2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I
III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	05161-78	N/A	SP-DCA-128-H130	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-128-H130	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H131	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13103-80	N/A	SP-DCA-128-H131	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H136	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27922-82	N/A	SP-DCA-128-H136	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H2016	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	27965-82	N/A	SP-DCA-128-H2016	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H2018	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	14425-80	N/A	SP-DCA-128-H2018	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H2019	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 26, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 15 of 17
Address


2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I
III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	14344-80	N/A	SP-DCA-128-H2019	1980	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-128-H2019	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H2023	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13100-80	N/A	SP-DCA-128-H2023	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H2025	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	23545-81	N/A	SP-DCA-128-H2025	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H2026	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	28009-82	N/A	SP-DCA-128-H2026	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H2027	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	13077-80	N/A	SP-DCA-128-H2027	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H2030	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date May 26, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 16 of 17
Address


2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP#90-31081 WA#'s SEE REMARKS SECTION
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I
III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22997-81	N/A	SP-DCA-128-H2030	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H2031	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	14374-80	N/A	SP-DCA-128-H2031	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H2033	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	23590-81	N/A	SP-DCA-128-H2033	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	SP-DCA-128-H2033	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H2062	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	22912-81	N/A	SP-DCA-128-H2062	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DCA-128-H2068	1982	REPLACED	NO
MECHANICAL SNUBBER	PACIFIC SCIENTIFIC	03477-78	N/A	SP-DCA-128-H2068	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	SP-DBA-120-H4	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date July 20, 1992

Sheet 17 of 17

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

DCP#90-31081 WA#'s SEE REMARKS SECTION
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol None

Authorization N/A

Expiration Date N/A

4. Identification of System STEAM FLOW MONITORS SYSTEM 183F CLASS I

III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 80 thru W'80
 19

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

PIPE SUPPORT	PP&L	N/A	N/A	SP-DBA-120-H4	1992	REPLACEMENT	NO
--------------	------	-----	-----	---------------	------	-------------	----



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date 12 MAY, 1992

Sheet 1 of 26

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE

 DCP 90-3108I; WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H301	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	14794-82	N/A	GBC-101-H301	1982	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H301	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H316	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01186-77	N/A	GBC-101-H316A	1977	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	02574-78	N/A	GBC-101-H316B	1978	REPLACED	N/A

7. Description of Work SNUBBER REDUCTION PROJECT

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure NO TESTING REQUIRED
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks WA #'s C13844, C13845, C13846, C13847, C14118, C14120, C14121, C14122, C14123, C14124,
Applicable Manufacturer's Data Reports to be attached
C14125, C14126, C14127, C23012, & C23213.

CALC. #'s SR-951-1, 951-2, 952, & 953.

CODE CASE #'s N-122, N-319, & N-411.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this REPLACEMENT conforms to the rules of the
repair or replacement ASME Code, Section XI.

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed SK Lal Date July 17, 1992
Owner or Owner's Designee, Title SUPERINTENDENT OF PLANT

CERTIFICATION OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of PENNSYLVANIA and employed by ARKWRIGHT MUTUAL INSURANCE CO. of
WALTHAM, MASSACHUSETTS have inspected the components described
in this Owner's Report during the period 2-12-92 to 4-30-92, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.


Dr. D. Dauling Commissions NB 7525 PA 2157
Inspector's Signature National Board, State, Province, and Endorsements

Date July 22, 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
- Two North Ninth St., Allentown, PA 18101 Sheet 2 of 26
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
- PO Box 467, Berwick, PA 18603 DCP 90-3108I; WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
- Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address
- Expiration Date N/A
4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III
5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H316	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H333	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06963-78	N/A	GBC-101-H333	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H106	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02617-78	N/A	GBC-101-H106	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H160	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01243-81	N/A	GBC-101-H160	1981	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H178	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02651-78	N/A	GBC-101-H178	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H188	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02743-78	N/A	GBC-101-H188	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 3 of 26
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108I; WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H189	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00912-77	N/A	GBC-101-H189	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H101	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02611-78	N/A	GBC-101-H101	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H103	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00933-77	N/A	GBC-101-H103	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H105	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02609-78	N/A	GBC-101-H105	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H73	1982	REPLACED	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H182	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01502-78	N/A	GBC-101-H182	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date 12 MAY, 1992

Sheet 4 of 26

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

DCP 90-3108I; WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H182	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H186	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00901-77	N/A	GBC-101-H186A	1977	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	00909-77	N/A	GBC-101-H186B	1977	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H186	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H158	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00925-77	N/A	GBC-101-H158	1977	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H158	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H200	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02671-78	N/A	GBC-101-H200	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H202	1982	REPLACED	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date 12 MAY, 1992
 Sheet 5 of 26

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 DCP 90-3108I; WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	04098-79	N/A	GBC-101-H202	1979	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H210	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01154-77	N/A	GBC-101-H210	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H211	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01155-77	N/A	GBC-101-H211	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H214	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02753-78	N/A	GBC-101-H214	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H198	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01242-78	N/A	GBC-101-H198	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H198	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H199	1982	REPLACED	NO

**FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI**

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date 12 MAY, 1992
 Sheet 6 of 26

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 DCP 90-3108I; WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

MECH. SNUBBER	PACIFIC SCIENTIFIC	02674-78	N/A	GBC-101-H199	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H199	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H215	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	08620-81	N/A	GBC-101-H215	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H215	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H139	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02838-00	N/A	GBC-101-H139	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H139	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H282	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01501-78	N/A	GBC-101-H282	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H282	1992	REPLACEMENT	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 7 of 26
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-31081; WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H140	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03244-78	N/A	GBC-101-H140	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H140	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H131	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00921-77	N/A	GBC-101-H131	1977	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H131	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H132	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00905-77	N/A	GBC-101-H132	1977	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H132	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H135	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00908-77	N/A	GBC-101-H135	1977	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date 12 MAY, 1992
 Sheet 8 of 26

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 DCP 90-3108I; WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H138	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02839-00	N/A	GBC-101-H138	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H226	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	09465-82	N/A	GBC-101-H226	1982	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H130	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00920-77	N/A	GBC-101-H130	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H136	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02837-78	N/A	GBC-101-H136	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H142	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02604-78	N/A	GBC-101-H142	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H108	1982	REPLACED	NO



**FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI**

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 9 of 26
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108I; WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III
5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	01308-70	N/A	GBC-101-H108	1970	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H109	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01537-78	N/A	GBC-101-H109	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H112	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01504-78	N/A	GBC-101-H112	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H117	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01384-78	N/A	GBC-101-H117	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H121	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01237-78	N/A	GBC-101-H121	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H128	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	11021-83	N/A	GBC-101-H128	1983	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 10 of 26
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-3108I; WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H110	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01257-78	N/A	GBC-101-H110	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H110	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H111	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02578-78	N/A	GBC-101-H111	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H111	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H126	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01241-78	N/A	GBC-101-H126	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H126	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H129	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00883-77	N/A	GBC-101-H129	1977	REPLACED	N/A



**FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI**

1. Owner * Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date 12 MAY, 1992
 Sheet 11 of 26

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 DCP 90-31081; WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H129	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H164	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01261-78	N/A	GBC-101-H164	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H169	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00881-77	N/A	GBC-101-H169	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H167	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01296-78	N/A	GBC-101-H167	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H167	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H173	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01496-78	N/A	GBC-101-H173A	1978	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	01388-78	N/A	GBC-101-H173B	1978	REPLACED	N/A



**FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI**

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date 12 MAY, 1992
 Sheet 12 of 26

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 DCP 90-31081; WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A


4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H173	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H175	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00890-77	N/A	GBC-101-H175	1977	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H175	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H177	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01299-78	N/A	GBC-101-H177	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H177	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H170	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	11020-83	N/A	GBC-101-H170	1983	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H170	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H151	1982	REPLACED	NO




FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 13 of 26
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108I; WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III
5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

MECH. SNUBBER	PACIFIC SCIENTIFIC	01541-78	N/A	GBC-101-H151	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H151	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H152	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	00800-77	N/A	GBC-101-H152	1977	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H152	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H155	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01512-78	N/A	GBC-101-H155	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H155	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H156	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	08644-81	N/A	GBC-101-H156	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H156	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 14 of 26
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-31081; WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H248	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01191-77	N/A	GBC-101-H248	1977	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H248	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H244	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01262-78	N/A	GBC-101-H244A	1978	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	01259-78	N/A	GBC-101-H244B	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H244	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H66	1982	REPLACED	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H68	1982	REPLACED	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H70	1982	REPLACED	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H100	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date 12 MAY, 1992
 Sheet 15 of 26

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 DCP 90-3108I; WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	02767-78	N/A	GBC-101-H100	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H153	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01536-78	N/A	GBC-101-H153	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H245	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01382-78	N/A	GBC-101-H245	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H246	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01491-77	N/A	GBC-101-H246	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H159	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01240-78	N/A	GBC-101-H159	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H159	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H330	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date 12 MAY, 1992

Sheet 16 of 26

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE

DCP 90-3108I; WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None

Authorization No. N/A

Expiration Date N/A


4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

MECH. SNUBBER	PACIFIC SCIENTIFIC	06965-80	N/A	GBC-101-H330	1980	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H330	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H331	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	06949-80	N/A	GBC-101-H331	1980	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H331	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H191	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01530-78	N/A	GBC-101-H191	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H191	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H216	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01371-78	N/A	GBC-101-H216	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H216	1992	REPLACEMENT	NO




FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
- Two North Ninth St., Allentown, PA 18101 Sheet 17 of 26
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
- PO Box 467, Berwick, PA 18603 DCP 90-3108I; WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
- Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address
- Expiration Date N/A
4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III
5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H190	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01383-78	N/A	GBC-101-H190	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H192	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01533-80	N/A	GBC-101-H192	1980	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H194	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01385-78	N/A	GBC-101-H194	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H213	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02577-78	N/A	GBC-101-H213	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H277	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H277	1992	REPLACEMENT	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03188-78	N/A	GBC-101-H277A	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 18 of 26
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-3108I; WA #s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H195	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01161-00	N/A	GBC-101-H195	1977	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H228	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02678-78	N/A	GBC-101-H228	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H204	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01360-78	N/A	GBC-101-H204	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H204	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H206	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01256-78	N/A	GBC-101-H206	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H206	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H208	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 19 of 26
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-31081; WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III
5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	01298-78	N/A	GBC-101-H208	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H208	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H209	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01292-78	N/A	GBC-101-H209	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H209	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H256	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02742-78	N/A	GBC-101-H256	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H256	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H257	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01331-78	N/A	GBC-101-H257	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H257	1992	REPLACEMENT	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 20 of 26
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-31081; WA #s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III
5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H266	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01349-78	N/A	GBC-101-H266A	1978	REPLACED	N/A
MECH. SNUBBER	PACIFIC SCIENTIFIC	01368-78	N/A	GBC-101-H266B	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H266	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H267	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01379-00	N/A	GBC-101-H267	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H267	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H252	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01327-78	N/A	GBC-101-H252	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H275	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02676-78	N/A	GBC-101-H275	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME-Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 21 of 26
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-31081; WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components


Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H263	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01513-78	N/A	GBC-101-H263	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H264	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01509-78	N/A	GBC-101-H264	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H268	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01531-78	N/A	GBC-101-H268	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H271	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03497-78	N/A	GBC-101-H271	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H274	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	02614-78	N/A	GBC-101-H274	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H230	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
 Two North Ninth St., Allentown, PA 18101 Sheet 22 of 26
Address
2. Plant Susquehanna Steam Electric Station Unit ONE
Name
 PO Box 467, Berwick, PA 18603 DCP 90-31081; WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
 Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A
4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III
5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MECH. SNUBBER	PACIFIC SCIENTIFIC	01522-78	N/A	GBC-101-H230	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H239	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03496-78	N/A	GBC-101-H239	1978	REPLACED	N/A
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H234	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	08645-81	N/A	GBC-101-H234	1981	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H234	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H238	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01364-78	N/A	GBC-101-H238	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H238	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H240	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01258-78	N/A	GBC-101-H240	1978	REPLACED	N/A



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date 12 MAY, 1992
 Sheet 23 of 26

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
Repair Organization P.O. No., Job No., etc.
DCP 90-3108I; WA #s SEE REMARKS

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address


Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H240	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H241	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	01234-78	N/A	GBC-101-H241	1978	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H241	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H279	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	03645-79	N/A	GBC-101-H279	1979	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H279	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H278	1982	REPLACED	NO
MECH. SNUBBER	PACIFIC SCIENTIFIC	04128-79	N/A	GBC-101-H278	1979	REPLACED	N/A
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H278	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H319	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Date 12 MAY, 1992
 Sheet 24 of 26

2. Plant Susquehanna Steam Electric Station
Name
 PO Box 467, Berwick, PA 18603
Address

Unit ONE
 DCP 90-3108I; WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
 Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
-------------------	----------------------	-------------------------	--------------------	----------------------	------------	------------------------------------	-------------------------------

PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H319	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H332	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H332	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H113	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H113	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H127	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H127	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H145	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H145	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H174	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H174	1992	REPLACEMENT	NO

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co. Date 12 MAY, 1992
Name
Two North Ninth St., Allentown, PA 18101 Sheet 25 of 26
Address

2. Plant Susquehanna Steam Electric Station Unit ONE
Name
PO Box 467, Berwick, PA 18603 DCP 90-31081; WA #'s SEE REMARKS
Address Repair Organization P.O. No., Job No., etc.


3. Work Performed by Pennsylvania Power & Light Co. Type Code Symbol Stamp None
Name
Two North Ninth St., Allentown, PA 18101 Authorization No. N/A
Address Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H255	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H255	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H261	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H261	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H276	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H276	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H318	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H318	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H222	1982	REPLACED	NO
PIPE SUPPORT	PP&L	N/A	N/A	GBC-101-H222	1992	REPLACEMENT	NO
PIPE SUPPORT	BECHTEL	N/A	N/A	GBC-101-H272	1982	REPLACED	NO



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Date 12 MAY, 1992
 Sheet 26 of 26

2. Plant Susquehanna Steam Electric Station
Name
PO Box 467, Berwick, PA 18603
Address

Unit ONE
DCP 90-3108I; WA #'s SEE REMARKS
Repair Organization P.O. No., Job No., etc.

3. Work Performed by Pennsylvania Power & Light Co.
Name
Two North Ninth St., Allentown, PA 18101
Address

Type Code Symbol Stamp None
 Authorization No. N/A
 Expiration Date N/A

4. Identification of System MAIN STEAM RELIEF SAFETY SYSTEM 183D CLASS III

5. (a) Applicable Construction Code III 19 77 Edition, thru S'79 Addenda, REMARKS Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 thru W'80

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PIPE SUPPORT.	PP&L	N/A	N/A	GBC-101-H272	1992	REPLACEMENT	NO

