

TITLE: <b>QUALIFICATION OF CABLE TRAY AND CONDUIT SYSTEMS BY A46 PROGRAM</b>		PLANT/UNIT <b>BFN Unit 0</b>	
PREPARING ORGANIZATION <b>NE-Civil</b>		KEY NOUNS (Consult RIMS DESCRIPTORS LIST) <b>CABLE TRAY, CONDUIT, SEISMIC, A46 OUTLIER</b>	
BRANCH/PROJECT IDENTIFIERS <b>CD-Q0000-931227</b>		Each time these calculations are issued, preparers must ensure that the original (R0) RIMS accession number is filled in. Rev (for RIMS' use) RIMS accession number	
APPLICABLE DESIGN DOCUMENTS <b>BFN-50-C-7104</b>		R0	940415B0016 R14 94 0131 111
		R4	<b>960131B0029 R14 '96 0124 107</b>
		R5	<b>R14 '96.0220 118</b>
SAR SECTION(S) <b>N/A</b>		UNID SYSTEM(S) <b>000</b>	R6 <b>R14 '96 0415 102</b>

Revision 0	R4	R5	R6	Safety-related? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
DCN No. (or indicate N/A)	N/A	N/A	N/A	Statement of Problem
Prepared P. S. Ghosal	ACR.	ACR	<i>[Signature]</i> G.S. NAIDAN	RESOLUTION OF OUTLIERS FOR A46 WALKDOWNS FOR RACEWAY SYSTEM. THIS CALCULATION IS PREPARED IN RESPONSE TO NRC UNRESOLVED SAFETY ISSUE, USI A-46
Checked A. C. Relwani	<i>[Signature]</i>	<i>[Signature]</i>	ACR	
Reviewed A. C. Relwani	<i>[Signature]</i>	<i>[Signature]</i>	ACR.	
Approved R. D. Cutsinger	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	
Date 1-31-94	24 Jan 96	20 Feb 96	15 Apr 96	
List all pages added by this revision	SEE	SEE	SEE	
List all pages deleted by this revision	REVISION	REV	REV	
List all pages changed by this revision	LOG	LOG	LOG	
Calculation revision (A) Entire calculation (P) Selected pages	P	P	P	<b>ORIGINAL</b>

**Abstract**

These calculations contain unverified assumptions that must be verified later. Yes  No

These calculations contain special requirements and/or limiting conditions Yes  No

Revision 4: THIS CALCULATION ADDRESSES THE LIMITED ANALYTICAL REVIEW CASES AND OTHER OUTLIERS FROM A-46 WALKDOWN. CALCULATIONS ARE BASED ON GUIDELINES GIVEN IN GENERIC IMPLEMENTATION PROCEDURE (GIP) FOR SEISMIC VERIFICATION OF NUCLEAR PLANT EQUIPMENT

REV. 5: NO CHANGE TO ABSTRACT

REV. 5: TOTAL PAGE COUNT: 556

REV. 5: MICROFILM ONLY THE REVISED, ADDED, OR REPLACED PAGES.

REV. 6: NO CHANGE TO ABSTRACT - TOTAL PAGE COUNT: 566

REV. 6: MICROFILM ONLY THE REVISED & ADDED PAGES.

Rev. 4 Microfilm only the Revised, Added and Replaced pages.


Rev. 4 Total No. of pages: 549

9810020153 980925  
PDR ADOCK 05000260  
P PDR

Microfilm and store calculations in RIMS Service Center. **ENGINEERING RECORDS PROCESSING CALCULATION CONTROL** Microfilm and destroy

Microfilm and return calculations to: **EDB ANNEX C BEN**

9810020153



# QA Record

DNE CALCULATIONS

SHEET. 1

TITLE: QUALIFICATION OF CABLE TRAY AND CONDUIT SYSTEM BY A46 PROGRAM		PLANT/UNIT BFN Unit 0	
PREPARING ORGANIZATION Civil	KEY WORDS (Consult RIMS DESCRIPTORS LIST) CONDUIT, CABLE TRAY, SEISMIC, A46 OUTLIER		
BRANCH/PROJECT IDENTIFIERS  CD-Q0000-931227	Each time these calculations are issued, preparers must ensure that the original (R0) RIMS accession number is filled in. Rev (for RIMS' use) RIMS accession number		
APPLICABLE DESIGN DOCUMENTS GIP FOR SEISMIC VERIFICATION OF NUCLEAR PLANT EQUIPMENT AND BFH-50-C-7104	R0	940415B0016	R14 '94 0131 111
	R1	940915D0007	R14 '94 0901 107
	R2	950615A0018	R14 '95 0608 103
SAR SECTION(S) N.A	UNID SYSTEM(S) 361 & 362	R3	951019C0019 R14 '95 1010 116

Revision 0	R1	R2	R3	Safety-related? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
DCN No. (or indicate N/A) DCN W22555A	DCN W22555A	WDP-CEB- 011-018	W17424, W33940	Statement of Problem
Prepared P.S. Ghosal PARTHA S. GHOSAL	<i>[Signature]</i> C.W. Andrews	<i>[Signature]</i> S.S. HAIDER	ACR.	RESOLUTION OF OUTLIERS FOR A46 WALKDOWN FOR RACEWAY SYSTEM. THIS CALCULATION IS PREPARED IN RESPONSE TO NRC UNRESOLVED SAFETY ISSUE, USI A-46.
Checked Anand C. Relwan	<i>[Signature]</i> P. ROSE	<i>[Signature]</i> S.N. SIK	CP	
Reviewed Anand C. Relwan	<i>[Signature]</i> 8-31-94	<i>[Signature]</i> L.E. SHUB	CP	
Approved R.D. CUTSINGER	<i>[Signature]</i> 8-31-94	<i>[Signature]</i> for RKG	<i>[Signature]</i>	
Date 8-31-94	8-31-94	6-8-95	10-10-95	
List all pages added by this revision	SEE	SEE	SEE	<b>ORIGINAL</b>
List all pages deleted by this revision	REV	REV	REV.	
List all pages changed by this revision	LOG	LOG	LOG.	

**Abstract**

These calculations contain unverified assumptions that must be verified later. Yes  No

These calculations contain special requirements and/or limiting conditions. Yes  No

This calculation addresses the limited Analytical Review cases and other outliers from A-46 walkdown. Calculations are based on guidelines given in Generic Implementation Procedure (GIP) for seismic verification of Nuclear Plant Equipment.

*The abstract remains unchanged for Revision 1. | R1*

*THE ABSTRACT REMAINS UNCHANGED FOR REVISION 2. | R2*

*THE ABSTRACT REMAINS UNCHANGED FOR REVISION 3.*

*TOTAL PAGE COUNT REV 3 = 542*

ENGINEERING RECORDS PROCESSING

CALCULATION CONTROL


EOB 1B-BFN

Microfilm and store calculations in RIMS Service Center.  
 Microfilm and return calculations to:

Microfilm and destroy.   
Address:




Title: QUALIFICATION OF CABLE TRAY AND CONDUIT SYSTEM BY A46 PROGRAM.		REVISION LOG CD-Q0000-931227
Revision No.	DESCRIPTION OF REVISION	Date Approved
0	Original issue  Total pages: 444	1-31-94
1	<p>Revised to incorporate DCNs F-31259A, F-31672A, F-31658A, and F-31869A for DCN W 22555A.</p> <p>Shts Revised: 1, 4, 9, 24, 47, 184, 240, 187-190, 209, 2</p> <p>Shts Added: 3a, App. C (C1-C3)</p> <p>Shts Replaced: 25, 55, 191, 210, 185</p> <p>Shts DELETED: NONE</p> <p>Legibility evaluated and accepted for issue.</p> <p><i>[Signature]</i> 8/30/94 Signature Date</p> <p>Shts 25, 55, 191, 210, 185 and App. C (C2 &amp; C3)</p> <p>Total pages 448</p>	8-31-94
2	<p>REVISED TO INCORPORATE WDP. CEB-011-018</p> <p>PAGES ADDED: 3b, APP. D (D1-D5)</p> <p>PAGES REVISED: 1, 2, 4, 16</p> <p>PAGES DELETED: NONE.</p> <p>Total sheets: 454</p>	6-8-95
3	<p>REVISED TO INCORPORATE WALKDOWN &amp; OUTLIERS FOR DRYWELL.</p> <p>REVISED PG. NO: 1, 2, 4, 9, 172, 175, 235 TO 238, APPENDIX A, PG A 135.</p> <p>REPLACED PG. NO - 5 TO 8, 10 THRU 13, 170, 229 TO 234, 240, APPENDIX A, PG A2 THRU A5</p> <p>ADDED PG. NO:- 3c, 8.1, 11.1, 11.2, 177.1 TO 177.23, 233-1, 239.1 TO 239.4, APPENDIX A - PG A5-1, A64.1 TO A64.3, A92.1, A92.2, A135.1, A192 TO A223; APPENDIX B, PG B14 THRU B16; APPENDIX D - PG D6 THRU D13; APPENDIX E - PG E1 THRU E6</p> <p>(ONLY PAGES CHANGED OR ADDED SHOULD BE RIMSED)</p>	10-10-95



Title: QUALIFICATION OF CABLE TRAY AND CONDUIT SYSTEMS  
BY A-46 PROGRAM

REVISION LOG  
CD-Q0000-931227

Revision No.	DESCRIPTION OF REVISION	Date
4	<p>Revised to incorporate additional walkdowns with NRC and minor clarifications.</p> <p>Revised pages: 197, 222, 240, Appendix D, page D6            Added pages: 1a, 2a, 3d, Appendix D, page D14, D15, D16, D17            Replaced pages: 177.23, 229, A92.1            Deleted pages: None</p> <p>Microfilm only the Revised, Added and Replaced pages</p>	24 Jan 76
5	<p>REVISED TO MAKE MINOR CLARIFICATIONS &amp; CORRECT MINOR OMISSIONS</p> <p>REVISED PG No: - 1a, 2a, APPENDIX A, SHT A11, A 53, A76            A 117, A128, A135-1, A145, A146, A147, A151, A 167, A 168</p> <p>ADDED PG NO: - 3e, 94.1 THRU 94.6</p> <p>REPLACED PG. NO: - A148, A156</p> <p>DELETED PG. NO: NONE</p> <p>MICROFILM ONLY THE REVISED, ADDED OR REPLACED PAGES.</p>	26 Feb 76
6	<p>REVISED TO DOCUMENT ADDITIONAL QUALIFICATION OF 3 OUTLIERS DUE TO DIFFICULTY OF MAINTENANCE.</p> <p>REVISED SHT No. 1a, 2a, 6, 7, 8, 8.1, 231, 232, 233, 233.1, A67, A125, A136, A147, A152, A176</p> <p>ADDED SHT. NO. 3f, 220a thru 220f, A 67-1, A152-1, A177-1            DELETED SHT. NO. NONE</p> <p>MICROFILM ONLY THE REVISED OR ADDED PAGES.</p>	27 Apr 76
	<p>THIS SHEET ADDED BY REV. 4</p>	





CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

CD-00000-931227

Calculation No.

0

Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review   X
- 2. Alternate Calculation
- 3. Qualification Test

Comments:

This revision of the calculation has been found to be technically adequate in that  
computations, judgements, assumptions, and logic are based on accepted engineering  
methods.

Arwand C. Rehsai 1/28/94  
 Design Verifier Date  
 (Independent Reviewer)



CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

CD-Q0000-931227

Calculation No.

1  
Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

✓  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similiar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

\_\_\_\_\_  
 The above referenced calculation was independently reviewed and  
 found to be adequate based on accepted sound engineering methods.  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Paul Kati

Design Verifier  
(Independent Reviewer)

8-31-94  
Date

*This Sht. Added at Rev. 1*



# CALCULATION DESIGN VERIFICATION FORM (INDEPENDENT REVIEW)

CD-00000-931227  
Calculation No.

2  
Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

The above referenced calculation was independently reviewed and found to be adequate based on accepted sound engineering methods.

---

---

---


---

---

---

  
Design Verifier  
(Independent Reviewer)

6/8/95  
Date



**CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM**

Calculation CD-Q0000 - 931227 R. 3

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.):

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

The above calculation revision so noted has been reviewed by the Design Review Methodology and has been determined to be technically adequate based on the design input information contained herein using accepted handbook and/or computer applications and sound engineering practices and techniques.

  
 \_\_\_\_\_  
 Design Verifier  
 (Independent Reviewer)

10-10-95  
 Date

This sheet added by Revision 3





\_\_\_ CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

Calculation CD - Q0000-931227 Rev. 4

Method of design verification (independent review) used (check method used):

1. Design Review  
 2. Alternate Calculation  
 3. Qualification Test

Justification (explain below):

- Method 1:** In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc).
- Method 2:** In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.
- Method 3:** In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

The above calculation revision so noted has been reviewed by the Design Review Methodology and has been determined to be technically adequate based on the design input information contained herein using accepted handbook and/or computer applications and sound engineering practices and techniques.

  
 Design Verifier      Date 01-23-96

This sheet added by Revision 4



\_\_\_\_ CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

Calculation CD - 0000-93227 Rev. 5

Method of design verification (independent review) used (check method used):

1. Design Review  
 2. Alternate Calculation  
 3. Qualification Test

Justification (explain below):

**Method 1:** In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc).

**Method 2:** In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

**Method 3:** In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

The above calculation revision so noted has been reviewed by the Design Review Methodology and has been determined to be technically adequate based on the design input information contained herein using accepted handbook and/or computer applications and sound engineering practices and techniques.

  
 \_\_\_\_\_ 02-15-96  
 Design Verifier Date

This sheet added by Revision 5



**CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM**

Calculation CD - 00000-931227 Rev. 6

Method of design verification (independent review) used (check method used):

1. Design Review  
 2. Alternate Calculation  
 3. Qualification Test

Justification (explain below):

- Method 1:** In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc).
- Method 2:** In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.
- Method 3:** In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

The above calculation revision so noted has been reviewed by the Design Review Methodology and has been determined to be technically adequate based on the design input information contained herein using accepted handbook and/or computer applications and sound engineering practices and techniques.

Anand C. Relwain    4-15-96  
 Design Verifier    Date

This sheet added by Revision 6



**QUALIFICATION OF CABLE TRAY AND CONDUIT  
SYSTEM BY A46 PROGRAM**

SHEET 4 OF  
CD-Q0000-931227, Rev. 1  
COMPUTED For DATE 1-28-94  
CHECKED ACE DATE 1-28-94

REV	Prepared By <u>ACR</u> Date <u>10-9-95</u>
<u>3</u>	Checked By <u>cup</u> Date <u>10-10-95</u>

Rev.	Orign <u>adh</u> Date <u>6/7/95</u>
<u>2</u>	Chkd. <u>OR</u> Date <u>6/8/95</u>

REV.	Prepared By <u>CWA</u> Date <u>8/30/94</u>
<u>1</u>	Checked By <u>Wbi</u> Date <u>8-31-94</u>

INDEX

<u>ITEM</u>	<u>PAGE</u>
CALCULATION COVER SHEET	1
REVISION LOG	2
INDEPENDENT REVIEW FORM	3, 3a, 3b, 3c   R2   R3
INDEX SHEET	4
OUTLIER INDEX TABLE	5
1.0 PURPOSE	9
2.0 ASSUMPTION	9
3.0 REFERENCE	10
4.0 DESIGN INPUT DATA	11
5.0 COMPUTATIONS	14
5.1 ANALYTICAL REVIEW	15
5.2 QUALIFICATION OF OUTLIERS	169
6.0 SUMMARY OF RESULTS	229
7.0 CONCLUSION	240
APPENDIX A (OUTLIER SEISMIC VERIFICATION SHEETS)	A 223   R3 A1-A191
APPENDIX B (DCN W22555A AND COPY OF DCA'S) R3 EDCH F38457,	B1-B13 B16
APPENDIX C (CATALOG INFORMATION)	C1-C3   R1
APPENDIX - D (NRC REVIEW SHEETS)	D1-D13
APPENDIX-E (PEER REVIEW SHEETS)	E1-E6   R3.






OUTLIER INDEX TABLE

AREA NO.	PROBLEM NO.	REFERENCE PAGE	
		CALC PAGE NO	APPENDIX PAGE NO.
9 NE CORNER RM	9-01		A6
	21-01		A7
21 REACTOR U3 E1 565'	21-02		A8
	21-03	170-176	A10
	21-04	16-25	A11
	21-05		A14
	21-06	26-34	A17
	21-07		A21
	21-08	186-191	A23
	21-09		A25
	21-10		A27
	21-11		A29
	21-12	170-176	A31
	21-13	170-176	A33
	21-14		A35
	21-15	172, 184, 185	A37
	21-16		A39
	21-17	170-174, 177, 192-194	A41
	21-18		A44
	21-19		A47
	21-20	195-199	A50
	21-21		A53
	21-22		A55
	21-23	192-194	A57
	21-24		A60

THIS PAGE REPLACED BY REV. 3



QUALIFICATION OF CABLE TRAY AND CONDUIT SYSTEM BY A46 PROGRAM

SHEET 6 OF           
 CD-Q0000-931227  
 COMPUTED ACR DATE 10-6-95  
 CHECKED. af DATE 10-7-95

AREA NO.	PROBLEM NO.	REFERENCE PAGE	
		CALC PAGE NO	APPENDIX PAGE NO.
21 REACTOR U3 EL. 565'-0"	21-25	35-44	A62
	21-26	177.1-177.22	A64.1
	21-27		A64.2
	21-28		A64.3
22 REACT U3 EL. 593	22-01		A65
	22-02	(A67.1)	A67
	22-03	200-204	A68
	22-04		A71
	22-05		A73
	22-06		A76
	22-07		A77
	22-08		A80
	22-09		A83
	22-10		A86
	22-11	205-207	A88
	22-12		A90
	22-13		A91
	22-14		A92
22-15	177.23	A92.1	
22-16		A92.2	
23 REACTOR U3 EL 621'	23-01		A93
	23-02	45-72	A97
	23-03		A100
	23-04	170-174, 178, 208-210	A102
	23-05	170-174, 178, 211-213	A104
	23-06		A106
	23-07		A109
	23-08		A113

R3

R6

R3

THIS PAGE REPLACED BY REV.3

REV 6	ORIGINATOR <u>SSH</u>	DATE <u>4/1/9.</u>
	CHECKER <u>ACR</u>	DATE <u>4/15/9</u>



QUALIFICATION OF CABLE TRAY AND CONDUIT SYSTEM BY A46 PROGRAM

SHEET 7 OF  
 CD-0000-931227  
 COMPUTED ACR DATE 10-6-95  
 CHECKED af DATE 10-7-95

AREA NO.	PROBLEM NO.	REFERENCE PAGE	
		CALC PAGE NO	APPENDIX PAGE NO.
23 REACTOR U3 EL. 621'0"	23-09	214-215	A115
24 REACTOR U3 EL 639'	24-01		A117
	24-02		A118
27 DRYWELL UNIT 3	27-01		A192
	27-02		A194
	27-03		A196
	27-04		A197
	27-05	172	A198
	27-06		A199
	27-07		A200
	27-08		A201
	27-09		A203
	27-10		A206
	27-11		A207
	27-12		A209
	27-13		A211
	27-14		A213
	27-15		A215
	27-16		A218
	27-17		A220
	27-18		A221
29 CONTROL BAY U1 EL 606	29-01		A119
	29-02	170-174, 179	A121
	29-03	216-220	A123
	29-04	220a-220d R6	A125
	29-05		A127
	29-06		A128
	29-07		A129
	29-08		A130

R3

REV 6  
 Prepared by DBS Date 3-21-90  
 Checked by ACR Date 3-22-90

THIS PAGE REPLACED BY REV.3




QUALIFICATION OF CABLE TRAY AND CONDUIT SYSTEM BY A46 PROGRAM

SHEET 8 OF  
CD-00000-931227  
 COMPUTED ACR DATE 10-6-95  
 CHECKED up DATE 10-7-95

AREA NO.	PROBLEM NO.	REFERENCE PAGE	
		CALC PAGE NO	APPENDIX PAGE NO.
31 CONTROL BAY U2 EL 593'	31-01	192-194	A132
	31-02		A134
	31-03		A135
32 Control Bay U2 EL 606'	32-01	<u>220C-220E/R6</u>	A136
	32-02		A137
	32-03		A138
	32-04		A139
	32-05		A140
	32-06		A141
	32-07	73-94	A142
	32-08		A145
	32-09	<u>R6</u>	A146
	32-10	<u>CD-02031-883491</u>	A147
34 CONTROL BAY U3 EL 593'	34-01		A148
35 CONTROL BAY U3 EL 606'	35-01	170-174, 180	A149
	35-02	170-174, 180	A150
	35-03		A151
	35-04	A152-1	A152
	35-05	95-113	A153
	35-06	114-133	A156
	35-07		A158
	35-08		A159
39 TORUS U3	39-01	170-174, 181	A160
	39-02		A162
	39-03		A164
	39-04		A167
	39-05		A168
45 U3 D.G BLDG	45-01	134-140	A170
46 SBGT	46-01	170-174, 182	A173

REV	6
	Prepared By <u>DL</u> Date <u>3-22-90</u> Checked By <u>ACB</u> Date <u>2-22-96</u>

R6





QUALIFICATION OF CABLE TRAY AND CONDUIT  
SYSTEM BY A46 PROGRAM

SHEET 8.1 OF  
CD-Q0000-931227  
 COMPUTED ACR DATE 10-6-95  
 CHECKED- up DATE 10-7-95

AREA NO.	PROBLEM NO.	REFERENCE PAGE	
		CALC PAGE NO	APPENDIX PAGE NO.
48 INTAKE PUMP HOUSE	48-01	221-225	A174
49 CABLE TUNNEL	49-01	A177.1	A176
	49-02	226-228	A178
	49-03		A180
	49-04	141-168	A182
50 REACTOR U1-U3 EL 664'	50-01		A186
	50-02		A188
	50-03	170-174, 183	A190
	50-04		A191

|R6

THIS PAGE ADDED BY REV. 3

REV	ORIGINATOR: <u>SSH</u>	DATE <u>4/11/96</u>
<u>6</u>	CHECKER <u>ACR</u>	DATE <u>4-15-96</u>



QUALIFICATION OF CABLE TRAY AND CONDUIT SYSTEM BY A46 PROGRAM

SHEET 2 OF  
CD-Q0000-931227, Rev. 1  
COMPUTED FZL DATE 1-29-94  
CHECKED ACR DATE 1-28-94

REV	Prepared By <u>ACR</u> Date <u>10-6-95</u>
3	Checked By <u>WJ</u> Date <u>10-10-95</u>

1.0 PURPOSE:

Purpose of this calculation is to qualify existing cable tray and conduit supports by A46 program. Field walkdown for A46 program was performed for all cable tray and conduit supports located in Reactor Building unit 3 (except Drywell), Control Bay Area for all three units, unit 3 Diesel Generator building, Standby Gas Treatment Building, Cable Tunnel and Pump House. The A46 program review for drywell shall be done under a separate DCN. Outliers were identified as per GIP walkdown procedure. Few Analytical samples were selected in the field based on major different types of raceway support configurations in the plant and most heavily loaded support for each configuration. *Revision 1 to this calculation provides evaluations for FDENS F31259A, F31672A, F31658A, & F31869A.*

The purpose of the calculations is not to estimate actual seismic response and system performance during an earthquake. Rather, the purpose of the calculations is to show that cable tray and conduit supports are at least as rugged as those that performed well as evidenced by past experience.

2.0 ASSUMPTIONS:

No unverified assumptions made in this calculation. Any assumption made are within the GIP guideline or design criteria BFN-50-C-7104.

REV.	Prepared By <u>WJ</u> Date <u>8/30/94</u>
1	Checked By <u>PLK</u> Date <u>8-31-94</u>




QUALIFICATION OF CABLE TRAY AND CONDUIT  
SYSTEMS BY A-46 PROGRAM

SHEET 10 OF \_\_\_\_\_  
CALC. # CD-Q0000-931227  
COMPUTED ACK DATE 10-9-95  
CHECKED ep DATE 10-10-95

3.0 REFERENCES:

- 1) Generic Implementation Procedure (GIP) for seismic verification of nuclear plant equipment by SQUG.
- 2) AISC Steel Construction Manual 8th Edition.
- 3) EPRI Report NP-7151, "Cable Tray and Conduit System seismic evaluation guidelines," EPRI, March 1991.
- 4) EPRI Report NP-5228, Revision 1, "Seismic Verification of Nuclear Plant Equipment Anchorage," EPRI, June 1991.
- 5) EPRI Report NP-7150, "The Performance of Raceway Systems in Strong Motion Earthquakes," EPRI, March 1991.
- 6) EPRI Report NP-7152, "Seismic Evaluation of Rod Hanger Supports for Electrical Raceway Systems," EPRI, March 1991.
- 7) P-W Industries catalog for cable tray system.
- 8) NEMA Standard VE 1-1984, "Metallic Cable Tray Systems"
- 9) BFN MARS Report
- 10) Civil Design Standard DS-C1.7.1
- 11) Design of Welded Structures by Blodgett
- 12) UNISTRUT - Nuclear Power Engineering Catalog
- 13) DCN W22555A
- 14) Work Request No. C314988, C069712 & C165048 | R3
- 15) Design Criteria BFN-50-C-7104
- 16) Work Request # C165050 & # C030297
- 17) TVA calc. # CD-Q0000-940339 - calculation of basic parameters for A-46 and individual plant examination of external events (IPEEE) seismic program. | R3
- 18) TVA calc. # CD-Q0999-940356- Concrete Anchors for USI-A46 and IPEEE review. |

REPLACED  
THIS PAGE ADDED BY REV. 3



QUALIFICATION OF CABLE TRAY AND CONDUIT  
SYSTEMS BY A-46 PROGRAM

SHEET 11 OF             
CALC. # CD-Q0000-931227  
COMPUTED CR DATE 10-9-95  
CHECKED ay DATE 10.10.95

DESIGN INPUT DATA:

1. CABLE TRAY WEIGHT INCLUDING 4" OF CABLE AND FLAMASTIC FILL EQUALS 25 PSF.
2. CABLE TRAY: STANDARD LADDER TYPE, SYSTEM NO. 1402, RUNGS SPACED AT 6".
3. STRUCTURAL STEEL MAT'L = A36 UNLESS OTHERWISE NOTED.
4. WELDING ELECTRODE = E70XX.
5. CONCRETE  $f'_c$  = 3000 PSI.
6. GIP BOUNDING SPECTRUM VS SSE GROUND RESPONSE SPECTRUM ANCHORED TO 0.2g AT 5% DAMPING. SINCE BOUNDING SPECTRUM COMPLETELY ENVELOPES SITE SPECTRUM, THE FINDINGS OF EXPERIENCE DATABASE ARE VALID FOR THIS SITE (REFER SHEET 11.2).
7. REACTOR BUILDING SEISMIC RESPONSE SPECTRA FROM MARS REPORT (REF. 9), SUPERIMPOSED ON ROD FATIGUE BOUNDING SPECTRA ANCHORED TO 0.33g, 0.50g, & 0.75g. THIS INFORMATION WILL BE USED FOR ROD FATIGUE EVALUATION (REFER SHEET 13).
8. DIESEL GENERATOR BUILDING SEISMIC RESPONSE SPECTRA FROM MARS REPORT (REF. 9) SUPERIMPOSED ON ROD FATIGUE BOUNDING SPECTRA ANCHORED TO 0.33g, 0.50g, & 0.75g. THIS INFORMATION WILL BE USED FOR ROD FATIGUE EVALUATION (REFER SHEET 12).
9. STRENGTH GAIN OF CONCRETE DUE TO AGING (FROM 3000 PSI TO 3600 PSI) MAY BE CONSIDERED (REF. 10).
10. ANCHORAGE TYPE:

THE PROMINENT ANCHORAGE TYPE USED FOR THIS PLANT HAS BEEN SELF DRILLING EXPANSION ANCHORS (SSD'S). OTHER TYPES SUCH AS WEDGE BOLTS AND UNDERCUT ANCHORS, WHICH HAVE HIGHER STRENGTHS THAN SSD'S HAVE ALSO BEEN USED. IT IS POSSIBLE, PARTICULARLY IN EARLIER STAGES OF CONSTRUCTION (LATE 60'S AND EARLY 70'S), THAT LEAD CINCH ANCHORS MIGHT HAVE BEEN USED IN SOME PLACES. LEAD ANCHORS PER GIP ARE OUTLIERS AND THEIR ALLOWABLE PULLOUT AND SHEAR VALUES PER REF. 10 ARE LESS THAN THOSE OF SSD'S. HOWEVER GIP DOES NOT REQUIRE THE REMOVAL OF EACH AND EVERY BOLT TO VERIFY THE ANCHOR TYPE AND THEREFORE

REPLACES  
THIS PAGE ADDED BY REV. 3





QUALIFICATION OF CABLE TRAY AND CONDUIT  
SYSTEMS BY A-46 PROGRAM

SHEET 11-1 OF \_\_\_\_\_  
CALC. # CD-Q0000-931227  
COMPUTED ACR DATE 10-9-95  
CHECKED CP DATE 10-12-95

DESIGN INPUT DATA (CON'T):

IN CASES, WHERE THE TYPE OF ANCHOR IS NOT KNOWN, THE ANCHORS WILL BE ASSUMED TO BE SSD'S. NO SIGNIFICANT DEGRADATION OF THE FUNCTIONALITY OF THE SUPPORT IS LIKELY, IF, INFREQUENTLY AND UNKNOWN TO THE ENGINEER, AN INSTALLED LEAD ANCHOR IS EVALUATED USING SSD ALLOWABLES. THE JUSTIFICATION FOR THIS CONCLUSION IS DOCUMENTED IN TVA CALC. AT REF. 18.

IF THE TYPE OF ANCHOR IS KNOWN OR DETERMINED TO BE A LEAD ANCHOR, THE SUPPORT SHALL BE TREATED AS AN OUTLIER AND EVALUATED ACCORDINGLY.


11. EXPANSION ANCHOR CAPACITIES: (Ref 1, Appendix C)

$$\begin{aligned} \text{PULLOUT CAPACITY} &= \text{GIP CAP.} \times (3600/4000) \\ &= 0.9 \times \text{GIP} \end{aligned}$$

$$\begin{aligned} \text{SHEAR CAPACITY} &= \text{GIP CAP.} \times (.65+3000/10000) \\ &= 0.95 \times \text{GIP} \end{aligned}$$

ANCHOR BOLT SIZE (IN)	PULLOUT CAPACITY (LBS)	SHEAR CAPACITY (LBS)
3/8	0.9 x 1460 = 1314	0.95 x 1420 = 1349
1/2	0.9 x 2290 = 2061	0.95 x 2380 = 2261
5/8	0.9 x 3170 = 2853	0.95 x 3790 = 3600
3/4	0.9 x 4690 = 4221	0.95 x 5480 = 5206

ALLOWABLES FOR SSD'S PER REF.10 ARE MORE CONSERVATIVE AS COMPARED TO THE VALUES CALCULATED ABOVE. IT IS THEREFORE ACCEPTABLE TO ALSO USE ALLOWABLES FOR SSD'S PER REF.10.



OVERSPAN QUALIFICATION OF OUTLIER NUMBER:

21-03

21-08

21-12

21-13

21-15

21-17

21-26

22-15

→ R3

23-04

23-05

27-05

→ R3

29-02

35-01

35-02

39-01

→ R3

46-01

50-03



BGR/0


CD-9000-931227

COMPUTED P.S.G. DATE 11-18-97

CHECKED ACR DATE 11-29-98

CONDUIT OVERSPAN CALCULATION

SOME OF THE CONDUITS WERE FOUND TO HAVE SPANS MORE THAN MAXIMUM ALLOWED BY GIP. THOSE CASES HAVE BEEN NOTED AS OUTLIER. THIS CALCULATION TRIES TO QUALIFY THE OVER SPAN CONDITION BASED ON INDIVIDUAL CONDITION



BFL/6

CD-90000-931227

COMPUTED P.S. DATE 11-18-93


CHECKED ACR DATE 11-29-93

PROB. NO	CONDUIT DIA.	ALLOWABLE SPAN (FT)	ACTUAL SPAN (FT)	REMARKS
21-03	3/4"	10	13'-0"	S.S. - ACCEPTABLE
21-12	3/4"		7'	CANTILEVER - ACCEPTABLE
21-13	3/4"	5	6	CANTILEVER - ACCEPTABLE
21-15	1"	12	18 FT.	SS - FAILS (COMPARED TO 96-01)
21-17	3"	20	25	SS - ACCEPTABLE
27-05	3/4"	10	13	S.S. ACCEPTABLE / R3.
23-04	1"	12	18'	S.S. - FAILS (COMPARED TO 46-01)
23-05	1"	12	18	S.S. - FAILS ( " )
29-02	2"	16	23'-10"	SS - FAILS
35-01	1"	12	15'	SS - ACCEPTABLE
35-02	1"	12	14'-9"	S.S. - ACCEPTABLE
39-01	1 1/2"	14	17'-6"	S.S. - ACCEPTABLE
46-01	1"	12	17'	S.S. - FAILS
50-03	3/4"	10	13'-9"	S.S. - FAILS

S.S. - SIMPLY SUPPORTED.

VA 11030 (WM-7-75)

REV	Prepared By ACR Date 10-6-95
3	Checked By <u>ayo</u> Date 10-10-95





BE/10  
CD-00000-931227

COMPUTED ERH DATE 11-18-93

CHECKED ACR DATE 11-29-93

LOAD CALCULATION:

DEAD LOAD

	STEEL.	AL
3/4" $\phi$ COLD WEIGHS -	1.4 #/FT.	0.7 #/FT
1" $\phi$ COLD WEIGHS =	2.2 #/FT.	1.1 #/FT
1 1/2" $\phi$ COLD WEIGHS -	3.6 #/FT.	1.8 #/FT
2" $\phi$ COLD WEIGHS	5.1 #/FT	2.8 #/FT.
3" $\phi$ COLD WEIGHS.	12.8 #/FT	7.9 #/FT



BEN/O

CD-80000-93122

COMPUTED P.S.G DATE 11-18-92

CHECKED ACR DATE 11-29-9

3/4"  $\phi$  COND.

$$A = 0.333 \text{ in}^2$$

$$I = 0.037 \text{ in}^4$$

$$S = 0.071 \text{ in}^3$$

$$r = 0.334 \text{ in}$$

1" COND

$$A = 0.494 \text{ in}^2$$

$$I = 0.087 \text{ in}^4$$

$$S = 0.133 \text{ in}^3$$

$$r = 0.421 \text{ in}$$

1/2" COND

$$A = 0.799$$

$$I = 0.310 \text{ in}^4$$

$$S = 0.326 \text{ in}^3$$

$$r = 0.623 \text{ in}$$

2"  $\phi$  COND

$$A = 1.07 \text{ in}^2$$

$$I = 0.666 \text{ in}^4$$

$$S = 0.561 \text{ in}^3$$

$$r = 0.787 \text{ in}$$


3"  $\phi$  COND

$$A = 2.23 \text{ in}^2$$

$$I = 3.02 \text{ in}^4$$

$$S = 1.72 \text{ in}^3$$

$$r = 1.16 \text{ in}$$



BR110

CD 00000-05122

COMPUTED P.S.C. DATE 11-15-93

CHECKED ACR DATE 12-6-93

OUTLIER 35-01 &amp; 35-02

LOCATED AT G17 SLAB OF CONTROL BAY  
USE:

$$Q_H @ 621 = 0.8683 \times 2 = 1.74 \text{ (REF. 3-E-W-5.7)}$$

$$Q_V @ 621 = 0.2556 \times 2 = 0.51 \text{ (REF. 3-V-5.7)}$$

DIAMETER OF ROND = 1".

SPAN = 15'-0".

WEIGHT = 2.2 #/FT. (0.183 #/IN) FOR STEEL  $\rightarrow$  STEEL GOVERNS  
1.1 #/FT FOR ALUMINIUM

$$S = 0.133$$

$$F = 0.087$$

$$\text{MOMENT (VERT)} = 2.2 \times 1.5111 \times \frac{(15)^2}{8} = 93.43 \text{ FT. LBS}$$

$$f_b_1 = \frac{M}{S} = \frac{93.43 \times 12}{0.133} = 8430 \text{ PSI}$$

$$\Delta_1 = \frac{5}{384} \times \frac{0.183 \times 1.51 \times (180)^4}{29 \times 10^6 \times 0.087} = 1.497"$$

$$\text{MOMENT (HORIZ)} = 2.2 \times 1.74 \times \frac{(15)^2}{8} = 107.66 \text{ FT. LBS}$$


$$f_b_2 = \frac{M}{S} = \frac{107.66 \times 12}{0.133} = 9713 \text{ PSI}$$

$$\Delta_2 = \frac{5}{384} \times \frac{0.183 \times 1.74 \times (180)^4}{29 \times 10^6 \times 0.087} = 1.725 \text{ IN.}$$

$$f_b = \left[ (f_b_1)^2 + (f_b_2)^2 \right]^{1/2} = \left[ (8430)^2 + (9713)^2 \right]^{1/2} = 12861$$

$$\Delta = \left( \Delta_1^2 + \Delta_2^2 \right)^{1/2} = \left[ (1.497)^2 + (1.725)^2 \right]^{1/2} = 2.284" \left( \frac{4}{179} \right)$$

$$\Delta \text{ FOR D.L. ONLY} = \frac{1.497}{1.51} = 0.991 \left( \frac{4}{181} \right) < \frac{L}{120} \text{ O.K.}$$



QUALIFICATION OF CABLE TRAY AND CONDUIT  
SYSTEM BY A46 PROGRAM


SHEET 200 OF

CD-Q0000-931227

COMPUTED PSM DATE 1-21-99

CHECKED ACR DATE 1-27-99


PROBLEM NO 22-03






PROBLEM NO. 22-03

AREA NO. 22




AVERAGE SPAN OF CONDUIT = 12'-6"  
 2" DIA CONDUIT (# 3PC944)  
 1 1/2" DIA CONDUIT (# 3PC931)  
 SYSTEM: 064, W.P# 13119

**ELEVATION LOOKING WEST**



**PLAN**

5/17/201  
 CD-9000-931221  
 REV: P.S.G. 1-21-94  
 Checked by: AGR E.M. 1-27-94



**PLATE A**


**PLATE B**

PREPARED BY

REVIEWED BY

ALL BOLTS ARE 1/2" Ø W.T.B.

BOLT DETAIL	
BOLT NO	DESCRIPTION
1	NUT FLUSH WITH END OF BOLT
2	PROJ. OF 5/8" FROM NUT AND 1 3/8" FROM PLATE
3	BOLT HANGING LOOSE
4	5 RECT. WASHER AND 1 ROUND WASHER. TOTAL PROJ. 3 1/4" FROM PLATE SURFACE. LOOSE NUT.
5	O.K
6	PROJ. OF 1 5/8" FROM PLATE AND 5/8" FROM NUT. HAS 3 WASHERS.
7	O.K
8	PROJ OF 1 1/8" FROM PLATE AND 1/2" FROM NUT




PR-B No 22-03

DEAD WEIGHT CALCULATION.

2"  $\phi$  COND, SPAN 12'-6"  $\therefore 5.1 \times 12.5 = 64\#$

1/2"  $\phi$  COND, SPAN 12'-6" =  $3.6 \times 12.5 = 45\#$



REACTION

@ JT. ① =  $64 \times \frac{22.5}{38} + 45 \times \frac{26.5}{38}$   
 $= 50 + 32$   
 $= 82\#$

@ JT. ② =  $(64 + 45) - 82$   
 $= 27\#$

SELF WT. T.S 2x2 = WT  $5.41 \times 11' = 60\#$

P1000 — WT.  $1.9 \times 5' = 10\#$


FR. 1/2" x 3" x 8" — WT.  $13.6 \times \frac{8}{12} \times 2 = 18\#$

TOTAL 88#

SELF WT AT EACH JOINT =  $\frac{88}{2} = 44\#$

$\therefore$  LOAD AT JT. ①  $82 + 44 = 126\#$


" " JT. ②  $27 + 44 = 71\#$



PROB NO 22-03

SO FOR 3 TIMES DEAD LOAD

$$\text{LOAD AT ST. 1} = 126 \times 3 = 378 \#$$



BOLT 3 IS HANGING  
LOOSE AND IS NOT  
CONSIDERED FOR  
ANALYSIS PURPOSES

BOLT 4 IS PROJECTING  
OUT  $3/4"$  AND NUT IS  
LOOSE, SO BOLT IS NOT  
CONSIDERED FOR ANALYSIS  
PURPOSES.

$$F_y = 378$$

$$M_z = 378 \times 3 = 1134 \# \text{in}$$

$$\text{TENSION/BOLT} = \frac{378}{2} + \frac{1134}{2 \times 1.5} = 567 \#$$


CAPACITY OF  $1/2"$   $\Phi$  WEDGE BOLT, (REF. GIP P.C. 2-2)

$$\text{PULLOUT CAPACITY} = 2290 \#$$

$$\text{SHEAR CAPACITY} = 2380 \#$$

REDUCTION FACTOR FOR CONCRETE STRENGTH = 0.75

$$\therefore \text{BOLT INTERACTION} = \frac{567}{2290 \times 0.75} = 0.33$$



BENH

CO-20000-931227

COMPUTED P. H. DATE 11-5-93

CHECKED ACR DATE 1-27-94

PROB NO 22-03.

FLATE STRESS.

$$S = \frac{1}{2} \times b \times t^2 = \frac{1}{6} \times 8 \times (1/2)^2 = 0.333 \text{ IN}^3$$

$$M = 1134 \text{ #IN}$$

$$f_b = \frac{M}{S} = \frac{1134}{0.333} = 3402 \text{ PSE} < 27 \text{ KSI OK.}$$

SO SUPPORT IS ACCEPTABLE IN AS IS  
CONDITION.





BROWNS FERRY UNIT 3  
OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

SHEET #68  
APPENDIX A

PROBLEM NO. 22-03

CD-0000-931227

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

BUILDING REACTOR AREA NO. 22  
ROOM OR ROW/COLUMN R17-R18/ S-T FLOOR EL. 593  
ITEM (CIRCLE ONE) CABLE TRAY CONDUIT

2. OUTLIER ISSUE DEFINITION

- a. Identify all the screening guidelines which are not met.  
(Check more than one if several guidelines could not be satisfied.)

Cable and Conduit Raceways

Inclusion Rules \_\_\_\_\_  
Other Seismic Performance Concerns X  
Limited Analytical Review \_\_\_\_\_  
Other \_\_\_\_\_

- b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item to be verified for seismic adequacy):

Conduit support vertical member TS 2X2 attached to base plate at ceiling. Out of the four bolts on South side base plate, one bolt is hanging loose and another bolt's nut is loose. See attached sketch and photos for detail.  
Three adjacent supports have problems for anchor embedments. Support sketch shown is for the worst case.

3. METHOD OF OUTLIER RESOLUTION (OPTIONAL)

SEE CALCULATION CD-Q0000-931227 FOR RESOLUTION. NO MODIFICATION INVOLVED. NO FURTHER ACTION REQUIRED.

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on this page will satisfy the requirements for this item to be verified for seismic adequacy:

Approved by:

PARTHA S. GHOSAL  
PRINT OR TYPE NAME


P. S. Ghosal  
SIGNATURE

12-10-93  
DATE

ANAND RELWANI  
PRINT OR TYPE NAME


Anand C. Relwani  
SIGNATURE

12-10-93  
DATE




PROJECT NO. 22-03


AREA NO. 22



**ELEVATION LOOKING WEST**



SHEET A69  
SECTION A





PREPARED BY

REVIEWED BY


BOLT DETAIL	
BOLT NO	DESCRIPTION
1	NUT FLUSH WITH END OF BOLT
2	PROJ. OF 5/8" FROM NUT AND 1 3/8" FROM PLATE
3	BOLT HANGING LOOSE
4	5 RECT. WASHER AND 1 ROUND WASHER. TOTAL PROJ. 3 1/4" FROM PLATE SURFACE. LOOSE NUT.
5	O.K
6	PROJ. OF 1 5/8" FROM PLATE AND 5/8" FROM NUT. HAS 3 WASHERS.
7	O.K
8	PROJ OF 1 1/8" FROM PLATE AND 1/2" FROM NUT

CD00000-931227





(3A) LKG EAST  
SOUTH PLATE




(3A) LKG NORTH  
-SOUTH PLATE



(3B) LKG WEST - SOUTH PLATE



(3C) LKG, North  
22-03.



BROWNS FERRY UNIT 3  
OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

SHEET A149

APPENDIX A

PROBLEM NO. 35-01

0220000-931227

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

BUILDING CONTROL BAY

AREA NO. 35

ROOM OR ROW/COLUMN SPREADING ROOM

FLOOR EL. 606

ITEM (CIRCLE ONE) CABLE TRAY

CONDUIT

2. OUTLIER ISSUE DEFINITION

- a. Identify all the screening guidelines which are not met. (Check more than one if several guidelines could not be satisfied.)

Cable and Conduit Raceways

Inclusion Rules X

Other Seismic Performance Concerns \_\_\_\_\_

Limited Analytical Review \_\_\_\_\_

Other \_\_\_\_\_

- b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item to be verified for seismic adequacy):

1" Diameter conduit (R435) running vertically by face of R21 wall, has a span of 15'-0" (against allowable of 12'-0").  
Also a 2" diameter conduit by its side (MRA 792889) has a span of 15'-0" (against allowable of 14'-0").

3. METHOD OF OUTLIER RESOLUTION (OPTIONAL)

This support qualified by calculation CD-Q3999-890678. For conduit qualification see calc. CD-Q0000-931227. Over span acceptable.

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on this page will satisfy the requirements for this item to be verified for seismic adequacy:

Approved by:

ANAND C. RELWANI  
PRINT OR TYPE NAME


Anand C. Relwani  
SIGNATURE

12-10-93.  
DATE

PARTHA S. GHOSAL  
PRINT OR TYPE NAME

P. S. Ghosal  
SIGNATURE

12-10-93  
DATE





TITLE SEISMIC QUALIFICATION OF CONDUIT AND SUPPORTS				PLANT/UNIT BFN/3
PREPARING ORGANIZATION BFEP08		KEY NOUNS (Consult RIMS DESCRIPTORS LIST) CONDUIT SUPPORTS		
BRANCH/PROJECT IDENTIFIERS 3785902 BFEP080323 CD-Q3999-890678		Each time these calculations are issued, preparers must ensure that the original (RO) RIMS accession number is filled in. Rev (for RIMS' use) (A) RIMS accession number		
APPLICABLE DESIGN DOCUMENT(S) BFN-50-723 RO		R0	860804B0037	B22 '86 0729 112
		R1	861218E0036	(9) B22 '86 1126 151
		R2	870223C0020	(9) B22 '87 0219 106
SAR SECTION(S)		R3	890620F0039	(2) B04 '89 0614 227
UNID SYSTEM(S)				
Revision 0	R1	R2	R3	Safety-related? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
ECN No. (or Indicate Not Applicable) P0864	P0864	P0864	P0864	Statement of Problem
Prepared Ralph Kegan	S. Epitkian	M. Doctra	R.P. Anderson	EVALUATION OF A CONDUIT AND/OR CONDUIT SUPPORT RESULTING FROM A DISCREPANCY DISCOVERED BY FIELD INSPECTION.
Checked Jeffery L. Campbell	M. Doctra	M. Bennett	C.P. Jones	
Reviewed R.D. Cutsinger	R.D. Cutsinger	R.D. Cutsinger	A.L. Reuschel FOR JMR	
Approved S.M. Brath	S.M. Brath	S.M. Brath	M.H. Perry FOR JMR	
Date 7-28-86	11-26-82	2-11-87	4/12/89	
Use form TVA 01534 if more space required.	List all pages added by this revision.			6, 6, 6 E 2a
	List all pages deleted by this revision.			NA
	List all pages changed by this revision.	2, 3	3	6, 1, 2, 3

ORIGINAL

**Abstract**

These calculations contain an unverified assumption(s) that must be verified later. Yes  No  BRS 5-11-89  
PT115 + 1117 design capacity | R3

THE FOLLOWING CALCULATIONS DESIGN/DETAIL CONDUIT SUPPORT 48B810-167 A DRAWING WITH THE SAME DESIGNATION WILL BE ISSUED CONCURRENTLY WITH THIS CALCULATION. THIS ISSUE CORRECTS DISCREPANCY NO. 27-002 DISCOVERED DURING A FIELD INSPECTION.

REMOVED UNVERIFIED ASSUMPTION, SEE SHEET 2a | R3

<input type="checkbox"/> Microfilm and store calculations in RIMS Service Center.	<b>CALCULATION LIBRARY</b>	Microfilm and destroy. <input type="checkbox"/>
<input checked="" type="checkbox"/> Microfilm and return calculations to: R.D. CUTSINGER	EDB F3 BFN	BFN/ENGR TRAILER
		Address: COMPLEX, TRLR-#4




TVA

Title: CONDUIT SUPPORT 48B810-167

REVISION LO  
CD-Q3999-89067  
-BFPC8-333

CP  
5-12-89

Revision No.	DESCRIPTION OF REVISION	Date Approved
1	Incorporated FCR 86-631R0	11-26-86
2	Incorporated FCR 87-113R0	2-19-88
3	REMOVED UNVERIFIED ASSUMPTION, SEE SHEET 2a	6-12-88



CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM

CDQ 3999890678  
Calculation No.

R3  
Revision

Method of design verification (independent review) used (check method used):

- 1. Design Review
- 2. Alternate Calculation
- 3. Qualification Test

Justification (explain below):

Method 1: In the design review method, justify the technical adequacy of the calculation and explain how the adequacy was verified (calculation is similar to another, based on accepted handbook methods, appropriate sensitivity studies included for confidence, etc.).

Method 2: In the alternate calculation method, identify the pages where the alternate calculation has been included in the calculation package and explain why this method is adequate.

Method 3: In the qualification test method, identify the QA documented source(s) where testing adequately demonstrates the adequacy of this calculation and explain.

The subject calculation at the revision level noted above has been found to be technically adequate in that computations, judgements, assumptions, and logic are in accordance with generally accepted methods.

This review is limited to information which is germane to the removal of the unverified assumption regarding the capacity of P100 series conduit clamps.

Charles Paul Smith  
Design Verifier  
(Independent Reviewer)

5-12-89  
Date



CONDUIT SUPPORT

RESOLUTION OF UVA (CDQ3999890678) Proj: BFN / UNIT 3

COMPUTED BRS DATE 5-11-89

CHECKED CPJ DATE 5-12-89

TABLE OF CONTENTS

<u>TITLE</u>	<u>PAGE</u>
COVER SHEET	i
REVISION LOG	ii
INDEPENDENT REVIEW SHEET	iii
TABLE OF CONTENTS	iii
PURPOSE	1a
ASSUMPTIONS	1a
REFERENCES	1a
CONCLUSION	1a
BODY OF CALCULATION	2 THRU 7
RESOLUTION OF UVA	2a





CONDUIT SUPPORT DWG. 488810-167

12 7  
BFN/UNIT 3

CALC. ID BFEP8 0523  
DISCREPANCY NO.: 27-002

COMPUTED REK DATE 6-12-8  
CHECKED JLC DATE 6-19-8

Purpose: Design Support for (1) 2"  $\phi$  AL  
(1) 1 1/2"  $\phi$  AL  
(1) 1"  $\phi$  AL Conduit Lines

Assumptions;  
SSE Conditions

~~Conduit Clamp is Adequate~~ PRS 5-11-89

~~Per Dynamic Load Test Done at Wyle Lab. P112, P115 & P117 CLAMPS~~

E70 XX Electrodes

SEE SHEET 2a

R3

CP 5-12-89

References:

BFN-50-723

AISC Manual 8th Edition

Unistrut Cat. 10R

Blodgett 'Design of Welded Structures'

DS-C1.6.9 (TABLE 1C)

CEB 840124 007

R3

CP 5-12-89

Conclusion:

Calculations Show This Support To Be Adequate  
And Meets All Criteria

2219A




CONDUIT SUPPORT FOR

- (1) 2" φ ALUM. CONDUIT, 16 ft SPAN, 2-WAY
- (1) 1 1/2" φ " " " " , 10 ft SPAN, 3-WAY
- (1) 1" φ " " " " , 19 ft SPAN, 3-WAY

(19 ft IS MAX SPAN 1" φ)

SUPPORT GEOMETRY:



SEE LOADS = (REF RFN-50-723)

2" φ	$F_x = 93 \#$	1 1/2" φ	$F_x = 16 \#$	1" φ	$F_x = 35 \#$
	$F_y = 65 \#$		$F_y = 25 \#$		$F_y = 31 \#$
	$F_z = 22 \#$		$F_z = 9 \#$		$F_z = 10 \#$
	(TABLE A2-2B-1)		(TABLE A2-1B-4)		(TABLE A2-1B-3)

STIFFNESS: -- SUPPORT STIFFNESS IS RIGHT -- BY ENGINEERING JUDGEMENT AND MEETS STIFFNESS REQUIREMENTS


JUDGEMENT AND MEETS STIFFNESS REQUIREMENTS

AS PER AISC 86-631-RO

NEW L2x2x1/4 (TYP)

LOADS @ PL. 'A'

THERE WILL BE NO  $M_z$  OR  $M_y$  FROM THE 2" φ OR 1 1/2" φ.  $M_z$  &  $M_y$  FROM 1" φ WILL BE VERY SMALL BY ENGINEERING JUDGEMENT.




$F_x = 93 + 35 = 128 \#$  (F (1" φ) TRANSFER THROUGH PL. B)

$F_y = 65 + 31 = 96 \#$

$F_z = 22 + 10 = 32 \#$

$M_x = a(F_y \frac{2.14}{12} + \frac{b}{c} F_z \frac{11}{12})$   
 $= .81(65 \# \div 12.5 + 31 \#) = 65 \# \text{ IN}$

$M_x = .81(65 + \frac{6}{9.625} \times 31) = 68 \text{ IN } \#$





CDQ 3999890678 (BFPC80323)

COMPUTED BRS DATE 5/11/89CHECKED CPJ DATE 5-12-891"  $\phi$  AL P1113 CLAMPTABLE A2-1B-3CEB840124007

$F_x = 35 = \text{LAT}$

$F_1 = 225$

$F_y = 31 = \text{VERT}$

$F_2 = 958$

$$\frac{35}{225} + \frac{31}{958} + \frac{10}{208} = .24 < 1.0$$

$F_z = 10 = \text{AXIAL}$

$F_3 = 108$

 $\therefore$  P1113 CLAMPS ARE ADEQUATE1 1/2"  $\phi$  AL P1115 CLAMPTABLE A2-1B-4DS-C1.6.9 (TABLE 1C)

$F_x = 16 = \text{LAT}$

$F_1 = 285$

$F_y = 25 = \text{VERT}$

$F_2 = 1240$

$$\frac{16}{285} + \frac{25}{1240} + \frac{9}{83} = .18 < 1.0$$

$F_z = 9 = \text{AXIAL}$

$F_3 = 83$

 $\therefore$  P1115 CLAMPS ARE ADEQUATE2"  $\phi$  AL P1117 CLAMPTABLE A2-2B-1DS-C1.6.9 (TABLE 1C)

$F_x = 93 = \text{LAT}$

$F_1 = 380$

$F_y = 65 = \text{VERT}$


$F_2 = 1660$

$$\frac{93}{380} + \frac{65}{1660} + \frac{22}{200} = .39 < 1.0$$

$F_z = 22 = \text{AXIAL}$

$F_3 = 200$

 $\therefore$  P1117 CLAMPS ARE ADEQUATE



P1000  
W120 2/12/87 488 4/14/87  
"EXISTING"

CONSIDERING THE SMALL LOADS AND SHORT LENGTH OF P1000, THE P1000 IS ADEQUATE BY ENGINEERING JUDGEMENT

UNISTANT DESCRIBED IN PS 6 & 7 WILL BE REPLACED WITH USE P1000.

NEW MATERIAL PER FC87-0130, BECAUSE EXISTING IS DAMAGED. DEWS 488610-570 WILL DETAIL REPAIRS.

L2X2X1/4

CONSIDERING THE SMALL LOADS, THE L2X2X1/4 IS ADEQUATE BY ENGINEERING JUDGEMENT. USE L2X2X1/4.

2" φ P1117 CLAMP

1 1/2" φ P1115 CLAMP

1" φ P1113 CLAMP

~~ASSUMED ADEQUATE~~ <sup>BR 5-11-89</sup> ~~SUBJECT TO VERIFICATION~~  
~~BY WELDE LABS TESTING, SEE SHEET 23~~

USE P1113, P1115 & P1117 CLAMPS

R?  
CP/ 5-12-

NOTE: FC87-86-631-R0

LOAD AT PT. A  
$$f_w = \left[ \left( \frac{32}{3.75} + \frac{68}{.177} \right)^2 + \left( \frac{96}{.75} \right)^2 + \left( \frac{128}{3} \right)^2 \right]^{1/2} = 415 \#/IN$$

M Doctor 11/25/86  
S. E. Jankan  
11/25/86

$$\frac{415}{.6 \times 33000} = 0.032 < 1/8" \therefore \text{WELD IS O.K.}$$


FC87-86-631-R0 IS ACCEPTABLE

WELDS

① WELD P1000 TO L2X2X1/4

WELD PATTERN:

USE LOADS AT PT. 'A' (SEE CH. 2)  
$$f_w = \left[ \left( \frac{32}{3.75} + \frac{65}{.177} \right)^2 + \left( \frac{96}{.75} \right)^2 + \left( \frac{128}{3} \right)^2 \right]^{1/2} = 399 \#/IN$$



$$\frac{399}{(.4)(33000 \text{ psi})} = .03" < 1/8", \text{ USE } 1/8" \text{ FILLET WELD.}$$

② WELD L2X2X1/4 TO EXIST W33 FLANGE: ADEQUATE BY COMPARISON TO THE WELD CALC ABOVE. USE 1/4" FILLET WELD (MIN DISC)

THIS SUPPORT IS ADEQUATE & MEETS ALL CRITERIA.





# DISCREPANCY RESOLUTION

SHEET SHT 01 OF 951  
 BFN UNIT --- SYS ---  
 BFEP8 ---  
 DESIGN --- DATE ---  
 CKD --- DATE ---

DISCREPANCY NO. 27-002

LOCATION Vol 27 - U3 Cable spreading Rm E1 606

SEISMIC INTEGRITY EVALUATION CATEGORY 4

## DESCRIPTION OF DISCREPANCY:

2"Ø Conduit ES 3875-I has an overspan condition, and a support that is not adequate to carry conduit loads.

SHEET 4 OF 7  
 BFN UNIT 3 SYS 27  
 BFEP8 0323  
 DESIGN Ret DATE 6-12-86  
 CKD JLB DATE 6-19-86

**INFORMATION ONLY**

## RECOMMENDED ACTION:

Add support and modify existing support as detailed on attached shts.

Rev. 1

SEE SHT. #4 FOR MODIFICATION.

H. Thompson 6-7-86  
H.B. Palled 6-09-86


DESIGNER

H.L. Peterson

CHECKER

Bill Radloff

OE COORDINATOR



CONDUIT SUPPORT

SHEET 5 OF 7 SHEET 4 OF 4

BFN UNIT 3 SYS 27

BFEP8 0323

DESIGNER *RK* DATE *6-12-86*

COMPUTED BK DATE 1-29-86

CKD *JL* DATE *6-19-86*

CHECKED HLP DATE 2-7-86

ES 3875-I  
(ALUMINUM)

1/2" φ S.S.D.  
ANCHORS.

3/4" ± φ 2" ES 3875-I

PI 1000


3-SICES

1/2" x 9" x 0'-9"

SECTION A-A @ EL. 611'-4"


NO LONGER REQ'D  
SEE SHT 4/4 FOR  
MODIFICATION TO EXIST.  
SUPPORT.



*MJ*  
5-9-86  
H.B. Patel  
6-09-86




LOCATION PLAN

INFORMATION ONLY






SECTION A-A  
(LKG. SOUTH)




PLAN

**INFORMATION ONLY**



SECTION AT SUPPORT  
(LKG. SOUTH)



SHEET 7 OF 7

SHEET A OF 4

DISC 27-002

BFN UNIT 3 SYS 27


BEPC80323

DESIGN *REK* DATE 6-11-86


COMPUTED *MJS* DATE 6-9-86

CKD *LLC* DATE 6-19-86

CHECKED *H.B. PATE* DATE 6-09-86



ELEV LK6 SOUTH



SECTION A-A

DESIGN SPANS \_\_\_\_\_

2"  $\phi$  AL 16' 3 DIRECTIONS

1"  $\phi$  AL MAY. 3 DIRECTIONS


1 1/2"  $\phi$  AL 10' span 3 DIRECTIONS

**INFORMATION ONLY**





**ATTACHMENT 10**



55EL LINE No. 1018

Revision 2, Corrected, 6/28/91  
Status  Y  N  U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 7

Equip. ID No. 2-FI-74-50 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description RHR/LOOP I FLOW INDICATOR

Location: Bldg. CB Floor El. 617 Room, Row/Col \_\_\_\_\_

Manufacturer, Model, Etc. (optional) \_\_\_\_\_

SEISMIC CAPACITY VS DEMAND

- |    |   |     |   |       |
|----|---|-----|---|-------|
| 1. | Elevation where equipment receives seismic input      |     |   |       |
| 2. | Elevation of seismic input below about 40' from grade | Y   | N | U     |
| 3. | Equipment has fundamental frequency above about 8 Hz  | Y   | N | U N/A |
| 4. | Capacity based on: Existing Documentation             | DOC |   |       |
|    | Bounding Spectrum                                     | BS  |   |       |
| 5. | Demand based on: Ground Response Spectrum             | GRS |   |       |
|    | 1:5 x Bounding Spectrum                               | ABS |   |       |
|    | Conserv. Des. In-Str. Resp. Spec.                     | CRS |   |       |
|    | Realistic M-Ctr. In-Str. Resp. Spec.                  | RRS |   |       |

Does capacity exceed demand?

Y N U

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)


- |     |   |   |   |   |     |
|-----|---|---|---|---|-----|
| 1.  | Equipment is included in earthquake experience equipment class  | Y | N | U | N/A |
| 2.  | No computers or programmable controllers  | Y | N | U | N/A |
| 3.  | No strip chart recorders  | Y | N | U | N/A |
| 4.  | Steel frame and sheet metal structurally adequate   | Y | N | U | N/A |
| 5.  | Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays | Y | N | U | N/A |
| 6.  | Drawers and equipment on slides restrained from falling out   | Y | N | U | N/A |
| 7.  | All doors secured by latch or fastener  | Y | N | U | N/A |
| 8.  | Attached lines have adequate flexibility  | Y | N | U | N/A |
| 9.  | Anchorage adequate (See checklist below for details)  | Y | N | U | N/A |
| 10. | Relays mounted on equipment evaluated   | Y | N | U | N/A |
| 11. | Have you looked for and found no other adverse concerns?  | Y | N | U | N/A |

Is the intent of all the caveats met for Bounding Spectrum?

Y N U N/A

ANCHORAGE

- |    |   |   |   |   |     |
|----|---|---|---|---|-----|
| 1. | Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation) | Y | N | U | N/A |
| 2. | Type of anchorage covered by GIP  | Y | N | U | N/A |
| 3. | Sizes and locations of anchors determined   | Y | N | U | N/A |



SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2, Corrected, 6/28/91  
Sheet 2 of 7

Equip. ID No. 2-FI-74-50 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description RHR/LOOP I FLOW DIAGRAM

ANCHORAGE (Cont'd)

- 4. Adequacy of anchorage installation evaluated (weld quality and length, nuts and washers, expansion anchor tightness, etc.) Y N U N/A
  - 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking Y N U N/A
  - 6. For bolted anchorages, gap under base less than 1/4-inch Y N U N/A
  - 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors Y N U N/A
  - 8. Base has adequate stiffness and effect of prying action on anchors considered Y N U N/A
  - 9. Strength of equipment base and load path to CG adequate Y N U N/A
  - 10. Embedded steel, grout pad or large concrete pad adequacy evaluated Y N U N/A
- Are anchorage requirements met? Y N U

INTERACTION EFFECTS


- 1. Soft targets free from impact by nearby equipment or structures Y N U N/A
  - 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures Y N U N/A
  - 3. Attached lines have adequate flexibility Y N U N/A
  - 4. Overhead equipment or distribution systems are not likely to collapse Y N U N/A
  - 5. Have you looked for and found no other adverse concerns? Y N U N/A
- Is equipment free of interaction effects? Y N U

IS EQUIPMENT SEISMICALLY ADEQUATE?


Y N U

COMMENTS

- 1. SEE THE FOLLOWING PAGES FOR THE SCHEMATIC DIAGRAMS FOR SSEZ LINE NOS 1018, 1019, 1046, 1047, 31018, 31019, 31043 AND 31044
- 2. SEE SSEZ #s 9040 & 9041 FOR THE EVALUATION OF THIS COMPONENT. QUALIFIED BY "RULE OF THE BOX"

Evaluated by:  J.R. LITTLE

Date: 10/17/95  
10-17-95





JOB NO. 50147

JOB BENP A4G / IREF

BY JJ

SHEET NO. 3/7

DATE 8-25-51

CALC. NO. \_\_\_\_\_

SUBJECT RHR FLOW INSTRUMENTATION

CHK'D JJD

DATE 8/25/59

REF. DWGS: 47E2610-74-1, 2


THE FOLLOWING ARE THE INSTRUMENTS WHICH CONSTITUTE THE RHR FLOW INSTRUMENTATION LOOPS; (TYP UNITS 2 & 3)

	NOTE ① MOUNTED ON PIPE	NOTE ② MOUNTED ON RACK	NOTE ③ MOUNTED ON CONTROL RM PANEL		
SOUTH EAST CORNER ROOM	FE-74-50	FI-74-50	FM-74-50	} PANEL 9-3, 9-18	
		FS-74-50	FI-74-50		
	FE-74-56	FI-74-56	FR-74-64	BKR-211,402	} PANEL 9-9
			PX-74-56	FM-74-56	} PANEL 9-3, 9-18
FI-74-56			PXMC-23-14		
SOUTH EAST CORNER ROOM	FE-74-70	FI-74-70	PX-74-70	} PANEL 9-3, 9-19	
			FM-74-70		
	FE-74-64	FI-74-64	BKR-322,402	PXMC-23-115	} PANEL 9-9
			FS-74-64	FM-74-64	} PANEL 9-3, 9-19
		FI-74-64			
		FR-74-64			

NOTE ① : THESE ARE PASSIVE IN-LINE COMPONENTS OF REINFORCED CONSTRUCTION ∴ SEISMICALLY ADEQUATE.

NOTE ② : SEISMICALLY QUALIFIED BY SEWS EVALUATION FOR SSEZ #s 9189 & 9190 (UNIT 2) AND 39200 & 39201 (UNIT 3) - (SEE PAGES 5-8). QUALIFIED BY "RULE OF THE BOX"

NOTE ③ : SEISMICALLY QUALIFIED BY "RULE OF THE BOX" BY THE EVALUATION FOR THE RESPECTIVE CONTROL ROOM PANEL OR THE INDIVIDUAL COMPONENT SEWS FORM (SEE PAGES 4-7)





FE-74-50

LPNL-  
2-25-59  
SEWS (9189)

FE-74-56

FT-74-50

FT-74-56

PNL-  
2-9-9 CAB 2  
SEWS (9045)

BKR 211

PNL-  
2-9-18  
SEWS (9048)

PX-74-56  
SEWS(9191)

FM-74-50

PXMC-23-114  
SEWS(9175)

FM-74-56

PNL-  
2-9-9  
SEWS(9045)

BKR 402

PNL-  
2-9-3  
SEWS (9040, 9041)

FI-74-50

FR-74-64

FI-74-56

SEWS 1018

SEWS 1019


2-FI-74-50 AND 2-FI-74-56




FE-74-64

LPNL-  
2-25-62  
SEWS (9190)


FE-74-70




PNL-  
2-9-9 CAB.3  
SEWS (9040, 9041)




PNL-  
2-9-19  
SEWS (9048) 9049



PNL-  
2-9-9  
SEWS (9045)



PNL-  
2-9-3  
SEWS (9040, 9041)



2-FI-74-64 AND 2-FI-74-70




1018

str. 6 of 7


FE-74-50

LPNL-  
3-25-59  
SEWS (39200)


FE-74-56




PNL  
3-9-9 CAB 2  
SEWS (39045, 39119)



PNL  
3-9-18  
SEWS (39123)




PNL  
3-9-9  
SEWS (39119)



PNL  
3-9-3  
SEWS (39115)



3-FI-74-50 AND 3-FI-74-56



1018

SH. 7 of 7


FE-74-64

PANEL  
3-25-62  
SEWS (39201)


FE-74-70




PANEL  
3-9-9 CAB 3  
SEWS (39045, 39119)




PANEL  
3-9-19  
SEWS (39124)



PANEL  
3-9-9  
SEWS (39119)



PANEL  
3-9-3  
SEWS (39115)



3-FI-74-64 AND 3-FI-74-70





SEL Line No. 1018

Status  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-FI-74-50 Equip. Class 20

Equipment Description \_\_\_\_\_

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U N/A

2. Are essential relays required to function during earthquake screened out? Y N U N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays, for later analysis.

3. Other relay concerns? Y N U N/A

Requirements for relays satisfied? Y N U

SYSTEM INTERACTION EFFECTS

4. No potential sources could flood or spill onto cabinet? Y N U N/A

SCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

*SEE THE SEWS FOR SSEZ # 9040/9041  
FOR THE EVALUATION OF THIS COMPONENT*

EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES  NO

EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: [Signature] J.R. Dissen

Date: 10/20/95

Evaluated by: John O. Pizon

Date: 10/20/95



SSEL # 7189

SCREENING EVALUATION WORK SHEET (SEWS)

Equip. ID No. 2-LPWL-925-0059 Equip. Class 18 - Instruments on Racks

Equipment Description LOCAL PANEL 25-59

Location: Bldg. RB Floor El. 519 Room, Row/Col T, R3

Manufacturer, Model, Etc. (optional) \_\_\_\_\_

SEISMIC CAPACITY VS DEMAND

- Elevation where equipment receives seismic input
- Elevation of seismic input below about 40' from grade
- Equipment has fundamental frequency above about 8 Hz
- Capacity based on: Existing Documentation  
Bounding Spectrum  
GERS
- Demand based on: Ground Response Spectrum  
1.5 x Bounding Spectrum  
Conserv. Des. In-Str. Resp. Spec.  
Realistic M-Ctr. In-Str. Resp. Spec.

519  
 Y N U  
 Y N U N/A Note 1  
 DOC  
 BS  
 GERS  
 GRS  
 ABS  
 CRS  
 RRS

Does capacity exceed demand?

Y N U

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- Equipment is included in earthquake experience equipment class
- No computers or programmable controllers
- Steel frame and sheet metal structurally adequate
- Adjacent racks which are close enough to impact or sections of multi-bay racks are bolted together if they contain essential relays
- Natural frequency relative to 8 Hz limit considered
- Attached lines have adequate flexibility
- Anchorage adequate (See checklist below for details)
- Relays mounted on equipment evaluated
- Have you looked for and found no other adverse concerns?

Y N U N/A  
 Y N U N/A  
 Y N U N/A Note 2, 4  
 Y N U N/A  
 Y N U N/A Note 1  
 Y N U N/A  
 Y N U N/A Note 4  
 Y N U N/A  
 Y N U N/A

Is the intent of all the caveats met for Bounding Spectrum?

Y N U N/A

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- Equipment is included in the generic seismic testing equipment class
- Meets all Bounding Spectrum caveats
- Component is a pressure, temperature, level or flow transmitter

Y N U N/A  
 Y N U N/A  
 Y N U N/A



SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2, Corrected, 6/28/91  
Sheet 2 of 24

Equip. ID No 2-LPNL-925-0059 Equip. Class 18 - Instruments on Racks

Equipment Description LOCAL PANEL 25-59

CAVEATS - GERS (Cont'd)


- |  |   |   |   |            |
|--|---|---|---|------------|
| 4. Component is one of the specific makes and models tested, as listed in Appendix B   | Y | N | U | <u>N/A</u> |
| 5. Necessary function of component not sensitive to seismically induced system perturbations (e.g., sloshing)                    | Y | N | U | <u>N/A</u> |
| 6. No vacuum tubes   | Y | N | U | <u>N/A</u> |
| 7. All external mounting bolts in place  | Y | N | U | <u>N/A</u> |
| 8. Demand based on amplified portion of 3% damped floor response spectrum if estimated natural frequency of rack less than 33 Hz | Y | N | U | <u>N/A</u> |
| 9. Rack capable of structurally transferring GERS level seismic loads to anchorage   | Y | N | U | <u>N/A</u> |
| Is the intent of all the caveats met for GERS?   | Y | N | U | <u>N/A</u> |

ANCHORAGE

- |  |          |   |   |            |
|--|----------|---|---|------------|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)   | <u>Y</u> | N | U | N/A        |
| 2. Type of anchorage covered by GIP  | <u>Y</u> | N | U | N/A        |
| 3. Sizes and locations of anchors determined   | <u>Y</u> | N | U | N/A        |
| 4. Adequacy of anchorage installation evaluated (weld quality and length, nuts and washers, expansion anchor tightness, etc.)  | <u>Y</u> | N | U | N/A        |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | <u>Y</u> | N | U | N/A        |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | <u>Y</u> | N | U | N/A        |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | Y        | N | U | <u>N/A</u> |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | <u>Y</u> | N | U | N/A        |
| 9. Strength of equipment base and load path to CG adequate   | <u>Y</u> | N | U | N/A        |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | Y        | N | U | <u>N/A</u> |
| Are anchorage requirements met?  | <u>Y</u> | N | U | <u>N/A</u> |

INTERACTION EFFECTS

- |   |          |   |   |            |
|---|----------|---|---|------------|
| 1. Soft targets free from impact by nearby equipment or structures  | <u>Y</u> | N | U | N/A        |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | Y        | N | U | <u>N/A</u> |
| 3. Attached lines have adequate flexibility   | <u>Y</u> | N | U | N/A        |



SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2, Corrected, 6/28/91  
Sheet 3 of 24

Equip. ID No. 2-LPNL-925-0059 Equip. Class 18 - Instruments on Racks

Equipment Description LOCKER PANEL 25-59

INTERACTION EFFECTS (Cont'd)

- 4. Overhead equipment or distribution systems are not likely to collapse
- 5. Have you looked for and found no other adverse concerns?  
Is equipment free of interaction effects?

<input checked="" type="radio"/>	Y	N	U	N/A
<input checked="" type="radio"/>	Y	N	U	N/A
				<input checked="" type="radio"/> Y N U
				<input checked="" type="radio"/> Y N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

COMMENTS

- 1) As the panel is well braced, it is judged to respond > 8 Hz.
- 2) Panel is well constructed of steel channels. Framing judged to be seismically adequate.
- 3) Using the Reduced Inspection Alternative of Appendix C of the GIP, neglecting 1/3 of the anchor bolts, the rack anchorage is still judged to be seismically adequate. Therefore anchor bolt tightness testing is not required.

Evaluated by: *D. J. Acquato*  
*[Signature]*

Date: 9-13-95  
9-19-95

PHOTO 24 13:14







JOB NO. 50147 JOB BENP A46/1PEEE  
CALC. NO. \_\_\_\_\_ SUBJECT RHR FLOW INSTRUMENTATION


SHEET NO. 4 of 4  
BY JLB DATE 8-25-91  
CHKD [Signature] DATE 8/25/91

WALKDOWN INFO

RACK # 25-59

UNIT 2, SW CORNER ROOM  
(SE CORNER ROOM RACK 25-59 SIMILAR) 02 (9190)


UNIT 3, SW { SE CORNER ROOM RACKS ARE SIMILAR EXCEPT BACK BRACING IS DIFFERENT, BUT STRONGER STRUCTURALLY.



NOTE ④: RACKS & ANCHORAGE ARE ADEQUATE DUE TO:

- a) LOW SEISMIC DEMAND AT ELEV. 51.9.
- b) RACKS ARE LIGHTLY LOADED
- c) RACKS ARE BACK BRACED
- d) INCOMING TUBING & CONDUIT PROVIDES SOME TOP BRACING
- e) RACKS ARE WELL DETAILED & WELL BUILT.

ELEVATION



SEC. A-A



SSEL Line No. 9189

Status  Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-LPNL-925-0059 Equip. Class 18 - Instruments on Racks

Equipment Description LOCAL PANEL 25-59

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U  N/A

2. Are essential relays required to function during earthquake screened out? Y N U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y N U  N/A

Requirements for relays satisfied?  Y  N  U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES  NO

EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: [Signature]

Date: 9-19-95

Evaluated by: M.D. Augusto

Date: 9-19-95



SSEL Line No. 9045

Status Y  N  U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 2

Equip. ID No. 2-PNLA-009-0009 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PANEL 9-9

Location: Bldg. CB Floor El. 617 Room, Row/Col U2 MCR

Manufacturer, Model, Etc. (optional but recommended) GE

SEISMIC CAPACITY VS DEMAND

1. Elevation where equipment receives seismic input
2. Elevation of seismic input below about 40' from grade
3. Equipment has fundamental frequency above about 8 Hz
4. Capacity based on: Existing Documentation  
Bounding Spectrum  
1.5 x Bounding Spectrum  
GERS
5. Demand based on: Ground Response Spectrum  
1.5 x Ground Response Spectrum  
Conserv. Des. In-Str. Resp. Spec.  
Realistic M-Ctr. In-Str. Resp. Spec.

617  
 Y  N  U (grade @ 550')  
 N U N/A (1)  
 DOC  
 BS  
 ABS  
 GERS  
 GRS  
 AGS  
 CRS  
 RRS

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)

N U (=)\*

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)


1. Equipment is included in earthquake experience equipment class
  2. No computers or programmable controllers
  3. No strip chart recorders
  4. Steel frame and sheet metal structurally adequate
  5. Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays
  6. Drawers and equipment on slides restrained from falling out
  7. All doors secured by latch or fastener
  8. Attached lines have adequate flexibility
  9. Anchorage adequate (See checklist below for details)
  10. Relays mounted on equipment evaluated  $AF=4.5$
  11. Have you looked for and found no other adverse concerns?
- Is the intent of all the caveats met for Bounding Spectrum?

N U N/A  
 N U N/A  
 N U N/A  
 N U N/A  
 N U N/A  
 N U N/A  
 N U N/A (6)  
 N U N/A  
 N U N/A (5)  
 N U N/A (3)  
 N U N/A  
 N U N/A

ANCHORAGE

1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)
2. Type of anchorage covered by GIP
3. Sizes and locations of anchors determined

N U N/A  
 N U N/A  
 N U N/A



Equip. ID No. 2-PNLA-009-0009 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PANEL 9-9

ANCHORAGE (Cont'd)

- 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness (Y) N U N/A
- 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking (Y) N U N/A
- 6. For bolted anchorages, gap under base less than 1/4-inch Y N U (N/A)
- 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors (Y) N U N/A
- 8. Base has adequate stiffness and effect of prying action on anchors considered (Y) N U N/A
- 9. Strength of equipment base and load path to CG adequate (Y) N U N/A
- 10. Embedded steel, grout pad or large concrete pad adequacy evaluated (Y) N U N/A

Are anchorage requirements met?

(Y) N U (5)

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures (Y) N U N/A (4)
  - 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures Y (N) U N/A (7), (9)
  - 3. Attached lines have adequate flexibility (Y) N U N/A (10)
  - 4. Overhead equipment or distribution systems are not likely to collapse (Y) N U N/A
  - 5. Have you looked for and found no other adverse concerns? (Y) N U N/A (8)
- Is equipment free of interaction effects? Y (N) U (7)

IS EQUIPMENT SEISMICALLY ADEQUATE?

Y (N) U (7)

COMMENTS

outlier OSVS-9045

- For notes 1 thru 7 see SEWS for 3-PNLA-009-0009 (SSEL 39119).
- 8) Blockwall @ front of the panel qualified per IERS 80-11 program (Ref. DMG-2-4/N-1202-1, Vol 11)
- 9) Breathing apparatus boxes are stacked up @ about 5' away from this panel. It is judged that these boxes are far enough not to cause any interaction with this panel in a DBE. ok
- 10) Flex conduit @ top ok

Evaluated by: Fanyi Bei  
John O. Dineen

Date: 11/16/95  
11/17/95





IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-PNLA-009-0009 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PANEL 9-9

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? (Y) N U N/A

2. Are essential relays required to function during earthquake screened out? Y N U (N/A)

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? (Y) N U N/A

Requirements for relays satisfied? (Y) N U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet? (Y) N U N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

*The frame of*  
1) The entry door to the area where this panel is located is attached to south side of cabinet of this panel. The door itself does not have any latches to secure the door. The banging of the door to the frame in a DBE may potentially cause relay chatter.

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?

YES ✓ NO     


IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES      NO ✓ (See note 1) above

Evaluated by: Fazli Beji

Date: 11-16-95

Evaluated by: John O. Dixon

Date: 11/17/95



SSEL Line No. 9045

OSVS-9045

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number 2-PNLA-009-0009 Equipment Class 20-Instr. & Control Panels

Equipment Location: Bldg. CB Floor Elevation 617'

Room or Row/Column MCR U2 Base Elevation 617'

Equipment Description PNL 9-9

2. OUTLIER ISSUE DEFINITION

a. Identify all the screening guidelines which are not met.  
(Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>		<u>Tanks and Heat Exchangers</u>	
Capacity vs. Demand	<input type="checkbox"/>	Shell Buckling*	<input type="checkbox"/>
Caveats	<input type="checkbox"/>	Anchor Bolts and Embedment	<input type="checkbox"/>
Anchorage	<input type="checkbox"/>	Anchorage Connections	<input type="checkbox"/>
Seismic Interaction	<input checked="" type="checkbox"/>	Flexibility of Attached Piping*	<input type="checkbox"/>
Other	<input type="checkbox"/>	Other	<input type="checkbox"/>
		<u>Cable and Conduit Raceways</u>	
<u>Essential Relays</u>		Inclusion Rules	<input type="checkbox"/>
Capacity vs. Demand	<input type="checkbox"/>	Other Seismic Performance Concerns	<input type="checkbox"/>
Mounting, Type, Location	<input type="checkbox"/>	Limited Analytical Review	<input type="checkbox"/>
Other	<input checked="" type="checkbox"/>	Other	<input type="checkbox"/>

\* Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

The area entry door @ south end of this panel is attached to cabinet 1 of this panel. The door latch is broken. In a DBE the impact of the door to its frame may cause relay chatter inside this panel.



SSEL Line No. 9045

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number 2-PNLA-009-0009

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

Provide latch or positively restrain this door  
from impacting its frame;

OR alternatively if it could be shown that this panel  
does not contain any essential relays then the outlier could be resolved

*There are no essential relays in panel 2-9-9. See attached informal memo. KAG 9-16-96  
mmdr. 9-16-96*

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

N/A  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

FARZIN R. BEIGI  
Print or Type Name

Farzin R. Beigi  
Signature

11-16-95  
Date

JOHN O. DIZON, P.E.  
Print or Type Name

John O. Dizon  
Signature

11/17/95  
Date

\_\_\_\_\_  
Print or Type Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date



INFORMAL

September 16, 1996

REVIEW FOR ESSENTIAL RELAYS IN PANELS 2-PNLA-009-0003A, 2-PNLA-009-0003B, 2-PNLA-009-0004, 2-PNLA-009-0009, 2-PNLA-009-0020, AND 2-PNLA-009-0021.

Modifications to panels 2-PNLA-009-0003A (SSEL No. 9040), 2-PNLA-009-0003B (SSEL No. 9041), 2-PNLA-009-0004 (SSEL No. 9042), 2-PNLA-009-0009 (SSEL No. 9045), 2-PNLA-009-0020, and 2-PNLA-009-0021 (SSEL No. 9050) were determined to possibly be required under the USI A-46 program, resulting from outliers OSVS-9040-2, OSVS-9045, and OSVS-9050, if these panels contain essential relays. A review of the Browns Ferry Nuclear Plant USI A-46 Seismic Evaluation Report, May 1996, Revision 0, Appendix A determined that there are no essential relays installed in these panels. This review resolves outliers OSVS-9040-2, OSVS-9045, and OSVS-9050. Note that modifications may be required resulting from other outliers on these panels.

Review performed by

Kenneth H. Gomek  
K. H. Gomek

9-16-96  
date

Verified by

B. M. Pedroso Jr.  
B. M. Pedroso

9-16-96  
date





SSEL Line No. 39119

Status Y  U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 24

Equip. ID No. 3-PNLA-009-0009 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PNL 9-9 (I&C CONT PWR, CAB 2&3)

Location: Bldg. CB Floor El. 621 617 Room, Row/Col U3 MCR

Manufacturer, Model, Etc. (optional but recommended) GE

SEISMIC CAPACITY VS DEMAND

- |  |   |
|--|---|
| 1. Elevation where equipment receives seismic input      |   |
| 2. Elevation of seismic input below about 40' from grade | Y <input checked="" type="radio"/> U (grade @ 563') |
| 3. Equipment has fundamental frequency above about 8 Hz  | <input checked="" type="radio"/> N U N/A (1)        |
| 4. Capacity based on: Existing Documentation             | DOC   |
| Bounding Spectrum  | BS  |
| 1.5 x Bounding Spectrum                                  | <input checked="" type="radio"/> ABS                |
| GERS   | GERS  |
| 5. Demand based on: Ground Response Spectrum             | GRS   |
| 1.5 x Ground Response Spectrum                           | AGS   |
| Conserv. Des. In-Str. Resp. Spec.                        | CRS   |
| Realistic M-Ctr. In-Str. Resp. Spec.                     | <input checked="" type="radio"/> RRS                |

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)

N U (2)\*

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |   |
|--|---|
| 1. Equipment is included in earthquake experience equipment class  | <input checked="" type="radio"/> N U N/A    |
| 2. No computers or programmable controllers  | <input checked="" type="radio"/> N U N/A    |
| 3. No strip chart recorders  | <input checked="" type="radio"/> N U N/A    |
| 4. Steel frame and sheet metal structurally adequate   | <input checked="" type="radio"/> N U N/A    |
| 5. Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays | <input checked="" type="radio"/> N U N/A    |
| 6. Drawers and equipment on slides restrained from falling out   | <input checked="" type="radio"/> N U N/A    |
| 7. All doors secured by latch or fastener  | <input checked="" type="radio"/> N U N/A(6) |
| 8. Attached lines have adequate flexibility  | <input checked="" type="radio"/> N U N/A    |
| 9. Anchorage adequate (See checklist below for details)  | <input checked="" type="radio"/> N U N/A(5) |
| 10. Relays mounted on equipment evaluated <i>AF=4.5</i>  | <input checked="" type="radio"/> N U N/A(3) |
| 11. Have you looked for and found no other adverse concerns?   | <input checked="" type="radio"/> N U N/A    |
- Is the intent of all the caveats met for Bounding Spectrum?  N U N/A

ANCHORAGE

- |  |  |
|--|--|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation) | <input checked="" type="radio"/> N U N/A (See sketch on p 4) |
| 2. Type of anchorage covered by GIP  | <input checked="" type="radio"/> N U N/A                     |
| 3. Sizes and locations of anchors determined   | <input checked="" type="radio"/> N U N/A                     |



Equip. ID No. 3-PNLA-009-0009 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PNL 9-9 (I&C CONT PWR, CAB 2&3)

ANCHORAGE (Cont'd)

- |  |             |
|--|-------------|
| 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness  | (Y) N U N/A |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | (Y) N U N/A |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | Y N U (N/A) |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | (Y) N U N/A |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | (Y) N U N/A |
| 9. Strength of equipment base and load path to CG adequate   | (Y) N U N/A |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | (Y) N U N/A |
| Are anchorage requirements met?  | (Y) N U (5) |

INTERACTION EFFECTS

- |   |                      |
|---|----------------------|
| 1. Soft targets free from impact by nearby equipment or structures  | (Y) N U N/A (4)      |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | Y (N) U N/A (7), (8) |
| 3. Attached lines have adequate flexibility   | (Y) N U N/A          |
| 4. Overhead equipment or distribution systems are not likely to collapse                                    | (Y) N U N/A          |
| 5. Have you looked for and found no other adverse concerns?   | (Y) N U N/A (9)      |
| Is equipment free of interaction effects?   | Y (N) U (7), (8)     |

IS EQUIPMENT SEISMICALLY ADEQUATE?

Y (N) U (7), (8)

COMMENTS

- For notes 1 thru 6 see page 3 of 4.

note 7) The frame of the entry door to this area is connected to the south side of this panel. The door latch is broken and the door may impact the frame in a DBE and may cause relay chatter in this panel. outlier OSVS-39119

note 8) Unanchored bookshelf, chairs and desk in front of the panel as well as unanchored printer, computer and storage cabinet in the back of the panel are too close and may cause seismic interaction. outlier OSVS-39119

Evaluated by: Fanni Beij  
W. J. [Signature]

Date: 11/16/85  
11/17/85

note 9; Blockwall near this panel is qualified per DWG. 3-411-1203-1, Rev. 2 (Wall 49) as part of IEC 80-11 program.






JOB NO. 56147 JOB TVA / BENP A-46 / IPEEE BY FBeji DATE 11-16-95  
CALC. NO. N/A SUBJECT Attach - to SENS for Panel 3-9-9 CHK'D J.D. Ditz DATE 11/17/95  
(SSEL 39119)

## NOTES:



- 1) The panel 3-9-9 is part of a long line up of panels (3-9-9 + 3-9-25 + 3-9-46 + 3-9-47 + 3-9-44). All these panels are bolted to their adjacent panels by  $\frac{1}{2}$ "  $\phi$  to  $\frac{5}{8}$ "  $\phi$  bolts along the height of the panels @ front and back sides. The panels are heavily welded to their sill channel by 1" x 1" x  $\frac{3}{4}$ " steel bars as shown on the sketch on the next page. The panels are constructed of  $\frac{3}{32}$ " sheet metal and are reinforced with "4 corner posts (63 x 3 x  $\frac{1}{4}$ ") as well as "base and top" framing angles. The internal components are rigidly mounted and heavy cantilevered controllers are also supported rigidly at their cantilevered end. The lowest natural frequency of this panel is judged to be greater than 8 HZ. Additionally, a simple but conservative frequency estimation calculation performed for a similar panel (see SENS for panel 3-9-54, SSEL 39133), showed the overall panel mode frequency is about 11.4 HZ. (see also GE seismic qualification of electrical equipment Report NEDO-10678, CEB-CQS-82-4 which shows that the frequency of similar panels and internal components are about or greater than 8 HZ from the results of shake table tests and resonant frequency search tests)
- 2) Per Calc. CD-Q0000-940339, the in-structure response spectra @ EL. 621' of the RB (seismic demand) exceeds the 1.5 X B.S. (seismic capacity) in the frequency range of 5 to 7 HZ. Since the lowest frequency of this panel is greater than 7 HZ the intent of the seismic capacity vs. demand criteria of the GIP is met.
- 3) panel sides are continuous and are reinforced by the mounting bars / plates or Unistrut channels. An in-cabinet amplification factor of 4.5 is reasonable and consistent with the recommendation provided in EPRI NP-714BSL for this type of panel.
- 4) Fluorescent lights inside the panels have wire mesh cage around them etc
- 5) welds at anchorage points are ok by reference to calculation no. CD-Q0009-871685, "Mounting details for Control Room Panels," Rev. 5.
- 6) slight door rattling @ closed position judged acceptable and not to cause room chatter.






JOB NO. S0147 JOB TVA / BENT A-46 / IPEEE BY F. Beij DATE 11-15-95  
 CALC. NO. N/A SUBJECT Attach. to SENS for Panel 3-9-9 CHK'D J.D. D DATE 1/17/95  
 (SSEL. 39119)


Panel height =  $98\frac{1}{2}$ "  
 thickness =  $\frac{3}{32}$ "




Typical Weld Config. of the panel base angle to sill channel



A-A



Detail of sill channel connection to the concrete floor (Obtained from DWG. 48N933, SEC. G-W)





IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 3-PNLA-009-0009 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PNL 9-9 (I&C CONT PWR, CAB 2&3)

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?  Y N U N/A

2. Are essential relays required to function during earthquake screened out? Y N U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y  N U N/A

Requirements for relays satisfied? Y  N U (1)

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y N U N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

1) Unanchored bookshelf, chairs, desk, computer, printer and storage cabinet either in front or the back of this panel may cause seismic interaction in a DBE and chatter relays inside this panel. See outlier OSVS-39119

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?

YES  NO


IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO  (see note 1) above

Evaluated by: Fazli Beyi

Date: 11-16-95

Evaluated by: W. O. Dizon

Date: 11/17/95



SSEL Line No. 39119

OSVS - 39119

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number 3-PNLA-009-0009 Equipment Class 20-Instr. & Control panels

Equipment Location: Bldg. CB Floor Elevation 617'

Room or Row/Column U3 MCR Base Elevation 617'

Equipment Description PNL 9-9 (I & C PWR, CAB 2 & 3)

2. OUTLIER ISSUE DEFINITION

a. Identify all the screening guidelines which are not met.  
(Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>	_____	<u>Tanks and Heat Exchangers</u>	_____
Capacity vs. Demand	_____	Shell Buckling*	_____
Caveats	_____	Anchor Bolts and Embedment	_____
Anchorage	_____	Anchorage Connections	_____
Seismic Interaction	<input checked="" type="checkbox"/>	Flexibility of Attached Piping*	_____
Other	_____	Other	_____
<u>Essential Relays</u>	_____	<u>Cable and Conduit Raceways</u>	_____
Capacity vs. Demand	_____	Inclusion Rules	_____
Mounting, Type, Location	_____	Other Seismic Performance Concerns	_____
Other	<input checked="" type="checkbox"/>	Limited Analytical Review	_____
		Other	_____

\* Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

- 1) <sup>The area entry</sup> door @ South end of this panel (door frame is attached to this panel) has broken latch and its impact in a DBE may cause relay chatter inside this panel.
- 2) Unanchored bookshelf, chair desk in front of this panel, as well as unanchored computer, printer and storage cabinet in the back panel area are too close to this panel and may cause seismic interaction with this panel in a DBE. This interaction may cause relay chatter inside this panel.



SSEL Line No. 39119

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number 3-PNLA-009-0009

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

- 1) Provide latch or positively restrain the door
- 2) Provide anchorage for the said misc. items or remove them from the area

Alternatively, if it is shown that there are no essential relays in

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

... This panel then the outlier is resolved as is and no further action is req'd.

REVIEW OF THE ESSENTIAL RELAY LIST INDICATED THAT NO ESSENTIAL RELAYS ARE PRESENT IN PANEL 3-PNLA-009-0009. THEREFORE, OSVS-39119 IS RESOLVED

*[Handwritten signatures and dates]*  
2.23.97  
2.23.97

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

FARZIN R BEIGI  
Print or Type Name

Farzin R. Beigi  
Signature

11-16-95  
Date

JOHN O. DIZON, PE.  
Print or Type Name

John O. Dizon  
Signature

11/17/95  
Date

\_\_\_\_\_  
Print or Type Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date



SSEL Line No. 3053  
3065

Status (Y) N U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 76

Equip. ID No. 2-LI-3-58A Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description RPV LEVEL INSTRUMENT

Location: Bldg. CR Floor El. \_\_\_\_\_ Room, Row/Col \_\_\_\_\_

Manufacturer, Model, Etc. (optional but recommended) \_\_\_\_\_

SEISMIC CAPACITY VS DEMAND

- |  |           |
|--|-----------|
| 1. Elevation where equipment receives seismic input      |           |
| 2. Elevation of seismic input below about 40' from grade | Y N U     |
| 3. Equipment has fundamental frequency above about 8 Hz  | Y N U N/A |
| 4. Capacity based on:                                    |           |
| Existing Documentation                                   | DOC       |
| Bounding Spectrum  | BS        |
| 1.5 x Bounding Spectrum                                  | ABS       |
| GERS   | GERS      |
| 5. Demand based on:                                      |           |
| Ground Response Spectrum                                 | GRS       |
| 1.5 x Ground Response Spectrum                           | AGS       |
| Conserv. Des. In-Str. Resp. Spec.                        | CRS       |
| Realistic M-Ctr. In-Str. Resp. Spec.                     | RRS       |

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)

Y N U

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |           |
|--|-----------|
| 1. Equipment is included in earthquake experience equipment class  | Y N U N/A |
| 2. No computers or programmable controllers  | Y N U N/A |
| 3. No strip chart recorders  | Y N U N/A |
| 4. Steel frame and sheet metal structurally adequate   | Y N U N/A |
| 5. Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays | Y N U N/A |
| 6. Drawers and equipment on slides restrained from falling out   | Y N U N/A |
| 7. All doors secured by latch or fastener  | Y N U N/A |
| 8. Attached lines have adequate flexibility  | Y N U N/A |
| 9. Anchorage adequate (See checklist below for details)  | Y N U N/A |
| 10. Relays mounted on equipment evaluated  | Y N U N/A |
| 11. Have you looked for and found no other adverse concerns?   | Y N U N/A |

Is the intent of all the caveats met for Bounding Spectrum?

Y N U N/A

ANCHORAGE

- |  |           |
|--|-----------|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation) | Y N U N/A |
| 2. Type of anchorage covered by GIP  | Y N U N/A |
| 3. Sizes and locations of anchors determined   | Y N U N/A |





SSEL Line No. 3053  
3065

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 2 of 76

Equip. ID No. 2-LI-3-58A Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description RPV LEVEL INSTRUMENT

ANCHORAGE (Cont'd)

- |  |   |   |   |       |
|--|---|---|---|-------|
| 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers; expansion anchor tightness  | Y | N | U | N/A   |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | Y | N | U | N/A   |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | Y | N | U | N/A   |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | Y | N | U | N/A   |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | Y | N | U | N/A   |
| 9. Strength of equipment base and load path to CG adequate   | Y | N | U | N/A   |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | Y | N | U | N/A   |
| Are anchorage requirements met?  |   |   |   | Y N U |

INTERACTION EFFECTS

- |   |   |   |   |       |
|---|---|---|---|-------|
| 1. Soft targets free from impact by nearby equipment or structures  | Y | N | U | N/A   |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | Y | N | U | N/A   |
| 3. Attached lines have adequate flexibility   | Y | N | U | N/A   |
| 4. Overhead equipment or distribution systems are not likely to collapse                                    | Y | N | U | N/A   |
| 5. Have you looked for and found no other adverse concerns?   | Y | N | U | N/A   |
| Is equipment free of interaction effects?   |   |   |   | Y N U |

IS EQUIPMENT SEISMICALLY ADEQUATE?

Y  N  U

COMMENTS

- FOR SCHEMATIC OF THE INSTRUMENTATION LOOP SEE PAGES C-9, ALL COMPONENTS IN THE LOOP ARE QUALIFIED BY THE SEWS OF THE RACK OR PANEL ON WHICH THEY ARE MOUNTED OR THE SEWS FOR THE INDIVIDUAL COMPONENT.
- TE-64-161A-H AND TE-64-162A-H ARE QUALIFIED IN THE SEWS FOR SSEL # 3059 AND 3060 (UNIT 2), AND 33057 AND 33058 (UNIT 3).

Evaluated by:

J.R. NISSIE

Date:

10/17/95  
10-17-95

- FOR THE EVALUATION OF THIS COMPONENT, SEE SSEL # 9043, QUALIFIED BY "RULE OF THE BOX".



2-INV-256-0001  
 DIV I ATU  
 INVERTER (14)


SEWS (9114)




DIV I INV FUSE BOX  
 (2-JBOX-256-9722) (4)  
 SEWS (9193)







ECCS ATU PNL 2-9-81  
 SEWS (9066) (20)



TORUS TEMP MON PNL 2-9-87  
 SEWS (9072) (20)




NO SEWS  
 NO LOCAL PNL  
 2-TE-64-161A-H  
 3059 A  
 B  
 C  
 D  
 E  
 F  
 G  
 H




UNIT 2 : DIV I ATU INVERTER AND POWER SUPPLIES




2-INV-256-0002  
 DIV II ATU  
 INVERTER  
 SEWS (9115) ✓



UNIT 2 : DIV II ATU INVERTER AND POWER SUPPLIES




DIV I ATU  
INVERTER  
SEWS (39070)



ECCS ATU PNL 3-9-81  
SEWS (39135)

TORUS TEMP MON PNL 3-9-87  
SEWS (39141)



3-PX-71-60-1  
SEWS (39071)

3-PX-71-60-1A  
SEWS (39072)

3-PX-64-161  
SEWS (39082)

LOGIC  
CARD

LOGIC  
CARD

LOGIC  
CARD

3-25-5D  
SEWS (39197)

3-25-5A  
SEWS (39195)

3-TE-64-161A-H

NO  
LOCAL  
PANEL

3-LT-3-58B

3-PT-3-74A

33057 A  
B  
C  
D  
E  
F  
G  
H

3-9-5  
SEWS (39117)

3-9-3  
SEWS (39115)

3-LI-3-58A  
SEWS 33051


3-PI-3-74A  
SEWS 33053

3-TI-64-161  
SEWS 33057

UNIT 3 : DIV I ATU INVERTER AND POWER SUPPLIES







UNIT 3 : DIV II ATU INVERTER AND POWER SUPPLIES



EL Line No. 3053

Status (Y) N U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-LI-3-58A Equip. Class 20

Equipment Description \_\_\_\_\_

LAY WALKDOWN

. Does spot check of essential relays indicate relays present and properly mounted? Y N U N/A

. Are essential relays required to function during earthquake screened out? Y N U N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays, for later analysis.

. No other relay concerns? Y N U N/A

Requirements for relays satisfied? Y N U

STEM INTERACTION EFFECTS

. No potential sources could flood or spill onto cabinet? Y N U N/A

SCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

SEE THE SEWS FOR SSEL # 9043  
FOR THE EVALUATION OF THIS COMPONENT

EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?

NO

EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES / NO

evaluated by: J.R. Dissanayake

Date: 10/20/95

evaluated by: John O. Dixon

Date: 10/20/95



SSEL # 9136

Revision 2, Corrected, 6/28/91  
Status Y N U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 3

Equip. ID No. Z-LPNL-925-005D Equip. Class 18 - Instruments on Racks

Equipment Description LOCAL PANEL 25-5D

Location: Bldg. 2B Floor El. 593 Room, Row/Col S, R10

Manufacturer, Model, Etc. (optional) \_\_\_\_\_

SEISMIC CAPACITY VS DEMAND

1. Elevation where equipment receives seismic input
2. Elevation of seismic input below about 40' from grade
3. Equipment has fundamental frequency above about 8 Hz
4. Capacity based on: Existing Documentation  
Bounding Spectrum  
GERS
5. Demand based on: Ground Response Spectrum  
1.5 x Bounding Spectrum  
Conserv. Des. In-Str. Resp. Spec.  
Realistic M-Ctr. In-Str. Resp. Spec.

593

Y N U  
Y N U N/A NOTE 1  
 DOC  
~~BS~~  
 GERS  
~~GRS~~  
 ABS  
 CRS  
 RRS

Does capacity exceed demand?

Y N U

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

1. Equipment is included in earthquake experience equipment class
2. No computers or programmable controllers
3. Steel frame and sheet metal structurally adequate
4. Adjacent racks which are close enough to impact or sections of multi-bay racks are bolted together if they contain essential relays
5. Natural frequency relative to 8 Hz limit considered
6. Attached lines have adequate flexibility
7. Anchorage adequate (See checklist below for details)
8. Relays mounted on equipment evaluated
9. Have you looked for and found no other adverse concerns?

Y N U N/A  
Y N U N/A  
Y N U N/A NOTE 2  
Y N U N/A  
Y N U N/A  
Y N U N/A  
Y N U N/A  
Y N U N/A

Is the intent of all the caveats met for Bounding Spectrum?

Y N U N/A

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

1. Equipment is included in the generic seismic testing equipment class
2. Meets all Bounding Spectrum caveats
3. Component is a pressure, temperature, level or flow transmitter

Y N U N/A  
Y N U N/A  
Y N U N/A



SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2, Corrected, 6/28/91  
Sheet 2 of 3

Equip. ID No. Z-LPNL-925-005D Equip. Class 18 - Instruments on Racks

Equipment Description LOCAL PANEL 25-5D

CAVEATS - GERS (Cont'd)

- |  |   |   |   |            |
|--|---|---|---|------------|
| 4. Component is one of the specific makes and models tested, as listed in Appendix B   | Y | N | U | <u>N/A</u> |
| 5. Necessary function of component not sensitive to seismically induced system perturbations (e.g., sloshing)                    | Y | N | U | <u>N/A</u> |
| 6. No vacuum tubes   | Y | N | U | <u>N/A</u> |
| 7. All external mounting bolts in place  | Y | N | U | <u>N/A</u> |
| 8. Demand based on amplified portion of 3% damped floor response spectrum if estimated natural frequency of rack less than 33 Hz | Y | N | U | <u>N/A</u> |
| 9. Rack capable of structurally transferring GERS level seismic loads to anchorage   | Y | N | U | <u>N/A</u> |

Is the intent of all the caveats met for GERS? Y N U N/A

ANCHORAGE

- |  |          |   |   |            |
|--|----------|---|---|------------|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)   | <u>Y</u> | N | U | N/A        |
| 2. Type of anchorage covered by GIP  | <u>Y</u> | N | U | N/A        |
| Sizes and locations of anchors determined  | <u>Y</u> | N | U | N/A        |
| Adequacy of anchorage installation evaluated (weld quality and length, nuts and washers, expansion anchor tightness, etc.)   | <u>Y</u> | N | U | N/A        |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | <u>Y</u> | N | U | N/A        |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | <u>Y</u> | N | U | N/A        |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | Y        | N | U | <u>N/A</u> |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | <u>Y</u> | N | U | N/A        |
| 9. Strength of equipment base and load path to CG adequate   | <u>Y</u> | N | U | N/A        |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | Y        | N | U | <u>N/A</u> |

Are anchorage requirements met? Y N U N/A

INTERACTION EFFECTS

- |   |          |   |   |            |
|---|----------|---|---|------------|
| 1. Soft targets free from impact by nearby equipment or structures  | <u>Y</u> | N | U | N/A        |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | Y        | N | U | <u>N/A</u> |
| Attached lines have adequate flexibility  | <u>Y</u> | N | U | <u>N/A</u> |

*Flex. OK for all components*





SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2, Corrected, 6/28/91  
Sheet 3 of 3

Equip. ID No. 2-LPNL-925-005D Equip. Class 18 - Instruments on Racks

Equipment Description LOCAL PANEL 25-5D

INTERACTION EFFECTS (Cont'd)

4. Overhead equipment or distribution systems are not likely to collapse

5. Have you looked for and found no other adverse concerns?  
Is equipment free of interaction effects?

Y N U N/A  
 Y N U N/A  
 Y N U  
 Y N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

COMMENTS

For notes see 2-LPNL-925-6D

PHOTO 18-11:41

Evaluated by:

*E. J. Augusto*  
*[Signature]*

Date:

9-18-95  
9-19-95



SSEL Line No. 9186

Status  Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-LPNL-925-005D Equip. Class 18 - Instruments on Racks

Equipment Description LOCAL PANEL 25-5D

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U  N/A

2. Are essential relays required to function during earthquake screened out? Y N U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y N U  N/A

Requirements for relays satisfied?  Y  N  U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: [Signature]

Date: 9-19-95

Evaluated by: [Signature]

Date: 9-19-95



SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 3

Equip. ID No. 2-LPNL-925-006D Equip. Class 18 - Instruments on Racks

Equipment Description LOCAL PANEL 25-6D

Location: Bldg. RB Floor El. 593 Room, Row/Col P, R12

Manufacturer, Model, Etc. (optional) \_\_\_\_\_

SEISMIC CAPACITY VS DEMAND

1. Elevation where equipment receives seismic input
2. Elevation of seismic input below about 40' from grade
3. Equipment has fundamental frequency above about 8 Hz
4. Capacity based on: Existing Documentation  
Bounding Spectrum  
GERS
5. Demand based on: Ground Response Spectrum  
1.5 x Bounding Spectrum  
Conserv. Des. In-Str. Resp. Spec.  
Realistic M-Ctr. In-Str. Resp. Spec.

593

Y N U  
Y N U N/A Note 1  
 DOC  
BS  
 GERS  
GRS  
 ABS  
 CRS  
 RRS

Does capacity exceed demand?

Y N U

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

1. Equipment is included in earthquake experience equipment class
2. No computers or programmable controllers
3. Steel frame and sheet metal structurally adequate
4. Adjacent racks which are close enough to impact or sections of multi-bay racks are bolted together if they contain essential relays
5. Natural frequency relative to 8 Hz limit considered
6. Attached lines have adequate flexibility
7. Anchorage adequate (See checklist below for details)
8. Relays mounted on equipment evaluated
9. Have you looked for and found no other adverse concerns?

Y N U N/A  
Y N U N/A  
Y N U N/A Note 2  
 Y N U N/A  
Y N U N/A Note 1 & 2  
Y N U N/A  
Y N U N/A Note 2  
Y N U N/A  
Y N U N/A


Is the intent of all the caveats met for Bounding Spectrum?

Y N U N/A

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

1. Equipment is included in the generic seismic testing equipment class
2. Meets all Bounding Spectrum caveats
3. Component is a pressure, temperature, level or flow transmitter

Y N U N/A  
 Y N U N/A  
 Y N U N/A



SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2, Corrected, 6/28/91  
Sheet 2 of 3

Equip. ID No. 2-LPNL-925-006D Equip. Class 18 - Instruments on Racks

Equipment Description LOCAL PANEL 25-6D

CAVEATS - GERS (Cont'd)

- 4. Component is one of the specific makes and models tested, as listed in Appendix B Y N U N/A
- 5. Necessary function of component not sensitive to seismically induced system perturbations (e.g., sloshing) Y N U N/A
- 6. No vacuum tubes Y N U N/A
- 7. All external mounting bolts in place Y N U N/A
- 8. Demand based on amplified portion of 3% damped floor response spectrum if estimated natural frequency of rack less than 33 Hz Y N U N/A
- 9. Rack capable of structurally transferring GERS level seismic loads to anchorage Y N U N/A

Is the intent of all the caveats met for GERS?

Y N U N/A

ANCHORAGE

- 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation) Y N U N/A
- 2. Type of anchorage covered by GIP Y N U N/A
- 3. Sizes and locations of anchors determined Y N U N/A
- 4. Adequacy of anchorage installation evaluated (weld quality and length, nuts and washers, expansion anchor tightness, etc.) Y N U N/A
- 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking Y N U N/A
- 6. For bolted anchorages, gap under base less than 1/4-inch Y N U N/A
- 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors Y N U N/A
- 8. Base has adequate stiffness and effect of prying action on anchors considered Y N U N/A
- 9. Strength of equipment base and load path to CG adequate Y N U N/A
- 10. Embedded steel, grout pad or large concrete pad adequacy evaluated Y N U N/A

Are anchorage requirements met?

Y N U

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures Y N U N/A *note 3*
- 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures Y N U N/A
- Attached lines have adequate flexibility Y N U N/A *Flex OK for all components*





SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2, Corrected, 6/28/91  
Sheet 3 of 3

Equip. ID No. 2-LPAIL-925-DDD Equip. Class 18 - Instruments on Racks

Equipment Description LOCAL PANEL 25-6D

INTERACTION EFFECTS (Cont'd)

4. Overhead equipment or distribution systems are not likely to collapse

5. Have you looked for and found no other adverse concerns?


Is equipment free of interaction effects?

Y N U N/A  
Y N U N/A  
Y N U  
Y N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

COMMENTS

1. Panel is well braced. Judged to respond > 8 Hz.




- Rack is very lightly loaded  
- Due to lightweight components, anchorage of rack judged to be seismically adequate.

3. Nearby fire extinguisher judged adequately supported.

Evaluated by: G.O. Augustin  
[Signature]

Date: 9-18-95  
9-19-95

Photo 18-1122



SSEL Line No. 9188

Status (Y) N U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-LPNL-925-006D Equip. Class 18 - Instruments on Racks

Equipment Description LOCAL PANEL 25-6D

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?

Y N U (N/A)

2. Are essential relays required to function during earthquake screened out?

Y N U (N/A)

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns?

Y N U (N/A)

Requirements for relays satisfied?

Y N U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?

(Y) N U N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?

YES ✓ NO    


IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES ✓ NO    

Evaluated by: [Signature]

Date: 9-19-91

Evaluated by: [Signature]

Date: 9-19-91



SSEL Line no. 3065

Note: This is a duplicate of Electrical SSEL Line Item # 9399

Revision 2A  
Status (Y) N U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 2

Equip. ID No. 2-NM-92-7/41A Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description Channel "A" IRM Indicator

Location: Bldg. CB Floor El. 617' Room, Row/Col Unit 2 MCR

Manufacturer, Model, Etc. (optional but recommended) \_\_\_\_\_

SEISMIC CAPACITY VS DEMAND

- |  |   |   |   |     |      |
|--|---|---|---|-----|------|
| 1. Elevation where equipment receives seismic input      |   |   |   |     |      |
| 2. Elevation of seismic input below about 40' from grade | Y | N | U | N/A |      |
| 3. Equipment has fundamental frequency above about 8 Hz  | Y | N | U | N/A |      |
| 4. Capacity based on:                                    |   |   |   |     |      |
| Existing Documentation                                   |   |   |   |     | DOC  |
| Bounding Spectrum  |   |   |   |     | BS   |
| 1.5 x Bounding Spectrum                                  |   |   |   |     | ABS  |
| GERS   |   |   |   |     | GERS |
| 5. Demand based on:                                      |   |   |   |     |      |
| Ground Response Spectrum                                 |   |   |   |     | GRS  |
| 1.5 x Ground Response Spectrum                           |   |   |   |     | AGS  |
| Conserv. Des. In-Str. Resp. Spec.                        |   |   |   |     | CRS  |
| Realistic M-Ctr. In-Str. Resp. Spec.                     |   |   |   |     | RRS  |

617'


Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.) Y N U

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |   |   |   |     |
|--|---|---|---|-----|
| 1. Equipment is included in earthquake experience equipment class  | Y | N | U | N/A |
| 2. No computers or programmable controllers  | Y | N | U | N/A |
| 3. No strip chart recorders  | Y | N | U | N/A |
| 4. Steel frame and sheet metal structurally adequate   | Y | N | U | N/A |
| 5. Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays | Y | N | U | N/A |
| 6. Drawers and equipment on slides restrained from falling out   | Y | N | U | N/A |
| 7. All doors secured by latch or fastener  | Y | N | U | N/A |
| 8. Attached lines have adequate flexibility  | Y | N | U | N/A |
| 9. Anchorage adequate (See checklist below for details)  | Y | N | U | N/A |
| 10. Relays mounted on equipment evaluated  | Y | N | U | N/A |
| 11. Have you looked for and found no other adverse concerns?   | Y | N | U | N/A |
- Is the intent of all the caveats met for Bounding Spectrum? Y N U N/A

ANCHORAGE

- |  |   |   |   |     |
|--|---|---|---|-----|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation) | Y | N | U | N/A |
| 2. Type of anchorage covered by GIP  | Y | N | U | N/A |
| 3. Sizes and locations of anchors determined   | Y | N | U | N/A |



SSEL Line no. 3065

SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2A  
Sheet 2 of 2

Equip. ID No. 2-NM-92-7/41A Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description Channel "A" IRM Indicator

ANCHORAGE (Cont'd)

- 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness Y N U N/A
- 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking Y N U N/A
- 6. For bolted anchorages, gap under base less than 1/4-inch Y N U N/A
- 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors Y N U N/A
- 8. Base has adequate stiffness and effect of prying action on anchors considered Y N U N/A
- 9. Strength of equipment base and load path to CG adequate Y N U N/A
- 10. Embedded steel, grout pad or large concrete pad adequacy evaluated Y N U N/A

Are anchorage requirements met? Y N U

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures Y N U N/A
- 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures Y N U N/A
- 3. Attached lines have adequate flexibility Y N U N/A
- 4. Overhead equipment or distribution systems are not likely to collapse Y N U N/A
- 5. Have you looked for and found no other adverse concerns? Y N U N/A

Is equipment free of interaction effects? Y N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

(Y) N U

COMMENTS

The above equipment item is adequately mounted on Panel 2-9-12 (SSEL # 9403) and is evaluated by the rule of the box per GIP. Refer to SEWS for SSEL # 9403 for detailed evaluation of the control panel.

Evaluated by:

John O. Dizer

Date:

4/12/96

J.R. DISSER

4/19/96





SSEL Line No. 3065

Status (Y) N U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-NM-92-7/41A Equip. Class 20 - Instr. & Control Panels + Cabinets

Equipment Description Channel "A" IRM Indicator

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U (N/A)

2. Are essential relays required to function during earthquake screened out? Y N U (N/A)

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y N U (N/A)

Requirements for relays satisfied? (Y) N U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet? Y N U (N/A)

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

*Refer to the SEWS package for Panel 2-9-12 (SSEL #9403)*

EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES ✓ NO     

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES ✓ NO     

Evaluated by: John O. Dim

Date: 4/18/96

Evaluated by: J.R. DISSER

Date: 4/19/96







SSEL # 9403

SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2A  
Sheet 2 of 2

Equip. ID No. 2-PNA-009-012 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description Panel 2-9-12

ANCHORAGE (Cont'd)

- 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness (Y) N U N/A
- 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking (Y) N U N/A
- 6. For bolted anchorages, gap under base less than 1/4-inch *welds* Y N U (N/A)
- 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors Y N U (N/A)
- 8. Base has adequate stiffness and effect of prying action on anchors considered (Y) N U N/A
- 9. Strength of equipment base and load path to CG adequate (Y) N U N/A
- 10. Embedded steel, grout pad or large concrete pad adequacy evaluated (Y) N U N/A

Are anchorage requirements met? (Y) N U (5)

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures (Y) N U N/A (4)
- 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures (Y) N U N/A
- 3. Attached lines have adequate flexibility (Y) N U N/A
- 4. Overhead equipment or distribution systems are not likely to collapse (Y) N U N/A
- 5. Have you looked for and found no other adverse concerns? (Y) N U N/A

Is equipment free of interaction effects? (Y) N U

IS EQUIPMENT SEISMICALLY ADEQUATE?


(Y) N U

COMMENTS

- For notes 1-5, refer to the SEWS package for Panel 3-9-9 (SSEL # 39119) based on similar configuration.

6. Latches to the doors are loose and may cause relay chatter during a seismic event.

Evaluated by: John O. Dizer Date: 4/19/96  
J.R. DISSER 4/19/96



SSEL Line No. 9403  
AI

Status Y  N  U  
Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-PNLA-009-012 Equip. Class 20 - I&C Panels + Cabinets

Equipment Description Panel 2-9-12

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?  Y  N  U  N/A

2. Are essential relays required to function during earthquake screened out?  Y  N  U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns?  Y  N  U  N/A

Requirements for relays satisfied?  Y  N  U  (1)

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

1. See outlier OSVS # 9403 for potential relay chatter concerns.

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?  
YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO  (1)

Evaluated by: John O. Dizon

Date: 4/19/96

Evaluated by: [Signature]

Date: 4/19/96





OSVS # 9403

Sheet 1 of 2

Exhibit 5-1

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number 2-PNLA-009-012 Equipment Class 20  
 Equipment Location: Building CB Floor Elevation 617'  
 Room or Row/Column MCR Base Elevation 617'  
 Equipment Description Panel 2-9-12

2. OUTLIER ISSUE DEFINITION

- a. Identify all the screening guidelines which are not met.  
(Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>		<u>Tanks and Heat Exchangers</u>	
Capacity vs. Demand	<input type="checkbox"/>	Shell Buckling <sup>1</sup>	<input type="checkbox"/>
Caveats	<input checked="" type="checkbox"/>	Anchor Bolts and Embedment	<input type="checkbox"/>
Anchorage	<input type="checkbox"/>	Anchorage Connections	<input type="checkbox"/>
Seismic Interaction	<input type="checkbox"/>	Flexibility of Attached Piping <sup>1</sup>	<input type="checkbox"/>
Other	<input type="checkbox"/>	Other	<input type="checkbox"/>
<u>Essential Relays</u>		<u>Cable and Conduit Raceways</u>	
Capacity vs. Demand	<input type="checkbox"/>	Inclusion Rules	<input type="checkbox"/>
Mounting, Type, Location	<input type="checkbox"/>	Other Seismic Performance Concerns	<input type="checkbox"/>
Other	<input checked="" type="checkbox"/>	Limited Analytical Review	<input type="checkbox"/>
		Other	<input type="checkbox"/>

<sup>1</sup> Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

- b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

Latches to the doors of this panel are loose and could potentially cause chatter to essential relays housed in the panel during a seismic event.



SSEL # 9403

Revision 2  
Corrected, 6/28/91

OSVS # 9403

Sheet 2 of 2

Exhibit 5-1 (Cont'd)

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number 2-PNLA-009-012

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

Repair loose latches or verify that there  
are no essential relay in the cabinet

There are no essential relays in panel 2-9-12. see attached  
informal memo dated 9-17-96. KAG

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

JOHN O. DIZON, PE      John O. Dizon      4/19/96  
Print or Type Name      Signature      Date

JAMES R. DISSER      [Signature]      4/19/96  
Print or Type Name      Signature      Date

\_\_\_\_\_  
Print or Type Name      Signature      Date



INFORMAL

September 17, 1996

REVIEW FOR ESSENTIAL RELAYS IN PANELS 2-PNLA-009-0012 and 2-PNLA-009-0036A

Modifications or repair to panels 2-PNLA-009-0012 (SSEL No. 9403) and 2-PNLA-009-0036A (SSEL No. 9307) were determined to possibly be required under the USI A-46 program, resulting from outliers OSVS-9403, OSVS-9307-1, and OSVS-9307-2, if these panels contain essential relays. A review of the Browns Ferry Nuclear Plant USI A-46 Seismic Evaluation Report, May 1996, Revision 0 (R92 960624 850), Appendix A determined that there are no essential relays in these panels. This review resolves outliers OSVS-9403, OSVS-9307-1, and OSVS-9307-2.

Review performed by

Kenneth H. Gromek  
K. H. Gromek

9-17-96  
date

Verified by

Anand C. Relwani  
A. C. Relwani

9-17-96  
date



SSEL Line No. 9168

Status (Y) N U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 1

Equip. ID No. 2-PX-64-67B Equip. Class 00 -

Equipment Description POWER SUPPLY (PNL 2-9-19 ; SUPPORTS 2-PI-64-67B)

Location: Bldg. CB Floor El. 593 Room, Row/Col U2 AIR

Manufacturer, Model, Etc. (optional but recommended) \_\_\_\_\_

\*\*\* ~~THE EQUIPMENT CLASS FOR THIS PIECE OF EQUIPMENT HAS NOT BEEN DETERMINED~~ \*\*\*


This equipment is housed in panel 2-9-19.

See SEWS for 2-PNLA-009-0019 (SSEL No. 9049)

for evaluation.

Evaluated by: Fanni Bai  
John A. Dixon

Date: 7-21-95  
7/21/95





SSEL Line No. 9168

Status  Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-PX-64-67B Equip. Class 00 -

Equipment Description POWER SUPPLY (PNL 2-9-19 ; SUPPORTS 2-PI-64-67B)

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U  N/A

2. Are essential relays required to function during earthquake screened out? Y N U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y N U  N/A

Requirements for relays satisfied? Y N U  N/A (1)

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

1) 2-PX-64-67B is housed in panel 2-9-19 (SSEL # 9049). Any essential relays within this panel will be evaluated separately in the A-46 relay review program.

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: Fazli Reji

Date: 7-21-95

Evaluated by: John D. Diem

Date: 7/21/95



SEL Line No. 9049

Status  N  U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 2

Equip. ID No. 2-PNLA-009-0019 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PANEL 9-19

Location: Bldg. CB Floor El. 593 Room, Row/Col U2 AIR

Manufacturer, Model, Etc. (optional but recommended) GE

SEISMIC CAPACITY VS DEMAND

1. Elevation where equipment receives seismic input
2. Elevation of seismic input below about 40' from grade
3. Equipment has fundamental frequency above about 8 Hz
4. Capacity based on: Existing Documentation  
Bounding Spectrum  
1.5 x Bounding Spectrum  
GERS
5. Demand based on: Ground Response Spectrum  
1.5 x Ground Response Spectrum  
Conserv. Des. In-Str. Resp. Spec.  
Realistic M-Ctr. In-Str. Resp. Spec.

593

N  U grade @ 550'

N  U N/A (1)

DOC

BS

ABS

GERS

GRS

AGS

CRS

RRS

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)

N  U  
(Ref. Calc. 20-00000-940339)

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

1. Equipment is included in earthquake experience equipment class
  2. No computers or programmable controllers ok
  3. No strip chart recorders
  4. Steel frame and sheet metal structurally adequate
  5. Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays
  6. Drawers and equipment on slides restrained from falling out
  7. All doors secured by latch or fastener
  8. Attached lines have adequate flexibility
  9. Anchorage adequate (See checklist below for details)
  10. Relays mounted on equipment evaluated AF = 4.5
  11. Have you looked for and found no other adverse concerns?
- Is the intent of all the caveats met for Bounding Spectrum?

N  U N/A

N  U N/A (11)

N  U N/A

N  U N/A

N  U N/A (7), (10)

N  U N/A

N  U N/A

N  U N/A

N  U N/A (6)

N  U N/A (4)

N  U N/A (12)

N  U N/A

ANCHORAGE

1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)
2. Type of anchorage covered by GIP
3. Sizes and locations of anchors determined

N  U N/A (4)

N  U N/A (2, 5)

N  U N/A J



SSEL Line No. 9049

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 2 of 2

Equip. ID No. 2-PNLA-009-0019 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PANEL 9-19

ANCHORAGE (Cont'd)

- 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness (Y) N U N/A (2)
  - 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking (Y) N U N/A
  - 6. For bolted anchorages, gap under base less than 1/4-inch (Y) N U N/A
  - 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors (Y) N U N/A (2)
  - 8. Base has adequate stiffness and effect of prying action on anchors considered (Y) N U N/A
  - 9. Strength of equipment base and load path to CG adequate (Y) N U N/A
  - 10. Embedded steel, grout pad or large concrete pad adequacy evaluated Y N U (N/A)
- Are anchorage requirements met? (Y) N U (2)

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures (Y) N U N/A
  - 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures (Y) N U N/A
  - 3. Attached lines have adequate flexibility (Y) N U N/A (6)
  - 4. Overhead equipment or distribution systems are not likely to collapse (Y) N U N/A (7)
  - 5. Have you looked for and found no other adverse concerns? (Y) N U N/A (9)
- Is equipment free of interaction effects? (Y) N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

(Y) N U

COMMENTS


For notes 1 thru 12 see notes 1-12 on SEWS for 2-PNLA-009-0018 (SSEL no. 9048).

Evaluated by:

Fangli Bei  
John O. Dizon

Date:

9-15-95  
9/15/95



SEL Line No. 9049

Status  Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-PNLA-009-0019 Equip. Class 20 - Instr. & Control Panels & Cabinets.

Equipment Description PANEL 9-19

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?  Y  N  U  N/A

2. Are essential relays required to function during earthquake screened out?  Y  N  U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns?  Y  N  U  N/A

Requirements for relays satisfied?  Y  N  U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: Fazli Bari

Date: 9-15-95

Evaluated by: John O. Dixon

Date: 9/15/95





SSEL Line No. 9048

Status  N  U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 27

Equip. ID No. 2-PNLA-009-0018 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PANEL 9-18

Location: Bldg. CB Floor El. 593 Room, Row/Col U2 AIR

Manufacturer, Model, Etc. (optional but recommended) GE

SEISMIC CAPACITY VS DEMAND

1. Elevation where equipment receives seismic input
2. Elevation of seismic input below about 40' from grade
3. Equipment has fundamental frequency above about 8 Hz
4. Capacity based on: Existing Documentation  
Bounding Spectrum  
1.5 x Bounding Spectrum  
GERS
5. Demand based on: Ground Response Spectrum  
1.5 x Ground Response Spectrum  
Conserv. Des. In-Str. Resp. Spec.  
Realistic M-Ctr. In-Str. Resp. Spec.

593'  
 N  U grade @ 550'  
 N  U N/A (1)  
 DOC  
 BS  
 ABS  
 GERS  
 GRS  
 AGS  
 CRS  
 RRS

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)

N  U  
(Ref. Calc. CD-90000-94033?)

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

1. Equipment is included in earthquake experience equipment class
  2. No computers or programmable controllers OK
  3. No strip chart recorders
  4. Steel frame and sheet metal structurally adequate
  5. Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays
  6. Drawers and equipment on slides restrained from falling out
  7. All doors secured by latch or fastener
  8. Attached lines have adequate flexibility
  9. Anchorage adequate (See checklist below for details)
  10. Relays mounted on equipment evaluated AF=4.5
  11. Have you looked for and found no other adverse concerns?
- Is the intent of all the caveats met for Bounding Spectrum?

N  U N/A  
 N  U N/A (11)  
 N  U N/A  
 N  U N/A  
 N  U N/A (3), (10)  
 N  U N/A  
 N  U N/A  
 N  U N/A (6)  
 N  U N/A (2)  
 N  U N/A (12)  
 N  U N/A  
 N  U N/A

ANCHORAGE

1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)
2. Type of anchorage covered by GIP
3. Sizes and locations of anchors determined

N  U N/A (4)  
 N  U N/A (2, 5)  
 N  U N/A ↓



Equip. ID No. 2-PNLA-009-0018 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PANEL 9-18

ANCHORAGE (Cont'd)

- |  |                         |
|--|-------------------------|
| 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness  | (Y) N U N/A (2)         |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | (Y) N U N/A             |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | (Y) N U N/A             |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | (Y) N U N/A (2)         |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | (Y) N U N/A             |
| 9. Strength of equipment base and load path to CG adequate   | (Y) N U N/A             |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | Y N U (N/A) (Y) N U (2) |
- Are anchorage requirements met?

INTERACTION EFFECTS

- |   |                 |
|---|-----------------|
| 1. Soft targets free from impact by nearby equipment or structures  | (Y) N U N/A     |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | (Y) N U N/A     |
| 3. Attached lines have adequate flexibility   | (Y) N U N/A (6) |
| 4. Overhead equipment or distribution systems are not likely to collapse                                    | (Y) N U N/A (7) |
| 5. Have you looked for and found no other adverse concerns?   | (Y) N U N/A (9) |
- Is equipment free of interaction effects? (Y) N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

(Y) N U

COMMENTS


For notes 1 thru 10 see pages 3 thru 7 of this SEWS.

Note 11) <sup>when</sup> programmable controllers <sup>are present in the AER panels, they</sup> are either mounted on the front face of the panel and their rear is independently supported by a member that spans the panel in the back or they have their own rigid support system inside the panel.

Note 12) By referring to notes 1 and 10, and EPRI Report NP-7148-SL, an in-cabinet

Evaluated by: Fazil Beji Date: 9-15-95  
John O. Dixon 9/15/95

amplification factor of 4.5 is appropriate for these panels.







JOB NO. 50147 JOB TVA / RIFWP A-46 / IPEEE BY ZBcij DATE 9-15-95  
 CALC. NO. NIA SUBJECT Attachment to SEWS for 2-PNLA-009-0018 CHK'D J.D. Dizer DATE 9/15/95  
 (SSEL 9048)

SSEL No. 9048

1) panel is in a row of other similar panels which are all bolted together. These panels (9-19, 9-18, 9-30, 9-38, 9-28, 9-27) are all constructed of heavy gage metal ( $t=3/16$ ). The front and sides of these panels where internal components are attached are reinforced. The panels base configuration consist of base angles ( $L2 \times 3 \times 1/4$ ) which are welded to the sill channel. There are many top entry conduit with short spans that either span to another set of panels in an adjacent row ( $\sim 4'$  away) or have independent rigid supports. The depth of these panels is 30". Based on the above discussion it can be judged <sup>(single units)</sup> that the panel frequency is at least 8 Hz. (Also, similar panels were shake table tested and showed to have fundamental frequency of about 10 Hz. Even though the tested panels are classified as switchboards, the configuration is similar to these panels.)

2) The anchorage of the sill channel to the floor is not visible. The detail shown on DWG. 0-47E605-3 (section F-F) indicates the following anchor configuration for the sill channel. However, the detail does not indicate at what interval this anchorage should be provided for the sill channel. Conservatively, Capacity vs. demand calculation performed on the following sheets, <sup>(pp. 4&5)</sup> determines that a min. of 7 such details are req'd per side (F&B) of channel. Total length of sill channel is 29'/side. This means that @  $n=7$ , one such detail is req'd at about every 5'. The detail is such that the anchor bolts could only be installed at the location of  $1/4"$   $\phi$  grout holes provided on top of the sill channel. Grout holes are typically provided at every 2'-3', <sup>from observations of similar configurations on site.</sup> since the anchors could only be tightened through the grout holes, as the above referenced drawing indicates, it is reasonable to assume that there are anchors at every 2'-3' per sill channel. Therefore, it is judged that there are adequate anchorage for these panels.







JOB NO. 50147 JOB TVA/BENP A-46 / IPEEE BY F Benz DATE 9-15-95  
 CALC. NO. NIA SUBJECT Attach. to SEWC for 2-PNLA-009-0018 CHK'D D. Dizon DATE 9/15/95  
 (SSEL 9048)

2 (cont'd)

Anchorage Evaluation: (Conservatively, ignore top restraint provided by the conduit)

$$\begin{aligned}
 \text{D. wt.} &= \left\{ 4 \times \left[ \frac{46,800}{31320} \left[ (30 \times 30) + 2(30 \times 90) + 2(30 \times 90) \right] + \frac{18000}{30960} \left[ (60 \times 30) + 2(60 \times 90) + 2(30 \times 90) \right] \right. \right. \\
 &\quad \left. \left. + 3 \left[ (24 \times 30) + 2(24 \times 90) + 2(30 \times 90) \right] + 2 \left[ (48 \times 30) + 2(48 \times 90) + 2(30 \times 90) \right] \right\} \times \frac{3}{32} \times \frac{490}{12^3} \times 3.0 = 10,135 \text{.}^{\#}
 \end{aligned}$$

(Conservatively use 3x Cabinet wt. per 61P. Some cabinets are relatively empty)

•  $f = 8 \text{ Hz}$

$a_h = 0.6g$  (Ref. NARS report, RB EL 593, DBE, 5% Damping)

$a_v = 0.16g$  (ZPA)

$F_h = 10,135 \text{.}^{\#} \times 0.6g \times 1.25 = 7601 \text{.}^{\#}$  ↙ To account for Mod. Ctr. spect.

$F_v = 10,135 \text{.}^{\#} \times 0.16g \times 1.25 = 2027 \text{.}^{\#}$

•  $\frac{1}{2} \text{'' } \phi$  shell anchor bolts

$T_{q11} = 2,290 \text{.}^{\#} \times 0.75 \times \frac{3600}{4000} = 1546 \text{. lbs}$  ↙ Reduction for relays

$V_{a11} = 2380 \text{.}^{\#} \times 0.75 = 1785 \text{. lbs}$

$T = \left[ \left( \frac{7601 \times 45^\circ}{(30^\circ - 3^\circ)n} \right)^2 + \left( \frac{2027}{2n} \right)^2 \right]^{1/2} - \frac{10135}{2n} \equiv 1546$

where  $n$  is the req'd. no. of anchor bolts per sill channel

$$\left( \frac{1.605 \times 10^8}{n^2} + \frac{1.027 \times 10^6}{n^2} \right)^{1/2} = \frac{10135 + 3092n}{2n}$$

$$\left( \frac{1.615 \times 10^8}{n^2} \right)^{1/2} = \frac{10135 + 3092n}{2n} \Rightarrow \frac{7626 \times 2}{3092} = n \rightarrow n = 5$$







JOB NO. 50147 JOB TVA/BENP A-46/1PEEE BY F. B. J. DATE 9-15-95  
 CALC. NO. N/A SUBJECT Attach. to SEWS for 2-PNLA-009-0018 CHK'D J. O. D. DATE 9/15/95  
 (SSEL 9048)

2 (Cont'd)

$$- V = \left( \frac{7601}{2^n} \right) \sqrt{2} \cong 1785$$

$$\Rightarrow n = 3$$

$$\text{Try } n=5 \rightarrow V = 1075. \quad \rightarrow \frac{V}{V_{all}} = 0.60$$

$$\rightarrow T = 1528. \quad \rightarrow \frac{T}{T_{all}} = 0.99$$

$$IR = 0.7 (0.99) + 0.6 = 1.3 > 1.0$$

→ use 6 anchors per sill channel

$$- @ n=6 \rightarrow V = 896 \# \quad \rightarrow \frac{V}{V_{all}} = 0.50$$

$$T = 1274 \# \quad \rightarrow \frac{T}{T_{all}} = 0.82$$

$$IR = 0.7 (0.82) + 0.50 = 1.07 > 1.0 \rightarrow \text{use } n=7$$

$$- @ n=7 \rightarrow V = 768 \# \quad \rightarrow \frac{V}{V_{all}} = 0.43$$

$$T = 1092. \quad \rightarrow \frac{T}{T_{all}} = 0.71$$


$$IR = 0.7 (0.71) + 0.43 = 0.93 < 1.0 \quad \text{ok}$$

∴ min Req'd anchor bolt per sill channel = 7

For typical grout hole spacing of 2'-3', use  $n = \frac{29'}{3'} = 9.7 \rightarrow \text{use } n=10$

$$- @ n=10 \rightarrow V = 537 \quad \rightarrow \frac{V}{V_{all}} = 0.3 \cong .3 \quad \text{ok}$$

$$\rightarrow T = 764. \quad \rightarrow \frac{T}{T_{all}} = \underline{\underline{0.49}} < 1.0 \quad \text{ok}$$





JOB NO. 50147 JOB TVA/BEND A-46/1PEEE BY F. Bein DATE 8-15-95  
 CALC. NO. N/A SUBJECT Attach to SEWS for 2-PNLA-009-0018 CHK'D. J.O. Dizon DATE 9/15/95

NOTE 2 (Cont'd).

- Evaluation of welds @ panel base to sill channel interface:

The connection of the panel to the sill channel is by providing weld on the inside of the panel base framing. Since, the panel base framing is L 3"x2"x1/4" it is judged that the base is rigid enough to adequately transfer the load from the panel sides to the welds, and as such the weld configuration (w.r.t welding on the inside edge of the angle) is adequate.

Total length of weld per sill channel = @ Back : 26"

@ Front : 29.5"

$$\text{use } \frac{26''}{2} = 13''$$

← conservative, to account for some deficient welds and overall weld positioning and quality

← conservative. 3/16" could be used

per Table C.6-2 of GIP every inch of a 1/8" weld is equivalent to a 1/2"  $\phi$  expansion anchor bolt. Therefore, by comparison to the req'd no. of 1/2"  $\phi$  Exp. anchors per sill channel (7 total), the welds are not the weak link in the load path and judged ok (13-1/2"  $\phi$ )





JOB NO. 50147 JOB TVA/BENP A-46 / IPTEE

BY F. Beji DATE 9-15-95

CALC. NO. N/A SUBJECT Attach to SEWS for 2-PNLA-009-0018 (SSEL 9048)

CHK'D J.O. Diaz DATE 9/15/95

Photo: 177:48x2,  
177:49


SSEL: 9048, 9049, 9057, 9058

ID: Panels 9-18, 9-19, 9-28, 9-30

3) All adjacent panels are bolted together along their entire height w/ 1/2" bolts.

4) Use 3.0 x D.L. for w.f. calculation.  
CG. @ geometric center of the panels

Thickness = 3/32"  
height = 90"



Fillet weld on the inside edge of base angle. 3/16" thr

- 6) Flex conduit have adequate flexibility
- 7) Fluorescent light tubes overhead adequately restrained from falling.
- 8) Conservatively, ignore any top restraint provided to these panels by top entry short span rigid conduit, in anchorage evaluation.
- 9) Blockwalls surrounding 42 AIR, i.e., at N, E + W of these panels have been qualified under IEB 80-11 program (Ref. DWG. 41N1202-1, R3)  
41N1201-1, R4)
- 10) Panel 9-27 is butted against blockwall at one side and bolted to panel 9-28 at the other side. The row of panels in E-W direction is very rigid and the deflections at top of panels will be insignificant. It is judged that the relative displacement between these row of panels and the blockwall in the E/W dir. is zero and therefore ok



SSEL Line No. 9048

Status  Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-PNLA-009-0018 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PANEL 9-18

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?  Y  N  U  N/A

2. Are essential relays required to function during earthquake screened out?  Y  N  U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns?  Y  N  U  N/A

Requirements for relays satisfied?  Y  N  U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: Forzi Deji

Date: 9-15-95

Evaluated by: John O. Dizon

Date: 9/15/95





SSEL Line No. 9393

Status  Y  N  U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 1

Equip. ID No. 2-AMP-092-0007/41A Equip. Class 00 - Other

Equipment Description IRM Ch. "A" Voltage Preamplifier 7-34A

Location: Bldg. RB Floor El. 565 Room, Row/Col S/R10

Manufacturer, Model, Etc. (optional but recommended) GE

IS EQUIPMENT SEISMICALLY ADEQUATE?

Y  N  U

COMMENTS

This component is adequately mounted inside Panel 2-LPNL-925-0027 and is evaluated by rule of the box per GIP. Refer to SEWS package for 2-LPNL-925-0027 (SSEL # 9395) for detailed evaluation of the panel.

Evaluated by: John A. Dixon  
J.R. Disser

Date: 4/19/96  
4/19/96



SSEL Line No. 9393  
AI

Status  Y  N  U  
Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-AMP-092-0007/41A Equip. Class 00 - Other  
Equipment Description IRM Ch. "A" Voltage Preamplifier 7-34A

RELAY WALKDOWN

- 1. Does spot check of essential relays indicate relays present and properly mounted? Y N U  N/A
- 2. Are essential relays required to function during earthquake screened out? Y N U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

- 3. No other relay concerns? Y N U  N/A

Requirements for relays satisfied?  Y  N  U

SYSTEM INTERACTION EFFECTS

- 1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

*See SEWS for SSEL # 9395*

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?  
YES  NO


IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: John A. Dizer

Date: 4/19/96

Evaluated by: J.R. DISSER

Date: 4/19/96



SEEL Line no. 9395

Revision 2A  
Status  Y  N  U

SCREENING EVALUATION WORK SHEET (SEWS) Sheet 1 of 3

Equip. ID No. 2-LPNL-925-0027 Equip. Class 14 - Distribution Panels

Equipment Description Panel 2-25-27 IRM PREAMP. RPS II

Location: Bldg. RB Floor El. 565 Room, Row/Col S/R10

Manufacturer, Model, Etc. (optional but recommended) \_\_\_\_\_

SEISMIC CAPACITY VS DEMAND

- Elevation where equipment receives seismic input
- Elevation of seismic input below about 40' from grade
- Equipment has fundamental frequency above about 8 Hz
- Capacity based on: Existing Documentation  
Bounding Spectrum  
1.5 x Bounding Spectrum  
GERS
- Demand based on: Ground Response Spectrum  
1.5 x Ground Response Spectrum  
Conserv. Des. In-Str. Resp. Spec.  
Realistic M-Ctr. In-Str. Resp. Spec.

~570' Eff. Grade  
530'

Y  N  U  N/A  
 Y  N  U  N/A (2)  
 DOC  
 BS  
 ABS  
 GERS  
 GRS  
 AGS  
 CRS  
 RRS

Does capacity exceed demand? (Indicate at right (\*)) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)

Y  N  U  
 Ref. Calc.  
 CD-Q0000-940339

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- Equipment is included in earthquake experience equipment class
- Contains only circuit breakers and switches
- All latches and fasteners in door secured
- Adjacent cabinets which are close enough to impact, or sections of multi-bay cabinets, are bolted together if they contain essential relays
- Wall- or floor-mounted NEMA-type enclosure
- Anchorage adequate (See checklist below for details)
- Relays mounted on equipment evaluated
- Have you looked for and found no other adverse concerns?

Y  N  U  N/A  
 Y  N  U  N/A (1)  
 Y  N  U  N/A  
 Y  N  U  N/A (1)  
 Y  N  U  N/A  
 Y  N  U  N/A  
 Y  N  U  N/A

Is the intent of all the caveats met for Bounding Spectrum?

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- Equipment is included in the generic seismic testing equipment class
- Meets all Bounding Spectrum caveats
- Use panelboard GERS unless unit is free-standing and designated as a switchboard by manufacturer
- W "Quicklag" Type E circuit breakers are not in distribution panel
- All adjacent cabinets or sections of multi-bay assemblies bolted together

Y  N  U  N/A  
 Y  N  U  N/A  
 Y  N  U  N/A  
 Y  N  U  N/A  
 Y  N  U  N/A  
 Y  N  U  N/A

Is the intent of all the caveats met for GERS?



SSEL Line no. 9395

SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2A  
Sheet 2 of 3

Equip. ID No. 2-LPNL-925-0027 Equip. Class 14 - Distribution Panels

Equipment Description Panel 25-27 IRM PREAMP. RPS I

ANCHORAGE

- |  |     |   |   |         |
|--|-----|---|---|---------|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)   | (Y) | N | U | N/A     |
| 2. Type of anchorage covered by GIP  | (Y) | N | U | N/A     |
| 3. Sizes and locations of anchors determined   | (Y) | N | U | N/A     |
| 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness  | (Y) | N | U | N/A     |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | (Y) | N | U | N/A     |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | (Y) | N | U | N/A (3) |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | Y   | N | U | (N/A)   |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | (Y) | N | U | N/A     |
| 9. Strength of equipment base and load path to CG adequate   | (Y) | N | U | N/A     |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | Y   | N | U | (N/A)   |
- Are anchorage requirements met? (Y) N U (4)...

INTERACTION EFFECTS

- |   |     |   |   |       |
|---|-----|---|---|-------|
| 1. Soft targets free from impact by nearby equipment or structures  | (Y) | N | U | N/A   |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | Y   | N | U | (N/A) |
| 3. Attached lines have adequate flexibility   | (Y) | N | U | N/A   |
| 4. Overhead equipment or distribution systems are not likely to collapse                                    | (Y) | N | U | N/A   |
| 5. Have you looked for and found no other adverse concerns?   | (Y) | N | U | N/A   |
- Is equipment free of interaction effects? (Y) N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

(Y) N U

See next page for walkdown notes





SSEL Line no. 9395

SCREENING EVALUATION WORK SHEET (SEWS) Revision 2A  
Sheet 3 of 3

Equip. ID No. 2-LPNL-925-0027 Equip. Class 14 - Distribution Panels  
Equipment Description Panel 2-25-27 IIRN PREAMP. RPS I

COMMENTS

- 1 - Typical Hoffman single door enclosure, size: 30"W x 36"H x 16"D (NEMA type, 14 gage). A total of 6 preamplifiers are rigidly mounted to the enclosure back panel. Two pulse preamps. on top row, and 2 voltage preamps. on the middle and bottom rows.
- 2 - The panel enclosure is rigidly mounted to the wall by 4- $\frac{1}{2}$ " $\phi$  exp. anchors (2 on top + 2 at the bottom). The preamplifiers are light weight and are rigidly mounted on  $\frac{1}{8}$ " thick plate which is bolted to the back of panel with 4- $\frac{3}{8}$ " $\phi$  welded studs. Top entry conduit are well supported. Overall frequency is judged to be  $> 8$  hz. (Also, per EPRI TR-102180, similar wall-mounted distribution panels exhibited a lowest natural frequency of  $> 12$  hz per test results.
- 3 - Gap between the enclosure and the wall is about  $\frac{1}{2}$ " due to the presence of ground wire behind the panel. Stacks of washers are provided at each of the bolt locations, thus considered adequate.
- 4 - Panel/anchorage configuration is enveloped by the bounding calculation performed for SSEL # 39051, with large margins.

Evaluated by:

John O. Dizer

Date:

4/19/96

J.R. DISSER

4/19/96



SSEL Line No. 9395  
AI

Status Y N U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-LPNL-925-0027 Equip. Class 14 - Distribution Panels

Equipment Description Panel 2-25-27 IRM PREAMP RPS I

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U N/A

2. Are essential relays required to function during earthquake screened out? Y N U N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y N U N/A

Requirements for relays satisfied? Y N U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet? Y N U N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?  
YES ✓ NO    

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES ✓ NO    

Evaluated by: Jim DiDion

Date: 4/19/96

Evaluated by: J.R. DISSER

Date: 4/19/96



SSEL Line No. 39051

Status  Y  N  U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 34

Equip. ID No. 3-JBOX-253-7162 Equip. Class 14 - Distribution Panels

Equipment Description I&C BUS 3B BREAKER BOX

Location: Bldg. U3 RB Floor El. 593 Room, Row/Col SD BD RM F

Manufacturer, Model, Etc. (optional but recommended) GE F225 + 1600 line circuit breakers

SEISMIC CAPACITY VS DEMAND

- |  |  |
|--|--|
| 1. Elevation where equipment receives seismic input      |  |
| 2. Elevation of seismic input below about 40' from grade | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <sup>599'</sup> grade @ 563 |
| 3. Equipment has fundamental frequency above about 8 Hz  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U N/A(2)                      |
| 4. Capacity based on:                                    |  |
| Existing Documentation                                   | <input type="radio"/> DOC  |
| Bounding Spectrum  | <input checked="" type="radio"/> BS  |
| 1.5 x Bounding Spectrum                                  | <input type="radio"/> ABS  |
| GERS   | <input type="radio"/> GERS   |
| 5. Demand based on:                                      |  |
| Ground Response Spectrum                                 | <input checked="" type="radio"/> GRS   |
| 1.5 x Ground Response Spectrum                           | <input type="radio"/> AGS  |
| Conserv. Des. In-Str. Resp. Spec.                        | <input type="radio"/> CRS  |
| Realistic M-Ctr. In-Str. Resp. Spec.                     | <input type="radio"/> RRS  |

Does capacity exceed demand? (Indicate at right (\*)) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)

Y  N  U  
(Ref. Calc  
CD-Q0000-940379)

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |  |
|--|--|
| 1. Equipment is included in earthquake experience equipment class  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A     |
| 2. Contains only circuit breakers and switches   | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A     |
| 3. All latches and fasteners in door secured   | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A     |
| 4. Adjacent cabinets which are close enough to impact, or sections of multi-bay cabinets, are bolted together if they contain essential relays | <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A     |
| 5. Wall- or floor-mounted NEMA-type enclosure  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A (1) |
| 6. Anchorage adequate (See checklist below for details)  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A     |
| 7. Relays mounted on equipment evaluated   | <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A     |
| 8. Have you looked for and found no other adverse concerns?  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A     |
- Is the intent of all the caveats met for Bounding Spectrum?  Y  N  U  N/A

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |   |  |
|---|--|
| 1. Equipment is included in the generic seismic testing equipment class                             | <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |
| 2. Meets all Bounding Spectrum caveats  | <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |
| 3. Use panelboard GERS unless unit is free-standing and designated as a switchboard by manufacturer | <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |
| 4. W "Quicklag" Type E circuit breakers are not in distribution panel                               | <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |
| 5. All adjacent cabinets or sections of multi-bay assemblies bolted together                        | <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |
- Is the intent of all the caveats met for GERS?  Y  N  U  N/A



Equip. ID No. 3-JBOX-253-7162 Equip. Class 14 - Distribution Panels

Equipment Description I&C BUS 3B BREAKER BOX

ANCHORAGE

- |  |                                  |   |   |  |
|--|----------------------------------|---|---|--|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)   | <input checked="" type="radio"/> | N | U | N/A (1, 4)                               |
| 2. Type of anchorage covered by GIP  | <input checked="" type="radio"/> | N | U | N/A                                      |
| 3. Sizes and locations of anchors determined   | <input checked="" type="radio"/> | N | U | N/A                                      |
| 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness  | <input checked="" type="radio"/> | N | U | N/A                                      |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | <input checked="" type="radio"/> | N | U | N/A                                      |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | <input checked="" type="radio"/> | N | U | N/A                                      |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | Y                                | N | U | <input checked="" type="radio"/> N/A     |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | <input checked="" type="radio"/> | N | U | N/A                                      |
| 9. Strength of equipment base and load path to CG adequate   | <input checked="" type="radio"/> | N | U | N/A                                      |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | Y                                | N | U | <input checked="" type="radio"/> N/A     |
| Are anchorage requirements met?  |                                  |   |   | <input checked="" type="radio"/> N U (4) |


INTERACTION EFFECTS

- |   |                                  |   |   |                                      |
|---|----------------------------------|---|---|--------------------------------------|
| 1. Soft targets free from impact by nearby equipment or structures  | <input checked="" type="radio"/> | N | U | N/A                                  |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | Y                                | N | U | <input checked="" type="radio"/> N/A |
| 3. Attached lines have adequate flexibility   | <input checked="" type="radio"/> | N | U | N/A (3)                              |
| 4. Overhead equipment or distribution systems are not likely to collapse                                    | <input checked="" type="radio"/> | N | U | N/A                                  |
| 5. Have you looked for and found no other adverse concerns?   | <input checked="" type="radio"/> | N | U | N/A                                  |
| Is equipment free of interaction effects?   |                                  |   |   | <input checked="" type="radio"/> N U |

IS EQUIPMENT SEISMICALLY ADEQUATE?

N U

See next pages for notes.






Equip. ID No. 3-JBOX-253-7162 Equip. Class 14 - Distribution Panels

Equipment Description I&C BUS 3B BREAKER BOX

COMMENTS


1) Hoffman box size 48" x 36" x 12" (NEMA Type 12 single door enclosure) gage #14



- 2) Box is wall-mount and is rigidly supported. Light wt. breakers are mounted on  $1/8"$  thick plate which is bolted to the back of the panel with  $8-1/2"$  welded studs.  $\rightarrow f > 8 \text{ Hz}$   
 (Also, per EPRI Report TR-102180 the lowest natural frequency of wall-mount distribution panels from test results indicate  $f > 12 \text{ Hz}$ )
- 3) Flex conduit w/ adequate flexibility. Top entry rigid conduit supported from wall. Relative displacement between the conduit & the box =  $0"$   $\rightarrow$  flexibility ok

Evaluated by: Fazli Bej  
John O. Dixon

Date: 9-18-95  
9/21/95





JOB NO. 50147 JOB TVA / BEND A-46 / IPEEE BY F. Reis DATE 9-19-99  
 CALC. NO. N/A SUBJECT Attachment to SEWS for 3-Box-253-762 CHK'D J. P. D. DATE 9/21/99  
 (SSEL 39051)

## 4) Anchorage Evaluation:

NEMA Type 12  
Typically gage 14 (Hoffman single door enclosure)

$$wt. = 3.0 \times \frac{490}{12^3} \times 0.7854 \left[ (48 \times 36) + (36 \times 12) + (48 \times 12) \right] = 365 \#$$

↳ conservative

Conservatively use peak accelerations @ RB, EL. 639' (for bonding purposes)

↳ Factor to account for Med. ctr. spectra

$$a_h = 2.48 g \rightarrow F_h = 2.48 g \times 1.25 \times 365 \# = 1132. \#$$

$$a_v = 0.73 g \rightarrow F_v = 0.73 g \times 1.25 \times 365 \# = 333. \#$$

$$T = \left[ \left( \frac{1132}{6} \right)^2 + \left( \frac{1132 \times 8}{36 \times 2} \right)^2 + \left( \frac{333 \times 8}{50 \times 3} \right)^2 \right]^{1/2} + \frac{365 \times 8}{50 \times 3}$$

$$= 247 \#$$

$$V = \left[ \left( \frac{1132}{6} \right)^2 + \left( \frac{333}{6} \right)^2 \right]^{1/2} + \frac{365}{6} = 257. \#$$

For  $3/8" \phi$  H/LT7 :

↳ Reduction factor for presence of relays, used here for bonding purposes

$$T_{all} = 1.46 \times \frac{3600}{4000} \times 0.75 = 0.986$$

$$V_{all} = 1.42 \times 0.75 = 1.065 \rightarrow \frac{V}{V_{all}} = \frac{257}{1065} = 0.24 < 0.3 \quad \text{ok}$$

$$\frac{T}{T_{all}} = \frac{247}{986} = 0.25 < 1.0 \quad \text{ok}$$


For  $3/8" \phi$  Unistrut bolts

$$T' = \left[ \left( \frac{1132}{4} \right)^2 + \left( \frac{1132 \times 8}{30 \times 2} \right)^2 + \left( \frac{333 \times 8}{50 \times 2} \right)^2 \right]^{1/2} + \frac{365 \times 8}{50 \times 2} = 351 \# < T_{all}' = 1000 \# \text{ (Ref. Unistrut Catal no. 12)}$$

$$V' = \frac{1132}{4} = 283 \# \text{ (slip)} < V_{all}' = 800 \# \text{ (Ref. " )}$$

∴ Anchorage adequate

(Also Calc. CD-Q 3253-900448, Rev. 1 conservatively qualifies the anchorage config. of this box.)



SSEL Line No. 39051

Status  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 3-JBOX-253-7162 Equip. Class 14 - Distribution Panels

Equipment Description I&C BUS 3B BREAKER BOX

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U  N/A

2. Are essential relays required to function during earthquake screened out? Y N U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y N U  N/A

Requirements for relays satisfied?  N  U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: Fazli Beigi

Date: 9-18-95

Evaluated by: Edm O. Dixon

Date: 9/21/95



INSTRUMENTATION LOOP

ASSEL Line No. 33055

Status Y N U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 2.5

S&E PANEL 9-3

Equip. ID No. 3-XR-64-159 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description TORUS LEVEL AND DRYWELL PRESSURE INSTRUMENT

Location: Bldg. CB Floor El. 617 Room, Row/Col \_\_\_\_\_

Manufacturer, Model, Etc. (optional but recommended) \_\_\_\_\_

SEISMIC CAPACITY VS DEMAND

- |  |      |   |   |     |
|--|------|---|---|-----|
| 1. Elevation where equipment receives seismic input      | Y    | N | U |     |
| 2. Elevation of seismic input below about 40' from grade | Y    | N | U |     |
| 3. Equipment has fundamental frequency above about 8 Hz  | Y    | N | U | N/A |
| 4. Capacity based on:                                    | DOC  |   |   |     |
| Existing Documentation                                   | BS   |   |   |     |
| Bounding Spectrum  | ABS  |   |   |     |
| 1.5 x Bounding Spectrum                                  | GERS |   |   |     |
| GERS   | GRS  |   |   |     |
| 5. Demand based on:                                      | GRS  |   |   |     |
| Ground Response Spectrum                                 | AGS  |   |   |     |
| 1.5 x Ground Response Spectrum                           | CRS  |   |   |     |
| Conserv. Des. In-Str. Resp. Spec.                        | RRS  |   |   |     |
| Realistic M-Ctr. In-Str. Resp. Spec.                     |      |   |   |     |

Does capacity exceed demand? (Indicate at right (\*)) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.) Y N U

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |   |   |   |     |
|--|---|---|---|-----|
| 1. Equipment is included in earthquake experience equipment class  | Y | N | U | N/A |
| 2. No computers or programmable controllers  | Y | N | U | N/A |
| 3. No strip chart recorders  | Y | N | U | N/A |
| 4. Steel frame and sheet metal structurally adequate   | Y | N | U | N/A |
| 5. Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays | Y | N | U | N/A |
| 6. Drawers and equipment on slides restrained from falling out   | Y | N | U | N/A |
| 7. All doors secured by latch or fastener  | Y | N | U | N/A |
| 8. Attached lines have adequate flexibility  | Y | N | U | N/A |
| 9. Anchorage adequate (See checklist below for details)  | Y | N | U | N/A |
| 10. Relays mounted on equipment evaluated  | Y | N | U | N/A |
| 11. Have you looked for and found no other adverse concerns?   | Y | N | U | N/A |

Is the intent of all the caveats met for Bounding Spectrum? Y N U N/A

ANCHORAGE

- |  |   |   |   |     |
|--|---|---|---|-----|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation) | Y | N | U | N/A |
| 2. Type of anchorage covered by GIP  | Y | N | U | N/A |
| 3. Sizes and locations of anchors determined   | Y | N | U | N/A |





SSEL Line No. 33055

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 2 of 25

Equip. ID No. 3-XR-64-159 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description TORUS LEVEL AND DRYWELL PRESSURE INSTRUMENT

ANCHORAGE (Cont'd)

- |  |   |   |   |       |
|--|---|---|---|-------|
| 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness  | Y | N | U | N/A   |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | Y | N | U | N/A   |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | Y | N | U | N/A   |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | Y | N | U | N/A   |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | Y | N | U | N/A   |
| 9. Strength of equipment base and load path to CG adequate   | Y | N | U | N/A   |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | Y | N | U | N/A   |
| Are anchorage requirements met?  |   |   |   | Y N U |

INTERACTION EFFECTS

- |   |   |   |   |       |
|---|---|---|---|-------|
| 1. Soft targets free from impact by nearby equipment or structures  | Y | N | U | N/A   |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | Y | N | U | N/A   |
| 3. Attached lines have adequate flexibility   | Y | N | U | N/A   |
| 4. Overhead equipment or distribution systems are not likely to collapse                                    | Y | N | U | N/A   |
| 5. Have you looked for and found no other adverse concerns?   | Y | N | U | N/A   |
| Is equipment free of interaction effects?   |   |   |   | Y N U |

IS EQUIPMENT SEISMICALLY ADEQUATE?

Y N U

COMMENTS

1. SEE SEWS FOR 2-XR-64-159 (SSEL # 3057)
2. FOR EVALUATION OF THIS COMPONENT SEE SSEL # 39115. QUALIFIED BY "RULE OF THE BOX."

Evaluated by:

J.R. NISSER  
[Signature]

Date:

10/17/95  
10-17-95



33055A

Revision 2, Corrected, 6/28/91  
Status Y N U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet ~~1 of 3~~ 3 OF 5

Equip. ID No. 3-LT-64-159B Equip. Class 18 - Instruments on Racks

Equipment Description TORUS LEVEL TRANSMITTER

Location: Bldg. RB Floor El. 579 Room, Row/Col TORUS ROOM

Manufacturer, Model, Etc. (optional) ROSEMOUNT

SEISMIC CAPACITY VS DEMAND

- |  |                  |
|--|------------------|
| 1. Elevation where equipment receives seismic input      | <u>Y</u> N U     |
| 2. Elevation of seismic input below about 40' from grade | <u>Y</u> N U     |
| 3. Equipment has fundamental frequency above about 8 Hz  | <u>Y</u> N U N/A |
| 4. Capacity based on: Existing Documentation             | DOC              |
| Bounding Spectrum  | <u>BS</u>        |
| GERS   | GERS             |
| 5. Demand based on: Ground Response Spectrum             | <u>GRS</u>       |
| 1.5 x Bounding Spectrum                                  | ABS              |
| Conserv. Des. In-Str. Resp. Spec.                        | CRS              |
| Realistic M-Ctr. In-Str. Resp. Spec.                     | RRS              |

523

Does capacity exceed demand?

Y N U

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |  |
|--|--|
| 1. Equipment is included in earthquake experience equipment class  | <u>Y</u> N U N/A                       |
| 2. No computers or programmable controllers  | <u>Y</u> N U N/A                       |
| 3. Steel frame and sheet metal structurally adequate   | <u>Y</u> N U N/A NOTE ①                |
| 4. Adjacent racks which are close enough to impact or sections of multi-bay racks are bolted together if they contain essential relays | Y N U <u>N/A</u>                       |
| 5. Natural frequency relative to 8 Hz limit considered   | <u>Y</u> N U N/A                       |
| 6. Attached lines have adequate flexibility  | <u>Y</u> N U N/A FLEX OK $\frac{1}{4}$ |
| 7. Anchorage adequate (See checklist below for details)  | <u>Y</u> N U N/A                       |
| 8. Relays mounted on equipment evaluated   | <u>Y</u> N U <u>N/A</u>                |
| 9. Have you looked for and found no other adverse concerns?  | <u>Y</u> N U N/A                       |

Is the intent of all the caveats met for Bounding Spectrum?

Y N U N/A

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |   |                  |
|---|------------------|
| 1. Equipment is included in the generic seismic testing equipment class | Y N U <u>N/A</u> |
| 2. Meets all Bounding Spectrum caveats                                  | Y N U <u>N/A</u> |
| 3. Component is a pressure, temperature, level or flow transmitter      | Y N U <u>N/A</u> |



SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2, Corrected, 6/28/91  
 Sheet ~~2 of 3~~ 4 of 5

Equip. ID No. 3-LT-64-159B Equip. Class 18 - Instruments on Racks

Equipment Description TORUS LEVEL TRANSMITTER

CAVEATS - GERS (Cont'd)

4. Component is one of the specific makes and models tested, as listed in Appendix B
5. Necessary function of component not sensitive to seismically induced system perturbations (e.g., sloshing)
6. No vacuum tubes
7. All external mounting bolts in place
8. Demand based on amplified portion of 3% damped floor response spectrum if estimated natural frequency of rack less than 33 Hz
9. Rack capable of structurally transferring GERS level seismic loads to anchorage

Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A

Is the intent of all the caveats met for GERS?

Y N U N/A

ANCHORAGE

1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)
2. Type of anchorage covered by GIP
3. Sizes and locations of anchors determined
4. Adequacy of anchorage installation evaluated (weld quality and length, nuts and washers, expansion anchor tightness, etc.)
5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking
6. For bolted anchorages, gap under base less than 1/4-inch
7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors
8. Base has adequate stiffness and effect of prying action on anchors considered
9. Strength of equipment base and load path to CG adequate
10. Embedded steel, grout pad or large concrete pad adequacy evaluated

Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A


Are anchorage requirements met?

Y N U N/A

INTERACTION EFFECTS

1. Soft targets free from impact by nearby equipment or structures
2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures
- Attached lines have adequate flexibility

Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A



SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2, Corrected, 6/28/91  
Sheet ~~3 of 3~~ 5 OF 5

Equip. ID No. 3-LT-64-159B Equip. Class 18 - Instruments on Racks

Equipment Description TRUS LEVEL TRANSMITTER

INTERACTION EFFECTS (Cont'd)

- 4. Overhead equipment or distribution systems are not likely to collapse
- 5. Have you looked for and found no other adverse concerns?  
Is equipment free of interaction effects?

<input checked="" type="radio"/>	N	U	N/A
<input checked="" type="radio"/>	N	U	N/A
	<input checked="" type="radio"/>	N	U
	<input checked="" type="radio"/>	N	U

IS EQUIPMENT SEISMICALLY ADEQUATE?

COMMENTS

① MOUNTING & ANCHORAGE OK BY TUG TEST  
LIGHT WEIGHT, WALL MOUNTED.

Evaluated by:

[Signature] J.R. Disser

Date:

10/13/95  
10-13-95





SEL Line No. 33055 A

Status  Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

SEE PART 9-3

3-LT-64-159B

Equip. ID No. 3-XR-64-159 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description TORUS LEVEL AND DRYWELL PRESSURE INSTRUMENT

THIS FORM APPLIES TO 3-LT-64-159B ONLY.

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U  N/A

2. Are essential relays required to function during earthquake screened out? Y N U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y N U  N/A

Requirements for relays satisfied?  Y  N  U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: [Signature]

Date: 9-15-95

Evaluated by: [Signature]

Date: 9-15-95



SEL Line No. 33055

Status  Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 3-XR-04-159 Equip. Class 20

Equipment Description \_\_\_\_\_

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U N/A

2. Are essential relays required to function during earthquake screened out? Y N U N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays, for later analysis.

3. No other relay concerns? Y N U N/A

Requirements for relays satisfied? Y N U

SYSTEM INTERACTION EFFECTS

4. No potential sources could flood or spill onto cabinet? Y N U N/A

SCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

SEE THE SEWS FOR SSEL # 39115  
FOR THE EVALUATION OF THIS COMPONENT

EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?

YES  NO

EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: J.R. Dissanayake

Date: 10/20/95

Evaluated by: John O. Dizon

Date: 10/20/95



INSTRUMENTATION LOOP

SSEL Line No. 3057  
3069

Status Y N U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 27

SEE PANEL 9-3

Equip. ID No. 2-XR-64-159 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description TORUS LEVEL INSTRUMENT

Location: Bldg. CR Floor El. 617 Room, Row/Col \_\_\_\_\_

Manufacturer, Model, Etc. (optional but recommended) \_\_\_\_\_

SEISMIC CAPACITY VS DEMAND

- |  |      |   |   |     |
|--|------|---|---|-----|
| 1. Elevation where equipment receives seismic input      | Y    | N | U |     |
| 2. Elevation of seismic input below about 40' from grade | Y    | N | U | N/A |
| 3. Equipment has fundamental frequency above about 8 Hz  | DOC  |   |   |     |
| 4. Capacity based on:                                    | BS   |   |   |     |
| Existing Documentation                                   | ABS  |   |   |     |
| Bounding Spectrum  | GERS |   |   |     |
| 1.5 x Bounding Spectrum                                  | GRS  |   |   |     |
| GERS   | AGS  |   |   |     |
| 5. Demand based on:                                      | CRS  |   |   |     |
| Ground Response Spectrum                                 | RRS  |   |   |     |
| 1.5 x Ground Response Spectrum                           |      |   |   |     |
| Conserv. Des. In-Str. Resp. Spec.                        |      |   |   |     |
| Realistic M-Ctr. In-Str. Resp. Spec.                     |      |   |   |     |

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.) Y N U

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |   |   |   |     |
|--|---|---|---|-----|
| 1. Equipment is included in earthquake experience equipment class  | Y | N | U | N/A |
| 2. No computers or programmable controllers  | Y | N | U | N/A |
| 3. No strip chart recorders  | Y | N | U | N/A |
| 4. Steel frame and sheet metal structurally adequate   | Y | N | U | N/A |
| 5. Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays | Y | N | U | N/A |
| 6. Drawers and equipment on slides restrained from falling out   | Y | N | U | N/A |
| 7. All doors secured by latch or fastener  | Y | N | U | N/A |
| 8. Attached lines have adequate flexibility  | Y | N | U | N/A |
| 9. Anchorage adequate (See checklist below for details)  | Y | N | U | N/A |
| 10. Relays mounted on equipment evaluated  | Y | N | U | N/A |
| 11. Have you looked for and found no other adverse concerns?   | Y | N | U | N/A |
- Is the intent of all the caveats met for Bounding Spectrum? Y N U N/A

ANCHORAGE

- |  |   |   |   |     |
|--|---|---|---|-----|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation) | Y | N | U | N/A |
| 2. Type of anchorage covered by GIP  | Y | N | U | N/A |
| 3. Sizes and locations of anchors determined   | Y | N | U | N/A |



SSEL Line No. 3057  
3069

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 2 of 27

Equip. ID No. 2-XR-64-159 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description TORUS LEVEL INSTRUMENT

ANCHORAGE (Cont'd)

- 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness Y N U N/A
  - 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking Y N U N/A
  - 6. For bolted anchorages, gap under base less than 1/4-inch Y N U N/A
  - 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors Y N U N/A
  - 8. Base has adequate stiffness and effect of prying action on anchors considered Y N U N/A
  - 9. Strength of equipment base and load path to CG adequate Y N U N/A
  - 10. Embedded steel, grout pad or large concrete pad adequacy evaluated Y N U N/A
- Are anchorage requirements met? Y N U

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures Y N U N/A
  - 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures Y N U N/A
  - 3. Attached lines have adequate flexibility Y N U N/A
  - 4. Overhead equipment or distribution systems are not likely to collapse Y N U N/A
  - 5. Have you looked for and found no other adverse concerns? Y N U N/A
- Is equipment free of interaction effects? Y N U

IS EQUIPMENT SEISMICALLY ADEQUATE?


Y N U

COMMENTS

- 1. FOR INSTRUMENTATION LOOP SCHEMATIC SEE PAGES 6 & 7. ALL COMPONENTS ARE QUALIFIED BY THE SEWS FOR THEIR SUPPORTING RACK OR PANEL OR BY THE SEWS FOR THE INDIVIDUAL COMPONENTS
- 2. Z-LT-64-159B IS QUALIFIED ON PAGES 3, 4 & 5 OF THIS SEWS.

Evaluated by: J.R. Sissler Date: 10/17/95  
10-17-95

3. FOR THE EVALUATION OF THIS COMPONENT SEE THE SEWS FOR SSEL LINE NOS. 9040/9041. QUALIFIED BY "RULE OF THE BOX".





SSRL # 3057A

Revision 2, Corrected, 6/28/91

Status Y N U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet <sup>3</sup> ~~1~~ of <sup>7</sup> ~~3~~

Equip. ID No. 2-LT-64-159B Equip. Class 18 - Instruments on Racks

Equipment Description TOWS LEVEL INSTRUMENT (TRANSMITTER)

Location: Bldg. TOWS Floor Et. 519 Room, Row/Col \_\_\_\_\_

Manufacturer, Model, Etc. (optional) ROSEMOUNT

SEISMIC CAPACITY VS DEMAND

- |  |                  |
|--|------------------|
| 1. Elevation where equipment receives seismic input      | <u>523</u>       |
| 2. Elevation of seismic input below about 40' from grade | <u>Y</u> N U     |
| 3. Equipment has fundamental frequency above about 8 Hz  | <u>Y</u> N U N/A |
| 4. Capacity based on:                                    |                  |
| Existing Documentation                                   | DOC              |
| Bounding Spectrum  | <u>BS</u>        |
| GERS   | GERS             |
| 5. Demand based on:                                      |                  |
| Ground Response Spectrum                                 | <u>GRS</u>       |
| 1.5 x Bounding Spectrum                                  | ABS              |
| Conserv. Des. In-Str. Resp. Spec.                        | CRS              |
| Realistic M-Ctr. In-Str. Resp. Spec.                     | RRS              |

Does capacity exceed demand?

Y N U

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)


- |  |                                 |
|--|---------------------------------|
| 1. Equipment is included in earthquake experience equipment class  | <u>Y</u> N U N/A                |
| 2. No computers or programmable controllers  | <u>Y</u> N U N/A                |
| 3. Steel frame and sheet metal structurally adequate   | <u>Y</u> N U N/A                |
| 4. Adjacent racks which are close enough to impact or sections of multi-bay racks are bolted together if they contain essential relays | <u>Y</u> N U N/A <u>NOTE</u>    |
| 5. Natural frequency relative to 8 Hz limit considered   | <u>Y</u> N U <u>N/A</u>         |
| 6. Attached lines have adequate flexibility  | <u>Y</u> N U N/A <u>REF. OK</u> |
| 7. Anchorage adequate (See checklist below for details)  | <u>Y</u> N U N/A                |
| 8. Relays mounted on equipment evaluated   | <u>Y</u> N U <u>N/A</u>         |
| 9. Have you looked for and found no other adverse concerns?  | <u>Y</u> N U N/A                |

Is the intent of all the caveats met for Bounding Spectrum?

Y N U N/A

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |   |                         |
|---|-------------------------|
| 1. Equipment is included in the generic seismic testing equipment class | <u>Y</u> N U <u>N/A</u> |
| 2. Meets all Bounding Spectrum caveats                                  | <u>Y</u> N U <u>N/A</u> |
| 3. Component is a pressure, temperature, level or flow transmitter      | <u>Y</u> N U <u>N/A</u> |



SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2, Corrected, 6/28/91  
Sheet 2 of 37  
4

Equip. ID No. 2-LT-64-159B Equip. Class 18 - Instruments on Racks

Equipment Description TORUS LEVEL TRANSMITTER

CAVEATS - GERS (Cont'd)

- |  |   |   |   |     |
|--|---|---|---|-----|
| 4. Component is one of the specific makes and models tested, as listed in Appendix B   | Y | N | U | N/A |
| 5. Necessary function of component not sensitive to seismically induced system perturbations (e.g., sloshing)                    | Y | N | U | N/A |
| 6. No vacuum tubes   | Y | N | U | N/A |
| 7. All external mounting bolts in place  | Y | N | U | N/A |
| 8. Demand based on amplified portion of 3% damped floor response spectrum if estimated natural frequency of rack less than 33 Hz | Y | N | U | N/A |
| 9. Rack capable of structurally transferring GERS level seismic loads to anchorage   | Y | N | U | N/A |

Is the intent of all the caveats met for GERS? Y N U N/A

ANCHORAGE

- |  |          |   |   |            |
|--|----------|---|---|------------|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)   | <u>Y</u> | N | U | N/A        |
| 2. Type of anchorage covered by GIP  | <u>Y</u> | N | U | N/A        |
| Sizes and locations of anchors determined  | <u>Y</u> | N | U | N/A        |
| Adequacy of anchorage installation evaluated (weld quality and length, nuts and washers, expansion anchor tightness, etc.)   | <u>Y</u> | N | U | N/A        |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | <u>Y</u> | N | U | N/A        |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | <u>Y</u> | N | U | N/A        |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | Y        | N | U | <u>N/A</u> |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | <u>Y</u> | N | U | N/A        |
| 9. Strength of equipment base and load path to CG adequate   | <u>Y</u> | N | U | N/A        |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | Y        | N | U | <u>N/A</u> |

Are anchorage requirements met? Y N U N/A Y N U NSTR 1

INTERACTION EFFECTS

- |   |          |   |   |            |
|---|----------|---|---|------------|
| 1. Soft targets free from impact by nearby equipment or structures  | <u>Y</u> | N | U | N/A        |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | Y        | N | U | <u>N/A</u> |
| Attached lines have adequate flexibility  | <u>Y</u> | N | U | N/A        |



SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2, Corrected, 6/28/91

Sheet 3 of 3  
5 7

Equip. ID No. 2-LT-64-159B Equip. Class 18 - Instruments on Racks

Equipment Description TORUS LEVEL TRANSMITTER

INTERACTION EFFECTS (Cont'd)

4. Overhead equipment or distribution systems are not likely to collapse

5. Have you looked for and found no other adverse concerns?

Is equipment free of interaction effects?

N U N/A  
 N U N/A  
 Y N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

Y N U

COMMENTS

① MOUNTING & ANCHORAGE ~~OK~~ BY TUG TEST ;  
LIGHTWEIGHT, WALL MOUNTED

Evaluated by:

[Signature]  
G.D. Augustin


Date:

9-14-95

7-14-95




2-PNLA-009-0009 CAB 3  
SEWS (9045)




2-PNLA-009-0043  
SEWS (9063)



2-LPNA-925-006A  
SEWS (9184) 9187




No LOCAL PANEL }




SEE SEWS FOR 3057

2-PNLA-009-0019  
SEWS (9049)



2-PNLA-009-0003  
SEWS (9040, 9041)




UNIT 2 : I&C BUS B POWER SUPPLIES







3-PNLA-009-0009 CAB 3  
SEWS (39054, 39119)




3-PNLA-009-0043  
SEWS (39132)



3-LPNA-925-006A  
SEWS (39198)




No LOCAL PANEL }




SEE  
SEWS FOR  
33055

3-PNLA-009-0019  
SEWS (39124)



3-PNLA-009-0003  
SEWS (39115)



UNIT 3: I&C BUS B POWER SUPPLIES

DONE

\*... 39046 IS CURRENTLY ID = 3-PX-64-15  
THIS WILL BE REVISED TO 3-PX-64-160!  
(LOCATION: PNL 9-19)



SSEL Line No. 3069

3057

Status  Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

SEE PANEL 9.3

2-LT-64-159B

Equip. ID No. 2-XR-64-159 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description TORUS LEVEL INSTRUMENTS

THIS FORM APPLIES TO 2-LT-64-159B

RELAY WALKDOWN

ONLY.

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U  N/A

2. Are essential relays required to function during earthquake screened out? Y N U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y N U  N/A

Requirements for relays satisfied?  Y  N  U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: [Signature]

Date: 9-14-95

Evaluated by: [Signature]

Date: 9-14-95



SSEL Line No. 3057  
AI

Status Y N U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2XR-64-159 Equip. Class 20

Equipment Description \_\_\_\_\_

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U N/A

2. Are essential relays required to function during earthquake screened out? Y N U N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays, for later analysis.

3. No other relay concerns? Y N U N/A

Requirements for relays satisfied? Y N U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet? Y N U N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

SEE THE SEWS FOR SSEL # 9040/9041  
FOR THE EVALUATION OF THIS COMPONENT

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?  
YES \_\_\_ NO \_\_\_

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES \_\_\_ NO \_\_\_

Evaluated by: J.R. Dissler

Date: 10/20/95

Evaluated by: John D. Dizon

Date: 10/20/95



SSEL Line No. 39115

Status Y (N) U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 2

Equip. ID No. 3-PNLA-009-0003 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description REACTOR SD & CONT. COOLING PNL

Location: Bldg. CB Floor El. 621 Room, Row/Col U3 MCR

Manufacturer, Model, Etc. (optional but recommended) GE

SEISMIC CAPACITY VS DEMAND

- Elevation where equipment receives seismic input
- Elevation of seismic input below about 40' from grade
- Equipment has fundamental frequency above about 8 Hz
- Capacity based on: Existing Documentation  
Bounding Spectrum  
1.5 x Bounding Spectrum  
GERS
- Demand based on: Ground Response Spectrum  
1.5 x Ground Response Spectrum  
Conserv. Des. In-Str. Resp. Spec.  
Realistic M-Ctr. In-Str. Resp. Spec.

G17'  
 Y (N) U (grade @ 563)  
 Y N U N/A (1)  
 DOC  
 BS  
 ABS  
 GERS  
 GRS  
 AGS  
 CRS  
 RRS

Does capacity exceed demand? (Indicate at right (\*) and in-  
COMMENTS if a special exception to enveloping of seismic  
 demand spectrum is invoked per Section 4.2 of the GIP.)

Y N U (2)\*

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which  
 are met by intent without meeting the specific wording of the caveat rule and  
 explain the reason for this conclusion in the COMMENTS section below)

- Equipment is included in earthquake experience equipment class
- No computers or programmable controllers
- No strip chart recorders
- Steel frame and sheet metal structurally adequate
- Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays
- Drawers and equipment on slides restrained from falling out
- All doors secured by latch or fastener
- Attached lines have adequate flexibility
- Anchorage adequate (See checklist below for details)
- Relays mounted on equipment evaluated AMP F = 4.5
- Have you looked for and found no other adverse concerns?

Y N U N/A  
 Y N U N/A (2)  
 Y N U N/A (2)  
 Y N U N/A (3)  
 Y (N) U N/A (10)  
 Y N U N/A (8)  
 Y N U N/A (5)  
 Y N U N/A  
 Y N U N/A (1)  
 Y N U N/A (9)  
 Y N U N/A

Is the intent of all the caveats met for Bounding Spectrum?

Y N U N/A

ANCHORAGE

- Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)
- Type of anchorage covered by GIP
- Sizes and locations of anchors determined

Y N U N/A (1)  
 Y N U N/A  
 Y N U N/A





Equip. ID No. 3-PNLA-009-0003 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description REACTOR SD & CONT. COOLING PNL

ANCHORAGE (Cont'd)

- 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness (Y) N U N/A
- 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking (Y) N U N/A
- 6. For bolted anchorages, gap under base less than 1/4-inch Y N U (N/A)
- 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors (Y) N U N/A
- 8. Base has adequate stiffness and effect of prying action on anchors considered (Y) N U N/A
- 9. Strength of equipment base and load path to CG adequate (Y) N U N/A
- 10. Embedded steel, grout pad or large concrete pad adequacy evaluated (Y) N U N/A

Are anchorage requirements met? (Y) N U (C)

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures (Y) N U N/A (C)
- 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures (Y) N U N/A
- 3. Attached lines have adequate flexibility (Y) N U N/A
- 4. Overhead equipment or distribution systems are not likely to collapse (Y) N U N/A
- 5. Have you looked for and found no other adverse concerns? (Y) N U N/A

Is equipment free of interaction effects? (Y) N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

(Y) N U (C)


COMMENTS

For Notes 1-3, 5, 6, 8-9 see the corresponding notes on SEWS for 2-PNLA-009-0003A (SSEL 9040)  
Notes 4 & 7 not used.

Evaluated by: Farsi Baij  
H. O. Dizon

Date: 11-27-95  
11/28/95

(10) All adjacent bench board panels are bolted together by 1/2" to 5/8" bolts. However, between panels 9-3 and 9-2, only one bolt is present (bottom) at the rear. The upper 3 bolts are all missing -> Outlier #39115. JOD 4/19/96  
A. #191



IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 3-PNLA-009-0003 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description REACTOR SD & CONT. COOLING PNL

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?  Y  N  U  N/A

2. Are essential relays required to function during earthquake screened out? Y  N  U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y  N  U  N/A

Requirements for relays satisfied?

Y  N  U  (1)

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

1. See OSVS # 39115 for relay chatter concern

Job 4/19/96  
4/19/96

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?

YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO  (1)

Evaluated by: Farsi Beigi

Date: 11-27-95

Evaluated by: John O. Dizon

Date: 1/28/95



OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number 3-PNLA-009-0003 Equipment Class 20  
 Equipment Location: Bldg. CB Floor Elevation 617'  
 Room or Row/Column Unit 3 MCR Base Elevation 617'  
 Equipment Description Panel 3-9-3

2. OUTLIER ISSUE DEFINITION

a. Identify all the screening guidelines which are not met.  
 (Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>	_____	<u>Tanks and Heat Exchangers</u>	_____
Capacity vs. Demand	_____	Shell Buckling*	_____
Caveats	<input checked="" type="checkbox"/>	Anchor Bolts and Embedment	_____
Anchorage	_____	Anchorage Connections	_____
Seismic Interaction	_____	Flexibility of Attached Piping*	_____
Other	_____	Other	_____
<u>Essential Relays</u>	_____	<u>Cable and Conduit Raceways</u>	_____
Capacity vs. Demand	_____	Inclusion Rules	_____
Mounting, Type, Location	_____	Other Seismic Performance Concerns	_____
Other	<input checked="" type="checkbox"/>	Limited Analytical Review	_____
		Other	_____

\* Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

At the interface between Panels 3-9-2 and 3-9-3, the upper 3 bolts connecting the two panels are missing in the rear, thus, may cause relay chatter in the event of an earthquake. Only the bottom bolt is present. Panels are connected at top + bottom in front.



OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number 3-PNLA-009-0003

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

Install a connection bolt at the top rear corner between Panels 3-9-2 + 3-9-3, or verify that there are no essential relays in Panel 3-9-3.

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

John O. Dizon, PE  
Print or Type Name

John O. Dizon  
Signature

4/19/96  
Date

J. R. Disser  
Print or Type Name

[Signature]  
Signature

4/19/96  
Date

\_\_\_\_\_  
Print or Type Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

*2/23/91*  
*Jul floor 2-23-91*  
*REVIEW OF THE ESSENTIAL RELAYS LIST INDICATES NO ESSENTIAL RELAYS ARE PRESENT IN 3-PNLA-009-003. THEREFORE, OSVS 39115 IS RESOLVED.*





**ATTACHMENT 11**



SSEL Line No. 9028

Status  N U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 24

Equip. ID No. 2-BDBB-268-0002E Equip. Class 01 - Motor Control Centers

Equipment Description 480V RMOV BD 2E

Location: Bldg. RB Floor El. 621'-3" Room, Row/Col U-R8

Manufacturer, Model, Etc. (optional but recommended) International Switchboard Corp

SEISMIC CAPACITY VS DEMAND

- |  |  |
|--|--|
| 1. Elevation where equipment receives seismic input      | <u>621'-3"</u>   |
| 2. Elevation of seismic input below about 40' from grade | <input checked="" type="radio"/> <input checked="" type="radio"/> U (grade @ 563') |
| 3. Equipment has fundamental frequency above about 8 Hz  | <input checked="" type="radio"/> N U N/A (1)                                       |
| 4. Capacity based on: Existing Documentation             | DOC  |
| Bounding Spectrum  | BS   |
| 1.5 x Bounding Spectrum                                  | <input checked="" type="radio"/> ABS   |
| GERS   | GERS   |
| 5. Demand based on: Ground Response Spectrum             | GRS  |
| 1.5 x Ground Response Spectrum                           | AGS  |
| Conserv. Des. In-Str. Resp. Spec.                        | CRS  |
| Realistic M-Ctr. In-Str. Resp. Spec.                     | <input checked="" type="radio"/> RRS   |

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)  N U (2) \*

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |  |
|--|--|
| 1. Equipment is included in earthquake experience equipment class  | <input checked="" type="radio"/> N U N/A           |
| 2. 600 V rating or less  | <input checked="" type="radio"/> N U N/A           |
| 3. Adjacent cabinets which are close enough to impact, or sections of multi-bay cabinets, are bolted together if they contain essential relays | <input checked="" type="radio"/> N U N/A (4), (12) |
| 4. Attached weight (except conduit) less than about 100 lbs per cabinet assembly   | <input checked="" type="radio"/> N U N/A           |
| 5. Externally attached items rigidly anchored  | <input checked="" type="radio"/> N U N/A           |
| 6. General configuration similar to NEMA Standards   | <input checked="" type="radio"/> N U N/A           |
| 7. Cutouts in lower half less than 6 in. wide and 12 in. high  | <input checked="" type="radio"/> N U N/A           |
| 8. All doors secured by latch or fastener  | <input checked="" type="radio"/> N U N/A           |
| 9. Natural frequency relative to 8 Hz limit considered   | <input checked="" type="radio"/> N U N/A (7), (11) |
| 10. Anchorage adequate (See checklist below for details)   | <input checked="" type="radio"/> N U N/A (3), (6)  |
| 11. Relays mounted on equipment evaluated $A_F=3.0$  | <input checked="" type="radio"/> N U N/A           |
| 12. Have you looked for and found no other adverse concerns? the intent of all the caveats met for Bounding Spectrum?                          | <input checked="" type="radio"/> N U N/A           |



ASSEL Line No. 9028

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 2 of 34

Equip. ID No. 2-80BB-268-0002E Equip. Class 01 - Motor Control Centers

Equipment Description 480V RMOV BD 2E

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

1. Equipment is included in generic seismic testing equipment class
2. Meets all Bounding Spectrum caveats
3. Floor mounted cabinet
4. Maximum weight per section less than 800 pounds
5. Base anchorage utilizing MCC base channels
6. Adequate strength and stiffness in load transfer path from anchorage to base frame (only for "function after" GERS)
7. Essential relays have GERS > 4.5g (only for "function during" GERS)
8. Able to reset starters (only for "function after" GERS)
9. All adjacent cabinets or sections of multi-bay assemblies bolted together

Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A

Is the intent of all the caveats met for GERS?

Y N U (N/A)

ANCHORAGE

1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)
2. Type of anchorage covered by GIP
3. Sizes and locations of anchors determined
4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness
5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking
6. For bolted anchorages, gap under base less than 1/4-inch
7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors
8. Base has adequate stiffness and effect of prying action on anchors considered
9. Strength of equipment base and load path to CG adequate
10. Embedded steel, grout pad or large concrete pad adequacy evaluated

<u>(Y)</u>	N	U	N/A(6, 7), (4)
<u>(Y)</u>	N	U	N/A
<u>(Y)</u>	N	U	N/A
<u>(Y)</u>	N	U	N/A
<u>(Y)</u>	N	U	N/A
<u>(Y)</u>	N	U	N/A
<u>(Y)</u>	N	U	N/A
<u>(Y)</u>	N	U	N/A
<u>(Y)</u>	N	U	N/A
<u>(Y)</u>	N	U	N/A

Are anchorage requirements met?

(Y) N U (3), (4)



SEL Line No. 9028

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 3 of 34

Equip. ID No. 2-BDBB-268-0002E Equip. Class 01 - Motor Control Centers

Equipment Description 480V RMOV BD 2E

INTERACTION EFFECTS

- |   |                                    |   |   |          |
|---|------------------------------------|---|---|----------|
| 1. Soft targets free from impact by nearby equipment or structures  | <input checked="" type="radio"/> Y | N | U | N/A      |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | <input checked="" type="radio"/> Y | N | U | N/A      |
| 3. Attached lines have adequate flexibility   | <input checked="" type="radio"/> Y | N | U | N/A (13) |
| 4. Overhead equipment or distribution systems are not likely to collapse                                    | <input checked="" type="radio"/> Y | N | U | N/A (15) |
| 5. Have you looked for and found no other adverse concerns?   | <input checked="" type="radio"/> Y | N | U | N/A      |
- Is equipment free of interaction effects?  Y N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

Y N U

COMMENTS

1) This MCC has 5 bays. The two end bays are 20"x36" (depth) x 90" height and the three middle bays are 20"x20" x 90". These bays are all bolted together. The panel sheet metal thickness is 3/32" and the sidepanels are continuous without any cutouts. The base and internal framing members are L1 1/2 x 1 1/2. Each of the bays are bolted to sill channel by 4-3/8" bolts. Even though no top bracing is provided it is judged that the lowest frequency of this MCC is greater than 8 Hz due to characteristics listed above.

2) per Calc. CD-Q0000-94-339, Figure B.1, the 1st structure spectra @ EL. 621' of RB exceeds the 1.5X bounding spectrum (seismic capacity) in the frequency range of 5.0 to 7 Hz. Since the lowest natural frequency of this MCC is greater than 7 Hz (see note 1) and there are no exceedances above 7 Hz, the intent of the GIP <sup>seismic</sup> Capacity vs. demand criteria is met.


- For notes 3, 4, 6, 7, 9, 10 see SEWS for 3-BDBB-268-0003D (SSEL 39016).
- notes 5 & 8 not used.

Evaluated by:

Ferris Baci  
John O. Dizon

Date:

10-10-95  
10/10/95








JOB NO. 50147 JOB TVA / BENP A-46 / IPEEE BY FRej DATE 10-10-  
 CALC. NO. N/A SUBJECT Attachment to SENS for 2-BDBB-268-0002E CHK'D. J.A. Dizon DATE 10/10/95  
 (SSEL 9028)

SSEL: 9028


ID: 2-BDBB-268-0002E

(DWG. 2-45N390-2, and 48N1125-1)

- 11) only one top entry rigid conduit with a  $\sim 12'$  span to rigid support.  $\rightarrow$  Can not provide adequate top restraint
- 12) 5 bays all bolted together.
- 13) Flex conduit with adequate flexibility. (min. 1" slack @ a 4" flex)
- 14) The base of each bay is made of  $L 1\frac{1}{4} \times 1\frac{1}{4} \times \frac{3}{16}$  which is then bolted to sill channel by 4- $\frac{3}{8}$ "  $\phi$  bolts. The sill channels are welded all along their front to the embedded plate.



- 15) Speaker overhead judged to have adequate anchorage. No interaction ok



SSEL Line No. 9028

Status  Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-BDBB-268-0002E Equip. Class 01 - Motor Control Centers

Equipment Description 480V RMOV BD 2E

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?  Y  N  U  N/A

2. Are essential relays required to function during earthquake screened out?  Y  N  U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns?  Y  N  U  N/A

Requirements for relays satisfied?  Y  N  U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?  
YES  NO


IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: Fazal Bejjani

Date: 10-10-95

Evaluated by: John O. Dizon

Date: 10/10/95



SSEL Line No. 39016

Status Y  N  U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 3/12

Equip. ID No. 3-BDBB-268-0003D Equip. Class 01 - Motor Control Centers

Equipment Description 480V RMOV BOARD 3D

Location: Bldg. U3-RB Floor El. 593 Room, Row/Col U,R17

Manufacturer, Model, Etc. (optional but recommended) International Switchboard Corp.

SEISMIC CAPACITY VS DEMAND


- |   |   |  |
|---|---|--|
| 1 | Elevation where equipment receives seismic input      |  |
| 2 | Elevation of seismic input below about 40' from grade | <input checked="" type="radio"/> N <input type="radio"/> U. (grade @ 563') |
| 3 | Equipment has fundamental frequency above about 8 Hz  | <input checked="" type="radio"/> N <input type="radio"/> U N/A (1)         |
| 4 | Capacity based on: Existing Documentation             | DOC  |
|   | Bounding Spectrum                                     | <input checked="" type="radio"/> BS  |
|   | 1.5 x Bounding Spectrum                               | ABS  |
|   | GERS  | GERS   |
| 5 | Demand based on: Ground Response Spectrum             | <input checked="" type="radio"/> GRS                                       |
|   | 1.5 x Ground Response Spectrum                        | AGS  |
|   | Conserv. Des. In-Str. Resp. Spec.                     | CRS  |
|   | Realistic M-Ctr. In-Str. Resp. Spec.                  | RRS  |

Does capacity exceed demand? (Indicate at right (\*) and in: COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)

N  U  
(Ref. Calc. CD-Q0000-940339)

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |     |   |  |
|-----|---|--|
| 1.  | Equipment is included in earthquake experience equipment class  | <input checked="" type="radio"/> N <input type="radio"/> U N/A           |
| 2.  | 600 V rating or less  | <input checked="" type="radio"/> N <input type="radio"/> U N/A           |
| 3.  | Adjacent cabinets which are close enough to impact, or sections of multi-bay cabinets, are bolted together if they contain essential relays | <input checked="" type="radio"/> N <input type="radio"/> U N/A (4)       |
| 4.  | Attached weight (except conduit) less than about 100 lbs per cabinet assembly   | <input checked="" type="radio"/> N <input type="radio"/> U N/A           |
| 5.  | Externally attached items rigidly anchored  | <input checked="" type="radio"/> N <input type="radio"/> U N/A           |
| 6.  | General configuration similar to NEMA Standards   | <input checked="" type="radio"/> N <input type="radio"/> U N/A           |
| 7.  | Cutouts in lower half less than 6 in. wide and 12 in. high  | <input checked="" type="radio"/> N <input type="radio"/> U N/A           |
| 8.  | All doors secured by latch or fastener  | <input checked="" type="radio"/> N <input type="radio"/> U N/A           |
| 9.  | Natural frequency relative to 8 Hz limit considered   | <input checked="" type="radio"/> N <input type="radio"/> U N/A (9)       |
| 10. | Anchorage adequate (See checklist below for details)  | <input checked="" type="radio"/> N <input type="radio"/> U N/A (3), (10) |
| 11. | Relays mounted on equipment evaluated AF=3.0  | <input checked="" type="radio"/> N <input type="radio"/> U N/A           |
| 12. | Have you looked for and found no other adverse concerns?  | <input checked="" type="radio"/> N <input type="radio"/> U N/A           |
- As the intent of all the caveats met for Bounding Spectrum?  N  U N/A



Equip. ID No. 3-BDBB-268-0003D Equip. Class 01 - Motor Control Centers


Equipment Description 480V RMOV BOARD 3D

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |   |   |   |     |
|--|---|---|---|-----|
| 1. Equipment is included in generic seismic testing equipment class  | Y | N | U | N/A |
| 2. Meets all Bounding Spectrum caveats   | Y | N | U | N/A |
| 3. Floor mounted cabinet   | Y | N | U | N/A |
| 4. Maximum weight per section less than 800 pounds   | Y | N | U | N/A |
| 5. Base anchorage utilizing MCC base channels  | Y | N | U | N/A |
| 6. Adequate strength and stiffness in load transfer path from anchorage to base frame (only for "function after" GERS) | Y | N | U | N/A |
| 7. Essential relays have GERS > 4.5g (only for "function during" GERS)   | Y | N | U | N/A |
| 8. Able to reset starters (only for "function after" GERS)   | Y | N | U | N/A |
| 9. All adjacent cabinets or sections of multi-bay assemblies bolted together   | Y | N | U | N/A |
| Is the intent of all the caveats met for GERS?   | Y | N | U | N/A |

ANCHORAGE

- |  |   |   |   |           |
|--|---|---|---|-----------|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)   | ⓪ | N | U | N/A (6,7) |
| 2. Type of anchorage covered by GIP  | ⓪ | N | U | N/A       |
| 3. Sizes and locations of anchors determined   | ⓪ | N | U | N/A       |
| 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness  | ⓪ | N | U | N/A       |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | ⓪ | N | U | N/A (11)  |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | ⓪ | N | U | N/A       |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | ⓪ | N | U | N/A       |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | ⓪ | N | U | N/A       |
| 9. Strength of equipment base and load path to CG adequate   | ⓪ | N | U | N/A       |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | ⓪ | N | U | N/A (11)  |
| Are anchorage requirements met?  | ⓪ | N | U | (3), (10) |





Equip. ID No. 3-BDBB-268-0003D Equip. Class 01 - Motor Control Centers

Equipment Description 480V RMOV BOARD 3D

INTERACTION EFFECTS

- |   |                                    |                                    |                                 |
|---|------------------------------------|------------------------------------|---------------------------------|
| 1. Soft targets free from impact by nearby equipment or structures  | <input checked="" type="radio"/> N | <input type="radio"/> U            | <input type="radio"/> N/A       |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | <input type="radio"/> Y            | <input checked="" type="radio"/> N | <input type="radio"/> U N/A (8) |
| 3. Attached lines have adequate flexibility   | <input checked="" type="radio"/> Y | <input type="radio"/> N            | <input type="radio"/> U N/A     |
| 4. Overhead equipment or distribution systems are not likely to collapse                                    | <input checked="" type="radio"/> Y | <input type="radio"/> N            | <input type="radio"/> U N/A     |
| 5. Have you looked for and found no other adverse concerns?   | <input checked="" type="radio"/> Y | <input type="radio"/> N            | <input type="radio"/> U N/A     |
- Is equipment free of interaction effects?  Y  N  U (8)
- IS EQUIPMENT SEISMICALLY ADEQUATE?  Y  N  U (8)

COMMENTS

- 1) See note 1 on SEWS for 2-BDBB-268-0002E (SSEL 9028). → f > 8Hz
  - 2) note no. not used.
  - 3) The weak links in the load path to the anchor point are judged to be the 3/8" φ bolts connecting the MCC to the sill channel & the 3/4" φ Red head anchor bolts @ sill. The welds @ sill to 3M<sup>®</sup> are less critical. See Note 10 for anchorage evaluation.
- see pages 4-10 for notes 4-10.
- 11) Some cracks noted on the exterior faces of the tapered grout pad. Judged to be not critical. (see page 11 for bolt bending evaluation)
- JOD 2/23/96  
2/23/96

evaluated by: Fanni Beiri  
John O. Dizon

Date: 10-10-95  
10/10/95






JOB NO. 50147 JOB TVA/BENP A-46/1PREE BY FR DATE 10-10-9  
 CALC. NO. N/A SUBJECT Attachment to SENS for 3-BDBB-268-00033 CHK'D J.D. [Signature] DATE 10/10/95  
 (SSEL 39016)

SSEL 39016

3-BDBB-268-0003D 480V RMOV BD 3D  
 (DWG. 3-45N389 and 48N1125-1)  
 (International Switchboard Corporation)

- 4) 5 bays all bolted together.
- 5) Top restraint not provided by the top entry conduit (3-2 1/2"  $\phi$ , 8-3"  $\phi$ );  
 Conduit span to the first support  $\sim$  12'
- 6) Each bay is bolted to the sill channel by 4-3/8"  $\phi$  bolts. The sill channel is welded to embedment plate which is on a 1 1/2" tapered grout pad.

- 7) The base of each unit consists of L 1 1/2 x 1 1/2 x 1/4 angles and the internal framing consists of L 1 1/2 x 1 1/2 x 3/32 to 1/8 angles and the side panels are continuous (no cutout in the sheet metal between the adjacent bays)



- 8) Long cable tray vertical riser has about 1 1/2" clearance to this equipment. The cable tray is supported by rod hangers ( $\sim$  20' rods) and will swing and impact this equipment.  $\rightarrow$  outlier OSVS-39016  
 (See sketch on the next pg.)
- 9) Breakers in compartments 1D and 5D are type K-600S (Gould Manuf.). These breakers are about 12' above the base of the equipment and are mounted on rails which are connected to a rigid "platform" plate 3/32" thick. The primary and secondary contacts are in the "BD" configuration but there is a grounding bar @ about the C.G. of the breaker which will restrain the breaker from side to side movement





EQE INTERNATIONAL


SHEET NO. 5 of 12

JOB NO. S0147 JOB TVA / REMP A-46 / IPEEE


BY ZRej DATE 10-10-95

CALC. NO. N/A SUBJECT SEWS for 3-BDBB-268-0003D  
(SSEL 39016)

CHK'D D. Diz DATE 10/10/95



Configuration of the Interaction of the  
 18" Cable Tray with MCC  
 (Interaction Documented in Outlier OSVS-39016)







JOB NO. 50147 JOB TVA/BEHP A-46/1PEFF  
 CALC. NO. N/A SUBJECT Attachment to SEWC for 3.8DRR-268.0003D  
 (SSEL 39016)

BY J.R. ... DATE 10-10-  
 CHK'D J.O. ... DATE 10/10/9

10) Anchorage Evaluation :



SILL PLAN  
 (DWG. 48N1125-1)



A-A

- Each bay is bolted to the sill channel by 4-3/8"  $\phi$  bolts:

$$T_{all_1} = 20 \times 1.7 \times 0.11 \text{ (in}^2\text{)} = 3.74^k$$

$$V_{all_1} = 10 \times 1.7 \times 0.11 \text{ (in}^2\text{)} = 1.870^k$$

- Sill channel is anchored by 3/4"  $\phi$  Red heads to the concrete floor:

$$T_{all_2} = 4.69^k \times \frac{3600}{4000} \times 0.75 = 3.166^k < T_{all_1} = 3.74^k$$

Reduction for presence of rebar

$$V_{all_2} = 5.48^k \times 0.75 = 4.11^k > V_{all_1} = 1.87^k$$

$\Rightarrow$  Check with 3/8"  $\phi$  H. bolts and 3/4"  $\phi$  anchor bolts.








JOB NO. 50147 JOB TKA/BENP A-UG/IEEE BY F. Beij DATE 10-10-95  
 CALC. NO. 111A SUBJECT SEWS for 3-BDBB-268-0003D CHK'D. D. D. Zan DATE 10/10/95  
 (SEEL 39016)

Note 10 (cont'd)



Dead wt. of type A panel per App. c of GIP:

$$D.Wt._A = 3.0 \times \frac{490}{12^3} \times \frac{3}{32} \times 2 \left[ (20 \times 90) + (36 \times 90) + (36 \times 20) \right] = 919.^\#$$

Dead wt. of type B panel:

$$D.Wt._B = 3.0 \times \frac{490}{12^3} \times \frac{3}{32} \times 2 \left[ (20 \times 20) + (20 \times 90) + (20 \times 90) \right] = 638.^\#$$

$$Y_{c.g.} = \frac{(2 \times 919 \times 18) + (3 \times 638 \times 10)}{(2 \times 919) + (3 \times 638)} = 13.9''$$

Overall center of mass @  $(x=50, y=13.9)$

Overall center of rigidity @  $(x=46+4=50'', y=12.2+1=13.2'')$

Eccentricity =  $13.9 - 13.2 = 0.7'' \rightarrow$  too small, can be neglected






JOB NO. 50147 JOB TVA/BEND A-46/IPREF BY ZBej DATE 10-10-91  
 CALC. NO. N/A SUBJECT SEWS for 3-BDBB-268-0003D CHK'D J.D. Din DATE 10/10/95  
 (SSEL 39016)

Note 10 (Cont'd)

- Determination of section modulus of bolt group:



$$\bar{y} = \frac{(6 \times 18) + (4 \times 34)}{20} = 12.2''$$

$$I_{xx} = 4(21.8)^2 + 4(12.2)^2 + 6(18 - 12.2)^2 + 6(12.2)^2 = 3591. \text{ in}^2$$

$$S_{xx} = \frac{3591.}{21.8} = 165. \text{ in} \quad (\text{for moments acting out of plane of the bolt group})$$

$$I_{yy} = 4(6^2 + 14^2 + 26^2 + 34^2 + 46^2) = 16720. \text{ in}^2$$

$$S_{yy} = \frac{16720}{46} = 363. \text{ in} \quad (\text{for moments acting out of plane of the bolt group})$$

$$I_p = I_{xx} + I_{yy} = 3591 + 16720 = 20,311. \text{ in}^2$$

$$S_p = \frac{20,311}{\sqrt{(21.8)^2 + (46)^2}} = 399. \text{ in}$$





JOB NO. 50147 JOB TVA/BFNP A-46/1PEEE BY ZBaj DATE 10-10-95  
 CALC. NO. N/A SUBJECT SEWS for 3-BDRB-268-0003D CHK'D. J.D. Dier DATE 10/10/95  
 (SSEL 39016)

Note 10 (cont'd)

- Determine Loads

- Conservatively consider 2-3"  $\phi$  and 1-2 1/2"  $\phi$  rigid conduit, with 6' tributary span @ top of each bay:

$$\text{Wt. cond.} = 5 \text{ bays} \times (2 \times 12.8 \#/\text{ft} + 1 \times 8.9 \#/\text{ft}) \times 6' = 1035 \# \quad (\text{@ } 90'' \text{ above base})$$

$$\text{Wt. cable tray (18" )} = 25 \times 1.5 \times (1.5' + 7' + 2' + .5' + 14') \times \frac{2}{3} \times \overset{\text{Impact factor}}{2.0} = 1250 \# \quad (\text{@ } 90'' \text{ above base and only in x-direction})$$

↳ conservative estimate of cable fill

$$\text{Wt. Mcc.} = 2 \times 919 \# + 3 \times 638 \# = 3752 \# \quad (\text{@ } 45'' \text{ above base})$$

- Accelerations:

$$a_h = 1.0g \quad (\text{@ } f = 8 \text{ Hz, RTB, EL. 621', DBE, 5\%}) \quad \leftarrow \text{conservatively used for Bounding purposes}$$

$$a_v = 0.16g \quad (\text{ZPA})$$

Acceleration to use, including 1.25 increase factor for Med. Centered spectra:

$$\rightarrow a_h = 1.0g \times 1.25 = 1.25g$$

$$\rightarrow a_v = 0.16g \times 1.25 = 0.20g$$

- Seismic loads:

$$F_x = 1250 \# + (1035 \# \times 1.25g) + (3752 \# \times 1.25g) = 7234 \#$$

$$F_y = (1035 \# \times 1.25g) + (3752 \# \times 1.25g) = 5984 \#$$

$$F_z = (1035 + 3752) \times 0.2g = 957 \#$$

$$M_x = (1035 \# \times 1.25g \times 90'') + (3752 \# \times 1.25g \times 45'') = 327,488 \#''$$

$$M_y = (1250 \# \times 90'') + (1035 \# \times 1.25g \times 90'') + (3752 \# \times 1.25g \times 45'') = 439,988 \#''$$

$$M_z \approx 0$$





JOB NO. 50147 JOB TVA/BFNP A-46/1PEEE BY ZB DATE 10-10-01  
 CALC. NO. N/A SUBJECT SEWS for 3-RDBB-268-0003D CHK'D John P. ... DATE 10/10/95  
 (SSEL 39016)

Note 10 (cont'd)

- Shear per  $\frac{3}{8}$ "  $\phi$  bolt:

$$V = \left[ \left( \frac{7234}{5 \times 4} \right)^2 + \left( \frac{5984}{5 \times 4} \right)^2 \right]^{1/2} = 469 \#$$

$$f_v = \frac{469 \#}{0.11 \text{ in}^2} = 4.3 \text{ ksi}$$

shear-tension interaction:

$$26(1.7) - 1.8(4.3) = 36.5 \text{ ksi} > F_t = 1.7 \times 20 \text{ ksi} = 34 \text{ ksi}$$

$$\rightarrow \text{use } F_t = 34 \text{ ksi}$$

- Tension per  $\frac{3}{8}$ "  $\phi$  bolt:

$$T = \sqrt{\left( \frac{327,488 \#}{165} \right)^2 + \left( \frac{439,108 \#}{363} \right)^2 + \left( \frac{957}{5 \times 4} \right)^2} - \frac{1035 \# + 3752 \#}{5 \times 4} = 2087 \#$$

$$f_t = \frac{2087 \#}{0.11 \text{ in}^2} = 19 \text{ ksi} < F_t = 34 \text{ ksi} \quad \text{ok}$$

$$\frac{f_t}{F_t} = 0.56 < 1.0 \quad \text{ok}$$

- Check  $\frac{3}{4}$ "  $\phi$  Anchor bolts:

Conservatively, use the same  $S_{xx}$  &  $S_{yy}$  as for  $\frac{3}{8}$ "  $\phi$  bolts.

$$\text{Therefore: } V = 469 \# < V_{a112} = 4.11 \text{ k} \quad , \quad \frac{V}{V_{a11}} = 0.11 < 0.3 \quad \text{ok}$$

$$T = 2087 \# < T_{a112} = 3.166 \text{ k} \quad , \quad \frac{T}{T_{a11}} = 0.66 < 1.0 \quad \text{ok}$$

$\therefore$  Anchorage config. Adequate







JOB NO. 50147 JOB TVA/RFPD A46/1PEEF BY ZB DATE 2/23/0  
 CALC. NO. N/A SUBJECT SEWS for 3-BDBB-268-0002D CHK'D. J.P. DATE 2/23/0  
 (SSEL 39016)

- Note 11 (cont'd from page 3)

Evaluation of bolt bending due to crack in the grout pad (e.g., the grout pad, since is cracked, is conservatively assumed to provide no lateral support to the anchor bolts and therefore these bolts will be subject to bending moments)

$$\text{Demand Tension} \cong 2087 \# \times \frac{0.6g}{1.0g} = 1252 \# \quad \xrightarrow{\text{actual}} \quad 1252 \#$$

$$\text{Demand shear} \cong 469 \# \times \frac{0.6g}{1.0g} = 281 \# \quad \xrightarrow{\text{actual}} \quad 281 \#$$

(Note: 2087# and 469# were obtained for this equipment (see page 10) using an acceleration value corresponding to EL. 621' of the RB for bounding purposes. This equipment is actually located @ EL. 593' of RB and the corresponding acceleration value is 0.6g)

The following evaluation is consistent with the EPRI document titled, "Recommended Approaches for resolving Anchorage outliers,":

$$e = 2.5" \quad (\text{average grout thickness})$$

$$Z = \frac{d^3}{6} = \frac{.75^3}{6} = .07 \text{ in}^3 \quad (\text{plastic section modulus of the bolt})$$

$$A = \frac{\pi d^2}{4} = \frac{\pi (.75)^2}{4} = .442 \text{ in}^2$$

$$V_T = \frac{Z}{e} \left( F_y - \frac{P}{A} \right)$$

$$= \frac{.07}{2.5} \left( 36 - \frac{1252}{.442} \right) = 0.93 \text{ K} \quad \rightarrow \text{shear load corresponding to forming plastic hinge @ the concrete surface}$$

$$\frac{V}{V_T} = \frac{.281}{.93} = 0.30$$

$$V_B = \frac{Z (F_y - P/A) + M_c}{e + 2d_b}$$

$$M_c = 5.4 f_c' d_b^3 = 5.4 (3.6) (.75)^3 = 8.2 \text{ K-IN}$$



JOB NO. 50147 JOB YVA/BEND A46/1PEEEBY F. Benz DATE 2/23/9CALC. NO. N/A SUBJECT SEWS for 3-BDRR-268-0003D  
(SSEL 39016)CHK'D Jo. Dim DATE 2/23/9

$$V_B = \frac{.07 (36 - 1.225 / .442) + 8.2}{2.5 + 2 (.75)}$$

$$= 2.63 \text{ k} \rightarrow$$

shear load corresponding to forming plastic hinge in the embedded portion of the bolt

$$\frac{V}{V_B} = \frac{.201}{2.63} = 0.11$$

- Additional pullout load on the anchorage due to bolt bending,  $P'$ , is negligible. ( $< 5\%$ ) per Sect. 1.3 of the above referenced EPR1 document on resolving anchorage outliers.

∴ As shown above the bolt bending is insignificant, resulting bolt interaction remains same.



SSEL Line No. 39016

Status Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 3-BDBB-268-0003D Equip. Class 01 - Motor Control Centers

Equipment Description 480V RMOV BOARD 3D

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?  Y  N  U  N/A

2. Are essential relays required to function during earthquake screened out?  Y  N  U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns?  Y  N  U  N/A (1)

Requirements for relays satisfied?  Y  N  U (note 1)

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

Note 1) A long cable tray vertical riser has about 1 1/2" clearance to this equipment. The cable tray is supported by ~20' long rod hangers, and therefore will swing in a seismic event and impact the MCC. This impact is potentially unacceptable if the MCC includes essential relays. → outlier OSVS-39016

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?

YES  NO  (IPEEE EVAL. req'd)

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO  (see note 1 above)

Evaluated by: Fanni Bajj

Date: 10-10-95

Evaluated by: John O. Dizon

Date: 10/10/95



SSEL Line No. 39016

## OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

## 1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number 3-BDBB-268-0002D Equipment Class 01-MCCEquipment Location: Bldg. U3-RB Floor Elevation 593'Room or Row/Column U, R17 Base Elevation 593'Equipment Description 480 V RMOV BOARD 3D

## 2. OUTLIER ISSUE DEFINITION

- a. Identify all the screening guidelines which are not met.  
(Check more than one if several guidelines could not be satisfied.)

Mechanical and Electrical Equipment

Capacity vs. Demand   
 Caveats   
 Anchorage   
 Seismic Interaction   
 Other

Tanks and Heat Exchangers

Shell Buckling\*   
 Anchor Bolts and Embedment   
 Anchorage Connections   
 Flexibility of Attached Piping\*   
 Other

Essential Relays

Capacity vs. Demand   
 Mounting, Type, Location   
 Other

Cable and Conduit Raceways

Inclusion Rules   
 Other Seismic Performance Concerns   
 Limited Analytical Review   
 Other

\* Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

- b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

A long cable tray vertical riser has about 1 1/2" clearance to this equipment. The cable tray is supported by ~20' long rod hangers and therefore will swing in a seismic event and impact the MCC. This impact is potentially unacceptable if the MCC includes essential relays.





SSEL Line No. 39016

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number 3-BDBB-268-0003D

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

Determine if this MCC contains essential relays. If  
yes, then the cable tray needs to be rigidly supported  
to preclude this impact. If it is determined that the MCC  
does not contain essential relays then this outlier is resolved.

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

SEE SEWS for this equipment for anchorage evaluation  
including impact loads from adjacent cable tray.

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

FARZIN R. BEGI  
Print or Type Name

Farzin R. Begi  
Signature

10-10-95  
Date

JOHN O. DIZON, PE.  
Print or Type Name

John O. Dizon  
Signature

10/10/95  
Date

\_\_\_\_\_  
Print or Type Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date



SSEL Line No. 9020

Status Y (N) U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 3

Equip. ID No. 2-BDBB-231-0002A Equip. Class 02 - Low Voltage Switchgear

Equipment Description 480V SHDN BD 2A

Location: Bldg. RB Floor El. 621'-3" Room, Row/Col S-R13

Manufacturer, Model, Etc. (optional but recommended) - GE TYPE AKD-5
-Breaker types AK-2A-25-1, AK-6A-25, AK-2A-50s-2

SEISMIC CAPACITY VS DEMAND

- 1. Elevation where equipment receives seismic input 621'-3"
2. Elevation of seismic input below about 40' from grade Y (N) U
3. Equipment has fundamental frequency above about 8 Hz (Y) N U N/A (4)
4. Capacity based on: Existing Documentation DOC
Bounding Spectrum BS
1.5 x Bounding Spectrum (ABS)
GERS GERS
5. Demand based on: Ground Response Spectrum GRS
1.5 x Ground Response Spectrum AGS
Conserv. Des. In-Str. Resp. Spec. CRS
Realistic M-Ctr. In-Str. Resp. Spec. (RRS)

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.) (Y) N U (5) \*

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- 1. Equipment is included in earthquake experience equipment class (Y) N U N/A (1)
2. 600 V rating or less (Y) N U N/A
3. Side-to-side restraint of draw-out circuit breakers is provided (Y) N U N/A (2, 3, 4)
4. Adjacent cabinets which are close enough to impact, or sections of multi-bay cabinets, are bolted together if they contain essential relays (Y) N U N/A (9)
5. Attached weight (except conduit) less than about 100 lbs per cabinet assembly (Y) N U N/A (8)
6. Externally attached items rigidly anchored (Y) N U N/A
7. General configuration similar to ANSI C37.20 Standards (Y) N U N/A
8. Cutouts in lower half of cabinet side sheathing less than 30% of width of side panel wide and less than 60% of width of side panel high excluding bus transfer compartment (Y) N U N/A
9. All doors secured by latch or fastener (Y) N U N/A
10. Anchorage adequate (See checklist below for details) (Y) N U N/A (6)
11. Relays mounted on equipment evaluated AF = 4.5 (Y) N U N/A (12)
12. Have you looked for and found no other adverse concerns? Y (N) U N/A (8)
Is the intent of all the caveats met for Bounding Spectrum? Y (N) U N/A (8)

(See outlier OSVC-9020)



Equip. ID No. 2-BDBB-231-0002A Equip. Class 02 - Low Voltage Switchgear

Equipment Description 480V SHDN BD 2A

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |   |   |   |             |
|--|---|---|---|-------------|
| 1. Equipment is included in generic seismic testing equipment class  | Y | N | U | (N/A)       |
| 2. Meets all Bounding Spectrum caveats   | Y | N | U | (N/A)       |
| 3. Floor-mounted enclosure   | Y | N | U | (N/A)       |
| 4. Manufactured by major vendor (ITE/Brown Boveri, Westinghouse, or GE)  | Y | N | U | (N/A)       |
| 5. Maximum weight per section less than 1600 lbs   | Y | N | U | (N/A)       |
| 6. Base anchorage adequate (See checklist below for details)   | Y | N | U | (N/A)       |
| 7. Relays used for breaker function are not on "Low Ruggedness Relays" list                                      | Y | N | U | (N/A)       |
| 8. Relay evaluation completed for all relays that are essential to other equipment or cause unacceptable lockout | Y | N | U | (N/A)       |
| 9. For 2.5 g level GERS, vertical restraint prevents breaker uplift  | Y | N | U | (N/A)       |
| 10. For 2.5 g level GERS, outside corners of end units are reinforced, if needed                                 | Y | N | U | (N/A)       |
| 11. <u>All</u> adjacent cabinets or sections of multi-bay assemblies bolted together                             | Y | N | U | (N/A)       |
| Is the intent of all the caveats met for GERS?   |   |   |   | Y N U (N/A) |

ANCHORAGE

- |  |   |   |   |           |
|--|---|---|---|-----------|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)   | ⊙ | N | U | N/A       |
| 2. Type of anchorage covered by GIP  | ⊙ | N | U | N/A (C)   |
| 3. Sizes and locations of anchors determined   | ⊙ | N | U | N/A       |
| 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness  | ⊙ | N | U | N/A       |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | Y | N | U | (N/A)     |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | ⊙ | N | U | N/A       |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | ⊙ | N | U | N/A       |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | ⊙ | N | U | N/A       |
| 9. Strength of equipment base and load path to CG adequate   | ⊙ | N | U | N/A       |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | ⊙ | N | U | N/A       |
| Are anchorage requirements met?  |   |   |   | ⊙ N U (C) |



Equip. ID No. 2-BDBB-231-0002A Equip. Class 02 - Low Voltage Switchgear

Equipment Description 480V SHDN BD 2A

INTERACTION EFFECTS

- |   |  |   |   |                  |
|---|--|---|---|------------------|
| 1. Soft targets free from impact by nearby equipment or structures  | Y  | N | U | N/A              |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | Y  | N | U | N/A (8) OSWS-907 |
| 3. Attached lines have adequate flexibility   | Y  | N | U | N/A (11)         |
| 4. Overhead equipment or distribution systems are not likely to collapse                                    | Y  | N | U | N/A (10)         |
| 5. Have you looked for and found no other adverse concerns?   | Y  | N | U | N/A (7)          |
| Is equipment free of interaction effects?   | Y <input checked="" type="radio"/> U (8) |   |   |                  |


IS EQUIPMENT SEISMICALLY ADEQUATE?

Y  U (8)

COMMENTS

- For Notes 1 thru 5 and 8 thru 12, see SEWS for 1BDBB-231-0001A (SSEL No. 9018).

Note 6) Switchgear is attached to the embedded sill channel by plug welds, as shown below.



Per note 6 on SEWS for BD 1A (SSEL 9018),

The resultant pull out load per plug weld is  $f_{tW} = 1.12 \text{ K}$

The shear load per weld is:

$$V_x = \frac{14000 \#}{24} = 583 \# = V_y \quad (\text{D.L.} = 14 \text{ K}, \text{ Ref. SEWS for SSEL \# 9018})$$

$$\Rightarrow f_{w_{\text{shear}}} = [583^2 + 583^2]^{1/2} = 824 \#$$

Shear-Tension Interaction:


$$\left( \frac{1.12}{1.832} \right)^2 + \left( \frac{0.824}{7.329} \right)^2 = 0.39 < 1.0 \quad \text{OK}$$

$F_{W_{\text{tensile}}} = \frac{0.707 \times 1/8 \times 2.71}{4} \times 30.6 \text{ ksi} = 1.832 \text{ K}$  ← Knock down factor for tensile loads

$F_{W_{\text{shear}}} = 1.832 \times 4 = 7.329 \text{ K}$  ← No knock down factor for shear loads (Ref. EPRI NP-5228-SL, Vc)

Evaluated by: Fazli Beig Date: 9-5-95  
John O. Dixon 9/15/95

Note 7) - Blockwalls in the area are qualified per IEB 80-11 program. (Ref. DWG. 41N1202-1, R3; Walls 63 & 64)





SSEL Line No. 9020.

Status Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-BDBB-231-0002A Equip. Class 02 - Low Voltage Switchgear

Equipment Description 480V SHDN BD 2A

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?  Y  N  U  N/A

2. Are essential relays required to function during earthquake screened out? Y  N  U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y  N  U  N/A

Requirements for relays satisfied? Y  N  U  (1)

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

1) Breaker lifting device mounted over one of the bays is not restrained from movement on its rails and would potentially slide and impact the rail stops in a seismic event. This impact could potentially cause relay chatter. → outlier (OSVS-9020)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?

YES  NO  (Candidate for IPEEE Anchorage Evaluation)

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO  (note 1) above

Evaluated by: Forsie Deis

Date: 9-5-95

Evaluated by: John O. Dizon

Date: 9/15/95



## Exhibit 5-1

## OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

## 1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number 2-8058-231-0002A Equipment Class 02-LVSGEquipment Location: Building U2, RB Floor Elevation 621'-3"Room or Row/Column S-R13 Base Elevation 621'-3"Equipment Description 480 VOLT SHUTDOWN BOARD 2A

## 2. OUTLIER ISSUE DEFINITION

- a. Identify all the screening guidelines which are not met.  
(Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>		<u>Tanks and Heat Exchangers</u>	
Capacity vs. Demand	___	Shell Buckling <sup>1</sup>	___
Caveats	___	Anchor Bolts and Embedment	___
Anchorage	___	Anchorage Connections	___
Seismic Interaction	✓	Flexibility of Attached Piping <sup>1</sup>	___
Other	___	Other	___
		<u>Cable and Conduit Raceways</u>	
<u>Essential Relays</u>		Inclusion Rules	___
Capacity vs. Demand	___	Other Seismic Performance Concerns	___
Mounting, Type, Location	___	Limited Analytical Review	___
Other	___	Other	___

<sup>1</sup> Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

- b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

Breaker lifting device is mounted over the top of one of the switchgear bays. The lifting device is free to move on its rails. In a seismic event the lifting device would potentially slide and impact the rail stops which would then potentially cause chatter of relays mounted inside this switchgear



OSVS-9020  
Exhibit 5-1 (Cont'd)

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number 2-BDDB-231-0002A

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

Provide a positive restraining mechanism for this  
lifting device so that it will not slide on its  
rails in a seismic event or when is not in use.  
→ issue work Request

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

N/A.  
DRAWING- 2-48B900-2160 Rev D AND  
CALCULATION CDQ0999 96.0092 Rev 1 ARE ISSUED  
BY DCIN T39883A TO RESOLVE OUTLIER.

HH  
9-15-96  
9-18-96

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

FARZIN R. BEIGI  
Print or Type Name

Farsi Beigi  
Signature

9-5-95  
Date

JOHN O. DIZON, P.E.  
Print or Type Name

John O. Dizon  
Signature

9/15/95  
Date

\_\_\_\_\_  
Print or Type Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date



SSEL Line No. 9018

Status Y  U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 3<sup>B</sup>

Equip. ID No. 1-BDBB-231-0001A Equip. Class 02 - Low Voltage Switchgear

Equipment Description 480V SHDN BD 1A

Location: Bldg. RB Floor El. 621'-3" Room, Row/Col S-R1

Manufacturer, Model, Etc. (optional but recommended) GE Low Voltage Power CB, TYPE  
GE TYPE AKD-5 SG AK-2A-15-1


SEISMIC CAPACITY VS DEMAND

- |  |  |
|--|--|
| 1. Elevation where equipment receives seismic input      | <u>621'-3"</u>                               |
| 2. Elevation of seismic input below about 40' from grade | Y <input checked="" type="radio"/> U         |
| 3. Equipment has fundamental frequency above about 8 Hz  | <input checked="" type="radio"/> N U N/A (4) |
| 4. Capacity based on: Existing Documentation             | DOC  |
| Bounding Spectrum  | BS   |
| 1.5 x Bounding Spectrum                                  | <input checked="" type="radio"/> ABS         |
| GERS   | GERS   |
| 5. Demand based on: Ground Response Spectrum             | GRS  |
| 1.5 x Ground Response Spectrum                           | AGS  |
| Conserv. Des. In-Str. Resp. Spec.                        | CRS  |
| Realistic M-Ctr. In-Str. Resp. Spec.                     | <input checked="" type="radio"/> RRS         |

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)  N U (5)\*

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |   |  |
|---|--|
| 1. Equipment is included in earthquake experience equipment class   | <input checked="" type="radio"/> N U N/A (1)           |
| 2. 600 V rating or less   | <input checked="" type="radio"/> N U N/A               |
| 3. Side-to-side restraint of draw-out circuit breakers is provided  | <input checked="" type="radio"/> N U N/A (4), (2), (3) |
| 4. Adjacent cabinets which are close enough to impact, or sections of multi-bay cabinets, are bolted together if they contain essential relays                                | <input checked="" type="radio"/> N U N/A (9)           |
| 5. Attached weight (except conduit) less than about 100 lbs per cabinet assembly  | <input checked="" type="radio"/> N U N/A (8)           |
| 6. Externally attached items rigidly anchored   | <input checked="" type="radio"/> N U N/A               |
| 7. General configuration similar to ANSI C37.20 Standards   | <input checked="" type="radio"/> N U N/A               |
| 8. Cutouts in lower half of cabinet side sheathing less than 30% of width of side panel wide and less than 60% of width of side panel high excluding bus transfer compartment | <input checked="" type="radio"/> N U N/A               |
| 9. All doors secured by latch or fastener   | <input checked="" type="radio"/> N U N/A               |
| 10. Anchorage adequate (See checklist below for details)  | Y <input checked="" type="radio"/> U N/A (6)           |
| 11. Relays mounted on equipment evaluated AF=7.0  | <input checked="" type="radio"/> N U N/A (12)          |
| 12. Have you looked for and found no other adverse concerns?  | Y <input checked="" type="radio"/> U N/A (8)           |
- As the intent of all the caveats met for Bounding Spectrum?  N U N/A (6)





Equip. ID No. 1-BDBB-231-0001A Equip. Class 02 - Low Voltage Switchgear


Equipment Description 480V SHDN BD 1A

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |   |   |   |             |
|--|---|---|---|-------------|
| 1. Equipment is included in generic seismic testing equipment class  | Y | N | U | (N/A)       |
| 2. Meets all Bounding Spectrum caveats   | Y | N | U | (N/A)       |
| 3. Floor-mounted enclosure   | Y | N | U | (N/A)       |
| 4. Manufactured by major vendor (ITE/Brown Boveri, Westinghouse, or GE)  | Y | N | U | (N/A)       |
| 5. Maximum weight per section less than 1600 lbs   | Y | N | U | (N/A)       |
| 6. Base anchorage adequate (See checklist below for details)   | Y | N | U | (N/A)       |
| 7. Relays used for breaker function are not on "Low Ruggedness Relays" list                                      | Y | N | U | (N/A)       |
| 8. Relay evaluation completed for all relays that are essential to other equipment or cause unacceptable lockout | Y | N | U | (N/A)       |
| 9. For 2.5 g level GERS, vertical restraint prevents breaker uplift  | Y | N | U | (N/A)       |
| 10. For 2.5 g level GERS, outside corners of end units are reinforced, if needed                                 | Y | N | U | (N/A)       |
| 11. All adjacent cabinets or sections of multi-bay assemblies bolted together                                    | Y | N | U | (N/A)       |
| Is the intent of all the caveats met for GERS?   |   |   |   | Y N U (N/A) |

ANCHORAGE

- |  |     |   |   |             |
|--|-----|---|---|-------------|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)   | (Y) | N | U | N/A         |
| 2. Type of anchorage covered by GIP  | (Y) | N | U | N/A (6)     |
| 3. Sizes and locations of anchors determined   | (Y) | N | U | N/A         |
| 4. Anchorage installation adequate, e.g., weld quality and length, <u>nuts and washers</u> , expansion anchor tightness  | (Y) | N | U | N/A         |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | Y   | N | U | (N/A)       |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | (Y) | N | U | N/A         |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | (Y) | N | U | N/A         |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | (Y) | N | U | N/A         |
| 9. Strength of equipment base and load path to CG adequate   | (Y) | N | U | N/A         |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | (Y) | N | U | N/A         |
| Are anchorage requirements met?  |     |   |   | Y (N) U (6) |



Equip. ID No. 1-BDBB-231-0001A Equip. Class 02 - Low Voltage Switchgear

Equipment Description 480V SHDN BD 1A

INTERACTION EFFECTS


- 1. Soft targets free from impact by nearby equipment or structures (Y) N U N/A
  - 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures Y (N) U N/A (8)
  - 3. Attached lines have adequate flexibility (Y) N U N/A (11)
  - 4. Overhead equipment or distribution systems are not likely to collapse (Y) N U N/A (10)
  - 5. Have you looked for and found no other adverse concerns? (Y) N U N/A (7)
- Is equipment free of interaction effects? Y (N) U (8)

IS EQUIPMENT SEISMICALLY ADEQUATE?

Y (N) U (6,8)

COMMENTS

- 1) Equipment consists of 8 bays. Each bay is 26" to 27" wide, 60" deep and 90" tall, which is within GIP size parameters for low voltage switchgears
- 2) Circuit breakers are of drawout type and have rail support system from the switchgear sheet metal housing. Each breaker is also restrained by two "Worm Gear" type racking mechanism.
- 3) Orientation and type of primary and secondary contacts are adequate to prevent damage or disconnection.



4) This switchgear is manufactured by GE and is well represented in the Earthquake experience data base. Per App. B.2 of the GIP this type of switchgear are determined to be seismically rugged based on the EQ database. Due to the aspect ratio of this type of switchgears (overall dimension = 181" x 60" x 90"(h), all bays are adequately bolted together on their sides and attached to each other @ top) the overall flexibility of the SG is due to shear flexibility. Per EPRI Report TR-102180 the lowest natural frequency of typical switchgears with the above dimensions has been shown to be greater than 8 Hz through testing of 2-3 bay units. (Actually, the side-to-side frequency of 2-3 bay units were shown to be less than 8 Hz and the front-to-back to be greater than 8 Hz. However

Evaluated by: Forzi Beig Date: 8/30/95  
John O. Dizon 9/5/95

due to the fact that the actual lineup for this switchgear is comprised of 8 bays which are all connected to each other their frequency of side-to-side will be through shear flexibility of the entire unit and therefore greater than 8 Hz)





JOB NO. 50147.05 JOB TVA / BEND A-46 / IPEE

BY F. Bai DATE 8-30-95

CALC. NO. N/A SUBJECT Attach. to SEWS for 1-BDRB-231-000A  
(SSEL 9018)

CHK'D J. Diaz DATE 9/5/95

Note 4 (cont'd) - The frequency associated with the individual breakers is judged to be greater than 8 Hz due to their rigid mounting inside the SG cubicle and adequate restraints provided against breaker sliding out or moving side-to-side.

The frequency of a typical heavy panel door is estimated below: (panel edges, conservatively, simply supported)

- x - Relay, est. wt = 7 lbs
- + - " , " = 3 lbs
- o - " , " = 2 lbs

Thickness of the door panel = 12 gage = 0.1"  
 $w = \text{uniform load per sq in including panel weight}$   
 $= \frac{(6 \times 7^{\#} + 7 \times 3^{\#} + 13 \times 2^{\#})}{27" \times 90"} + 0.283 \frac{\text{lb}}{\text{in}^3} \times 0.1"$

$$= 0.0649 \text{ lb/in}^2$$

From Ref. Roark & Young, 5<sup>th</sup> ed., Table 36, Case 16


$$\alpha/b = \frac{27}{90} = 0.3 \rightarrow k_1 = 10.9$$

$$f = \frac{k_1}{2\pi} \sqrt{\frac{Dg}{wa^4}}$$

$$D = Et^3/12(1-\nu^2) = 29 \times 10^6 \times .1^3 / 12(1-.3^2) = 2656.$$

$$f = \frac{10.9}{2\pi} \sqrt{\frac{2656 \times 386.4}{.0649 \times 27^4}} = \underline{\underline{9.5 \text{ Hz}}}$$

(This frequency is actually conservative since the additional stiffening of the panel provided by the relay boxes is not considered.)



Typical SG Door  
with Relays





JOB NO. 50147.05 JOB TVA / PENP A-46 / IEEE BY F. Reji DATE 8/30/95  
 CALC. NO. N/A SUBJECT Attach. to SEWS for 1-BDDB-231-0001A CHK'D J.O. Pizem DATE 9/5/95  
 (SSEL 9018)

5) Per Calc. CD-Q 0000-940339, the in-structure response spectra at EL. 621' of the RB (@ 5% Damping, DDE) exceeds the 1.5X Bounding spectrum in the frequency range of about 5.0 to 6.8 Hz. Since, the lowest natural frequency of this switchgear is greater than 6.8 Hz the intent of the GIP seismic capacity vs. demand criteria is met.

### 6) Anchorage Evaluation:

- Equipment Wt. = 14000 lbs (Ref. DWG. 1-45N336)

- From MARS Report:

$$a_L = 1.0 g \quad (\text{@ EL. 621' of RB, 5\% DDE spectra, @ } f = 4 \text{ Hz})$$

$$a_V = 0.16 g \quad (\text{EPA})$$


$$\rightarrow F_H = 14^k \times 1.0 \times 1.25 = 17.5^k, \quad F_V = 14^k \times 0.16 \times 1.25 = 2.8^k$$

- Pull out per  $\frac{1}{2}$ "  $\phi$  Connecting bolt @ base:

$$T = \left[ \left( \frac{17.5 \times 90^{1/2}}{58 \times 8} \right)^2 + \left( \frac{2.8^k}{24} \right)^2 \right]^{1/2} - \frac{14^k}{24} = 1.12^k$$

Note: The  $\frac{1}{2}$ "  $\phi$  bolt at one location was removed and it was observed that there are 4 to 5 thread showing inside the hole in the embedded channel. The total depth of the 4-5 threads was measured to be at least  $\frac{1}{2}$ ". Therefore, it was concluded that there is a welded nut underside of the channel web and that the method of connection is not drill and Tap into channel web (thickness of channel web =  $\frac{3}{16}$ " for C4X5.4 member)

$$T_{all} = 0.142 \times 20 \times 1.7 = 4.828^k \gg T = 1.12^k \quad \text{OK}$$









JOB NO. 50147.05 JOB TVA/BEND A-46/IEEE BY FBeir DATE 2/30/87  
CALC. NO. N/A SUBJECT Attach. to SEWS for EADBBR-231-0001A CHK'D. J.O. Dira DATE 2/5/87  
(SSEL 9018)

Note 6 (cont'd) :

- shear per  $\frac{1}{2}'' \phi$  connecting bolt @ base :

since the holes at the base of the switchgear compartments are long slotted holes the connection need to be of friction-type connection which is achieved by the use of high strength bolts (A325 or A490 bolts) with hardened washers. There are no markings on the bolt heads to identify them as high strength bolts and per DWG. 48E1300-1 The bolt material shall conform to A36 or equivalent. Therefore, the only shear resistance provided is through the friction between the base of the equipment and the concrete floor, which is not adequate to resist sliding of the equipment under seismic loads. → outlier (OSVS-9018-02)

12) Per EPRI REPORT NP-714B-SL an effective in-cabinet amplification factor of 7 is considered appropriate for this type of switchgear.





JOB NO. 50147.05 JOB TVA/BFNP A-46/IEEE BY FRei DATE 8-30-95

CALC. NO. N/A SUBJECT Attach. to SENS for 1-BDBB-231-0001A CHK'D OSD DATE 9/5/95  
(SS-EL 9018)

SSEL: 9018, 9019

ID: 1-BDBB-231-0001A, 0001B  
(480 V SHD BD 1A & 1B)

TYPE:  
GE low voltage power CB, A1K-2A-15-1


Note 7) Block walls @ North and east side of the Board 1A <sup>and west of Board 1B</sup> qualified per IEB 80-11 Program (Ref. walls 2B & 30, DWG. 41N1201-1, R4).

Note 8) Lifting device on top of bay No. 1 and 2 is not positively restrained and could move on its rails and impart impact loads to the panels. Since the panels include relays, this interaction is a seismic concern. → outlier (OSVS-9018-01) (Wt. < 100#)

Note 9) Panels are bolted to their adjacent panels w/ 12-1/4" bolts @ each side. ok

Note 10) Fluorescent light tubes are of compression fitting type and judged not to become a falling hazard in a seismic event. ok

Note 11) Top entry conduit are mostly red hung and have adequate flexibility.









JOB NO. 50147.05 JOB TVA / RFP A-46 / IPEEE BY F. Reij DATE 8/3/04  
CALC. NO. N/A SUBJECT Attach. to SEWS for LEDBB-231-0001A CHK'D. D. J. P. DATE 9/5/95  
(SSEL 9018)


SSEL No. 9018 , 9019  
ID 1-BDBB-231-0001A & 1B

(480V SHDN BD 1A & 1B)

General arrangement DWG. 1-45N336 → Wt. = 14000. lbs  
Sill Plan DWG. 1-45N367 → sill channel = C4x5.4  
Embed & DWG. 48N1114 :



Long slotted hole  
@ Anchor locations



PLAN OF THE Equip. Base



SSEL Line No. 9018

Status Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 1-BDBB-231-0001A Equip. Class 02 - Low Voltage Switchgear

Equipment Description 480V SHDN BD 1A

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?  Y  N  U  N/A

2. Are essential relays required to function during earthquake screened out?  Y  N  U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns?  Y  N  U  N/A

Requirements for relays satisfied?  Y  N  U (1), (2)

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

1) Anchorage provided for the equipment is not adequate to resist shear loads caused from lateral seismic loads. → outlier (OSVS-9018-02)

2) Breaker lifting device mounted over one of the bays is not restrained from movement on its rails and would potentially slide and impact the rail stops in a seismic event. This could potentially cause relay chatter. → outlier impact (OSVS-9018-01)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?

YES  NO  (see note 1 above)

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO  (see notes 1 & 2 above)

Evaluated by: Fargi Bey

Date: 8-30-95

Evaluated by: John O. Dizon

Date: 9/5/95






Exhibit 5-1

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number 1-8288-231-0001A Equipment Class 02-LVSG  
 Equipment Location: Building UL, RB Floor Elevation 621'-3"  
 Room or Row/Column S-R1 Base Elevation 621'-3"  
 Equipment Description 480 VOLT SHUTDOWN BOARD 1A

2. OUTLIER ISSUE DEFINITION.

a. Identify all the screening guidelines which are not met.  
 (Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>		<u>Tanks and Heat Exchangers</u>	
Capacity vs. Demand	_____	Shell Buckling <sup>1</sup>	_____
Caveats	_____	Anchor Bolts and Embedment	_____
Anchorage	_____	Anchorage Connections	_____
Seismic Interaction	<input checked="" type="checkbox"/>	Flexibility of Attached Piping <sup>1</sup>	_____
Other	_____	Other	_____
<u>Essential Relays</u>		<u>Cable and Conduit Raceways</u>	
Capacity vs. Demand	_____	Inclusion Rules	_____
Mounting, Type, Location	_____	Other Seismic Performance Concerns	_____
Other	_____	Limited Analytical Review	_____
		Other	_____

<sup>1</sup> Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

Breaker lifting device is mounted over the top of one of the switchgear bays. The lifting device is free to move on its rails. In a seismic event the lifting device would potentially slide and impact the rail stops which would then potentially cause chatter of relays mounted inside this switchgear.



OSVS-9018-1  
Exhibit 5-1 (Cont'd)

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number 1-BDBB-231-001A

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

Provide a positive restraining mechanism  
for this lifting device so that it will  
not slide on its rails in a seismic event  
or when is not in use. } issue work Request

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

N/A.  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

FARZIN BEGI  
Print or Type Name

Farzi Begi  
Signature

8-30-95  
Date

JOHN O. DRON, PE  
Print or Type Name

John O. Dron  
Signature

9/5/95  
Date

\_\_\_\_\_  
Print or Type Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date



Exhibit 5-1

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number 1-BDBB-231-0001A Equipment Class 02-LVSG

Equipment Location: Building U1-RB Floor Elevation 621'-3"

Room or Row/Column S-R1 Base Elevation 621'-3"

Equipment Description 480 VOLT SHUTDOWN BOARD 1A

2. OUTLIER ISSUE DEFINITION

a. Identify all the screening guidelines which are not met.  
(Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>		<u>Tanks and Heat Exchangers</u>	
Capacity vs. Demand	<input type="checkbox"/>	Shell Buckling <sup>1</sup>	<input type="checkbox"/>
Caveats	<input type="checkbox"/>	Anchor Bolts and Embedment	<input type="checkbox"/>
Anchorage	<input checked="" type="checkbox"/>	Anchorage Connections	<input type="checkbox"/>
Seismic Interaction	<input type="checkbox"/>	Flexibility of Attached Piping <sup>1</sup>	<input type="checkbox"/>
Other	<input type="checkbox"/>	Other	<input type="checkbox"/>
		<u>Cable and Conduit Raceways</u>	
<u>Essential Relays</u>		Inclusion Rules	<input type="checkbox"/>
Capacity vs. Demand	<input type="checkbox"/>	Other Seismic Performance Concerns	<input type="checkbox"/>
Mounting, Type, Location	<input type="checkbox"/>	Limited Analytical Review	<input type="checkbox"/>
Other	<input type="checkbox"/>	Other	<input type="checkbox"/>

<sup>1</sup> Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

Equipment anchorage does not provide adequate shear resistance for seismic induced lateral loads. (Base anchorage to the embedded channels is provided by 1/2" dia bolts installed in long-slotted holes at equipment base sheet metal)



OSVS-9018-2

Sheet 2 of 2

Exhibit 5-1 (Cont'd)

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number 1-BDBB-231-0001A

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

Provide adequate anchorage for the equipment to resist shear loads. One option is to provide adequate amount of plug welds @ the location of slotted holes in the base of the equipment, similar to low voltage switchgear in unit 2.

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

FARZIN BEIGI  
Print or Type Name

Farzi Beigi  
Signature

8-31-95  
Date

JOHN A DIZON, PE  
Print or Type Name

John O. Dizon  
Signature

9/5/95  
Date

\_\_\_\_\_  
Print or Type Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date





SEL Line No. 9014

Status Y  N  U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 3

Equip. ID No. 0-BDAA-211-0000C Equip. Class 03 - Medium Voltage Switchgear

Equipment Description 4KV SHDN BD C

Location: Bldg. RB Floor El. 621-3" Room, Row/Col R-R13


Manufacturer, Model, Etc. (optional but recommended) GE, Magne-Blast Circuit Breaker  
model MAH-476-250-10

SEISMIC CAPACITY VS DEMAND

- |   |  |  |
|---|--|--|
| 1. Elevation where equipment receives seismic input   | <u>621-3"</u>  |  |
| 2. Elevation of seismic input below about 40' from grade  | Y <input checked="" type="radio"/> N <input type="radio"/> U <input type="radio"/> | grade @ el. 550'   |
| 3. Equipment has fundamental frequency above about 8 Hz   | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U | N/A (1)  |
| 4. Capacity based on:   |  |  |
| Existing Documentation  |  | DOC  |
| Bounding Spectrum   |  | BS   |
| 1.5 x Bounding Spectrum   |  | <input checked="" type="radio"/> ABS   |
| GERS  |  | GERS   |
| 5. Demand based on:   |  |  |
| Ground Response Spectrum  |  | GRS  |
| 1.5 x Ground Response Spectrum  |  | AGS  |
| Conserv. Des. In-Str. Resp. Spec.   |  | CRS  |
| Realistic M-Ctr. In-Str. Resp. Spec.  |  | <input checked="" type="radio"/> RRS   |
| Does capacity exceed demand? (Indicate at right (*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.) |  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U (2) * |

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |  |  |
|--|--|--|
| 1. Equipment is included in earthquake experience equipment class  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U | N/A (6)  |
| 2. 2.4 KV to 4.16 KV rating  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U | N/A  |
| 3. Internally mounted potential and/or control power transformers are restrained to prevent damage to or disconnection of contacts                                       | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U | N/A  |
| 4. Adjacent cabinets which are close enough to impact, or sections of multi-bay cabinets, are bolted together if they contain essential relays                           | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U | N/A (5)  |
| 5. Attached weight (excluding conduit) less than about 100 lbs per cabinet bay   | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U | N/A (14), (11)   |
| 6. Externally attached items rigidly anchored  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U | N/A (14), (11)   |
| 7. General configuration similar to ANSI C37.20 Standards  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U | N/A  |
| 8. Cutouts in lower half of cabinet sheathing less than 30% of width of side panel wide and less than 60% of width of side panel high excluding bus transfer compartment | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U | N/A  |
| 9. All doors secured by latch or fastener  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U | N/A  |
| 10. Anchorage adequate (See checklist below for details)   | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U | N/A (3)  |
| 11. Relays mounted on equipment evaluated AF=7.0   | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U | N/A (15)   |
| 12. Have you looked for and found no other adverse concerns?   | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U | N/A  |
| Is the intent of all the caveats met for Bounding Spectrum?  |  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U N/A |



Equip. ID No. 0-BDAA-211-0000C Equip. Class 03 - Medium Voltage Switchgear

Equipment Description 4KV SHDN BD C

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)


- |   |   |   |   |     |
|---|---|---|---|-----|
| 1. Equipment is included in generic seismic testing equipment class   | Y | N | U | N/A |
| 2. Meets all Bounding Spectrum caveats  | Y | N | U | N/A |
| 3. Floor-mounted enclosure  | Y | N | U | N/A |
| 4. The switchgear is not a specially-designed type  | Y | N | U | N/A |
| 5. Circuit breakers are truck-mounted type, not jack-up or vertical-lift  | Y | N | U | N/A |
| 6. Maximum weight per vertical section less than 5000 lbs   | Y | N | U | N/A |
| 7. Base anchorage adequate (See checklist below for details)  | Y | N | U | N/A |
| 8. Relays used for breaker function are not on "Low Ruggedness Relays" list   | Y | N | U | N/A |
| 9. Relay evaluations completed for all relays that are essential to other equipment or cause unacceptable lockout             | Y | N | U | N/A |
| 10. For 2.5g level GERS, vertical restraint prevents circuit breaker uplift   | Y | N | U | N/A |
| 11. For 2.5g level GERS, circuit break arc chutes are restrained horizontally   | Y | N | U | N/A |
| 12. For 2.5g level GERS, a Beaver Type Z relay is not used in Westinghouse MV switchgear for the "Y" anti-pump relay          | Y | N | U | N/A |
| 13. Separate evaluation of breaker racking mechanism completed; seismic positioner or sufficient side-to-side restraints used | Y | N | U | N/A |
| 14. All adjacent cabinets or sections of multi-bay assemblies bolted together   | Y | N | U | N/A |

Is the intent of all the caveats met for GERS?

Y N U (N/A)

ANCHORAGE

- |  |     |   |   |            |
|--|-----|---|---|------------|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)   | (Y) | N | U | N/A (3, 8) |
| 2. Type of anchorage covered by GIP  | (Y) | N | U | N/A        |
| 3. Sizes and locations of anchors determined   | (Y) | N | U | N/A (8)    |
| 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness  | (Y) | N | U | N/A        |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | Y   | N | U | (N/A)      |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | Y   | N | U | (N/A)      |



SSEL Line No. 9014

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 3 of 3

Equip. ID No. 0-BDAA-211-0000C Equip. Class 03 - Medium Voltage Switchgear

Equipment Description 4KV SHDN BD C

ANCHORAGE (Cont'd)

- 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors (Y) N U N/A
  - 8. Base has adequate stiffness and effect of prying action on anchors considered (Y) N U N/A
  - 9. Strength of equipment base and load path to CG adequate (Y) N U N/A
  - 10. Embedded steel, grout pad or large concrete pad adequacy evaluated (Y) N U N/A
- Are anchorage requirements met? (Y) N U (3)

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures (Y) N U N/A (12)
  - 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures (Y) N U N/A (7)
  - 3. Attached lines have adequate flexibility (Y) N U N/A (9)
  - 4. Overhead equipment or distribution systems are not likely to collapse (Y) N U N/A
  - 5. Have you looked for and found no other adverse concerns? Y (N) U N/A (13)
- Is equipment free of interaction effects? Y (N) U (13)

IS EQUIPMENT SEISMICALLY ADEQUATE?

*loosely attached breaker wrench to the bay no. 3* Y (N) U (13)

*potential relay chatter concern → outlier (OSVS-9014)*

COMMENTS

For notes 1-6 & 8-15 see SEWS for 0-BDAA-211-0000A, (SSEL No. 9012). These two equipment are similar in every respect except that the back side of this equipment is fillet welded to the embed plate by total of approx. 72" of 1/3" weld (24 bays x 2 weld/bay x 1.5"/weld) vs. Board A which has 192" of weld. However, the anchorage evaluation performed in SEWS for Board A (Note #3) considered 32.5" weld in tension, and 130" weld for shear resistance calculation showed a F.s. > 11 against weld stress allowable. Also, the plug welds provided in the front holes of this S.G. (SSEL# 9014) do not fully cover the entire slotted hole opening on the bottom of the S.G. bars.

evaluated by: Farzi Bazi Date: 9-12-95  
John O. Dixon 9/18/95

This is also accepted in light of large margin and conservative nature of the anchorage calc. performed as referenced above. *all*

Note 7) Block walls in the area are included per IBC 20-11 provision. *all* 4/11/2002-1, R3



SSEL Line No. 9014

Status Y N U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 0-BDAA-211-0000C Equip. Class 03 - Medium Voltage Switchgear

Equipment Description 4KV SHDN BD C

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?  Y  N  U  N/A

2. Are essential relays required to function during earthquake screened out?  Y  N  U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns?  Y  N  U  N/A (1)

Requirements for relays satisfied?  Y  N  U (1)

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

(1) Breaker wrench is attached loosely to the front of the bay no 3. In a seismic event this wrench will "bang" into the door and may cause relays in this bay to chatter - outlier (OSVS-9014).

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?

YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO  (1)

Evaluated by: Forsji Besi

Date: 7-12-95

Evaluated by: H. O. Diaz

Date: 9/18/95





SSEL Line No. 9014

(OSVS-9014)

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number D-BDAA-211-0000C Equipment Class 03 - MVSG

Equipment Location: Bldg. 112, RB Floor Elevation 621'-3"

Room or Row/Column R-R13 Base Elevation 621'-3"

Equipment Description 4 KV SHDN BDC

2. OUTLIER ISSUE DEFINITION

- a. Identify all the screening guidelines which are not met.  
(Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>	_____	<u>Tanks and Heat Exchangers</u>	_____
Capacity vs. Demand	_____	Shell Buckling*	_____
Caveats	_____	Anchor Bolts and Embedment	_____
Anchorage	_____	Anchorage Connections	_____
Seismic Interaction	<input checked="" type="checkbox"/>	Flexibility of Attached Piping*	_____
Other	_____	Other	_____
<u>Essential Relays</u>	_____	<u>Cable and Conduit Raceways</u>	_____
Capacity vs. Demand	_____	Inclusion Rules	_____
Mounting, Type, Location	_____	Other Seismic Performance Concerns	_____
Other	<input checked="" type="checkbox"/>	Limited Analytical Review	_____
		Other	_____

\* Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

- b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

A breaker racking wrench is loosely attached to bay No. 3 of this switchgear. In a seismic event this wrench will interact with the panel it is attached to (it will "bang" into it). This impact by the wrench could chatter relays in this bay.



ASSEL Line No. 9014

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number Q-BDAA-211-0000C

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

If the relay review identifies this bay to include essential relays, then the wrench needs to be removed from the bay or positively attached to it such that any interaction would be precluded.

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

↳ Issue Work Request

N/A

4. CERTIFICATION:

The information on this OSVS is; to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

FARZIN BEIGI  
Print or Type Name

Farzin Beigi  
Signature

9-12-95  
Date

JOHN O. DIZON, PE  
Print or Type Name

John O. Dizon  
Signature

9/12/95  
Date

Print or Type Name

Signature

Date



SSEL Line No. 9012

Status Y (N) U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 3/9

Equip. ID No. 0-BDAA-211-0000A Equip. Class 03 - Medium Voltage Switchgear

Equipment Description 4KV SHDN BD A

Location: Bldg. RB Floor El. 621'-3" Room, Row/Col R-R2

Manufacturer, Model, Etc. (optional but recommended) GE Circuit Breaker Type Magn-Blast MAH-4.76-250-1D

SEISMIC CAPACITY VS DEMAND

- |  |   |
|--|---|
| 1. Elevation where equipment receives seismic input      |   |
| 2. Elevation of seismic input below about 40' from grade | Y (N) U <sup>621'-3"</sup> grade = 561' |
| 3. Equipment has fundamental frequency above about 8 Hz  | (Y) N U N/A (1)                         |
| 4. Capacity based on:                                    | DOC                                     |
| Existing Documentation                                   | BS                                      |
| Bounding Spectrum  | 1.5 x Bounding Spectrum                 |
| 1.5 x Bounding Spectrum                                  | (ABS)                                   |
| GERS   | GERS                                    |
| 5. Demand based on:                                      | GRS                                     |
| Ground Response Spectrum                                 | 1.5 x Ground Response Spectrum          |
| 1.5 x Ground Response Spectrum                           | AGS                                     |
| Conserv. Des. In-Str. Resp. Spec.                        | CRS                                     |
| Realistic M-Ctr. In-Str. Resp. Spec.                     | (RRS)                                   |

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.) (Y) N U (-) \*

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |                        |
|--|------------------------|
| 1. Equipment is included in earthquake experience equipment class  | (Y) N U N/A (4)        |
| 2. 2.4 KV to 4.16 KV rating  | (Y) N U N/A            |
| 3. Internally mounted potential and/or control power transformers are restrained to prevent damage to or disconnection of contacts                                       | (Y) N U N/A            |
| 4. Adjacent cabinets which are close enough to impact, or sections of multi-bay cabinets, are bolted together if they contain essential relays                           | (Y) N U N/A (5)        |
| 5. Attached weight (excluding conduit) less than about 100 lbs per cabinet bay   | (Y) N U N/A (14), (11) |
| 6. Externally attached items rigidly anchored  | (Y) N U N/A (14), (11) |
| 7. General configuration similar to ANSI C37.20 Standards  | (Y) N U N/A            |
| 8. Cutouts in lower half of cabinet sheathing less than 30% of width of side panel wide and less than 60% of width of side panel high excluding bus transfer compartment | (Y) N U N/A            |
| 9. All doors secured by latch or fastener  | (Y) N U N/A            |
| 10. Anchorage adequate (See checklist below for details)   | (Y) N U N/A (3)        |
| 11. Relays mounted on equipment evaluated AF = 7.0   | (Y) N U N/A (15)       |
| 12. Have you looked for and found no other adverse concerns?   | (Y) N U N/A            |

Is the intent of all the caveats met for Bounding Spectrum? (Y) N U N/A



Equip. ID No. 0-BDAA-211-0000A Equip. Class 03 - Medium Voltage Switchgear


Equipment Description 4KV SHDN BD A

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

1. Equipment is included in generic seismic testing equipment class	Y	N	U	N/A
2. Meets all Bounding Spectrum caveats	Y	N	U	N/A
3. Floor-mounted enclosure	Y	N	U	N/A
4. The switchgear is not a specially-designed type	Y	N	U	N/A
5. Circuit breakers are truck-mounted type, not jack-up or vertical-lift	Y	N	U	N/A
6. Maximum weight per vertical section less than 5000 lbs	Y	N	U	N/A
7. Base anchorage adequate (See checklist below for details)	Y	N	U	N/A
8. Relays used for breaker function are not on "Low Ruggedness Relays" list	Y	N	U	N/A
9. Relay evaluations completed for all relays that are essential to other equipment or cause unacceptable lockout	Y	N	U	N/A
10. For 2.5g level GERS, vertical restraint prevents circuit breaker uplift	Y	N	U	N/A
11. For 2.5g level GERS, circuit break arc chutes are restrained horizontally	Y	N	U	N/A
12. For 2.5g level GERS, a Beaver Type Z relay is not used in Westinghouse MV switchgear for the "Y" anti-pump relay	Y	N	U	N/A
13. Separate evaluation of breaker racking mechanism completed; seismic positioner or sufficient side-to-side restraints used	Y	N	U	N/A
14. All adjacent cabinets or sections of multi-bay assemblies bolted together	Y	N	U	N/A
Is the intent of all the caveats met for GERS?	Y	N	U	N/A

ANCHORAGE

1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)	(Y)	N	U	N/A (3,3)
2. Type of anchorage covered by GIP (plug & fillet welds)	(Y)	N	U	N/A
3. Sizes and locations of anchors determined	(Y)	N	U	N/A (2)
4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness	(Y)	N	U	N/A
5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking	Y	N	U	N/A
6. For bolted anchorages, gap under base less than 1/4-inch	Y	N	U	N/A





SSEL Line No. 9012

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 3 of 29

Equip. ID No. 0-BDAA-211-0000A Equip. Class 03 - Medium Voltage Switchgear

Equipment Description 4KV SHDN BD A

ANCHORAGE (Cont'd)

- 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors (Y) N U N/A
  - 8. Base has adequate stiffness and effect of prying action on anchors considered (Y) N U N/A
  - 9. Strength of equipment base and load path to CG adequate (Y) N U N/A
  - 10. Embedded steel, grout pad or large concrete pad adequacy evaluated (Y) N U N/A
- Are anchorage requirements met? (Y) N U (3)

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures (Y) N U N/A (12)
  - 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures (Y) N U N/A (7)
  - 3. Attached lines have adequate flexibility (Y) N U N/A (5)
  - 4. Overhead equipment or distribution systems are not likely to collapse (Y) N U N/A
  - 5. Have you looked for and found no other adverse concerns? Y (N) U N/A (13)
- Is equipment free of interaction effects? Y (N) U (13)

IS EQUIPMENT SEISMICALLY ADEQUATE?

Y (N) U (13)

COMMENTS

1) The heavy circuit breakers in this med. voltage switchgear are horizontally racked and their weight rests on the floor mechanical jack screws secure the breakers to the rear of the enclosure. The lowest frequency associated with the rigidity of the breakers in racked-in position is estimated to be 22.9 Hz based on a conservative calculation (Ref. Calc. CD-40211-890151). Test results of a 2.3 unit sections of switchgear showed that the side-to-side response is often less than 8 Hz, while the front-to-back response is greater than 8 Hz (Ref. EPRI Report TR-102180, March 1993). However, since all individual sections of this switch gear are bolted together, the side-to-side frequency would at least match that of the front-to-back. Therefore, it is concluded that the switchgear lowest fundamental frequency is greater than 8 Hz.

Evaluated by: Fanni Brini  
John O. Dizon

Date: 9-12-95  
9/18/95





JOB NO. 50147 JOB TVA / BFNP A-46 / IPEEE BY Z. Benji DATE 9-12-95  
 CALC. NO. N/A SUBJECT Attach. to SEWS for 2-BDAP-211-000-A CHK'D. J. Dizon DATE 1/18/95  
 (SSEL 9012)

- 2) Per Calc. CD-Q0000-940339, FIG. B.1, the 1.5 x Bounding spectrum is exceeded by the in-structure spectra at EL. 621' of RB in the frequency range of 5.0 Hz to 7 Hz. Since, the lowest natural frequency of this Switchgear is greater than 7 Hz, the intent of GIP seismic Capacity vs. Demand Criteria is met

3) Anchorage Evaluation :

$$Wt. = 60^k \text{ (Ref. DWG. 45N326)}$$

DBE Horiz. Accel. @  $f = 8 \text{ Hz}$

$$a_h = 1.0 g \text{ (RB, EL. 621', 5\% Damping, DBE)}$$

$$a_v = 0.16 g \text{ (ZPA)}$$

$$F_h = 60 \times 1.25 \times 1.0 g = 75^k$$

Factor to account for Med. ctr. spectra

$$F_v = 60 \times 1.25 \times 0.16 g = 12^k$$

- Weld properties



$$\text{Perimeter of Hole} = \pi(5/8) + (1 - 5/8) \times 2 = 2.71''$$

$$\text{Equivalent weld length (for shear) @ front} = 2.71'' \times 48 = 130''$$

$$\text{Equivalent weld length (for tension, @ front)} = \frac{130}{1} = 130''$$

knock down factor for poor workmanship. Per GIP, App. C

$$\text{Equivalent weld length @ back} = \frac{24 \times 2 \times 4''}{\# \text{ of } 4'' \text{ welds per Bay}} = 192'' \quad (\text{does not govern})$$





JOB NO. 50147 JOB TVA / BENP A-46 / IPEEEBY F. Bejjani DATE 9-12-95CALC. NO. N/A SUBJECT Attach. to SEWS for O-85AA-211-000A  
(SSEL 9012)CHK'D. J.O. Diem DATE 9/18/95Note 3 (cont'd)

- Weld allowables :

$$F_{W_s} = 30.6 \text{ ksi} \times \frac{1}{8} \text{''} \times 0.707 \times 130 \text{''} = 352.6 \text{''}$$

(Total allowable weld shear stress for plug welds @ front of S.G.)

$$F_{W_T} = 30.6 \text{ ksi} \times \frac{1}{8} \text{''} \times 0.707 \times 32.5 \text{''} = 87.9 \text{''}$$

(Total allowable weld Tensile stress for plug welds @ front of S.G.)

- Weld seismic forces (Moment about A)

$$OTM = (75 \text{ k} \times 38 \text{''}) + (12 \text{ k} \times (73 \frac{1}{2} - 17)) - \overbrace{(60 \times (73 \frac{1}{2} - 17))}^{\text{Resisting Moment due to D.L.}} = 138 \text{ k-in}$$

$$F_y = \frac{138 \text{ k-in}}{73.5 - 4} + \frac{12 \text{ k}}{2} = 8.0 \text{ k}$$

$$F_x = \frac{75 \text{ k}}{2} = 37.5 \text{ k}$$

$$F_{z_1} = F_x = 37.5 \text{ k}$$

$$F_{z_2} = \frac{75 \text{ k} (73.5 - 21)}{73.5 - 4} = 56.7 \text{ k}$$

$$\Rightarrow F_z = 37.5 + 56.7 = 94.2 \text{ k}$$

- Shear-Tension Interaction :

$$\left( \frac{F_y}{F_{W_T}} \right)^2 + \left( \frac{(F_x^2 + F_z^2)^{1/2}}{F_{W_s}} \right)^2 \leq 1.0$$

$$\left( \frac{8 \text{ k}}{87.9 \text{ k}} \right)^2 + \left( \frac{101 \text{ k}}{352.6 \text{ k}} \right)^2 = 0.09 \ll 1.0 \quad \underline{\text{ok}}$$

∴ Anchorage Adequate





EQE INTERNATIONAL

SHEET NO. 6 of 9

JOB NO. 50147 JOB TVA / BEND A-46 / IPEE BY Fin DATE 7-12-95

CALC. NO. N/A SUBJECT Attachment to SEWS for O-BDAA-211-0000A CHK'D D. Dizon DATE 9/18/95  
(SSEL No. 9012)


SSEL: 9012

ID: O-BDAA-211-000A

(4 KV shut down Board)

Breaker Type: GE Magna-blast circuit breaker  
Type MAH-476-250-1D


- 4) primary contact: 3 in series (round cross-section) @ 2 levels




- 5) 24 panels, all bolted together, with 5 rows of 1/4" to 1/2" phi along the height of each panel (~15" spacing). Also each adjacent panel is bolted to each other @ top by 2" x 3/16" metal strip that are bolted heavily to the panels.

- 6) Size: 73 1/2 (D) x 26 (W) x 90 (H) @ 9 panels  
64 1/2 (D) x 26 (W) x 90 (H) @ 15 panels

- 7) Blockwalls in the vicinity of Board qualified per IEB 80-11 program (Ref. DWG. 41N1201-1, wall nos. 28 and 35)



along the back edge  
1/8" V 4-12cc.








JOB NO. 50147 JOB TVA BENT A-46 / IDEEE BY Sur DATE 9-12-95  
 CALC. NO. N/A SUBJECT Attachment to SENS Lr 0-2DA1-21-0000A CHK'D (N.S.) DATE 9/12/95  
 (SSEL 9012)

9012 (cont'd)


- 9) Top entry conduit are rod hung → adequate flexibility
- 10) Consider 2-3"φ, 1-2"φ, 1-1/2"φ, 1-3/4"φ conduit w/ 4' span @ top of each bay.  
 $[2 \times 12.8 + 1 \times 5.1 + 1 \times 3.6 + 1 \times 1.4] \times 4' = 143. \# \Rightarrow$  small enough to ignore in Anchorage Calc.
- 11) There is a synchronizing panel (24" x 17" x 10") @ top of bay No. 12.  
 See note 14 for its estimated weight and frequency calculation.  
 Load path from the C.G. of this panel to the S.G. is rugged (6-1/2" dia)  
 The frequency estimation in Note 14 is based on the determination that the lowest frequency of this panel is attributed to its base flexibility.
- 12) Fluorescent lights overhead are far enough not to cause seismic interaction, since compression type fittings are used. <sup>ducts</sup> HVAC supports in the proximity are rigid. OK  
 (For SSEL 9013 and 9015, there are 2 Fluorescent fixtures without compress. fitting → OK since they are far and are located behind the Boards.)
- 13) There is a racking wrench attached to bay No. 2 which would impact the front of the panel in a seismic event. The upper compartment in this bay has relays and the impact of this wrench to the bottom compartment would potentially chatter these relays. → Outlier (OSVS-9012)





JOB NO. 50147 JOB TVA / REVD A-46 / IPEEE BY F3e DATE 9-12-95  
 CALC. NO. N/A SUBJECT Attachment to SENS for A-23AA-211-0000A CHK'D 10. Dizer DATE 9/18/95  
 (SSEL 9012)

14) Synchronizing panel details:



$$\text{Weight of housing} = \frac{490}{12^3} \times \frac{5}{32} \times 2 [(17 \times 10) + (17 \times 24) - (10 \times 24)] = 43.5 \#$$

There are total of 5 components (meters) mounted inside the box. wt. of each component is estimated to be less than 10 #.

$$\text{Total wt. of the box} = 43.5 + 5(10 \#) = 93.5 \#$$


$$\begin{aligned} \text{wt. of the support panel} &= \frac{490}{12^3} \times \frac{5}{32} \times [(24 \times 6) + 2(6 \times 24) + (24 \times 24)] \\ &= 45 \# \end{aligned}$$

$$\text{wt. of connecting arms} \approx \frac{490}{12^3} \times \frac{5}{32} \times 2 [(18 \times 2) + (18 \times 6) - (6 \times 2)] = 14 \#$$

(~18" x 6" x 2")

$$\text{Total wt. of synchronizing panel} = 93.5 + 45 + 14 = 152. \#$$

(This wt. could be ignored in anchorage calc. since it is very small as compared to the overall S.G. wt. ( $\frac{153}{60000} = 0.3\%$ )).






JOB NO. 50147 JOB TVA/BFNP A-46 / IPEEE BY F. Reig DATE 9-12-95  
 CALC. NO. N/A SUBJECT Attachment to SEWS for 0-RDAA-211-0000A CHK'D J.D. Dize DATE 9/18/95  
 (SSEL No 9012)

Note 14 (Cont'd)

Consider the following model and calculate the frequency of the synch panel:




$$\delta_{x_1} (\text{due to } F_x) = \frac{(153/2)(24)^3}{3 \times 29 \times 10^6 \times 2.81} = 0.0043''$$

$$\delta_{x_2} (\text{due to } F_y) = \frac{(153/2 \times 10'')(24)^2}{2 \times 29 \times 10^6 \times 2.81} = 0.0027''$$

$$\delta_x = \delta_{x_1} + \delta_{x_2} = 0.0043 + 0.0027 = 0.007''$$

$$f = \frac{1}{2\pi} \sqrt{\frac{g}{\delta_x}}$$

$$= \frac{1}{2\pi} \sqrt{\frac{386.4}{0.007}} = 37.4 \text{ Hz} \quad (\therefore \text{Rigid})$$



Note:  $F_x$  and  $F_y$  above are conservative since the restraint provided by the lower member connecting the box to the supporting panel is ignored in the frequency calculation.

- 15) The long heavy loaded panel doors are consistently reinforced with stiffening angles. A similar panel door for low voltage switch gear with no reinforcement was shown to have an estimated fundamental frequency of 7.5 Hz (see SEWS for SSEL No 9018). By comparison, the fundamental frequency of the panel doors on this equipment where relays are attached to is greater than 7.5 Hz (due to additional stiffeners). A conservative amplification factor of 7.0 is assigned to this switchgear, consistent with that suggested in EPRI Report



SEL Line No. 9012

Status Y  N U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 0-BDAA-211-0000A Equip. Class 03 - Medium Voltage Switchgear

Equipment Description 4KV SHDN BD A

RELAY WALKDOWN

- 1. Does spot check of essential relays indicate relays present and properly mounted?  Y N U N/A
- 2. Are essential relays required to function during earthquake screened out? Y N U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

- 3. No other relay concerns? Y  N U N/A (1)
- Requirements for relays satisfied? Y  N U (1)

SYSTEM INTERACTION EFFECTS

- 1. No potential sources could flood or spill onto cabinet?  Y N U N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

1) Racking wrench is loosely attached to bay no. 2 and it would impact the front of this bay of switch gear in a seismic event. IF it is determined that there are essential relays in this bay, the impact could potentially chatter the relays. outlier OSVS-9012.

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO  (1)

Evaluated by: F. Ben:

Date: 9-12-95

Evaluated by: John A. Dixon

Date: 9/18/95





SSEL Line No. 9012 ( OSVS-9012 )

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number 0-BDAA-211-0000A Equipment Class 03-MVSG

Equipment Location: Bldg. RB-111 Floor Elevation 621'-3"

Room or Row/Column R-R2 Base Elevation 621'-3"

Equipment Description 4KV SHDN BD A

2. OUTLIER ISSUE DEFINITION


a. Identify all the screening guidelines which are not met.  
(Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>		<u>Tanks and Heat Exchangers</u>	
Capacity vs. Demand	<input type="checkbox"/>	Shell Buckling*	<input type="checkbox"/>
Caveats	<input type="checkbox"/>	Anchor Bolts and Embedment	<input type="checkbox"/>
Anchorage	<input type="checkbox"/>	Anchorage Connections	<input type="checkbox"/>
Seismic Interaction	<input checked="" type="checkbox"/>	Flexibility of Attached Piping*	<input type="checkbox"/>
Other	<input type="checkbox"/>	Other	<input type="checkbox"/>
		<u>Cable and Conduit Raceways</u>	
<u>Essential Relays</u>		Inclusion Rules	<input type="checkbox"/>
Capacity vs. Demand	<input type="checkbox"/>	Other Seismic Performance Concerns	<input type="checkbox"/>
Mounting, Type, Location	<input type="checkbox"/>	Limited Analytical Review	<input type="checkbox"/>
Other	<input checked="" type="checkbox"/>	Other	<input type="checkbox"/>

\* Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

A breaker racking wrench is loosely attached  
to bay No. 2 of this switchgear. In a seismic  
event this wrench will interact with the panel  
it is attached to (it will "bang" into it). This  
impact by the wrench could chatter relays in this  
bay.



ASSEL Line No. 9012 (OSVS-9012)

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number 0-BDAA-211-0000A

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

1) IF the relay raised identifies this bay to include essential relays then the wrench needs to be removed from the bay or positively attached to it such that any interaction would be precluded.

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

↳ issue work Request

N/A  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

FARZIN BEGI  
Print or Type Name

Farzi Begi  
Signature

9-12-95  
Date

JOHN O. DIZON, P.E.  
Print or Type Name

John O. Dizon  
Signature

9/18/95  
Date

\_\_\_\_\_  
Print or Type Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date



Asset Line No. 9006

Status  Y  N  U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 35

Equip. ID No. 2-XFA-253-0002A1 Equip. Class 04 - Transformers

Equipment Description 480V-120/208V XFMR FOR I&C BUS 2A

Location: Bldg. RB Floor Et. 621'-3" Room, Row/Col P-R13

Manufacturer, Model, Etc. (optional but recommended) SQUARE D, 75 KVA, 3 phase

SEISMIC CAPACITY VS DEMAND

- |  |   |
|--|---|
| 1. Elevation where equipment receives seismic input      | <u>621'-3"</u>  |
| 2. Elevation of seismic input below about 40' from grade | <input checked="" type="radio"/> Y <input checked="" type="radio"/> N <input type="radio"/> U (1) |
| 3. Equipment has fundamental frequency above about 8 Hz  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U N/A (2)        |
| 4. Capacity based on:                                    |   |
| Existing Documentation                                   | DOC   |
| Bounding Spectrum  | BS  |
| 1.5 x Bounding Spectrum                                  | ABS   |
| GERS   | <input checked="" type="radio"/> GERS   |
| 5. Demand based on:                                      |   |
| Ground Response Spectrum                                 | GRS   |
| 1.5 x Ground Response Spectrum                           | AGS   |
| Conserv. Des. In-Str. Resp. Spec.                        | CRS   |
| Realistic M-Ctr. In-Str. Resp. Spec.                     | <input checked="" type="radio"/> RRS  |

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)  Y  N  U (3,10) \*

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |  |
|--|--|
| 1. Equipment is included in earthquake experience equipment class  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U N/A                       |
| 2. 4.16 KV rating or less  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U N/A                       |
| 3. For floor-mounted dry- and oil-type unit, transformer coils are positively restrained within cabinet  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U N/A                       |
| 4. For 750 kVA or larger units, coils are top braced or adequacy shown by evaluation   | <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |
| 5. For 750 kVA or larger units, 2-inch clearance is provided between energized component and cabinet   | <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |
| 6. For 750 kVA or larger units, the slack in the connection between the high-voltage leads and the first anchor accomodates 3-inch relative displacement | <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |
| 7. For wall-mounted units, transformer coils anchored to enclosure near enclosure support surface  | <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |
| 8. For floor-mounted units, anchorage does not rely on weak-way bending of cabinet structures under lateral forces                                       | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U N/A (9)                   |
| 9. Adjacent cabinets which are close enough to impact are bolted together if they contain essential relays   | <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |
| 10. All doors secured by latch or fastener   | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U N/A                       |
| 11. Anchorage adequate (See checklist below for details)   | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U N/A (8)                   |
| 12. Relays mounted on equipment evaluated <i>on by also in relays deemed essential (6)</i>   | <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |
| 13. Have you looked for and found no other adverse concerns?   | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U N/A                       |

Is the intent of all the caveats met for Bounding Spectrum?  Y  N  U N/A



Equip. ID No. 2-XFA-253-0002A1 Equip. Class 04 - Transformers

Equipment Description 480V-120/208V XFMR FOR I&C BUS 2A

CAVEATS - GERS

- |   |     |   |   |       |
|---|-----|---|---|-------|
| 1. Equipment is included in generic seismic testing equipment class                 | (Y) | N | U | N/A   |
| 2. Meets all Bounding Spectrum caveats  | (Y) | N | U | N/A   |
| 3. Dry-type unit (not oil-filled)   | (Y) | N | U | N/A   |
| 4. Wall or floor-mounted NEMA-type enclosure  | (Y) | N | U | N/A   |
| 5. 120 to 480 VAC rating  | (Y) | N | U | N/A   |
| 6. 7.5 to 225 KVA rating  | (Y) | N | U | N/A   |
| 7. 180 to 2000 pound weight   | (Y) | N | U | N/A   |
| 8. Internal supports provide positive attachment of transformer components          | (Y) | N | U | N/A   |
| 9. There is a minimum clearance of 3/8 inches between bare conductors and enclosure | (Y) | N | U | N/A   |
| 10. All adjacent cabinets or sections of multi-bay assemblies bolted together       | Y   | N | U | (N/A) |
- Is the intent of all the caveats met for GERS? (Y) N U N/A

ANCHORAGE

- |  |     |   |   |           |
|--|-----|---|---|-----------|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)   | (Y) | N | U | N/A (4,5) |
| 2. Type of anchorage covered by GIP (Exp. Anch.)   | (Y) | N | U | N/A (4,5) |
| 3. Sizes and locations of anchors determined   | (Y) | N | U | N/A       |
| 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness  | (Y) | N | U | N/A       |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | (Y) | N | U | N/A       |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | (Y) | N | U | N/A       |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | Y   | N | U | (N/A)     |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | (Y) | N | U | N/A (9)   |
| 9. Strength of equipment base and load path to CG adequate   | (Y) | N | U | N/A (9)   |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | Y   | N | U | (N/A)     |
- Are anchorage requirements met? (Y) N U (8)

INTERACTION EFFECTS

- |   |     |   |   |         |
|---|-----|---|---|---------|
| 1. Soft targets free from impact by nearby equipment or structures  | (Y) | N | U | N/A (6) |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | Y   | N | U | (N/A)   |
| 3. Attached lines have adequate flexibility   | (Y) | N | U | N/A     |
| 4. Overhead equipment or distribution systems are not likely to collapse                                    | (Y) | N | U | N/A (7) |





Equip. ID No. 2-XFA-253-0002A1 Equip. Class 04 - Transformers

Equipment Description 480V-120/208V XFMR FOR I&C BUS 2A

INTERACTION EFFECTS (Cont'd)

5. Have you looked for and found no other adverse concerns?  N  U  N/A  
Is equipment free of interaction effects?  N  U

IS EQUIPMENT SEISMICALLY ADEQUATE?  N  U

COMMENTS

- 1) Effective grade for RBZ is @ EL. 550' (Adj. Calc. CD-90000-940339)
- 2) The fundamental frequency of this transformer is judged to be greater than 8 Hz due to rigid mounting configuration of its coil, small mass and reinforced base channel. Additionally, per EPRI Report TR-102180 the fundamental frequency of Transformers < 750 KVA is greater than 8 Hz (See also Note 10)
- 3) Per Calc. CD-90000-940339, Rev. 0, Figure B.3A, the 1.5x Instructure SSE Response Spectra (i.e., Realistic Median Centered Instructure Response spectrum) exceeds the GERS for Transformers in the frequency range of about 5.5 Hz to 6.2 Hz. Since the lowest frequency of this transformer is estimated to be greater than 8 Hz (see note 2) the intent of the Capacity vs. Demand criteria is met. ok

- Notes 4 thru 9 continued on sheets 4 & 5.


10) Furthermore, the above transformer (75 KVA) is also seismically qualified [\*] by comparison to similar transformer (45 KVA) that was tested per IEEE 344-75 requirements. The 75 KVA transformer base mounting bracket and base mounting dimension were increased to lower the resulting stresses and increase the natural frequency, based on comparable test results from the 45 KVA transformer. (Wyle Test Report # 44509-1, 5/14/80)

JOJ 9/21  
B 9/21

Evaluated by: Fozzi Beig  
John O. Dizon

Date: 7-21-95  
7/25/95

[\*] seismic qualification documented in a letter from B.R. Rich (Square D Co.) to Anita Helton (TVA) dated 1/21/81.





JOB NO. 50147.05 JOB TWA/BFW A-46/1PEEF

BY 78ej DATE 7-21-

CALC. NO. NA SUBJECT 2-XFA-253-0002A1 (SSEL # 9006)

CHK'D J. Dizon DATE 7/25/9


SSEL No. 9006, 9008

(photos; R1, F 9 & 10)

Comp-1D: 2-XFA-253-0002A1, 2B1

Manufacturer: SQUARED Company  
75 KVA, 3 phase


Note 4) - as-built sketch



5) - C.G. @ center of the Transformer (Conservative)

6) - Fire Extinguisher near by not supported positively may fall & impact the transformer. Judged ok since Transf. is enclosed by 3/32 thick steel & does not have any soft targets or relays.

7) - Fluorescent lights above this comp. are potential interaction hazard. but it is insignificant (see above note)







JOB NO. SD147.05 JOB TVA/BFN A-46/PEEE BY FBeji DATE 7-21-9  
 CALC. NO. N/A SUBJECT 2-XFA-253-0002A1 CHK'D Wilson DATE 7/25/9  
 (SSEL # 9006)

SSEL No. 9006

Equip. ID. 2-XFA-253-0002A1

8) Anchorage Evaluation:

WT = 385 # (similar to the transformer analyzed in Calc. CD-Q30+3-9309 Rev.)

Conservatively use peak accelerations @ RB, EL 621'-3", 5% Damping, SS

$$a_h^{\text{Peak}} = 2.15 g \quad (\text{Ref: CEB-88-05-C, Rev.1})$$

$$a_v^{\text{Peak}} = 0.66 g$$

T = Resultant pullout load per 1/2"  $\phi$  Exp. Anchor

for median-centers spectra

$$T = \left[ \left( \frac{385 \# \times 2.15 g \times 20.5''}{28'' \times 2} \right)^2 + \left( \frac{385 \# \times 2.15 g \times 20.5''}{17'' \times 2} \right)^2 + \left( \frac{385 \# \times 0.66 g}{4} \right)^2 \right]^{1/2} \times 1.25$$

$$= \frac{385 \#}{4} = 638 \# < T_{all} = 2.29^k \times \frac{3600}{4000} = 2.06^k \quad (\text{Ref. GIP, App. C})$$

L<sub>f</sub> Red. Factor

V = Resultant shear load per 1/2"  $\phi$  Anchor

$$= \sqrt{2} (385 \# \times 2.15 g \times 1.25) / 4 = 366 \# < V_{all} = 2.38^k ; \frac{V}{V_{all}} < 0.3$$

$$IR = \frac{638}{2060} = \underline{\underline{0.31}} < 1.0 \quad \underline{\underline{OK}}$$

9) - Base channel

The stress in the base channel is very small by inspection and due to the fact that the channel flanges are reinforced @ the anchor points by L 1/2 x 1/2 x 3/16 members.



SSEL Line No. 9006

Status Y N U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-XFA-253-0002A1 Equip. Class 04 - Transformers

Equipment Description 480V-120/208V XFMR FOR I&C BUS 2A

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U (N/A)

2. Are essential relays required to function during earthquake screened out? Y N U (N/A)

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y N U (N/A)

Requirements for relays satisfied? (Y) N U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet? (Y) N U N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY. (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES ✓ NO    

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES ✓ NO    

Evaluated by: Farzi Beigi

Date: 7-21-95

Evaluated by: John O. Dizon

Date: 7/25/95





**SQUARE D COMPANY**  
ELECTRICAL EQUIPMENT

BORGEL TRANSFORMERS

(414) 394-8100



838 WEST NATIONAL AVE.

MILWAUKEE, WIS. 53204

P.O. BOX 04548

CERTIFICATION

The transformers described in the following documentation are nuclear qualified based on previous test data from similar equipment. This similar equipment operated properly before, during and after the Qualification Test Program performed at the Wyle Laboratories and as recorded in Wyle Test Report No. 44509-1. (One copy included for documentation).

State of Wisconsin ) ss Wisconsin Professional Engineer  
County of Milwaukee) License No. E 10174

Marvin O. Kanter, being duly sworn, desposes and says: The information contained in this report is the result of complete and carefully conducted tests and is to the best of his knowledge true and correct in all respects.

Marvin O. Kanter

SUBSCRIBED and sworn to before me this 26<sup>TH</sup> day of FEBRUARY, 19 81.

[Signature]

Notary Public for the County of Milwaukee, State of Wisconsin.

My Commission expires 29<sup>TH</sup> FEBRUARY, 19 81.

0000020183



RECEIVED REPORT

SHIPPER'S NAME <b>SQUARE "D" COMPANY</b>		SHIPMENT TYPE <b>SAFE</b>	SHIPMENT NUMBER <b>6601-01436</b>
SHIPMENT POINT <b>ATLANTA, GA.</b>		ORIGIN POINT <b>BROWNS FERRY NUCLEAR PLANT</b>	SHIPMENT CLASSIFICATION <b>POWER STOREROOM MODIFICATIONS</b>
DELIVERY METHOD <b>GRANT EXPRESS</b>		SHIPMENT WEIGHT <b>1330 LB</b>	SHIPMENT DATE
SHIPMENT ID <b>3-353883 7</b>		SHIPMENT TYPE <input type="checkbox"/> COMPLETE <input type="checkbox"/> PARTIAL <input type="checkbox"/> FINAL	SHIPMENT TRACKING NUMBER <b>707633-31159-02344</b>

CONF. ITEM NO.	ARTICLES OR SERVICES	CLASS. BIN OR STOCK NO.	QUAN. RECD.	UNIT	UNIT PRICE	AMOUNT
1	TRANSFORMER, DRY TYPE, 75 KVA, 3 PHASE, 480V DELTA PRIMARY, SECONDARY 208Y/120V, 60 HERTZ FLOOR MOUNTED, 220 DEG INSULATION SYS, INS CL H, MAX TEMP RISE 80 DEG, IMPEDANCE 4.0, ALUM WINDINGS, CLASS 1E, STANDARD INDOOR ENCLOSURE SERIAL NO. - 156541-1 156541-4 156541-2 156541-5 156541-3 156541-6 MFG. BY SQUARE "D" CO. TVA QC CHECKLIST AND SHIPPING RELEASE FURNISHED QUALIFICATION TEST PER BULLETIN NEG-80 TO DEMONSTRATE COMPLIANCE OF ITEM 1 WITH ICC 323- 1974 AND 344-1975	0810-8	6	EA		


**DIRECT CHARGE**

CC: JERRY DEWENT, OUTAGE SECTION, BEMP  
RON BORUM, EXPEDITOR, 350 CURB-C

**COMPLETE**

Carrier's Charges	Collect \$	179.71	XXX
Date Material Was Received	8 APRIL 81		
I certify that the articles or services listed above have been received and are in accordance with the invoice unless noted.			
Addressed as Reported Above:		Signature: <b>RUDIE J. [unclear]</b>	

4. Since items are not returned, the carrier is not responsible for non-delivery items, return, or loss of items.  
5. Retained by carrier for 90 days after date of invoice.  
6. Extra.



**SQUARE D COMPANY**  
ELECTRICAL EQUIPMENT



16181 677-1381

4220 DAYTON BOULEVARD POST OFFICE 18820 CHATTANOOGA, TENNESSEE 37415

January 21, 1981

Ms. Anita Helton  
Tennessee Valley Authority  
Division of Purchasing  
400 Commerce Union Bank Bldg.  
633 Chestnut St.  
Chattanooga, TN 37401

Subject: TVA Ref. #6-828602

Dear Ms. Helton:

This letter is to confirm our phone conversation wherein I advised you that we would supply additional material in the form of a documentation of test results on the 45KVA transformer and the calculations necessary to show how these test results can be applied to the 75KVA transformer to show that it does meet your seismic requirements.

Shipment can be made in order for material to arrive at the job site by April 1, if the order is received by January 23, with the following requirements:

1. Approval drawings are waived by TVA. Drawings will be for record.
2. TVA will accept previous qualification data. No additional testing required.


If you have any questions concerning the documentation of test results and their application to the 75KVA transformer, you may contact Ron Franzen at (414) 384-8100.

Very truly yours,

SQUARE D COMPANY


*B. R. Rich*  
B. R. Rich  
Senior Field Representative

BR/mc



U 0 0 0 2 0 1 7 4

JAN 22 1981



**SQUARE D COMPANY**  
ELECTRICAL EQUIPMENT

SQRJFL TRANSFORMERS

(414) 384-8100



838 WEST NATIONAL AVE.  
P.O. BOX 04548

MILWAUKEE, WIS. 53204

**Nuclear Environmental Qualification  
of Class 1E Transformers**

**Tennessee Valley Authority  
1010 Georgia Ave.,  
Chattanooga, Tennessee**

**Tennessee Valley Authority  
Brown's Ferry Nuclear Plant  
Near Athens, Alabama**

**Project Identification  
Contract No. 81P6-828602  
Specification No. 6-828602**

0000020182





**SQUARE D COMPANY**  
ELECTRICAL EQUIPMENT

3000 PL TRANSFORMERS

(414) 384-8100



838 WEST NATIONAL AVE.  
P.O. BOX 04349

MILWAUKEE, WIS. 53204

DOCUMENTATION

Method of Qualification:

The equipment required for this contract specification is seismically qualified in accordance with IEEE 344-1975 and meets all environmental requirements of IEEE 323-1974 as described in Test Report No. 44509-1.

I. Description of both equipment

- A. Tested equipment is rated 45 KVA, three phase, 60 Hertz, 480 volt delta primary to 208Y/120 volt secondary, 115°C rise transformer. Dimensions and physical description as shown on comparison analysis sheet B-111113 with modification per drawing A-103247.
- B. Equipment to be supplied on this contract is rated 75 KVA, three phase, 60 Hertz, 480 volt delta primary to 208Y/120 volt secondary, 80°C rise transformer. Dimensions and physical description as shown on comparison analysis sheet B-111118 and drawing A-111117 with modification per drawing A-103247. Electrical connections and wiring details as per drawing A-109886.

II. Test data on original equipment

- A. Wyle Laboratories nuclear environmental qualification test report No. 44509-1 provides complete test data on the original equipment.
- B. The environmental limits for temperature, pressure, humidity and radiation are defined in the qualification plan Section II, page 12.

U 0 0 0 0 2 0 1 8 4



- 000020185
- C. The age-sensitive materials involved are listed on Page 34, Figure 1 of the qualification plan. The qualified life for 80°C rise transformers is 59 years at 100% load. Qualified life at other conditions are listed in Table III, Page 30 of the qualification plan.
  - D. Documentation Figure No. 1 is a comparative plot of the horizontal TRS at 3% damping using composite response spectra taken from test report No. 44509-1 Pages IX-56 and IX-66 showing a ZPA of 3.2 g compared with the response acceleration spectra in Appendix A of Spec. 6-828602. The data on this floor spectra was doubled for an equivalent horizontal SSE and shown as the RRS with a ZPA of 0.5 g.
  - E. Documentation Figure No. 2 is a comparative plot of the vertical TRS at 3% damping using composite response spectra taken from test report No. 44509-1 Pages IX-57 and IX-67 showing a ZPA of 3.8 g compared with the response acceleration spectra in Appendix A of Spec. 6-828602. The data on this floor spectra was doubled for an equivalent horizontal SSE and then reduced to 2/3 horizontal response for an equivalent vertical SSE and shown as the RRS with a ZPA of 0.33 g.

III. Detailed description of difference between the two equipments.

- A. The enclosure housing on both designs is the same part 43005-033-50.
- B. The same mounting bolts and ESNA type elastic stop nuts are used to fasten the base mounting brackets to the enclosure base.
- C. The base mounting brackets of the test unit were made from 1/2" x 1-1/2" iron bar. The base mounting brackets of the transformer to be supplied will have base mounting brackets of 1/2" x 2" iron bar.
- D. The transformer to be supplied will be very similar in electrical design and overall weight to the tested transformer, however, the center of gravity will be one inch higher.



## IV. Justification of Data.

- U 0 0 0 0 2 0 1 8 6
- A. The nuclear environmental qualification test plan No. 44509-1 is a generic program to qualify a line of transformers. The qualification will satisfy any specification whose environmental conditions fall within the worst-case environments defined in Paragraph 1.0, Section II of the plan. Since the transformer to be furnished incorporates the same age-sensitive materials as the tested transformer, the documentation satisfies the qualification of this unit.
- B. The seismic acceptability of the transformer to be furnished is covered by comparison analysis with the tested transformer per paragraph 3.1.1, Section I of the plan. The data necessary to make both the static and dynamic comparison of the two transformers is given on drawing B-111118. Since the furnished transformer's center of gravity was found to be higher, the stresses and fundamental frequency were adjusted by increasing the size of the base mounting brackets and by increasing the base mounting dimension (d) by 2 inches. These modifications had the effect of lowering the normalized stresses and increasing the fundamental frequency and thus satisfying the qualification of this unit.
- C. With reference to the Documentation Curves Figures 1 and 2, taking into account that the TRS is plotted at 3% damping and that at 2% damping it would have an even higher g peak level in the flexible frequency range of 1 to 20 Hz and thus envelope the RRS with an even greater margin, this variation in damping can be ignored since the important consideration is the comparison of the Zero Period Acceleration (ZPA) between the two curves.
- D. Comparison of the ZPA levels indicates that the tested transformer passed tests at levels six times greater in the horizontal and eleven times greater in the vertical than those required in Appendix A of Spec. 6-828602. This wide margin or factor of safety in seismic activity should be ample to justify the qualification of the transformers to be supplied on this contract.






# SORDEL TRANSFORMERS SQUARE D COMPANY

MILWAUKEE WISCONSIN  
DOCUMENTATION

FIG. NO. 1

FULL SCALE SHOCK SPECTRUM (G PEAK)




0.0002  
0.0003  
0.0005  
0.001  
0.002  
0.003  
0.005  
0.01  
0.02  
0.03  
0.05  
0.1  
0.2  
0.3  
0.5  
1  
2  
3  
5  
10  
20  
30  
50  
100

K/E

FREQUENCY (HZ)

SSE HORIZONTAL RESPONSE SPECTRUM








**SQUARE D COMPANY**

MILWAUKEE WISCONSIN


DOCUMENTATION

FIG. NO. 2


FULL SCALE SHOCK SPECTRUM (G PEAK)




SSE VERTICAL RESPONSE SPECTRUM








000002 0190 DWG. NO. A-103247




TOP VIEW

1/4" x 3.0 x 4.0 ANGLE



FRONT & REAR VIEWS



END VIEW

DWG. NO. A-103247

NO.	REVISION	DATE

DETAILS OF WELDING 3x4.0 ANGLE TO BASE MOUNTING BRACKET & CORE CLAMPING ANGLES.





SORDEL TRANSFORMERS  
**SQUIRE COMPANY**  
 MILWAUKEE WISCONSIN

DRAWN BY  
 DATE  
 JOB NO.



DWG. NO. A-111117



SPACE AVAILABLE ON BOTH ENDS FOR CUSTOMER CONDUIT

SPACE AVAILABLE IN BOTTOM FOR CUSTOMERS CONDUIT

FOR CENTER OF GRAVITY SEE DWG. B-111118

DWG. NO. A-111117

ALUMINUM WOUND  
PAINT - ANSI 61 LIGHT GRAY.  
TVA CONTRACT. NO. 81P6-828602

KVA 75 PHASE 3 HERTZ 60  
 HIGH VOLTAGE 480 DELTA  
 HIGH VOLT. TAPS (6) 2.5%, 2+ & 4-  
 LOW VOLTAGE 208Y/120  
 TYPE S0 NET WEIGHT 690 LBS.  
 220°C INS. SYSTEM FOR 80 °C. RISE  
 IMPEDANCE APPROX. 4.5%

CHECKED BY: *KFL* 2-16-81

DIMENSION PRINT FOR THREE-PHASE INSULATED TRANSFORMER  
SEISMIC CLASS IE




SORGEL TRANSFORMERS  
**SQUARE D COMPANY**  
MILWAUKEE WISCONSIN

DRAWN BY B. D. J.  
DATE 2-13-81


JOB NO.

NO.	REVISION	DATE





DWG. NO. A-109886



CONNECTIONS

WINDING	VOLTAGE	AMPERES	CONNECT TO TAP
	504	86	1
	492	88	2
	480	90	3
	468	93	4
	456	95	5
	444	98	6
	432	100	7
LOW VOLTAGE	208Y/120	208	

75 KVA 3 PHASE 60 Hz  
 HIGH VOLTAGE 480  
 LOW VOLTAGE 208Y/120  
 TYPE 80

DWG. NO. A-109886

CHECKED BY: *RFL* 2-16-81

TVA CONTRACT NO. 81P6-828602

WIRING DIAGRAM FOR THREE PHASE INSULATED TRANSFORMER.




SORGEL TRANSFORMERS  
**SQUARE COMPANY**

DRAWN BY B.U.  
 DATE 2-13-81

MILWAUKEE WISCONSIN

JOB NO.

NO.	REVISION	DATE







SSEL Line no. 9285  
AI

SCREENING EVALUATION WORK SHEET (SEWS)      Revision 2A  
Sheet 2 of 3

Equip. ID No. 2-JBOX-268-5991      Equip. Class 14 - Distribution Panels  
Equipment Description M-G Set 2DA Control Station (2-HS-268-0002DA)

ANCHORAGE

- |  |                                    |                         |                         |                                      |
|--|------------------------------------|-------------------------|-------------------------|--------------------------------------|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)   | <input checked="" type="radio"/> Y | <input type="radio"/> N | <input type="radio"/> U | <input type="radio"/> N/A            |
| 2. Type of anchorage covered by GIP  | <input checked="" type="radio"/> Y | <input type="radio"/> N | <input type="radio"/> U | <input type="radio"/> N/A            |
| 3. Sizes and locations of anchors determined   | <input checked="" type="radio"/> Y | <input type="radio"/> N | <input type="radio"/> U | <input type="radio"/> N/A            |
| 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness  | <input type="radio"/> Y            | <input type="radio"/> N | <input type="radio"/> U | <input type="radio"/> N/A            |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | <input checked="" type="radio"/> Y | <input type="radio"/> N | <input type="radio"/> U | <input type="radio"/> N/A            |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | <input checked="" type="radio"/> Y | <input type="radio"/> N | <input type="radio"/> U | <input type="radio"/> N/A            |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | <input type="radio"/> Y            | <input type="radio"/> N | <input type="radio"/> U | <input checked="" type="radio"/> N/A |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | <input checked="" type="radio"/> Y | <input type="radio"/> N | <input type="radio"/> U | <input type="radio"/> N/A            |
| 9. Strength of equipment base and load path to CG adequate   | <input checked="" type="radio"/> Y | <input type="radio"/> N | <input type="radio"/> U | <input type="radio"/> N/A            |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | <input type="radio"/> Y            | <input type="radio"/> N | <input type="radio"/> U | <input checked="" type="radio"/> N/A |
- Are anchorage requirements met?       Y    N    U    (3)

INTERACTION EFFECTS

- |   |                                    |                         |                         |                                      |
|---|------------------------------------|-------------------------|-------------------------|--------------------------------------|
| 1. Soft targets free from impact by nearby equipment or structures  | <input checked="" type="radio"/> Y | <input type="radio"/> N | <input type="radio"/> U | <input type="radio"/> N/A            |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | <input type="radio"/> Y            | <input type="radio"/> N | <input type="radio"/> U | <input checked="" type="radio"/> N/A |
| 3. Attached lines have adequate flexibility   | <input checked="" type="radio"/> Y | <input type="radio"/> N | <input type="radio"/> U | <input type="radio"/> N/A            |
| 4. Overhead equipment or distribution systems are not likely to collapse                                    | <input checked="" type="radio"/> Y | <input type="radio"/> N | <input type="radio"/> U | <input type="radio"/> N/A            |
| 5. Have you looked for and found no other adverse concerns?   | <input checked="" type="radio"/> Y | <input type="radio"/> N | <input type="radio"/> U | <input type="radio"/> N/A            |
- Is equipment free of interaction effects?       Y    N    U

IS EQUIPMENT SEISMICALLY ADEQUATE?

- Y    N    U
- (1) Component is rigidly mounted to the wall close to the floor elevation;  $f > 8\text{ Hz}$ , by judgment.
- (2) Per calc. CD-Q0000-940339, h-structure spectra @ RB E1.639' (seismic demand) exceeds the capacity (1.5 x Bounding spectrum) at and beyond the component's lowest bound fundamental frequency ( $> 8\text{ Hz}$ ). The intent of the GIP is met.



SSEL Line no. 9285  
AI

SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2A  
Sheet 3 of 3

Equip: ID No. 2-JBOX-268-5991 Equip. Class 14 - Distribution Panels

Equipment Description MG Set 2DA Control Station (2-175-268-0002DA)

COMMENTS

(3) Component is small + light weight. Tag test demonstrates adequate anchorage.

Evaluated by:

John O. Dixon

Date:

1/12/96

J.R. Sissore

1/12/96





SSEL Line No. 9285  
AI

Status  Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-JBox-268-5991 Equip. Class 14- Dist. Panels  
Equipment Description M-G Set 2DA Control Station (2-115-268-0002DA)

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U  N/A

2. Are essential relays required to function during earthquake screened out? Y N U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns?  Y  N  U N/A

Requirements for relays satisfied?  Y  N  U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?  
YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: John O. Dizan

Date: 1/12/96

Evaluated by: J.R. Disser

Date: 1/12/96



SSEZ No. 9406

INTENT

Revision 2A  
Status

Y (N) U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 34

Equip. ID No. Z-CHGD-283-A1-2 Equip. Class 16 - Battery Chargers & Inverters

Equipment Description ± 24V NEUTRON MONITOR BATTERY CHARGERS A1-2

Location: Bldg. CB Floor Et. 593 Room, Row/Col BATTERY BOARD-ROOM 2

Manufacturer, Model, Etc. (optional but recommended) GENERAL ELECTRIC ±24V

SEISMIC CAPACITY VS DEMAND

- Elevation where equipment receives seismic input
- Elevation of seismic input below about 40' from grade
- Equipment has fundamental frequency above about 8 Hz
- Capacity based on: Existing Documentation  
Bounding Spectrum  
1.5 x Bounding Spectrum  
GERS
- Demand based on: Ground Response Spectrum  
1.5 x Ground Response Spectrum  
Conserv. Des. In-Str. Resp. Spec.  
Realistic M-Ctr. In-Str. Resp. Spec.

598'  
Y (N) U N/A  
(Y) N U N/A NOTE 1  
DOC  
BS  
(ABS)  
GERS  
GRS  
AGS  
CRS  
(RRS)

Does capacity exceed demand? (Indicate at right (\*)) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)

(Y) N U  
\* NOTE 1

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- Equipment is included in earthquake experience equipment class
- Solid state type
- For floor-mounted, transformer positively anchored and mounted near base, or load path is evaluated
- Base assembly of floor-mounted unit properly braced or stiffened for lateral forces
- For wall-mounted units, transformer supports and bracing provide adequate load path to the rear cabinet wall *XMFR secured w/ 4-1/4" φ bolts to internal frame*
- All latches and fasteners in doors secured
- Anchorage adequate (See checklist below for details)
- Relays mounted on equipment evaluated *AF = 3.0*
- Have you looked for and found no other adverse concerns?

(Y) N U N/A  
(Y) N U N/A  
Y N U (N/A) NOTE 2  
Y N U (N/A) NOTE 2  
(Y) N U N/A NOTE 2  
Y N U (N/A)  
(Y) (N) U N/A NOTE 2  
(Y) N U N/A NOTE 3  
(Y) N U N/A

Is the intent of all the caveats met for Bounding Spectrum?

(N) U N/A

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- Equipment is included in generic seismic testing equipment class
- Meets all Bounding Spectrum caveats

Y N U (N/A)  
Y N U (N/A)



SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2A  
Sheet 2 of 3/4

Equip. ID No. Z-CHGN-203-A1-2 Equip. Class 16 - Battery Chargers & Inverters

Equipment Description ±24 V NEUTRON MONITOR BATTERY CHARGERS A1-2

CAVEATS - GERS (Cont'd)

3. Silicon-Controlled Rectifier (SCR) power controls; wall- or floor-mounted NEMA-type enclosure
4. Within range of battery charger ratings:  
24-250 VDC  
120-480 VAC  
25-600 amps  
150-2850 pounds (floor-mounted)  
150-600 pounds (wall-mounted)
5. Within range of inverter ratings:  
120 VDC only  
120-480 VAC  
0.5-15 KVA  
300-2000 pounds
6. Heavy components are located in lower half of cabinet and are supported from base or rear panel with no panel cutouts adjacent to attachment

Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A

Is the intent of all the caveats met for GERS?

Y N U N/A

ANCHORAGE

1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)
2. Type of anchorage covered by GIP
3. Sizes and locations of anchors determined
4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness
5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking
6. For bolted anchorages, gap under base less than 1/4-inch
7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors
8. Base has adequate stiffness and effect of prying action on anchors considered
9. Strength of equipment base and load path to CG adequate
10. Embedded steel, grout pad or large concrete pad adequacy evaluated

<u>Y</u>	N	U	N/A
Y	N	<u>U</u>	N/A
Y	N	<u>U</u>	N/A
Y	N	<u>U</u>	N/A
Y	N	<u>U</u>	N/A
Y	N	<u>U</u>	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	U	N/A
Y	N	<u>U</u>	N/A

Are anchorage requirements met?

Y N U

INTERACTION EFFECTS

1. Soft targets free from impact by nearby equipment or structures
2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures

<u>Y</u>	N	U	N/A
<u>Y</u>	N	U	N/A



Equip. ID No. 2-CHGD-283-A1-2 Equip. Class 16 - Battery Chargers & Inverters

Equipment Description +24V NEUTRON MONITOR BATTERY CHARGERS A1-2

INTERACTION EFFECTS (Cont'd)

- 3. Attached lines have adequate flexibility  Y  N  U  N/A NOTE 4
- 4. Overhead equipment or distribution systems are not likely to collapse  Y  N  U  N/A
- 5. Have you looked for and found no other adverse concerns?  
Is equipment free of interaction effects?  Y  N  U  N/A

IS EQUIPMENT SEISMICALLY ADEQUATE?  Y  N  U

COMMENTS

1. THE BATTERY CHARGER IS RIGIDLY MOUNTED TO THE WALL WITH 4 - 3/8"  $\phi$  DIAMETER ANCHORS USING WASHERS AS SPACERS TO PROVIDE ABOUT 1/2" CLEARANCE FROM THE WALL. TEST RESULTS INDICATE THE NATURAL FREQUENCY OF TYPICAL WALL MOUNTED BATTERY CHARGERS TO BE GREATER THAN 8 HZ (REFER TO EPR1 TR-102180). THE 593' REACTOR BUILDING ELEVATION RES EXCEEDS THE ABS IN THE FREQUENCY RANGE OF 5.5-6.2 HZ. BECAUSE THE NATURAL FREQUENCY OF THE BATTERY CHARGER IS GREATER THAN 8 HZ, THE CAPACITY SPECTRUM ENVELOPES THE DEMAND SPECTRA AND THE INTENT OF THE CHARGE IS MET.
2. THE BATTERY CHARGER IS WALL MOUNTED USING 4 - 3/8"  $\phi$  ANCHORS. HOWEVER, THE ANCHORS ARE MOUNTED IN A SEISMIC BLOCK WALL AND DETAILS OF THE ANCHORAGE USED ARE UNAVAILABLE, OUTLIER. SEE OSVS - 9406. SEE THE ATTACHED SKETCH OF THE BATTERY CHARGER AND VISIBLE ANCHORAGE DETAILS.
3. RELAYS ARE EVALUATED IN A SEPARATE PROGRAM. IT IS NOT KNOWN IF RELAYS ARE LOCATED IN THE CHARGERS.
4. CONDUIT EXITING/ENTERING THE TOP OF THE CHARGER ARE RIGID. CONDUIT EXITING/ENTERING THE BOTTOM OF THE CHARGER ARE FLEX CONDUITS. THE ATTACHED CONDUIT IS ACCEPTABLE AS THEY ARE ATTACHED TO THE SAME BLOCK WALL THE CHARGER IS MOUNTED ON.

evaluated by: John O. Dizer J.R. DISSER Date: 4/19/96  
4/19/96







EQE INTERNATIONAL


JOB NO. 50147 JOB 2-CHGA-283-A1-2

CALC. NO. N/A SUBJECT SSEL # 9406


- SHEET NO. 1/4

BY [Signature] DATE 4/19/86

CHK'D [Signature] DATE 4/19/86



FRONT OF WALL



~ 2X2X 1/16" THK. PL (TYP)

BACK OF WALL



SSEL Line No. 9406  
AI

Status Y  N  U  
Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. Z-CHGD-283-A1-2 Equip. Class 16-BATTERY CHARGERS  
Equipment Description 124V NEUTRON MONITOR BATTERY CHARGERS A1-2

RELAY WALKDOWN

- 1. Does spot check of essential relays indicate relays present and properly mounted?
- 2. Are essential relays required to function during earthquake screened out?

Y N U  N/A <sup>COULD NOT ACCESS INSIDE OF CHARGERS</sup>  
 N U N/A  
 RELAYS EVALUATED SEPARATELY

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

- 3. No other relay concerns?

N U N/A

Requirements for relays satisfied?

N U

SYSTEM INTERACTION EFFECTS

- 1. No potential sources could flood or spill onto cabinet?

N U N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

ADEQUACY OF ANCHORAGE IS INDETERMINATE.  
SEE OSUS - 9406

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?  
YES \_\_\_ NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO \_\_\_

Evaluated by: J.R. Dwyer J.R. Dwyer

Date: 4/19/96

Evaluated by: J.O. Dixon

Date: 4/19/96



OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number Z-CHGD-283-A1-2 Equipment Class 18 16

Equipment Location: Bldg. CB Floor Elevation 593

Room or Row/Column BATTERY BENCH RM 2 Base Elevation 598'

Equipment Description ±24V NEUTRON MONITOR BATTERY CHARGERS A1-2

2. OUTLIER ISSUE DEFINITION

a. Identify all the screening guidelines which are not met. (Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>	_____	<u>Tanks and Heat Exchangers</u>	_____
Capacity vs. Demand	_____	Shell Buckling*	_____
Caveats	_____	Anchor Bolts and Embedment	_____
Anchorage	<u>X</u>	Anchorage Connections	_____
Seismic Interaction	_____	Flexibility of Attached Piping*	_____
Other	_____	Other	_____
<u>Essential Relays</u>	_____	<u>Cable and Conduit Raceways</u>	_____
Capacity vs. Demand	_____	Inclusion Rules	_____
Mounting, Type, Location	_____	Other Seismic Performance Concerns	_____
Other	_____	Limited Analytical Review	_____
		Other	_____

\* Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

CHARGERS ARE MOUNTED ON A SEISMIC MASONARY BLOCK  
WALL USING 3/8" ANCHORS (NUTS ON STUDS VISIBLE;  
3-1/16" PLATES ON BACK OF WALL VISIBLE). NO DETAILS  
ARE AVAILABLE TO DETERMINE THE SEISMIC  
ADEQUACY OF THE ANCHORAGE.



OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number Z-CHGD-283-A1-2

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

LOCATE ANCHORAGE DETAILS AND EVALUATE OR  
INSTALL THROUGH BOLTS IN BLOCK WALL

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

SEE SKETCH IN THE SENS FOR THIS EQUIPMENT.

SEE  
ATTACHED  
SHEETS  
9/23/96

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

JAMES R. DISSOR [Signature] 4/19/96  
Print or Type Name Signature Date

JOHN DIZON, PE [Signature] 4/19/96  
Print or Type Name Signature Date

\_\_\_\_\_  
Print or Type Name Signature Date





24V Neutron Monitoring Battery Chargers

A1-2, A2-2, B1-2, & B2-2


SSEL # 9406, 9407, 9408, 9409

The 24V Neutron Monitoring Battery Chargers A1-2, A2-2, B1-2, & B2-2 are located in the Battery Board Room, Unit 2, floor elevation 593. They are mounted on the existing block wall adjacent to the MG-Motor Set room. There is no drawing available which shows the existing anchorage and mounting details to these chargers. It is clear, however, that each of these battery chargers are securely fastened to the block wall via 4 anchor bolts. (appear to be 1/2 inch or greater in diameter). If any plates were used as they were in Unit 3, they were inaccessible at the time of inspection. As was previously calculated for Unit 3, an analytical approach was used to determine an effective load on each of the anchors. That effective load was determined to be 47.6 lbs. To get this load it was assumed the chargers weighed (conservatively), 150 lbs. For the purpose of determining the anchorage inherent strength and ability to withstand seismic forces, a vertical live load (200 lbs +, full weight applied by R. T. Deal), was applied to the chargers. The result was no slip or damage to the chargers or existing anchors. Additionally, an approximate horizontal force of 100 lbs. was placed on the boxes. This also produced no damage, slip, or failures. These applied loads were applied and witnessed by R. T. Deal and J. W. Beason (9.10.96). Both agreed on results, i.e. the charger's anchorage inherent strength would prevent the chargers from falling during or after an SSE. (this of course is contingent upon the masonry block performing its function and remaining in place..

Currently, the EMS shows these chargers as quality-related. Therefore, being in the Reactor Building, they must maintain Class II/I criteria, i.e. not to fall in an SSE.


Based upon the anchorage geometry, rigidity of the chargers, inherent strength, and the added live load with no changes to support/anchorage integrity, it is concluded by engineering judgement that the chargers would remain on the block wall during and after an SSE.

Prepared:



Date: 9.11.96

Checked:



Date: 9-12-96




24 V NEUTRON MONITORING BATTERY CHARGERSA1-3, A2-3, B1-3 & B2-3(SSEL # 39307, 39308, 39309 & 39310)COMPUTED SSH DATE 8-6-96CHECKED RTD DATE 9-10-96

24V. NEUTRON MONITORING BATTERY CHARGERS A1-3, A2-3, B1-3 & B2-3 ARE LOCATED IN BATTERY BOARD ROOM UNIT-3. THEY ARE MOUNTED ON BLOCK WALL NEXT TO THE STAIRWELL. THERE IS NO DRAWING AVAILABLE TO DEPICT THE DETAIL OF THE ATTACHMENT TO THE BLOCK WALL. WHAT IS CLEARLY VISIBLE, IS THAT THERE ARE FOUR BOLTS ATTACHING EACH OF THE BATTERY CHARGERS TO THE BLOCK WALL. ON THE OTHER SIDE OF THE BLOCK WALL, THERE IS A PLATE  $\frac{1}{16}'' \times 2'' \times 2''$  AT THE LOCATION OF EACH ANCHOR. IN THE ABSENCE OF INFORMATION AVAILABLE ON THESE BATTERY CHARGERS AND THEIR SUPPORTS, S.S. HAIDER AND C.N. SIMMS, VISUALLY INSPECTED AND CONSERVATIVELY ESTIMATED WEIGHTS OF EACH CHARGERS AS 150 LBS.

FOLLOWING CALCULATION WILL DEMONSTRATE THAT 47.6 LBS. OF WEIGHT NEEDS TO BE HUNG FROM THE FRONTS OF THE CHARGERS, TO SIMULATE THE EFFECT OF SSE ON ANCHORS.

IN REALITY A PERSON WEIGHING 125 LBS. HUNG HIMSELF FROM EACH OF THE 4 BATTERY CHARGERS, WITHOUT ANY DETRIMENTAL EFFECT ON THE CHARGERS OR ITS SUPPORTS. THIS DEMONSTRATION WAS WITNESSED BY SEVERAL INDIVIDUALS, INCLUDING S.S. HAIDER, JOHNNY DUKE (SRO) AND DAVE WHITEHEAD (MOD). HENCE, IT IS CONCLUDED THAT THE SUPPORTS FOR THE BATTERY CHARGERS ARE ACCEPTABLE AS IS.

\* ON 9-10-96 R.T.O. ACCOMPANIED BY J.W. BEASON INSPECTED CHARGERS. R.T.O. APPLIED LOAD TO EACH CHARGER  $> 50 \frac{16}{16}$  LB.



COMPUTED SSH DATE 8/6/96CHECKED RSD DATE 9.10.96

BASED ON THE SIZE AND SHAPE OF THE CHARGERS, AND THE FACT THAT IT IS MOUNTED DIRECTLY ON THE WALL WITH 4 ANCHORS, IT IS JUDGED TO BE RIGID, AND ZPA IS USED TO CALCULATE SSE REACTION AT EACH ANCHOR.

PER CEM REPORT 88-05-C, EL. 621'-3":

$$g_H = 2 \times 0.19 = 0.38 g$$

$$g_V = 2 \times 0.08 = 0.16 g$$

$$H = 150 \times 0.38 = 57 \text{ LBS.}$$


$$V = 150 \times 1.16 = 174 \text{ LBS.}$$

$$\text{TENSION/ANCHOR} = \frac{57}{4} + \frac{174 \times 8}{20 \times 2} = 49.05 \text{ LBS.}$$


TO SIMULATE THE ABOVE EFFECT,  
CALCULATE THE MAGNITUDE OF P:

$$\frac{P(16)}{20 \times 2} + \frac{150 \times 8}{20 \times 2} = 49.05 \text{ LBS.}$$

$$\therefore P = 47.6 \text{ LBS.}$$



ELEV. LOOKING  
AT WALL



A-A



SSEL Line No. 9305

Revision 2, Corrected, 6/28/91  
Status  Y  N  U

SCREENING-EVALUATION WORK SHEET (SEWS)

Sheet 1 of 3

Equip. ID No. 2-LPNL-925-247A Equip. Class 18 - Instruments on Racks  
Equipment Description LOCAL Panel 2-25-247A (CAD Drawings & SUPRS CHM V)  
Location: Bldg. RR 2 Floor El. 621-3" Room, Row/Col Q, R11  
Manufacturer, Model, Etc. (optional) \_\_\_\_\_

SEISMIC CAPACITY VS DEMAND

- |  |      |  |
|--|------|--|
| 1. Elevation where equipment receives seismic input      | 626' | Y <input type="radio"/> N <input checked="" type="radio"/> U <input type="radio"/> (grade @ 550')                |
| 2. Elevation of seismic input below about 40' from grade |      | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A (1) |
| 3. Equipment has fundamental frequency above about 8 Hz  |      | DOC  |
| 4. Capacity based on: Existing Documentation             |      | BS   |
| 1.5 x Bounding Spectrum > Bounding Spectrum              |      | GERS <input checked="" type="radio"/> (ABS)  |
|  |      | GRS  |
| 5. Demand based on: Ground Response Spectrum             |      | GRS  |
| Ground <del>1.5 x</del> Bounding Spectrum                |      | ABS AGS  |
| Conserv. Des. In-Str. Resp. Spec.                        |      | CRS  |
| Realistic M-Ctr. In-Str. Resp. Spec.                     |      | <input checked="" type="radio"/> RRS   |

Does capacity exceed demand?  Y  N  U (3)\*


CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |  |
|--|--|
| 1. Equipment is included in earthquake experience equipment class  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A     |
| 2. No computers or programmable controllers  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A     |
| 3. Steel frame and sheet metal structurally adequate   | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A     |
| 4. Adjacent racks which are close enough to impact or sections of multi-bay racks are bolted together if they contain essential relays | Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A                           |
| 5. Natural frequency relative to 8 Hz limit considered   | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A     |
| 6. Attached lines have adequate flexibility  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A (2) |
| 7. Anchorage adequate (See checklist below for details)  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A (4) |
| 8. Relays mounted on equipment evaluated   | Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A                           |
| 9. Have you looked for and found no other adverse concerns?  | <input checked="" type="radio"/> Y <input type="radio"/> N <input type="radio"/> U <input type="radio"/> N/A     |

Is the intent of all the caveats met for Bounding Spectrum?  Y  N  U  N/A

CAVEATS - GERS (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |   |  |
|---|--|
| 1. Equipment is included in the generic seismic testing equipment class | Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |
| 2. Meets all Bounding Spectrum caveats                                  | Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |
| 3. Component is a pressure, temperature, level or flow transmitter      | Y <input type="radio"/> N <input type="radio"/> U <input checked="" type="radio"/> N/A |





SCREENING EVALUATION WORK SHEET (SEWS)

Equip. ID No. 2-LPNL-925-0247A Equip. Class 18 - Instruments on Racks

Equipment Description Panel 2-25-247A

CAVEATS - GERS (Cont'd)

- |  |   |   |   |             |
|--|---|---|---|-------------|
| 4. Component is one of the specific makes and models tested, as listed in Appendix B   | Y | N | U | (N/A)       |
| 5. Necessary function of component not sensitive to seismically induced system perturbations (e.g., sloshing)                    | Y | N | U | (N/A)       |
| 6. No vacuum tubes   | Y | N | U | (N/A)       |
| 7. All external mounting bolts in place  | Y | N | U | (N/A)       |
| 8. Demand based on amplified portion of 3% damped floor response spectrum if estimated natural frequency of rack less than 33 Hz | Y | N | U | (N/A)       |
| 9. Rack capable of structurally transferring GERS level seismic loads to anchorage   | Y | N | U | (N/A)       |
| Is the intent of all the caveats met for GERS?   |   |   |   | Y N U (N/A) |

ANCHORAGE

- |  |     |   |   |             |
|--|-----|---|---|-------------|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)   | (Y) | N | U | N/A (1)     |
| 2. Type of anchorage covered by GIP  | (Y) | N | U | N/A         |
| 3. Sizes and locations of anchors determined   | (Y) | N | U | N/A         |
| 4. Adequacy of anchorage installation evaluated (weld quality and length, nuts and washers, expansion anchor tightness, etc.)  | (Y) | N | U | N/A         |
| 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking | (Y) | N | U | N/A         |
| 6. For bolted anchorages, gap under base less than 1/4-inch  | (Y) | N | U | N/A         |
| 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors   | Y   | N | U | (N/A)       |
| 8. Base has adequate stiffness and effect of prying action on anchors considered   | (Y) | N | U | N/A         |
| 9. Strength of equipment base and load path to CG adequate   | (Y) | N | U | N/A         |
| 10. Embedded steel, grout pad or large concrete pad adequacy evaluated   | Y   | N | U | (N/A)       |
| Are anchorage requirements met?  |     |   |   | (Y) N U (✓) |

INTERACTION EFFECTS

- |   |     |   |   |         |
|---|-----|---|---|---------|
| 1. Soft targets free from impact by nearby equipment or structures  | (Y) | N | U | N/A     |
| 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures | Y   | N | U | (N/A)   |
| 3. Attached lines have adequate flexibility   | (Y) | N | U | N/A (2) |



SCREENING EVALUATION WORK SHEET (SEWS)

Equip. ID No. 2-LPNL-925-0247A Equip. Class 18 - Instruments on Racks

Equipment Description Panel 2-25-247A


INTERACTION EFFECTS (Cont'd)

4. Overhead equipment or distribution systems are not likely to collapse ⓪ N U N/A  
 5. Have you looked for and found no other adverse concerns? ⓪ N U N/A  
 Is equipment free of interaction effects? ⓪ N U

IS EQUIPMENT SEISMICALLY ADEQUATE? ⓪ N U

COMMENTS

1) Rack (local panel) configuration is shown below. The rack is of all welded construction. Components mounted on this rack are light weight and are rigidly attached. Fundamental frequency of this rack is greater than 8 Hz, by judgment.



Wall-mounted panel

2) Attached lines (conduit & tubing) are rigidly supported from the same wall and are rigidly attached to the components on the rack.  $\therefore$  line flexibility ok

3) Per calc. CD-Q0000-940339, The 1.5x B.S. is exceeded by the In-structure spectra @ EL. 621' of RB, in the 5.0 to 7.0 Hz frequency range. Since the lowest natural frequency of this rack is  $> 8$  Hz (see note 1), the intent of the GIP seismic capacity vs. Demand criteria is met.

4) The anchorage of this rack to the wall is judged adequate due to rack rigidity (low spectral acceleration) and that Dead wt. on this rack is very small

Evaluated by: Fazal Bari  
Kunjal D. Yashwanth

Date: 3-1-96  
3-4-96



ESSEL Line No. 9305  
AI

Status  Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-LPNL-925-0247A Equip. Class 18 - Instruments on Racks

Equipment Description Local Panel 2-25-247A

RELAY WALKDOWN.

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U  N/A
2. Are essential relays required to function during earthquake screened out? Y N U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y N U  N/A

Requirements for relays satisfied?  Y  N  U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?  
YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: Forzi Bai

Date: 7-1-96

Evaluated by: Kurt W. Frank

Date: 3-4-96

2-10-11



SSEL Line No. 9040

Status Y (N) U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 2/4

Equip. ID No. 2-PNLA-009-0003A Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PANEL 9-3A

Location: Bldg. CB Floor El. 617 Room, Row/Col U2 MCR

Manufacturer, Model, Etc. (optional but recommended) GE

SEISMIC CAPACITY VS DEMAND

- 1. Elevation where equipment receives seismic input
- 2. Elevation of seismic input below about 40' from grade
- 3. Equipment has fundamental frequency above about 8 Hz
- 4. Capacity based on: Existing Documentation  
Bounding Spectrum  
1.5 x Bounding Spectrum  
GERS
- 5. Demand based on: Ground Response Spectrum  
1.5 x Ground Response Spectrum  
Conserv. Des. In-Str. Resp. Spec.  
Realistic M-Ctr. In-Str. Resp. Spec.

617  
 Y (N) U (grade @ 550')  
 (Y) N U N/A (1)  
 DOC  
 BS  
 (ABS)  
 GERS  
 GRS  
 AGS  
 CRS  
 (RRS)

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)

(Y) N U (2)\*

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- 1. Equipment is included in earthquake experience equipment class
- 2. No computers or programmable controllers
- 3. No strip chart recorders
- 4. Steel frame and sheet metal structurally adequate
- 5. Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays
- 6. Drawers and equipment on slides restrained from falling out
- 7. All doors secured by latch or fastener
- 8. Attached lines have adequate flexibility
- 9. Anchorage adequate (See checklist below for details)
- 10. Relays mounted on equipment evaluated AF=4.5
- 11. Have you looked for and found no other adverse concerns?

(Y) N U N/A  
 (Y) N U N/A (8)  
 (Y) N U N/A (8)  
 (Y) N U N/A (3)  
 (Y) N U N/A (10)  
 (Y) N U N/A (8)  
 (Y) N U N/A (5)  
 (Y) N U N/A  
 (Y) N U N/A (1)  
 (Y) N U N/A (9)  
 Y (N) U N/A (4)

Is the intent of all the caveats met for Bounding Spectrum?

Y (N) U N/A (4)

ANCHORAGE

- 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)
- 2. Type of anchorage covered by GIP
- 3. Sizes and locations of anchors determined

(Y) N U N/A (1)  
 (Y) N U N/A }  
 (Y) N U N/A }





SEL Line No. 9040

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 2 of 24

Equip. ID No. 2-PNLA-009-0003A Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PANEL 9-3A

ANCHORAGE (Cont'd)

- 4. Anchorage installation adequate; e.g., weld quality and length, nuts and washers, expansion anchor tightness
  - 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking
  - 6. For bolted anchorages, gap under base less than 1/4-inch
  - 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors
  - 8. Base has adequate stiffness and effect of prying action on anchors considered
  - 9. Strength of equipment base and load path to CG adequate
  - 10. Embedded steel, grout pad or large concrete pad adequacy evaluated
- Are anchorage requirements met?.

(Y) N U N/A  
 (Y) N U N/A  
 Y N U (N/A)  
 (Y) N U N/A  
 (Y) N U N/A  
 (Y) N U N/A  
 (Y) N U N/A  
 (Y) N U N/A  
 (Y) N U (1)

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures
  - 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures
  - 3. Attached lines have adequate flexibility
  - 4. Overhead equipment or distribution systems are not likely to collapse
  - 5. Have you looked for and found no other adverse concerns?
- Is equipment free of interaction effects?

(Y) N U N/A (4)  
 Y (N) U N/A (7)  
 (Y) N U N/A  
 (Y) N U N/A  
 (Y) N U N/A  
 Y (N) U (7)

IS EQUIPMENT SEISMICALLY ADEQUATE?


Y (N) U (4), (7)

COMMENTS

*For notes see pages 3 and 4 of this SEWS.*

Evaluated by: Fayzi Beg  
John O. Dixon

Date: 11-27-95  
11/28/95






EQE INTERNATIONAL

SHEET NO. 3 of 4


JOB NO. 50147 JOB TVA / BTNP A-46 / IPEEE BY 7Bey DATE 11-27-95

CALC. NO. N/A SUBJECT Attach. to SEWS for 2-PNLA-909-0003A (SSEL9040) CHK'D J.D. Dize DATE 11/28/95


1) Benchboards 2-9-3A, 3B, 4-8, 3-9-3, 4-8 and 1-9-3 & 8 are all of the same construction type. This includes panel thickness of  $5/32$ " and reinforced panel faces (with  $1/4$ "x3" welded plate bars) where the components are mounted. There are also angle irons reinforcing the panel perimeters. These benchboards are heavily welded to their sill channel by closely spaced (front & back of the panels) welded bars (14" to 22" max. c.c. spacing). This anchorage configuration is conservatively qualified in calculation CD-Q0009: 871685, Rev. 6. DWG. 48N933 and O.48N934 shows the embedment details (shown below). This type of benchboards have exhibited natural frequency of 11 to 13 Hz when shake table tested (see GE Report NEDO-10678, "seismic qualification of Electrical Equipment," CER-CQS-82-4.)



(Benchboard Panel lineup)



(Ref. DWG. O-48N934)





JOB NO. 50147 JOB TVA/BFNP A-46/IDEE BY 7 Bay DATE 11-27-95  
CALC. NO. N/A SUBJECT Attach to SEWS for 2-PNL A-009-0003 CHK'D J.D. B. DATE 11/29/95  
(SSEL 9040)

- 2) Per calculation CD-Q 0000-940339, the in-structure response spectra @ EL. 621' of RB ( seismic Demand) exceeds the 1.5x B.S. ( seismic Capacity) in the frequency range of 5 to 7 Hz. Since the lowest natural frequency of these panels is greater than 7 Hz the intent of the GIP seismic Capacity vs. Demand Criteria is met.
- 3) Face of the benchboards are stiffened with welded 1/4" x 3" plate bars.
- 4) Cables running horizontally right under the face of the benchboard 9-3A (bay 2) are sagging. It appears that plastic strap ties holding these cables to their supporting unistrut member are missing. In a seismic event these cables may potentially pull out at their terminal connection points. outlier OSVS-9040-1
- 5) All doors rattle in closed position. due to small gap between door + cab. framing. Since relays in these panels are too far from the doors it is judged that this condition (door rattling) is ok-as-is, as it will not cause any relay chatter in a seismic event, except for isolated cases as noted on the respective SEWS.
- 6) Fluorescent lights in the panel are all caged in with a wire mesh housing - ok
- 7) Miscellaneous items, such as; Vacuum on wheels, breathing apparatus boxes and typor covers are located very near the back side of this panel (2-9-3A). These items are unanchored and may slide and impact this panel in a seismic event. outlier OSVS-9040-2
- 8) Programmable controller in bay 3 has its own rigid independent support and the panel face at this controller is heavily reinforced. Strip charts and flow control devices on slides are positively restrained.
- 9) A typical in-cabinet amplification factor of 4.5 is reasonable and conservative for benchboard type panels consistent with the recommendations provided in EPRI Reports NP-7146-SL and NP-7148-SL
- 10) All adjacent bench board panels (shown in the figure on the previous page)



SESEL Line No. 9040

Status Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 2-PNLA-009-0003A Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description PANEL 9-3A

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?  Y  N  U  N/A

2. Are essential relays required to function during earthquake screened out? Y  N  U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y  N  U  N/A

Requirements for relays satisfied? Y  N  U  (-)

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

1) See note 7 on SEWS for this equipment. → outlier OSVS-9040-2 (unanchored equipment/objects near this panel)

2) See note 4 on SEWS for this equipment. → outlier OSVS-9040-1 (sagging cables/unrestrained cables inside this panel)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?

YES  NO  (see note 2) above


IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO  (see note 1) above

Evaluated by: Fanyi Bei

Date: 11-27-95

Evaluated by: John O. Dizon

Date: 1/28/95





SSEL Line No. 9040

OSVS - 9040 - 1

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number 2-PNLA-009-0003A Equipment Class 20 - Instr. & Control Panels

Equipment Location: Bldg. CPB Floor Elevation 617'

Room or Row/Column MCR U2 Base Elevation 617'

Equipment Description PANEL 2-9-3A

2. OUTLIER ISSUE DEFINITION

a. Identify all the screening guidelines which are not met.  
(Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>	_____	<u>Tanks and Heat Exchangers</u>	_____
Capacity vs. Demand	_____	Shell Buckling*	_____
Caveats	<input checked="" type="checkbox"/>	Anchor Bolts and Embedment	_____
Anchorage	_____	Anchorage Connections	_____
Seismic Interaction	_____	Flexibility of Attached Piping*	_____
Other	_____	Other	_____
<u>Essential Relays</u>	_____	<u>Cable and Conduit Raceways</u>	_____
Capacity vs. Demand	_____	Inclusion Rules	_____
Mounting, Type, Location	_____	Other Seismic Performance Concerns	_____
Other	_____	Limited Analytical Review	_____
		Other	_____

\* Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

Cables running horizontally inside the benchboard  
panel 9-3A (bay 2) are sagging. It appears that  
plastic strap ties holding these cables to their supporting  
Unistrut member are missing. In a seismic event these  
cables may potentially pull out at their terminal  
connection points.



OSSEL Line No. 9040

OSVS-9040-1

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number 2-PNLA-009-0003A

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

Provide positive restraint for the sagging cables.  
(This could be accomplished by plastic strapping  
that wrap around the cables, as a bundle, and  
the unistrut member supporting the plastic tray containing these cables)

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

N/A  
WORK REQUEST (WR) C165336 IS INITIATED  
TO RESOLVE OUTLIER 9040-1  
   
   
 

HL 9-18-96  
from Dr. 9-18-96

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

FARZIN R. BEIGI  
Print or Type Name

Farzi R. Beigi  
Signature

11-27-95  
Date

JOHN O. DIZON, P.E.  
Print or Type Name

John O. Dizon  
Signature

11/28/95  
Date

\_\_\_\_\_  
Print or Type Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date



SSEL Line No. 9040

OSVS-9040-2

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number 2-PNLA-009-0003A Equipment Class 20-Instr & Control Panels

Equipment Location: Bldg. CB Floor Elevation 617'

Room or Row/Column MCR U2 Base Elevation 617'

Equipment Description PANEL 2-9-3A

2. OUTLIER ISSUE DEFINITION

a. Identify all the screening guidelines which are not met.  
(Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>	_____	<u>Tanks and Heat Exchangers</u>	_____
Capacity vs. Demand	_____	Shell Buckling*	_____
Caveats	_____	Anchor Bolts and Embedment	_____
Anchorage	_____	Anchorage Connections	_____
Seismic Interaction	<input checked="" type="checkbox"/>	Flexibility of Attached Piping*	_____
Other	_____	Other	_____
<u>Essential Relays</u>	_____	<u>Cable and Conduit Raceways</u>	_____
Capacity vs. Demand	_____	Inclusion Rules	_____
Mounting, Type, Location	_____	Other Seismic Performance Concerns	_____
Other	<input checked="" type="checkbox"/>	Limited Analytical Review	_____
		Other	_____

\* Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

Miscellaneous items, such as: vacuum on wheels,  
breathing apparatus boxes and typewriter cover for  
electrical cabinets, are near the back side of  
This panel. These items are unanchored and  
may slide / tipover and impact this panel in  
a seismic event causing potential relay chatter.



SSEL Line No. 9040

OSVS-9040-2

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number 2-PNLA-009-0003A

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

1) provide positive restraint for these items;

OR 2) relocate these items

OR if it is shown that these panels (2-9-3A & 3B & 4)

do not contain essential relays this outlier can be resolved as-is.

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

N/A

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

There are no essential relays in panels 2-9-3A, 3B, and 4, see attached info memo. KAC 9-16-96

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

FARZIN R. BEIGI  
Print or Type Name

Farzi R. Beigi  
Signature

11-27-95  
Date

JOHN O. DIZON, P.E.  
Print or Type Name

John O. Dizon  
Signature

11/28/95  
Date

\_\_\_\_\_  
Print or Type Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date





INFORMAL

September 16, 1996

REVIEW FOR ESSENTIAL RELAYS IN PANELS 2-PNLA-009-0003A, 2-PNLA-009-0003B, 2-PNLA-009-0004, 2-PNLA-009-0009, 2-PNLA-009-0020, AND 2-PNLA-009-0021.

Modifications to panels 2-PNLA-009-0003A (SSEL No. 9040), 2-PNLA-009-0003B (SSEL No. 9041), 2-PNLA-009-0004 (SSEL No. 9042), 2-PNLA-009-0009 (SSEL No. 9045), 2-PNLA-009-0020, and 2-PNLA-009-0021 (SSEL No. 9050) were determined to possibly be required under the USI A-46 program, resulting from outliers OSVS-9040-2, OSVS-9045, and OSVS-9050, if these panels contain essential relays. A review of the Browns Ferry Nuclear Plant USI A-46 Seismic Evaluation Report, May 1996, Revision 0, Appendix A determined that there are no essential relays installed in these panels. This review resolves outliers OSVS-9040-2, OSVS-9045, and OSVS-9050. Note that modifications may be required resulting from other outliers on these panels.

Review performed by

K. H. Gromek  
K. H. Gromek

9-16-96  
date

Verified by

B. M. Pedrosa  
B. M. Pedrosa

9-16-96  
date



INTENT

SSEL Line No. 39117

Status Y  U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 2

Equip. ID No. 3-PNLA-009-0005 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description REACTOR CONTROL PNL

Location: Bldg. CB Floor El. 621 Room, Row/Col U3 MCR

Manufacturer, Model, Etc. (optional but recommended) GE

SEISMIC CAPACITY VS DEMAND

- |  |                                      |  |  |  |
|--|--------------------------------------|--|--|--|
| 1. Elevation where equipment receives seismic input      |                                      |  |  |  |
| 2. Elevation of seismic input below about 40' from grade |                                      |  |  | <u>G 17'</u><br>Y <input checked="" type="radio"/> U (grade @ 56') |
| 3. Equipment has fundamental frequency above about 8 Hz  |                                      |  |  | Y <input checked="" type="radio"/> N U N/A (1)                     |
| 4. Capacity based on:                                    | Existing Documentation               |  |  | DOC  |
|  | Bounding Spectrum                    |  |  | BS   |
|  | 1.5 x Bounding Spectrum              |  |  | <u>ABS</u>   |
|  | GERS                                 |  |  | GERS   |
| 5. Demand based on:                                      | Ground Response Spectrum             |  |  | GRS  |
|  | 1.5 x Ground Response Spectrum       |  |  | AGS  |
|  | Conserv. Des. In-Str. Resp. Spec.    |  |  | CRS  |
|  | Realistic M-Ctr. In-Str. Resp. Spec. |  |  | <u>RRS</u>   |

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.) Y  N U (2) \*

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |  |  |  |   |
|--|--|--|--|---|
| 1. Equipment is included in earthquake experience equipment class  |  |  |  |   |
| 2. No computers or programmable controllers  |  |  |  | Y <input checked="" type="radio"/> N U N/A (8)                                  |
| 3. No strip chart recorders  |  |  |  | Y <input checked="" type="radio"/> N U N/A (8)                                  |
| 4. Steel frame and sheet metal structurally adequate   |  |  |  | Y <input checked="" type="radio"/> N U N/A (3)                                  |
| 5. Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays |  |  |  | Y <input checked="" type="radio"/> N U N/A (10)                                 |
| 6. Drawers and equipment on slides restrained from falling out   |  |  |  | Y <input checked="" type="radio"/> N U N/A (8)                                  |
| 7. All doors secured by latch or fastener  |  |  |  | Y <input checked="" type="radio"/> <input checked="" type="radio"/> N U N/A (5) |
| 8. Attached lines have adequate flexibility  |  |  |  | Y <input checked="" type="radio"/> N U N/A                                      |
| 9. Anchorage adequate (See checklist below for details)  |  |  |  | Y <input checked="" type="radio"/> N U N/A (1)                                  |
| 10. Relays mounted on equipment evaluated  |  |  |  | Y <input checked="" type="radio"/> N U N/A (9)                                  |
| 11. Have you looked for and found no other adverse concerns?   |  |  |  | Y <input checked="" type="radio"/> N U N/A                                      |
- Is the intent of all the caveats met for Bounding Spectrum? Y  N U N/A (5)

ANCHORAGE

- |  |  |  |  |  |
|--|--|--|--|--|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation) |  |  |  |  |
| 2. Type of anchorage covered by GIP  |  |  |  | Y <input checked="" type="radio"/> N U N/A } |
| 3. Sizes and locations of anchors determined   |  |  |  | Y <input checked="" type="radio"/> N U N/A ↓ |



SEL Line No. 39117

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 2 of 2

Equip. ID No. 3-PNLA-009-0005 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description REACTOR CONTROL PNL

ANCHORAGE (Cont'd)

- 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness (Y) N U N/A
  - 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking (Y) N U N/A
  - 6. For bolted anchorages, gap under base less than 1/4-inch Y N U (N/A)
  - 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors (Y) N U N/A
  - 8. Base has adequate stiffness and effect of prying action on anchors considered (Y) N U N/A
  - 9. Strength of equipment base and load path to CG adequate (Y) N U N/A
  - 10. Embedded steel, grout pad or large concrete pad adequacy evaluated (Y) N U N/A
- Are anchorage requirements met? (Y) N U (C)

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures (Y) N U N/A (G)
  - 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures (Y) N U N/A
  - 3. Attached lines have adequate flexibility (Y) N U N/A
  - 4. Overhead equipment or distribution systems are not likely to collapse (Y) N U N/A
  - 5. Have you looked for and found no other adverse concerns? (Y) N U N/A
- Is equipment free of interaction effects? (Y) N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

Y (N) U (5)

COMMENTS

For notes 1-3, 6, 8-10 see the corresponding notes on SEWS for 2-PNLA-009-0003A (SSEL 9040)

note 5) The door latch to bay no. 2 of this panel is broken. outlier OSVC-39117  
Notes 4 + 7 not used.

evaluated by: Fargi Beji  
John O. Dizon

Date: 11-27-95  
11/28/95



ASSEL Line No. 39117

Status Y  N U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 3-PNLA-009-0005 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description REACTOR CONTROL PNL

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?  Y N U N/A

2. Are essential relays required to function during earthquake screened out? Y N U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y  N U N/A

Requirements for relays satisfied? Y  N U  (1)

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  Y N U N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

1) Door latch is broken on bay no-2. outlier OSVS-39117

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?

YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO  (see note 1) above

Evaluated by: Fazli Beji

Date: 11-27-95

Evaluated by: John O. Dixon

Date: 11/28/95





SSEL Line No. 39117

OSVS-39117

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number 3-PNLA-009-0005 Equipment Class 20-Instr. & Control Panels

Equipment Location: Bldg. CB Floor Elevation 617'

Room or Row/Column MCR U3 Base Elevation 617'

Equipment Description. Reactor Control Panel

2. OUTLIER ISSUE DEFINITION

a. Identify all the screening guidelines which are not met.  
(Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>	_____	<u>Tanks and Heat Exchangers</u>	_____
Capacity vs. Demand	_____	Shell Buckling*	_____
Caveats	<input checked="" type="checkbox"/>	Anchor Bolts and Embedment	_____
Anchorage	_____	Anchorage Connections	_____
Seismic Interaction	_____	Flexibility of Attached Piping*	_____
Other	_____	Other	_____
<u>Essential Relays</u>	_____	<u>Cable and Conduit Raceways</u>	_____
Capacity vs. Demand	_____	Inclusion Rules	_____
Mounting, Type, Location	_____	Other Seismic Performance Concerns	_____
Other	_____	Limited Analytical Review	_____
		Other	_____

\* Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

The door latch to bay no. 2 of this panel  
is broken. The door could impact to the  
panel frame in a seismic event and cause  
potential relay chatter.



ESSEL Line No. 39117

OSVS-39117  
OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number 3-PNLA-009-0005

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

Replace the broken latch:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

N/A  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

REVIEW OF ESSENTIAL RELAY LIST INDICATED  
NO ESSENTIAL RELAYS ARE PRESENT  
IN PANEL 3 - PNLA-009-0005. THEREFORE,  
OSVS 39117 IS RESOLVED.

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

FARZIN R. BEIGI  
Print or Type Name

Farzin R. Beigi  
Signature

11-27-95  
Date

JOHN O. DIZON, P.E.  
Print or Type Name

John O. Dizon  
Signature

11/28/95  
Date

\_\_\_\_\_  
Print or Type Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

John O. Dizon  
2-13-97  
John O. Dizon  
2-27-97



INTENT

SSEL line no. 39216  
AI

Revision 2A  
Status Y N U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 2

Equip. ID No. 3-LPNL-925-655A Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description DIV. I Load Shed Logic Panel

Location: Bldg. 43-RB Floor El. 621'-3" Room, Row/Col 480V SD Bd Rm. 3A

Manufacturer, Model, Etc. (optional but recommended) Spectrum Technologies

SEISMIC CAPACITY VS DEMAND

- |  |                                      |          |          |           |
|--|--------------------------------------|----------|----------|-----------|
| 1. Elevation where equipment receives seismic input      |                                      |          |          |           |
| 2. Elevation of seismic input below about 40' from grade |                                      | <u>Y</u> | <u>N</u> | U N/A     |
| 3. Equipment has fundamental frequency above about 8 Hz  |                                      | <u>Y</u> | <u>N</u> | U N/A (8) |
| 4. Capacity based on:                                    | Existing Documentation               |          |          |           |
|  | Bounding Spectrum                    |          |          |           |
|  | 1.5 x Bounding Spectrum              |          |          |           |
|  | GERS                                 |          |          |           |
| 5. Demand based on:                                      | Ground Response Spectrum             |          |          |           |
|  | 1.5 x Ground Response Spectrum       |          |          |           |
|  | Conserv. Des. In-Str. Resp. Spec.    |          |          |           |
|  | Realistic M-Ctr. In-Str. Resp. Spec. |          |          |           |
- Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)
- Y N U (\*)

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- |  |  |          |          |                  |
|--|--|----------|----------|------------------|
| 1. Equipment is included in earthquake experience equipment class  |  | <u>Y</u> | <u>N</u> | U N/A            |
| 2. No computers or programmable controllers  |  | <u>Y</u> | <u>N</u> | U N/A            |
| 3. No strip chart recorders  |  | <u>Y</u> | <u>N</u> | U N/A            |
| 4. Steel frame and sheet metal structurally adequate   |  | <u>Y</u> | <u>N</u> | U N/A (1)(5)     |
| 5. Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays |  |          |          | Y N U <u>N/A</u> |
| 6. Drawers and equipment on slides restrained from falling out   |  | <u>Y</u> | <u>N</u> | U <u>N/A</u>     |
| 7. All doors secured by latch or fastener  |  | <u>Y</u> | <u>N</u> | U N/A (4)        |
| 8. Attached lines have adequate flexibility  |  | <u>Y</u> | <u>N</u> | U N/A (7)        |
| 9. Anchorage adequate (See checklist below for details)  |  | <u>Y</u> | <u>N</u> | U N/A (5)        |
| 10. Relays mounted on equipment evaluated <i>AF = 4.5</i>  |  | <u>Y</u> | <u>N</u> | U N/A            |
| 11. Have you looked for and found no other adverse concerns?   |  | <u>Y</u> | <u>N</u> | U N/A            |
- Is the intent of all the caveats met for Bounding Spectrum? Y N U N/A

ANCHORAGE

- |  |  |          |          |       |
|--|--|----------|----------|-------|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation) |  | <u>Y</u> | <u>N</u> | U N/A |
| 2. Type of anchorage covered by GIP  |  | <u>Y</u> | <u>N</u> | U N/A |
| 3. Sizes and locations of anchors determined   |  | <u>Y</u> | <u>N</u> | U N/A |



SSEL Line no. 39216

AI

SCREENING EVALUATION WORK SHEET (SEWS)

Revision 2A  
Sheet 2 of 2

Equip. ID No. 3-LPNL-925-655A Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description DIV. I Load Shed Logic Panel

ANCHORAGE (Cont'd)

- 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness (Y) N U N/A
  - 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking (Y) N U N/A
  - 6. For bolted anchorages, gap under base less than 1/4-inch (Y) N U N/A
  - 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors (Y) N U N/A
  - 8. Base has adequate stiffness and effect of prying action on anchors considered (Y) N U N/A
  - 9. Strength of equipment base and load path to CG adequate (Y) N U N/A
  - 10. Embedded steel, grout pad or large concrete pad adequacy evaluated Y N U (N/A) (Y) N U (7)
- Are anchorage requirements met?

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures (Y) N U N/A
  - 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures (Y) N U N/A
  - 3. Attached lines have adequate flexibility (Y) N U N/A (4)
  - 4. Overhead equipment or distribution systems are not likely to collapse (Y) N U N/A (6)
  - 5. Have you looked for and found no other adverse concerns? (Y) N U N/A (2)
- Is equipment free of interaction effects? (Y) N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

(Y) N U

COMMENTS

See notes on SEWS package for 3-LPNL-925-654A (SSEL#39105) since both equipment are similar. (panel and anchorage configurations).

Evaluated by: John O. Dixon

J.R. A. ISSER

Date: 1/12/96

1/12/96





SSEL Line No. 39216  
AI

Status  Y  N  U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 3-LPNL-925-655A Equip. Class 20 - I&C Panels + Cabinets

Equipment Description Div. I Load Shed Logic Panel

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?

Y  N  U  N/A

2. Are essential relays required to function during earthquake screened out?

Y  N  U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns?

Y  N  U  N/A

Requirements for relays satisfied?

Y  N  U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?

Y  N  U  N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER?  
YES  NO

IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: John O. Dixon

Date: 1/12/96

Evaluated by: J.R. DISSER

Date: 1/12/96

100-100000



SEL Line No. 39105

Status  N  U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 3

Equip. ID No. 3-LPNL-925-654A Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description DIV I LOAD SHED LOGIC PANEL - DCN W21284

Location: Bldg. RB Floor El. 621'-3" Room, Row/Col SD BD RM E

Manufacturer, Model, Etc. (optional but recommended) Spectrum Technologies

SEISMIC CAPACITY VS DEMAND

- Elevation where equipment receives seismic input
- Elevation of seismic input below about 40' from grade
- Equipment has fundamental frequency above about 8 Hz
- Capacity based on: Existing Documentation  
Bounding Spectrum  
1.5 x Bounding Spectrum  
GERS
- Demand based on: Ground Response Spectrum  
1.5 x Ground Response Spectrum  
Conserv. Des. In-Str. Resp. Spec.  
Realistic M-Ctr. In-Str. Resp. Spec.

CGZC Eff. (5.0 Hz to 5.6 Hz)  
 N  U N/A (8)  
 DOC  
 BS  
 ABS  
 GERS  
 GRS  
 AGS  
 CRS  
 RRS

Does capacity exceed demand? (Indicate at right (\*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.)

N  U (9) \*

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (\*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- Equipment is included in earthquake experience equipment class
- No computers or programmable controllers
- No strip chart recorders
- Steel frame and sheet metal structurally adequate
- Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays
- Drawers and equipment on slides restrained from falling out
- All doors secured by latch or fastener
- Attached lines have adequate flexibility
- Anchorage adequate (See checklist below for details)
- Relays mounted on equipment evaluated AF=4.5
- Have you looked for and found no other adverse concerns?

N  U N/A  
 N  U N/A  
 N  U N/A  
 N  U N/A (1, 5)  
 Y N U  N/A  
 Y N U  N/A  
 N  U N/A  
 N  U N/A(4)  
 N  U N/A(7)  
 N  U N/A(5)  
 N  U N/A

Is the intent of all the caveats met for Bounding Spectrum?

N  U N/A

ANCHORAGE

- Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation)
- Type of anchorage covered by GIP
- Sizes and locations of anchors determined

N  U N/A  
 N  U N/A  
 N  U N/A



SEL Line No. 39105

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 2 of 2<sub>3</sub>

Equip. ID No. 3-LPNL-925-654A Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description DIV I LOAD SHED LOGIC PANEL - DCN W21284

ANCHORAGE (Cont'd)

- 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness (Y) N U N/A
  - 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking (Y) N U N/A
  - 6. For bolted anchorages, gap under base less than 1/4-inch (Y) N U N/A
  - 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors (Y) N U N/A
  - 8. Base has adequate stiffness and effect of prying action on anchors considered (Y) N U N/A
  - 9. Strength of equipment base and load path to CG adequate (Y) N U N/A
  - 10. Embedded steel, grout pad or large concrete pad adequacy evaluated Y N U (N/A)
- Are anchorage requirements met? (Y) N U (7)

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures (Y) N U N/A
  - 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures (Y) N U N/A
  - 3. Attached lines have adequate flexibility (Y) N U N/A (4)
  - 4. Overhead equipment or distribution systems are not likely to collapse (Y) N U N/A (6)
  - 5. Have you looked for and found no other adverse concerns? (Y) N U N/A (2)
- Is equipment free of interaction effects? (Y) N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

(Y) N U

COMMENTS

- See next sheet for notes.

Evaluated by: Fangzi Bai  
John O. Dizon

Date: 9-19-95  
9/21/95






JOB NO. 50147 JOB TVA/BFNP A-46/1PEEE BY JBj DATE 9-19-95

CALC. NO. N/A SUBJECT Attach. to SENS for 3-LPNL-925-654A CHK'D. J.D. DATE 9/21/95  
(SSEL 39105)

SSEL: 39105

I.D. 3-LPNL-925-654A (DIVISION I Load Shed Logic panel)  
Spectrum Technologies

- 1) size: 36x48x16" (gage 14)  
Typ. Hoffman single door enclosure,  
NEMA type 12
- 2) - Block wall on panel's south  
side qualified per 100 80-11 proj.  
(Ref. DWG. 41N1203-1)
- 3) - panel is very lightly loaded
- 4) - Flex & rigid conduit w/ adequate  
flexibility
- 5) - Relays and other components  
(mostly buses) are mounted  
on a 1/8" thick mounting  
plate. The mounting  
plate is attached to  
the back of the panel  
by 8-3/8"  $\phi$  welded studs.



Elevation  
(Lily west)

Front Door & Back of Panel have stiffeners (Ref. Hoffman Catalog)  $\rightarrow AF = 4.5$

- 6) - Fluorescent light tubes overhead have compression fittings, OK no falling hazard
- 7) Anchorage is conservatively qualified in Calc. CD-Q 3361-930572, Rev. 1.  
(Also see bounding Calc. in SENS for 3-JBOX-253-7162, SSEL No. 39051)
- 8) See note 1 on SENS for 2-JBOX-253-7193 (SSEL 9310).  $\rightarrow f > 84 Hz$ .
- 9) Per Figure B.1 of Calc. CD-Q 0000-940339, The 1.5 x 85 exceeds the 1n-structure spectrum @ EL 639' of RB in the frequency range of  $\sim 4.8 Hz$  to  $7.3 Hz$  since the lowest natural frequency of this panel is greater than  $7.3 Hz$  The intent of seismic Capacity vs Demand criteria of





SEL Line No. 39105

Status  N U

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 3-LPNL-925-654A Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description DIV I LOAD SHED LOGIC PANEL - DCN W21284

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted?  N U N/A

2. Are essential relays required to function during earthquake screened out? Y N U  N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns?  N U N/A

Requirements for relays satisfied?  N U

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet?  N U N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

IS EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES  NO


IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES  NO

Evaluated by: Fazli Beji

Date: 9-19-95

Evaluated by: John O. Dixon

Date: 9/21/95



**ATTACHMENT 8-4**

