

NUSCO
IN-SERVICE INSPECTION REPORT
CLASS 1, 2, SYSTEMS
AND
IWF - SUPPORTS
MILLSTONE NUCLEAR POWER STATION
UNIT 2
WATERFORD CONNECTICUT 06385

OWNER:

Northeast Utilities Energy Company
P. O. Box 270
Hartford Connecticut 06101
Commercial Service Date:
December 26, 1975

Report Date: March 1993

Prepared By: L. D. Baird

L. D. Baird
NUSCO ISI Coordinator

Reviewed By: R. J. Fuller

R. J. Fuller
NUSCO ISI Coordinator

Approved By: R. T. Blanchard

R. T. Blanchard
NUPCO ISI Coordinator

SECTION 1

TABLE OF CONTENTS

NUSCO
TABLE OF CONTENTS

Section	Title
1	Table of Contents
2	Owner's Data Report NIS-1
3	Abbreviations and Acronyms
4	Introduction
5	Procedures and Personnel Qualifications
6	Equipment and Material List
7	Conditions Noted
8	Class 1 Examination Results
9	Class 2 Examination Results
10	IWF Examination Results
11	Corrective Measures Recommended and Taken

SECTION 2

OWNER'S DATA REPORT NIS-1

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

As required by the Provisions of the ASME Code Rules

1. Owner Northeast Nuclear Energy Company, P.O. Box 270, Hartford, CT 06141
(Name and Address of Owner)
2. Plant Millstone Nuclear Power Station, P.O. Box 128, Waterford, CT 06385
(Name and Address of Plant)
3. Plant Unit #2 4. Owner Certificate of Authorization (if required) N/A
5. Commercial Service Date 12/26/75 6. National Board Number for Unit 20914
7. Components Inspected

Component or Appurtenance	Manufacturer or Installer	Manufacturer or Installer Serial No.	State or Province No.	National Board No.
New SG #1 Class 1, Welds	B&W--Fluor	761201	N/A	123
New SG #1 Class 2 Welds	B&W--Fluor	761201	N/A	123
New SG #2 Class 1 Welds	B&W--Fluor	761202	N/A	124
RV Internal Exam	M--CE	67110	N/A	20914
Prz. Noz. Welds	M--CE	67605	N/A	20918
New RCS Welds CI-1	Fluor	N/A	N/A	N/A
Piping Welds Class 1	M--Bechtel	N/A	N/A	N/A
Piping Welds Class 2	M--Bechtel	N/A	N/A	N/A
New Class 2 Piping Welds	Fluor	N/A	N/A	N/A
Class 1 & 2 Bolting	Various	N/A	N/A	N/A
JWF Supports	Various	N/A	N/A	N/A
RCP "A" Welds	M--Byron--Jackson	681-N-0449	N/A	N/A
Class 2/3 CMT Pens	Various	N/A	N/A	N/A

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-1 (back)

8. Examination Dates 1/4/91 to 1/24/93 9. Inspection Interval from 12/26/85 to 12/26/95

10. Abstract of Examinations. Include a list of examinations and a statement concerning status of work required for current interval. See Sections 8, 9, and 10 of the attached report for Class 1, Class 2 and IWF support examination results, respectively.

11. Abstract of Conditions Noted.

See Section 7 of the attached report.

12. Abstract of Corrective Measures Recommended and Taken

See Section 11 of the attached report.

We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Date April 14 19 93 Signed Northeast Nuclear Energy Co By JT Blanchard Jr
Owner

Certificate of Authorization No. (if applicable) - NA - Expiration Date - NA -

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of CONNECTICUT and employed by THE HFD STM BLR I&IC of HARTFORD, CT have inspected the components described in this Owners' Data Report during the period 04 JANUARY '91 to 24 JANUARY '93, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners' Data Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 14 APRIL 19 93

ELIZABETH YORK

Inspector's Signature

Commissions CT 1137 NB 9384

National Board, State, Province and No.

1. Owner: Northeast Nuclear Energy Company, P.O. Box 270, Hartford, CT 06141
(Name and Address of Owner)

2. Plant: Millstone Nuclear Power Station, P.O. Box 128, Waterford, CT 06385
(Name and Address of Plant)

3. Plant Unit: 2 4. Owner Certificate of Authorization (if required): N/A

5. Commercial Service Date: 12/26/75 6. National Board Number for Unit: 20914

SECTION 3

ABBREVIATIONS AND ACRONYMS

ABBREVIATIONS AND ACRONYMS

81W	- ASME Section XI, Winter 1981 Addenda
ANII	- Authorized Nuclear In-Service Inspector
AR	- ANII Review
Cal. Block	- UT Calibration Block
CEDM	- Control Element Drive Mechanism
ISI	- In-Service Inspection per ASME Section XI
RFO #11	- Refueling Outage #11
LP	- Liquid Penetrant
MSGRP	- Millstone Steam Generator Replacement Project
MT	- Magnetic Particle Examination
MP	- Magnetic Particle
MP-2	- Millstone Point Unit #2
MP-3	- Millstone Point Unit #3
NU	- Northeast Utilities
NUSCO	- Northeast Utilities Service Company
PR	- Plant Reviewer
PT	- Liquid Penetrant Testing
UT	- Ultrasonic Testing
VT	- Visual Examination

SECTION 4

INTRODUCTION

INTRODUCTION

1. During the Millstone Unit 2, Refueling Outage #11, both steam generators were replaced. The new generator subassemblies were manufactured by Babcock and Wilcox and installed by Fluor Daniels. The required preservice examinations were conducted by Babcock and Wilcox, Fluor Daniels, Abb/Amdata and Northeast Utilities Service Company.
2. Volumetric, surface and visual examinations were performed as required by Section XI of the ASME BOILER and Pressure Vessel Code, 1980 Edition, including the Winter 1981 Addenda.
3. The above examinations were conducted during:
 - a mid-cycle shut down in 1991. We examined several Category B-G-2, sets of bolting for the steam generator and pressurizer manways. We also examined several Class 3/2, Containment Penetration welds.
 - between January 1992 and the start of RFO #11, in May, the majority of the new steam generators Class 1, preservice examinations were performed.
 - from May through January 1993, ROF #11, ISI exams, preservice MSGRP Class 1, Class 2, and IWF support exams were completed.
4. All records, examination data sheets, personnel certificates, equipment, and material certificates for the examinations performed are on file at the Millstone Nuclear Power Station Unit 2.
5. Several items listed in Sections 8, 9, and 10 of this report are creditable items to the Second Period of the Second Interval. They are identified by "Note 1."
6. Since the refueling outage ran over into the early months of the Third Period, several items are also creditable to that Period. They are also identified in Sections 8, 9, and 10, of this report by "Note 2."
7. Preservice examinations will also be identified by "Note 3" or a specific note pertaining to the particular item listed in Sections 8, 9, or 10 of this report.
8. Reactor coolant pump "A," was disassembled during this outage. We invoked Code Case N-481, and performed a visual examination of the pump casing welds and a internal remote visual examination of the accessible surfaces of the pump casing. The stress analysis required by the Code Case is under evaluation and will be forwarded to the NRC upon completion.
9. There were a few rejectable indications noted during the 'WF examinations that required expanding the IWF support population per IWF-2430 (a) and (b). Refer to Section 10 of this report for specific details.

10. The examinations listed in this report were performed by personnel from:

Northeast Utilities Service Company
Northeast Utilities Energy Company
Abb/Amdata
Babcock and Wilcox
Cramer and Lindell
Fluor Daniels
NRT Technical

SECTION 5

PROCEDURES AND PERSONNEL QUALIFICATIONS

PROCEDURE LIST

ABB/AMDATA

NUMBER	REV.	TITLE
AMD-010	0	MAIN STEAM & FEEDWATER NOZZLE INNER RADII EXAM

BABCOCK & WILCOX

NUMBER	REV.	TITLE
MP-XII-04	1	LIQUID PENETRANT EXAMINATION
MP-XII-06	0	MAGNETIC PARTICLE EXAMINATION (DRY METHOD)

NORTHEAST UTILITIES

NUMBER	REV.	TITLE
NU-LP-1	10	LP EXAM COLOR CONTRAST SOLVENT REMOVABLE
NU-MP-1	9	MP EXAM YOKE METHOD
NU-MP-3 *	0	MP EXAM THROUGH PAINT AND COATINGS
NL-UT-1	8 & 9	UT GENERAL REQUIREMENTS
NU-UT-2	8	UT EXAM AUSTENITIC AND DISSIMILAR METAL WELDS
NU-UT-3	7	UT EXAM FERRITIC PIPING WELDS
NU-UT-7	4 & 5	UT EXAM VESSEL WELDS
NU-UT-11	2	UT EXAM L-WAVE BUTT WELDS
NU-UT-16	3	UT EXAM PRESSURIZER SUPPORT STRUCTURE WELDS
NU-UT-17	4 & 5	UT EXAM NOZZLE TO SAFE END WELDS
NU-UT-20	4 & 5	UT EXAM NOZZLE INNER RADIUS AREAS
NU-UT-21	4	UT EXAM REACTOR COOLANT PUMP FLYWHEELS
NU-UT-26	3	PRIMARY COOLANT PIPING WELDS
NU-VT-1	9 & 10	VISUAL EXAM

* 1991 MID CYCLE OUTAGE EXAMINATIONS

BABCOCK & WILCOX
PERSONNEL CERTIFICATIONS

NAME	METHODS/LEVELS				EXPIRATION DATE OF EYE CERTIFICATIONS
	VT	PT	UT	MT	
R. ALPECHE				II	07/02/93
L. BOUGHNER				II	09/29/93
T. PAGE				II	09/22/92

CRAMER / LINDELL
PERSONNEL CERTIFICATIONS

NAME	METHODS/LEVELS				EXPIRATION DATE OF EYE CERTIFICATIONS
	VT	PT	UT	MT	
A. E. KISSINGER *	II	II	II	II	06/07/91
M. R. ROBERTS *	II	II		II	08/13/91

FLUOR
PERSONNEL CERTIFICATIONS

NAME	METHODS/LEVELS				EXPIRATION DATE OF EYE CERTIFICATIONS
	VT	PT	UT	MT	
R. BOONE				II	08/21/93
G. CABRAL		II		II	05/22/93
R. C. CUPP		II		II	09/04/93
S. DRIGGERS				II	06/19/93
D. DUMAIS				II	06/19/93
S. D. GARRETT				II	08/04/93
D. JOHNSON		II			06/25/93
R. MILLER		II		II	06/15/93
R. J. PACKER		II			06/13/93
D. RICKETTS				II	06/13/93
L. STERLING				II	06/05/93

* 1991 MID CYCLE OUTAGE EXAMINATIONS

ABB/AMDATA
PERSONNEL CERTIFICATIONS

NAME	METHODS/LEVELS				EXPIRATION DATE OF EYE CERTIFICATIONS
	VT	PT	UT	MT	
J. H. ABBOTT	II	II	I		11/23/92
T. T. BOHENKAMPER	II	II	II	II	07/22/92
T. J. BOYERS	II	II	III		11/12/92
M. C. BREHLER			I		08/11/93
S. E. FONICELLO		II	I	II	10/16/93
J. C. GRIGSBY			II		11/22/93
M. D. HAHN		II	II	II	05/07/93
S. G. HALL			II		01/20/93
R. S. HARMON			I		02/05/93
T. E. HURST			II		09/04/93
C. L. LASOYA	II	II	II		11/02/93
N. L. LASOYA		I	I	I	05/11/93
S. W. NEWBOLD	II	III	I	III	02/20/93
G. A. POOLER		II	II		07/07/93
B. F. RHODES			I		09/19/93
C. E. SHAW			II		01/06/93
K. K. SMITH			II		11/02/93
D. M. SUMMERFORD	II	I	II	II	12/17/92
K. F. WICKENHAUSER		II	II	II	05/07/93
T. W. WINGFIELD			II		11/02/93
J. P. PHILLIPPI *				II	02/03/92
C. T. SELLERS *				I	04/03/92

* 1991 MID CYCLE OUTAGE EXAINATIONS

NRT TECHNICAL
PERSONNEL CERTIFICATIONS

NAME	METHODS/LEVELS				EXPIRATION DATE OF EYE CERTIFICATIONS
	VT	PT	UT	MT	
J. VAUGHN	II				05/19/93

NUPOC
PERSONNEL CERTIFICATIONS

NAME	METHODS/LEVELS				EXPIRATION DATE OF EYE CERTIFICATIONS
	VT	PT	UT	MT	
V. BURNETT	II				03/16/93
R. MONTGOMERY	II				09/09/93
J. TYROL	II				02/20/93
T. QUINLEY	II				10/01/93

NUSCO
PERSONNEL CERTIFICATIONS

NAME	METHODS/LEVELS				EXPIRATION DATE OF EYE CERTIFICATIONS
	VT	PT	UT	MT	
P. J. DURAND	II	II	II	II	08/24/93
R. J. FULLER	III	III	III	III	09/29/93
T. LAWRENCE	II	II		II	09/05/93
D. R. MACNEILL			III		02/11/93
R. A. PFANNELSTIEL		III	III	III	06/24/93
J. PINTO*	II	III	II	III	02/11/93

* 1991 MID CYCLE OUTAGE EXAMINATIONS

SECTION 6

EQUIPMENT AND MATERIAL LIST

EQUIPMENT AND MATERIAL LIST

Manufacturer	Item	Model or Type	Serial or Batch Number
MAGNAFLUX	CLEANER	SKC-NF	90C01K
MAGNAFLUX	CLEANER	SKC-NF	91B02K
MAGNAFLUX	CLEANER	SKC-NF	91B02K-A
MAGNAFLUX	CLEANER	SKC-NF	92A13K
ULTRAGEL II	COUPLANT	ECHO	091011
ULTRAGEL II	COUPLANT	ECHO	8872
ULTRAGEL II	COUPLANT	ECHO	92101
MAGNAFLUX	DEVELOPER	SKD-NF	90K07K
MAGNAFLUX	DEVELOPER	SKD-NF	91B04P
MAGNAFLUX	DEVELOPER	SKD-NF	92E04K
PARKER *	MT YOKE	B-300	1416
PARKER	MT YOKE	B300	3434
PARKER	MT YOKE	B300	4092
PARKER	MT YOKE	B300	4093
PARKER	MT-YOKE	DA200	6751
MAGNAFLUX	PENETRANT	SKL-EF/S	90L02K
MAGNAFLUX	PENETRANT	SKL-EF/S	92A05P
K/B	UT INSTRUMENT	EPOCH II	91031004
K/B	UT INSTRUMENT	USK-7D	32810-548
K/B	UT INSTRUMENT	USK-7D	32810-821
K/B	UT INSTRUMENT	USK-7D	32810-869
K/B	UT INSTRUMENT	USK-7D	32810-897
K/B	UT INSTRUMENT	USK-7D	32810-900
K/B	UT INSTRUMENT	USK-7D	32810-917
K/B	UT INSTRUMENT	USK-7D	32810-924
K/B	UT INSTRUMENT	USK-7D	32810-941

* 1991 MID CYCLE OUTAGE EXAMINATIONS

EQUIPMENT AND MATERIAL LIST

Manufacturer	Item	Model or Type	Serial or Batch Number
K/B	UT INSTRUMENT	USK-7D	32810-949
K/B	UT INSTRUMENT	USL-37	211286
K/B	UT INSTRUMENT	USL-37	211290
K/B	UT INSTRUMENT	USL-37	211649
K/B	UT INSTRUMENT	USL-38	210158
K/B	UT INSTRUMENT	USL-38	210760
K/B	UT INSTRUMENT	USL-38	211178

ULTRASONIC TRANSDUCER LIST

SERIAL NUMBER	FREQUENCY	SIZE	MANUFACTURER
B6-71	2.00 MHz	1.0 x 1.0"	RTD
B417	1.00 MHz	1.0 x 1.0"	C-E
00841T	2.25 MHz	0.5 X 1.0"	SONIC
130509	2.25 MHz	0.5 X 1.0"	PANAMETRICS
A02628	2.25 MHz	0.75"	AEROTECH
A12960	5.00 MHz	0.50"	AEROTECH
A23652	2.25 MHz	0.75"	AEROTECH
A26462	2.25 MHz	0.5 X 1.0"	AEROTECH
A31369	2.25 MHz	1.0"	AEROTECH
B02363	2.25 MHz	0.50"	AEROTECH
B11541	2.25 MHz	0.50"	AEROTECH
B11543	2.25 MHz	0.50"	AEROTECH
B17739	2.25 MHz	0.5 X 1.0"	AEROTECH
B25550	2.25 MHz	0.5 X 1.0"	AEROTECH
B26091	2.25 MHz	0.5 X 1.0"	AEROTECH
D17695	2.25 MHz	0.75"	AEROTECH
E19700	2.25 MHz	0.5 X 1.0"	AEROTECH
E19712	2.25 MHz	0.5 X 1.0"	AEROTECH
F03122	2.25 MHz	0.5 X 1.0"	AEROTECH
F03125	2.25 MHz	0.5 X 1.0"	AEROTECH
F15164	2.25 MHz	1.0"	AEROTECH
F15174	2.25 MHz	1.0"	AEROTECH
F18226	2.25 MHz	0.5"	AEROTECH

ULTRASONIC TRANSDUCER LIST

SERIAL NUMBER	FREQUENCY	SIZE	MANUFACTURER
F18229	2.25 MHz	0.5"	AEROTECH
F18233	2.25 MHz	0.5"	AEROTECH
F23611	2.25 MHz	0.5"	AEROTECH
F26508	2.25 MHz	0.75"	AEROTECH
F27608	2.25 MHz	0.5"	AEROTECH
F27618	2.25 MHz	0.5"	AEROTECH
G15615	2.25 MHz	0.5 X 1.0"	AEROTECH
G15619	2.25 MHz	0.5 X 1.0"	AEROTECH
G15620	2.25 MHz	0.5 X 1.0"	AEROTECH
G15624	2.25 MHz	0.5 X 1.0"	AEROTECH
H20505	2.25 MHz	1.0"	AEROTECH
H20519	2.25 MHz	0.5"	AEROTECH
H20520	2.25 MHz	0.5"	AEROTECH
H30549	2.25 MHz	0.5"	AEROTECH
K05696	2.25 MHz	1.0"	AEROTECH
K16415	2.25 MHz	1.0"	AEROTECH
K26261	2.25 MHz	0.5"	AEROTECH
K30647	2.25 MHz	0.75"	AEROTECH
L03138	2.25 MHz	0.5 X 1.0"	AEROTECH
M16512	2.25 MHz	1.125"	AEROTECH

CALIBRATION BLOCK LIST

BABCOCK AND WILCOX

CAL. BLOCK #	DRAWING #	REVISION
20-T-046	1P-18000	B
20-T-048	1P-18001	O
20-T-049	1P-18003	C
20-T-052	1P-18040	O
20-T-053	1P-18002	A
20-T-054	1P-18004	O

NORTHEAST UTILITIES

CAL. BLOCK #	DRAWING 25203-29449	REVISION
UT- 4	SHEET # 5	1
UT- 8	SHEET # 2	1
UT-12	SHEET #14	1
UT-13	SHEET #32	1
UT-14	SHEET #13	1
UT-15	SHEET #30	3
UT-23	SHEET #10	1
UT-28	SHEET #21	1
UT-29	SHEET #22	1
UT-34	SHEET #15	1
DRAWING #25203-29449		
UT-46	PART # 46	3
UT-47	PART # 47	3
UT-60	PART # 60	3
RCP FLYWHEEL	NONE	NONE
ROMPAS BLOCK	SN# 054892	NONE
STEP WEDGE	SN# 91-6478	NONE
UT-31 (MP-3)	WESTINGHOUSE DRAWING #80D7571 REV.0	

SECTION 7

CONDITIONS NOTED

CONDITIONS NOTED

1. Volumetric, surface and visual examinations were performed, as required, by the ASME Boiler and Pressure Vessel Code, Section XI, 1980 Edition, including the 1981 Winter Addenda. However, the extent of the examinations for class 1 (B-J) and class 2 (C-F and C-G) are determined by the 1974 Edition, including the 1975 Summer Addenda, as required and/or permitted by 10CFR50.55a.
2. Reactor coolant pump "A" was disassembled for maintenance and rework during this outage. The visual examinations required by Code Case N-481, were performed on the pump casing. The Category B-G-1, studs were examined in accordance with IE Bulletin #82-02. A new rotating assembly and cover were installed and the pump was returned to service.
3. Both steam generators (#1 and #2) were replaced during this outage. The preservice examinations were performed in accordance with the ASME Boiler and Pressure Vessel Code, Section XI, 1980 Edition, including the 1981 Winter Addenda. However, due to the geometric configuration of the hot and cold leg nozzles and the bottom head only a limited ultrasonic examination was performed on these nozzles. Relief request number RR-13 and RR-14, will be submitted to the NRC seeking relief from performing 100% volumetric examination of these welds.
4. Several components and supports were reworked or replaced during this outage. refer to sections 8, 9 and 10 of this report for the preservice examination details and section 11, for the NIS-2 reports.
5. The high stress areas (bore and keyways) of the four reactor coolant pump flywheels were examined during the 1989, mid-cycle shutdown. These ultrasonic examinations were conducted to meet Regulatory Guide #1.14, requirements and are creditable to the second period, second interval.

SECTION 8

CLASS 1 EXAMINATION RESULTS

CLASS 1 EXAMINATION RESULTS

Category B-B

Examination Area: Pressure Retaining Welds in Vessels Other Than Reactor Vessels
Examination Method: Volumetric (UT) 0 - 45 - 60 Degree Scans

Item Number	Results	Remarks/Notes
SG-1-BHC-1-A	Acceptable	UT / 3
SG-1-BHC-2-A	Acceptable	UT / 3
SG-1-TSS-3-A	Acceptable	UT / 3, 15
SG-2-BHC-1-A	Acceptable	UT / 3, 15
SG-2-BHC-2-A	Acceptable	UT / 3, 15
SG-2-TSS-3-A	Acceptable	UT / 3

Category B-D

Examination Area: Full Penetration Welds of Nozzles In Vessels

Examination Method: Volumetric (UT) 0 - 45 - 60 Degree and 60 - 70 Degree Scans

Item Number	Results	Remarks/Notes
PR-B-IR-1	Acceptable	UT / 1
PR-NTH-4	Acceptable	UT / 2
PR-NTH-5	Acceptable	UT / 2
PR-T-IR-1	Acceptable	UT / 1, 7
PR-T-IR-3	Acceptable	UT / 1, 7
PR-T-IR-4	Acceptable	UT / 2
PR-T-IR-5	Acceptable	UT / 2
SG-1-IR-2-A	Acceptable	UT / 3
SG-1-IR-4-A	Acceptable	UT / 3
SG-1-IR-5A	Acceptable	UT / 3
SG-1-NH-2-A	Acceptable	UT / 3, 15
SG-1-NH-4-A	Acceptable	UT / 3, 15
SG-1-NH-5-A	Acceptable	UT / 3
SG-2-IR-2-A	Acceptable	UT / 3
SG-2-IR-4-A	Acceptable	UT / 3
SG-2-IR-5-A	Acceptable	UT / 3
SG-2-NH-2-A	Acceptable	UT / 3
SG-2-NH-4-A	Acceptable	UT / 3
SG-2-NH-5-A	Acceptable	UT / 3

Category B-E

Examination Area: Pressure Retaining Partial Penetration Welds in Vessels
Examination Method: Visual (VT)

Item Number	Results	Remarks/Notes
PR-PHC-026	Acceptable	VT-2 / 1
PR-PHC-030	Acceptable	VT-2 / 1
PR-PHC-034	Acceptable	VT-2 / 1
PR-PHC-038	Acceptable	VT-2 / 1
PR-PHC-044	Acceptable	VT-2 / 1
PR-PHC-078	Acceptable	VT-2 / 1
PR-PHC-082	Acceptable	VT-2 / 1
PR-PHC-090	Acceptable	VT-2 / 1
PR-PHC-098	Acceptable	VT-2 / 1
PR-PHC-102	Acceptable	VT-2 / 1
PR-PHC-106	Acceptable	VT-2 / 1
PR-PHC-114	Acceptable	VT-2 / 1

Category B-F

Examination Area: Pressure Retaining Dissimilar Metal Welds In Piping NPS <4 In.
Examination Method: Surface (PT)

Item Number	Results	Remarks/Notes
BPD-C-1001	Acceptable	PT / 1

Category B-G-1

Examination Area: Pressure Retaining Bolting Larger than 2" in Dia.

Examination Method: To meet the requirements of IE Bulletin #82-02, a surface examination (MT) was performed on the disassembled "A" reactor coolant pump studs. While pump was disassembled, a visual exam was also performed on the flange surface.

Item Number	Results	Remarks/Notes
RP-40A-S-01 thru S-16	Acceptable	MT
RP-40A-F-01 thru F16	Acceptable	VT

Category B-G-2

Examination Area: Pressure Retaining Bolting Two Inches in Diameter and Less
 Examination Method: Visual (VT)

Item Number	Results	Remarks/Notes
HJTC-B	Acceptable	VT-1 / 3
RC-100E	Acceptable	VT-1 / 2
RC-100F	Acceptable	VT-1 / 2
RC-200 FLANGE	Acceptable	VT-1 / 3
RC-250	Acceptable	VT-1 / 2
RC-251	Acceptable	VT-1 / 2
SG-1-B-1-A	Acceptable	VT-1 / 3, 15
SG-1-B-3-A	Acceptable	VT-1 / 3
SG-2-B-1-A	Acceptable	VT-1 / 3
SG-2-B-3-A	Acceptable	VT-1 / 3
SI-227 BONNET	Acceptable	VT-1 / 3
SI-235 BONNET	Acceptable	VT-1 / 2
SI-235 PIVOT	Acceptable	VT-1 / 2
SI-634 BONNET	Acceptable	VT-1 / 2

Category B-H

Examination Area: Integral Attachments for Vessels
Examination Method: Volumetric (UT) Surface

Item Number	Results	Remarks/Notes
SG-1-CLL	Acceptable	MT / 3
SG-1-HLL	Acceptable	MT / 3
SG-1-SUP-C-1-A	Acceptable	MT UT / 3, 4
SG-2-CLL	Acceptable	MT / 3, 5
SG-2-HLL	Acceptable	MT / 3, 5
SG-2-SUP-C-1-A	Acceptable	UT / 3, 5

Category B-J

Examination Area: Pressure Retaining Welds in Piping
 Examination Method: Volumetric (UT) and Surface (PT) or (MT) 4" and Over

Item Number	Results	Remarks/Notes
BLD-C-4000-A	Acceptable	PT / 17
BLD-C-4000-B	Acceptable	PT / 17
BLD-C-4008	Acceptable	PT / 2
BLD-C-4010	Acceptable	PT / 2
BLD-C-4012	Acceptable	PT / 2
BLD-C-4018	Acceptable	PT / 2
BLD-C-4022	Acceptable	PT / 2
BLD-C-4024	Acceptable	PT / 2
BLD-C-4036	Acceptable	PT / 2
BLD-C-4044	Acceptable	PT / 2
BLD-C-4046	Acceptable	PT / 2
BPS-C-1009	Acceptable	PT UT / 2
BPS-C-1015	Acceptable	PT UT / 5
BPS-C-1021	Acceptable	PT UT / 2
BPY-C-3046	Acceptable	PT / 2
BPY-C-5037	Acceptable	PT / 2
BPY-C-5039	Acceptable	PT / 2
BPY-C-5055	Acceptable	PT / 2
BPY-C-5057	Acceptable	PT / 2
BPY-C-5061	Acceptable	PT / 2
BSI-C-2027	Acceptable	PT UT / 2
BSI-C-2027A	Acceptable	PT UT / 2
BSI-C-3044	Acceptable	PT UT / 2, 15
BSI-C-3046	Acceptable	PT UT / 2, 15
BSI-C-3048	Acceptable	PT UT / 2, 15
BSI-C-4038	Acceptable	PT UT / 1
BSI-C-4040	Acceptable	PT UT / 1
P-1-C-3-A-A	Acceptable	MT UT / 3, 15

CLASS 1 EXAMINATION RESULTS

Category B-J

Examination Area: Pressure Retaining Welds in Piping
Examination Method: Volumetric (UT) and Surface (PT) or (MT) 4" and Over

Item Number	Results	Remarks/Notes
P-1-C-3-B	Acceptable	MT UT / 3, 15
P-10-C-3-A-A	Acceptable	MT UT / 3, 15
P-10-C-3-B	Acceptable	MT UT / 3, 15
P-11-C-1-A-A	Acceptable	MT UT / 3, 15
P-11-C-1-B	Acceptable	MT UT / 3
P-15-C-1-A-A	Acceptable	MT UT / 3, 15
P-15-C-1-B	Acceptable	MT UT / 3
P-2-C-1-A-A	Acceptable	MT UT / 3, 15
P-2-C-1-B	Acceptable	MT UT / 3
P-6-C-1-A-A	Acceptable	MT UT / 3, 15
P-6-C-1-B	Acceptable	MT UT / 3

CLASS 1 EXAMINATION RESULTS

Category B-L-1

Examination Area: Pressure Retaining Welds in Pump Castings
Examination Method: Volumetric (UT)

Item Number	Results	Remarks/Notes
RP-PCA-1	Acceptable	VT-1 / 1, 18
RP-PCA-1A	Acceptable	VT-1 / 1, 18

CLASS 1 EXAMINATION RESULTS

Category B-M-2

Examination Area: Valve Bodies
Examination Method: Visual (VT)

Item Number	Results	Remarks/Notes
SI-652	Acceptable	VT-1 / 1

CLASS 1 EXAMINATION RESULTS

Category B-N-1

Examination Area: Interior of Reactor Vessel

Examination Method: Visual (VT)

Item Number	Results	Remarks/Notes
CHKW-1	Acceptable	VT-3 / 1
CHKW-2	Acceptable	VT-3 / 1
CHKW-3	Acceptable	VT-3 / 1
CHKW-4	Acceptable	VT-3 / 1
CHMS	Acceptable	VT-3 / 1
KW-1	Acceptable	VT-3 / 1
KW-2	Acceptable	VT-3 / 1
KW-3	Acceptable	VT-3 / 1
KW-4	Acceptable	VT-3 / 1
RV-INT	Acceptable	VT-3 / 1

CLASS 1 EXAMINATION RESULTS

Category C-4.A

Examination Area: Reactor Coolant Pump Flywheels High Stressed Area (Bore & Keyway)
Examination Method: Volumetric (UT)

Item Number	Results	Remarks/Notes
RP-40A-FHS	Acceptable	UT / 19
RP-40B-FHS	Acceptable	UT / 19
RP-40C-FHS	Acceptable	UT / 19
RP-40D-FHS	Acceptable	UT / 19

Notes
Class 1, 2, and 3
Components

- Note 1 Second Period, Second Interval ISI Code Creditable Exam.
- Note 2 Third Period, Second Interval ISI Code Creditable Exam.
- Note 3 This examination was performed for preservice code credit.
- Note 4 The new Steam Generator Number One was selected to be the ISI component. A baseline ultrasonic and magnetic particle examination were both performed on the B-H Category examination area. However, only the magnetic particle examination will be applicable for preservice code credit.
- Note 5 The examination performed on this weld was for information only.
- Note 6 The Steam Generator Number One hydrostatic test was conducted prior to the Class 2 steam generator preservice examination.
- Note 7 Additional inner radius UT examinations were performed on this nozzle to assure adequate coverage.
- Note 8 Indications were noted during this examination but were dispositioned, acceptable per IWF-3400.
- Note 9 This support was rejected per IWF-3400, repaired, and reinspected.
- Note 10 This support examination was added to the work plan per IWF-2430(a).
- Note 11 This support examination was added to the work plan per IWF-2430(b).
- Note 12 This support was examined for preservice credit, rejected per IWF-3400, repaired, and reinspected.
- Note 13 Support #380009 was examined for second period credit instead of support #405707.
- Note 14 This exam was performed while in the area performing exams on adjacent components. It is not for code credit.
- Note 15 NDE indications were noted and reported. However, they were dispositioned as acceptable per the applicable section of the ASME code.
- Note 16 This support was rejected during last period and is being re-examined in accordance with the requirements of IWF-2420(b).
- Note 17 This is a new weld added during the steam generator replacement project and was examined for preservice credit.

- Note 18 This weld was examined in accordance with the requirements of code case N-481, paragraph (b).
- Note 19 The reactor coolant pump flywheel high stress keyway and bore were examined per Reg. Guide 1-14, for second period, second interval credit.
- Note 20 A 70 degree UT scan was also performed to assure comprehensive coverage.
- Note 21 This weld was examined during the 1991 midcycle shutdown. It is located in the Class 2, containment penetration portion of a piping system. These welds will be added to the ten-year ISI program and examined in accordance with the 1980 Edition, including the Winter 1981 Addenda of the ASME Boiler and Pressure Vessel Code, Section XI.
- Note 22 This support has been removed from the piping system. The removal was verified during this refueling outage.

SECTION 9

CLASS 2 EXAMINATION RESULTS

CLASS 2 EXAMINATION RESULTS

Category C-A

Examination Area: Pressure Retaining Welds in Pressure Vessels
Examination Method: Volumetric (UT) 0-45-60 Degrees

Item Number	Results	Remarks/Notes
1-SC-2A	Acceptable	UT / 3, 15, 20
1-SC-3	Acceptable	UT / 1, 15
1-SC-4	Acceptable	UT / 3, 15
1-SC-5	Acceptable	UT / 3, 15
2-SC-2A	Acceptable	UT / 5, 15, 20
2-SC-4	Acceptable	UT / 5, 15
2-SC-5	Acceptable	UT / 5, 15
SG-1-BHSC-2-A	Acceptable	UT / 3, 15
SG-1-THS-1	Acceptable	UT / 2, 15
SG-1-THS-2	Acceptable	UT / 2, 15
SG-2-BHSC-2-A	Acceptable	UT / 5, 15

CLASS 2 EXAMINATION RESULTS

Category C-B

Examination Area: Pressure Retaining Nozzle Welds in Vessels
Examination Method: Volumetric (UT) Surface (MT)

Item Number	Results	Remarks/Notes
SG-2-MS-1	Acceptable	MT UT / 2
SG-2-MS-IR-1	Acceptable	UT / 2

CLASS 2 EXAMINATION RESULTS

Category C-C

Examination Area: Integral Attachments for Vessels, Piping, Pumps & Valves
Examination Method: Surface (PT or MT)

Item Number	Results	Remarks/Notes
402060 C-C	Acceptable	PT / 2
404020 C-C	Acceptable	PT / 2
412017 C-C	Acceptable	MT / 2
502024 C-C	Acceptable	PT / 2
SG-1-CC-1	Acceptable	MT / 3
SG-1-CC-2	Acceptable	MT / 3

CLASS 2 EXAMINATION RESULTS

Category C-F

Examination Area: Pressure Containing Welds in Piping
Examination Method: Thickness 1/2" or Less, Surface (PT) or (MT); Thickness Over 1/2",
Volumetric (UT) Surface (PT) or (MT)

Item Number	Results	Remarks/Notes
CP-050 *	Acceptable	MT / 21
CP-055 *	Acceptable	MT / 21
CP-125 *	Acceptable	MT / 21
W -008 *	Acceptable	MT / 21
W -010 *	Acceptable	MT / 21
W -024 *	Acceptable	MT / 21
W -036 *	Acceptable	MT / 21
W -044 *	Acceptable	MT / 21
W -050 *	Acceptable	MT / 21
W -125 *	Acceptable	MT / 21
W -CHP-01 *	Acceptable	MT / 21
W -CHP-07 *	Acceptable	MT / 21
W -CHP-08 *	Acceptable	MT / 21

CLASS 2 EXAMINATION RESULTS

Category C-F

Examination Area: Pressure Containing Welds in Piping
 Examination Method: Thickness 1/2" or Less Surface (PT or MT); Thickness Over 1/2"
 Volumetric (UT) and Surface (PT or MT)

Item Number	Results	Remarks/Notes
FWA-C-G-01-A	Acceptable	MT UT / 3
FWA-C-G-02-A	Acceptable	PT UT / 3, 15
FWA-C-G-03-A	Acceptable	MT UT / 3
FWA-C-G-04-A	Acceptable	MT UT / 3
FWA-C-G-18	Acceptable	MT / 3
FWA-C-G-19	Acceptable	MT / 3
FWA-C-G-20	Acceptable	MT / 3
FWB-C-G-01-A	Acceptable	MT UT / 3, 15
FWB-C-G-02-A	Acceptable	PT UT / 3, 15
FWB-C-G-03-A	Acceptable	MT UT / 3, 15
FWB-C-G-04-A	Acceptable	MT UT / 3, 15
MSA-CG-01B	Acceptable	MT UT / 3, 15
MSA-CG-02A	Acceptable	MT UT / 3
MSA-CG-03A	Acceptable	MT UT / 3
MSA-CG-04A	Acceptable	MT UT / 3
MSB-CG-01B	Acceptable	MT UT / 3, 15
MSB-CG-02A	Acceptable	MT UT / 3
MSB-CG-03A	Acceptable	MT UT / 3
MSB-CG-04A	Acceptable	MT UT / 3
SI-CF-A-076	Acceptable	PT / 2
SI-CF-A-084	Acceptable	PT / 2
SI-CF-B-072	Acceptable	PT / 2
SI-CF-B-076	Acceptable	PT / 2
SI-CF-B-085	Acceptable	PT / 2, 15
SI-CF-C-009	Acceptable	PT / 2

CLASS 2 EXAMINATION RESULTS

Category C-F

Examination Area: Pressure Containing Welds in Piping
Examination Method: Thickness 1/2" or Less Surface (PT or MT); Thickness Over 1/2"
Volumetric (UT) and Surface (PT or MT)

Item Number	Results	Remarks/Notes
SI-CF-E-037	Acceptable	PT / 2
SI-CF-X-04	Acceptable	PT / 2
SI-CF-X-07	Acceptable	PT / 2
SI-CF-X-14	Acceptable	PT / 2
SIT-CF-D007	Acceptable	PT / 2

CLASS 2 EXAMINATION RESULTS

Category C-H

Examination Area: All Pressure Retaining Components
Examination Method: Visual (VT-2)

Item Number	Results	Remarks/Notes
STM GEN #1	Acceptable	VT-2 / 6
STM GEN #2	Acceptable	VT-2

**Notes
Class 1, 2, and 3
Components**

- Note 1 Second Period, Second Interval ISI Code Creditable Exam.
- Note 2 Third Period, Second Interval ISI Code Creditable Exam.
- Note 3 This examination was performed for preservice code credit.
- Note 4 The new Steam Generator Number One was selected to be the ISI component. A baseline ultrasonic and magnetic particle examination were both performed on the B-H Category examination area. However, only the magnetic particle examination will be applicable for preservice code credit.
- Note 5 The examination performed on this weld was for information only.
- Note 6 The Steam Generator Number One hydrostatic test was conducted prior to the Class 2 steam generator preservice examination.
- Note 7 Additional inner radius UT examinations were performed on this nozzle to assure adequate coverage.
- Note 8 Indications were noted during this examination but were dispositioned, acceptable per IWF-3400.
- Note 9 This support was rejected per IWF-3400, repaired, and reinspected.
- Note 10 This support examination was added to the work plan per IWF-2430(a).
- Note 11 This support examination was added to the work plan per IWF-2430(b).
- Note 12 This support was examined for preservice credit, rejected per IWF-3400, repaired, and reinspected.
- Note 13 Support #380009 was examined for second period credit instead of support #405707.
- Note 14 This exam was performed while in the area performing exams on adjacent components. It is not for code credit.
- Note 15 NDE indications were noted and reported. However, they were dispositioned as acceptable per the applicable section of the ASME code.
- Note 16 This support was rejected during last period and is being re-examined in accordance with the requirements of IWF-2420(b).
- Note 17 This is a new weld added during the steam generator replacement project and was examined for preservice credit.

- Note 18 This weld was examined in accordance with the requirements of code case N-481, paragraph (b).
- Note 19 The reactor coolant pump flywheel high stress keyway and bore were examined per Reg. Guide 1-14, for second period, second interval credit.
- Note 20 A 70 degree UT scan was also performed to assure comprehensive coverage.
- Note 21 This weld was examined during the 1991 midcycle shutdown. It is located in the Class 2, containment penetration portion of a piping system. These welds will be added to the ten-year ISI program and examined in accordance with the 1980 Edition, including the Winter 1981 Addenda of the ASME Boiler and Pressure Vessel Code, Section XI.
- Note 22 This support has been removed from the piping system. The removal was verified during this refueling outage.

SECTION 10

IWF EXAMINATION RESULTS

CLASS 1 EXAMINATION RESULTS

Category IWF 1

Examination Area: Class 1, IWF Supports
 Examination Method: Visual (VT)

Item Number	Results	Remarks/Notes
408017-E	Acceptable	VT-3 & 4 / 3
410024	Acceptable	VT-3 / 1
410049	Acceptable	VT-3 / 1
491385-E	Acceptable	VT-3 / 2
491385-J	Acceptable	VT-3 / 2
491385-L	Acceptable	VT-3 / 2
491385-M	Acceptable	VT-3 / 2
491385-N	Acceptable	VT-3 / 2
491385-U	Acceptable	VT-3 / 12
491389-T	Acceptable	VT-3 / 2
491412	Acceptable	VT-3 / 2
491418-A	Acceptable	VT-3 / 14
491422-B	Acceptable	VT-3 / 2
491440	Acceptable	VT-3 / 2, 8
491440-H	Acceptable	VT-3 / 2
491440-M	Acceptable	VT-3 / 2
491440-P	Acceptable	VT-3 / 2
491440-W	Acceptable	VT-3 / 2
491440-X	Acceptable	VT-3 / 2
491440-Z	Acceptable	VT-3 / 2, 8

CLASS 2 EXAMINATION RESULTS

Category IWF 2

Examination Area: Class 2, IWF Supports
 Examination Method: Visual (VT)

Item Number	Results	Remarks/Notes
304015	Acceptable	VT-3 / 22
312009	Acceptable	VT-3 & 4 / 3, 15
380278	Acceptable	VT-3 & 4 / 2, 8, 16
402047	Acceptable	VT-3 / 10, 15
402048	Acceptable	VT-3 / 10
402052	Acceptable	VT-3 / 2, 9
402060	Acceptable	VT-3 / 2
402062	Acceptable	VT-3 / 10
402078	Acceptable	VT-3 / 2
404018	Acceptable	VT-3 & 4 / 2, 15
404019	Acceptable	VT-3 & 4 / 2
404020	Acceptable	VT-3 / 2
404022	Acceptable	VT-3 / 2
407001	Acceptable	VT-3 / 2, 15
407003	Acceptable	VT-3 / 2
412012	Acceptable	VT-3 & 4 / 3, 9
412017	Acceptable	VT-3 / 3
502004	Acceptable	VT-3 / 2
502013	Acceptable	VT-3 / 2
502023	Acceptable	VT-3 / 2
502024	Acceptable	VT-3 / 2, 9
502026	Acceptable	VT-3 & 4 / 2
502035	Acceptable	VT-3 / 2

CLASS 3 EXAMINATION RESULTS

Category IWF 3

Examination Area: Class 3, IWF Supports
 Examination Method: Visual (VT)

Item Number	Results	Remarks/Notes
1-156SHT.1	Acceptable	VT-3 / 2
303002	Acceptable	VT-3 / 2, 15
303004	Acceptable	VT-3 / 2
303071	Acceptable	VT-3 / 2, 15
305573	Acceptable	VT-3 / 2
305574	Acceptable	VT-3 / 2
305581	Acceptable	VT-3 / 2, 3
305582	Acceptable	VT-3 / 3
305583	Acceptable	VT-3 / 2
305807	Acceptable	VT-3 / 2
305808	Acceptable	VT-3 / 2
305923	Acceptable	VT-3 / 2
313074	Acceptable	VT-3 / 2
327002	Acceptable	VT-3 / 11
327007	Acceptable	VT-3 / 3, 15
327017	Acceptable	VT-3 / 3
327122	Acceptable	VT-3 / 3
327123	Acceptable	VT-3 / 3
327124	Acceptable	VT-3 / 3
327125	Acceptable	VT-3 / 3, 15
327135	Acceptable	VT-3 / 3
327138	Acceptable	VT-3 / 3, 15
327141	Acceptable	VT-3 / 3
327145	Acceptable	VT-3 / 2, 9
327147	Acceptable	VT-3 / 3
327148	Acceptable	VT-3 / 2, 15

CLASS 3 EXAMINATION RESULTS

Category IWF 3

Examination Area: Class 3, IWF Supports
 Examination Method: Visual (VT)

Item Number	Results	Remarks/Notes
327149	Acceptable	VT-3 / 3
327150	Acceptable	VT-3 / 2, 3, 15
327157	Acceptable	VT-3 / 3
327160	Acceptable	VT-3 / 3, 15
327165	Acceptable	VT-3 / 3
329012	Acceptable	VT-3 / 2, 15
329015	Acceptable	VT-3 / 3, 9
329033	Acceptable	VT-3 / 3
329042	Acceptable	VT-3 / 3
329044	Acceptable	VT-3 / 3
329047	Acceptable	VT-3 / 3, 15
380009	Acceptable	VT-3 / 1, 13
403016	Acceptable	VT-3 / 2
403047	Acceptable	VT-3 / 2
403048	Acceptable	VT-3 & 4 / 2
403064	Acceptable	VT-3 / 14
403067	Acceptable	VT-3 / 14
403068	Acceptable	VT-3 / 2
403071	Acceptable	VT-3 / 2, 15
403080	Acceptable	VT-3 / 2
403090	Acceptable	VT-3 & 4 / 2
405123	Acceptable	VT-3 / 2, 15
405503	Acceptable	VT-3 / 2, 15
405634	Acceptable	VT-3 / 2
405635	Acceptable	VT-3 / 2
405692	Acceptable	VT-3 / 2
405875	Acceptable	VT-3 / 2

CLASS 3 EXAMINATION RESULTS

Category IWF 3

Examination Area: Class 3, IWF Supports
 Examination Method: Visual (VT)

Item Number	Results	Remarks/Notes
405876	Acceptable	VT-3 / 2
405889	Acceptable	VT-3 / 2
405890	Acceptable	VT-3 / 2
405891	Acceptable	VT-3 / 2
405901	Acceptable	VT-3 / 16
405962	Acceptable	VT-3 / 2
413128	Acceptable	VT-3 / 2
413185	Acceptable	VT-3 / 2
413186	Acceptable	VT-3 / 2
413187	Acceptable	VT-3 / 2
413189	Acceptable	VT-3 / 2
413190	Acceptable	VT-3 / 2
415053	Acceptable	VT-3 & 4 / 2
427055	Acceptable	VT-3 / 3, 15
427056	Acceptable	VT-3 / 2
427063	Acceptable	VT-3 / 2
427067	Acceptable	VT-3 / 2, 3, 9
427069	Acceptable	VT-3 / 3
427080	Acceptable	VT-3 / 3, 9
427082	Acceptable	VT-3 / 3
427084	Acceptable	VT-3 / 3
427085	Acceptable	VT-3 / 3
427087	Acceptable	VT-3 / 3
427092	Acceptable	VT-3 / 3
427093	Acceptable	VT-3 / 2, 3
427094	Acceptable	VT-3 / 3
427098	Acceptable	VT-3 / 10, 9

CLASS 3 EXAMINATION RESULTS

Category IWF 3

Examination Area: Class 3, IWF Supports
 Examination Method: Visual (VT)

Item Number	Results	Remarks/Notes
427099	Acceptable	VT-3 / 2
427102	Acceptable	VT-3 & 4 / 2, 15
427104	Acceptable	VT-3 / 3
427110	Acceptable	VT-3 / 2
427112	Acceptable	VT-3 / 2, 3
427113	Acceptable	VT-3 / 14
450172	Acceptable	VT-3 / 3
503012	Acceptable	VT-3 / 2
503013	Acceptable	VT-3 / 2
503014	Acceptable	VT-3 / 2
503017	Acceptable	VT-3 / 2
503018	Acceptable	VT-3 / 2
503020	Acceptable	VT-3 / 2
503021	Acceptable	VT-3 / 2
503022	Acceptable	VT-3 / 2
505179	Acceptable	VT-3 / 2
505230	Acceptable	VT-3 / 2
513018	Acceptable	VT-3 / 2
527009	Acceptable	VT-3 / 3
527010	Acceptable	VT-3 / 3
527011	Acceptable	VT-3 / 3, 15
527012	Acceptable	VT-3 / 3, 9
527013	Acceptable	VT-3 / 3
527014	Acceptable	VT-3 / 3, 12
527017	Acceptable	VT-3 / 3, 12
527019	Acceptable	VT-3 / 3
527045	Acceptable	VT-3 / 2, 15

CLASS 3 EXAMINATION RESULTS

Category IWF 3

Examination Area: Class 3, IWF Supports
 Examination Method: Visual (VT)

Item Number	Results	Remarks/Notes
527067	Acceptable	VT-3 / 3
527068	Acceptable	VT-3 / 9, 11
527069	Acceptable	VT-3 / 9, 11
527070	Acceptable	VT-3 / 9, 11
59894	Acceptable	VT-3 / 2
60469	Acceptable	VT-3 / 3
60518	Acceptable	VT-3 / 3
60519	Acceptable	VT-3 / 3
6JGD-M-7A-4	Acceptable	VT-3 / 2
6JGD-M-7A-5	Acceptable	VT-3 / 2
6JGD-M-7A-7	Acceptable	VT-3 / 2, 15
8JGD-M-7A-1	Acceptable	VT-3 / 2
8JGD-M-7A-2	Acceptable	VT-3 / 2, 3, 15
8JGD-M-7A-3	Acceptable	VT-3 / 2
8JGD-M-7B-2	Acceptable	VT-3 / 3
8JGD-M-7B-3	Acceptable	VT-3 / 3

**Notes
Class 1, 2, and 3
Components**

- Note 1 Second Period, Second Interval ISI Code Creditable Exam.
- Note 2 Third Period, Second Interval ISI Code Creditable Exam.
- Note 3 This examination was performed for preservice code credit.
- Note 4 The new Steam Generator Number One was selected to be the ISI component. A baseline ultrasonic and magnetic particle examination were both performed on the B-H Category examination area. However, only the magnetic particle examination will be applicable for preservice code credit.
- Note 5 The examination performed on this weld was for information only.
- Note 6 The Steam Generator Number One hydrostatic test was conducted prior to the Class 2 steam generator preservice examination.
- Note 7 Additional inner radius UT examinations were performed on this nozzle to assure adequate coverage.
- Note 8 Indications were noted during this examination but were dispositioned, acceptable per IWF-3400.
- Note 9 This support was rejected per IWF-3400, repaired, and reinspected.
- Note 10 This support examination was added to the work plan per IWF-2430(a).
- Note 11 This support examination was added to the work plan per IWF-2430(b).
- Note 12 This support was examined for preservice credit, rejected per IWF-3400, repaired, and reinspected.
- Note 13 Support #380009 was examined for second period credit instead of support #405707.
- Note 14 This exam was performed while in the area performing exams on adjacent components. It is not for code credit.
- Note 15 NDE indications were noted and reported. However, they were dispositioned as acceptable per the applicable section of the ASME code.
- Note 16 This support was rejected during last period and is being re-examined in accordance with the requirements of IWF-2420(b).
- Note 17 This is a new weld added during the steam generator replacement project and was examined for preservice credit.

- Note 18 This weld was examined in accordance with the requirements of code case N-481, paragraph (b).
- Note 19 The reactor coolant pump flywheel high stress keyway and bore were examined per Reg. Guide 1-14, for second period, second interval credit.
- Note 20 A 70 degree UT scan was also performed to assure comprehensive coverage.
- Note 21 This weld was examined during the 1991 midcycle shutdown. It is located in the Class 2, containment penetration portion of a piping system. These welds will be added to the ten-year ISI program and examined in accordance with the 1980 Edition, including the Winter 1981 Addenda of the ASME Boiler and Pressure Vessel Code, Section XI.
- Note 22 This support has been removed from the piping system. The removal was verified during this refueling outage.

SECTION 11

CORRECTIVE MEASURES RECOMMENDED AND TAKEN

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/06/93
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California AWO 42-92-1910
(Address)

4. Identification of System Feedwater Piping Support

5. (a) Applicable Construction Code 19 Edition, Addenda, Code Cases (SEE ATTACHMENT)
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, B1W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Pipe Support	Bechtel	-	-	-	412012	1975	Modification	No
	Fluor	-	-	-		1992	Modified	No

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other - NOT APPLICABLE
 Pressure psi Test Temp. °F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Modification conforms to Section XI of the ASME Code.
(repair or replacement)

Signed [Signature] Title Owner Date January 26, 1992
(Owner or Owner's Designee) (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by HJB&T Co of Hartford, CT have inspected the Feedwater Piping Support described in this Report
(Repair(s) or Replacement(s))
 on Dec 08, 1992 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12 FEB 93 [Signature] YORK AND CT 1137
(Inspector) (Commissions) (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in Items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/05/93
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System Feedwater Piping Support

5(a) Applicable Construction Code: Original supports were fabricated to ANSI B31.7 requirements which invoked AISC for design, MSS-SP-58 for fabrication and AWS for welding. Replacement supports invoke AISC, MSS-SP-58 and AWS D1.1-1990 Edition for welding.

7. Replacement steam generator necessitated a portion of feedwater piping be replaced. This piping replacement necessitated an adjustment in the subject piping support.

Work was performed per AWO M2-92-19118.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/15/92
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California AWO - 112-92-17852
(Address)

4. Identification of System Feedwater Piping Support

5. (a) Applicable Construction Code 19 Edition, Addenda, Code Cases (SEE ATTACHMENT)
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Pipe Support	Bechtel	-	-	-	412017	1975	Modified	No
	Fluor	-	-	-		1992	Modification	No

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other - NOT APPLICABLE
Pressure psi Test Temp. °F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Gilbert Sauter 1/20/ 1993
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by HOBAS of HARTFORD, CT have inspected the Repair by MODERN described in this Report
(Repair(s) or Replacement(s))

on December 7, 1992 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12 FEB 93 Yorkville Commissions CT 1137
13 FEB 93 (Inspector) (State or Province National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/15/92
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System Feedwater Piping Support

5(a) Applicable Construction Code: Original supports were fabricated to ANSI B31.7 requirements which invoked AISC for design, MSS-SP-58 for fabrication and AWS for welding. Replacement supports invoke AISC, MSS-SP-58 and AWS D1.1-1990 Edition for welding.

7. Replacement steam generator necessitated a portion of feedwater piping be replaced. This piping replacement necessitated an adjustment in the subject piping support.

Work was performed per AWO M2-92-17852.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/23/92
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Milistone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California 772-92-17832
(Address)

4. Identification of System Steam Generator #1 - Arc Strike Repair

5. (a) Applicable Construction Code ASME Section III 1983 Edition, Summer '84 Addenda, Code Cases NA
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1980, B1W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Steam Generator	B&W	761201	123			1983 1984S	Repair	Yes

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 1250 psi Test Temp. 140°F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Repair conforms to Section XI of the ASME Code.
(Repair or replacement)

Signed Alberto Medina Luna Engineer January 26, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of NY, employed by HSBITE CO of Hartford, CT have inspected the REPAIR described in this Report
(Repair(s) or Replacement(s))

on Dec 8, 19 92 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 26 Jan 93 Alberto Medina Luna Commissions NY 5137
(Inspector) (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in Items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/23/92
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)
4. Identification of System Steam Generator #1 - Arc Strike Repair

7. Description of Work: Arc strike was removed by grinding. Surface NDE was performed after grinding. Work was performed per AWO M2-92-17832.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/22/92
 (Name)
Waterford, Connecticut Sheet 1 of 2
 (Address)

2. Plant Millstone Unit Two
 (Name)
Waterford, Connecticut
 (Address)

3. Work Performed by Fluor Constructors Fluor Constructors
 (Name) Repair Organization P.O. No., Job No., etc.
Irvine, California AWC 172-92-17134
 (Address)

4. Identification of System Reactor Coolant - Pressurizer Surge Line Support

5. (a) Applicable Construction Code 19 Edition, Addenda, Code Cases (SEE ATTACHMENT)
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Pipe Support	Bechtel	-	-	-	408017	1975	Modified	No
	Fluor	-	-	-	408017	1992	Modification	No

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other - NOT APPLICABLE
 Pressure psi Test Temp. °F

9. Remarks _____
 (Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Modification conforms to Section XI of the ASME Code. (repair or replacement)

Signed John P. ... January 26, 1993
 (Owner or Owner's Designee) Title Date

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by HEBI-IL of Waterford, CT have inspected the Reactor Coolant - Pressurizer Surge Line Support described in this Report (Repairs) or Replacement(s) on 08 Jan, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12 FEB 93 E YORK AVE CT 06187
10 000 02 Paul Commissions 1125047
 (Inspector) AWI (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/22/92
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System Reactor Coolant - Pressurizer Surge Line Support

5(a) Applicable Construction Code: Original supports were fabricated to ANSI B31.7 requirements which invoked AISC for design MSS-SP-58 for fabrication and AWS for welding. Modification invoked AISC, MSS-SP-58 and AWS D1.1-1990 Edition for welding.

7. Modification entailed cutting off 9 inches of beam end. This end provided no structural strength to remaining support.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/06/93
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California AWO 172-92-14235
(Address)

4. Identification of System Steam Generator #1 - Instrument Nozzle Repair

5. (a) Applicable Construction Code ASME III 1983 Edition, SB4 Addenda, Code Cases
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Steam Generator	B&W	761201	123			1983 1984S	Repaired	Yes

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 1250 psi Test Temp. 140°F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Repair conforms to Section XI of the ASME Code.
(repair or replacement)

Signed [Signature] January 26, 1993
(Owner or Owner's Designee) Title Date

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by HARTFORD of HARTFORD, CT have inspected the Repair described in this Report
(Repair(s) or Replacement(s))

on Dec 8, 1992 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 26 Jan 1993 [Signature] ANI Commissions WA 5012 41137 NB9304
(Inspector) ANI (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/06/93
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)
4. Identification of System Steam Generator #1 - Instrument Nozzle Repair

7. Description of Work: During installation of the steam generator subassembly a nozzle was damaged by the grinding of adjacent girth weld. Weld repair of nozzle was performed. Work was performed per AWO M2-92-16235.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/03/92
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California M2-92-07339, M2-92-09857
(Address)

4. Identification of System Main Steam Support

5. (a) Applicable Construction Code 19 Edition, See Attachment Addenda, Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980, 81W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Support 312009 H2	Bechtel	N/A	N/A	N/A	N/A	1975	Replaced	No
	Fluor	N/A	N/A	N/A	N/A	1992	Replacement	No

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other - NOT APPLICABLE
Pressure psi Test Temp. °F

9. Remarks
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Repair conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Richard Louis Evans January 26, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by NSRI-IG of Waterford, CT have inspected the Replacement described in this Report
(Repair or Replacement)

on December 09, 19 92 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12 FEB 93 EXORL AM III Commissions CT 1137
12 FEB 93 NSI 2
(Inspector) (State or Province, National Board) 42

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/03/92
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)
4. Identification of System Main Steam Support

5(a) Original Code of Construction for piping was ANSI B31.7 and ASME Section III. Both these codes invoked MSS-SP-58 for support components and fabrications. The replacement support components were fabricated to MSS-SP-58, 1988 Edition.

7. Work Description: Steam generator replacement necessitated modification of a main steam piping hanger support (34-EBB-2, Hanger 2). Modification required installation of new spring hanger.

*Work performed per AWO M2-92-07339 and M2-92-09857,
J. Palmer 1/26/93*

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California AWO 112-92-11390 / MANUAL
(Address) ORDER
2-92-016
4. Identification of System RBCCW - Bolting Replacement

5. (a) Applicable Construction Code B31.1 1983 Edition, No Addenda, Code Cases N/A (SEE ATTACHMENT)
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Re,aced or Replacement	ASME Code Stamped (Yes or No)
RBCCW Piping	Bechtel				6-HBD(B)-125 3-HBD(B)-125	1975	Replaced	No
	Fluor				3-HBD(B)-125 6-HBD(B)-125	1992	Replacement	No

7. Description of Work See Attachment
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
Pressure 175 psi Test Temp. 75°F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replaced conforms to Section XI of the ASME Code. (repair or replacement)

Signed Charles Louis Egan Title _____ Date January 26, 1993
(Owner or Owner's Designer)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by HSR, I.G. of Waterford, CT have inspected the Replacement described in this Report (Repair(s) or Replacement(s))

on November 28, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12 FEB 93 E. YORK CT1137
11 FEB 93 R. W. KANE Commissions 115502
(Inspector) (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System RBCCW - Bolting Replacement

5(a) Applicable Construction Code: Original Construction Code was ANSI B31.1-1967 and modified by Bechtel specification. Replacement was performed per ANSI B31.1-1983 Edition

7. Description of Work: Bolting replacement was performed on 6-HBD(B)-125 and 3-HBD(B)-125. Work was performed per AWO M2-92-11340 and M2-92-00016. *Hydrostatic Test per M2-92-11340*

Replacement bolting materials were as follows:

- 3/4 inch - SA 193, Grade B7 HT #VV
- 3/4 inch - SA 194, Grade 2H HT #045
- 5/8 inch - SA 193, Grade B7 HT #PP
- 5/8 inch - SA 194, Grade 2H HT #CB

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/15/92
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California AWO 112-92-11291
(Address) 112-92-14087

4. Identification of System RBCCW

5. (a) Applicable Construction Code B31.1 1983 Edition, No Addenda, Code Cases N/A (SEE ATTACHMENT)
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, B1W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
RBCCW Piping	Bechtel	-	-		6-HBD(B)-125	1975	Replaced	No
	Fluor	-	-		6-HBD(B)-125	1992	Replacement	No

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
Pressure 175 psi Test Temp. 75°F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Alan H. ... 1/20, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by HSBI-IG of Hartford, CT have inspected the REPLACEMENT described in this Report
(Repair(s) or Replacement(s))

on NOVEMBER 28, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12 FEB 93 F. YORIKANI CT1137
11 FEB 93 PH... Commissions ...
(Inspector) ANI (State or Province) National Board 39

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/15/92
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)


2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System RBCCW

5(a) Applicable Construction Code: Original Construction Code was ANSI B31.1-1967 and modified by Bechtel specification. Replacement was performed per ANSI B31.1-1983 Edition.

7. Description of Work: Replacement comprised of the removal and reinstallation of a section of 6-inch diameter piping. Two new welds were added to piping. Original piping materials were reused. Work was performed per AWO M2-92-11291.



25208-20180 SH 772

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/23/92
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California AWO M2-92-15267
(Address)

4. Identification of System Reactor Coolant System

5. (a) Applicable Construction Code ASME Section III 1971 Edition, Summer '71 Addenda, Code Cases NA
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
RCS Piping	Bechtel	-	-	-	2-CCA-14	1975	Modified	Yes(NA)
	Fluor	-	-	-	2-CCA-14	1992	No	

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
Pressure 2295 psi Test Temp. 532°F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replant conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Anthony Louis Egos February 11, 1993
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by HSBI-IG of Waterford, Ct have inspected the Repair/replace RCS described in this Report (Repair or Replacement(s)) on Jan 08, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12 FEB 93 EYORK ANI CT1137
11 FEB 93 Richard Commissions 224502
(Inspector) ANI (State or Province, National Board) 38

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in Items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/23/92
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)
4. Identification of System Reactor Coolant System

7. Description of Work: Pipe segments were removed to facilitate RCS piping debris removal. Pipe returned to original configuration with exception of a socket weld coupling added. (Reference Drawings 25203-20152, Sheets 2 and 143). Work performed per AWO M2-92-15267. Coupling material HT: 1G5099/DBK

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/15/92
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California FWO-12-92-10175
(Address)

4. Identification of System Feedwater

5. (a) Applicable Construction Code ASME Section III 1983 Edition, 84S Addenda, Code Cases N/A
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Feedwater Pipe Elbow	Connex	-	-		SBA CS-3428-2	1992	Repaired	No

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 1250 psi Test Temp. 140°F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Alan Shive Senior Engineer January 26 19 93
(Owner or Owner's Designer) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by HSBI-IG of Waterford, CT have inspected the Repair described in this Report
(Repair(s) or Replacement(s))
 on February 12, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12 FEB 93 PHANK NEW YORK ANI CT 1137
(Inspector) (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/15/92
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)


2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System Feedwater

7. Feedwater pipe elbow required weld buildup to meet minimum wall requirements. See Sketch below.
Work performed per AWO M2-92-10175.

18" SCH 160 ELBOW
SN/SBA-3



FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/03/92
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System Steam Generator #2 - Blowdown

5. (a) Applicable Construction Code 19 Edition, N/A Addenda, Code Cases See Attached
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases N/A

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Net'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Pipe Supports	Fluor	N/A	N/A	N/A	N/A	1992	Replacement	No
	Bechtel	N/A	N/A	N/A	N/A	1975	Replaced	No

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other - N/A
 Pressure psi Test Temp. °F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Richard L. Sauer January 30, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CT, employed by HEBBI CO of CT have inspected the REPLACEMENT described in this Report
(Repair(s) or Replacement(s))

on 28 Dec, 19 92 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 1-26-93 Richard L. Sauer CT 1137
(Inspector) Commissions (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/03/92
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System Steam Generator #2 - Blowdown

- 5(a) Applicable Construction Code: Original supports were fabricated to ANSI B31.7 requirements which invoked AISC for design, MSS-SP-58 for fabrication and AWS for welding. Replacement supports invoke AISC, MSS-SP-58 and AWS D1.1-1990 Edition for welding.
7. Replacement steam generator necessitated portions of blowdown piping be redesigned and replaced. The replacement blowdown piping required new support design and installation. See attached sketches for new support locations.

SUPPORT IDENTIFICATION	DRAWING	WORK ORDER
60386 (SHOP)	86242-22200-60386*	M2-91-11876
60387 (SHOP)	86242-22200-60387*	M2-91-11876
60388 (SHOP)	86242-22200-60388*	M2-91-11876
60390 (SHOP)	86242-22200-60390*	M2-91-11876
60386 (FIELD)	86242-22200-60386	M2-92-01763
60387 (FIELD)	86242-22200-60387	M2-92-01763
60388 (FIELD)	86242-22200-60388	M2-92-01763
60389 (FIELD)	86242-22200-60389	M2-92-01763
60390 (FIELD)	86242-22200-60390	M2-92-01763
60386 **	86242-22200-60386	M2-92-04584
60387 **	86242-22200-60387	M2-92-04584
60391 **	86242-22200-60391	M2-92-04584
Hanger 2	86242-22200-491356A	M2-92-04129
Hanger 3	86242-22200-491356B	M2-92-04129
Hanger 4	86242-22200-491356C	M2-92-04129
Hanger 6	86242-22200-491356C	M2-92-04129
Hanger 2	86242-22200-491357B	M2-92-04129
Hanger 2	86242-22200-491357	M2-92-04129

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California AWO 172-92-10820
(Address)

4. Identification of System RBCCW Piping Support

5. (a) Applicable Construction Code 19 Edition, Addenda, Code Cases
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, B1W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Pipe Support	Bechtel				305581	1975	Replaced	No
	Bechtel				450172	1975	Replaced	No
	Fluor				305581	1992	Replacement	No
	Fluor				450172	1992	Replacement	No

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other NOT APPLICABLE
 Pressure psi Test Temp. °F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed William J. Taylor January 26, 1993
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by H&B I G of Waterford CT have inspected the Replacement described in this Report
(Repair(s) or Replacement(s))

on Nov. 23, 1992 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 26 Jan 93 William J. Taylor Commissions 1745047
(Inspector) (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System RBCCW Piping Support

5(a) Applicable Construction Code: Original supports were fabricated to ANSI B31.7 requirements which invoked AISC for design, MSS-SP-58 for fabrication and AWS for welding. Replacement supports invoke AISC, MSS-SP-58 and AWS D1.1-1990 Edition for welding.

7. Replacement steam generator necessitated a portion of feedwater piping be replaced. This piping replacement necessitated the temporary removal and reinstallation of two supports. Hangers replaced were H-1 on Drawing 25203-22200, Sheet 305581 and H-13, R-15 on Drawing 25203-22200, Sheet 450172.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/03/92
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System Steam Generator #1 - Blowdown

5. (a) Applicable Construction Code 19 Edition, N/A Addenda, Code Cases See Attached
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases N/A

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Pipe Supports	Fluor	N/A	N/A	N/A	N/A	1992	Replacement	No
	Bechtel	N/A	N/A	N/A	N/A	1975	Replaced	No

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other - N/A
 Pressure psi Test Temp. °F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Richard A. [Signature] Date January 28, 19 93
(Owner or Owner's Designee) (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by HEBI-IGA of HARTFORD, CT have inspected the Replacement described in this Report
(Repairs) or Replacement(s)

on Dec 8, 19 93 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 26 Dec 93 [Signature] Commissions NYSC12
(Inspector) (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this date report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/03/92
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System Steam Generator #1 - Blowdown

- 5(a) Applicable Construction Code: Original supports were fabricated to ANSI B31.7 requirements which invoked AISC for design, MSS-SP-58 for fabrication and AWS for welding. Replacement supports invoke AISC, MSS-SP-58 and AWS D1.1-1990 Edition for welding.
7. Replacement steam generator necessitated portions of blowdown piping be redesigned and replaced. The replacement blowdown piping required new support design and installation. See attached sketches for new support locations.

SUPPORT IDENTIFICATION	DRAWING	WORK ORDER
60395 (SHOP)	86242-22200-60395*	M2-91-11876
60396 (FIELD)	86242-22200-60396	M2-92-01762
60397 (FIELD)	86242-22200-60397	M2-92-01762
60395 (FIELD)	86242-22200-60395	M2-92-01762
60395 **	86242-22200-60395	M2-92-04583
60396 **	86242-22200-60396	M2-92-04583
NO. 4 **	86242-22200-491354E	M2-92-04583
NO. 3 **	86242-22200-491355C	M2-92-04583
NO. 4	86242-22200-491354D	M2-92-04128
NO. 5	86242-22200-491354F	M2-92-04128
NO. 6	86242-22200-491354G	M2-92-04128
NO. 3	25203-22200-491354C	M2-92-18559

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 1 of 4
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California M2-92-10672
(Address) M2-92-01611

4. Identification of System Steam Generator #2 - Blowdown Piping

5. (a) Applicable Construction Code ASME III 1971 Edition, No Addenda, Code Cases N/A
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, B1W Addenda, Code Cases
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Blowdown Piping	Bechtel					1975	Replaced	Yes (N/A)
	Fluor					1992	Replacement	No
							Replacement	Yes

7. Description of Work See Attachment
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
Pressure 1250 psi Test Temp. 140°F
9. Remarks See attached sheet for valves
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed [Signature] Senior Engineer February 10, 1993
(Owner or Owner's Designer) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by HSSI + I C of WATERFORD, CT have inspected the REPLACEMENT described in this Report
(Repair(s) or Replacement(s))
on December 08, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12 FEB 93 EXORK AMI CT1137
11 FEB 93 [Signature] [Signature] Commissions NY 5012
(Inspector) (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 2 of 4
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California M2-92-10672
(Address) M2-92-01611

4. Identification of System Steam Generator #2 - Blowdown Piping

- 5(a) Original field installation was performed in accordance with ASME Section III, 1971 Edition. Valves were originally installed in accordance with various ASME Code editions including ASME Draft Pump and Valve Code. Replacement valves were manufactured to ASME Section III, 1986 Edition.
6. Bechtel field installation was NA stamped in accordance with ASME Section III, 1971. Dravo spool pieces were fabricated in accordance with ANSI B31.7 and provided with NPP-1 form. Replacement piping materials for this replacement were procured in accordance with ASME Section III, 1983 Edition including Summer, 1984 Addenda. Field installation was in accordance with ASME Section III, 1971 Edition.
7. Blowdown piping was replaced from steam generator nozzle out to connection to existing 2 inch blowdown piping within containment.


Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Valves	*	**						
4"-Gate	A-D	-7-7	N/A	-	2-MS-454B	1992	Replacement	Yes
4"-Gate	A-D	-7-8	N/A	-	2-MS-455B	1992	Replacement	Yes
4"-Gate	A-D	-7-9	N/A	-	2-MS-456B	1992	Replacement	Yes
4"-Gate	A-D	-7-10	N/A	-	2-MS-457B	1992	Replacement	Yes
2"-Globe	A-D	-5-5	N/A	-	2-WL-27B	1992	Replacement	Yes
2"-Globe	A-D	-5-7	N/A	-	2-WL-29B	1992	Replacement	Yes
2"-Globe	A-D	-5-30	N/A	-	2-MS-12A	1992	Replacement	Yes

* Manufacturer - Anchor Darling (A-D)
 ** Manufacturers Serial Number Prefix E-T022-

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner	<u>Northeast Nuclear Energy Company</u> (Name) <u>Waterford, Connecticut</u> (Address)	Date <u>1/08/93</u>
2. Plant	<u>Millstone</u> (Name) <u>Waterford, Connecticut</u> (Address)	Sheet <u>3</u> of <u>4</u>
3. Work Performed by	<u>Fluor Constructors</u> (Name) <u>Irvine, California</u> (Address)	<u>Fluor Constructors</u> Repair Organization P.O. No., Job No., etc.
4. Identification of System	<u>Steam Generator #2 - Blowdown Piping</u>	

FIGURE
Blowdown Piping




3	1/8" dia	1/2" dia	THIS JOINT IDENT SCHEMATIC
2	1/8" dia	1/2" dia	F2 STM GENERATOR BLOWDOWN
1	1/8" dia	1/2" dia	STEAM GENERATOR #2
0	1/8" dia	1/2" dia	REVISION NO. EC242-20116 SH 87
REV	BY	DATE	NO. 91-1012 DRAWING NO. 4 20

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner	<u>Northeast Nuclear Energy Company</u> (Name) <u>Waterford, Connecticut</u> (Address)	Date <u>1/08/93</u>
2. Plant	<u>Millstone</u> (Name) <u>Waterford, Connecticut</u> (Address)	Sheet <u>4</u> of <u>4</u>
3. Work Performed by	<u>Fluor Constructors</u> (Name) <u>Irvine, California</u> (Address)	<u>Fluor Constructors</u> Repair Organization P.O. No., Job No., etc.
4. Identification of System	<u>Steam Generator #2 - Blowdown Piping</u>	

FIGURE
Wet Layup Piping



⊙ = SHOP WELD

			IDENTIFICATION SCHEMATIC
			#2 GEN. ELU. DOWN. PIPING
			REVISED BY: ECP-111 DATE: N/A
			REVISED BY: ECP-111 DATE: N/A
REVISED BY: ECP-111	DATE: N/A	REVISED BY: ECP-111	DATE: N/A
REVISED BY: ECP-111	DATE: N/A	REVISED BY: ECP-111	DATE: N/A

8. Remarks 4"-600#-FW Valve for E-T022-7, Gasket Retainer SA515-70

9. Design conditions 1095 psi 600 °F or valve pressure class 600 (11)
(pressure) (temperature)

10. Cold working pressure 1480 psi at 100°F

11. Hydrostatic test 2225 psi. Disk differential test pressure 1628 (11)

CERTIFICATION OF DESIGN

Design Specifications certified by Kenneth T. Roberts P.E. State Connecticut Reg. no. 16915
 Design Report certified by Theron C. Bartlett II P.E. State PA Reg. no. PE-039036-E

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. 41712 Expires 4/15/92

Date 4-3-92 Name Anchor/Darling Valve Company signed Gary D. Larson
(N Certificate holder) (authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State ~~of~~ of Pennsylvania and employed by Commercial Union Ins. Co. of Boston, Mass. have inspected the pump, or valve, described in this Data Report on 11-791 Rev 4-7, 19 92 and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4-7-92 Signed Charles J. Grimes Commission Pennsylvania 2392
(N.B. 1. Bd. (incl. endorsement) state or prov. and no.)

(1) For manually coated valves only.

4"-600#-FW Valve for E-T022-7, Gasket Retainer SA515-70

8. Remarks

9. Design conditions (pressure) 1095 psi (temperature) 600 °F or valve pressure class 600 (1)

10. Cold working pressure 1480 psi at 100°F

11. Hydrostatic test 2225 psi. Disk differential test pressure 1628 psi

CERTIFICATION OF DESIGN

Design Specification certified by Kenneth T. Roberts P.E. State Connecticut Reg. no. 16915
Design Report certified by Theron C. Bartlett II P.E. State PA Reg. no. PE-039036-E

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N1712 Expires 4-15-95
Date 4-15-92 Name Anchor/Darling Valve Company Signed Henry R. Larson
(N Certificate Holder) (Authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Pennsylvania and employed by Commercial Union Ins. Co. of Boston, Mass. have inspected the pump, or valve, described in this Data Report on 11-2-91 at 4-20-92, 19 92, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4-20-92 Signed Charles Young Commissions Pennsylvania 2392
(Natl. Bd. and endorsement) state or prov. and no.

(1) For manually operated valves only.

8. Remarks 2"-1878#-GB for E-T022-5

9. Design conditions 3425 psi 600 °F or valve pressure class 1878 (1)

10. Cold working pressure 4635 psi at 100°F

11. Hydrostatic test 6975 psi. Disk differential test pressure 5101 psi

CERTIFICATION OF DESIGN

Design Specification certified by Kenneth T. Roberts P.E. State Connecticut Reg. no. 16915
Design Report certified by Theron C. Bartlett II P.E. State PA Reg. no. PE-039036-E

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N1712 Expires 4/15/92

Date 1-30-92 Name Anchor/Darling Valve Company Signed Gay D. Larson
(IN Certificate Holder) (authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State ~~XXXXXX~~ of Pennsylvania and employed by Commercial Union Ins. Co. of Boston, Mass. have inspected the pump, or valve, described in this Data Report on 2-90-9064-2-18, 19 92, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-18-92 Signed Charles Young Commissions Pennsylvania 2392
(Natl. Bd. (incl. endorsement) state or prov. and no.)

(1) For manually operated valves only.

8. Remarks 2"-1700#-DD for E-T022-6

9. Design conditions 3425 psi 600 °F or valve pressure class 1700 (1)

(pressure) (temperature)

10. Cold working pressure 4198 psi at 100°F

11. Hydrostatic test 6300 psi. Disk differential test pressure 4618 psi

CERTIFICATION OF DESIGN

Design Specification certified by Kenneth T. Roberts P.E. State Connecticut Reg. no. 16915

Design Report certified by Theron C. Bartlett II P.E. State PA Reg. no. PE-039036-E

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N1712 Expires 4/15/92

Date 1-30-92 Name Anchor/Darling Valve Company Signed Gary R. Larson
(N Certificate Holder) (Authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State ~~MASSACHUSETTS~~ of Pennsylvania and employed by Commercial Union Ins. Co. of Boston, Mass. have inspected the pump, or valve, described in this Data Report on 4-29-92 at 26, 19 92, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-6-92 Signed Charles Young Commissions Pennsylvania 2392
(Natl. Bd. (incl. endorsements) state or prov. and no.)

(1) For manually operated valves only.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 1 of 4
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California M2-92-10672
(Address) M2-92-01610

4. Identification of System Steam Generator #1 - Blowdown Piping

5. (a) Applicable Construction Code ASME III 1971 Edition, No Addenda, Code Cases N/A
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Blowdown Piping	Bechtel					1975	Replaced	Yes (N/A)
	Fluor					1992	Replacement	No
							Replacement	Yes

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
Pressure 1250 psi Test Temp. 140°F

9. Remarks See attached sheet for valves
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code. (repair or replacement)

Signed [Signature] [Signature] February 10, 1993
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by HCRC-IG of Waterford, CT have inspected the Replacement described in this Report (Repair(s) or Replacement(s))

on December 08, 1992 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12 FEB 93 [Signature] AN CT 1137
11 FEB 93 (Inspector) AN Commissions (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
 (Name)
Waterford, Connecticut Sheet 2 of 4
 (Address)

2. Plant Millstone Unit Two
 (Name)
Waterford, Connecticut
 (Address)

3. Work Performed by Flyor Constructors Flyor Constructors
 (Name) Repair Organization P.O. No., Job No., etc.
Irvine, California M2-92-10672
 (Address) M2-92-01610

4. Identification of System Steam Generator #1 - Blowdown Piping

- 5(a) Original field installation was performed in accordance with ASME Section III, 1971 Edition. Valves were originally installed in accordance with various ASME Code editions including ASME Draft Pump and Valve Code. Replacement valves were manufactured to ASME Section III, 1986 Edition.
6. Bechtel field installation was NA stamped in accordance with ASME Section III, 1971. Dravo spool pieces were fabricated in accordance with ANSI B31.7 and provided with NPP-1 form. Replacement piping materials for this replacement were procured in accordance with ASME Section III, 1983 Edition including Summer, 1984 Addenda. Field installation was in accordance with ASME Section III, 1971 Edition.
7. Blowdown piping was replaced from steam generator nozzle out to connection to existing 2 inch blowdown piping within containment.

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Valves	*	**						
4"-Gate	A-D	-7-3	N/A	-	2-MS-454A	1992	Replacement	Yes
4"-Gate	A-D	-7-4	N/A	-	2-MS-455A	1992	Replacement	Yes
4"-Gate	A-D	-7-5	N/A	-	2-MS-456A	1992	Replacement	Yes
4"-Gate	A-D	-7-6	N/A	-	2-MS-457A	1992	Replacement	Yes
2"-Globe	A-D	-5-1	N/A	-	2-WL-27A	1992	Replacement	Yes
2"-Globe	A-D	-5-3	N/A	-	2-WL-29A	1992	Replacement	Yes
2"-Gate	A-D	-5-29	N/A	-	2-MS-12A	1992	Replacement	Yes

- * A-D is Anchor Darling
- ** Manufacturers Serial Number Prefix E-T022-

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI


1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 3 of 4
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System Steam Generator #1 - Blowdown Piping

FIGURE
Blowdown Piping



	3	1/2	5/8	TITLE	JOINT IDENT MAP
	2	1/2	3/4		BLOWDOWN PIPING #1 SGT
	1	1/2	3/4	SECTION NO.	BDD-362
				SCALE	NA
				REFERENCE Dwg.	PR-242-20116 SHT 022
				WORK NO.	M2-92-01610
				ENCLOSURE NO.	A.1

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI


1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 4 of 4
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System Steam Generator #1 - Blowdown Piping

FIGURE
Wet Layup Piping



			THIS JOINT IDENT MAP	
			WET LAY UP PIPING	
			SECTION NO. EPR-502	SCALE NA
			REFERENCE NO. EG242-20251	
			EG242-20116 SHEET 001	
REV	DATE	BY	APPROV NO. M09-01610	ENCLOSURE NO. 4.1

8. Remarks 4"-600#-FW Valve for E-T022-7, Gasket Retainer SA515-70

9. Design conditions 1095 psi 600 °F or valve pressure class 600 (1)

(pressure) (temperature)

10. Cold working pressure 1480 psi at 100°F

11. Hydrostatic test 2225 psi. Disk differential test pressure 1628 psi

CERTIFICATION OF DESIGN

Design Specification certified by Kenneth T. Roberts P.E. State Connecticut Reg. no. 16915
 Design Report certified by Theron C. Bartlett II P.E. State PA Reg. no. PE-039036-E

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N1712 Expires 4/15/92

Date 4-3-92 Name Anchor/Darling Valve Company Signed Gary D. Larson
(N Certificate Holder) (Authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State ~~Board of~~ of Pennsylvania and employed by Commercial Union Ins. Co. of Boston, Mass. have inspected the pump, or valve, described in this Data Report on 11-291 thru 4-7, 19 92, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4-7-92 Signed Charles J. Gonyea Commission No. Pennsylvania 2392
(Inspector) (N.B. Bd. (incl. endorsement) state or prov. and no.)

(1) For manually operated valves only.

8. Remarks 4"-600#-FW Valve for E-T022-7, Gasket Retainer SA515-70

9. Design conditions 1095 psi 600 °F or valve pressure class 600 (11)
(pressure) (temperature)

10. Cold working pressure 1480 psi at 100°F

11. Hydrostatic test 2225 psi. Disk differential test pressure 1628 psi

CERTIFICATION OF DESIGN

Design Specification certified by Kenneth T. Roberts P.E. State Connecticut Reg. no. 16915
Design Report certified by Theron C. Bartlett II P.E. State PA Reg. no. PE-039036-E

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N1712 Expires 4-15-95
Date 4-15-92 Name Anchor/Darling Valve Company Signed Henry D. Larson
(N Certificate Holder) (Authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State ~~Inspector~~ of Pennsylvania and employed by Commercial Union Ins. Co. of Boston, Mass. have inspected the pump, or valve, described in this Data Report on 11-7-91 to 4-20, 1992, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4-20-92 Signed Charles Young Commissions Pennsylvania 2392
(Natl. Bd. (incl. endorsements) state or prov. and no.)

(1) For manually operated valves only.

8. Remarks 2"-1878#-GB for E-T022-5

9. Design conditions 3425 psi 600 °F or valve pressure class 1878 (1)

(pressure) (temperature)

10. Cold working pressure 4635 psi at 100°F

11. Hydrostatic test 6975 psi. Disk differential test pressure 5101 psi

CERTIFICATION OF DESIGN

Design Specification certified by Kenneth T. Roberts P.E. State Connecticut Reg. no. 16915
 Design Report certified by Theron C. Bartlett II P.E. State PA Reg. no. PE-039036-E

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N1712 Expires 4/15/92

Date 1-30-92 Name Anchor/Darling Valve Company Signed Henry D. Larson
(N Certificate Holder) (Authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State ~~XXXXXX~~ of Pennsylvania and employed by Commercial Union Ins. Co. of Boston, Mass. have inspected the pump, or valve, described in this Data Report on 2-90-9062-18, 19 92, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-18-92 Signed Charles T. Young Commissions Pennsylvania 2392
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) state or prov. and no.)

(1) For manually operated valves only.

8. Remarks 2"-1700#-DD for E-T022-6

9. Design conditions 3425 psi 600 °F or valve pressure class 1700 (1)

(pressure) (temperature)

10. Cold working pressure 4198 psi at 100°F

11. Hydrostatic test 6300 psi. Disk differential test pressure 4618 psi

CERTIFICATION OF DESIGN

Design Specification certified by Kenneth T. Roberts P.E. State Connecticut Reg. no. 16915
 Design Report certified by Theron C. Bartlett II P.E. State PA Reg. no. PE-039036-E

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N1712 Expires 4/15/92

Date 1-30-92 Name Anchor/Darling Valve Company Signed Harry R. Larson
(N Certificate Holder) (Authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State ~~XXXXXX~~ of Pennsylvania and employed by Commercial Union Ins. Co. of Boston, Mass. have inspected the pump, or valve, described in this Data Report on 4-29-88 thru 26, 19 92, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 2-6-92 Signed Charles E. Young Commissions Pennsylvania 2392
(Natl. Bd. Incl. endorsements; state or prov. and no.)

(1) For manually operated valves only.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/01/92
(Name)
Waterford, Connecticut Sheet 1 of 3
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California 72-92-01769 SGRP20/32
(Address) 72-92-00593 SGRP20
72-92-07314 SGRP20
4. Identification of System Steam Generator #2 - Main Steam
5. (a) Applicable Construction Code ASME III 1971 Edition, No Addenda, Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19P, 81W Addenda, Code Cases
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Piping	Bechtel	2103				1975	Partial Replaced	Yes (NA)
	Dravo				EBB 3-8	1974	Partial Replaced	No
	Connex	42171				1982	Replacement	Yes
	Fluor					1992	Replacement	No

7. Description of Work See Attachment
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other - SEE ATTACHMENT
Pressure 1250°F psi Test Temp. 140 °F
9. Remarks NPP-1 for 42171
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Report conforms to Section XI of the ASME Code. (repair or replacement)

Signed [Signature] [Signature] [Signature] January 26, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by NSRI/IG of Waterford, CT have inspected the Replacement described in this Report (Repair(s) or Replacement(s))

on Dec 8-9, 19 93 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19 FEB 93 [Signature] FLUOR ANE CTN37
(Inspector) (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/01/92
(Name)
Waterford, Connecticut Sheet 2 of 3
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)
4. Identification of System Steam Generator #2 - Main Steam

6. Original field installation NA stamped by Bechtel per ASME Section III, 1971 Edition. Dravo shop spool pieces provided with ANSI B31.7, Class II Form NPP-1.

7. Description of Work: Steam generator replacement necessitated the removal and replacement of main steam piping from steam generator safe end to approximately second elbow from generator (see attached sketches). The original spool pieces were shop fabricated to ANSI B31.7 by Dravo. The original field installation was performed by Bechtel and stamped to ASME Section III, 1971 Edition.

An NPT stamped spool piece replacement shop fabricated by Connex was field installed by Fluor. The shop fabricated spool piece was stamped in accordance with ASME Section III, 1983 Edition including Summer, 1984 Addenda. The field installation of the replaced piping was in accordance with ASME Section III, 1971 Edition.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI


1. Owner Northeast Nuclear Energy Company Date 12/01/92
(Name)
Waterford, Connecticut Sheet 3 of 3
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)

4. Identification of System Steam Generator #2 - Main Steam

FIGURE



- P.O. # 71510-50-5001-00
1. HTR 24412 WK 10-28-92
 2. HTR 2152 FW 3147 WK 10-28-92
 3. HTR 24412 WK 10-28-92
 4. HTR CMC-FAH-F3005A 10-28-92

* WELDS "E", "C" & "D" DONE BY CONEX. SEE SKETCH # E-4217-1

FORM NPP-1 CERTIFICATE HOLDERS' DATA REPORT FOR FABRICATED
NUCLEAR PIPING SUBASSEMBLIES*

As Required by the Provisions of the ASME Code, Section III, Division 1

Pg. 1 of 2

1. Fabricated and certified by Connex Pipe Systems, Inc., 1115 Gilman Street, Marietta, Ohio 45750
(Name and address of NPT Certificate Holder)
2. Fabricated for Fluor Constructors International, Inc. **
(Name and address)
3. Location of installation Millstone Unit 2 SGRP **
(Name and address of Purchaser)
4. Type 42171 N/A E4217-1 Rev. 2 N/A 1992
(Cert. Holder's serial no.) (CRN) (drawing no.) (Nat'l. Bd. no.) (year built)
5. ASME Code, Section III, Division 1: 1983 Summer 1984 2 N/A
(edition) (issuance date) (class) (Code Case no.)
6. Shop hydrostatic test N/A psi at N/A *F (if performed)
7. Description of piping Main Steam See page 2 of 2
8. Certificate Holders' Data Reports properly identified and signed by commissioned inspectors have been furnished for the following items of this report: Piece Mark Number: 715100-50-5006K0 #2.11
9. Remarks: N/A

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that the fabrication of the described piping subassembly conforms to the rules for construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. N-1320 Expires March 1, 1994
Date 4-17-92 Name Connex Pipe Systems, Inc. Signed Mark A. L. D.
(NPT Certificate Holder) (Authorized Representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Ohio and employed by Allendale Mutual Insurance Company, Factory Mutual System of Norwood, MA have inspected the piping subassembly described in this Data Report on 4-17-92 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated this piping subassembly in accordance with the ASME Code, Section III, Division 1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the piping subassembly described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4-17-92 Signed J. E. Farrell Commissions Ohio
(Authorized Inspector) (Nat'l. Bd. and state or prov. and no.)

* Supplemental information in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/88)

This form (E00062) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300

** Rope Ferry Road, Route 156, Waterford, CT 06385

Certificate Holder's Serial No. _____

10. Description of field fabrication _____

11. Pneu., hydro., or comb. test pressure _____ psi at temp. _____ *F (if performed)

CERTIFICATE OF FIELD FABRICATION COMPLIANCE

We certify that the statements on this report are correct and that the field fabrication of the described piping subassembly conforms with the rules for construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. _____ Expires _____

Date _____ Name _____ (Certificate Holder) Signed _____ (Authorized representative)

CERTIFICATE OF FIELD FABRICATION INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of _____ and employed by _____

of _____ have compared the statements in this Data Report with the described piping subassembly and state that parts referred to as data items _____, not included in the Certificate of Shop Inspection, have been inspected by me on _____ and that to the best of my knowledge and belief the Certificate Holder has fabricated this piping subassembly in accordance with the ASME Code, Section III, Division 1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the piping subassembly described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ (Authorized Inspector) Commissions _____ (that include endorsements and 1-52, 52A, and 52B)



PIPE SYSTEMS

Connex Pipe Systems, Inc.
1115 Gilmer Street
Marietta
Ohio 45750
Telephone 614 373 7541
Fax 614 373 8480
Twx 810 466 2605

SUMMARY PAGE - CMTR'S SKETCH E4217-1

<u>ITEM #</u>	<u>HEAT #</u>	<u>SERIAL #</u>	<u>MTR SERIAL #</u>	<u>DESCRIPTION</u>
1	P18502	1	7	34" (.977" MW) SMLS PIPE SA106C
2	L4065	1	6	34" X 28" (.977" MW) R/ELL SA234 WPC
3	SCC	1	3	36" X 28" (1.007" MW) C/RED SA234 WPC
4	337TNR	-	8	3/4" ON 34" 3000# S-O-L SA105
5	AUE	-	5	CODE PLATE SA240 TP304

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/01/92
(Name)
Waterford, Connecticut Sheet 1 of 3
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California AWO 72-92-01768/SGRP 19131
(Address) 72-92-00592/SGRP 19
72-92-07314/SGRP A420

4. Identification of System Steam Generator #1 - Main Steam

5. (a) Applicable Construction Code ASME III 1971 Edition, No Addenda, Code Cases
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Piping	Bechtel	2103				1975		Yes (NA)
	Dravo				EBB-2-1 EBB-2-2	1974		No
	Connex	42172				1992	Replacement	Yes
	Fluor					1992	Replacement	No

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other - SEE ATTACHMENT
 Pressure 1250°F psi Test Temp. 140 °F

9. Remarks NPP-1 for 42172
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code. (repair or replacement)

Signed William Louis Emerson January 26, 1993
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by HERTZIG of Watford CT have inspected the Replacement described in this Report (Repair(s) or Replacement(s)) on Dec 8-9, 1992 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19 FEB 93 F YORK ANZE CT1137
11 FEB 93 P. W. G. Commissions NY5042
(Inspector) AWA (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/01/92
(Name)
Waterford, Connecticut Sheet 2 of 3
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California #12-92-0176B / SGRP 19431
(Address) #12-92-00592 / SGRP 19
#12-92-073141

4. Identification of System Steam Generator #1 - Main Steam

6. Original field installation NA stamped by Bechtel per ASME Section III, 1971 Edition. Dravo shop spool pieces provided with ANSI B31.7, Class II Form NPP-1.


7. Description of Work: Steam generator replacement necessitated the removal and replacement of main steam piping from steam generator safe end to approximately second elbow from generator (see attached sketches). The original spool pieces were shop fabricated to ANSI B31.7 by Dravo. The original field installation was performed by Bechtel and stamped to ASME Section III, 1971 Edition.

An NPT stamped spool piece replacement shop fabricated by Connex was field installed by Fluor. The shop fabricated spool piece was stamped in accordance with ASME Section III, 1983 Edition including Summer, 1984 Addenda. The field installation of the replaced piping was in accordance with ASME Section III, 1971 Edition.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner	<u>Northeast Nuclear Energy Company</u> (Name) <u>Waterford, Connecticut</u> (Address)	Date <u>12/01/92</u> Sheet <u>3</u> of <u>3</u>
2. Plant	<u>Millstone</u> (Name) <u>Waterford, Connecticut</u> (Address)	Unit <u>Two</u>
3. Work Performed by	<u>Fluor Constructors</u> (Name) <u>Irvine, California</u> (Address)	<u>Fluor Constructors</u> Repair Organization P.O. No., Job No., etc. <u>112-92-01768</u> <u>112-92-00592</u> <u>112-92-07314</u>
4. Identification of System	<u>Steam Generator #1 - Main Steam</u>	

FIGURE



*WELDS "B", "C", "D" DONE BY CONNEX SEE SKETCH # E-4217-2

**FORM NPP-1 CERTIFICATE HOLDERS' DATA REPORT FOR FABRICATED
NUCLEAR PIPING SUBASSEMBLIES***

As Required by the Provisions of the ASME Code, Section III, Division 1

Pg. 1 of 2

1. Fabricated and certified by Connex Pipe Systems, Inc., 1115 Gilman Street, Marietta, Ohio 45750
(Name and address of NPT Certificate Holder)

2. Fabricated for Fluor Constructors International, Inc. **
(Name and address)

3. Location of installation Millstone Unit 2 SGRP **
(Name and address of Purchaser)

4. Type 42172 N/A E4217-2 Rev. 2 N/A 1992
(Cert. Holder's serial no.) (CRN) (Drawing no.) (Nat'l. Bd. no.) (Year built)

5. ASME Code, Section III, Division 1: 1983 Summer 1984 2 N/A
(Edition) (Issuance date) (Class) (Code Case no.)

6. Shop hydrostatic test N/A psi at N/A *F (if performed)

7. Description of piping Main Steam See page 2 of 2

8. Certificate Holders' Data Reports properly identified and signed by commissioned inspectors have been furnished for the following items of this report: Piece Mark Number: 715100-50-5006KQ #2.11

9. Remarks: N/A

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that the fabrication of the described piping subassembly conforms to the rules for construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. N-1320 Expires March 1, 1994

Date 4-17-92 Name Connex Pipe Systems, Inc. Signed Mark A. Felt
(NPT Certificate Holder) (Authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Ohio and employed by Allendale Mutual Insurance Company, Factory Mutual System of Norwood, MA have inspected the piping subassembly described in this

Data Report on 4-17-92, and state that to the best of my knowledge and belief, the Certificate Holder has fabricated this piping subassembly in accordance with the ASME Code, Section III, Division 1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the piping subassembly described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4-17-92 Signed B. E. Lowell Commissions OH-10
(Authorized Inspector) (Nat'l. Bd. Incl. endorsements and state or prov. and no.)

*Supplemental information in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/88)

This form (E00062) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300

** Rope Ferry Road, Route 156, Waterford, CT 06385

Certificate Holder's Serial No. _____

10. Description of field fabrication _____

11. Pneu., hydro., or comb. test pressure _____ psi at temp. _____ °F (if performed)

CERTIFICATE OF FIELD FABRICATION COMPLIANCE

We certify that the statements on this report are correct and that the field fabrication of the described piping subassembly conforms with the rules for construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. _____ Expires _____

Date _____ Name _____ (Certificate Holder) Signed _____ (Authorized representative)

CERTIFICATE OF FIELD FABRICATION INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of _____ and employed by _____ of _____ have compared the statements in this Data Report with the described piping subassembly and state that parts referred to as data items _____, not included in the Certificate of Shop Inspection, have been inspected by me on _____ and that to the best of my knowledge and belief the Certificate Holder has fabricated this piping subassembly in accordance with the ASME Code, Section III, Division 1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the piping subassembly described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ (Authorized Inspector) Commissions _____ (Nat'l. Bd. (incl. endorsements) and state or prov. and no.)



CONNEX

PIPE SYSTEMS

Connex Pipe Systems, Inc.
1115 Birman Street
Marietta
Ohio 45750
Telephone 614 373 7541
Fax 614 373 8480
Twx 810 486 2808

SUMMARY PAGE - CMTR'S SKETCH E4217-2

<u>ITEM #</u>	<u>HEAT #</u>	<u>SERIAL #</u>	<u>MTR SERIAL #</u>	<u>DESCRIPTION</u>
1	P18502	2	7	34" (.977" MW) SMLS PIPE SA106C
2	L4065	2	6	34" X 28" (.977" MW) R/ELL SA234 WPC
3	SOC	2	3	36" X 28" (1.007" MW) C/RED SA234 WPC
4	337TNR	-	8	3/4" ON 34" 3000# S-O-L SA105
5	AUE	-	5	CODE PLATE SA240 TP304

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/03/92
(Name)
Waterford, Connecticut Sheet 1 of 3
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California AWO M2-92-00637
(Address) M2-92-01771

4. Identification of System Steam Generator No. 2 - Feedwater

5. (a) Applicable Construction Code ASME 1971 Edition, No Addenda, Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Feedwater	Bechtel	2103				1975	Replaced	Yes
Piping	Dravo				EBB-6-12	1974	Replaced	No
	NU	N/A	N/A	N/A		1979	Replaced	No
	Fluor	N/A	N/A	N/A		1992	Replacement	No
	Connex	42176			E4217-6	1992	Replacement	Yes

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other - SEE ATTACHMENT
Pressure 1250 psi Test Temp. 140°F

9. Remarks NPP-1
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Alan Melvin Senior Engineer January 26, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE		SGRP 1611B
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of <u>Connecticut</u> , employed by <u>HSEI-IC</u> of <u>Waterford, CT</u> have inspected the <u>Replacement</u> described in this Report (Repair(s) or Replacement(s))		
on <u>Dec 27th</u> , 19 <u>93</u> and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.		
Date <u>19 FEB 1993</u>	<u>E. J. ORK ANZI</u> (Inspector) <u>AWI</u>	<u>CT 1139</u> Commissions <u>DISCZ</u> (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in Items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/03/92
(Name)
Waterford, Connecticut Sheet 2 of 3
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California *M2-92-00637*
(Address) *M2-92-01771*


4. Identification of System Steam Generator No. 2 - Feedwater

- 5(a) Original field installation was performed in accordance with ASME Section III, 1971 Edition. Original shop fabricated spool pieces were fabricated in accordance with ANSI B31.7-1967. A portion of the feedwater piping being replaced was a replacement performed by NU in 1979 under ASME Section XI.
6. Bechtel field installation was stamped in accordance with ASME Section III, 1971. Dravo spool pieces were fabricated in accordance with ANSI B31.7 and provided with NPP-1 form. Replacement spool pieces for this replacement were procured in accordance with ASME Section III, 1983 Edition including Summer, 1984 Addenda. Field installation was in accordance with ASME Section III, 1971 Edition.
7. Feedwater piping was replaced from steam generator nozzle out to and including second elbow outside of steam generator blockhouse (see attached sketch).

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner	<u>Northeast Nuclear Energy Company</u> (Name) <u>Waterford, Connecticut</u> (Address)	Date <u>12/03/92</u> Sheet <u>3</u> of <u>3</u>
2. Plant	<u>Millstone</u> (Name) <u>Waterford, Connecticut</u> (Address)	Unit <u>Two</u>
3. Work Performed by	<u>Fluor Constructors</u> (Name) <u>Irvine, California</u> (Address)	<u>Fluor Constructors</u> Repair Organization P.O. No., Job No., etc. <u>M2-92-00637</u> <u>M2-92-01771</u>
4. Identification of System	<u>Steam Generator No. 2 - Feedwater</u>	

FIGURE



FEEDWATER WELD SEQUENCE

1. FEEDWATER PIPE TO NOZZLE
 - A. AUTOMATIC INTERNAL MACHINE WELD
 - B. PRE-HEAT = 250 DEGREE
 - C. PWHT TO 1150 DEGREES
2. THERMAL SLEEVE TO GOOSENECK OF FEEDWATER RING HEADER
 - A. AUTOMATIC INTERNAL MACHINE WELD
 - B. PRE-HEAT = 50 DEGREE
 - C. NO PWHT
3. FEEDWATER PIPE TO SCH 160 ELBOW
 - A. MANUAL GTAW AND SMAW WELD
 - B. GTAW ROOT AND HOT PASS
 - C. SMAW REMAINDER OF JOINT
 - D. PRE-HEAT = 50 DEGREE
 - E. NO PWHT
4. THERMAL SLEEVE TO SCH 160 ELBOW
 - A. AUTOMATIC INTERNAL MACHINE WELD
 - B. PRE-HEAT = 50 DEGREE
 - C. NO PWHT
5. SCH 160 ELBOW TO SCH 60 ELBOW
 - A. MANUAL GTAW AND SMAW WELD
 - B. GTAW ROOT AND HOT PASS
 - C. SMAW REMAINDER OF JOINT
 - D. PRE-HEAT = 50 DEGREE
 - E. NO PWHT
6. SCH 60 ELBOW TO EXISTING 18" FEEDWATER PIPE
 - A. MANUAL GTAW AND SMAW WELD
 - B. GTAW ROOT AND HOT PASS
 - C. SMAW REMAINDER OF JOINT
 - D. PRE-HEAT = 50 DEGREE
 - E. NO PWHT

TITLE <u>FW WELDING SEQUENCE AND JOINT IDENT MAP</u>			
SHEET NO. <u>EXP-356</u>		SCALE <u>NA</u>	
REFERENCE DOC. <u>NA</u>			
REV	DATE	CHG BY	APPROV NO. <u>M2-92-00637</u> ENCLOSURE NO. <u>4.2</u>

**FORM NPP-1 CERTIFICATE HOLDERS' DATA REPORT FOR FABRICATED
NUCLEAR PIPING SUBASSEMBLIES***

As Required by the Provisions of the ASME Code, Section III, Division 1

Pg. 1 of 2

- Fabricated and certified by Connex Pipe Systems, Inc., 1115 Gilman Street, Marietta, Ohio 45750
(Name and address of NPT Certificate Holder)
2. Fabricated for Fluor Constructors International Inc. **
(Name and address)
3. Location of installation Millstone Unit 2 SGRP **
(Name and address of Purchaser)
4. Type 42176 N/A E4217-6 Rev. 3 N/A 1992
(Cert. Holder's serial no.) (CRN) (drawing no.) (Nat'l. Bd. no.) (year built)
5. ASME Code, Section III, Division 1: 1983 Summer 1984 2 N/A
(edition) (addenda date) (class) (Code Case no.)
6. Shop hydrostatic test N/A psi at N/A °F (if performed)
7. Description of piping Feedwater See page 2 of 2
8. Certificate Holders' Data Reports properly identified and signed by commissioned inspectors have been furnished for the following items of this report: Piece Mark Number: 715100-50-5006K0 #2.10
9. Remarks: N/A

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that the fabrication of the described piping subassembly conforms to the rules of construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. N-1320 Expires March 1, 1994
Date 4-17-92 Name Connex Pipe Systems, Inc. Signed Mark A. Link
(NPT Certificate Holder) (Authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Ohio and employed by Allendale Mutual Insurance Company, Factory Mutual System of Norwood, MA have inspected the piping subassembly described in this Data Report on 4-17-92 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated this piping subassembly in accordance with the ASME Code, Section III, Division 1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the piping subassembly described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4-17-92 Signed Richard Commissions OHIO
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) and state or prov. and no.)

* Supplemental information in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.
(12/88) This form (E00062) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300.

** Rope Ferry Road, Route 156, Waterford, CT 06385

Certificate Holder's Serial No. _____

10. Description of field fabrication _____

11. Pneu., hydro., or comb. test pressure _____ psi at temp. _____ °F (if performed)

CERTIFICATE OF FIELD FABRICATION COMPLIANCE

We certify that the statements on this report are correct and that the field fabrication of the described piping subassembly conforms with the rules for construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. _____ Expires _____

Date _____ Name _____ (Certificate Holder) Signed _____ (Authorized representative)


CERTIFICATE OF FIELD FABRICATION INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of _____ and employed by _____

of _____ of _____ have compared the statements in this Data Report with the described piping subassembly and state that parts referred to as data items _____, not included in the Certificate of Shop Inspection, have been inspected by me on _____ and that to the best of my knowledge and belief the Certificate Holder has fabricated this piping subassembly in accordance with the ASME Code, Section III, Division 1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the piping subassembly described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ (Authorized Inspector) Commissions _____ (Nat'l. Bd. (incl. endorsements) and state or prov. and no. 1)



CONNEX

PIPE SYSTEMS

Connex Pipe Systems, Inc.
1115 Gilman Street
Marietta
Ohio 45750
Telephone 614.373.7541
Fax 614.373.8460
Twx 810.455.2808

SUMMARY PAGE - QMTR'S SKETCH E4217-6

<u>ITEM #</u>	<u>BEAT #</u>	<u>SERIAL #</u>	<u>MTR SERIAL #</u>	<u>DESCRIPTION</u>
1	L21137	1	4	18" SCH 60 SMLS PIPE SA106B
2	AUE	-	5	CODE PLATE SA240 TP304

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/03/92
(Name)
Waterford, Connecticut Sheet 1 of 3
(Address)

2. Plant Millstone Unit Two
(Name)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California AWC M2-92-00636
(Address) M2-92-01770

4. Identification of System Steam Generator No. 1 - Feedwater

5. (a) Applicable Construction Code ASME 1971 Edition, No Addenda, Code Cases
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, B1W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Feedwater	Bechtel	2103				1975	Replaced	Yes
Piping	Dravo				EBB-6-6	1974	Replaced	No
	NU	N/A	N/A	N/A		1979	Replaced	No
	Fluor	N/A	N/A	N/A		1992	Replacement	No
	Connex	42175			E4217-5	1992	Replacement	Yes

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other - SEE ATTACHMENT
 Pressure 1250 psi Test Temp. 140°F

9. Remarks NPP-1
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Charles Lewis Evans January 26, 1992
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE JGRP15+17

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of MI/CT, employed by W32+I CC of HARTFORD, CT have inspected the REPLACEMENT described in this Report
(Repair(s) or Replacement(s))
 on Dec 28, 1992 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Feb 19, 1993 Chal ANE CT1137
(Inspector) Commissions (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 12/03/92
(Name)
Waterford, Connecticut Sheet 2 of 3
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irving, California
(Address)

4. Identification of System Steam Generator No. 1 - Feedwater


- 5(a) Original field installation was performed in accordance with ASME Section III, 1971 Edition. Original shop fabricated spool pieces were fabricated in accordance with ANSI B31.7-1967. A portion of the feedwater piping being replaced was a replacement performed by NU in 1979 under ASME Section XI.
6. Bechtel field installation was stamped in accordance with ASME Section III, 1971. Dravo spool pieces were fabricated in accordance with ANSI B31.7 and provided with NPP-1 form. Replacement spool pieces for this replacement were procured in accordance with ASME Section III, 1983 Edition including Summer, 1984 Addenda. Field installation was in accordance with ASME Section III, 1971 Edition.
7. Feedwater piping was replaced from steam generator nozzle out to and including second elbow outside of steam generator blockhouse (see attached sketch).

Work performed per
AWO M2-92-00636 and M2-92-01770
affin 1/24/95

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner	<u>Northeast Nuclear Energy Company</u> (Name)	Date <u>12/03/92</u>
	<u>Waterford, Connecticut</u> (Address)	Sheet <u>3</u> of <u>3</u>
2. Plant	<u>Millstone</u> (Name)	Unit <u>Two</u>
	<u>Waterford, Connecticut</u> (Address)	
3. Work Performed by	<u>Fluor Constructors</u> (Name)	<u>Fluor Constructors</u>
	<u>Irvine, California</u> (Address)	Repair Organization P.O. No., Job No., etc.
4. Identification of System	<u>Steam Generator No. 1 - Feedwater</u>	

FIGURE



TITLE <u>FEEDWATER WELDING SEQ. AND JOINT IDENT MAP</u>			
SKETCH NO. <u>62P-353</u>		SCALE <u>NA</u>	
REFERENCE Dwg. <u>NA</u>			
REV	DES BY	CHEK BY	ENCLOSURE NO. <u>4.2</u>

**FORM NPP-1 CERTIFICATE HOLDERS' DATA REPORT FOR FABRICATED
NUCLEAR PIPING SUBASSEMBLIES***

As Required by the Provisions of the ASME Code, Section III, Division 1

Fabricated and certified by Connex Pipe Systems, Inc., 1115 Gilman Street, Marietta, Ohio 45750
(Name and address of NPT Certificate Holder)

2. Fabricated for Fluor Constructors International Inc. **
(Name and address)

3. Location of installation Millstone Unit 2 SGRP **
(Name and address of Purchaser)

4. Type 42175 N/A E4217-5 Rev. 3 N/A 1992
(Cert. Holder's serial no.) (CRN) (Drawing no.) (Nat'l. Bd. no.) (Year built)

5. ASME Code, Section III, Division 1: 1983 Summer 1984 2 N/A
(Edition) (Addenda date) (Class) (Code Case no.)

6. Shop hydrostatic test N/A psi at N/A °F (if performed)

7. Description of piping Feedwater See page 2 of 2

8. Certificate Holders' Data Reports properly identified and signed by commissioned inspectors have been furnished for the following items of this report: Piece Mark Number: 715100-50-5006KO #2.10

9. Remarks: N/A

CERTIFICATE OF SHOP COMPLIANCE

I hereby certify that the statements made in this report are correct and that the fabrication of the described piping subassembly conforms to the rules for construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. N-1320 Expires March 1, 1994

Date 4-17-92 Name Connex Pipe Systems, Inc. Signed *Mark A. Hub*
(NPT Certificate Holder) (Authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Ohio and employed by Allendale Mutual Insurance Company, Factory Mutual System of Norwood, MA have inspected the piping subassembly described in this Data Report on 4-17-92 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated this piping subassembly in accordance with the ASME Code, Section III, Division 1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the piping subassembly described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4-17-92 Signed *D. E. Howell* Commissions OHIO
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) and state or prov. and no.)

* Supplemental information in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.
(12/88) This form (E00062) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300.

** Rope Ferry Road, Route 156, Waterford, CT 06385

Certificate Holder's Serial No. _____

10. Description of field fabrication _____

11. Pneu., hydro., or comb. test pressure _____ psi at temp. _____ °F (if performed)

CERTIFICATE OF FIELD FABRICATION COMPLIANCE

We certify that the statements on this report are correct and that the field fabrication of the described piping subassembly conforms with the rules for construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. _____ Expires _____

Date _____ Name _____ (Certificate Holder) Signed _____ (Authorized representative)

CERTIFICATE OF FIELD FABRICATION INSPECTION


I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of _____ and employed by _____ of _____ have compared the statements in this Data Report with the described piping subassembly and state that parts referred to as data items _____ not included in the Certificate of Shop Inspection, have been inspected by me on _____ and that to the best of my knowledge and belief the Certificate Holder has fabricated this piping subassembly in accordance with the ASME Code, Section III, Division 1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the piping subassembly described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ (Authorized Inspector) Commissions _____ (Nat'l B. & P. V. Ins.) _____ (endorsement) and state or prov. and no. _____

NPP-1 SHEET 2 OF 2

CONNEX <small>CONNEX Pipe Systems, Inc. A member of the Westinghouse Group</small>		SKETCH NUMBER E-4217-5	
CUSTOMER <u>FLUOR / MILLSTONE</u>	DWG REF. _____	SHOP CODE <u>174</u>	3
SYSTEM <u>111 FREEWATER</u>	TOTAL WT <u>760</u>	SPEC CLASS <u>NJ-50-5006/2</u>	
ISO NO. _____	PC MK NO. <u>715100-50-5006KQ # 2.10</u>	DESIGN COND. P. <u>1100</u>	PSIG _____
AREA _____	SERIAL NUMBER <u>42175</u>	T. <u>600</u>	°F _____
ASME SECT. III CL. <u>2</u>	A PT		



FAB PROC NO. <u>SP-1</u> A TYPICAL		<input type="checkbox"/> BACKING RINGS/INSERTS	<input type="checkbox"/> SAND BLAST I.D./O.D.	<input type="checkbox"/> STD PRIME TYPE OXIDE/LACQUER
SHOP BEV. _____ A TYPE _____		<input type="checkbox"/> PAINT _____	<input checked="" type="checkbox"/> SDRIT BLAST I.D.	<input type="checkbox"/> CSPCL. PAINT TYPE _____
FIELD BEV. <u>A1</u> A TYPE _____		<input type="checkbox"/> SPECT. CLEAN LEV. _____	<input type="checkbox"/> INSV. INSP. PREP.	<input type="checkbox"/> BEND HOT/COLD
N.D.E. _____	PROCEDURE _____	REQUIRED WELDS _____	<input type="checkbox"/> SHIPPING PREP.	<input type="checkbox"/> VERIFY BEND THICK.
S/WP A	ASME III-MPA A	B1C <small>IN ACCORDANCE WITH SACS.18</small>	<input type="checkbox"/> FERRITE MEAS.	<input type="checkbox"/> MIN. WALL MEAS.
S/RT A	ASME III-RT A	B1C <small>IN ACCORDANCE WITH SACS.18</small>	WELD FILLER METAL REQ'D	
S/UT _____	_____	_____	<input type="checkbox"/> YELLOW ACTUAL	<input type="checkbox"/> RED ACTUAL WITH CHARPY @ 10 °F
S/VISUAL _____	ES-VE-1 A	FINAL SQUARE, B, C, D	SPEC _____	B/W FINISH CODES/N _____
QUA. _____	DESCRIPTION _____	_____	_____	PC REF _____
1 A	18" SCH 60 SMLS PIPE	SA106B	7cm1 L21137	1 4
2 A	CODE PLATE PER ES-1 24" x 5"	SA370 TP 304	1342	- -
2	18" MEA	SMLS		
3 A	PER TELETYPE TO FLUOR 4-16-91	RA TEL		
2 A	PER FAX 3-25-91	RA TEL		
1 A	REV'D SP-1/A	RA TEL		
REV. DATE _____	DESCRIPTION OF REVISION _____	DR. CKD _____	REV. DATE _____	DESCRIPTION OF REVISION _____
DR. CKD 12-9-91	CKD TEL 12-15-91		REV. DATE _____	DESCRIPTION OF REVISION _____



CONNEX

PIPE SYSTEMS

Connex Pipe Systems, Inc.
1115 Gilman Street
Marietta
Ohio 45750
Telephone 614.373.7541
Fax 614.373.8480
Twx 810.486.2808

SUMMARY PAGE - QMTR'S SKETCH E4217-5

<u>ITEM #</u>	<u>HEAT #</u>	<u>SERIAL #</u>	<u>MTR</u> <u>SERIAL #</u>	<u>DESCRIPTION</u>
1	L21137	1	4	18" SCH 60 SMLS PIPE SA106B
2	AUE	-	5	CODE PLATE SA240 TP304

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California M2-92-03342 M2-92-11818 M2-92-03316
(Address) M2-92-03252 M2-92-10633

4. Identification of System Reactor Coolant Piping - Steam Generator #2, Cold Leg B

5. (a) Applicable Construction Code ASME Section III 1971 Edition, 71 Summer Addenda, Code Cases N/A
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, B1W Addenda, Code Cases
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Reactor Coolant Piping	Bentel				30-CCA-2 W24	1975	Replaced	Yes (N/A)
	CE				503-03-2	1992	Repaired	Yes (B31.7)
	Fluor				30-CCA-2	1982	Replacement	No

7. Description of Work See Attachment
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
Pressure 2295 psi Test Temp. 532°F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Charles Lewis Engineer February 10, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by WGTZG of Waterford, CT have inspected the Repair + Replacement described in this Report (Repairs or Replacement(s)) on Jan 8, 19 93 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19 FEB 93 ETORX ANZ CTN37
Richard Commissions N7502
(Inspector) AN (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California M2-92-03342 M2-92-11818 M2-92-03316
(Address) *R. J. H. S.* M2-92-03202 M2-92-10633

4. Identification of System Reactor Coolant Piping - Steam Generator #2, Cold Leg B

7. Description of Work: Steam Generator Replacement necessitated the cutting of reactor coolant piping at the steam generator nozzles. The steam generator nozzle-to-reactor coolant piping weldments were partially replaced. Original Bechtel weld identification was W24 per Drawing 25203-20152, Sheet 143.

Temporary attachments were placed on the piping adjacent to the pipe-to-nozzle weldment. During removal of these attachments, the piping base material was nicked requiring repair.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/07/93
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors
(Name) Fluor Constructors
Repair Organization P.O. No., Job No., etc.
Irvine, California M2-92-03342 M2-92-03292
(Address) John 2/10/93 M2-92-00017 M2-92-1181E
4. Identification of System Reactor Coolant Piping - Steam Generator #2, Cold Leg A M2-92-10633
5. (a) Applicable Construction Code ASME Section III 1971 Edition, 71 Summer Addenda, Code Cases N/A
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Reactor Coolant Piping	Bechtel				30-CCA-2 W28	1975	Replaced	Yes (N/A)
	CE				503-03-3	1992	Repaired	Yes (B31.7)
	Fluor				30-CCA-2	1992	Replacement	No

7. Description of Work See Attachment
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
Pressure 2295 psi Test Temp. 532°F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement ^{Repaired} conforms to Section XI of the ASME Code.
(repair or replacement)

Signed [Signature] Senior Engineer February 10, 1993
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE SGRP 13+14

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by SGRP 13+14 of Waterford, CT have inspected the Repair/Replacement described in this Report (Repair or Replacement)

on Jan 8, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19 FEB 93 [Signature] CT 1137
Date 11 FEB 93 [Signature] Commissions 115612
(Inspector) [Signature] (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/07/93
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California M2-92-03342 A2-92-03292
(Address) M2-92-03317- M2-92-1181F
A2-92-1-033

4. Identification of System Reactor Coolant Piping - Steam Generator #2, Cold Leg A

7. Description of Work: Steam Generator Replacement necessitated the cutting of reactor coolant piping at the steam generator nozzles. The steam generator nozzle-to-reactor coolant piping weldments were partially replaced. Original Bechtel weld identification was W28 per Drawing 25203-20152 Sheet 143.

Temporary attachments were placed on the piping adjacent to the pipe-to-nozzle weldment. During removal of these attachments, the piping base material was nicked requiring repair.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/07/93
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California MZ-92-03342, MZ-92-03317
(Address)

4. Identification of System Reactor Coolant Piping - Steam Generator #2, Hot Leg

5. (a) Applicable Construction Code ASME Section III 1971 Edition, 71 Summer Addenda, Code Cases N/A
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Reactor Coolant Piping	Bechtel				42-CCA-1 W15	1975	Replaced	Yes (N/A)
	Fluor				42-CCA-1	1992	Replacement	No

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
Pressure 2295 psi Test Temp. 532°F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code.
(Repair or replacement)

Signed William L. Ryan Title Owner Date January 26, 19 93
(Owner or Owner's Designee)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by NSA-1 Co of Waterford, CT have inspected the Replacement described in this Report
(Repair(s) or Replacement(s))
on Jan 8, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11 FEB 93 William L. Ryan Commissions NSA-1
(Inspector) (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/07/93
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California
(Address)
4. Identification of System Reactor Coolant Piping - Steam Generator #2, Hot Leg

7. Description of Work: Steam Generator Replacement necessitated the cutting of reactor coolant piping at the steam generator nozzles. The steam generator nozzle-to-reactor coolant piping weldments were partially replaced. Original Bechtel weld identification was W15 per Drawing 25203-20153, Sheet 143.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California M2-92-03340 M2-92-10945
(Address) M2-92-03315 *SGRP 11*

4. Identification of System Reactor Coolant Piping - Steam Generator #1, Cold Leg B

5. (a) Applicable Construction Code ASME Section III 1971 Edition, 71 Summer Addenda, Code Cases N/A
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Reactor Coolant Piping	Bechtel				30-CCA-2 W14	1975	Replaced	Yes (N/A)
	CE				503-03-4	1992	Repaired	Yes (B31.7)
	Fluor				30-CCA-2	1992	Replacement	No

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
Pressure 2295 psi Test Temp. 532°F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code. (repair or replacement)

Signed [Signature] Title February 10, 19 93
(Owner or Owner's Designee) (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by Arthur G. [Signature] of Waterford, CT have inspected the Reactor Coolant Piping described in this Report (Repair(s) or Replacement(s)) on 1/08, 19 93 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19 FEB 93 [Signature] Commissions NY 5012
4 FEB 93 [Signature] Commissions NY 5012
(Inspector) AW (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California M2-92-03340 M2-92-10945 *ISCRP II*
(Address) M2-92-03315

4. Identification of System Reactor Coolant Piping - Steam Generator #1, Cold Leg B

7. Description of Work: Steam Generator Replacement necessitated the cutting of reactor coolant piping at the steam generator nozzles. The steam generator nozzle-to-reactor coolant piping weldments were partially replaced. Original Bechtel weld identification was W10 per Drawing 25203-20152, Sheet 143.
- Temporary attachments were placed on the piping adjacent to the pipe-to-nozzle weldment. During removal of these attachments, the piping base material was nicked requiring repair.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California M2-92-03340 M2-92-10945
(Address) M2-92-02904
4. Identification of System Reactor Coolant Piping - Steam Generator #1, Cold Leg A
5. (a) Applicable Construction Code ASME Section III 1971 Edition, 71 Summer Addenda, Code Cases N/A
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Reactor Coolant Piping	Bechtel				30-CCA-2 W-10	1975	Replaced	Yes (N/A)
	CE				503-03-1	1992	Repaired	Yes (B31.7)
	Fluor				30-CCA-2	1992	Replacement	No

7. Description of Work ✓
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
Pressure 2295 psi Test Temp. 532 °F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code. (repair or replacement)

Signed [Signature] [Signature] February, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by NORNEUC of Waterford CT have inspected the Repair + Replacement described in this Report (Repairs) or Replacement(s)

on Jan 8, 19 93 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19 FEB 93 [Signature] NY ANY
(Inspector) (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California M2-92-03340 M2-92-10945
(Address) M2-92-02904

4. Identification of System Reactor Coolant Piping - Steam Generator #1, Cold Leg A

7. Description of Work: Steam Generator Replacement necessitated the cutting of reactor coolant piping at the steam generator nozzles. The steam generator nozzle-to-reactor coolant piping weldments were partially replaced. Original Bechtel weld identification was W14 per Drawing 25203-20152, Sheet 143.

Temporary attachments were placed on the piping adjacent to the pipe-to-nozzle weldment. During removal of these attachments, the piping base material was nicked requiring repair.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California AWO M2-92-03340 CGPA 9,10+11
(Address) M2-92-03318

4. Identification of System Reactor Coolant Piping - Steam Generator #1, Hot Leg

5. (a) Applicable Construction Code ASME Section III 1971 Edition, 71 Summer Addenda, Code Cases N/A
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases
 6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Reactor Coolant Piping	Bechtel				42-CCA-1 W-1	1975	Replaced	Yes (N/A)
	Fluor				42-CCA-1	1992	Replacement	No

7. Description of Work See Attachment
 8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2295 psi Test Temp. 532°F
 9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code, (repair or replacement)

Signed Richard L. Lane February 10, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors, and the State or Province of Connecticut, employed by NIS-2 of Waterford, Ct have inspected the Replacement described in this Report (Repair(s) or Replacement(s)) on Jan 8, 19 93 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11 FEB 93 YORK ANZ CY1137
(Inspector) AWI Commissions (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/08/93
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California AWO M2-92-03340
(Address) M2-92-03318
4. Identification of System Reactor Coolant Piping - Steam Generator #1, Hot Leg

7. Description of Work: Steam Generator Replacement necessitated the cutting of reactor coolant piping at the steam generator nozzles. The steam generator nozzle-to-reactor coolant piping weldments were partially replaced. Original Bechtel weld identification was W1 per Drawing 25203-20152, Sheet 143.

**FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI**

1. Owner Northeast Nuclear Energy Company Date 11/30/92
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)

2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)

3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California See Attached Sheet
(Address)

4. Identification of System Steam Generator #2

5. (a) Applicable Construction Code 19 Edition, Addenda, Code Cases - SEE ATTACHMENT
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, 81W Addenda, Code Cases

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Steam Generator	CE	67511	20929			1968 S69	Partial Replacement	Yes
	B&W	761202	124			1983 S84	Replacement	Yes

7. Description of Work See Attachment

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other - SEE ATTACHMENT
 Pressure psi Test Temp. °F

9. Remarks
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code. (repair or replacement)

Signed *Richard J. Tubery* 10, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by WBI-IG of Hartford, CT have inspected the Replacement described in this Report on Dec 8-9, 1992 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11 FEB 93 *Richard J. Tubery* Commissions W5562
(Inspector) (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in Items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 11/30/92
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California See Attached Sheet
(Address)
4. Identification of System Steam Generator #2

5. Applicable Construction Code: The original construction code for the steam generator was ASME Section III, 1968 Edition including 1969 Summer Addenda. The replacement subassembly was fabricated to ASME Section III, 1983 Edition including Summer, 1984 Addenda.

7. Description of Work: A partial replacement and modification of the steam generator was performed. The original steam generator was cut in the middle of the secondary side transition cone. The upper portion of the steam generator was modified and retained. Modification included replacement of steam drum internals, addition of main steam line flow restrictor and feedwater nozzle reconfiguration.

A new lower assembly including tube bundle, primary channel head and secondary shell to middle of transition cone was installed as replacement. This subassembly was NPT stamped.

Modifications to the steam generator steam drum pressure boundary included removal of feedwater nozzle safe-end, remachining of feedwater nozzle and the introduction of flow restrictor attachment to main steam outlet nozzle.

8. Tests Conducted: The primary side of the steam generator received a shop hydrostatic test per ASME Section III at 3250 psi. After installation, the primary side shall receive a Section XI hydrostatic test at 2295 psi (1.02 x operating pressure). The secondary side shall receive a Section XI hydrostatic test at 1250 psi (1.25 x design pressure).

WORK PERFORMED PER FOLLOWING WORK ORDERS:

M2-92-01898	M2-92-12397
M2-92-01895	M2-91-10852
M2-92-01936	M2-92-00285
M2-92-01893	M2-92-01771
M2-92-04410	M2-92-04733
M2-92-01936	M2-92-01769
M2-92-04412	M2-92-02363
M2-91-09036	M2-92-03337

**FORM N-2 N OR NPT CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES***

As Required by the Provisions of the ASME Code, Section III, Division 1
Not To Exceed One Day's Production

Pg 1 of 2

1. Manufactured and certified by The Japan Steel Works, Ltd., Muroran Plant/4-Chatsu-Machi, Muroran,
(name and address of certificate holder) Hokkaido 051, Japan
2. Manufactured for Babcock & Wilcox Canada, a division of Babcock & Wilcox Industries Ltd, Coronation
(name and address of purchaser) Bird, Cambridge, Ontario Canada
3. Location of installation Millstone Unit 2 Generating Station Waterford, Connecticut, USA
(name and address) NIR 5V3
4. Type N145581W, Rev.4 SA508, C1.3 Min. 80ksi - 1989
(drawing no.) (mat'l. spec. no.) (tensile strength) (CRN) (year built)
5. ASME Code, Section III: 1983 1984 S. Addenda 1 -
(edition) (addenda) (class) (Code Case no.)
6. Fabricated in accordance with Const. Spec. (Div. 2 only) - Revision - Date -
(No.)
7. Remarks: - Hydrostatic test is not performed in Japan Steel Works, Ltd.

- Cladding thickness is Min. 6 mm.

- Cladding materials are SFA-5.4, AWS C1. E309L-16 + E308L-16.

8. Nom. thickness (in.) 7" Min. design thickness (in.) 7" Dia. ID (ft. & in.) 12'-5 3/8" Length overall (ft. & in.) 6'-6 13/16"
9. When applicable, Certificate Holders' data reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. In Numerical Order	Part or Appurtenance Serial Number	National Board Number In Numerical Order
1002	207	(26)	
(2)		(27)	
(3)		(28)	
(4)		(29)	
(5)		(30)	
(6)		(31)	
(7)		(32)	
(8)		(33)	
(9)		(34)	
(10)		(35)	
(11)		(36)	
(12)		(37)	
(13)		(38)	
(14)		(39)	
(15)		(40)	
(16)		(41)	
(17)		(42)	
(18)		(43)	
(19)		(44)	
(20)		(45)	
(21)		(46)	
(22)		(47)	
(23)		(48)	
(24)		(49)	
(25)		(50)	

Design pressure 2500 psi Temp 650 °F. Hydro. test pressure - at temp °F.
(when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 X 11, (2) information in Items 2 and 3 on this data report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

CERTIFICATE OF DESIGN

Design specifications certified by _____ P. E. state _____ Reg. no. _____
 (when applicable)

Design report* certified by _____ P. E. state _____ Reg. no. _____
 (when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Primary Head Stainless Steel Cladding conform to the rules of construction of the ASME Code, Section III.

NPT Certificate of Authorization no. N-2725 Expires June 16, 1989

Date Jan 11, '89 Name The Japan Steel Works, Ltd. Signed [Signature]
Muroran Plant (Authorized Representative)
 (NPT Certificate Holder) H. TSUKABA

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or province of Illinois and employed by H.S.B.I. & I.CO. of Conn. have inspected these items described in this data report on 1-11-89 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 1-11-89 Signed [Signature] Commissions NB # 10145N
 (Authorized Inspector) (Natl. Bd. (incl. endorsements) state or prov. and no.)
H. KAWABATA

**FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES***

As Required by the Provisions of the ASME Code, Section III
Not To Exceed One Day's Production

Pg. 1 of 6

1. Manufactured and certified by Babcock & Wilcox Canada, 581 Coronation Blvd., Cambridge, Ontario
(Name and address of NPT Certificate Holder)
2. Manufactured for Northeast Utilities Service Company, P.O. Box 270, Hartford, Connecticut, 06141-0270
(Name and address of purchaser)
3. Location of installation Millstone II, Waterford, Connecticut
(Name and address)
4. Type 7612 E101 Rev. 04 - See Attached List #1 1991
(drawing no.) (mat'l. spec. no.) (tensile strength) (ICRN) (year built)
5. ASME Code, Section III: 1983 Summer 1984 1 See attached list #2
(edition) (addenda date) (class) (Code Case no.)
6. Fabricated in accordance with Const. Spec. (Div. 2 only) _____ Revision _____ Date _____
(no.)
7. Remarks: Secondary side hydro test has not been performed.
Post-hydrotest final NDE has not been performed on the secondary side.
8. Nom. thickness (in.) See Att. List #3 Min. design thickness (in.) See Att. List #3 Dia. ID (ft & in.) See Att. List #3 Length overall (ft & in.) 43'-11"
9. When applicable, Certificate Holders' Data Reports are attached for each item of this report.

Part or Appurtenance Serial Number	National Board No. in Numerical Order	Part or Appurtenance Serial Number	National Board Number in Numerical Order
(1) <u>761202</u>	<u>124</u>	(26) _____	
(2) _____		(27) _____	
(3) _____		(28) _____	
(4) _____		(29) _____	
(5) _____		(30) _____	
(6) _____		(31) _____	
(7) _____		(32) _____	
(8) _____		(33) _____	
(9) _____		(34) _____	
(10) _____		(35) _____	
(11) _____		(36) _____	
(12) _____		(37) _____	
(13) _____		(38) _____	
(14) _____		(39) _____	
(15) _____		(40) _____	
(16) _____		(41) _____	
(17) _____		(42) _____	
(18) _____		(43) _____	
(19) _____		(44) _____	
(20) _____		(45) _____	
(21) _____		(46) _____	
(22) _____		(47) _____	
(23) _____		(48) _____	
(24) _____		(49) _____	
(25) _____		(50) _____	

10. Design pressure See Attached List #4 Temp. See Attached List #4 Hydro. test pressure See Attached List #4
(when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

CERTIFICATION OF DESIGN

Design specifications certified by R. P. Necci P.E. State CT Reg. no. 11513
(when applicable)

Design report* certified by R. G. Klarner P.E. ~~State~~ Ont. Reg. no. 24064503
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Steam Generator Sub-Assembly (See Fig. 1)
 conforms to the rules of construction of the ASME Code, Section III.

NPT Certificate of Authorization No. N-2791 Expires January 13, 1992

Date JUN 19 1991 Name Babcock & Wilcox Canada Signed [Signature]
(NPT Certificate Holder) (Authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of
Ontario and employed by Ministry of Consumer & Commercial Relations
 of Ontario have inspected these items described in this Data Report on JUN 19 1991, and state that to the
 best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section
 III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described
 in the Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or
 loss of any kind arising from or connected with this inspection.

Date JUN 19 1991 Signed [Signature] Commissions NB# 8112
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) state or prov. and no.)

Form N-2
Mfr. Serial No.:

761202

Page 2 of 6

Manufactured for:

Northeast Utilities Service Company
P.O. Box 270, Hartford, Connecticut, 06141-0270

Location of Installation:

Millstone II, Waterford, Connecticut

List #1

	Material Specification No.	Tensile Strength
Channel Head	SA508 CL.3	80 ksi
Primary Side Inlet Nozzle	SA508 CL.3	80 ksi
Primary Side Outlet Nozzles	SA508 CL.3	80 ksi
Primary Side Inlet Nozzle Safe End	SA508 CL.1	70 ksi
Primary Side Outlet Nozzle Safe Ends	SA508 CL.1	70 ksi
Tubesheet	SA508 CL.3	80 ksi
Tubes	SB-163 N-20 (Alloy 690)	80 ksi
Secondary Side Shell Plates	SA533 GR.B CL.1	80 ksi
Secondary Side Cone Plate	SA533 GR.B CL.1	80 ksi
Primary Manway Covers	SA533 GR.B CL.1	80 ksi
Secondary Handholes	SA508 CL.3	80 ksi
Secondary Handhole Covers	SA533 GR.B CL.1	80 ksi
Stay Cylinder	SA508 CL.3	80 ksi
Base Support Skirt	SA533 GR.B CL.1	80 ksi

Form N-2
Mfr. Serial No.:

761202

Page 3 of 6

Manufactured for:

Northeast Utilities Service Company
P.O. Box 270, Hartford, Connecticut, 06141-0270

Location of Installation:

Millstone II, Waterford, Connecticut

List #2

Code Cases:	N-20	7/16/82
	N-10	1/21/82
	N-474-1	3/6/90

Form N-2
Mfr. Serial No.:

761202

Page 4 of 6

Manufactured for:

Northeast Utilities Service Company
P.O. Box 270, Hartford, Connecticut, 06141-0270

Location of Installation:

Millstone II, Waterford, Connecticut

List #3

	Nominal Thickness	Min. Design Thickness	Inner Diameter
Channel Head	7"	7.000"	-
Tubesheet	21.75"	21.440"	-
Tubes	0.045"	0.041"	0.660" Nom.
Secondary Side Shell Plates			
1/ Shell Section Below Cone	4"	3.813"	13' - 2½"
2/ Middle Shell Section	3.3125"	3.100"	13' - 2½"
3/ Shell Section Above Tubesheet	4.3125"	4.000"	13' - 2½"
Secondary Side Cone Plate	5.75"	5.563"	-

Form N-2
Mfr. Serial No.:

761202

Page 5 of 6

Manufactured for:

Northeast Utilities Service Company
P.O. Box 270, Hartford, Connecticut, 06141-0270

Location of Installation:

Millstone II, Waterford, Connecticut

List #4

	Secondary Side	Primary Side
Design Pressure	1015 psia	2500 psia
Design Temperature	550°F	650°F
Hydro. Test Pressure	-	3125 psia
Hydro. Test Temperature	-	70°F

Form N-2
Mfr. Serial No.:

761202

Page 6 of 6


Manufactured for:

Northeast Utilities Service Company
P.O. Box 270, Hartford, Connecticut, 06141-0270

Location of Installation:

Millstone II, Waterford, Connecticut

Figure 1
General Arrangement



**FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES***

As Required by the Provisions of the ASME Code, Section III
Not To Exceed One Day's Production

Pg. 1 of 1

1. Manufactured and certified by Babcock & Wilcox Canada, 581 Coronation Blvd., Cambridge, Ontario
(Name and address of NPT Certificate Holder)
2. Manufactured for Northeast Utilities Service Company, P. O. Box 270, Hartford, Connecticut 0614
(Name and address of purchaser) 0270
3. Location of installation Millstone II, Waterford, Connecticut
(Name and address)
4. Type 7612D275 Rev. 04 SA 533 Gr. B Cl. 1 80 ksi 1991
(drawing no.) (mat'l. spec. no.) (tensile strength) (CRN) (year built)
5. ASME Code, Section III: 1983 Summer 1984 1 N/A
(edition) (addenda date) (class) (Code Case no.)
6. Fabricated in accordance with Const. Spec. (Div. 2 only) - Revision - Date -
(inc.)
7. Remarks: Hydro test has not been performed.

8. Nom. thickness (in.) 5.25 Min. design thickness (in.) 4.75 Dia. 2 (ft & in.) 2 - 4.5 Length overall (ft & in.) N/A
9. When applicable, Certificate Holders' Data Reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. in Numerical Order	Part or Appurtenance Serial Number	National Board Number in Numerical Order
(1) <u>761203</u>	<u>126</u>	(26)	
(2) <u>761204</u>	<u>127</u>	(27)	
(3)		(28)	
(4)		(29)	
(5)		(30)	
(6)		(31)	
(7)		(32)	
(8)		(33)	
(9)		(34)	
(10)		(35)	
(11)		(36)	
(12)		(37)	
(13)		(38)	
(14)		(39)	
(15)		(40)	
(16)		(41)	
(17)		(42)	
(18)		(43)	
(19)		(44)	
(20)		(45)	
(21)		(46)	
(22)		(47)	
(23)		(48)	
(24)		(49)	
(25)		(50)	

10. Design pressure 2500 psi. Temp. 650 °F. Hydro. test pressure See Remarks at temp. °F
(when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in Items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

CERTIFICATION OF DESIGN

Design specifications certified by R. P. Necci P.E. State Ct. Reg. no. 11513
(when applicable)

Design report* certified by R. G. Klarner P.E. ^{Prov.}~~State~~ Ont. Reg. no. 24064503
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE:

We certify that the statements made in this report are correct and that this (these) Primary Manway Covers
 conforms to the rules of construction of the ASME Code, Section III.

NPT Certificate of Authorization No. N-2791 Expires January 13, 1992

Date SEP 16 1991 Name Babcock & Wilcox Canada Signed EL Dahlm
(NPT Certificate Holder) (Authorized Representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Ontario and employed by Ministry of Consumer & Commercial Relations of Ontario have inspected these items described in this Data Report on SEP 16 1991 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or of any kind arising from or connected with this inspection.

Date SEP 16 1991 Signed [Signature] Commissions NB # 212
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) state or prov. and no.)

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 11/30/92
(Name)
Waterford, Connecticut Sheet 1 of 2
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California See Attached Sheet
(Address)
4. Identification of System Steam Generator #1
5. (a) Applicable Construction Code 19 Edition, See Attachment Addenda, Code Cases
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1980, B1W Addenda, Code Cases
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Net'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced or Replacement	ASME Code Stamped (Yes or No)
Steam Generator	CE	CE67510	2092B			1968 S69	Partial Replacement	Yes
	B&W	761201	123			1983 1984S	Subassembly	Yes

7. Description of Work See Attachment
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other - SEE ATTACHMENT
Pressure psi Test Temp. °F
9. Remarks
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code. (repair or replacement)

Signed Charles L. Engman February 10, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF COMPLIANCE

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by NSBIB-IG of Hartford, CT have inspected the Replacement described in this Report (Repairs or Replacement(s))
on Dec 8-9 1992 and Jan 8 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19 FEB 93 F. York ANII CT1137
11 FEB 93 PH Commissions 1215062
(Inspector) ANI (State or Province, National Board)

NOTE: Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in.; (2) information in Items 1 through 4 on this data report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 11/30/92
(Name)
Waterford, Connecticut Sheet 2 of 2
(Address)
2. Plant Millstone Unit Two
(Name)
Waterford, Connecticut
(Address)
3. Work Performed by Fluor Constructors Fluor Constructors
(Name) Repair Organization P.O. No., Job No., etc.
Irvine, California See Attached Sheet
(Address)
4. Identification of System Steam Generator #1

5. Applicable Construction Code: The original construction code for the steam generator was ASME Section III, 1968 Edition including 1969 Summer Addenda. The replacement subassembly was fabricated to ASME Section III, 1983 Edition including Summer, 1984 Addenda.

7. Description of Work: A partial replacement and modification of the steam generator was performed. The original steam generator was cut in the middle of the secondary side transition cone. The upper portion of the steam generator was modified and retained. Modification included replacement of steam drum internals, addition of main steam line flow restrictor and feedwater nozzle reconfiguration.

A new lower assembly including tube bundle, primary channel head and secondary shell to middle of transition cone was installed as replacement. This subassembly was NPT stamped.

Modifications to the steam generator steam drum pressure boundary included removal of feedwater nozzle safe-end, remachining of feedwater nozzle and the introduction of flow restrictor attachment to main steam outlet nozzle.

8. Tests Conducted: The primary side of the steam generator received a shop hydrostatic test per ASME Section III at 3250 psi. After installation, the primary side shall receive a Section XI hydrostatic test at 2295 psi (1.02 x operating pressure). The secondary side shall receive a Section XI hydrostatic test at 1250 psi (1.25 x design pressure).

WORK PERFORMED PER AWO'S

M2-92-01899	M2-91-10846
M2-92-01896	M2-92-00284
M2-92-12396	M2-92-02362
M2-92-01935	M2-92-03366
M2-92-01894	M2-92-01770
M2-92-04409	M2-92-03736
M2-92-16727	M2-92-01769
M2-92-01935	M2-91-09035
M2-92-04411	

FORM N-2 N OR NPT CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL NUCLEAR PARTS AND APPURTENANCES*

As Required by the Provisions of the ASME Code, Section III, Division 1
Not To Exceed One Day's Production

Pg 1 of 2

1. Manufactured and certified by The Japan Steel Works, Ltd., Muroran Plant/4-Chatsu-Machi, Muroran,
(name and address of certificate holder) Hokkaido 051, Japan
2. Manufactured for Babcock & Wilcox Canada, a division of Babcock & Wilcox Industries Ltd. Coronatic
(name and address of purchaser) Bird, Cambridge, Ontario Canada
NIR 5V3
3. Location of installation Millstone Unit 2 Generating Station Waterford, Connecticut, USA
(name and address)
4. Type N145581W, Rev. 4 SA508, C1.3 Min. 80ksi. - 1989
(drawing no.) (mat'l. spec. no.) (tensile strength) (CRN) (year built)
5. ASME Code, Section III: 1983 1984 S. Addenda 1 -
(edition) (addenda) (class) (Code Case no.)
6. Fabricated in accordance with Const. Spec. (Div. 2 only) - Revision - Date -
(No.)
7. Remarks: - Hydrostatic test is not performed in Japan Steel Works, Ltd.
- Cladding thickness is Min. 6 mm.
- Cladding materials are SFA-5.4, AWS C1. E309L-16 + E308L-16.
8. Nom. thickness (in.) 7" Min. design thickness (in.) 7" Dia. ID (ft. & in.) 12'-5 3/8" Length overall (ft. & in.) 6' - 6 13/16"
9. When applicable, Certificate Holders' data reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. In Numerical Order	Part or Appurtenance Serial Number	National Board Number In Numerical Order
(1) 1001	206	(26)	
(2)		(27)	
(3)		(28)	
(4)		(29)	
(5)		(30)	
(6)		(31)	
(7)		(32)	
(8)		(33)	
(9)		(34)	
(10)		(35)	
(11)		(36)	
(12)		(37)	
(13)		(38)	
(14)		(39)	
(15)		(40)	
(16)		(41)	
(17)		(42)	
(18)		(43)	
(19)		(44)	
(20)		(45)	
(21)		(46)	
(22)		(47)	
(23)		(48)	
(24)		(49)	
(25)		(50)	

10. Design pressure 2500 psi Temp. 650 °F. Hydro. test pressure - at temp. °F.
(when applicable)

*Supplemental Information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 X 11, (2) information in Items 2 and 3 on this data report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

CERTIFICATE OF DESIGN

Design specifications certified by _____ P. E. state _____ Reg. no. _____
(when applicable)

Design report* certified by _____ P. E. state _____ Reg. no. _____
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Primary Head Stainless Steel Cladding conform to the rules of construction of the ASME Code, Section III.

NPT Certificate of Authorization no. N-2725 Expires June 16, 1989

Date Dec. 14, '88 Name The Japan Steel Works, Ltd. Signed H. Tsukada
Muroran Plant (NPT Certificate Holder) (Authorized representative)
H. TSUKADA

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or province of Illinois and employed by H.S.B.I. & I. CO. of Conn. have inspected these items described in this data report on 12-14-88 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 12-14-88 Signed H. Kawabata Commissions NB # 10145N
(Authorized Inspector) (Natl. Bd. (incl. endorsements) state or prov. and no.)
H. KAWABATA

**FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES***

As Required by the Provisions of the ASME Code, Section III
Not To Exceed One Day's Production

Pg. 1 of 6

1. Manufactured and certified by Babcock & Wilcox Canada, 581 Coronation Blvd., Cambridge, Ontario
(name and address of NPT Certificate Holder)
2. Manufactured for Northeast Utilities Service Company, P.O. Box 270, Hartford, Connecticut 06141-0270
(name and address of purchaser)
3. Location of installation Millstone II, Waterford, Connecticut
(name and address)
4. Type 7612 E101 Rev. 04 - See Attached List #1 - 1991
(drawing no.) (mat'l. spec. no.) (tensile strength) (ICRN) (year built)
5. ASME Code, Section III: 1983 Summer 1984 1 See attached list #2
(edition) (validity date) (class) (Code Case no.)
6. Fabricated in accordance with Const. Spec. (Div. 2 only) - Revision - Date -
(no.)
7. Remarks: Secondary side hydro test has not been performed.
Post-hydrotest final NDE has not been performed on the secondary side.

8. Nom. thickness (in.) See Att. List #3 Min. design thickness (in.) See Att. List #3 Dia. ID (ft & in.) See Att. List #3 Length overall (ft & in.) 43'-11"
9. When applicable, Certificate Holders' Data Reports are attached for each item of this report.

Part or Appurtenance Serial Number	National Board No. in Numerical Order	Part or Appurtenance Serial Number	National Board Number in Numerical Order
(1) 761201	123	(26)	
(2)		(27)	
(3)		(28)	
(4)		(29)	
(5)		(30)	
(6)		(31)	
(7)		(32)	
(8)		(33)	
(9)		(34)	
(10)		(35)	
(11)		(36)	
(12)		(37)	
(13)		(38)	
(14)		(39)	
(15)		(40)	
(16)		(41)	
(17)		(42)	
(18)		(43)	
(19)		(44)	
(20)		(45)	
(21)		(46)	
(22)		(47)	
(23)		(48)	
(24)		(49)	
(25)		(50)	

10. Design pressure See Attached List #4 See Attached List #4 Hydro. test pressure See Attached List #4
(psi) (temp.) (psi) (temp.) (when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

This form (E00040) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300

11/2/86

CERTIFICATION OF DESIGN

Design specifications certified by R. P. Necci P.E. State CT Reg. no. 11513
(when applicable)

Design report* certified by R. G. Klarner P.E. ~~NY~~ Ont. Reg. no. 24064503
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Steam Generator Sub-Assembly (See Fig. 1) conforms to the rules of construction of the ASME Code, Section III.

NPT Certificate of Authorization No. N-2791 Expires January 13, 1992

Date JUN 13 1991 Name Babcock & Wilcox Canada Signed EB Dahl
(NPT Certificate Holder) Authorized representative

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Ontario and employed by Ministry of Consumer & Commercial Relations of Ontario have inspected these items described in this Data Report on JUN 13 1991 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 9/10/13 Signed [Signature] Commissions NB#8112
(Authorized Inspector) (Nat'l. Bd. incl. endorsements, state or prov. and no.)

Form N-2
Mfr. Serial No.:

761201

Page 2 of 6

Manufactured for:

Northeast Utilities Service Company
P.O. Box 270, Hartford, Connecticut, 06141-0270

Location of Installation:

Millstone II, Waterford, Connecticut

List #1

	Material Specification No.	Tensile Strength
Channel Head	SA508 CL.3	80 ksi
Primary Side Inlet Nozzle	SA508 CL.3	80 ksi
Primary Side Outlet Nozzles	SA508 CL.3	80 ksi
Primary Side Inlet Nozzle Safe End	SA508 CL.1	70 ksi
Primary Side Outlet Nozzle Safe Ends	SA508 CL.1	70 ksi
Tubesheet	SA508 CL.3	80 ksi
Tubes	SB-163 N-20 (Alloy 690)	80 ksi
Secondary Side Shell Plates	SA533 GR.B CL.1	80 ksi
Secondary Side Cone Plate	SA533 GR.B CL.1	80 ksi
Primary Manway Covers	SA533 GR.B CL.1	80 ksi
Secondary Handholes	SA508 CL.3	80 ksi
Secondary Handhole Covers	SA533 GR.B CL.1	80 ksi
Stay Cylinder	SA508 CL.3	80 ksi
Base Support Skirt	SA533 GR.B CL.1	80 ksi

Form N-2
Mfr. Serial No.:

761201

Page 3 of 6

Manufactured for:

Northeast Utilities Service Company
P.O. Box 270, Hartford, Connecticut, 06141-0270

Location of Installation:

Millstone II, Waterford, Connecticut

List #2

Code Cases:

N-20	7/16/82
N-10	1/21/82
N-474-1	3/6/90

Form N-2
Mfr. Serial No. -

761201

Page 4 of 6

Manufactured for:

Northeast Utilities Service Company
P.O. Box 270, Hartford, Connecticut, 06141-0270

Location of Installation:

Millstone II, Waterford, Connecticut

List #3

	Nominal Thickness	Min. Design Thickness	Inner Diameter
Channel Head	7"	7.000"	-
Tubesheet	21.75"	21.440"	-
Tubes	0.045"	0.041"	0.660" Nom.
Secondary Side Shell Plates			
1/ Shell Section Below Cone	4"	3.813"	13' - 2 1/2"
2/ Middle Shell Section	3.3125"	3.100"	13' - 2 1/2"
3/ Shell Section Above Tubesheet	4.3125"	4.000"	13' - 2 1/2"
Secondary Side Cone Plate	5.75"	5.563"	-

Form N-2
Mfr. Serial No.:

761201

Page 5 of 6

Manufactured for:

Northeast Utilities Service Company
P.O. Box 270, Hartford, Connecticut, 06141-0270

Location of Installation:

Millstone II, Waterford, Connecticut

List #4

	Secondary Side	Primary Side
Design Pressure	1015 psia	2500 psia
Design Temperature	550°F	650°F
Hydro. Test Pressure	-	3125 psia
Hydro. Test Temperature	-	70°F

Form N-2
Mfr. Serial No.:

761201

Page 6 of 6


Manufactured for:

Northeast Utilities Service Company
P.O. Box 270, Hartford, Connecticut, 06141-0270

Location of Installation:

Millstone #1, Waterford, Connecticut

Figure 1
General Arrangement



**FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES***

As Required by the Provisions of the ASME Code, Section III
Not To Exceed One Day's Production

1. Manufactured and certified by Babcock & Wilcox Canada, 581 Coronation Blvd., Cambridge, Ontario
(Name and address of NPT Certificate holder)
2. Manufactured for Northeast Utilities Service Company, P. O. Box 270, Hartford, Connecticut 0614
(Name and address of purchaser) 0270
3. Location of installation Millstone II, Waterford, Connecticut
(Name and address)
4. Type 7612D275 Rev. 04 SA 533 Gr. B Cl. 1 80 ksi - 1991
(drawing no.) (mat'l. spec. no.) (tensile strength) (CRN) (year built)
5. ASME Code, Section III: 1983 Summer 1984 1 N/A
(edition) (addenda date) (class) (Code Case no.)
6. Fabricated in accordance with Const. Spec. (Div. 2 only) - Revision - Date -
(no.)
7. Remarks: Hydro test has not been performed.

8. Nom. thickness (in.) 5.25 Min. design thickness (in.) 4.75 Dia. ^{OD} (ft & in.) 2 - 4.5 Length overall (ft & in.) N/A
9. When applicable, Certificate Holders' Data Reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. in Numerical Order	Part or Appurtenance Serial Number	National Board Number in Numerical Order
(1) 761203	126	(26)	
(2) 761204	127	(27)	
(3)		(28)	
(4)		(29)	
(5)		(30)	
(6)		(31)	
(7)		(32)	
(8)		(33)	
(9)		(34)	
(10)		(35)	
(11)		(36)	
(12)		(37)	
(13)		(38)	
(14)		(39)	
(15)		(40)	
(16)		(41)	
(17)		(42)	
(18)		(43)	
(19)		(44)	
(20)		(45)	
(21)		(46)	
(22)		(47)	
(23)		(48)	
(24)		(49)	
(25)		(50)	

10. Design pressure 2500 psi. Temp. 650 °F. Hydro. test pressure See Remarks at temp. °F
(when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

CERTIFICATION OF DESIGN

Design specifications certified by R. P. Necci P.E. State Ct. Reg. no. 11513
(when applicable)

Design report* certified by R. G. Klarner P.E. ~~State~~ Prov. Ont. Reg. no. 24064503
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Primary Manway Covers
 conforms to the rules of construction of the ASME Code, Section III.

NPT Certificate of Authorization No. N-2791 Expires January 13, 1992

Date SEP 16 1991 Name Babcock & Wilcox Canada Signed EM Dahlm
(NPT Certificate Holder) (Authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Ontario and employed by Ministry of Consumer & Commercial Relations of Ontario have inspected these items described in this Data Report on SEP 16 1991 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or of any kind arising from or connected with this inspection.

Date SEP 16 1991 Signed [Signature] Commissions 115-2112
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements, state or prov. and no.)

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/28/93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Address)
2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. Dresser Industries PO# 885482, MAIR# 292-087
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System Main Steam
5. (a) Applicable Construction Code Part 19 G8 Edition, Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1981 W 81 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-MS-254	Dresser	BN4963	NB		PSV 4229	1973	Replaced	Yes
2-MS-242	Dresser	BN4964	NB		PSV 4236	1973	Replaced	Yes
2-MS-244	Dresser	BN4970	NB		PSV 4238	1973	Replaced	Yes
2-MS-248	Dresser	BN4975	NB		PSV 4232	1973	Replaced	Yes

7. Description of Work Replaced Discs
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 900 psi Test Temp. 532 °F
9. Remarks Leak test performed under AWC's M2-92-4391, M2-92-4372, M2-92-4374
and M2-92-4377
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code.
 Signed Mark J. Wynn Station Technician Title Jan. 29 1993
(Owner or Owner's Designee) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the DISC REPLMNT described in this Report on 11 JANUARY, 1993
(Repairs or Replacement(s))
 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 05 APRIL 1993 E. YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/18/93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)
2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-90-11353
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System Main Steam Blowdown
5. (a) Applicable Construction Code ASME III 1971 Edition, 1980 Addenda, Code Cases WR1
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, WR1 Addenda, Code Cases ---
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Net'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-MS-220A	Masonville	N00126-6-1	---	---	NRIBs: NUTS 492-068-1 STUDS 387-157-849		replaced	No

7. Description of Work Replaced body to bonnet studs
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 1200 psi Test Temp. --- °F
9. Remarks: (Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed RI Gletter Mate Engineer 1/18, 19 93
(Owner or Owner's Designer) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the BOLTING RPLMNT described in this Report on 09 DECEMBER, 19 92
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19 MARCH 1993 [Signature] E YORK Commissions CT 1137
(Inspected) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1-8-92
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. M2-90-1353
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System Main Steam Blowdown
5. (a) Applicable Construction Code ASME III 1971 Edition, _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, WB1 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfr. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>Z-MS-220B</u>	<u>Masmeilla</u>	<u>N00216-6-2</u>	<u>--</u>	<u>--</u>	<u>MAIRS:</u> <u>NUT</u> <u>992-06B-1</u> <u>STUP</u> <u>289-137-199</u>		<u>Replaced</u>	<u>No</u>

7. Description of Work Replaced body to bonnet bolts
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 900 psi Test Temp. 553°F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this Replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Paul H. G. Volle Mate Engineer 1/19, 19 92
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the BOLTING REPLMNT described in this Report on 08 JANUARY, 1993
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 19 MARCH 1993 E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 22, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address) 2
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-92-05255
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
4. Identification of System SAFETY INJECTION
5. (a) Applicable Construction Code ASME III 1968 Edition, _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1982, 1981 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Ed. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>2-SI-652^x</u>	<u>VELAN</u>	<u>(A2-0654)</u> <u>N-17</u>	-	-	-	-	<u>REPAIR</u>	<u>YES (N)</u>

7. Description of Work ① MACHINE VALV BONNET IN SEAL RING SEATING SURFACE TO REMOVE ALL
② WELD REPAIR AND MACHINE VALV BODY IN SEAL RING SEATING SURFACE
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 22 psi Test Temp. 83 °F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR conforms to Section XI of the ASME Code. (repair or replacement)

Signed: Marion A. North Title ASME ENGINEER Date FEB 22, 19 93
(Owner or Owner's Designer) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the REPAIR described in this Report on 01 MARCH, 1993 (Repairs or Replacements)

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 01 MARCH 1993 York E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., information in items 1 through 4 on this data report is included on each sheet, and (2) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Northeast Nuclear Energy Company Date: FEBRUARY 22, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet: 1 of 1
(Name) (Address) 2
2. Plant: Millstone Unit: _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by: Northeast Nuclear Energy Co. - AWO M2-92-12813
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System: SAFETY INJECTION
5. (a) Applicable Construction Code: ASME B31.7 - CL II 1967 Edition, _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, 1981 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>2-SI-657</u>	<u>FISHER</u>	<u>5467053</u>	-	-	<u>MR1A</u>		<u>REPLACEMENT</u>	<u>NO</u>
					<u>2-65-80</u> <u>(SEAL RING AND BOLT)</u>			
"	"	"	-	-	<u>MR1A</u>			
					<u>2-9-75</u> <u>(FLANGE STUD BOLTS)</u>		<u>REPLACEMENT</u>	<u>NO</u>

7. Description of Work: REPLACED (1) SEAL RING AND BOLT AND (1) FLANGE STUD BOLT
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure: 405 psi Test Temp: 140 °F
9. Remarks: _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
(repair or replacement)

Signed: Thomas A. Moran MNTC ENGINEER Title: _____ Date: FEB. 22, 19 93
(Owner or Owner's Designee) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the BOLTING REPLMNT described in this Report on 04 JANUARY, 19 93 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date: 16 MARCH 1993 Inspector: [Signature] E YORK Commissions: CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date Jan 19, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
(Name) (Address)
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-92-05323
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Name) (Address)
4. Identification of System Reactor Coolant
5. (a) Applicable Construction Code ASME Part IV 1968 Edition _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, WBI Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>2-RC-403</u>	<u>Velan</u>	<u>Wedge</u>			<u>MRIR</u>		<u>replaced wedge</u>	<u>Value: yes</u>
		<u>IN 3888</u>			<u>292-237</u>			
					<u>1/2 #</u>			
					<u>5990225</u>			

7. Description of Work Replaced wedge
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2310 psi Test Temp. 533 °F
9. Remarks NEW WEDGE MATL APPROVED VIA R.I.E. #AF6-MPRE-92-018; removed indicator from NEW wedge per NCR 292-864. Machine's wedge to fit valve per NCR 292-887.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed J.H. Colletta Mech Engr. Jan 19 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the BOLTG RPLMNT described in this Report on 08 JANUARY, 19 93 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 22 MARCH 1993 E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., information in items 1 through 4 on this data report is included on each sheet, and (2) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Northeast Nuclear Energy Company Date: Jan 18, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet: 1 of 1
(Name) (Address) 2
2. Plant: Millstone Unit: _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by: Northeast Nuclear Energy Co. AWO M2-91-13037
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
4. Identification of System: Safety Injection
5. (a) Applicable Construction Code ASME B31.1 Edition, _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, WB1 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>2-SI-410</u>	<u>Atwood</u> <u>Morrill</u>	<u>22-094-04</u>					<u>repaired</u>	<u>NO</u>

7. Description of Work: LP'd existing "SCRAPE" on internal surface of valve body
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other EMFAN 21136-4
 Pressure _____ psi Test Temp. _____ °F
9. Remarks: WORK WAS PERFORMED IAW NCR 292-883.
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR conforms to Section XI of the ASME Code.
 Signed: Ronald H. Collette Maint Engineer 1/18, 1993
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER I&I CO. of HARTFORD, CT have inspected the REPAIR described in this Report on 02 MARCH, 1993
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date: 03 MARCH 1993 E YORK Commissions: CT 1137
(Inspected) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., information in items 1 through 4 on this data report is included on each sheet, and (2) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Northeast Nuclear Energy Company Date: FEBRUARY 22, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet: 1 of 1
(Name) (Address)
2. Plant: Millstone Unit: 2
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by: Northeast Nuclear Energy Co. AWO M2-92-14374
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System: CHARGING
5. (a) Applicable Construction Code: ANSI B31.7 - CLASS II Edition: 1969 ED Addenda, Code Cases: -
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1980, WRI Addenda, Code Cases: -
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>FE-212</u> <u>STUDS AND NUTS</u>	-	-	-	-	<u>MFR. 300-181-18</u> <u>FOR NUTS</u>		<u>REPLACEMENT</u>	<u>No</u>
	-	-	-	-	<u>MFR. 310-181-2</u> <u>AND 330-378-1</u> <u>FOR STUDS</u>		<u>REPLACEMENT</u>	<u>No</u>

7. Description of Work: REPLACED FLANGE STUDS AND NUTS (8) 1" GBBS STUDS, (16) 1" CR 8 NUTS
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other JOINT HAS HAD MANY LEAKS.
 Pressure: 378 psi Test Temp: 378 °F
9. Remarks: FLANGED JOINT AT ORIFICE PLATE LEAKING AT RETEST. AWO M2-92-15758
(Applicable Manufacturer's Data Reports to be attached)
ATTEMPTED TO TIGHTEN UNSUCCESSFULLY. AWO M2-93-00950 WILL CONTINUE REPAIR
INDIC NEXT RETEST.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
(repair or replacement)

Signed: [Signature] Title: WPE ENGINEER Date: 3/5/93
(Owner or Owner's Designee) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO. of HARTFORD, CT have inspected the REVIEWED BOLTING REPLMNT described in this Report on 08-10-93, 1993
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date: 10 MARCH 1993 Inspector: E YORK Commissions: CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date Jan 18, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)
2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-92-14958
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System charging
5. (a) Applicable Construction Code ASME B31.1 Edition, 1980 Addenda, Code Cases 481
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements -- 19 80, 481 Addenda, Code Cases ---
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-CH-432	Velan	934-1			MR1A #MP2- 24-74	1974	replaced	Yes

7. Description of Work Performed Weld build-up of socket weld ends; machined butt weld ends, LP:RTed new weld
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2310 psi Test Temp. 533°F
9. Remarks NCR 901 Authorized socket weld to butt weld ends
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed PH Lott Mntg Engineer 1/18 19 93
(Owner or Owner's Designer) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the REPAIR/RPLMNT described in this Report on 08 JANUARY, 19 93
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 23 MARCH 1993 York E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 22, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name)
(Address)
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-91-14015
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System MAIN STEAM
5. (a) Applicable Construction Code PUMP AND VALVE 1985 Edition _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1990 WPS Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>2-MS-64A</u>	<u>ATWOOD MORRIS</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>REPAIR</u>	<u>NO</u>

7. Description of Work WELD BUILD UP AND MACHINING OF 34" CHECK VALVE BODY AT SEAL RING SEATING SURFACE
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 900 psi Test Temp. 532 °F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR conforms to Section XI of the ASME Code.
 Signed William D. Moore MECHANICAL ENGINEER Title 2/22 Date 1993
(Owner or Owner's Designer) (Repair or Replacement)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT employed by THE HARTFORD STEAM BOILER INSPN & INS CO. of HARTFORD, CT have inspected the WELD REPAIR described in this Report on 25 MARCH, 1993
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 25 MARCH 1993 Inspector [Signature] E YORK Commissions CT 1137
(State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date Jan 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address) 2
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-89-5715
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System Charging / Letdown
5. (a) Applicable Construction Code ASME 1988 Edition _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, WPI Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>2-CH-442</u>	<u>Velan</u>				<u>MR112</u>		<u>replace wedge</u>	<u>Valve: yes</u>
					<u>NP2-24-74</u>			
					<u>VC</u>			
					<u>59901337</u>			

7. Description of Work Weld build-up (stellite) new wedge; machine to suit valve; install
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2310 psi Test Temp. 553 °F
9. Remarks Weld build-up of new wedge approved via NCE 292-9B1
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Aldelletta Mintz Engineers 1/19, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the REPLACEMENT described in this Report on 08 JANUARY, 19 93
(Repairs) or Replacement(s)

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 24 MARCH 1993 E York E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1-14-93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)
2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-92-16825
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System Charging
5. (a) Applicable Construction Code ASME B1PV 19 71 Edition, — Addenda, Code Cases —
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements — 1980, w91 Addenda, Code Cases —
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-CH-51B	Fisher	5167850	—	—	—		Replacement	Yes

7. Description of Work Replaced plug (disc)
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2310 psi Test Temp. 234 °F
9. Remarks "NEW DISC" WAS REORDERED VIA AWO M2-92-16825. Parts
(Applicable Manufacturer's Data Reports to be attached)
were originally removed from identical valve 2-CH-519, re-surfaced

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed PH D'Alte MISC Eng'g JAN 14 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by Waterford Steam Boiler Inspection Inc of Waterford, Ct have inspected the Replacement described in this Report on Jan 9, 1993
(Repairs or Replacements)

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Feb 18, 1993 Charles J. ... Commissions CTU37
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1-14-93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385 AWO M2-92-18730
AWO M2-92-17147
3. Work Performed by Northeast Nuclear Energy Co. Repair Organization P.O. No., Job No., etc.
P.O. Box 128 Waterford, Ct.
4. Identification of System Main Feedwater
5. (a) Applicable Construction Code ASME III G2 19 71 Edition, — Addenda, Code Cases —
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements — 1980, VBI Addenda, Code Cases —
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-FW SA	Amwood	Model #					repaired	Yes
	12692-1							

7. Description of Work ① APPLIED weld build-up to disk back stop ② Machined body to Feasible Gasket
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other PSI
 Pressure 1200 psi Test Temp. — °F
9. Remarks ① weld build-up authorized by NCR 292-1090. ② Gasket Modification
Authorized by PPCR 2-200-92. Hybrid after weld build-up as part
of SIM Gen Hydro. In-Service leak tested after gasket modification.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this repair conforms to Section XI of the ASME Code.

Signed: [Signature] Title Matt Enjimen Date 1/21 1993

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO. of HARTFORD CT have inspected the REPAIR described in this Report on 08 JANUARY, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 29 MARCH 1993 Inspector [Signature] E YORK Commissions CT 1137

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1-14-93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)
2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
(Address)
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-92-18732
P.O. Box 128 Waterford, Ct. AWO M2-91-13122
(Name) (Address) Repair Organization P.O. No., Job No., etc.
4. Identification of System Main Feedwater
5. (a) Applicable Construction Code ASME II C 2 19 71 Edition, - Addenda, Code Cases -
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 19 80, 6/81 Addenda, Code Cases -
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-FW-5B	Arwood & Merrill	Model # 12692-H					repaired	Yes

7. Description of Work ① APPLIED Weld build-up to disc BACKSTOP ② Machined body for Flowtastic gasket
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 1280 psi Test Temp. - °F
9. Remarks ① Repair authorized by NCR 292-1030. ② BASKET modification
(Applicable Manufacturer's Data Reports to be attached)
authorized by PRCR 2-200-92. Hydro'd after weld build-up as part of
SRM 604 Hydro. In-service leak test after gasket modification.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this repair conforms to Section XI of the ASME Code.
 Signed PLJ Collette Maint Engineer Jan 14 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the REPAIR described in this Report on 08 JANUARY, 19 93 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 29 MARCH 1993 E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 24, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Address) 2
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. - AWO M2-92-12273
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
4. Identification of System REACTOR COOLANT (ICI)
5. (a) Applicable Construction Code ASME III - 1982 Edition, WB Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, WS1 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>HI</u>	<u>CE</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>MRIR</u>	<u>FO2</u>	<u>REPLACEMENT</u>	<u>NO</u>
<u>ICI FLANGE (HEAD) #5</u>					<u>292-128</u>	<u>STUDS</u>		

7. Description of Work REPLACED (8) 1 3/4" STUDS ON ICI FLANGE NO. 5.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2310 psi Test Temp. 533 °F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Thomas A. Moran Title UNIC ENGINEER Date FEB 24, 1993
(Owner or Owner's Designee) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO. of HARTFORD, CT have inspected the REPLACEMENT described in this Report on 08 JANUARY, 1993
(Repairs) or Replacement(s)

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage of any kind arising from or connected with this inspection.

Date 12 MARCH 1993 E. YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in Items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1-18-93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address) 2
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-92-3484
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address) (Address)
4. Identification of System Containment Penetration - Fuel Transfer Flange
5. (a) Applicable Construction Code ASME III 2.19.80 Edition, _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, W81 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>Fuel Transfer FLANGE</u>					<u>SPEC SP-ME-727</u>		<u>replacement</u>	<u>NO</u>

7. Description of Work REPAIRED "lost" bolting
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 560 psi Test Temp. AMM-F
9. Remarks PRESSURE TESTED VIA LOCAL LEAK RATE TESTING, OPS FORM 2605C-2
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed P.J. G. Uetto Maint. Engr. 1/18, 1992
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the BOLTING REPLMNT described in this Report on 08 JANUARY, 1993
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 18 MARCH 1993 E. YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., information in items 1 through 4 on this data report is included on each sheet, and (2) each sheet is numbered the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner NORTHEAST NUCLEAR ENERGY COMPANY Date Jan 29, 91
P.O. Box 128 WATERFORD, CT 06385 Sheet 1 of 1
(Name) (Address)
2. Plant MILLSTONE Unit 2
P.O. Box 128 WATERFORD, CT 06385 AWO M2-90-16145 (Cold leg)
(Name) (Address) AWO M2-90-16146 (Hot leg)
3. Work Performed by NORTHEAST Nuclear Energy Co. Repair Organization P.O. No., Job No., etc.
P.O. Box 128 Waterford, CT 06385
(Name) (Address)
4. Identification of System Reactor Containment
5. (a) Applicable Construction Code ASME III Sub 119 GB Edition Summary 69 Addenda, Code Cases -
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 19 80 WB1 Addenda, Code Cases -
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
X-25								
No. 1 Station								
Primary Manifold								
16 STUDS	Cardinal	-	-	-	MRIR 289-179-1	1989	REPLACED	NO
9 NUTS	A+G				MRIR 289-179-1	1989	REPLACED	NO

7. Description of Work REPLACED 16 STUDS AND 9 NUTS HOT LEG: 8 STUDS 6 NUTS
 COLD LEG: 8 STUDS 3 NUTS
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2265 psi Test Temp. 532 °F
9. Remarks Refer to NCR 290-605 for STUD CHANG TEST RESULT EVALUATION.
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Paul H. Colletta Maintenance Engineer Jan 29, 19 91
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSP&INS CO
HARTFORD, CT have inspected the REPLACEMENTS described in this Report on MAY 04, 19 91
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date MAY 04, 1991 E. A. YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in Items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: NORTHEAST Nuclear Energy Company Date: Jan. 29, 1991
P.O. Box 128 WATERFORD, CT 06385 Sheet 1 of 1
2. Plant: MILLSTONE Unit: 2
P.O. Box 128 WATERFORD, CT 06385 AWO M2-90-16147 (Cold Log)
 AWO M2-90-16149 (Hot Log)
3. Work Performed by: NORTHEAST Nuclear Energy Co. Repair Organization P.O. No., Job No., etc.
P.O. Box 128 Waterford, CT 06385
4. Identification of System: Reactor Coolant
5. (a) Applicable Construction Code: ASME III G4 1968 Edition, Summary 69 Addenda, Code Cases: ---
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 19 80 401 Addenda, Code Cases: ---
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
X-26, No 2 Steam Gen Primary Manifold								
39 STUDS	Corbinal	-	-	-	MRIR 289-209-1	1989	REPLACED	NO
11 NUTS	A:G				MRIR 289-174	1989	REPLACED	NO
6 STUDS	EG:G				MRIR 283-120-1	1983	REPLACED	NO

7. Description of Work: REPLACED 9 STUDS AND 11 NUTS: Cold Log; 5 STUDS 11 NUTS
Hot Log: 4 STUDS
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2265 psi Test Temp. 532 °F
9. Remarks: Refer to NCR 290-605 for STUD Charpy Test Result Evaluation.
 (Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
 Signed: Paul J. Collett Maint. Engr. Title: 1/29 Date: 19 91

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSP&INSCO HARTFORD, CT have inspected the REPLACEMENTS described in this Report on MAY 04, 1991 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date: MAY 04, 1991 E.A. YORK (Inspector) Commissions CT 1137 (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner NORTHEAST NUCLEAR ENERGY COMPANY Date Jan 29, 1991
P.O. Box 128 WATERFORD, CT 06385 Sheet 1 of 1
(Name) (Address)
2. Plant MILLSTONE Unit 2
P.O. Box 128 WATERFORD, CT 06385
(Name) (Address)
3. Work Performed by NORTHEAST Nuclear Energy Co. Repair Organization P.O. No., Job No., etc. AWO M2-90-16203
P.O. Box 128 Waterford, CT 06385
(Name) (Address)
4. Identification of System Reactor Coolant
5. (a) Applicable Construction Code ASME II LA, 19 68 Edition, Summer 69 Addenda, Code Cases ---
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 19 80, WBI Addenda, Code Cases ---
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<i>Pressure J-37 Primary Manifold</i>								
<u>1 Stud</u>	<u>Cardinal</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>MRIR 289-2041</u>	<u>1989</u>	<u>REPLACED</u>	<u>NO</u>
<u>NUT</u>					<u>MRIR 289-177</u>		<u>REPLACED</u>	<u>NO</u>

*N/A
PAC 1/29/91*

7. Description of Work REPLACED 1 STUD(S)
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2265 psi Test Temp. 235 °F
9. Remarks Refers to NCR 290-605 for Stud Charpy Test Result Evaluation.
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Paul Volante Title MAINTENANCE ENGR Date Jan 29, 1991
(Owner or Owner's Designee) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSP&INSCO
HARTFORD, CT have inspected the REPLACEMENT described in this Report on MAY 04, 1991
(Repair(s) or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date MAY 04, 1991 Inspector E.A. YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 9/22/92
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)
2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWO N2-91-05669
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No. (Job No.) etc.
(Address)
4. Identification of System RCS
5. (a) Applicable Construction Code ASME III 1968 Edition, 1969 Addenda, Code Cases ASME II 80 W80
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, W80 Addenda, Code Cases
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>PRESSURIZER STUDS</u>	<u>JCRC NUCLEAR PRODUCTS</u>	<u>291-037</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>91</u>	<u>Replacement</u>	<u>NO</u>

7. Description of Work Replaced 3 Pressurizer Nonway Studs
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2250 psi Test Temp. 532 °F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code (repair or replacement)

Signed Robert L. Engineers Title 9/22 Date 1992
(Owner or Owner's Designee)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & TESTS CO
HARTFORD, CT have inspected the 3 STUDS REPLMNT described in this Report on JUNE 17, 1991
(Repair(s) or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 10-05-92 E. YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 6 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: NORTHEAST NUCLEAR ENERGY COMPANY Date: 6/3/91
P.O. Box 128 WATERFORD, CT 06385 Sheet: 1 of 1
 2. Plant: MILLSTONE Unit: 2
P.O. Box 128 WATERFORD, CT 06385
 3. Work Performed by: NORTHEAST Nuclear Energy Co. AWO MZ-90-14107
P.O. Box 128 Waterford, CT 06385 Repair Organization P.O. No., Job No., etc.
 4. Identification of System: FEEDWATER
 5. (a) Applicable Construction Code: PUMP & VALVE Edition: 68 Addenda, Code Cases: ---
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 19 80 W81 Addenda, Code Cases: ---
 6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Natl. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-FW-SA STUDS		---	---	---	MR12 291-019-3	---	REPLACEMENT	NO
2-FW-SA NUTS		---	---	---	MR12 291-019-1	---	REPLACEMENT	NO

7. Description of Work: REPLACED ALL 20 CLOSURE STUDS AND NUTS (1/2" - Ø)
 8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure: 910 psi Test Temp: 437 °F
 9. Remarks: 1 - 5/8"
 (Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR REPLACEMENT conforms to Section XI of the ASME Code. JUL 6/3/91
 Signed: [Signature] Title: MAINT ENGR Date: 6/3, 19 91
 (Owner or Owner's Designee) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSP & INS CO of HARTFORD, CT have inspected the BOLTING REPLACEMENT described in this Report on 1/4/91 THRU 7/2, 1991 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date: JULY 02, 1991 Commissions: CT 1137
[Signature] (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner NORTHEAST Nuclear Energy Company Date 6/3/91
P.O. Box 128 WATERFORD, CT 06385 Sheet 1 of 1
2. Plant MILLSTONE Unit 2
P.O. Box 128 WATERFORD, CT 06385
3. Work Performed by NORTHEAST Nuclear Energy Co. AWO MZ-90-14107
P.O. Box 128 Waterford, CT 06385 Repair Organization P.O. No., Job No., etc.
4. Identification of System FEEDWATER
5. (a) Applicable Construction Code CR PUMP 450 VLV Edition, — Addenda, Code Cases —
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements -- 19 80, W51 Addenda, Code Cases —
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Natl. Ed. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>3-FW-5A</u>	<u>ATWOOD & MORRILL</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>REPAIRED</u>	<u>NO</u>

7. Description of Work WELDED REPAIR OF BODY GASKET SEATING SURFACE / MACH COVER
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
Pressure 910 psi Test Temp. 437 °F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR conforms to Section XI of the ASME Code.

Signed Thomas P. Motta Title MAINT ENGR Date 6/3, 1991
(Owner or Owner's Designee)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the REPAIR described in this Report on 1/4/91 THRU 7/2, 1991 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date JULY 02, 1991 Inspector E. A. York Commissions CT 1137
(State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner NORTHEAST Nuclear Energy Company Date 1/8/91
P.O. Box 128 WATERFORD, CT 06385 Sheet 1 of 1
(Name) (Address)
2. Plant MILLSTONE Unit 2
P.O. Box 128 WATERFORD, CT 06385
(Name) (Address)
3. Work Performed by NORTHEAST Nuclear Energy Co. AWO MZ-90-14109
P.O. Box 128 Waterford, CT 06385
(Name) (Address) Repair Organization P.O. No., Job No., etc.
4. Identification of System MAIN STEAM
5. (a) Applicable Construction Code GB PUMP & TANK Edition CLASS 2 Addenda, Code Cases ---
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 19 80 4/81 Addenda, Code Cases ---
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>2-MIS-190A</u>	<u>COPIES VULCAN</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>REPLACEMENT</u>	<u>NO</u>
<u>NUTS</u>					<u>MRIR-291-019</u>			

7. Description of Work REPLACED ALL (8) 1 3/8" d BOTTOM COVER NUTS
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 335 psi Test Temp 520 °F
9. Remarks (Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
 Signed Thomas A. Moore MAINT EDGR 1/8, 1991
(Owner or Owner's Designer) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by ASBIEICO of CONN. have inspected the REPLACEMENTS described in this Report on 1/23, 1991 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 1/03/91 J. P. [Signature] Commissions NB10644 CT1062
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner NORTHEAST NUCLEAR ENERGY COMPANY Date 1/8/91
P.O. Box 128 WATERFORD, CT 06385 Sheet 1 of 1
(Name) (Address)
2. Plant MILLSTONE Unit 2
P.O. Box 128 WATERFORD, CT 06385
(Name) (Address)
3. Work Performed by NORTHEAST Nuclear Energy Co. AWO MB-90-14109
P.O. Box 128 Waterford, CT 06385
(Name) (Address) Repair Organization P.O. No., Job No., etc.
4. Identification of System MAIN STEAM
5. (a) Applicable Construction Code CBPUMP + VALVE Edition CLASS 2 Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 19 80, WB1 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-MS-190A	COPE'S VULCAN	-	-	-	-	-	REPAIRED	NO

7. Description of Work MACHINED BOTTOM COVER TO REMOVE STEAM CUTTING
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 835 psi Test Temp. 520 °F
9. Remarks NUSCO DRAWING 25202-29087, SHEET 1
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR conforms to Section XI of the ASME Code (Repair or Replacement)

Signed Thomas A. Moore Title MAINT ENGINEER Date 1/8, 1991
(Owner or Owner's Designer) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by HSBIS I CO of CONN have inspected the REPAIRS described in this Report on 1/23, 1991
(Repair(s) or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 1/23/91 Inspector Jan P. [Signature] Commission NB 10644 CT1262
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 22, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name)
(Address)
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. - AWO M2-91-04949
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System CHARGING
5. (a) Applicable Construction Code PLMP & VLV 1986 Edition, _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, W81 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Ed. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
P-18A	GALIN	87B030	-	-	MARK 2-285-284	-	REPLACED	NO
'A' CHG PMP								

7. Description of Work REPLACED CRACKED CHARGING PUMP BLOCK
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2300 psi Test Temp. 108 °F
9. Remarks NEW BLOCK IS SHOP PEENED AND HAS LARGER RADIUS AT BORE TRANSITION
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Thomas A. Mow MTC ENGINEER 2/22, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the REPLACEMENT described in this Report on 05-24-91, 19 _____

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 03-03-93 E YORK E York Commissions CT 1137
(Inspector) (State or Province National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., information in items 1 through 4 on this data report is included on each sheet, and (2) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/2/92
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)
2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
(Address)
3. Work Performed by Northeast Nuclear Energy Co. AWO 112-91-05623
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System 2316 MAIN STEAM
5. (a) Applicable Construction Code ASME SEC. XI Edition, _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1992, 2E1 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>2-MS-19A</u>	<u>COOPER</u>	<u>710-95210</u> <u>-1-1</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>REPAIR</u>	<u>NO</u>
<u>1-MS-20A</u>								
<u>1-MS-20B</u>								
<u>1-MS-20C</u>								

7. Description of Work REWORK OF PLUG TO INCORPORATE DESIGN CHANGE
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 250 psi Test Temp. 230 °F
9. Remarks CRACKS IN MAIN PLUG FOR PLUG RINGS WERE MACHINED DEEPER
(Applicable Manufacturer's Data Reports to be attached)
PER VENDOR SPECIFICATION.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR conforms to Section XI of the ASME Code.
(repair or replacement)

Signed [Signature] Title QA ENGINEER Date 1/2, 19 92
(Owner or Owner's Designee) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the REPAIR described in this Report on 7-8-91, 1991
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date JULY 28, 1992 [Signature] Commissions NB 9384 CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Northeast Nuclear Energy Company Date: 1/29/92
P.O. Box 128 Waterford, Ct. 06385 Sheet: 1 of 2
(Name) (Address)
2. Plant: Millstone Unit: _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by: Northeast Nuclear Energy Co. AWO M2-91-12219
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
4. Identification of System: MAIN STEAM
- * 5. (a) Applicable Construction Code: Section XI 1968 Edition, _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1968, WB1 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Inlet flange AT Safety Valve	DRAYO	-	-	-	6"-EBB-2	-	REPAIRED	PIPING "NPT" STAMP
2-MS-242 (6"-EBB-2)								

7. Description of Work: Weld REPAIRED AND MACHINED 2-MS-242 inlet flange (PIPE SIDE) steam cut
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure: 850 psi Test Temp. 525 °F
- * 9. Remarks: PIPE SYSTEM WAS DESIGNED FOR ANSI B31.7-1969; VALVE IS 1968 DRAFT PUMPING CO.
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR conforms to Section XI of the ASME Code.
(repair or replacement)

Signed: Paul H. Clabby MAINT ENGINEER 1/29 19 92
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPECTION & INS. CO of HARTFORD, CT have inspected the REPAIR described in this Report on FEBRUARY 24, 1992
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date: 24 FEB 92 E YORK Commissions: CT 1137 NB 9384
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 5/6/92
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)

2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
(Address)

3. Work Performed by Northeast Nuclear Energy Co. AWO MZ-91-12244
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)

4. Identification of System 2316 MAIN STEAM

5. (a) Applicable Construction Code ASME III 1971 Edition W72 Addenda, Code Cases ---
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, WBI Addenda, Code Cases ---

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
1. 2-MS-220B	MASONEILIAN	N-00126-6-2	N/A	N/A	-	-	REPAIR	NO
2. (8) 5/8" x 3/16" BR STUDS	SEE MFR	N/A	N/A	N/A	RRIR 390-291-1	-	REPLACEMENT	NO

7. Description of Work 1. MACHINE BONNET GASKET SEATING SURFACE
2. REPLACE BODY/BONNET STUDS

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 550 psi Test Temp. 525 °F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR / REPLACEMENT conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Thomas A. Moore MAINT ENGR 5/6, 19 92
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the REPAIR & REPLMNT described in this Report on 06 JANUARY, 19 92
(Repair(s) or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 04 AUGUS. E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/15/92
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name)
(Address)
2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWO MD-91-13216
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System MAIN STEAM
5. (a) Applicable Construction Code 1992 Edition Addenda, Code Cases -
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1992 Addenda, Code Cases -
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>3-MD-132</u>							<u>REPLACEMENT</u>	<u>NO</u>
					<u>SEE NCR</u>		<u>291-287 AND 291-310</u>	
							<u>AND PDR 2-110-91</u>	
							<u>MRIR 291-212-19</u>	

7. Description of Work REPAIRED UNDER PDR 2-110-91 IN CONTROL VALVE
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 350 psi Test Temp. 525 °F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
(repair or replacement)

Signed Thomas J. Moore INSPECTOR 1/15, 19 92
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO. of HARTFORD, CT have inspected the REPLACEMENT described in this Report on 6 JANUARY ----, 1992
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 29 JULY 1992 ELIZABETH YORK CT 1137 NB 9384
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1-18-93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)

2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385

3. Work Performed by Northeast Nuclear Energy Co. Repair Organization P.O. No., Job No., etc. AWO M2-92-00614
P.O. Box 128 Waterford, Ct.
(Address)

4. Identification of System RCS

5. (a) Applicable Construction Code ASME CC-1 1968 Edition, Summer 69 Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, 81 Addenda, Code Cases _____

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>HJTC</u>	<u>GRAYLOCK</u>				<u>STUD MARK:</u>		<u>replacement</u>	<u>NO</u>
<u>GRAYLOCK</u>					<u>286-M231</u>			
<u>FLANGE</u>					<u>NUTS</u>			
					<u>289-59-5</u>			
					<u>289-57-5</u>			

7. Description of Work replace (1) stud & (2) NUTS on "B" HJTC flange

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2310 psi Test Temp 533 °F

9. Remarks _____
(Applicable Manufacturers Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed PJ Galletta Metc Engineers 118, 19 93
(Owner or Owner's Designer) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the BOLTG RPLMNT described in this Report on 22 MARCH & 11 DECEMBER, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 22 MARCH 1993 E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 3/26/93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Address)
2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWOT # 4292-15200
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
4. Identification of System REACTOR COOLANT
5. (a) Applicable Construction Code SCMH 19.6B Edition, _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980 Addenda, Code Cases WINTER 1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRT No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
COVER HT-X	BYRON	222434			291-099	1991	REPLACEMENT	YES
ROT. ELEMENT	TRIP SCW	REWORKED 34137			287-116	1966	REPLACEMENT	YES - NO KE 3/26/93

7. Description of Work REMOVED ORIGINAL ROTATING ELEMENT & COVER & INSTALLED NEW COMPONENTS.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 210 psi Test Temp 553 °F
9. Remarks ORIGINAL PUMP SN-061-N-0451 (RLPA)
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
 Signed John L. Ciscone SRENG. # 3/26/93 1993
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO. of HARTFORD, CT have inspected the REPLACEMENT/BLOCK described in this Report on 30 MARCH, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 30 MARCH 1993 E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

*reviewed & verified

Notes: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1-9-93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address) 2

2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385

3. Work Performed by Northeast Nuclear Energy Co. M2-91-13033
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.

4. Identification of System Basic Acid

5. (a) Applicable Construction Code FCVCLII 19 68 Edition _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, WB1 Addenda, Code Cases _____

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-CH-155	VELON	-	-	-	G238- M3-II-C	1973	Replacement	NO

7. Description of Work Replace nut and stud

8. Test Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 117 psi Test Temp. 80 °F

9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code.
 Signed [Signature] Engineer January 9, 1993
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN&INS CO.
HARTFORD, CT have inspected the BOLT& REPLMNT described in this Report on 08 JANUARY, 1993
(Repairs or Replacements)

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 30 MARCH 1993 [Signature] E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1-8-93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-92-06297
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
4. Identification of System Safety INJECTION
5. (a) Applicable Construction Code Part 1 of Div 1 1968 Edition _____ Addenda, Code Cases _____
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, WBI Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-SI-008	Velan						REPAIRED	No

7. Description of Work Re-MACHINED Bonnet to restore seal ring seating surface
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
Pressure 182 psi Test Temp. 65 °F
9. Remarks WORK PERFORMED JAW NCR 292-948
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR conforms to Section XI of the ASME Code.
Signed Paul H. Colletto MNTC Engineer TAN 8, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the MACHING REPAIR described in this Report on 08 JANUARY, 19 93 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 30 MARCH 1993 JAW E YORK Commissions CT 1137
*reviewed/verified (Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1-18-93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
(Address)
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-92-16719
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System Letdown
5. (a) Applicable Constructor Code ASME III 42.19 71 Edition _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, W91 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-CH-515	Fisher	5967848			NEW PLUG MRIR # 2-141-77		replacement	No

7. Description of Work replaced valve plug in time
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 3310 psi Test Temp. 533 °F
9. Remarks Hydro'd as part of RCS Hydro. Valve also tested IAW
(Applicable Manufacturer's Data Reports to be attached)
OPR Form 26052 (LLRT)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed PJ Colletta Mate Engineer 1/18, 19 93
(Owner or Owner's Designee) (Title) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the PLUG REPLMNT described in this Report on 17 MARCH & 08 JANUARY, 1993
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 17 MARCH 1993 E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1-14-93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name)
(Address)
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
(Address)
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-92-16667
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System changing
5. (a) Applicable Construction Code ASME III 19 71 Edition, _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 19 90, W/91 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-CH-519	Fisher	5467052					replacement	Yes

7. Description of Work Replaced valve plug (disc)
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2310 psi Test Temp. 533 °F
9. Remarks EXISTING DISC WAS FITTED. A one-for-one replacement was installed. New plug MEIR # 292-8-7
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed R.H. Hetter Mntz Engr 1-18, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the DISC RPLMNT described in this Report on 08 JANUARY, 19 93
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 18 MARCH 1993 E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 24, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Address) 2
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. - AWO MZ-90-13363
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System REACTOR COOLANT
5. (a) Applicable Construction Code ASME III 1991 Edition, Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1982, 1981 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>2-RC-200</u>	<u>DRESSER</u>	<u>BN 7128</u>	<u>-</u>	<u>-</u>	<u>MR12 250-250-1</u>	<u>STUDS</u>	<u>REPLACEMENT</u>	<u>NO</u>
					<u>MR12 250-250-2</u>	<u>NUT</u>		

7. Description of Work REPLACED 1 STUD AND 2 NUTS (1/8" ASTM 193/194 GR B318) AT VALVE INLET
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2310 psi Test Temp 533 °F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code (repair or replacement)

Signed Thomas A. Thode MTC ENGINEER FEB 24 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the NUT & STUD REPLACEMENT described in this Report on 08 JANUARY, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 04 MARCH 1993 E. YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 6 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 22, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name)
(Address) 2
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. - AWO M2-92-18622
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
4. Identification of System REACTOR COOLANT SUPPORT
5. (a) Applicable Construction Code MS-SP-5819-67 Edition, _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, W81 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>HGR</u>	-	-	-	-	<u>WIR 291-231-1</u>	<u>BOLTS</u>	<u>REPLACEMENT</u>	<u>NO</u>
<u>408010A</u>					<u>391-253-1</u>	<u>NUTS</u>		
<u>A2 VLV</u>								
<u>Z-R1-201</u>								

7. Description of Work REPLACE 1 BOLT AND 1 NUT ON SPRING CAN SUPPORT
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure _____ psi Te Temp _____ °F
9. Remarks A VISUAL EXAM OF THE INSTALLED SUPPORT WAS MADE VERIFYING
(Applicable Manufacturers Data Reports to be a... *d) INSTALLATION

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
 Signed Thomas A. Moore MUTC ENGINEER Title 2/22/ Date 1993
(Owner or Owner's Designer) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the BOLT'G REPLMNT described in this Report on 04 JANUARY, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 16 MARCH 1993 E. YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., information in Items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 22, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name)
(Address)
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. - AWO MZ-92-18621
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System REACTOR COOLANT SUPPORT
5. (a) Applicable Construction Code B31.1-1982 Edition, _____ Addenda, Code Cases _____
1982, 481 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
HGR	-	-	-	-	PAIR 392-077-1	BOLTS	REPLACEMENT	NO
408009A					PAIR 492-023-1	NUTS		
AT VLV								
2-RC-200								

7. Description of Work REPLACED 2 BOLTS AND 2 NUTS ON SUPPORT WHICH ATTACHES TO INLET FLANGE ON
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other PRESSURIZATION SAFETY 2-RC-200
 Pressure _____ psi Test Temp. _____ °F
9. Remarks A VI-1 VISUAL EXAM OF THE INSTALLED SUPPORT WAS MADE VERIFYING
(Applicable Manufacturer's Data Reports to be attached) INSTALLATION

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the:
(repair or replacement)
 ASME Code _____
 Signed Thomas A. Moore MTC ENGINEER Title FEB 22 19 93 Date
(Owner or Owner's Designer) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the BOLT'G REPLMNT described in this Report on 04 JANUARY 19 93
(Repair or Replacement)

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 17 MARCH 1993 E. YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this date report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 22, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Address) 2
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. - AWO 112-92-16821
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System CHARGING
5. (a) Applicable Construction Code ASME III - 1971 Edition, Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, 1981 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-CH-517	FISHER	4924590	-	-	721 22-104 11/11/93 (MPSN# MP-SP-858)	4/14/93	REPLACEMENT	NO

7. Description of Work REPLACED WORN VALVE DISC PLUG 17.7M 4/16/93
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2310 psi Test Temp. 534 °F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
 Signed Thomas A. Moore MTC ENGINEER FEB 24 1993
(Owner or Owner's Designer) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the PLUG REPLACEMENT described in this Report on 08 JANUARY, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 16 APRIL 1993 E York E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of tabs, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 24, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. - AWO M2-92-16784
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
4. Identification of System MAIN STEAM
5. (a) Applicable Construction Code 1965 PUMPS & VALVE CODE Edition, _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, 1991 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>2-MS-190B</u>	<u>W.P.E.S. VOLCAN</u>	<u>7110-95212-1-2</u>	-	-	-	-	<u>REPAIRED</u>	<u>NO</u>

7. Description of Work REPAIRED GASKET SEATING SURFACE ON VALVE BODY AND COVER IAW PDQR 2-171-9
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 900 psi Test Temp. 532 °F
9. Remarks REPAIR PERFORMED UNDER AWO M2-91-13268
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR conforms to Section XI of the ASME Code.

Signed Thomas A. Morris MNTC ENGINEER Title FEBRUARY 24, 1993 Date

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the MAKING REPAIR described in this Report on JAN 11, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date April 16, 93 [Signature] Commissions CT-1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this date report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 24, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address) Unit 2
2. Plant Millstone
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. - AWO MZ-91-13268
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
4. Identification of System MAIN STEAM
5. (a) Applicable Construction Code ASME PUMP AND VALVE Edition, 1968 ED Addenda, Code Cases -
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, 1981 Addenda, Code Cases -
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>2-MS-190B</u>	<u>COPELAND</u>	<u>7110-95210-1-2</u>	-	-	<u>P.O. 93997</u> <u>FOR PLUG</u> <u>(MIRA 292-341-1)</u>		<u>* REPAIR *</u> <u>REPLACEMENT</u>	

7. Description of Work REPAIRED UPPER TRIM GASKET SEATING SURFACE BY MACHINING.
REPLACED INNER PLUG (PILOT PLUG) IN TANDEM TRIM ATM DUMP CONTROL VALVE
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure: 20 psi Test Temp: 532 °F
9. Remarks: (Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR + REPLACEMENT conforms to Section XI of the:
(repair or replacement)
 ASME Code
 Signed: Thomas A. Moor MATC ENGINEER FEBRUARY 24, 1993
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Connecticut, employed by The Hartford Steam Boiler Inspection & Ins. Co. of Hartford Ct. have inspected the Repair + Replace described in this Report on 11 January, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date: 20 April 1993 Chadwick Commissions: C71137 NE 9504
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 6 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 04-09-93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. M2-92-08955/08443
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
4. Identification of System 2312 CONTAINMENT STRUCTURE SYSTEM - PENETRATIONS
5. (a) Applicable Construction Code ASME B31.7 II 19 67 Edition, Addenda, Code Cases
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1986 July 86 Addenda, Code Cases
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>6" PIPE BECHTEL CAP</u>					<u>PEN#48</u>	<u>1971</u>	<u>REPAIR</u>	<u>NO</u>

7. Description of Work REMOVED (CUT) 6" PIPE CAP FOR ACCESS - REPLACED WITH ORIGINAL CAP.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 54 psi Test Temp. 71 °F
9. Remarks ILRT WAS PERFORMED ON ENTIRE CONTAINMENT STRUCTURE 12-23-92.
 (Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR conforms to Section XI of the ASME Code.
 Signed Thomas G. Quinlan Eng. ESE Title Date 04-09, 19 93
 (Owner or Owner's Designee) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO. of HARTFORD, CT have inspected the REPAIR described in this Report on 20 DECEMBER, 1992 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 09 APRIL 1993 NEW YORK Commissions CT 1137
 (Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1/8/93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name)
(Address)
2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWO No. M2-92-15088
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System AUX. FEEDWATER CLASS
5. (a) Applicable Construction Code ASME III 1971 & B6 Edition, WINTER 1981 Addenda, Code Cases 2
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, WINTER Addenda, Code Cases 2
6. Identification of Components Repaired or Replaced, and Replacement Components 1981

Name of Component	Name of Mfr.	Mfrs. Ser. No. MPSN No.	Nat'l. Ed. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
6" - 90° ELBOW	HUB	188-181-3	NA	NA	NA	NA	REPLACED	NA
6" - STRAIGHT	TIOGA	391-246-1	NA	NA	NA	NA	REPLACED	NA

7. Description of Work REMOVE NON-CONFORMING COMPONENTS, REPLACE ONE FOR ONE.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 1250 psi Test Temp. _____ °F
9. Remarks NA
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
 Signed Carol C. Cygan SENIOR ENGINEER Title 1-11, 19 93 (Date)
(Owner or Owner's Designee)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the REPLACEMENT described in this Report on 09 DECEMBER, 19 92 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12 JANUARY 1993 ELIZABETH YORK Inspector CT 1137 (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 22, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address)
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-92-13294
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System SAFETY INJECTION
5. (a) Applicable Construction Code ASME II 19.6E Edition, _____ Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, 1981 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Ed. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>2-SI-652</u>	<u>VELAN</u>	<u>(P2-0634)</u> <u>(N-17)</u>	<u>'N'</u>	<u>-</u>	<u>-</u>	<u>-</u>	<u>REPAIR</u>	<u>'N' (YES)</u>

7. Description of Work DRILL 1/4" HOLE ON UPSTREAM SIDE OF VALVE WEDGE TO INSURE HYDRAULIC FORCES WILL EQUALIZE AND ELIMINATE POTENTIAL FOR BINDING
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 22 psi Test Temp. 83 °F
9. Remarks RETEST PERFORMED PER AWO M2-92-05255
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR conforms to Section XI of the ASME Code.
(repair or replacement)

Signed [Signature] Title MUTC ENGR Date FEB 22, 19 93
(Owner or Owner's Designee) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the REPAIR described in this Report on 01 MARCH, 19 93
(Repair(s) or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 01 MARCH 1993 [Signature] E YORK Commissions CT 1137
Inspector (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date 1-18-93
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Address)
2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AWO M2-9214959
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System Charging
5. (a) Applicable Construction Code ASME VIII 19 6B Edition, — Addenda, Code Cases —
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 19 20, 4B Addenda, Code Cases —
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-CH-433	Velan	933-1			MRI R MP-V- 134	1974	replaced	No - see remark

7. Description of Work Performed weld build-up of socket welds, machined to butt weld, welded in plant
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2310 psi Test Temp. 553°F
9. Remarks Valve was upgraded to CLASS 1 via NCR 292-651; Conversion to
butt welds accomplished via NCR 292-901
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code.
(repair or replacement)

Signed AJ Galletti Plant Engineer Jan 18, 19 93
(Owner or Owner's Designee) Title Date

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the RPLMN/REPAIR described in this Report on 08 JANUARY, 1993
(Repairs or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 26 MARCH 1993 E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date March 25, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name) (Address) Unit 2

2. Plant Millstone
P.O. Box 128 Waterford, Ct. 06385

3. Work Performed by Northeast Nuclear Energy Co. AWO MZ-92-14026
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.

4. Identification of System Charging

5. (a) Applicable Construction Code ASME III 1974 Edition S75 Addenda, Code Cases -
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, WB1 Addenda, Code Cases -

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
P18B	APV-GALLIN	87E040	N/A	N/A	N/A	1989	Replacement	Yes

7. Description of Work Replacement of pump P-18B block assembly.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2345 psi Test Temp. 101°F

9. Remarks Manufacturer's hydro at 4600 psi per attached data report.
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to Section XI of the ASME Code.
 Signed [Signature] Engineer March 25, 1993
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO. of HARTFORD, CT have inspected the REPLACEMENT described in this Report on 30 MARCH, 1993 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 30 MARCH 1993 [Signature] E YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 22, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name)
(Address)
 2. Plant Millstone Unit 2
P.O. Box 128 Waterford, Ct. 06385
 3. Work Performed by Northeast Nuclear Energy Co. AWO M2-92-00231
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
 4. Identification of System MAIN STEAM Addenda, Code Cases -
 5. (a) Applicable Construction Code PUMP & VALVE CODE 1962 Edition - Addenda, Code Cases -
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, WBI Addenda, Code Cases -
 6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Ed. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
① 2-MS 65B	VELAN	-	-	-	-	-	REPAIRED	NO
② 2-MF 68B	BONNET CLAMP	VELAN	-	-	MFR 252-1057	-	REPLACE	NO

7. Description of Work REPLACED BONNET CLAMP RESTORE SEAL RING SEATING SURFACE ON VALVE BONNET BY MACHINING
 8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 880 psi Test Temp. 530 °F
 9. Remarks (Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR AND REPLACEMENT conforms to Section XI of the ASME Code.
 Signed Thomas A. Mor MAR Matic Engineer 2/22, 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO. of HARTFORD, CT have inspected the BONNETS & BNT CLMP described in this Report on 12-8-92, 1992 and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 02-26-93 E YORK CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 22, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Address)
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. AIWO M2-92-01665
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System MAIN STEAM
5. (a) Applicable Construction Code ASME III, LR 1974 Edition, S 75 Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980 HB1 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Ed. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2-MS4B	ANCHOR DARLING	-	-	-	-	-	REPAIRED	NO

7. Description of Work WELD REPAIR AND MACHINING OF SHAFT COVER GASKET SEATING SURFACE
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 900 psi Test Temp. 532 °F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPAIR conforms to Section XI of the:
(Repair or replacement)

ASME Code _____

Signed Thomas A. Moore MECH ENGINEER FEB 22 19 93
(Owner or Owner's Designee) Title (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the REPAIR described in this Report on 15 FEBRUARY, 1992
(Repair(s) or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 10 MARCH 1993 E. YORK Commissions CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company Date FEBRUARY 23, 1993
P.O. Box 128 Waterford, Ct. 06385 Sheet 1 of 1
(Name)
(Address)
2. Plant Millstone Unit _____
P.O. Box 128 Waterford, Ct. 06385
3. Work Performed by Northeast Nuclear Energy Co. - AWO M2-92-03788
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.
(Address)
4. Identification of System SAFETY INJECTION
5. (a) Applicable Construction Code ASME PLM-19 VALVE Edition, 1968 ED Addenda, Code Cases _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, 481 Addenda, Code Cases _____
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
<u>2-SI-227</u>	<u>ATWOOD & MORRILL</u>	—	—	—	<u>MP12 291-200-1</u>	<u>STUDS</u>	<u>REPLACEMENT</u>	<u>N/D</u>
					<u>MP12 292-334-1</u>	<u>NUTS</u>	<u>REPLACEMENT</u>	

7. Description of Work REPLACED COVER STUDS AND NUTS WITH DESIGN SUITABLE FOR USE WITH HYDRAULIC TENSIONER
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
 Pressure 2235 psi Test Temp. 550 °F
9. Remarks _____
(Applicable Manufacturer's Data Reports to be attached)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this REPLACEMENT conforms to Section XI of the ASME Code.
(repair or replacement)

Signature: [Signature] Title: MNTC ENGINEER Date: FEB 23, 1993
(Owner or Owner's Designee) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of HARTFORD, CT have inspected the BOLTING REPLMNT described in this Report on 08 JANUARY, 1993
(Repair(s) or Replacement(s))

and state that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date: 05 MARCH 1993 Inspection by: [Signature] E YORK Commissions: CT 1137
(Inspector) (State or Province, National Board)

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Northeast Nuclear Energy Company
P.O. Box 128 Waterford, Ct. 06385 Date 1/27/93

2. Plant Millstone (Address) Sheet 1 of 1
P.O. Box 128 Waterford, Ct. 06385 Unit 2

3. Work Performed by Northeast Nuclear Energy Co. Dresser Industries PO #885482 MAIR #292-087
P.O. Box 128 Waterford, Ct. Repair Organization P.O. No., Job No., etc.

4. Identification of System Main Steam Addenda, Code Cases _____
Edition _____

5. (a) Applicable Construction Code Pump & Valve 1968 Edition _____
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements - 1980, W 81 Addenda, Code Cases _____

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l. Bd. No.	CRN No.	Other Identification	Year Built	Repaired, Replaced, or Replaced	ASME Code Stamped (Yes or No)
MS-239	Dresser	BN4976	NB		PSV 4253	1973	Repaired	NV-2
MS-241	Dresser	BN4968	NB		PSV 4235	1973	Repaired	NV-2
MS-244	Dresser	BN4970	NB		PSV 4238	1973	Repaired	NV-2
MS-248	Dresser	BN4975	NB		PSV 4232	1973	Repaired	NV-2
MS-249	Dresser	BN4965	NB		PSV 4226	1973	Repaired	NV-2
MS-250	Dresser	BN4971	NB		PSV 4231	1973	Repaired	NV-2
MS-251	Dresser	BN4969	NB		PSV 4227	1973	Repaired	NV-2
MS-254	Dresser	BN4963	NB		PSV 4229	1973	Repaired	NV-2

Description of Work Machined valve and valve Red Net.

Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure Other
Pressure 180 psi Test Temp. 532 °F

Remarks Leak Test informed under AWC's No. M2-92-2983, M2-92-4371, M2-92-4374, M2-92-4377, M2-92-4378, M2-92-4379, M2-92-4380 and M2-92-4381

CERTIFICATE OF COMPLIANCE

I certify that the statements made in this report are correct and this repair conforms to Section XI of the ASME Code.

Mark Wynn (Owner or Owner's Designer) Station Technician Title 1/29/93 Date 19 93

CERTIFICATE OF INSPECTION

I, undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of CONNECTICUT, employed by THE HARTFORD STEAM BOILER INSPN & INS CO of WATERFORD, CT have inspected the REPAIR described in this Report on 11 JANUARY, 19 93.

I certify that to the best of my knowledge and belief, this repair or replacement has been constructed in accordance with Section XI of the ASME Code. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the repair or replacement described in this Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for personal injury or property damage or a loss of any kind arising from or connected with this inspection.

05 APRIL 1993 (Inspector) E YORK Commissions CT 1137 (State or Province, National Board)

Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. X 11 in., (2) information in items 1 through 4 on this date report is included on each sheet, and (3) each sheet is numbered in the order in which it is recorded at the top of this form.