



INTEROFFICE CORRESPONDENCE

Nuclear Engineering Design (NED)

NA1E

3582

Office

MAC

Telephone

SUBJECT: Crystal River Unit 3
Quality Document Transmittal - Analysis/Calculation

TO: Records Management - NR2A

The following analysis/calculation package is submitted as the QA Record copy:

DOCNO (FPC DOCUMENT IDENTIFICATION NUMBER)	REV	SYSTEM(S)	TOTAL PAGES TRANSMITTED
S96-0130	0	MS	21

TITLE

Qualification of Pipe Supports MSH-13B and MSH-27B

KEYWORDS (IDENTIFY KEYWORDS FOR LATER RETRIEVAL)

Hangers, Pipe Supports

DXREF (REFERENCES OR FILES - LIST PRIMARY FILE FIRST)

Problem Report 96-0180

M75-0012

M75-0013

VEND (VENDOR NAME)	VENDOR DOCUMENT NUMBER (DXREF)	SUPERSEDED DOCUMENTS (DXREF)
n/a	n/a	n/a

TAG

MSH-13B

MSH-27B

PART NO

COMMENTS (USAGE RESTRICTIONS, PROPRIETARY, ETC.)

NOTE:

Use Tag number only for valid tag numbers (i.e., RCV-8, SWV-34, DCH-99), otherwise; use Part number field (i.e., CSC14599, AC1459). If more space is required, write "See Attachment" and list on separate sheet.

DESIGN ENGINEER	DATE	VERIFICATION ENGINEER	DATE	SUPERVISOR, NUCLEAR ENG.	DATE
<i>C. Blum</i>	8/1/96	<i>D. Buchanan</i>	2/1/96	<i>A. Johnson</i>	8/1/96

cc: MAR Office (If MAR Related) Yes No

Mgr. Nucl. Config. Mgt.

Mgr., Nucl. Eng. Design

(Original) w/attach

Plant Document Updates Required Yes No (If Yes, send copy of the Calculation Review form to Nuclear Licensing and a copy of the Calculation to the Responsible Organization(s) identified in Part III on the Calculation Review form.)

A/E Yes No

(If yes, Transmit w/attach)

9608140088 960807
PDR ADOCK 05000302
P PDR



Florida Power Corporation

ANALYSIS/CALCULATION SUMMARY

DOCUMENT IDENTIFICATION NUMBER	DISCIPLINE S	CONTROL NO 96-0130	REVISION LEVEL 0
TITLE Qualification of Pipe Supports MSH-13B and MSH-27B			CLASSIFICATION (CHECK ONE) <input checked="" type="checkbox"/> Safety Related <input type="checkbox"/> Non Safety Related
			PAR/SP/CGWR/PEERE NUMBER n/a
			VENDOR DOCUMENT NUMBER n/a

	REVISION APPROVALS	ITEMS REVISED
Design Engineer	C. Glenn Pugh <i>[Signature]</i>	Original Issue
Date	8/1/96	
Verification Engineer	D. Beckwood <i>[Signature]</i>	
Date/Method*	8/1/96 CR	
Supervisor	A. Peltowski <i>[Signature]</i>	
Date	8/1/96	


***VERIFICATION METHODS:** R - Design Review; A - Alternate Calculation; T - Qualification Testing
 DESCRIBE BELOW IF METHOD OF VERIFICATION WAS OTHER THAN DESIGN REVIEW

PURPOSE SUMMARY

The purpose of this calculation is to provide detailed qualification calculations for pipe supports MSH-13B and MSH-27B.

RESULTS SUMMARY

Pipe supports are qualified to the piping analysis loads.



DOCUMENT IDENTIFICATION NO

S96-0130

REVISION
0

SECTION I PURPOSE:

The purpose of this calculation is to provide technical qualification of two Main Steam Pipe Supports MSH-13B and MSH-27B. This specific calculation is to supplement calculations sent to FPC by Parsons Power Group, Inc.. A copy of these calculations is included as Attachment 5 for reference.

SECTION II DESIGN INPUTS:

This calculation uses the following items as design inputs. The design loads are taken from the "Analysis of Record" for the appropriate piping system.

MSH-13B:

This hanger is located on Drawing 305-753 (Reference 1). It is part of analysis CR-6. This analysis is filed under FPC Calculation Number M75-0013 (Reference 3). The pipe support load summary sheets for this hanger list the following loads:

Deadweight: -7208 lbs.
Thermal: -2323 lbs.
Seismic: +/- 6796 lbs.


MSH-27B:

This hanger is located on Drawing 305-752 (Reference 2). It is part of analysis CR-5. This analysis is filed under FPC Calculation Number M75-0012 (Reference 4). The pipe support load summary sheets for this hanger list the following loads:

Deadweight: -6070 lbs.
Thermal: -2597 lbs.
Seismic: +/- 9892 lbs.

SECTION III ASSUMPTIONS:

Any assumptions used in this calculation will be stated in the body of the calculation. Any assumptions made will not require further action.




DOCUMENT IDENTIFICATION NO

S96-0130

REVISION
0

SECTION IV REFERENCES:

1. Drawing 305-753, Revision 1
2. Drawing 305-752, Revision 2
3. Analysis Calculation M75-0013, Revision 0
4. Analysis Calculation M75-0012, Revision 0
5. Pipe Support Drawing for MSH-13B, Revision 1
6. Pipe Support Drawing for MSH-27B, Revision 1
7. "Pipe Hangers and Supports," by Power Piping Company, Catalog 90.
8. "Manual of Steel Construction," by American Institute of Steel Construction, Seventh Edition.
9. Drawing 521-212, Revision 11
10. DCN 96-217
11. "Load Capacity Data Sheets for Component Standard Supports," by Power Piping Company.



DOCUMENT IDENTIFICATION NO

S96-0130

REVISION

0

SECTION V DETAILED CALCULATIONS:

Section V.1 Design Loads:

From Section II, use the following for analysis loads:

MSH-13B:

Deadweight: -7208 lbs.
Thermal: -2323 lbs.
Seismic: +/- 6796 lbs.


Or, use $7208 + 2323 + 6796 = 16327$ lbs. acting downward (applying tension load to rods). In an seismic event, the vertical seismic uplift (6796 lbs.) will not exceed the dead load on the pipe. Therefore, no uplift considerations for this hanger.

MSH-27B:

Deadweight: -6070 lbs.
Thermal: -2597 lbs.
Seismic: +/- 9892 lbs.

Or, use $6070 + 2597 + 9892 = 18559$ lbs. acting downward (applying tension load to rods). In an seismic event, the vertical seismic uplift (9892 lbs.) will exceed the dead loads on the pipe by $9892 - 6070 = 3822$ lbs. Therefore, this rod must be designed for uplift considerations.

For the design verification of these supports, use 19000 lbs (Faulted) as a tension load. Use 4000 lbs. (Faulted) as a compression load.



SECTION V DETAILED CALCULATIONS (Continued):

Section V.2 Hanger Component Qualification:

Both hangers have some hanger components in common. This section of the calculation will qualify the Power Piping Components. Allowable loads are taken from Reference 7. The below comparison is conservative since it compares the Normal/Upset allowable loads to the Faulted applied loads.

2" Diameter Rods:

The straight rods and the eye rods are considered to have the same allowable loads. The Power Piping Catalog lists the Normal/Upset allowable load of 20690 pounds > 19000 pounds.

Therefore, acceptable

Hanger Attachment, Figure 203:

The hanger attachment, Figure 203, has a published allowable load of 22000 pounds (using a 2" diameter bolt) > 19000 pounds.

Therefore, acceptable

Clevis


Per the Power Piping Catalog, clevises are designed to develop the full strength of the hanger rod with that used. Therefore, the Normal/Upset allowable load is 20690 pounds > 19000 pounds.

Therefore, acceptable

Turnbuckle:

The hanger drawing refers to a turnbuckle with a 12" opening. This corresponds to a Power Piping Figure 166 for 2" diameter rod. The catalog lists a Normal/Upset allowable loads of 37,200 pounds > 19000 pounds.

Therefore, acceptable



DOCUMENT IDENTIFICATION NO

S96-0130

REVISION

0

SECTION V DETAILED CALCULATIONS (Continued):

Section V.2 Hanger Component Qualification (Continued):


Pipe Clamp:

Support MSH-13B references a Power Piping Figure 224 pipe clamp. Support MSH-27B references a Power Piping Figure 225 pipe clamp.

The allowable Normal/Upset load for the Figure 224 is 16200 pounds. This is greater than the applied Normal/Upset load. The allowable faulted load is 30450 pounds. This is greater than the faulted load of 16327 for MSH-13B.

The allowable Normal/Upset load for the Figure 225 (MSH-27B) is 20600 pounds > 19000 pounds.

Therefore, acceptable



SECTION V DETAILED CALCULATIONS (Continued):

Section V.3 Weld Qualification:

Both Hanger Drawings reference a Figure 203 beam attachment. Power Piping Catalog shows this to be flat plate, 3/4" thick x 6" long.

VERIFIED

Faulted Loads:

$$F_x = 19000 \cdot \text{lbf}$$

$$F_y = F_x \cdot \sin(4 \cdot \text{deg})$$

$$F_y = 1325.373 \cdot \text{lbf}$$

$$F_z = F_x \cdot \sin(4 \cdot \text{deg})$$

$$F_z = 1325.373 \cdot \text{lbf}$$


$$M_x = 0 \cdot \text{lbf} \cdot \text{in}$$

$$M_y = F_z \cdot 3.5 \cdot \text{in}$$

$$M_y = 4638.806 \cdot \text{lbf} \cdot \text{in}$$

$$M_z = F_y \cdot 3.5 \cdot \text{in}$$

$$M_z = 4638.806 \cdot \text{lbf} \cdot \text{in}$$



Weld Properties:

$$d = 6 \cdot \text{in}$$

$$b = .75 \cdot \text{in}$$

$$A_w = d \cdot 2 \cdot 1 \cdot \text{in}$$

$$A_w = 12 \cdot \text{in}^2$$

$$C_y = \frac{b}{2}$$

$$S_y = d \cdot b \cdot 1 \cdot \text{in}$$

$$S_y = 4.5 \cdot \text{in}^3$$

$$C_z = \frac{d}{2}$$

$$S_z = \frac{d^2}{3} \cdot 1 \cdot \text{in}$$

$$S_z = 12 \cdot \text{in}^3$$

$$C_y = 0.375 \cdot \text{in}$$


$$J_{wx} = \frac{d}{6} \cdot 3 \cdot b^2 + d^2 \cdot 1 \cdot \text{in} \quad J_{wx} = 37.688 \cdot \text{in}^4$$

$$C_z = 3 \cdot \text{in}$$

General Weld Equation:

$$f_w = \frac{F_x}{A_w} + \frac{M_y}{S_y} + \frac{M_z}{S_z} + \frac{F_y}{A_w} + \frac{M_x}{A_w} + \frac{C_y}{J_{wx}} + \frac{F_z}{A_w} + \frac{M_x}{A_w} + \frac{C_z}{J_{wx}}$$

$$f_w = 3004.809 \cdot \frac{\text{lbf}}{\text{in}^2}$$



SECTION V DETAILED CALCULATIONS (Continued):

Section V.3 Weld Qualification (Continued):

For general A-36 type material and E60 electrodes (assumed for older hangers), the controlling allowable stress will be the shear in the weld material.

$$tw = \frac{fw \cdot (1 \cdot \text{in})}{1.33 \cdot 0.3 \cdot 0.707 \cdot 60000 \cdot \text{psi}} \quad tw = 0.178 \cdot \text{in}$$

Weld symbol shown on drawings indicate a partial penetration weld with 1/8" and 1/4" prep shown. Field walkdowns show the attachments to have a fillet weld cap. The existing fillet weld with the assumed partial penetration weld exceeds the "tw" above.

Normal / Upset Loads:

$$Fx = 9531 \cdot \text{lbf}$$

$$Fy = Fx \cdot \sin(4 \cdot \text{deg})$$

$$Fy = 664.849 \cdot \text{lbf}$$

$$Fz = Fx \cdot \sin(4 \cdot \text{deg})$$

$$Fz = 664.849 \cdot \text{lbf}$$

$$Mx = 0 \cdot \text{lbf} \cdot \text{in}$$

$$My = Fz \cdot 3.5 \cdot \text{in}$$

$$My = 2326.971 \cdot \text{lbf} \cdot \text{in}$$

$$Mz = Fy \cdot 3.5 \cdot \text{in}$$

$$Mz = 2326.971 \cdot \text{lbf} \cdot \text{in}$$


General Weld Equation:

$$fw = \sqrt{\frac{Fx}{Aw} + \frac{My}{Sy} + \frac{Mz}{Sz}}^2 + \frac{Fy}{Aw} + Mx \cdot \frac{Cy}{Jwx}}^2 + \frac{Fz}{Aw} + Mx \cdot \frac{Cz}{Jwx}}^2$$

$$fw = 1507.307 \cdot \frac{\text{lbf}}{\text{in}^2}$$

$$tw = \frac{fw \cdot (1 \cdot \text{in})}{0.30 \cdot 0.707 \cdot 60000 \cdot \text{psi}} \quad tw = 0.118 \cdot \text{in}$$

Acceptable by comparison



SECTION V DETAILED CALCULATIONS (Continued):

Section V.4 Uplift (Compression) Check:

To check the support for the compression load, need to find the pin-to-pin length of the rod. The drawing shows a dimension of 10'-0 1/4" from centerline of pipe to bottom of beam. The hanger attachment has a 3.5" dimension from bottom of beam to bolt. From the pipe centerline to the top bolt of the clamp is 21 3/4". Therefore, use a rod length of 10'-0 1/4" - 3 1/2" - 21 3/4" = 95".
(MSH-27B)

Reference 8 gives the properties of the round rod as:

Moment of Inertia: $I = \frac{\pi \cdot (2 \cdot \text{in})^4}{64}$ $I = 0.785 \cdot \text{in}^4$

Cross-sectional Area: $A = \frac{\pi \cdot (2 \cdot \text{in})^2}{4}$ $A = 3.142 \cdot \text{in}^2$

Radius of Gyration: $r = \frac{2 \cdot \text{in}}{4}$ $r = 0.5 \cdot \text{in}$

Modulus of Elasticity: $E = 29000000 \cdot \text{psi}$

Length Factor: $K = 1$

Length: $L = 95 \cdot \text{in}$

Euler Buckling load is defined as:

$$P = \frac{I \cdot \pi^2 \cdot E}{(K \cdot L)^2} \quad P = 24908.089 \cdot \text{lbf}$$

Greater than 4000#
assumed compression
load


Allowable Compressive stress as defined by AISC is:

$$\frac{K \cdot L}{r} = 190$$

$$F_a = \frac{12 \cdot \pi^2 \cdot E}{23 \cdot \frac{K \cdot L}{r}} \quad F_a = 4136.604 \cdot \text{psi}$$

$$P = F_a \cdot A \quad P = 12995.525 \cdot \text{lbf}$$

Greater than 4000#
assumed compression
load




SECTION V DETAILED CALCULATIONS (Continued):

Section V.5 Building Steel Check:

The hanger drawing for MSH-27B shows an existing 24WF68. However, Drawing 521-212 shows this beam to be a 24WF76. This does not affect this calculation. However, this discrepancy is being resolved by DCN 96-217. Hanger MSH-13B attaches to an 12WF31. Recent walkdowns show miscellaneous conduits and smallbore pipe also attach to these structural members.

MSH-13B



$$w = 31 \text{ \#/ft (W12x31)}$$

$$+ 100 \text{ \#/ft TO ACCOUNT FOR CONDUIT SUPPORT}$$

$$131$$

$$R = 7171$$

$$F = 10378$$


$$M_{max} = 37998 \text{ \#-ft FROM AISC, 7th EDITION,}$$

$$\text{PAGE 2-97, } w/L_b = 9\frac{1}{2}' \quad M_{max} = 72 \text{ \#-ft}$$

∴ OKAY

MSH-27B:

ACCEPTABLE BY COMPARISON



DOCUMENT IDENTIFICATION NO

S96-0130

REVISION
0

SECTION VI RESULTS/CONCLUSIONS:

The detailed calculations show the pipe supports, MSH-13B and MSH-27B, to be qualified to the design loads.

SECTION VII ATTACHMENTS:

- Attachment 1: Copy of Pipe Support Drawing MSH-13B for reference, one page.
- Attachment 2: Copy of Pipe Support Drawing MSH-27B for reference, one page.
- Attachment 3: Copy of pipe support load summary sheet from M75-0012 for MSH-27B, one page.
- Attachment 4: Copy of pipe support load summary sheet from M75-0013 for MSH-13B, one page.
- Attachment 5: Copy of existing calculations of MSH-13B and MSH-27B as found by Parson Power Group, Inc., five pages.




POWER PIPING COMPANY
PITTSBURGH, PA. 15233


FLORIDA POWER CORPORATION
CRYSTAL RIVER - UNIT #3
P. O. PR3-1403

FIELD NOTE:

1. THIS UNIT REQUIRES BEING
B3M-13 SUT NR 30013
B3M-13 SUT NR 30013
P.C. NO. B3M-13A SUT NR. 37812



REBERT
DESIGN-INC. W.O. No.
NOV 19 80



NO.	QUAN.	DESCRIPTION	ASTM	MP#	RECD. NR
		<input checked="" type="checkbox"/> INSPECTION <input type="checkbox"/> HOT & COLD IND. <input type="checkbox"/> SPECIAL PAINT			M5W-138
F	1	2" HORIZ. ATTACH. R. FLY 228 - DIA. 2 1/4"	575		
G	1	2" x 10 1/2" Lx 4" DIA. SUT w/ 1/2" DIA. 1 1/2" TOP EN. END	153/146	NR-348	
H	1	2" S. CURVE TAP. 2" DIA. 2" DIA. 2 1/4" DIA. GRIP. 1/4"			
J	1	2" x 20" Lx 4 1/2" DIA. w/ 1/2" TOP EN. END	575		
K	1	2" TUB. DIA. 12" Lx 12" DIA.			
L	1	2" EXTENSION 20" Lx 1/2" DIA. EN. DIA. 2 1/4"	575		
M	2	2" x 10 1/2" Lx 4" DIA. SUT w/ 1/2" DIA. 1 1/2" TOP EN. END	153/146	NR-348	
N	1	2" SUT. RISE CLAMP EN. 228 (LESS TOP PART OF DIA. TOP DIA. HOLE 2 1/4" DIA. W/ 228"			

1 Drawing
1 Assembly

Attachment 1
Analysis/Calculation
S96-0130, Rev. 0
Page 1 of 1


REF. DWG. HD-300-013 Rev. 2	DESIGNER ESM	AUTH 3926-N	ISSUE
REVISIONS 1. AS BUILT PER MAR 791271 9EC	REL. DATE OCT 03 1975	DEPT 39036	REV (1)
ES	PROJ. ENGR. LENIEWSKI		




POWER PIPING COMPANY
 PITTSBURGH, PA. 15233-

FLORIDA POWER CORPORATION
 CRYSTAL RIVER - UNIT #3
 P. O. PR3-1403

FIELD NOTE:
 1 THIS SET, PACKAGES ARE NO.
 250-27 SET NO. 20127
 250-27 SET NO. 30125
 250-27 SET NO. 30125



GILBERT
 ASSOC., INC. W.O. RO.
 NOV 19, 80



QTY	DESCRIPTION	INSPECTION	HOT & COLD NO.	SPECIAL PRINT	ASTM	MRS
1	2" HORIZ. ATTACH. R. END FOR 2 1/2" DIA. 2 1/2" DIA. 2 1/2" DIA.				575	
1	2" x 3/4" L. ALLOY SORB W/18 MM. 1 3/4" DIA. END				157/86	WT-34
1	2" S. CLAS. TAP 2" DIA. 2 1/2" DIA. 2 1/2" DIA.				575	
1	2" BOLL. 3-11" L. W/18" DIA. 18 MM. END				575	
1	2" TURNBUCKLE X 12" OPENING				575	
1	2" x 3/4" L. EYE END W/18" L.H. TRD. DIA. 2 1/2" DIA.				575	
1	2" x 3/4" L. ALLOY SORB W/18 MM. 1 3/4" DIA. END				157/86	WT-14
1	2" SPECIAL PIPE CLAMP FOR 2 1/2" DIA. (LESS TAP)					
1	DRIFT TAP BOLT FOR 2 1/2" DIA. WT-302"					

REQD. BY MSH-27B

Attachment 2
 Analysis/Calculation
 S96-0130, Rev. 0
 Page 1 of 1

REV. DATE	HO-202-21 Rev. 2	REV. DATE	OCT 03 1975	ISSUE	1
REVISIONS	REV. AS BUILT PER PARA 79-12-71 GFC	DESIGNER	LENCZEWSKI	CHKD	39037

SYSTEM MS

CALCULATION FOR CR - EN Pipe Supports


ORIGINATOR AA

DATE 5-2-74

REVIEWER S. Ferrello

DATE 1/9/75

Note: All loads act on pipe.
Positive directions are shown here.



~~ANALYSIS/CALCULATION~~
DOC ID: M-B-001 ATT: 1
REV: 0 SHEET: 20 OF 27

Comments

Mk. No.	analysis	Mx	My	Mz	Fx	Fy	Fz
<u>MSH-27</u>	deadload					<u>3370</u>	
Sheet No.	seismic					<u>2402</u>	
<u>20127</u>	thermal					<u>2597</u>	
Type	calc. load (+)					<u>1559</u>	
<u>P. 1</u>	allow. load (+)						
Analysis	calc. load (-)					<u>-2202</u>	
point <u>HQ</u>	allow. load (-)						
Mk. No.	analysis	Mx	My	Mz	Fx	Fy	Fz
<u>MSH-27</u>	deadload					<u>0</u>	<u>0</u>
Sheet No.	seismic					<u>2174</u>	<u>5302</u>
<u>20121</u>	thermal					<u>0</u>	<u>0</u>
Type	calc. load (+)					<u>2174</u>	<u>5302</u>
<u>1/201</u>	allow. load (+)						
Analysis	calc. load (-)					<u>-2174</u>	<u>-5302</u>
point <u>(HP) PP</u>	allow. load (-)						
Mk. No.	analysis	Mx	My	Mz	Fx	Fy	Fz
<u>MSH-213</u>	deadload					<u>18616</u>	
Sheet No.	seismic					<u>5240</u>	
	thermal					<u>-1559</u>	
Type	calc. load (+)					<u>23856</u>	
<u>MSH-213</u>	allow. load (+)						
Analysis	calc. load (-)						
point <u>HQ</u>	allow. load (-)						

Attachment 3
Analysis/Calculation
S96-0130, Rev. 0
Page 1 of 1

SYSTEM
MS

ORIGINATOR
M. J. Smith

DATE 4/2/74

CALCULATION FOR
CR - GB Pipe Supports

REVIEWER
A. J. Jurek

DATE 1/9/75

Note: All loads act on pipe.
Positive directions are shown here.

~~ANALYSIS CALCULATION~~
DOC ID: M-75-000 ATT: 1
REV: 0 SHEET 19 OF 29

Comments

Mk. No.	analysis	Mx	My	Mz	Fx	Fy	Fz
MSH-12	deadload					2549	
Sheet No.	seismic					2	
2-112	thermal					0	
Type	calc. load (+)					2571	
5-112	allow. load (+)						
Analysis	calc. load (-)						
point HQ	allow. load (-)						
Mk. No.	analysis	Mx	My	Mz	Fx	Fy	Fz
MSH-227	deadload				0		
Sheet No.	seismic				10262		
	thermal				0		
Type	calc. load (+)				10262		
11-200-112	allow. load (+)						
Analysis	calc. load (-)				-10262		
point HP	allow. load (-)						
Mk. No.	analysis	Mx	My	Mz	Fx	Fy	Fz
MSH-13	deadload					7208	
Sheet No.	seismic					6796	
	thermal					2323	
Type	calc. load (+)					16327	
1-13-10	allow. load (+)						
Analysis	calc. load (-)						
point 113	allow. load (-)						

Attachment 4
Analysis/Calculation
S96-0130, Rev. 0
Page 1 of 1



Gilbert/Commonwealth
ENGINEERS/CONSULTANTS
CALCULATION

SUBJECT: <u>HY/CRAB</u>				IDENTIFIER: <u>5500-035-MS-13</u>	PAGE: <u>1</u> OF <u>3</u>
POTENTIAL EFFECTS OF OTSG OVERFILL					
REV.	0	1	2	3	PAGE: <u>3</u>
MICROFILMED					
ORIGINATOR	<u>T. BURKE</u>				
DATE	<u>6-26-85</u>				

NUCLEAR SAFETY RELATED

MK. U# W.O. 04-5500-035
MSH-013B


1.0) OBJECTIVE
EVALUATE PIPE SUPPORT FOR EFFECTS FROM OTSG OVERFILL

2.0) DESIGN LOAD (ANALYSIS CR.6)
DWT = +0/- 24911 # THER. = +0/- 2323 #
TOTAL = +0/- 27234 #
USE FAULTED ALLOWABLES.

3.0) COMPONENTS	ACTUAL	≤	ALLOW. **
2" HGR. ATTACH R (203)	27234	≤	44000 #
#5 CLEVIS (161)	27234	≤	41260 #
2" Φ ROD (51)	27234	≤	41260 #
2" TURNBUCKLE	27234	≤	41260 #
2" Φ EYEBOO	27234	≤	41260 #
24" PIPE CLAMP (224)	27234	≤	30450 #

** USE FAULTED ALLOW. FROM POWER PLANT NF CATALOG

4.0) WELD (PART 203)
FY = 27234 #
AW = 14"
W = .875"



$$f = \frac{F_T}{AW} = \frac{1945}{14} = 138.9 \text{ #/in}$$

$$S = \frac{f}{.707W} = \frac{138.9}{.707(.875)} = 272.34 \text{ #}$$

∴ OK

Attachment 5
Analysis/Calculation
S96-0130, Rev. 0
Page 1 of 5



Gilbert/Commonwealth
ENGINEERS/CONSULTANTS
CALCULATION


SUBJECT FPC/CR#3 POTENTIAL EFFECTS OF OTCX OVER				IDENTIFIER S500-035-M3-13	PAGE 2 OF 3 PAGES
REV.	0	1	2	3	
MICROFILMED					
ORIGINATOR	T. BURUE				
DATE	7-8-85				

NUCLEAR SAFETY
RELATED

MK. NO
MSH-0130

W.O. 09-8230-025


5.0) SPRING CONSTANT
W12 = 31



$a = 67.25"$
 $b = 45.5"$
 $L = 112.75"$

PROPERTIES
FOR W12x31
 $E = 29.7 \times 10^6$ PSI
 $I = 230$ IN⁴
 $S = 39.8$ IN³

$$K_1 = \frac{3EI \cdot 2}{a^3 + b^3} = \frac{3(29.7 \times 10^6)(230)(112.75)}{67.25^3 + 45.5^3} = 239,170 \text{ LBS/IN}$$




$L = 120"$
 $A = \pi r^2 = \pi (1)^2 = 3.14$ IN²
 $E = 29.7 \times 10^6$ PSI

$$K_2 = \frac{AE}{L} = \frac{3.14(29.7 \times 10^6)}{120} = 7,129,34 \text{ LBS/IN}$$

COMBINE K'S

$$K = \frac{1}{\frac{1}{K_1} + \frac{1}{K_2}} = \frac{1}{\frac{1}{239,170} + \frac{1}{7,129,34}} = 1.3 \times 10^5 \text{ LBS/IN}$$


Attachment 5
Analysis/Calculation
S96-0130, Rev. 0
Page 2 of 5

 Gilbert/Commonwealth ENGINEERS/CONSULTANTS CALCULATION	SUBJECT EPC/CRS			IDENTIFIER	PAGE
	POTENTIAL EFFECTS OF OTSG OVERFILL			5500-025-MS-13	3 OF 5
	REV.	0	1	2	3
	MICROFILMED				
ORIGINATOR	T. BYRNE				
DATE	7-8-85				

NUCLEAR SAFETY RELATED

Mk. 42 W.O. 04-5500-025
 MSH-013B

6.0) W12x31



F = 27234#
 a = 67.25"
 b = 45.5"
 L = 112.75"

PROPERTIES
 I = 239. IN⁴
 S = 39.6 IN³

$$M_{MAX} = \frac{F \cdot a \cdot b}{L} = \frac{27234(67.25)(45.5)}{112.75} = 739092 \# \cdot IN$$

$$\sigma = \frac{M}{S} = \frac{739092}{39.6} = 18711 \text{ PSI} \leq 21600 \text{ PSI}$$

∴ OK

7.0) CONCLUSION
 SUPPORT OK FOR OTSG OVERFILL.

=====
 Attachment 5
 Analysis/Calculation
 S96-0130, Rev. 0
 Page 3 of 5
 =====



Gilbert/Commonwealth
ENGINEERS/CONSULTANTS
CALCULATION

SUBJECT REF./CR#		IDENTIFIER		PAGE
Power Plant Effects of ...		5520-025-MS-27		1 of 1
REV.	0	1	2	3
MICROFILMED				
ORIGINATOR T. BYRNE				
DATE 6-25-85				

NUCLEAR SAFETY RELATED

MK. U:
MSH-027B

U.O.C. 5520-027

1.0) OBJECTIVE

EVALUATE PIPE SUPPORT FOR EFFECTS FROM DTSG OVERFILL

2.0) DESIGN LOAD (Analysis CG-2)



DWT + THER. = 26081 #

USE FAULTED ALLOWABLES FROM POWER PIPING'S NF CATALOG

3.0) COMPONENTS

	ACT. DR. =	≤	ALLOW. N.
2" HGR. ATTACH. R (203)	26081	≤	44000 #
#5 CLEVIS (161)	26081	≤	41260 #
2" φ ROD (81)	26081	≤	41260 #
2" φ TURNBUCKLE	26081	≤	41260 #
2" φ EVEROD	26081	≤	41260 #
24" φ PIPE CLAMP (223)	26081	≤	38730 #

4.0) WELD
(PART 203)



$$F_1 = 26081 \#$$

$$\Delta W = 14 \#$$

$$f = \frac{F_1}{\Delta W} = 1863 \# / \text{IN}$$

$$U = \frac{f}{.707W} = \frac{1863}{.707(.375)} = 3011 \text{ PSI}$$

5.0) CONCLUSION

SUPPORT OK TO USE NORMAL ALLOWABLES.

Attachment 5
Analysis/Calculation
S96-0130, Rev. 0
Page 4 of 5

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE 39-MSH-27	
	PROJECT	FLORIDA POWER CORPORATION CONDENSER TOWER UNIT #3	NO. 4203 PAGE 1 of 1
SYSTEM Main Steam		ORIGINATOR	
CALCULATION FOR MSH-27		DATE	
RIGID ROD WITH COMPRESSIVE LOAD ROD IS 10 FT LONG d = 2"		REVISOR D. Jones	
		DATE 6-19-74	
		RESULTS	
$P_{CR} = \frac{\pi^2 EI}{L^2}$			
$I = \frac{\pi d^4}{64} = .00069 = .784$			
$P_{CR} = \frac{(3.01)^2 (29,000,000)(.784)}{122^2}$			
$P_{CR} = \frac{(9.596)(29,000,000)(.784)}{14,884} = 15,060.995 \#$			
TENSION			
$S = \frac{P}{A} =$			
$9000 = \frac{P}{3.1416}$			
$P = 28,000 \#$			
USE 2" DIA ROD			

Pipe Stress Analysis Specification

Basic Guideline for the design of piping has been the Code for Pressure Piping B31.1.0-1967 and those portions of Code Case N7. In accordance with this code, Deadweight/Pressure, Thermal, Seismic and any additional transient type of loading must be considered.

The original design methodology used GAI Topical Report No. 1729, "Dynamic Analysis of Vital Piping Systems Subjected to Seismic Motion" as a guideline. A copy of this guideline is attached to this document. For all new or revised piping analyses completed today, Piping Analysis Design Guide MDG-1 is followed as a guideline.

Design Basis Loading Conditions for Main Steam System

Requirement Outline - R.O. 2891 and Enhanced Design Basis Document (EDBD) - Section 6/10

Design Pressure = 1050 psi
Operating Temperature = 590 degrees F

Seismic Input - Reference: Environmental and Seismic Qualification Program Manual (ESQPM) - Section 5

The response spectra used in the analysis was Curve CRW2. This curve is a response spectra that was developed for analysis of piping supported by the Reactor Building Shell at Elevation 123.00. Response spectra, CRW2, was used since a significant portion of the mass of this system, in particular the relief valves, will be directly accelerated by the Reactor Building Shell and it was felt that it was a more conservative response spectra curve than the ground response curve due to the two peaks which occur at 4 to 5 Hz and 14 to 18 Hz.

While this curve is not contained in the ESQPM, it was developed using the same methodology as the original curves. Response curve CRW2 utilized lower margins to envelop the derived response spectra in peak regions of amplifications when compared to the base curve, CR-R2, which is contained in the ESQPM as Figure 2.

Seismic response spectra were developed using the response spectrum method. The inherent conservatism of the response spectrum method is discussed in FSAR Section 5.4.5.1 and demonstrated in FSAR Figure 5-29 and 5-30.

Design Basis Loading Conditions for Main Steam System (cont'd)

As documented in the FSAR, period domain broadening of the response spectra was implemented on the analytical derived curves to establish "design envelope" values. Conservatively, additional acceleration value enveloping was applied in the regions of amplified response. The magnitude of margin between the analytical derived peak acceleration and the "design envelope" value was established at the judgement of the senior engineer tasked with development of the response curves. Specific margin amplification percentage varies from building to building and level to level within a given structure. The implied basis for this variable was to provide additional conservatism to the CR3 design, since typically seismic design conditions did not govern CR3 design.

Based upon review of original design documentation, Curve CRW2 was established specifically for the piping analysis of containment anchored piping in the intermediate building. The period domain broadening of CRW2 is identical to the basic design envelop, CRR2. The acceleration amplitude margin was reduced to a minimum of 5% above the analytical derived acceleration value

Analysis Criteria and Methodology

During the original design of CR3, those piping systems which required computer analyses were analyzed on main frame program - "Pipe Stress Analysis - M003".

Various computer analyses were completed on safety related systems. For the Main Steam system, a deadweight, thermal, seismic, safety valve discharge loading were all computer analyzed. For steam hammer, a simplified, conservative, manual calculation was performed to document this loading condition.

The deadweight/longitudinal pressure analysis was completed with the supports placed at specified locations based on field information. This analysis checked the deadweight/pressure stress and this value was compared to the B31.1 Code allowable of S_h .

Using the same field supplied support information, the thermal analysis was completed to insure that all code allowables were met. The thermal stress value was compared to the B31.1 Code Allowable of S_a . Where required, the Maximum Seismic Anchor Movement Stress was included with the thermal stress.

Analysis Criteria and Methodology (cont'd)

Upon completion of successful deadweight and thermal analyses, the seismic (and transient loadings, if any) analysis was performed to insure code allowables were not exceeded. Snubbers and other necessary restraints were added to the system to control the seismic loadings. The combined primary stresses produced by the MHE (0.10g horizontal ground acceleration) are maintained at less than or equal to 120% of the code allowable stresses from ANSI B31.1.0-1967, plus code case N-7 for duration up to 1% of the operating period.

To obtain the Operating Basis Earthquake (OBE) stress levels and support loadings, the seismic analysis involved choosing the appropriate response spectrum curve and analyzing a two dimensional earthquake (i.e. x-y quake and a y-z quake). The loadings and stresses from this analysis were then doubled to obtain the Safe Shutdown Earthquake (SSE) values. The results of these two separate earthquakes were reviewed and the largest values (stresses and support loads) were documented. The seismic stresses were then combined with the deadweight/pressure stresses and compared a code allowable of 1.2 Sh. This is a very conservative allowable whereas, methodology that is used for a plant in a comparable time frame compares the OBE stress levels to 1.2 Sh and the SSE stress levels to 1.8 Sh (Reference ASME Section III, Subsection NC, 1971 through Winter 1973 Addenda). Upon successful completion of the seismic analysis, the deadweight and thermal analyses were again analyzed if seismic restraints, other than snubbers were added to the system.

It should be noted, piping analysis CR-5 modeled a significant portion of the non-safety, Seismic Class S-III main piping run from the class break to the Turbine connection. This was done for overlap purposes to determine the effects the non-safety piping had on the safety related piping. Regulatory Guide 1.29, Section C.3 states the following:

"Seismic Category I design requirements should extend to the first seismic restraint beyond the defined boundaries. Those portions of structures, systems, or components that form interfaces between Seismic Category and non-Seismic Category I features should be designed to Seismic Category I requirements."

Analysis Criteria and Methodology (cont'd)

The non-safety supports after the class break have been designed accounting for the seismic loadings. Therefore, the intent of Regulatory Guide 1.29 has been met. Various flow transients were required to be analyzed to account for any other type of dynamic loading in nature. For the Main Steam Line those analyses included Relief (Safety) Valve Discharge and Steam Hammer.

Relief Valve Discharge forces were originally documented by manual calculations and were then subsequently backed-up by computer generated results. The stress results of this analysis were combined with the deadweight/pressure and SSE stress levels and compared to 1.2 Sh. A copy of the manual calculations has been included with this document.

Also as a part of the safety valve analyses, the movements of the Main Steam Safety Valves relative to the discharge piping were calculated to assist in the design of the flexonic connections at the valve/piping interface. A copy of the manual calculations documenting these movements is included with this document.

The steam hammer analysis for this piping system was a simplified, conservative, manual calculation that provided the necessary documentation that when valve closure did occur, the system would be capable of withstanding any unbalanced forces that was created by the pressure wave traveling through the pipe. During this calculation, the seismic restraints (snubbers/rigid supports) were considered the main restraints in the piping system. Rod supports were only considered active in the vertical downward direction. A copy of the Steam Hammer Analysis by MZ Lee dated 11/2/73 is attached to this document.

The final phase of the design for the Main Steam piping system was visual observation during functional testing and during Initial Operation. For the Main Steam system one of the most critical loading conditions was the observation of a Turbine Trip. The final results of the steam hammer visual inspection was quite favorable. A few supports did require minor modifications; however, in general the system responded favorably and was capable of withstanding all loadings. A copy of the Report entitled "Main Steam and Feedwater - Steam Hammer Observations and Instrumentation" dated May 31, 1977 covering the observations and instrumentation has been attached to this document.

Qualification Criteria and Methodology on Rod Hangers

The ability of an item of pipe support hardware to resist forces due to static and dynamic events is a function of the physical properties and installation details specified for the hardware.

For static dead weight evaluations, all hardware capable of resisting vertical forces are modeled as active. For analysis of dynamic transients, only hardware which can resist load reversals without undergoing non linear or non elastic deflections is considered effective. In the seismic analyses where the spring constants were inserted into the analysis, the seismic loading was minimal when compared to the deadweight loading. Since the seismic loading never exceeded the deadweight loading, the supports remained within the elastic range and thus would be acceptable for the minimal seismic loading that has occurred. Generalities regarding the applicability of a hardware component are not used to classify the resistance capability of hardware. Specific installation parameters are evaluated to establish the load resistance capability of individual hardware items.

Installation parameters evaluated to establish the resistance capability of hardware include:

- Physical strength of the hardware component to resist tension forces and compression force. Buckling criteria governs this review and is based upon the components length and cross sectional properties. AISC and SSRC (Structural Stability Research Council) criteria for limiting slenderness ratios, kl/r , to 200 governs component members.
- Hardware fit up can not permit a gap movement or unrestrained deflection beyond the industry standard of 1/8" under a load reversal.
- The supported piping system must be of sufficient physical size to provide inherent lateral support to potential compression members which form "pinned" columns.

A rod hanger supported by a spring can would not be effective for dynamic events if the upper working range of the spring can is exceeded and the spring has no downward deflection since the rod bearing plate can uplift from the spring coil resulting in gap movement.

Qualification Criteria and Methodology on Rod Hangers (cont'd)

A larger diameter rod with attachment hardware at the pipe and structural attachment point which preclude gap movement is effective for dynamic loads if the stability slenderness ratio criteria is complied with. Behavior of large diameter rods meeting the stability fit up criteria and rigid struts are identical from a piping analysis standpoint.

MOVEMENTS OF MAIN STEAM
SAFETY VALVES RELATIVE TO DISCHARGE
PIPING

MOVEMENTS OF MAIN STEAM
SAFETY VALVES RELATIVE TO DISCHARGE
PIPING

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT FPC	FILING CODE	
	PROJECT CR UNIT 3	W.O. 4203-27	PAGE 1 OF 2
SYSTEM Notes for Calculations of Safety	ORIGINATOR A. ECKENRGT		
CALCULATION FOR Valve Movements	DATE 12/5/73		
	REVIEWER M. Z. LOP		
	DATE 12/5/73		
	RESULTS		
<p>① Safety Valves may be closed or open. Therefore both conditions are considered.</p> <p>② Data from the seismic analysis is the sum of X and Y or Y and Z movement.</p> <p>③ Seismic movement may be positive or negative. Therefore both conditions are considered.</p> <p>④ Axial and lateral movement are calculated separately so that the worst condition is found in each case. For example a positive seismic value may be used to calculate axial movement while the negative value is used to calculate lateral movement.</p> <p>⑤ The largest possible lateral movement in the XY-plane not including stack movement is calculated. The smallest</p>			

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 2 OF 2
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
<p><i>possible is also calculated. This figure is used to calculate the maximum lateral movement off the XY plane including stack movement.</i></p>	REVIEWER		
	DATE		
	RESULTS		

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT FPC	FILING CODE	
	PROJECT CR UNIT 3	W.O. 4203-027	PAGE 1 of 6
SYSTEM CR-3	ORIGINATOR A. ECKENROTH		DATE 11/30/73
CALCULATION FOR Movement on Safety Valve MSV-46F		REVIEWER M. Z. Lee	DATE 12/5/73
<p>Thermal (original run) movements @ Pt HO-51</p> <p> $\Delta X = +.3043"$ $\Delta Y = +.1754"$ $\Delta Z = +.8246"$ </p> <p> $\theta = 53^\circ$ Facing East </p>			RESULTS
<p>Axial Mov't = $(0.1754) \sin \theta + (0.3043) \cos \theta$ $0.1401 + 0.1831 =$ $+ 0.3232"$</p>			
<p>Lateral Mov't in XY Plane = $(0.1754) \cos \theta - (0.3043) \sin \theta$ $.1056 - .2430 =$ -0.1374</p>			
<p>Lateral Mov't off XY Plane ($\Delta Z = 0.8246"$)</p>			
<p>Absolute Lateral Mov't = $\sqrt{(0.8246)^2 + (\text{Lateral Mov't in XY})^2}$ $\sqrt{(0.8246)^2 + (0.1374)^2} =$ $0.8359"$</p>			

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT

PROJECT

FILING CODE

W.O.

PAGE

2 of 6

SYSTEM

ORIGINATOR

CALCULATION FOR

DATE


REVIEWER

M. Z. Lee

DATE 12/5/73

RESULTS

Safety Valve Loads (Case No. 2) mov't @ Pt. HO-51



$$\begin{aligned} \text{Axial Mov't} &= (-0.0046) \sin \theta + (-0.0409) \cos \theta \\ &= (-0.0037) + (-0.0246) = \\ &= -0.0283" \text{ or } 0" \end{aligned}$$

$$\begin{aligned} \text{Lateral Mov't in XY Plane} &= \\ &= (-0.0046) \cos \theta - (-0.0409) \sin \theta \\ &= (-0.0028) - (-0.0327) = \\ &= +0.0299" \text{ or } 0" \end{aligned}$$

Lateral Mov't off XY Plane ($\Delta Z = +0.0614"$)

$$\begin{aligned} \text{Absolute Lateral Mov't} &= \sqrt{(0.0614)^2 + (\text{Lateral Mov't in XY})^2} \\ &= \sqrt{(0.0614)^2 + (0.0299)^2} = \\ &= 0.0683" \text{ or } 0" \end{aligned}$$

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT

PROJECT

FILING CODE

W.O.

PAGE

3 of 6

SYSTEM

ORIGINATOR

CALCULATION FOR

DATE

REVIEWER

M. Z. Lee

DATE 12/5/72


RESULTS

Seismic Mov't @ Pt MP-48

$$\Delta X = \pm 0.0078''$$

$$\Delta Y = \pm 0.0037''$$

$$\Delta Z = \pm 0.0278''$$



Facing East



$$\begin{aligned} \text{Axial Mov't} &= (.0037) \sin \theta + (.0078) \cos \theta \\ &= .0030 + .0047 = \\ &= .0077'' \end{aligned}$$

$$\begin{aligned} \text{Lateral Mov't in XY Plane} &= \\ &= (\pm .0037) \cos \theta - (\pm .0078) \sin \theta \\ &= (\pm .0022) - (\pm .0062) = \\ &= \pm .0040'' \end{aligned}$$

Lateral Mov't off XY Plane ($\Delta Z = \pm .0278''$)

$$\begin{aligned} \text{Absolute Lateral Mov't} &= \sqrt{(.0278)^2 + (\text{Lateral Mov't in XY})^2} \\ &= \sqrt{(.0278)^2 + (.0040)^2} = \end{aligned}$$

0.0280

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE
	PROJECT	
SYSTEM	W.O.	PAGE 4 of 6
CALCULATION FOR	ORIGINATOR	DATE
	REVIEWER M. Z. Lee	DATE 12/5/73
<u>Stack Mov't due to Thermal Expansion:</u>		RESULTS
ELEV. of anchor in roof = 149'-0"		
ELEV. of safety valve = 128'-3"		
Length of stack = 20'-9"		
* Expansion of A106-GR.B steel @ 500°F = .0362 in./ft. of pipe		
20.75 ft x .0362 in/ft = 0.7512 in		
 <p>$\theta = 53^\circ$ Facing East</p>	 <p>axial lateral</p>	
Axial Mov't = $(-0.7512) \sin \theta =$		- .5999" (compressive)
Lateral Mov't in XY Plane = $(-0.7512) \cos \theta =$		- .4521"
* Temperature is found in pipe specifications (page 65) for Safety Valve Relief Lines.		

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE
	PROJECT	
SYSTEM	ORIGINATOR	W.O. PAGE 5 of 6
CALCULATION FOR	DATE	REVIEWER M. Z Lee
		DATE 12/5/73
Total Mov't @ Pt. HO-51 =		RESULTS
Thermal + Safety Valve + Seismic Mov't		
Axial Mov't = (+.3232) + (-.0283) + (+.0077) =		+ .3026"
		OR
When Safety Valve is Closed = (+.3232) + (+.0077) =		+ .3309"
		(compressive)
Lateral Mov't in XY Plane =		
(-.1374) + (+.0299) + (+.0040) =		- .1035"
		OR
When Safety Valve is Closed = (-.1374) + (-.0040) =		- .1414"
Mov't in Z Direction =		
(+.8246) + (+.0614) + (+.0278) =		+ .9138"
		OR
When Safety Valve is Closed = (+.8246) + (+.0278) =		+ .8524"
Lateral Mov't off XY Plane =		
$\sqrt{(.9138)^2 + (.1414)^2} =$.9247"
<u>Total Movement</u>		
Axial Mov't = (.3309) + (.5999) =		.9308"
Lateral Mov't in XY Plane = (-.4521) - (-.1035) =		-.3486"
Lateral Mov't off XY Plane =		
$\sqrt{(.9138)^2 + (.3486)^2} =$.9780"

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE
	PROJECT	

W.O. PAGE
6 of 6

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER

M. Z. Lee
DATE 12/5/73

MSV-46F Summary
MSEJ-4

RESULTS

DIRECTION	WITHOUT STACK MOVEMENT	WITH STACK MOVEMENT	
AXIAL	.3309"	.9308"	Compression
X-Y	-.1414"	-.3486"	
Z	+.9138"	+.9138"	
LATERAL	.9247"	.9780"	

Design Conditions

Axial = .85" Compression max

Lateral = .81"

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT FPC	FILING CODE	
	PROJECT CR UNIT 3	W.O.	PAGE 1 of 6
SYSTEM CR-3	ORIGINATOR A. ECKENROTH		DATE 12/6/73
CALCULATION FOR Movement of Safety Valve MSV-42		REVIEWER M. Z. Lee	DATE 12/08/73
Thermal (original run) movements @ Pt HP-58			RESULTS
$\Delta X = -.0328"$ $\Delta Y = +.1742"$ $\Delta Z = +.9852"$			
$\text{Axial mov't} = (+.1742) \cdot \sin \theta - (-.0328) \cos \theta$ $(+.1391) - (-.0197) =$ $+.1588"$			
$\text{Lateral Mov't in XY Plane} =$ $(+.1742) \cos \theta + (-.0328) \sin \theta$ $(+.1048) + (-.0262) =$ $+.0786"$			
$\text{Lateral Mov't off XY Plane } (\Delta Z = +.9852")$			
$\text{Absolute Lateral Mov't} = \sqrt{(.9852)^2 + (\text{Lat. Mov't in XY})^2}$ $\sqrt{(.9852)^2 + (.0786)^2} =$ $.9883"$			

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 2 of 6
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
Safety Valve Loads (case No. 2) mov't a Pt. HP-58			
$AX = -.0138"$ $AY = -.0057"$ $AZ = +.0197"$ $\theta = 53^\circ$ Facing East			
Axial Mov't = $(-.0057) \sin \theta - (-.0138) \cos \theta =$ $(-.0046) - (-.0083) =$ $+ .0037" \text{ or } 0"$			
Lateral Mov't in XY Plane = $(-.0057) \cos \theta + (-.0138) \sin \theta =$ $(-.0034) + (-.0110) =$ $-.0144" \text{ or } 0"$			
Lateral Mov't off XY Plane ($AZ = +.0197$)			
Absolute Lateral Mov't = $\sqrt{(.0197)^2 + (\text{Lateral Mov't in XY})^2}$ $= \sqrt{(.0197)^2 + (.0144)^2} =$ $.0244"$			

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 3 of 6
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
		DATE	
Seismic Mov't @ Pt. MR-55 $A_x = \pm .0028"$ $A_y = \pm .0013"$ $A_z = \pm .0291"$ $\theta = 53^\circ$ Facing East			
$\text{Axial Mov't} = (.0013) \sin \theta - (.0028) \cos \theta =$ $(\pm .0010) - (\pm .0017) =$ $\pm .0027"$		RESULTS	
$\text{Lateral Mov't in XY Plane} =$ $(\pm .0013) \cos \theta + (\pm .0028) \sin \theta =$ $(\pm .0008) + (\pm .0022) =$ $\pm .0030"$			
$\text{Lateral Mov't off XY Plane} = (A_z = \pm .0291")$			
$\text{Absolute Lateral Mov't} = \sqrt{(.0291)^2 + (\text{Lateral Mov't in XY})^2}$ $\sqrt{(.0291)^2 + (.0030)^2} =$ $.0293"$			

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 4 of 6

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE

Stack Mov't due to Thermal Expansion:



ELEV of anchor in roof = 149'-0"

ELEV of safety valve = 128'-3 1/8"

Length of stack = 20'-8 7/8"

* Expansion of A106-GRB steel @ 500°F =
.0326 in/ft. of pipe

20.7396 ft x .0362 in/ft = .7508 in.



Axial Mov't = $(-.7508) \sin \theta =$ -.5996"
(compressive)

Lateral Mov't in XY Plane = $(-.7508) \cos \theta =$ -.4518"


* Temperature is found in pipe specifications (page 65) for Safety Valve Relief Lines.

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 5 OF 6
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
Total Mov't @ Pt. HP-58 =		RESULTS	
Thermal + Safety Valve + Seismic Mov't			
Axial Mov't = (+.1588) + (+.0037) + (+.0027) =		+.1652"	
When Safety Valve is Closed = (+.1588) + (+.0027) =		+.1615" (compressures)	
Lateral Mov't in XY Plane =			
(+.0786) + (-.0144) + (-.0030) =		+.0612"	
When Safety Valve is Closed = (+.0786) + (+.0030) =		+.0816"	
Mov't in Z Direction =			
(+.9852) + (+.0197) + (+.0291) =		+1.0340"	
When Safety Valve is Closed = (+.9852) + (+.0291) =		+1.0143"	
Lateral Mov't off XY Plane =			
$\sqrt{(1.0340)^2 + (.0816)^2} =$		1.0372"	
<u>Total Movement</u>			
Axial Mov't = (.5996) + (.1652) =		.7648"	
Lateral Mov't in XY Plane = (-.4518) - (+.0816) =		-.5334"	
Lateral Mov't off XY Plane =			
$\sqrt{(1.0340)^2 + (.5334)^2} =$		1.1635"	

FILING
CODE


GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.		CLIENT	FILING CODE	
		PROJECT	W.O.	PAGE 6 of 6
SYSTEM			ORIGINATOR	
CALCULATION FOR			DATE	
MSV-42F Summary MSEJ-3			REVIEWER	
			DATE	
			RESULTS	
DIRECTION	WITHOUT STACK MOVEMENT	WITH STACK MOVEMENT		
AXIAL	.1652"	.7648"	Compression	
XY	+ .0816"	- .5334"		
Z	+1.0340"	+1.0340"		
LATERAL	1.0372"	1.1635"		
Design Conditions				
Axial = 0.84"				
Lateral = 0.73"				

FILING

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT FPC	FILING CODE	
	PROJECT CR UNIT 3	W.D. 4203027	PAGE 1 OF 6
SYSTEM CR-4	ORIGINATOR A. ECKENROTH		DATE 12/5/73
CALCULATION FOR Movement on Safety Valve MSV-40 F		REVIEWER M. Z. Lee	DATE 10/5/73
Thermal (Revision #1) mov't @ Pt. DH-572			RESULTS
$\Delta X = +.0848"$ $\Delta Y = +.1747"$ $\Delta Z = +1.2388"$	 <p style="text-align: center;">$\theta = 53^\circ$ Facing East</p>		
Axial Mov't = $(+.1747) \sin \theta - (+.0848) \cos \theta =$ $(+.1395) - (+.0510) =$ $+.0885"$			
Lateral Mov't in XY Plane = $(+.1747) \cos \theta + (+.0848) \sin \theta =$ $(+.1051) + (+.0677) =$ $+.1728"$			
Lateral Mov't off XY Plane Absolute Lateral Mov't = $\sqrt{(1.2388)^2 + (\text{Lateral Mov't in XY})^2}$ $\sqrt{(1.2388)^2 + (.1728)^2} =$ $1.2508"$			

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE

Safety Valve Loads (case #3) mov't @ Pt DH-572



$\Delta X = +.0608"$
 $\Delta Y = -.0022"$
 $\Delta Z = +.0127"$

$\theta = 53^\circ$
Facing East

Axial Mov't = $(-.0022) \sin \theta - (+.0608) \cos \theta =$
 $(-.0018) - (+.0366) =$
 $-.0384" \text{ or } 0"$

Lateral Mov't in XY Plane =
 $(-.0022) \cos \theta + (+.0608) \sin \theta =$
 $(-.0013) + (+.0486) =$
 $+.0473" \text{ or } 0"$

Lateral Mov't off XY Plane

Absolute Lateral Mov't =

$$\sqrt{(.0127)^2 + (\text{Lateral Mov't in XY})^2}$$

$$\sqrt{(.0127)^2 + (.0473)^2} =$$

$$.0490" \text{ or } 0"$$

RESULTS

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT
PROJECT

FILING CODE

W.D. PAGE
3 OF 6

SYSTEM

ORIGINATOR

CALCULATION FOR

DATE


REVIEWER

DATE


RESULTS

Seismic Mov't @ Pt. MV-57

$$\begin{aligned}\Delta X &= \pm .0092'' \\ \Delta Y &= \pm .0158'' \\ \Delta Z &= \pm .0123''\end{aligned}$$



Facing East



$$\begin{aligned}\text{Axial Mov't} &= (+.0158)\text{Sin } \theta - (+.0092)\text{Cos } \theta \\ &= (+.0126) - (+.0055) = \\ &= +.0071''\end{aligned}$$

$$\begin{aligned}\text{Lateral Mov't in XY Plane} &= \\ &= (\pm .0158)\text{Cos } \theta + (\pm .0092)\text{Sin } \theta \\ &= (\pm .0095) + (\pm .0073) = \\ &= \pm .0168''\end{aligned}$$

Lateral Mov't off XY Plane =

$$\sqrt{(.0123)^2 + (\text{Lateral Mov't in XY})^2}$$

$$\sqrt{(.0123)^2 + (.0168)^2} =$$

$$.0208''$$

FILING
CODE

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE

Stack Mov't due to Thermal Expansion -


ELEV. of anchor in roof = 149'-0"

ELEV. of safety valve = 128'-0 5/16"

Length of stack = 20'-11 1/16"

* Expansion of A106 Gr. B steel @ 500°F =
.0362 in / ft. of pipe

20.9740 ft x .0362 in/ft. = .7593"



Axial Mov't = (-.7593) Sin θ = -0.6064"

(compressive)

Lateral Mov't in XY Plane =
(-.7593) Cos θ = -0.4570"

* Temperature is found in pipe specifications
(page 65) for Safety Valve Relief Lines.

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.D.	PAGE 5 of 6
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
Total Mov't @ Pt. DH-572 =			RESULTS
Thermal + Safety Valve + Seismic Mov't			
Axial Mov't = (+.0885) + (-.0384) + (+.0071) =			+ .0572"
When Safety Valve is closed = (+.0885) + (+.0071) =			OR + .0956" (compressive)
Lateral Mov't in XY Plane =			
(+.1728) + (+.0473) + (+.0168) =			+ .2369"
When Safety Valve is closed = (+.1728) + (-.0168) =			OR + .1560"
Mov't in Z Direction =			
(+1.2388) + (+.0127) + (+.0123) =			+ 1.2638"
When Safety Valve is closed = (+1.2388) + (+.0123) =			OR + 1.2511"
Lateral Mov't off XY Plane =			
$\sqrt{(1.2638)^2 + (.2369)^2}$ =			1.2858"
Total Movement			
Axial Mov't = (.0956) + (.6064) =			.7020"
Lateral Mov't in XY Plane = (-.4570) - (+.1560) =			-.6130"
Lateral Mov't off XY Plane =			
$\sqrt{(1.2638)^2 + (.6130)^2}$ =			.9864"

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 6 of 6


SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE
	RESULTS

MSV-40 F Summary
MSEJ-9


DIRECTION	WITHOUT STACK MOVEMENTS	WITH STACK MOVEMENTS
AXIAL	.0956"	.7020"
XY	+ .2369"	- .6130"
Z	+1.2638"	+1.2638"
LATERAL	1.2858"	.9864"

Design Conditions
Axial = .84"
Lateral = 1.14"

Florida Power Corp.	MADE 12/4/73	GILBERT ASSOCIATES, INC.	
	CHK'D.	ENGINEERS AND CONSULTANTS	
Crystal River #3	BO. CP.	READING, PENNA.	
MSEJ-7 Flexonic Joint on MSV-38	CF. DFM.	4007-27	
Movements Calculation	ENG. M. Z. Lee	WORK	SIZE DRAWING REV
	REV. CH. APP. DATE		




PLAN



Section A-A

- Notes:
1. X-Y-Z matches with Iso.
 2. a = axial movement
l = lateral movement (⊥ axis of Flexonic Jt)
Lr = lateral movement in vertical plane
Lh = lateral movement in horizontal plane



Section B-B

$$\vec{H} = \Delta Z \vec{e} + \Delta X \vec{x}$$

$$|\vec{H}| = \sqrt{(\Delta Z)^2 + (\Delta X)^2}$$

$$\varphi = \tan^{-1} \frac{\Delta X}{\Delta Z} + 35^\circ$$

$$H_s = |\vec{H}| \cdot \sin \varphi$$

$$L_h = |\vec{H}| \cdot \cos \varphi$$

$$L_r = H_s \cdot \sin \theta + L_h \cdot \cos \theta$$

$$|\vec{L}| = \sqrt{L_r^2 + L_h^2}$$

$$a = \vec{L} \cdot \sin \theta - H_s \cdot \cos \theta$$

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT FPC	FILING CODE	
	PROJECT CR - UNIT 3	W.D.	PAGE 1 OF 9
SYSTEM CR-4	ORIGINATOR A. ECKENROTH		DATE 12/5/73
CALCULATION FOR Movement of Safety Valve MSV-38		REVIEWER M. Z. Lee	DATE 12/6/73
Thermal (Revision #1) Mov't @ Pt. FH-662			RESULTS
$\Delta X = -.1676''$ $\Delta Y = +.1735''$ $\Delta Z = +.8552''$			
$\vec{H} = \vec{\Delta Z} + \vec{\Delta X}$			
$ \underline{H} = \sqrt{(.8552)^2 + (.1676)^2} = .8715''$			
$\varphi = \tan^{-1} \frac{\Delta X}{\Delta Z} + 35^\circ =$			
$\tan^{-1} (-.19598) + 35^\circ = -11^\circ + 35^\circ = 24^\circ$			
$\underline{HS} = \underline{H} \cdot \sin \varphi = (.8715) \sin \varphi = .3545''$			
$\underline{a} = \vec{y} \sin \theta - HS \cos \theta$			
$= (+.1735) \sin \theta - (.3545) \cos \theta =$ $(+.1386) - (+.2133) = -.0747''$			
Axial Mov't = $-.0747''$			

FILING
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 2 OF 9
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
$L_h = H \cdot \cos \theta$ $= (.8715) \cos \theta = +.7962$		RESULTS	
$L_v = HS \cdot \sin \theta + \vec{a}_y \cos \theta =$ $(+.3545) \sin \theta + (+.1735) \cos \theta =$ $.2831 + .1044 = .3875$			
$L = \sqrt{L_v^2 + L_h^2} =$ $\sqrt{(.3875)^2 + (.7962)^2} = .8855$			
Lateral Mov't = .8855"			

FILING
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.D.	PAGE 3 OF 9
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
			DATE
Safety Valve (Case #3) Mov't @ Pt. FH-662			RESULTS
$\Delta X = +.0286"$ $\Delta Y = +.0122"$ $\Delta Z = +.0046"$			
$\vec{H} = \vec{\Delta Z} + \vec{\Delta X}$			
$ H = \sqrt{(+.0046)^2 + (.0286)^2} = .0290'$			
$\phi = \tan^{-1} \frac{\Delta X}{\Delta Z} + 35^\circ =$			
$\tan^{-1} (+6.2174) + 35^\circ =$			
$8.1^\circ + 35^\circ = 116^\circ$			
$HS = H \cdot \sin \phi =$			
$(.0290) \sin \phi = +.0261"$			
$a = \vec{\Delta Y} \sin \theta - HS \cos \theta$			
$= (+.0122) \sin \theta - (+.0261) \cos \theta =$			
$(+.0097) - (+.0157) = -.0060"$			
Axial Mov't = $-.0060"$			

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 4 of 9
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
$l_h = H \cdot \cos \phi$ $= (.0290) \cdot \cos \phi = -.0127"$ $l_v = HS \cdot \sin \theta + \vec{AY} \cos \theta =$ $(+.0261) \sin \theta + (+.0122) \cos \theta =$ $(+.0208) + (+.0073) = +.0281"$ $ H = \sqrt{l_v^2 + l_h^2} =$ $\sqrt{(.0281)^2 + (.0127)^2} = .0308"$ Lateral Mov't = .0308"	DATE		
	RESULTS		

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 5 OF 9

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE

Seismic Mov't @ Pt MZ-66

$$\Delta X = \pm .0009"$$

$$\Delta Y = \pm .0116"$$

$$\Delta Z = \pm .0088"$$

$$\vec{H} = \vec{\Delta Z} + \vec{\Delta X}$$

$$|H| = \sqrt{(.0088)^2 + (.0009)^2} = .0092"$$

$$\phi = \tan^{-1} \frac{\Delta X}{\Delta Z} + 35^\circ =$$

$$\tan^{-1} (\pm .1023) + 35^\circ =$$

$$\pm 6^\circ + 35^\circ = 29^\circ \text{ or } 42^\circ$$

$$HS = |H| \sin \phi =$$

$$(.0092) \sin \phi = .0045 \text{ or } .0062$$

$$a = \vec{y} \sin \theta - HS \cos \theta =$$

$$(+.0116) \sin \theta - (+.0045) \cos \theta =$$

$$(+.0093) - (+.0027) = +.0066"$$

Axial Mov't = $\pm .0066"$

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.D.	PAGE 6 of 9
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
	RESULTS		

$$l_h = |H| \cdot \cos \theta =$$

$$(0.0092) \cos \theta = 0.0080''$$

$$l_v = H_S \sin \theta + \overline{A_y} \cos \theta =$$

$$(+0.0062) \sin \theta + (+0.0116) \cos \theta =$$

$$(+0.0050) + (+0.0070) = 0.0120''$$

$$|H| = \sqrt{l_v^2 + l_h^2} =$$

$$\sqrt{(0.0120)^2 + (0.0080)^2} = 0.0144''$$

$$\text{Lateral Mov't} = 0.0144''$$

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 7 of 9

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE

Mov't A on stack

ELEV of anchor in roof = 149'-0"



ELEV of safety valve = 128'-3"

Length of stack = 20'-9"

Expansion of A106-GR.B. steel @ 500°F =

.0362 in / ft. of pipe

20.75 ft x .0362 in / ft = .7512 in



$\theta = 53^\circ$

axial

lateral

axial

lateral

axial

lateral

axial

lateral

axial

lateral

axial

lateral

axial

lateral

axial

lateral

axial

lateral




axial Mov't = (.7512) Sin θ = -.5999"

(in) Lateral Mov't = (-.7512) Cos θ = -.4521"

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 8 of 9
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
			DATE
<u>Total Mov't @ Pt. FH-662</u>			RESULTS
Thermal + Safety Valve + Seismic Mov't			
Axial Mov't = $(-.0747) + (-.0060) + (-.0066) =$			$-.0873''$
When Safety Valve is closed = $(-.0747) + (+.0066) =$			$-.0681''$ (elongation)
Lateral Mov't $lv =$			
$(+.3875) + (+.0281) + (+.0120) =$			$+.4276''$
When Safety Valve is closed = $(+.3875) + (+.0120) =$			$+.3995''$
Lateral Mov't $lh =$			
$(+.7962) + (-.0127) + (+.0080) =$			$+.7915''$
When Safety Valve is closed = $(+.7962) + (+.0080) =$			$+.8042''$
Absolute Lateral Mov't =			
$\sqrt{(.4276)^2 + (.8042)^2} =$			$.9108''$
<u>Total Movement</u>			
Axial Mov't = $(+.5999) + (-.0873) =$			$+.5126''$ $+.6872''$
Lateral Mov't $lv = (-.4521) - (+.4276) =$			$-.8797''$
Absolute Lateral Mov't =			
$\sqrt{(.8797)^2 + (.8042)^2} =$			$1.1909''$


GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.		CLIENT	FILING CODE	
		PROJECT	W.O.	PAGE 9 of 9
SYSTEM			ORIGINATOR	
CALCULATION FOR			DATE	
			REVIEWER	
			DATE	
MSV-38 Summary MSEJ-7			RESULTS	
DIRECTION	WITHOUT STACK MOVEMENT	WITH STACK MOVEMENT		
AXIAL	- .0873"	+ .5126 (COMPRESSION) - .6872"	Elongation (WITHOUT STACK MOV)	
lv	+ .4276"	- .8797"		
lh	+ .8042"	+ .8042"		
LATERAL	.9108"	1.1909"		
<p>Design Conditions</p> <p>Axial = 0.84" Compression</p> <p>Lateral = 0.77"</p>				

Florida Power Corp	MADE 12/6/73	GILBERT ASSOCIATES, INC.		
	CHK'D.	ENGINEERS AND CONSULTANTS		
Crystal River #3	DES. CP.	READING, PENNA.		
MSEJ-6 Flexible Joint on MSV-34	CF. BPM.	4203-007		
Movement Calculation	ENG. M. Z. Lee	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE			



Plan

Section A-A (Vertical Plane)



Section B-B

$$\vec{H} = \Delta X + \Delta Z$$

$$|H| = \sqrt{(\Delta Z)^2 + (\Delta X)^2}$$

$$\varphi = \tan^{-1}\left(\frac{\Delta Z}{\Delta X}\right) + 90^\circ$$

$$H_S = |H| \cdot \sin \varphi$$

$$L_h = |H| \cdot \cos \varphi$$

$$L_v = \Delta y \cos \theta - H_S \cdot \sin \theta$$

$$|L| = \sqrt{L_v^2 + L_h^2}$$

$$\alpha = \gamma \cdot \sin \theta + H_S \cos \theta$$

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT FPC	FILING CODE	
	PROJECT CR UNIT 3	W.O.	PAGE 1 of 9
SYSTEM CR-4	ORIGINATOR A. ECKENROTH		DATE 12/16/73
CALCULATION FOR Movement of Safety Valve MSV-34		REVIEWER H.Z. Lee	DATE 10/08/73
Thermal (Revision #1) Mov't @ Pt GH-722			RESULTS
$\Delta X = -.0458"$ $\Delta Y = +.1745"$ $\Delta Z = +.7156"$			
$\vec{H} = \vec{\Delta X} + \vec{\Delta Z}$			
$ \vec{H} = \sqrt{(.0458)^2 + (.7156)^2} = .7171"$			
$\phi = \tan^{-1}\left(\frac{\Delta Z}{\Delta X}\right) + 80^\circ =$ $\tan^{-1}(-15.6245) + 80^\circ =$ $-94^\circ + 80^\circ = 174^\circ$			
$HS = \vec{H} \sin \phi =$ $(.7171) \sin 6 =$			
$(.1394) \sin \theta + HS \cos \theta =$ $(+.1394) + (+.0451) = +.1845"$			
Axial Mov't = +.1845"			

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT

PROJECT

FILING CODE

W.O.

PAGE

2 of 9

SYSTEM

ORIGINATOR

CALCULATION FOR

DATE

REVIEWER

DATE

RESULTS

$$h = |H| \cdot \cos \phi$$

$$= (.7171) \cos 6 = -.7132$$

$$v = \Delta y \cos \theta - HS \sin \theta =$$

$$(+.1745) \cos \theta - (+.0750) \sin \theta =$$

$$(+.1050) - (+.0599) =$$

$$+.0451''$$

$$|H| = \sqrt{v^2 + h^2} =$$

$$\sqrt{(.0451)^2 + (.7132)^2} = .7146''$$

$$\text{Lateral Mov't} = .7146''$$

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT
PROJECT

FILING CODE

W.D. PAGE
3 of 9

SYSTEM

ORIGINATOR

CALCULATION FOR

DATE

REVIEWER

DATE

RESULTS

Safety Valve (case #3) Mov't @ Pt. GH-722

$$\Delta X = +.0167''$$

$$\Delta Y = -.0160''$$

$$\Delta Z = -.0007''$$

$$\vec{H} = \vec{\Delta X} + \vec{\Delta Z}$$

$$|H| = \sqrt{(.0167)^2 + (.0007)^2} = .0167''$$

$$\phi = \tan^{-1} \left(\frac{\Delta Z}{\Delta X} \right) + 80^\circ =$$

$$\tan^{-1} (-.0419) + 80^\circ =$$

$$-2^\circ + 80^\circ = 78^\circ$$

$$HS = |H| \sin \phi =$$

$$(.0167) \sin 6 = +.0163''$$

$$a = \vec{y} \cdot \sin \theta + HS \cos \theta =$$

$$(-.0160) \sin \theta + (+.0163) \cos \theta =$$

$$(-.0128) + (+.0098) =$$

$$-.0030''$$

$$\text{Axial Mov't} = -.0030''$$

FILING
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 4 of 9
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
$l_h = H \cdot \cos \theta =$ $(.0167) \cos \theta = +.0035"$			RESULTS
$l_v = Ay \cos \theta - H.S \cdot \sin \theta =$ $(-.0160) \cos \theta - (+.0163) \sin \theta =$ $(-.0096) - (+.0130) =$ $-.0226"$			
$ l = \sqrt{l_v^2 + l_h^2} =$ $\sqrt{(-.0226)^2 + (.0035)^2} = .0229"$			
Lateral Mov't = .0229"			

FILING
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 5 of 9
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
Seismic Mov't @ Pt. NB-72			RESULTS
$\Delta X = \pm .0028"$			
$\Delta Y = \pm .0085"$			
$\Delta Z = \pm .0085"$			
$\vec{H} = \vec{\Delta X} + \vec{\Delta Z}$			
$ \vec{H} = \sqrt{(.0028)^2 + (.0085)^2} = .0089"$			
$\theta = \tan^{-1} \left(\frac{\Delta Z}{\Delta X} \right) + 80^\circ =$			
$\tan^{-1} (\pm 3.0357) + 80^\circ =$			
$\pm 72^\circ + 80^\circ = 8^\circ \text{ or } 152^\circ$			
$HS = \vec{H} \cdot \sin \theta =$			
$(.0089) \cdot \sin \theta = +.0012" \text{ or } +.0042"$			
$a = \vec{y} \sin \theta + HS \cos \theta =$			
$(.0085) \sin \theta + (+.0042) \cos \theta =$			
$(+.0068) + (+.0025) = +.0093"$			
Axial Mov't = +.0093"			

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT _____	FILING CODE _____	
	PROJECT _____	W.O. _____	PAGE 6 of 9
SYSTEM _____	ORIGINATOR _____		
CALCULATION FOR _____	DATE _____		
	REVIEWER _____		
	DATE _____		
	RESULTS _____		

$$h = |H| \cdot \cos \theta =$$

$$(.0089) \cos \theta = +.0088" \text{ or } -.0079"$$

$$lv = 4Y \cos \theta - HS \sin \theta =$$

$$(\pm .0085) \cos \theta - (+.0042) \sin \theta =$$

$$(\pm .0051) - (+.0034) =$$

$$-.0085" \text{ or } +.0017"$$

$$|H| = \sqrt{lv^2 + h^2} =$$

$$\sqrt{(.0085)^2 + (.0088)^2} =$$



$$.0122"$$

Lateral Mov t = .0122"

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 7 of 9

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE
	RESULTS

Mov't on stack
 ELEV of anchor in roof = 149'-0"
 ELEV of safety valve = 128'-3"
 Length of stack = 20'-9"
 Expansion of A106-GR B steel @ 500°F =
 .0362 in/ft. of pipe
 20.75 ft x .0362 in/ft = .7512 in



Axial Mov't = $(-.7512) \sin \theta =$ -.5999"
(compression)

(Lr) Lateral Mov't = $(-.7512) \cos \theta =$ -.4521"

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 8 OF 9
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
			DATE
Total Mov't @ Pt GH-722			RESULTS
Thermal + Safety Valve + Seismic Mov't			
Axial Mov't = (+.1845) + (-.0030) + (+.0093) =			+ .1908"
When Safety Valve is closed = (+.1845) + (+.0093) =			+ .1938" (compression)
Lateral Mov't Δv =			
(+.0451) + (-.0226) + (-.0085) =			+ .0140"
When Safety Valve is closed (+.0451) + (+.0017) =			+ .0468"
Lateral Mov't Δh =			
(-.7132) + (+.0035) + (+.0088) =			- .7007"
When Safety Valve is closed (-.7132) + (-.0079) =			- .7211"
Absolute Lateral Mov't $ \Delta $ =			
$\sqrt{(.0468)^2 + (.7211)^2}$ =			.7226"
<u>Total Movement</u>			
Axial Mov't = (.5999) + (.1938) =			.7937"
Lateral Mov't Δv = (-.4521) - (+.0468) =			-.4989"
Absolute Lateral Mov't $ \Delta $ =			
$\sqrt{(.4989)^2 + (.7211)^2}$ =			.8769"

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.		CLIENT	FILING CODE	
		PROJECT	W.O.	PAGE 9 of 9
SYSTEM			ORIGINATOR	
CALCULATION FOR			DATE	
MSV-34 Summary MSEJ-6			REVIEWER	
			DATE	
RESULTS				
DIRECTION	WITHOUT STACK MOVEMENT	WITH STACK MOVEMENT		
AXIAL	.1938"	.7937"	compression	
IN	+ .0468"	- .4989"		
th	- .7211"	- .7211"		
LATERAL	.7226"	.8769"		
Design Conditions				
Axial = 0.84" compression				
Lateral = 0.66"				

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT FPC	FILING CODE	
	PROJECT CR UNIT 3	W.O. 423-027	PAGE 1 OF 6
SYSTEM CR-5	ORIGINATOR A. ECKENROTH		DATE 12/3/73
CALCULATION FOR Movement on Safety Valve MSV-48F		REVIEWER M. Z. Lee	DATE 12/5/73
Thermal (Revision #1) movements @ Pt. EH-652			RESULTS
$\Delta X = +.1907''$ $\Delta Y = +.1749''$ $\Delta Z = +1.1043''$ <p style="text-align: center;">$\theta = 53^\circ$ Facing East</p>			
<p>Axial Mov't = $(+.1749) \sin \theta + (+.1907) \cos \theta =$ $(+.1397) + (+.1148) =$ $+ .2545''$</p>			
<p>Lateral Mov't in XY Plane = $(+.1749) \cos \theta - (+.1907) \sin \theta =$ $(+.1053) - (+.1523) =$ $-.0470$</p>			
<p>Lateral Mov't off XY Plane ($\Delta Z = +1.1043$)</p>			
<p>Absolute Lateral Mov't = $\sqrt{(1.1043)^2 + (\text{Lateral Mov't in XY})^2} =$ $\sqrt{(1.1043)^2 + (.0470)^2} =$ 1.1053</p>			

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 2 of 6
SYSTEM	ORIGINATOR		DATE
CALCULATION FOR	REVIEWER M. Z. Lee		DATE 10/5/73
Safety Valve Loads (Case # 2) mov't @ Pt EH-652			RESULTS
$\Delta X = +.0264"$ $\Delta Y = +.0053"$ $\Delta Z = -.0128"$ $\theta = 53^\circ$ Facing East			
Axial Mov't = $(+.0053) \sin \theta + (+.0264) \cos \theta -$ $(+.0042) + (+.0159) =$ $+.0201" \text{ or } 0"$			
Lateral Mov't in XY Plane = $(+.0053) \cos \theta - (+.0264) \sin \theta$ $(+.0032) - (+.0211) =$ $-.0179" \text{ or } 0"$			
Lateral Mov't off XY Plane = $(\Delta Z = -.0128")$			
Absolute Lateral Mov't = $\sqrt{(.0128)^2 + (\text{Lateral Mov't in XY})^2} =$ $\sqrt{(.0128)^2 + (.0179)^2} =$ $.0220"$			

FILING CODE

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT
PROJECT

FILING CODE

W.O. PAGE
3 of 6

SYSTEM

ORIGINATOR

CALCULATION FOR

DATE

REVIEWER

M. Z. Lee

DATE 12/5/73

RESULTS

Seismic Mov't @ Pt. MW-65

$$\begin{aligned} \Delta X &= \pm .0014'' \\ \Delta Y &= \pm .0015'' \\ \Delta Z &= \pm .0018'' \end{aligned}$$

$\theta = 53^\circ$
Facing East



$$\begin{aligned} \text{Axial Mov't} &= (+.0015) \sin \theta + (+.0014) \cos \theta \\ &= (+.0012) + (+.0008) = \\ &= +.0020'' \end{aligned}$$

Lateral Mov't in XY Plane =

$$\begin{aligned} &(+.0015) \cos \theta - (+.0014) \sin \theta \\ &= (+.0009) - (+.0011) = \\ &= \pm .0002'' \end{aligned}$$

Lateral Mov't off XY Plane =

$$\begin{aligned} \text{Absolute Lateral Mov't} &= \sqrt{(.0018)^2 + (\text{Lateral Mov't in XY})^2} \\ &= \sqrt{(.0018)^2 + (.0002)^2} = \\ &= .0018'' \end{aligned}$$

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE
	PROJECT	
SYSTEM	ORIGINATOR	
CALCULATION FOR	DATE	REVIEWER M. Z. Lee
Stack Mov't due to Thermal Expansion		DATE 12/5/73
ELEV of anchor in roof = 149'-0"		RESULTS
ELEV of safety valve = 128'-0 7/16"		
Length of stack = 20'-11 9/16"		
* Expansion of A106 GR.B steel @ 500°F = .0362 in./ft. of pipes		
20.9635 ft x .0362 in/ft = .7589 in.		
 <p>$\theta = 53^\circ$ Facing East</p>		
Axial Mov't = $(-.7589) \sin \theta =$		$-.6061''$ (compressive)
Lateral Mov't in XY Plane = $(-.7589) \cos \theta =$		$-.4567''$
* Temperature is found in pipe specifications (page 65) for Safety Valve Relief Lines.		

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 5 of 6
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER M. Z. Lee		
	DATE 12/5/73		
RESULTS			
<u>Total Mov't @ Pt EH-652</u>			
<u>Thermal + Safety Valve + Seismic Mov't</u>			
Axial Mov't = (+.2545) + (+.0201) + (+.0020) =		+.2766"	
		OR	
When Safety Valve is closed = (+.2545) + (+.0020) =		+.2565"	
		(compressive)	
Lateral Mov't in XY Plane =			
(-.0470) + (-.0179) + (-.0002) =		-.0651"	
		OR	
When Safety Valve is closed = (-.0470) + (+.0002) =		-.0468"	
Mov't in Z Direction =			
(+1.1043) + (-.0128) + (+.0018) =		+1.0933"	
When Safety Valve is closed = (+1.1043) + (+.0018) =		+1.1061"	
Lateral Mov't off XY Plane =			
$\sqrt{(1.1061)^2 + (.0651)^2}$		= 1.1080"	
<u>Total Movement</u>			
Axial Mov't = (.2766) + (.6061) =		.8827"	
Lateral Mov't in XY Plane = (-.4567) - (-.0468) =		-.4099"	
Lateral Mov't off XY Plane =			
$\sqrt{(1.1061)^2 + (.4099)^2}$		= 1.1796"	


GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.		CLIENT	FILING CODE	
		PROJECT	W.O.	PAGE 6 of 6
SYSTEM			ORIGINATOR	
CALCULATION FOR			DATE	
MSV-48 F Summary MSES-14			REVIEWER M. Z. Lee	
			DATE 12/5/73	
RESULTS				
DIRECTION	WITHOUT STACK MOVEMENT	WITH STACK MOVEMENT		
AXIAL	.2766"	.8827"		
XY	-.0651"	-.4099"		
Z	+1.1061"	+1.1061"		
LATERAL	1.1080"	1.1796"		
Design Conditions				
Axial = .84"				
Lateral = 1.42"				

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT FPC	FILING CODE	
	PROJECT CR UNIT 3	W.O.	PAGE 1 OF 6
SYSTEM CR-5	ORIGINATOR A. ECKENROTH		DATE 12/6/73
CALCULATION FOR Movement of Safety Valve MSV-36		REVIEWER N. Z. LEE	DATE 12/8/73
Thermal (Revision #1) movements @ Pt. IH-7B2			RESULTS
$\Delta X = +.0299"$ $\Delta Y = +.1743"$ $\Delta Z = +.8079"$ $\theta = 53^\circ$ Facing East			
Axial Mov't = $(+.1743) \sin \theta + (+.0299) \cos \theta$ $(+.1392) + (+.0180) =$ $+.1572"$			
Lateral Mov't in XY Plane = $(+.1743) \cos \theta - (+.0299) \sin \theta =$ $(+.1049) - (+.0239) =$ $+.0810"$			
Lateral Mov't off XY Plane ($\Delta Z = +.8079"$)			
Absolute Lateral Mov't = $\sqrt{(.8079)^2 + (\text{Lateral Mov't in XY})^2}$ $\sqrt{(.8079)^2 + (.0810)^2} =$ $.8120"$			

FILING
CODE

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE

Safety Valve Loads (case #2) mov't @ Pt. IH-782



Axial Mov't = $(-.0166) \sin \theta + (-.0365) \cos \theta$
 $(-.0133) + (-.0220) =$
 $-.0353" \text{ or } 0"$

Lateral Mov't in XY Plane =
 $(-.0166) \cos \theta - (-.0365) \sin \theta =$
 $(-.0100) - (-.0292) =$
 $+ .0192" \text{ or } 0"$

Lateral Mov't off XY Plane ($\Delta Z = -.0162"$)


Absolute Lateral Mov't = $\sqrt{(.0162)^2 + (\text{Lateral Mov't in XY})^2}$
 $\sqrt{(.0162)^2 + (.0192)^2} =$
 $.0251"$

RESULTS

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE
	PROJECT	
SYSTEM	ORIGINATOR	
CALCULATION FOR	DATE	
	REVIEWER	
	DATE	
	RESULTS	

Seismic Mov't @ Pt. NC-78

$\Delta X = \pm .0010"$
 $\Delta Y = \pm .0005"$
 $\Delta Z = \pm .0007"$



$\theta = 53^\circ$
 Facing East

Axial Mov't = $(\pm .0005) \sin \theta + (\pm .0010) \cos \theta$
 $(\pm .0004) + (\pm .0006) =$
 $\pm .0010"$

Lateral Mov't in XY Plane =
 $(\pm .0005) \cos \theta - (\pm .0010) \sin \theta =$
 $(\pm .0003) - (\pm .0008) =$
 $\pm .0011"$

Lateral Mov't off XY Plane ($\Delta Z = \pm .0007"$)

Absolute Lateral Mov't = $\sqrt{(.0007)^2 + (\text{lateral Mov't in XY})^2} =$
 $\sqrt{(.0007)^2 + (.0011)^2} =$
 $.0013"$

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT
PROJECT

FILING CODE

W.O. PAGE
4 OF 6

SYSTEM

ORIGINATOR

CALCULATION FOR

DATE

REVIEWER

DATE

RESULTS

Stack Mov't due to Thermal Expansion



ELEV. of anchor in roof = 149'-0"

ELEV. of safety valve = 128'-7 1/8"

Length of stack = 20'-4 7/8"

* Expansion of A106 GR B steel @ 500°F =
.0362 in / ft. of pipe

20.4063 ft x .0362 in/ft = .7387 in



Axial Mov't = $(-.7387) \sin \theta = -.5900"$
(compressive)

Lateral Mov't in XY Plane = $(-.7387) \cos \theta = -.4446"$

* Temperature is found in pipe specifications
(page 65) for Safety Valve Relief Lines

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE
	PROJECT	
SYSTEM		W.O. PAGE 5 of 6
CALCULATION FOR		ORIGINATOR
		DATE
		REVIEWER
		DATE
		RESULTS
<u>Total Mov't @ Pt IH-782</u>		
<u>Thermal + Safety Valve + Seismic Mov't</u>		
Axial Mov't = $(+.1572) + (-.0353) + (+.0010) =$		$+.1229"$
When Safety Valve is closed = $(+.1572) + (+.0010) =$		$+.1582"$ <i>or</i> <i>(compressive)</i>
Lateral Mov't in XY Plane = $(+.0810) + (+.0192) + (+.0011) =$		$+.1013"$
When Safety Valve is closed = $(+.0810) + (-.0011) =$		$+.0799"$
Mov't in Z Direction = $(+.8079) + (-.0162) + (+.0007) =$		$+.7924"$
When Safety Valve is closed = $(+.8079) + (+.0007) =$		$+.8086"$
Lateral Mov't off XY Plane = $\sqrt{(.8086)^2 + (.1013)^2} =$		$.8149"$
<u>Total Movement</u>		
Axial Mov't = $(.5900) + (.1582) =$		$.7482"$
Lateral Mov't in XY Plane = $(-.4446) - (+.1013) =$		$-.5459"$
Lateral Mov't off XY Plane = $\sqrt{(.8086)^2 + (.5459)^2} =$		$.9756"$

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 6 of 6

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE
MSV-36 Summary MSEJ-11	
	RESULTS

DIRECTION	WITHOUT STACK MOVEMENT	WITH STACK MOVEMENT	
AXIAL	.1582"	.7482"	Compression
XY	+.1013"	-.5459"	
Z	+.8086"	+.8086"	
LATERAL	.8149"	.9756"	


Design Conditions
 Axial = 0.9" compression
 Lateral = 0.84"

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT FPC	FILING CODE
	PROJECT CR UNIT #3	W.O. 4243-027 PAGE 1 of 6
SYSTEM CR-6A	ORIGINATOR A ECKENROTH	DATE 12/3/73
CALCULATION FOR Movement on Safety Valve MSV-47F		REVIEWER M. Z. Lee
		DATE 12/5/73
Thermal (Revision #1) movements @ Pt. ID-723 		RESULTS
$\Delta X = +.1752"$ $\Delta Y = +.1725"$ $\Delta Z = +.9191"$ $\theta = 53^\circ$ Facing East		
Axial Mov't = $(+.1725) \sin \theta + (.1752) \cos \theta$ $(+.1378) + (.1054) =$ $+.2432"$		
Lateral Mov't in XY Plane = $(+.1725) \cos \theta - (.1752) \sin \theta =$ $(+.1038) - (.1399) =$ $-.0361"$		
Lateral Mov't off XY Plane = $\sqrt{(.9191)^2 + (\text{Lateral Mov't in XY})^2}$ Absolute Lateral Mov't = $\sqrt{(.9191)^2 + (.0361)^2} =$ $.9198"$		

FILING CODE

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE

Safety Valve Loader (case # 1) mov't @ Pt. ID-723



Axial Mov't = $(-.0049) \sin \theta + (-.0230) \cos \theta$
 $(-.0039) + (-.0138) =$
 $-.0177" \approx 0"$

Lateral Mov't in XY Plane =
 $(-.0049) \cos \theta - (-.0230) \sin \theta$
 $(-.0029) - (-.0184) =$
 $+.0155" \approx 0"$

Lateral Mov't off XY Plane =


Absolute Lateral Mov't = $\sqrt{(.0103)^2 + (\text{Lateral Mov't in XY})^2} =$
 $\sqrt{(.0103)^2 + (.0155)^2} =$
 $.0186"$

RESULTS


GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE
	PROJECT	
SYSTEM	W.O.	PAGE 3 of 6
CALCULATION FOR	ORIGINATOR	DATE
	REVIEWER	DATE
	RESULTS	

Seismic Mov't @ Pt. NA-72

$\Delta X = \pm .0089"$
 $\Delta Y = \pm .0231"$
 $\Delta Z = \pm .0088"$



Facing East



Axial Mov't = $(+.0231) \sin \theta + (+.0089) \cos \theta$
 $(+.0184) + (+.0054) =$
 $+.0238"$

Lateral Mov't in XY Plane =
 $(\pm .0231) \cos \theta - (\pm .0089) \sin \theta$
 $(\pm .0139) - (\pm .0071) =$
 $\pm .0068"$

Lateral Mov't off XY Plane

Absolute Lateral Mov't = $\sqrt{(.0088)^2 + (\text{Lateral Mov't in XY})^2} =$
 $\sqrt{(.0088)^2 + (.0068)^2} =$
 $.0111"$

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 4 of 6
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
<u>Stack Mov't due to Thermal Expansion</u>			RESULTS
ELEV. of anchor in roof = 149'-0"			
ELEV. of safety valve = 128'-6 ¹⁵ / ₁₆ "			
Length of stack = 20'-5 ¹ / ₁₆ "			
* Expansion of A106-GR B steel @ 500°F = .0362 in / ft. of pipe			
20.4219 ft x .0362 in/ft = .7393 in			
Axial Mov't = (-.7393) Sin θ =			- .5904" (compressive)
Lateral Mov't in xy Plane = (-.7393) Cos θ =			- .4449"
* Temperature is found in pipe specifications (page 65) for Safety Valve Relief Lines.			

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE
	PROJECT	
SYSTEM	ORIGINATOR	
CALCULATION FOR	DATE	
	REVIEWER	
	DATE	
	RESULTS	
<u>Total Mov't @ Pt. ID-723 =</u>		
Thermal + Safety Valve + Seismic Mov't		
Axial Mov't = (+.2432) + (-.0177) + (+.0238) =		+ .2493"
		OR
When Safety Valve is closed = (+.2432) + (+.0238)		+ .2670" (compressive)
Lateral Mov't in XY Plane =		
(-.0361) + (+.0155) + (+.0068) =		- .0138"
		OR
When Safety Valve is closed = (-.0361) + (-.0068) =		- .0429"
Mov't in Z Direction =		
(+.9191) + (+.0103) + (+.0088) =		+ .9382"
		OR
When Safety Valve is closed = (+.9191) + (+.0088) =		+ .9279"
Lateral Mov't off XY Plane =		
$\sqrt{(.9382)^2 + (.0429)^2} =$.9392"
<u>Total Movement</u>		
Axial Mov't = (.2493) + (.5904) =		.8397"
Lateral Mov't in XY Plane = (-.4449) - (-.0138)		- .4311"
Lateral Mov't off XY Plane =		
$\sqrt{(.9382)^2 + (.4311)^2}$		1.0325"

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.		CLIENT	FILING CODE	
		PROJECT	W.O.	PAGE 6 of 6
SYSTEM			ORIGINATOR	
CALCULATION FOR			DATE	
MSV-47F Summary MSEJ-18			REVIEWER	
			DATE	
			RESULTS	
DIRECTION	WITHOUT STACK MOVEMENT	WITH STACK MOVEMENT		
AXIAL	.2670"	.8397"		
XY	-.0429"	-.4311"		
Z	+.9382"	+.9382"		
LATERAL	.9392"	1.0325"		
Design Conditions				
Axial = .84"				
Lateral = 1.32"				

FILING
CODE

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT

FPC

FILING CODE

PROJECT

W.O.

PAGE

1 of 10

SYSTEM

CR-6A

ORIGINATOR

A. ECKENROTH

CALCULATION FOR

Movement on Safety Valve MSV-35

DATE 12/6/73


REVIEWER

M. Z. LEE

DATE 12/28/73

Thermal (Revision #1) movements @ Pt IG-853

RESULTS



$$\begin{aligned} \text{Axial Mov't} &= (+.1752) \sin \theta + (+.0783) \cos \theta \\ &= (+.1399) + (+.0471) = \\ &= +.1870" \end{aligned}$$


$$\begin{aligned} \text{Lateral Mov't in XY Plane} &= \\ &= (+.1752) \cos \theta - (.0783) \sin \theta \\ &= (+.1054) - (+.0625) = \\ &= +.0429" \end{aligned}$$

Lateral Mov't off XY Plane ($\Delta Z = +.6318"$)

$$\begin{aligned} \text{Absolute Lateral} \\ \text{Mov't} &= \sqrt{(.6318)^2 + (\text{Lateral Mov't in XY})^2} \\ &= \sqrt{(.6318)^2 + (.0429)^2} = \\ &= .6333" \end{aligned}$$

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE

Safety Valve Loads (Case #1) mov't @ Pt. IG-853



$Ax = -0.0172"$
 $Ay = -0.0018"$
 $Az = -0.0013"$

$\theta = 53^\circ$
Facing East

Axial Mov't = $(-0.0018) \sin \theta + (-0.0172) \cos \theta =$
 $(-0.0014) + (-0.0104) =$
 $-0.0118" \text{ or } 0"$

Lateral Mov't in XY Plane =
 $(-0.0018) \cos \theta - (-0.0172) \sin \theta =$
 $(-0.0010) - (-0.0137) =$
 $+0.0127" \text{ or } 0$

Lateral Mov't off XY Plane ($Az = +0.0013$)

Absolute Lateral Mov't = $\sqrt{(0.0013)^2 + (\text{Lateral Mov't in XY})^2}$
 $\sqrt{(0.0013)^2 + (0.0127)^2} =$
 $0.0128"$

RESULTS

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT

PROJECT

FILING CODE

W.O.

PAGE

306

SYSTEM

ORIGINATOR

CALCULATION FOR

DATE

REVIEWER

DATE


RESULTS

Seismic Mov't @ Pt. NG-85


$$\Delta X = \pm .0062''$$

$$\Delta Y = \pm .0091''$$

$$\Delta Z = \pm .0160''$$



$\theta = 53^\circ$
Facing East



$$\begin{aligned} \text{Axial Mov't} &= (\pm .0091) \sin \theta + (\pm .0062) \cos \theta \\ &= (\pm .0073) + (\pm .0037) = \\ &= \pm .0110'' \end{aligned}$$

$$\begin{aligned} \text{Lateral Mov't in XY Plane} &= \\ &= (\pm .0091) \cos \theta - (\pm .0062) \sin \theta \\ &= (\pm .0055) - (\pm .0050) = \\ &= \pm .0105'' \end{aligned}$$

Lateral Mov't off XY Plane ($\Delta Z = \pm .0160''$)

$$\begin{aligned} \text{Absolute Lateral Mov't} &= \sqrt{(.0160)^2 + (\text{Lateral Mov't in XY})^2} \\ &= \sqrt{(.0160)^2 + (.0105)^2} = \\ &= .0191'' \end{aligned}$$

FILING CODE

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE

Stack Mov't due to Thermal Expansion



ELEV of anchor in roof = 149'-0"

ELEV of safety valve = 128'-3 1/4"

Length of stack = 20'-8 3/4"

* Expansion of A106 GR. B steel @ 500°F =
.0362 in / ft of pipe

20.7292 ft x .0362 in / ft = .7504 in.



Axial Mov't = (-.7504) Sin θ = -.5993" (compression)

Lateral Mov't = (-.7504) Cos θ = -.4516"

* Temperature is found in pipe specifications (page 65) for Safety Valve Relief Lines



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 5 of 6
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
	RESULTS		
<u>Total Mov't @ Pt IG-853</u>			
Thermal + Safety Valve + Seismic Mov't			
Axial Mov't = (+.1870) + (-.0118) + (+.0110) = +.1862"			
When Safety Valve is closed = (+.1870) + (+.0110) = +.1980 (compression)			
Lateral Mov't in XY Plane = (+.0429) + (+.0127) + (+.0105) = +.0661"			
When Safety Valve is closed (+.0429) + (-.0105) = +.0324"			
Mov't in Z Direction = (+.6318) + (-.0013) + (+.0160) = +.6465"			
When Safety Valve is closed (+.6318) + (+.0160) = +.6478"			
Lateral Mov't off XY Plane = $\sqrt{(.6478)^2 + (.0661)^2} = .6512"$			
<u>Total Movement</u>			
Axial Mov't = (.5993) + (.1980) = .7973"			
Lateral Mov't in XY Plane = (-.4516) - (+.0661) = -.5177"			
Lateral Mov't off XY Plane = $\sqrt{(.6478)^2 + (.5177)^2} = .8293"$			

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 6 OF 6

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE
MSV-35F Summary MSEJ-15	
	RESULTS

DIRECTION	WITHOUT STACK MOVEMENT	WITH STACK MOVEMENT	
AXIAL	.1980"	.7973"	Compression
XY	+0.0661"	-0.5177"	
Z	+0.6478"	+0.6478"	
LATERAL	.6512"	.8293"	

Design Conditions
 Axial = 0.84"
 Lateral = 0.76"


GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE OF
SYSTEM CR-3	ORIGINATOR S. ARAUZ		
CALCULATION FOR Movement on Safety Valve MSV-46V		DATE 1-3-73	
		REVIEWER	
		DATE	
		RESULTS	
<p><u>Stack Mov't due to Thermal Expansion</u></p> <p>ELEV of anchor in roof = 149'-0"</p> <p>ELEV. of safety valve = 128'-3"</p> <p>Length of stack = 20'-9"</p> <p>Expansion of A106-GR. B steel @ 380°F = .0252 in/ft. of pipe.</p> <p>20.75 ft. x .0252 in/ft = 0.5229 in</p> <div style="display: flex; justify-content: space-around;"> <div style="text-align: center;">  <p>$\theta = 53^\circ$ Facing East.</p> </div> <div style="text-align: center;">  </div> </div> <p>Axial Mov't = $(-0.5229) \sin. \theta =$ -.4176" (compressive)</p> <p>Lateral Mov't in xy Plane = $(-0.5229) \cos. \theta =$ -.3147"</p>			

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE OF
SYSTEM	ORIGINATOR G. ARAUZ		DATE 1-3-79
CALCULATION FOR	REVIEWER		DATE
<u>Total Mov't @ Pt. H0-51</u> Thermal + Safety Valve + Seismic Mov't Axial Mov't = $(+.3232) + (-.0283) + (+.0077) =$ +.3026" OR When Safety Valve is Closed = $(+.3232) + (+.0077) =$ +.3309" (compressive) Lateral Mov't in XY Plane = $(-.1374) + (+.0299) + (+.0040) =$ -.1035" OR When Safety Valve is Closed = $(-.1374) + (-.0040) =$ -.1414" Mov't in Z direction = $(+.8246) + (+.0614) + (+.0278) =$ +.9138" OR When safety valve is closed = $(+.8246) + (+.0278) =$ +.8524 Lateral Mov't off XY Plane = $\sqrt{(.9138)^2 + (.1414)^2} =$.9247" <u>Total Movement</u> Axial Mov't = $(.3309) + (.4176) =$.7485 Lateral Mov't in XY Plane = $(-.3147) - (-.1035) =$ -.2112" Lateral Mov't off XY Plane = $\sqrt{(.9138)^2 + (.2112)^2} =$.9379"			RESULTS

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.		CLIENT	FILING CODE	
		PROJECT	W.O.	PAGE OF
SYSTEM			ORIGINATOR G. ARAUZ	
CALCULATION FOR			DATE 1-3-74	
MSV-46 F SUMMARY MSEJ-4			REVIEWER	
			DATE	
RESULTS				
DIRECTION	WITHOUT STACK MOVEMENT	WITH STACK MOVEMENT		
AXIAL	.3309"	.7485"	Compression	
X - Y	-.1414"	-.2112"		
Z	+.9138"	+.9138"		
LATERAL	.9247"	.9379"		
<p>Design Conditions</p> <p>Axial = .85" Compression max</p> <p>Lateral = .81"</p>				

FILING
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT F P C.	FILING CODE	
	PROJECT C R # 3	W.O.	PAGE OF
SYSTEM C R - 3	ORIGINATOR G. ARAUZ		DATE 1-3-74
CALCULATION FOR Movement of Safety Valve MSV-42		REVIEWER	
<p><u>STACK MOV'T DUE TO THERMAL EXPANSION</u></p> <p>ELEV OF ANCHOR IN ROOF = 149'-0"</p> <p>ELEV. OF SAFETY VALVE = 128'-3 7/8"</p> <p>LENGTH OF STACK = 20'-8 7/8"</p> <p>Expansion of A106-GR-B steel @ <u>380°F</u> = .0252 in/ft. of pipe</p> <p>20.7396 ft x .0252 in/ft = 0.5226 in</p> 		DATE	
		RESULTS	
<p>Axial Mov't = $(-.5226) \sin \theta = -.4174"$ (Compressive)</p> <p>Lateral Mov't. in xy Plane = $(-.5226) \cos \theta = -.3145"$</p>			

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.		CLIENT	FILING CODE	
		PROJECT	W.O.	PAGE OF
SYSTEM			ORIGINATOR G. ARAUZ	
CALCULATION FOR			DATE 1-3-74	
MSY-42F SUMMARY MSEJ-3			REVIEWER	
			DATE	
RESULTS				
DIRECTION	WITHOUT STACK MOVEMENT	WITH STACK MOVEMENT		
AXIAL	.1652"	.5826"	Compressive	
X Y	+.0816"	-.3961"		
Z	+1.0340"	1.0340"		
LATERAL	1.0372"	1.1073		
<p><i>Design Conditions</i></p> <p><i>Axial = 0.84"</i></p> <p><i>Lateral = 0.73"</i></p>				

File

CR # 3

I-21

CRYSTAL RIVER #3

Main Steam Pipe

Steam Hammer Analysis

54203MS02A0

Food grade steam

hammer restraint

Please see

Restraints

at the back of the

report

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE S4203M502A0	
	PROJECT Crystal River #3	W.D. 4203-027	PAGE 1 OF
SYSTEM Main Steam Piping	ORIGINATOR M.Z. Lee		DATE 11/2/73
CALCULATION FOR Steam Hammer	REVIEWER		DATE
<p style="text-align: center;"><i>Assumptions</i></p> <ol style="list-style-type: none"> 1. Turbine emergency stop valves are energized to close when the turbine is operating at max load. 2. No steam is extracted or released from the main steam piping when the valve is closing and sometime thereafter. 3. Turbine emergency stop valves close according to the time history shown in Fig. 1. 4. Net travelling time of valve is 0.15 Sec. 			RESULTS

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE
Crystal River #3			2 OF
SYSTEM Main Steam Ring		ORIGINATOR M. Z. Lee	
CALCULATION FOR Steam Hammer		DATE 11/2/73	
		REVIEWER	
		DATE	
		RESULTS	
DATA			
Operating Conditions			
Steam Pressure	1065.0	psia	
Steam Temperature	600°	F	
Flow Rate	2,784,350	#/hr	
Ratio of Specific Heat, Cp/Cv	1.27		
Pipe, I.D.	22.064	in	
Calculated Initial Conditions			
Steam Velocity	137.8	f/sec	
Acoustic Velocity	1,722.5	f/sec	
Pressure Drop in Valve	5.344	psi	
Density	0.065644	lb-sec ² /ft ⁴	
Entropy	1.4329	Btu/lb °R	
Specific Weight	2.1137	lb/ft ³	
Valve Closing Time			
Information obtained from Westinghouse			
Total closing time	0.25	Sec	
Valve travelling time	0.15	Sec	

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE 542031502A0	
	PROJECT Crystal River #3	W.O.	PAGE 3 OF
SYSTEM Main Steam Piping	ORIGINATOR M. Z. Lee		DATE 11/2/73
CALCULATION FOR Steam Hammer	REVIEWER		DATE
<p>Unbalanced Force</p> <p>Maximum pressure increase due to stop valve closure computed by GAI Computer Program MA15 is</p> $\Delta p_{max} = 113.27 \text{ psi}$ <p>$\Delta p(\tau)$ is plotted in Fig. 1 along with $A(\tau)$ for dimensionless time τ.</p> <p>Maximum slope of pressure increase curve is</p> $\frac{dp}{d\tau} _{max} = \frac{dp(0.7) - dp(0.4)}{0.3} = \frac{5p}{0.3} = 193 \text{ psi/wave length}$ <p>Unbalanced Force</p> $F_{max} = \Delta p_{max} \cdot A = 113.27 \cdot \frac{\pi}{4} (22.064)^2 = 43309 \text{ lb} = 43.3 \text{ kips}$ $\frac{dF}{d\tau} _{max} = \frac{dp}{d\tau} _{max} \cdot A = 193 \times \frac{\pi}{4} (22.063)^2 = 73.7 \text{ kips/wave length}$ <p>It is easily seen that the maximum axial thrust on i-th section of pipe with length L_i can be approximated by</p> $U_i \leq \min \left[F_{max}, \frac{L_i}{\lambda} \frac{dF}{d\tau} _{max} \right]$ <p>where λ = length of pressure wave</p>			RESULTS

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE S4263MS02A0	
	PROJECT Crystal River #3	W.O.	PAGE 4 OF
SYSTEM Main Steam Piping	ORIGINATOR M. Z. Lee		DATE 11/2/73
CALCULATION FOR Steam Hammer	REVIEWER		DATE
<p>For valve closing time $t_c = 0.15$ sec, the wave length is</p> $\lambda = V_a t_c = 1722.5 \times 0.15 = 258 \text{ ft}$ <p>where $V_a = \text{acoustic velocity} = 1722.5 \text{ ft/sec}$</p> <p>Pressure gradient and unbalanced force gradient</p> $\frac{dp'}{dL}_{\max} = \frac{193}{258} = 0.75 \text{ Dsi/ft of pipe}$ $\frac{dF}{dL}_{\max} = \frac{73.7}{258} = 0.286 \text{ Kips/ft of pipe}$			RESULTS

	MADE 11/2/73	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.				
	CHK'D.					
Crystal River #3 Main Steam Steam Hammer	DR. CP.	4203-027	WORK ORDER	SIZE	DRAWING	REV.
	CP. DPN.					
	ENG. M. Z. Lee					
	REV. CK. APP. DATE					




Fig. 1.

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.		CLIENT	PROJECT		FILING CODE																																																																															
			Crystal River #3		S4203 MS02A0																																																																															
SYSTEM		Main Steam Piping			W.O.	PAGE																																																																														
CALCULATION FOR		Steam Hammer				6 OF																																																																														
					ORIGINATOR																																																																															
					M. Z. Lee																																																																															
					DATE	11/2/73																																																																														
					REVIEWER																																																																															
					DATE																																																																															
Line CR-3A & Line CR-13A (Fig. 2)					RESULTS																																																																															
<table border="1"> <thead> <tr> <th>Sec. No. i</th> <th>Length li</th> <th>Force Ui</th> <th>Existing Snubber Capacity</th> <th>Additional Snubber</th> <th>Notes</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>27.552</td> <td>7.85</td> <td>0</td> <td></td> <td rowspan="2">Connected to Turbine Stop valve</td> </tr> <tr> <td>2</td> <td>29.438</td> <td>8.4</td> <td>49.5</td> <td></td> </tr> <tr> <td>3</td> <td>67.25</td> <td>19.2</td> <td>49.5</td> <td></td> <td></td> </tr> <tr> <td>4</td> <td>12.73</td> <td>3.6</td> <td>49.5</td> <td></td> <td></td> </tr> <tr> <td>5</td> <td>23.75</td> <td>6.6</td> <td>49.5</td> <td></td> <td></td> </tr> <tr> <td>6</td> <td>21.406</td> <td>6.0</td> <td>0</td> <td></td> <td>Restrained by Penetr. Anchor</td> </tr> <tr> <td>7</td> <td>21.469</td> <td>6.0</td> <td>0</td> <td></td> <td>"</td> </tr> <tr> <td>8</td> <td>16.88</td> <td>4.7</td> <td>0</td> <td></td> <td>"</td> </tr> <tr> <td>9</td> <td>19.6</td> <td>5.5</td> <td>0</td> <td>49.5 Kp</td> <td></td> </tr> <tr> <td>10</td> <td>22.99</td> <td>6.3</td> <td>0</td> <td>49.5</td> <td></td> </tr> <tr> <td>11</td> <td>9.67</td> <td>2.7</td> <td>0</td> <td>30</td> <td></td> </tr> <tr> <td>12</td> <td>23.672</td> <td>6.7</td> <td>0</td> <td></td> <td>Connected to Steam Gen.</td> </tr> </tbody> </table>						Sec. No. i	Length li	Force Ui	Existing Snubber Capacity	Additional Snubber	Notes	1	27.552	7.85	0		Connected to Turbine Stop valve	2	29.438	8.4	49.5		3	67.25	19.2	49.5			4	12.73	3.6	49.5			5	23.75	6.6	49.5			6	21.406	6.0	0		Restrained by Penetr. Anchor	7	21.469	6.0	0		"	8	16.88	4.7	0		"	9	19.6	5.5	0	49.5 Kp		10	22.99	6.3	0	49.5		11	9.67	2.7	0	30		12	23.672	6.7	0		Connected to Steam Gen.		
Sec. No. i	Length li	Force Ui	Existing Snubber Capacity	Additional Snubber	Notes																																																																															
1	27.552	7.85	0		Connected to Turbine Stop valve																																																																															
2	29.438	8.4	49.5																																																																																	
3	67.25	19.2	49.5																																																																																	
4	12.73	3.6	49.5																																																																																	
5	23.75	6.6	49.5																																																																																	
6	21.406	6.0	0		Restrained by Penetr. Anchor																																																																															
7	21.469	6.0	0		"																																																																															
8	16.88	4.7	0		"																																																																															
9	19.6	5.5	0	49.5 Kp																																																																																
10	22.99	6.3	0	49.5																																																																																
11	9.67	2.7	0	30																																																																																
12	23.672	6.7	0		Connected to Steam Gen.																																																																															
						MS#-237																																																																														
						-238																																																																														
						-239																																																																														
						-240																																																																														
						MS#-102																																																																														

<p><i>Crystal River #3</i></p> <p><i>Main Steam Piping</i></p> <p><i>Steam Hammer</i></p>	MADE <i>11/2/78</i>	GILBERT ASSOCIATES, INC.			
	CHK'D.	ENGINEERS AND CONSULTANTS			
	BY CP.	READING, PENNA.			
	CP. DPK.	<i>4203-027</i>			
	ENG. <i>M. Z. Lee</i>	WORK ORDER	SIZE	DRAWING	REV.
	REV. CH. APP. DATE				




Fig. 2 Lines CR-3 & CR-13

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE S4203 M502A0
	PROJECT Crystal River #3	
SYSTEM Main Steam Piping	ORIGINATOR M. Z Lee	DATE 11/2/73
CALCULATION FOR Steam Hammer	REVIEWER	DATE

Line CR-3 Outside Containment Bldg.




Fig 3

Stresses at A₂ from Piping Stress Program

Vibration (Y-Z) 853 psi

S.V. Discharge Pressure (PD) 761
6500

stress program gives
2x 2 in stress = 6500

Allowable Stress = 1.2 S_n = 18,000 psi

Bending Stress at A₂ due to Steam Hammer.

$$M = T_6 \sin 52^\circ \times l$$

$$= T_6 \times (9.875 \times 12) \sin 52^\circ = 93.4 T_6$$

$$S_0 = \frac{M}{S} = \frac{93.4}{389} T_6 = \frac{1}{4.16} T_6$$


$$\text{Let } S_0 = 18,000 - 853 \times 2 - 761 \times 1.5 - 6500$$

$$= 8,650 \text{ psi}$$

$$\text{Then } T_6 = 4.16 \times 8,650 = 36,000 \text{ lb} = 36 \text{ klps}$$

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE 54203 M502A0	
	PROJECT Crystal River #3	W.O.	PAGE 9 of
SYSTEM Main Steam Piping	ORIGINATOR M. Z. Lee		DATE 11/2/73
CALCULATION FOR Steam Hammer	REVIEWER		DATE


If the pressure wave has a form of Fig 1 the max unbalanced force on Sec 6 is 6 kips



Though the form of pressure wave may deviate from Fig 1 and results in steeper slope consequently larger unbalanced force, it is unlikely that the unbalanced force will reach say 20 kips in the section of pipe 21' long when the normal wave length is 258 ft

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE
SYSTEM	Crystal River #3		10 OF
CALCULATION FOR	Main Steam Piping	ORIGINATOR	M. Z. Lee
		DATE	11/2/73
		REVIEWER	
		DATE	
		RESULTS	

Line CR-13 Inside Pen. 105 (Ref. Fig. 2)



Stresses at A₂ from Piping Stress Program

Vibration (x-y) 516 psi
 Pressure 6,500

Bending stress allowed for steam Hammer

$$S_b = 18,000 - 516 \times 2 - 6,500 = 10,468 \text{ psi}$$

$$M = U_8 \times (11.594 \times 12) \sin 52^\circ = 109.2 U_8$$

Let $\frac{M}{Z} = S_b = 10,468$

$$U_8 = \frac{388}{109.2} \times 10,468 = 37,000 \text{ lbs} = 37 \text{ Kips}$$

Calculated U_8 for max $\frac{dP}{dt}$ is 4.7 Kips.

No additional support is recommended.

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE S4203M502A0	
	PROJECT Crystal River #3	W.O.	PAGE 11 OF
SYSTEM Main Steam Piping	ORIGINATOR M. Z. Lee		DATE 11/2/73
CALCULATION FOR Steam Hammer	REVIEWER		DATE
Line CR-13A at EL 142'-10 3/4" Near Steam Gen.			RESULTS
<p style="text-align: right;">Fig. 6</p>			
<p>Consider sec. 12 as a cantilever fixed at Gen. Then</p> $\delta = \frac{PL^3}{3EI} \quad \sigma = \frac{M}{S} = \frac{PL}{S}$ $\therefore \delta = \frac{3}{2} \frac{\sigma}{E} \frac{L^2}{d} \quad \text{or} \quad \sigma = \frac{3}{2} \frac{Ed}{L^2} \delta$ $\sigma = \frac{3}{2} \frac{20 \times 10^6 \times 12^2}{(23.672 \times 12)^2} \delta = 13600 \delta$ <p>Assume the snubber lock up at $\delta = \frac{1}{4}$", then</p> $\sigma = 13,600 \times \frac{1}{4} = 3,400 \text{ psi}$			

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE
	PROJECT	W.D. PAGE
SYSTEM	Crystal River #3	12 of
CALCULATION FOR	Main Steam Piping	ORIGINATOR
	Steam Hammer	M. Z. Lee
		DATE
		11/2/73
		REVIEWER
		DATE
		RESULTS

Computer Piping Stress program gives the following stresses

Vibration (x-y)	1309 psi
Dead Load	824
Pressure (hand calculation)	6,500
Expansion	4,579

Combined Occasional stress

$$S_b = 1309 + 824 + 6,500 + 3,400 = 12,033 \text{ psi}$$

vib D.L. Pr St Hammer

$$< 1.2 S_b = 14,000 \text{ psi}$$

∴ A snubber can protect point A₁ from overstressing.

Snubber Capacity

Snubber A	59.5 Kips	Sec. 9
B	59.5 Kips	Sec. 10
C	80.0 Kips	Sec. 11

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT
PROJECT *Crystal River #3*

FILING CODE
S 4203 11502 A0
W.O. PAGE
13 OF

SYSTEM *Main Steam Piping*

ORIGINATOR
M. Z. Lee

CALCULATION FOR
Steam Hammer

DATE *11/2/73*

DATE

Line CR-4 & Line CR-14A

RESULTS

Sec No <i>i</i>	Length <i>li</i>	Force <i>Ui</i>	Existing Axial Snubber	Additional Axial Snubber	
1	27.552	7.9	0 kips		Restrained by Turbine
2	35.94	10.3	49.5		
3	85.25	24.4	49.5		
4	12.58	3.6	49.5		
5	32.12	9.2	49.5		
6	20.646	5.9			Restrained by Pen. 106
7	21.355	6.1			Anchored at Pen. 106
8	14.479	4.2			Restrained by Pen. 106
9	31.578	9.1		49.5 kips	
10	26.7	7.7	49.5		
11	26.513	7.6		30 kips	
12	11.87	3.4		49.5 kips	
13	20.125	5.8			Restrained by Steam Gen.

FILING CODE

Crystal River #3	MADE 11/2/73	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.				
	CHK'D.					
Main Steam Piping	DES. CF.	4203-027	WORK ORDER	SIZE	DRAWING	REV.
	CF. DPN.					
Steam Hammer Analysis	ENG. M.Z. Lee					
	REV. CK. APP. DATE					




Fig. 7 Lines CR-4 & CR-14

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE
	PROJECT	W.O. PAGE
SYSTEM	Crystal River #3	150F
CALCULATION FOR	Main Steam Piping	ORIGINATOR
	Steam Hammer	M. Z. Lee
		DATE 11/2/73
		REVIEWER
		DATE
		RESULTS

Stresses at Penetration 106




Fig. 8

Outside Pen. 106

Stresses from Piping Stress Program

- Dead Load & Press. 4026 psi use 6500
- Seismic 857
- S. V. Disch. 357

Allowable Stress for steam Hammer

$$S_b = 18,000 - 6500 - 857 \times 2 - 357 \times 1.5 = 9,250$$

$$M = U_6 \times (8.552 \times 12) \sin 42.5^\circ = 70.7 U_6 = S_b \cdot Z$$

$$U_6 = \frac{Z}{70.7} S_b = \frac{388}{70.7} \times 9,250 = 50,700 \text{ lb} > 43.3 \text{ Kips}$$

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE S4203MS62A0													
	PROJECT Crystal River #3	W.O.	PAGE 16 OF												
SYSTEM Main Steam Piping	ORIGINATOR M. Z. Lee		DATE 11/2/73												
CALCULATION FOR Steam Hammer	REVIEWER		DATE												
<p>Inside Pen. 106</p> <p>Stresses from Piping Stress Program</p> <p>Dead Load 349</p> <p>Pressure 6,500</p> <p>Seismic 1,126</p> <p>Allowable Stress for Steam Hammer</p> $S_b = 18,000 - 349 - 6,500 - 1,126 \times 2 = 9,101$ $M = U_8 \times (12.703 \times 12) \sin 43.5^\circ = 105 U_8 = S_b z$ $U_8 = \frac{z S_b}{105} = \frac{388}{105} \times 9,101 = 33,700^{165} = 33.7 \text{ Kips}$ <p>Calculated U_8 from max $\frac{dP}{dt} = 42 \text{ Kips.}$</p> <p>Snubben Capacity</p> <table> <tr> <td>D</td> <td>Sec. 9</td> <td>49.5 Kips</td> </tr> <tr> <td>E</td> <td>Sec. 10</td> <td>(49.5) Existing</td> </tr> <tr> <td>F</td> <td>Sec. 11</td> <td>30 Kips</td> </tr> <tr> <td>G</td> <td>Sec. 12</td> <td>49.5 Kips</td> </tr> </table>			D	Sec. 9	49.5 Kips	E	Sec. 10	(49.5) Existing	F	Sec. 11	30 Kips	G	Sec. 12	49.5 Kips	RESULTS
D	Sec. 9	49.5 Kips													
E	Sec. 10	(49.5) Existing													
F	Sec. 11	30 Kips													
G	Sec. 12	49.5 Kips													

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT

PROJECT

Crystal River #3

FILING CODE

54203 MS02A0

W.O.

PAGE

17 OF

SYSTEM

Main Steam Piping

ORIGINATOR

M. Z. Lee

CALCULATION FOR

Steam Hammer

DATE 11/2/73

REVIEWER

DATE

RESULTS

Line CR-5 & Line CR-15

Section i	Length L _i	Force U _i	Existing axial Snubber	Additional Axial Snubber	Notes
1	6.052	1.2 ^{kips}			Restrained by Turb.
2	30.94	8.8	49.5		
3	67.0	19.	49.5		
4	28.0	8.0	49.5		
5	7.29	2.7	0	49.5 ^{kip}	No Y-Snubber on neighboring sections
6	81.06	23.	49.5		
7	91.5	26			Anchored at Pen 107
8	25.4	7.2		49.5 ^{kip}	
9	31.84	9.0		49.5	
10	26.87	7.6		/	Restrained by Snubbers on Secs 9 & 11
11	14.07	4.0		49.5	
12	8.32	2.4		30	Y-direction
13	16.26	4.6			

Crystal River #3	MADE 11/2/73	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D.			
Main Steam Piping Steam Hammer Analysis	DR. CF.	4203-027		
	CF. BFM.	WORK ORDER	SIZE	DRAWING
	ENG. M. Z. Lee			REV.
	REV. CH. APP. DATE			




Fig 9 Lines CR-5 & CR-15

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE SA20311502AD	
	PROJECT Crystal River #3	W.O.	PAGE 19 of

SYSTEM Main Steam Piping	ORIGINATOR M. Z. Lee
CALCULATION FOR Steam Hammer	DATE 11/2/73
	REVIEWER

	DATE
--	------

	RESULTS
--	---------




Fig. 10

$$\sigma = \frac{3}{2} \frac{Ed}{l^2} \delta = \frac{3}{2} \frac{30 \times 10^6 \times 24}{(16.26 \times 12)^2} \delta = 28,400 \delta$$

Stresses at connection A1 are

Vibration (Y-Z)	≤ 104	psi
Dead Load	1058	psi
Pressure	6,500	
Total	12,662	

If snubber lock up at $\frac{3}{16}$ " displacement

$$\sigma = 28,400 \times \frac{3}{16} = 5,310 \text{ psi}$$

Max Stress at A1

$$S_{max} = 12,662 + 5,310 = 17,972 \text{ psi}$$

$$< 1.2 S_n = 18,000 \text{ psi}$$

Snubber limits δ for both vibration and steam hammer as a result the stresses will be lower.

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE
SYSTEM	Crystal River #3		20 OF
CALCULATION FOR	Main Steam Piping	ORIGINATOR	M. Z. Lee
	Steam Hammer	DATE	11/2/73
be protected from overstresses by using snubber		REVIEWER	
		DATE	
		RESULTS	




Fig. 11

Capacity of snubber in Y-direction

$$43.3 \sin 45^\circ = 30.6 \text{ Kips}$$

From

$$P = \frac{3EI}{L^3} \delta = \frac{3 \times 20 \times 10^6 \times 4653}{(16.26 \times 12)^3} \delta$$

$$= 56800 \delta$$

$$\text{For } \delta = \frac{1}{8}'' \quad P = 56.8 \times \frac{1}{8} = 7.1 \text{ Kips}$$

$$\text{Snubber Capacity} = 30.6 - 7.1 = 23.5 \text{ Kips}$$


Snubber Capacity

H	Sec. 5	49.5 Kips
I	Sec. 8	49.5
J	Sec. 9	49.5
K	Sec. 11	49.5
L	Sec. 12	30

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE S4203 MS 02 A0	
	PROJECT Crystal River #3	W.O.	PAGE 2/02
SYSTEM Main Steam Piping	ORIGINATOR M. Z. Lee		DATE 11/2/73
CALCULATION FOR Steam Hammer	REVIEWER		DATE
Line CR-6 & Line CR-16			RESULTS

Section i	Length Li	Force Ui	Existing Axial Snubber	Additional Axial Snubber	Notes
1	6.052	1.7			Restrained by Turb.
2	36.938	10.6	49.5		
3	79.0	22.8	49.5		
4	28.0	8.0	49.5		
5	9.51	2.7	0	49.5	✓
6	98.568	38.2	49.5		
7	44.323	12.7			Restrained by Pen 108
8	33.078	9.5			Anchored at Pen 108
9	20.38	5.9			Restrained by Pen 108
10	19.474	5.6		49.5	
11	28.919	8.3		49.5	
12	16.615	7.6		30	← - direction
13	17.026	4.9			

Crystal River #3	MADE 11/2/73	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHE. E.			
Main Steam Piping	NO. CP.	4203-027		
Steam Hammer Analysis	CF. DFK.		WORK ORDER	SIZE
	ENG. M. Z. Lee			REV.
	REV. CH. APP. DATE			



GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE
SYSTEM	Crystal River #3		23 OF
CALCULATION FOR	Main Steam Piping	ORIGINATOR	M. Z. Lee
	Steam Hammer	DATE	11/2/73
		REVIEWER	
		DATE	
	Summary	RESULTS	
	Max. Pressure Rise	113.27 psi	
	Max. Unbalanced Force	43.3 Kips	
	Wave Length for 0.15 Sec Valve Closing Time	258 ft/sec	
	Max Pressure Gradient	0.36 Psi/ft pipe	
	Max Unbalance Force Gradient	0.286 Kips/ft pipe	

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.		CLIENT		FILING CODE	
		PROJECT		W.D.	PAGE
SYSTEM		Crystal River #3		54203 145 02A0	
CALCULATION FOR		Main Steam Piping		ORIGINATOR	
Steam Hammer				M. Z. Lee	
				DATE 11/2/73	
				REVIEWER	
				DATE	
				RESULTS	
Recommendations					
Add 15 Snubbers as follows					
Line No	Sec. No.	Capacity kips	Orientation	Notes	
3	9	49.5	Axial		
	10	49.5	Axial		
	11	30	Axial		
4	9	49.5	"		
	11	30	"		
	12	49.5	"		
5	5	49.5	"		
	8	49.5	"		
	9	49.5	"	} As close to Sec 10 as is possible	
	11	49.5	"		
	12	30	Vertical	End of Sec. No 12 NEAR Sec. 13	
6	5	49.5	Axial		
	10	49.5	"		
	11	49.5	"	Close to Sec. 12	
	13	30	Z-dir.	Lower end of Sec. 13	

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O. 4203-027	PAGE 25 OF
SYSTEM	ORIGINATOR M. E. Lee		DATE 11/21/73
CALCULATION FOR	REVIEWER		DATE
<p style="text-align: center;"><u>Steam Hammer Restraints on Branch Lines.</u></p> <p>Pressure wave created by turbine trip may travel along all branches connected to the main steam pipes. As a result, steam hammer may hit those branches in the same way as it hits on the main lines. Therefore, it is necessary to provide proper restraints on the branch lines. The branches to be considered are</p> <p style="margin-left: 40px;">10" turbine by-pass to condenser - 2 lines</p> <p style="margin-left: 40px;">6" main steam to moisture separator - 4 lines</p> <p style="margin-left: 40px;">6" main steam to emergency F.W. Pump turbine - 2 Lines</p> <p>Maximum unbalanced forces corresponds to pressure rise of 113.27 psi are calculated and restraints are located on sketches on the following pages.</p>			RESULTS

FILING CODE

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT

PROJECT

FILING CODE

W.O.

PAGE

4303-027 260

SYSTEM

ORIGINATOR

M. Z. Lee

CALCULATION FOR

DATE 11/21/73


REVIEWER

DATE

RESULTS

	10" SCH 60	6" SCH 40	4" SCH 40	
Flow Area A_f (in ²)	74.7	28.9	17.73	
Max Unbalance Force $F = \rho \cdot v_{max} \cdot A_f + 1000(K_p)$	847	328	145	
$\frac{\Delta F}{\Delta L_{max}}$ (lbs/ft)	56	22	11	
Calculated Unbalanced Force in Pipe Section with length L	$L = 10$ ft	560	220	110
	$L = 20$ ft	1120	440	220
	$L = 30$ ft	1680	660	330
	$L = 40$ ft	2240	880	440
	$L = 50$ ft	2800	1100	550

CRYSTAL RIVER #3	MADE 11/30/72	GILBERT ASSOCIATES, INC.		
	CHK'D.	ENGINEERS AND CONSULTANTS		
Main Steam By-Pass to Condenser #3A	DR. CF.	READING, PENNA.		
Main Steam to Feedwater Pump Turbine #3B	CF. DFM.	4202-007	WORK ORDER	SIZE DRAWING REV.
STEAM HAMMER RESTRAINTS	ENG. H. Z. LEE			
	REV. CH. APP. DATE			




11 Snubbers to be added.

CRYSTAL RIVER #3	MADE 11/20/73	GILBERT ASSOCIATES, INC.		
	CHE'S.	ENGINEERS AND CONSULTANTS		
Main Steam By-Pass to Condenser 3A	DR. CF.	READING, PENNA.		
	CF. DFN.	4203-027		
Main steam to Emergency Feedwater Pump	ENG. M. Z. Lee	WORK ORDER	SIZE	DRAWING
Turbine 3A STEAM HAMMER RESTRAINTS	REV. CH. APP. DATE			REV




10 Strubbers to be added

CRYSTAL RIVER #3	MADE 11/21/73	GILBERT ASSOCIATES, INC.		
	CHE'D.	ENGINEERS AND CONSULTANTS		
Main Steam Piping to #3A Moisture Separator Reheater Steam Hammer Restraints	BQ. CF.	READING, PENNA.		
	CF. DPK	#203-027		
	ENG. M. Z. Lee	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE			REV.




6 Snubbers to be added

CRYSTAL RIVER #3	MADE 11/20/73	GILBERT ASSOCIATES, INC.		
	CHE'S	ENGINEERS AND CONSULTANTS		
Main Steam Piping to Moisture Separator Reheater #3B Steam Hammer Restraints	DR. CP.	READING, PENNA.		
	CP. DFM.	4213-027		
	ENG. M. Z. Lee	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE			REV.



15 Snubbers to be added


CRYSTAL RIVER #3	MADE 11/21/72	GILBERT ASSOCIATES, INC.		
	CHE. B.	ENGINEERS AND CONSULTANTS		
Main Steam Piping to Moisture Separator Reheater #3C	DE. CP.	READING, PENNA.		
	CF. DPH.	4003-027		
Steam Hammer Restraints	ENG. M. Z. Lee	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE			REV.



Note: For illustration only. Dimensions given are approximate values.


5 Snubbers to be added

CRYSTAL RIVER #3	MADE 11/20/73	GILBERT ASSOCIATES, INC.		
	CHK'D.	ENGINEERS AND CONSULTANTS		
Main Steam Piping to #3D Moisture Separator Reheater Steam Hammer	SG. CP.	READING, PENNA.		
	CF. DFR.	4203-027		
Restrains	ENG. MZ Lep	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE			REV.




4 Snubbers to be added

CRYSTAL RIVER #3	MADE 11/21/73	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PENNA.		
	CHK'D.			
Main Steam Piping to Emergency F.W. Pump-Turbine Steam Header Restraints	RD. CF.	4203-027		
	CF. DFR.	ENG. M. Z. Lee	WORK ORDER	SIZE DRAWING
	REV. CK. APP. DATE			REV.




CRYSTAL RIVER #3	MADE "1/173	GILBERT ASSOCIATES, INC.		
	CHE'D.	ENGINEERS AND CONSULTANTS		
Main Steam Piping to Emergency F.W. Pump Turbine Steam Hammer Restraint	DR. CF.	READING, PENNA.		
	CF. DFM.	4003-007		
	ENG. M.Z. Lee	WORK ORDER	SIZE	DRAWING
	REV. CH. APP. DATE			REV



2 Snubbers to be added

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE S4203MS02 AD	
	PROJECT Crystal River #3	W.O.	PAGE 350F
SYSTEM Main Steam Piping	ORIGINATOR M. Z. Lee		DATE 11/2/73
CALCULATION FOR Steam Hammer	REVIEWER		DATE
References			RESULTS
[1] Coccio, C. L. Steam Hammer in Turbine Piping Systems. <u>Combustion</u> , Feb. 1967			
[2] Piping Stress Analysis File			
CR-3 CR-13			
CR-4 CR-14			
CR-5 CR-15			
CR 6 CR-16			

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE OF
SYSTEM	ORIGINATOR M. Z. Lee		
CALCULATION FOR	DATE 11/21/73		
	REVIEWER		
<p style="text-align: center;">Line CR-14 Section 13</p> 		DATE	
		RESULTS	

Stress at A₁ from computer output

Dead Load	504 psi
X-Y Quake	1309
Y-Z Quake	461

Pressure

$$\frac{PD}{4t} = \frac{1100 \times 24}{4 \times 0.968} = 6,820$$

Total 9,414

Provide a vertical snubber at B

$$\delta = \frac{Pl^3}{3EI}, \quad \sigma = \frac{M}{c} = \frac{MD}{2I}$$

$$\therefore \sigma = \frac{3}{2} \frac{ED}{l^2} \delta = \frac{90 \times 10^6 \times 24}{2 \times (17 \times 12)^2} \delta = 26,000 \delta$$

Suppose snubber locks up at $\frac{1}{4}$ " movement

$$\sigma = 26,000 \times \frac{1}{4} = 6,500$$

$$9,414 + 6,500 = 15,914 \approx 16,000$$

\therefore Snubber can be placed at B

GILBERT ASSOCIATES, INC.
TELEPHONE AND CONFERENCE MEMORANDUM

DATE 10/30/77 10:30 AM

BY: M. Z. Lee WORK ORDER NO. 4203-027

TELEPHONE CALL CONFERENCE

WITH: Khemlani 595-3936 (Crystal River Project)
System Engineer

COMPANY: Westinghouse, Lester office

SUBJECT: _____

NOTES: Request information on Main Steam Turbine
Emergency stop valve closing time for
Crystal River Unit #3.

Ans.

Total closing time = 250 milisec

Includes signal etc.

Value Travelling Time = 150 milisec

Copies To:

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE
SYSTEM	Crystal River #3	4203-027	OF
Calculation for	Main Steam Piping Inside Containment Bldg.	ORIGINATOR	M. Z Lee
		DATE	12/21/73
		REVIEWER	
		DATE	
		RESULTS	
Steam Hammer Restraints (Revised)			
Line CR-13			
1. Add one axial snubber on Sec. 10 (Ref. Fig. 2 of original Report) Capacity 30 Kips			
2. Modify MSH-151 to take 20 Kips upward force (Insert a saddle support between 24" pipe and 21WF67 above the pipe)			
Line CR-14			
1. Add a rigid vertical support near elbow of the vertical drop section upstream of MSH-152. Design Load 43 Kips downward 35 Kips upward			
Line CR-15			
1. Add one vertical snubber near the the elbow between Sec. 12 & 13. Capacity 30 Kips.			
2. Modify MSH-142 to take 44 Kips downward load 20 Kips upward load Desirable to move MSH-142 closer to elbow			
Line CR-16			
1. Add a 30 Kips axial snubber on Sec. 12			
2. Modify MSH-137 as recommended for MSH-142			

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE

Crystal River #3

4003-027 | *1* OF

SYSTEM	ORIGINATOR
--------	------------

Main Steam Piping Inside Containment Bldg

M Z Lop

CALCULATION FOR	DATE
-----------------	------

12/21/73

REVIEWER	DATE
----------	------


RESULTS

	<i>No. of Snubbers to be added</i>	<i>No. of Rigid Support to be Modified</i>
<i>CR-13</i>	<i>1</i>	<i>1</i>
<i>CR-14</i>		<i>1</i>
<i>CR-15</i>	<i>1</i>	<i>1</i>
<i>CR-16</i>	<i>1</i>	<i>1</i>
<i>Total</i>	<i>3</i>	<i>4</i>

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 2 OF
SYSTEM		ORIGINATOR	
CALCULATION FOR		DATE	
		REVIEWER	
		DATE	
		RESULTS	

CR-13

Sections Near Steam Gen



$$M_{A1} = 5.4 \text{ kips} \times 23.67' + 12.6 \text{ kips} \times 24' = 430 \text{ Kip-ft}$$

Bending stress at A1

$$S_b = \frac{M_{A1}}{Z} = \frac{430 \times 12}{388} = 13.3 \text{ Ksi} = 13,300 \text{ psi}$$

Combined Stress at A1 (p.10)

Vibration	1,309.2	2,618	(from Piping Stress code)
Dead Load		204	
Pressure		6,500	
Steam Hammer		13,800	
Total		22,242	> 18,000 = 1.2 S _b N.G.

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE																
	PROJECT	W.O.	PAGE 3 OF															
SYSTEM	ORIGINATOR																	
CALCULATION FOR	DATE																	
	REVIEWER																	
			DATE															
			RESULTS															
<p>Suppose an axial snubber is installed on Sec. 10</p> <p>Assume the snubber take up at movement $\delta_{10} = \frac{1}{4}''$</p> <p>Then $\delta_{11} = \frac{1}{4} \cdot \frac{1}{\cos 43.5^\circ} = 0.344''$</p> <p>Bending stress at A₁ corresponding to δ_{11} is</p> <p>$\sigma = 13,600 \delta_{11} = 13,600 \cdot 0.344 = 4,680 \text{ psi}$ (p.11)</p> <p>Combined Stress at A₁</p> <table> <tr> <td>Vibration</td> <td>2,618</td> <td></td> </tr> <tr> <td>Dead Load</td> <td>824</td> <td></td> </tr> <tr> <td>Pressure</td> <td>6,500</td> <td></td> </tr> <tr> <td>Steam Hammer</td> <td>4,680</td> <td></td> </tr> <tr> <td>Total</td> <td>14,622</td> <td>< 18,000 O.K.</td> </tr> </table> <p>Since $\sigma = 4,680 \ll S_b = 13,300$ with snubber without snubber</p> <p>and deflection < stress</p> <p>Without snubber sec. 10 may move axially</p> <p>$\frac{1}{4} \times \frac{13,300}{4680} = 0.71''$</p> <p>Therefore the snubber will be effective.</p>				Vibration	2,618		Dead Load	824		Pressure	6,500		Steam Hammer	4,680		Total	14,622	< 18,000 O.K.
Vibration	2,618																	
Dead Load	824																	
Pressure	6,500																	
Steam Hammer	4,680																	
Total	14,622	< 18,000 O.K.																

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 4 OF
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
<p style="font-size: 1.2em; text-align: center;"><i>Capacity of snubber on Sec. 10</i></p> $12.6 + 5.4 \frac{1}{\cos 43.5^\circ} = 12.6 + 6.5 = 19.1 \text{ Kips}$	REVIEWER		
	DATE		
	RESULTS		

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT

FILING CODE

PROJECT

W.O.

PAGE

5 OF

SYSTEM

ORIGINATOR

CALCULATION FOR

DATE


REVIEWER

CR-13

DATE

RESULTS

Vertical Drop to Penetration Anchor



MSH 151 operation load 31,300 lbs
structure Design Load 32,000 lbs

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE									
	PROJECT	W.O.	PAGE 6 of								
SYSTEM	ORIGINATOR										
CALCULATION FOR	DATE										
	REVIEWER										
	DATE										
<p>The effects of 11 Kips force on vertical drop section are obtained by Thermal Programs.</p> <p>1. MSH-151 will be subject to 16,000 Kips additional downward force</p> <p>Combined loads of MSH-151</p> <table> <tr> <td>Seismic</td> <td>2.045 Kips x 2</td> </tr> <tr> <td>Dead Wt</td> <td>4.9 Kips</td> </tr> <tr> <td>Steam Hammer</td> <td>16.006</td> </tr> <tr> <td>Total</td> <td>24.0 Kips</td> </tr> </table> <p style="text-align: right;">< 31.3 Kips hanger design load</p> <p>Δ MSH-151 can take downward steam hammer load.</p> <p>Δ MSH-151 must be modified to take 20 Kip upward load.</p> <p>From stress summary of CR-14 (without steam hammer load)</p> <p>$S_{max} = 10,817 \text{ psi}$</p> <p>Max stress due to steam hammer = 1,801 psi</p> <p>∴ $S'_{max} = 10,817 + 1,801 = 12,618 \text{ psi}$</p> <p style="text-align: right;">< 18,000 = 1.2 S_h</p>			Seismic	2.045 Kips x 2	Dead Wt	4.9 Kips	Steam Hammer	16.006	Total	24.0 Kips	RESULTS
Seismic	2.045 Kips x 2										
Dead Wt	4.9 Kips										
Steam Hammer	16.006										
Total	24.0 Kips										

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 7 OF
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
<p>CR-13 Conclusion</p> <ol style="list-style-type: none"> Add one axial snubben on Sec 10 Capacity 19.1 Kips min. use 30 Kip Modify MSH-151 to take 20 Kips upward force (Insert saddle support between 4" pipe and 21WF62 above the pipe) 			DATE
			RESULTS


FILING
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE																					
	PROJECT	W.O.	PAGE 8 OF																				
SYSTEM	ORIGINATOR																						
CALCULATION FOR	DATE																						
	REVIEWER																						
CR-14			DATE																				
Sec. 12 & Sec. 13 Near Steam Gen.			RESULTS																				
<p>Bending stress at A₁ due to 7 kips steam hammer load acting on sec. 12</p> $S_b = \frac{7000 \times 20.125 \times 12}{388} = 4,360 \text{ psi}$ $\delta = \frac{pl^3}{3EI} = \frac{7000 \times (20.125 \times 12)^3}{90 \times 10^6 \times 4653} = 0.23''$ <p>Combined stress at A₁</p> <table border="0"> <tr> <td>Dead Weight</td> <td></td> <td>925</td> <td></td> </tr> <tr> <td>Seismic</td> <td>1395 x 2</td> <td>2,610</td> <td></td> </tr> <tr> <td>Pressure</td> <td></td> <td>6,500</td> <td></td> </tr> <tr> <td>Steam Hammer</td> <td></td> <td>4,360</td> <td></td> </tr> <tr> <td>Total</td> <td></td> <td>14,295</td> <td>< 18,000 = 1.2 S_b</td> </tr> </table> <p>No additional restraint is needed.</p>				Dead Weight		925		Seismic	1395 x 2	2,610		Pressure		6,500		Steam Hammer		4,360		Total		14,295	< 18,000 = 1.2 S _b
Dead Weight		925																					
Seismic	1395 x 2	2,610																					
Pressure		6,500																					
Steam Hammer		4,360																					
Total		14,295	< 18,000 = 1.2 S _b																				

FILING CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.D.	PAGE 9 OF
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
	RESULTS		

CR-14
Sec. 10 & Sec. 11



Restrain Capacity of MSH-161 = 49.5 Kips

Axial Thrust along Sec. 10

$$= 15.2 \times \frac{1}{\cos 45^\circ} + 15.4 = 21.5 + 15.4 = 37 \text{ Kips} < 49.5$$

Assume movement of sec. 10 is $\frac{1}{4}$ " axial. Then

$$\text{Axial movement of Sec. 11} = \frac{1}{4} \cdot \frac{1}{\cos 45^\circ} = 0.354$$

Movement at g with MSH-159 acting as support:

Assume MSH-159 lock up at movement $\frac{3}{16}$ "

Then movement of g is

$$(0.354 - \frac{3}{16}) \times \frac{5.8}{6.1} = 0.168"$$

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 10 OF
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
	RESULTS		

Stress imposed on A1 due to movement of 8 in

$$\sigma = \frac{3 E d \delta}{2 l^2} = \frac{90 \times 10^6 \times 24}{2 \times (24.125 \times 12)^2} \delta = 18,300 \delta$$

$$= 18,300 \times 0.168 = 3,080 \text{ psi}$$

Combined stress at A1 (See Sec. 12)


$$14,395 + 3,080 = 17,475 \text{ psi} < 18,000 \text{ psi}$$

No additional support is required.

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 11 OF

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE
	RESULTS

CR-14



Case 1
Put 18.2 Kip downward force on Sec. 9 (Steam Hammer stress Prog. Case 2)
Stress at pt (36) = 8,074 psi

Combined stress at 26

Seismic	$1614 \times 2^{0.4}$	= 32,28	} 10,052	N.G
D.W		324		
Pressure		6,500		
Steam Hammer		8,074		
Total		18,126	$> 18,000 = 1.2 S_h$	

Loads on MSH-152

DW.	6.5 Kips	
Seismic	$10.05 \times 2 = 20.1$	
S. H.	58,278	
	84.9 Kip	
Str. Design load	15,450 lbs	N.G

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 12 OF
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
RESULTS			

Movement of Sec. 9 = 0.43"

Need a snubber on Sec. 9

Case 2
Suppose Sec. 9 moves $\frac{1}{4}$ " axially (Steam Hammer Load Case #2)

max S.H. stress = 4727 psi at pt 36

Combined $S_{max} = 10,052 + 4727 = 14,780$ psi
 $< 18,000 = 1.2 S_u$

Loads on MSH-152

DW	6.5
Seismic + S.H.	34.9 (with snubber on Sec. 9)
Total	41.4 kips down
	35 kips up

Case 4 A Better Design

- Add another support between MSH142 & elbow. Without snubber on vertical sec.
 max stress is
 2258 psi at pt 32 (New position of MSH-152)

FILING
CODE


GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 13 OF
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
<p><i>Load on Support at New Location</i></p> <p><i>Steam Hammer Load = 23.2 Kip</i></p> <p><i>D.L. 6.5 estimated</i></p> <p><i>Seismic 1.5 from MSN-142</i></p> <p><i>Thermo (negative) —</i></p> <p><i>Total 42 Kip downward</i></p> <p><i>35 Kip upward</i></p>			RESULTS

FILING
PAGE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.D.	PAGE 14 OF
SYSTEM	ORIGINATOR		
CALCULATION FOR	DATE		
	REVIEWER		
	DATE		
	RESULTS		

CR-14 Conclusion

1. Add a rigid support near elbow




Design Load 42 Kips tension
 35 Kips compr.

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 15 of

SYSTEM	ORIGINATOR
CALCULATION FOR	DATE
	REVIEWER
	DATE

CR-15

Sec 7 & Sec 8 (vertical drop)



Applied 14.4 kips on Sec. 8

max stress = 4,036 at pt 38
 $F_y = 20.2$ kips at MSH 142
 $\Delta y = +0.05''$ at MSH 141

Pipe stress at pt 38

Seismic	$1332 \times 2 = 2,664$
D.W.	884
Pressure	6,500
Steam Hammer	4,036
Total	$13,684 < 18,000 = 1.2 S_u$

Pipe is O.K

FILING CODE

SYSTEM _____

ORIGINATOR _____

CALCULATION FOR _____

DATE _____

REVIEWER _____

DATE _____


RESULTS _____

Support MSH-142 Loading

Seismic	$5.65 \times 2 = 11.3$	Kips
Dead Load	7.414	
Thermal (dd)	4.666	
Steam Hammer	20.2	
Total	43.58	downward

Upward load
 $20.2 + 11.3 - 7.4 - 4.6 = 20$ Kip upward

Case 2.
Suppose MSH-142 is located at 6" from the elbow



Load on MSH-142

Seismic	11.3
Dead Load	7.414
Thermal	4.666
Steam Hammer	17.38
Total	40.86

Piping Stress due to steam hammer decreased to 2955 from 4036 psi

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT

FILING CODE

PROJECT

W.O.

PAGE

17 OF

SYSTEM

ORIGINATOR

CALCULATION FOR

DATE


REVIEWER

DATE

RESULTS

CR-15

Secs 9 & 10



Load on MSH-167

$$\cong \frac{15.2}{\cos 45} + 18 = 21.5 + 18 = 40 \text{ kips}$$

Existing Seismic Snubber 49.5 kips

Bending stress in pipe at CH (20)

$$S_b = \frac{18,000 \times (8.4 \times 12)}{388} = 4,680 \text{ psi}$$

Seismic stress 87512 = 1,750

Pressure 6520

Dead Load (-)

Total 12,920 < 18,000 = 12.5%

FILING
CODE

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT

PROJECT

FILING CODE

W.O.

PAGE

18 OF

SYSTEM

ORIGINATOR

CALCULATION FOR

DATE


REVIEWER

DATE

RESULTS

CR-15

Sec. 11



Axial Thrust on Sec. 11

$$F = 8 + 5 \times 0.707 + 15.2 \times 0.707 = 22.3 \text{ kips}$$

$$\cos \theta_1 = 0.817 \quad \cos \theta_2 = 0.595$$

Load on Snubber


$$= \frac{F}{\cos \theta_1 \cos \theta_2} = \frac{22.3}{0.817 \times 0.595} = 46 \text{ kips}$$

Existing Snubber MSH-166 is sized to 49.5 kips

FILING
CODE

SYSTEM _____	ORIGINATOR _____
CALCULATION FOR _____	DATE _____
	REVIEWER _____

CR-15



Vertical Component of 5 Kip thrust on sec 12

$$F_v = 5 \times 0.707 = 3.5 \text{ Kips}$$

Bending Stress at A1 due to Fv

$$S_b = \frac{F_v \times (16.25 \times 12)}{8} = \frac{3,500 \times 16.25 \times 12}{388}$$

$$= 1,760$$

Combined Stress at A1

Seismic	5104 x 2	= 10,208
Dead WT		1,110
Pressure		6,200
Steam Hammer		1,760
Total		19,578 > 18,000
		= 1.2 Sh

N.G

Need additional restraint

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE								
	PROJECT									
SYSTEM	W.O.	PAGE 20 OF								
CALCULATION FOR	ORIGINATOR	DATE								
	REVIEWER	DATE								
CR-15.		RESULTS								
<p>If a vertical snubber is placed at B. and locks up at 1/4", then</p> $\sigma = \frac{3}{2} \frac{E d}{l^2} \delta = \frac{3}{2} \frac{30000 \times 24}{(16.26 \times 12)^2} \delta = 28,400 \delta$ $= 28,400 \times \frac{1}{4} = 7,100 \text{ psi}$ <p>Combined stress at A₁ is</p> <table> <tr> <td>Dead wt</td> <td>1,110</td> </tr> <tr> <td>Pressure</td> <td>6,500</td> </tr> <tr> <td>Steam Hammer & Seismic (1/4" snubber movement)</td> <td>7,100</td> </tr> <tr> <td>Total</td> <td>14,710 < 18,000 = 1.2 Sn</td> </tr> </table> <p>Load Capacity of snubber</p> <p>Assume: Seismic stress at A₁ is caused by a concentrated load at B (F_s)</p> $F_s = \frac{S_b Z}{L} = \frac{5104 \times 388}{16.25 \times 12} = 10,200$ $F_s + F_v = 10.2 + 3.5 \approx 14 \text{ Kips. (min)}$			Dead wt	1,110	Pressure	6,500	Steam Hammer & Seismic (1/4" snubber movement)	7,100	Total	14,710 < 18,000 = 1.2 Sn
Dead wt	1,110									
Pressure	6,500									
Steam Hammer & Seismic (1/4" snubber movement)	7,100									
Total	14,710 < 18,000 = 1.2 Sn									

FILING

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 21 OF
SYSTEM	ORIGINATOR		
CALCULATION FOR CR-15	DATE		
	REVIEWER		
	DATE		
RESULTS			
Conclusion			
1. Add one vertical snubber near the elbow between Sec. 12 & 13. Capacity 30 Kips			
2. Modify MSH-42: 44 Kip downward load 20 Kip upward "			
Both pipe stress & support load will be decreased by moving MSH-42 closer to elbow.			


FILING CODE

SYSTEM _____	ORIGINATOR _____
--------------	------------------

CALCULATION FOR _____	DATE _____
	REVIEWER _____

<i>CR-16</i>	DATE _____
--------------	------------

<i>Sec 12 & Sec 13 Near Steam Gen</i>	RESULTS _____
---	---------------



Stresses at A1 (Piping stress program)

<i>Seismic</i>	1.132×2	$= 2.264$
<i>Pressure</i>		6.500
<i>D.L.</i>		405
<i>Total</i>		$9,170$

Axial force on Sec 12

$$P = 15.2 + 16.6 \cos 45^\circ = 26.9$$

Deflection at B

$$\delta = \frac{P L^3}{3 E I} = \frac{26,900 \times (17 \times 12)^3}{3 \times 29 \times 10^6 \times 4653} = 0.545''$$

$$\sigma = \frac{P L}{S} = \frac{26,900 \times (17 \times 12)}{388} = 14,100 \text{ psi}$$

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT	FILING CODE	
	PROJECT	W.O.	PAGE 23 OF

SYSTEM	ORIGINATOR
--------	------------

CALCULATION FOR	DATE
	REVIEWER

	DATE
--	------

	RESULTS
--	---------

CR-16
Combined Stress at A₁

$$S_{max} = 14,100 + 9,170 = 23,270$$

$$> 18,000 = 1.2 S_h$$

Need restraint on Sec. 12.

$$\text{Snubber Capacity} = 30 \text{ Kips}$$

Suppose the snubber stops movement of B within 1/4"

$$\sigma = \frac{3}{2} \frac{E\delta}{L^2} \delta = \frac{3}{2} \frac{30 \times 10^6 \times 0.25}{(17 \times 12)^2} \delta = 23,100 \delta$$

$$= 23,100 \times \frac{1}{4} = 5,780 \text{ psi at } A_1$$

Combined stress at A₁ is

$$S_{max} = 5,780 + 9,170 = 14,950$$

$$< 18,000 = 1.2 S_h$$

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT
PROJECT

FILING CODE

W.O. PAGE
24 OF

SYSTEM

ORIGINATOR

CALCULATION FOR

DATE


REVIEWER

DATE

RESULTS

CR-16

Sec. 11



$$\cos \theta_h = \frac{5.25}{5.4} = 0.971 \quad \cos \theta_v = \frac{5.25}{5.65} = 0.9$$

$$F_x = 16.6 \text{ Kips}$$

Load on MSH-170 due to F_x

$$= F_x \frac{1}{\cos \theta_h \cos \theta_v} = 16.6 \frac{1}{0.971 \times 0.9} = 22.4 \text{ Kips}$$

$$\text{Existing Capacity } 49.5 \text{ Kips} > 22.4 \text{ Kips}$$

GILBERT ASSOCIATES, INC.
ENGINEERS AND CONSULTANTS
READING, PA.

CLIENT

FILING CODE

PROJECT

W.D.

PAGE

25 OF

SYSTEM

ORIGINATOR

CALCULATION FOR

DATE


REVIEWER

DATE

RESULTS

CR-16

Sec. 10 (vertical drop)



Since the layout is close to that of CR-15 and with smaller axial thrust on the vertical section, the modification of MSH-142 on CR-15 can be applied to MSH-137.

FILING
CODE

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS READING, PA.	CLIENT _____	FILING CODE _____	
	PROJECT _____	W.O. _____	PAGE 26 of
SYSTEM _____	ORIGINATOR _____		
CALCULATION FOR	DATE _____		
	REVIEWER _____		
CR-16	DATE _____		
RESULTS			
<i>Conclusion</i>			
1. Add one snubber on Sec. 12 (20 Kips)			
2. Modify MSH-137 as recommended for MSH-142 of CR-15			