



Public Service Electric and Gas Company 80 Park Place Newark, N.J. 07101 Phone 201 430-7000

March 3, 1980

Mr. Albert Schwencer, Chief
Operating Reactor Branch #1
Division of Operating Reactors
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Gentlemen:

DEGRADED GRID VOLTAGE PROTECTION (70-90%)
SUPPLEMENTAL INFORMATION
SALEM GENERATING STATION
UNITS NO. 1 AND 2
DOCKET NO. 50-272


The enclosures attached to this letter are submitted in response to your questions about the degraded grid voltage protection at Salem. Since the October, 1979 meeting with the NRC staff, questions about the proposed design for a second level of undervoltage protection have been received and are addressed in Enclosure 1. Enclosure 2 contains related information requested by Mr. W. Ross during the October, 1979 meeting.

If you have any questions, please do not hesitate to contact us.

Very truly yours,

Frank P. Librizzi
General Manager -
Electric Production

Attachments



8003110 512 P

A015
3/11

ENCLOSURE 1

1. The onsite distribution system for each unit at Salem is arranged so that two vital buses are connected to one station power transformer and the third is connected to the other station power transformer (FSAR figure 8.3.1). The in-feed breakers for each vital bus from the two station power transformers are electrically interlocked to prevent paralleling both sources through a vital bus. The breakers also provide the means for transferring between sources in the event of an interruption of power from one source.

Undervoltage protection for each vital bus will be provided by two protective relay groups. One group is designed to protect the vital buses if bus supply voltage falls below 70% of its rated value. This group is already installed and operable. The other group will be designed to protect the vital buses if bus supply voltage falls below 91% of its rated value.

Each undervoltage protection group is/will be comprised of two sets of relays:

- A set for undervoltage transfer, and

- A set for generating "Blackout" signals.

The 91% group will be comprised of adjustable time delay relays. The protective relays will be connected to the electrical system in the same manner and location as the present undervoltage protection. The new design essentially duplicates the present protective scheme in all regards (Attachment A) with the following exception.

The 91% relays will be equipped with an administratively controlled lockout which will allow the control room operator to disarm the system during the start of any reactor coolant pump. This feature is required to forestall any unnecessary undervoltage signals due to the voltage transient caused by a reactor coolant pump start. The lack of this manual lockout feature would require that an extended time delay (30 seconds) be used to actuate the 91% relays. The system will be armed by the control room operator upon completion of any RCP start, and will remain armed under all conditions other than a RCP start. The disarming and rearming of the system will become an integral part of the RCP starting

procedures used at Salem and an alarm will be provided for the disarmed condition. In addition to manual re-arming, a timer will be provided to automatically rearm the system in the event the control room operator neglects to do so after a RCP has been started.

The time delay of the 91% undervoltage transfer relays will be 10.5 seconds when the output of the station power transformers is below 91% of its rated value (Figure 1).

The time delay of the 91% bus "blackout" relays will be 13 seconds when the voltage on the affected bus (or buses) is below 91% of rated value (Figure 1).

In the event the supply voltage to a 4 KV vital bus or buses falls below 91% of its rated voltage, the affected bus or buses will be automatically transferred to the alternate source by the action of the vital bus transfer relay (XET-230, Fig. 1) and the 91% transfer relays after a 10.5 second time delay.

The following conditions must be met before a bus transfer may be accomplished at either low-voltage condition:

- a. The bus differential or overload relays have not operated.
- b. Voltage on the affected bus or buses is below 35% (this permissive prevents transfer with excessive out-of-phase residual bus voltage).
- c. The in-feed breaker of the normal supply is opened.
- d. The related diesel-generator circuit breaker is open.
- e. The alternate source voltage is above 91%.
- f. The SEC (Safeguards Equipment Control) bus undervoltage (blackout) relays have not operated.

For both groups (70% and 91%), the undervoltage and vital bus (XET-230) transfer relays allow the affected bus or buses to be transferred to the remaining station power transformer before the bus blackout relays are tripped.

If the supply voltage to the vital buses falls below 70% of rated voltage and a transfer is not accomplished, the 70% blackout relays will provide a signal to start the diesel-generators. If the supply voltage to the vital buses falls below 91% of rated voltage and a transfer is not accomplished, the 91% bus blackout relays will provide a signal to start the diesel-generators.

Undervoltage signals generated by either set of blackout relays will be combined (through the use of buffer relays) in a 2/3 logic matrix per bus to develop a blackout loading signal for that bus. The buffer relays will be used on each vital bus undervoltage sensor to supply independent signals to each SEC unit to maintain independence among the three buses.

If the output voltage of a station power transformer supplying one vital bus falls to 70% of its rated value and the transfer mechanism fails, the 70% blackout relay for that bus will generate a signal which results in a 1/3 condition at each SEC controller. The Salem design is such that a loss of one vital bus is tolerable for all normal operating conditions; therefore, no automatic equipment actuation will take place for this condition. This design will also apply to the new 91% protective relays. For a postulated LOCA, this criterion will not apply. A postulated LOCA concurrent with an undervoltage condition on one vital bus is discussed in the response to question 5.

2. The proposed design will employ test switches which can be used in conjunction with any external equipment (variable power supply, etc.) necessary for proper calibration and testing.

Technical specifications similar to those for the existing undervoltage protection will be generated upon the Staff's approval of the proposed design.

3. Since this design is a duplicate of the present undervoltage protection system (except for the administrative controls), it will meet the necessary criteria for protection and control of Class 1E equipment (IEEE 279-1971).

4. If a LOCA concurrent with a voltage degradation which reduces the output of both station power transformers to between 90% and 70% of rated voltage is postulated, the SEC system will react only to the LOCA while the 91% transfer relays are timing out. The time for the relays to actuate will be 10.5 seconds.

While the relays are timing out, the SEC system will perform the following functions:

- a. Start the diesel-generator units.
- b. Lockout manual control of equipment circuit breakers until the required loads are connected to the vital buses.
- c. Connect all required accident loads.

The diesel-generators are started automatically so as to be available in the event they are subsequently required. They are not automatically connected to the vital buses.

The ability of the safeguards motors to start and carry their designated loads under degraded voltage conditions is described in Attachment B. The safeguards motors are capable of withstanding degraded voltage conditions for the times under consideration without suffering any thermal damage.

When the 91% transfer relays time out (10.5 seconds), the transfer will not take place because the station power transformer potential relays will not generate a permissive. Therefore, the 91% blackout relays will be allowed to time out (in an additional 2.5 seconds), and a blackout signal will be generated. When the blackout signal is generated, the SEC will automatically shift modes from that for a LOCA (Mode I) to that for a LOCA plus blackout (Mode III). The shift of modes will require less time than the recognition and action required to combat only a blackout due to the "ready" status of the diesel-generators.

The above mentioned sequence of operations will take place within the required time limits to successfully mitigate the consequences of a LOCA. A delay time of 15 seconds between the occurrence of the incident and the application of power to the first sequenced safeguards pumps was assumed in the original LOCA analysis.

Although regarded as extremely unlikely, it may be postulated that one station power transformer may suffer a voltage degradation which reduces its output voltage to between 90% and 70% of its rated value while the output of the remaining station power transformer is reduced to just above 91% of rated voltage. Under these conditions, one set of 91% transfer relays will begin timing out while the other set "sees" no abnormal conditions. It may be possible to reduce the output voltage of the "normal" transformer to below 91% of its rated value after the transfer from the affected transformer takes place. Also, the output voltage of the initially affected transformer may rise above 91% of its rated value due to its partial unloading. These voltage changes will not amount to more than 3% for each transformer. Consequently, the 91% transfer relays for the alternate transformer will begin timing out and would effect a subsequent transfer at the end of an additional 10.5 seconds. These conditions would result in a continual flip-flop condition causing intermittent power interruptions on the vital buses.

This action will be prevented by the installation of 91% blackout relays which have a 95% reset setting. The 91% blackout relays began timing out at the same time as the 91% transfer relays on the initially affected transformer. Since their time delay will be 2.5 seconds longer than that of the transfer relays, and if the transfer does not successfully raise the bus voltage above 95%, the bus relays will initiate separation of the bus from both transformers. The reset setting of 95% on the transfer relays will also ensure that the buses do not continually transfer from one source to the other.

The interlocks and permissives utilized in the transfer of buses are described in Item 1.

5. In the event a LOCA occurs concurrent with a voltage level on one vital bus below 90% and above 70% of rated voltage, the SEC response will be the same as that explained in Item 4 while the 91% transfer relays are timing out. Once the relays have timed out, a transfer to the alternate source will take place.

If the transfer mechanism fails, a blackout signal will be generated for the affected bus and the SEC will automatically shift from a Mode I (LOCA) to a Mode IV (LOCA plus one vital bus undervoltage) condition, whereby only the affected bus is connected to its diesel-generator. The other two buses will remain connected to offsite power.

If a LOCA occurs concurrent with a degraded voltage condition on two of the three vital buses which reduces the bus voltages to between 90% and 70% of rated voltage, the SEC will react as explained in Item 4 while the 91% transfer relays are timing out. Once the relays time out, the buses will be transferred to their alternate source.

If the transfer mechanism fails, a blackout signal will be generated and the SEC will automatically shift from a Mode I (LOCA) to a Mode III (LOCA plus blackout) condition, whereby all three vital buses will be shifted to diesel-generator power.

For both postulated conditions, the safeguards motors on the affected bus or buses will be subjected to degraded voltage conditions for no more than 13 seconds. Their ability to start and maintain operation (or to withstand a postulated voltage degradation which prevents starting) during the period prior to bus transfer, and the acceptability of the time delays involved are explained in Item 4.

6. The characteristics of AC contactors and associated control fuses are described in Attachment B.
7. With regard to Staff's suggestions of utilizing only bus blackout relays in the proposed design (no attempted transfer), the following scenario is presented.

The existing diesel starting and sequence loading logic is located in the Safeguards Equipment Control (SEC) system associated with each bus. The plant design is predicated on each SEC performing the master decision making and resultant actions associated with bus loading. To make use of this existing logic with the design suggested, would require paralleling the existing bus under-voltage inputs and the proposed secondary bus under-voltage relays.

Assuming an initial system configuration of two buses being supplied from one station power transformer (assume #11) and the remaining bus powered by #12 SPT, a degraded voltage condition on #11 SPT side, coupled with a single failure within the bus voltage monitoring logic, could result in the following condition:

Bus "A" operating with degraded voltage due to failure in monitoring logic.

Bus "B" operating with degraded voltage due to lack of required coincident logic in SEC (failure cascaded from failure in Bus "A" circuits).

Bus "C" operating at normal voltage supplied from #12 SPT.

The above scenario assumed that no condition exists which would generate a Safety Injection (SI) signal. If an SI signal were to exist during this occurrence, the following system configuration would result:


Bus "A" could attempt to block load all ESF loads during a degraded voltage situation. This would most likely result in a further bus voltage degradation to below 70% and cause the diesel to start and commence sequential loading via the SEC.

Bus "B" would follow the sequence of events described in Item 5 for a postulated LOCA concurrent with a voltage degradation on one vital bus.

Bus "C" would "block load" the ESF loads on the normal supply from the #12 SPT.

The sequence described for the case of "No SI Signal" is unacceptable. The proposed design which includes an attempted transfer, precludes that sequence of events and ensures that at least two buses are capable of supplying the needed equipment.

ATTACHMENT A




| | |
|---|-----------|
| PUBLIC SERVICE ELECTRIC AND GAS COMPANY | |
| SALEM NUCLEAR GENERATING STATION | |
| FSAN | 718.8.5-1 |
| AUXILIARY POWER SYSTEM DIAGRAM | |

POOR ORIGINAL

FIGURE 1

SALEM NUCLEAR GENERATING STATION
 4KV VITAL BUS U.V. PROTECTION AND
 TRANSFER CHARACTERISTIC CURVES



PSE&G

Public Service
Electric and Gas
Company

| | |
|---------------------|------|
| ELECTRICAL DIVISION | |
| HRP | PRHL |
| OCT 12 1979 | |
| FFK | JB |
| WU | KOH |
| KC | RWM |
| EL | VJ |
| DJH | FILE |

WSR

October 10, 1979

ATTACHMENT B

| | |
|----------------------------------|--|
| GENERAL MANAGER - ENCL. 10 | |
| ENGINEERING AND TESTING DIVISION | |
| R. R. EAST | |
| OCT 12 1979 | |
| <input type="checkbox"/> MC | <input type="checkbox"/> ROR |
| <input type="checkbox"/> RAA | <input checked="" type="checkbox"/> GY/C |
| <input type="checkbox"/> JJK | <input type="checkbox"/> FAC |
| <input type="checkbox"/> VDD | <input type="checkbox"/> |
| <input type="checkbox"/> PRHL | <input type="checkbox"/> |

Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Attention: Mr. William Gammill, Acting Assistant Director
for Operating Reactors Projects
Division of Operating Reactors

Gentlemen:

ADEQUACY OF STATION ELECTRIC DISTRIBUTION SYSTEM VOLTAGES - SALEM GENERATING STATION UNITS NOS. 1 AND 2

We have performed the analysis on the Salem Generating Station Units Nos. 1 and 2 electric power system in accordance with NRC letter, Adequacy of Station Electric Distribution System Voltages dated August 8, 1979 and its enclosures.

The analysis demonstrates that the offsite power system and the onsite distribution system is of sufficient capacity and capability to automatically start as well as operate all safety loads within their voltage ratings for all anticipated transients and accidents.

Satisfactory results were obtained as a result of the original design considerations. The Salem Generating Station was designed such that the resulting voltage profile was within component voltage limitations, being +5% of transformer secondary voltage and -10% of motor nameplate voltage under steady-state conditions. The system was also designed such that the inrush current associated with the start of a 6000 horsepower, 4.0 kV motor would not cause the bus voltages to drop below 80%. All motors are designed to accelerate their driven equipment with at least 80% motor nameplate voltage applied to its terminals. This was accomplished by optimum selection of transformer impedances, incorporation of no-load taps on all power and unit substation transformers, and a +10% automatic load tap changer on all the 13.8/4.16 station power transformers. All motor starters have a guaranteed drop out voltage of 70%. All starters were bought with 300 VA control power transformers, regardless of NEMA size, to minimize voltage drop at the contactor coil. Further, consideration was given to cable size and length to limit voltage drop in a feeder.

The analysis showed the worse sustained under-voltage condition imposed upon the distribution system occurred with a severely degraded 500kV offsite system simultaneous with a concurrent LOCA on Unit 2 and Unit trip on Unit 1 (or vice versa). This under-voltage condition results from the automatic transfer of the group buses from the auxiliary power transformers to the station power transformer and the automatic start of the required vital bus loads. For this condition the lowest voltages at the 4.16 kV, 460V and 230V loads were .917, .923 and .91 per unit respectively. The above analysis indicates that the onsite distribution system and its components will operate within component voltage limitations. The motors are the limiting component under steady-state conditions as they are designed to run continuously at .9 per unit nameplate voltage.

Transient voltage drops due to the starting of motors were analyzed at each voltage level with no adverse effects. This analysis assumed the prestart voltage to be that corresponding to the degraded 500 kV system and the load in parallel with the motor being started equal to the maximum continuous rating of the transformer to which it is connected less the running load of the motor being started. Further, the impedance of the parallel load was conservatively assumed to decrease as the square of the bus voltage to analytically compensate for the additional current drawn by induction motors upon decrease in voltage. The minimum transient voltages obtained on the 4.16 kV, 460V and 230V levels were .86, .86 and .78 per unit, respectively for a duration of approximately 5 seconds. These transients are within motor and motor starter design capabilities, thereby having no adverse effect on system operation. The results of this analysis were used to reexamine under-voltage protective settings and establish that no spurious separations of the safety buses from offsite power would occur.

The 5 kV power cables that connect the 13.8/4.16 kV station power transformers to the group and vital buses are the load limiting component in the distribution system. The sixteen hour rating of the cable is utilized for the load that results from the concurrent LOCA Unit 2 and Unit trip on Unit 1. There is sufficient margin between the cable rating and the resultant load to allow for implementation of existing station procedures used during the events analyzed and thus, avoid overloading.

As indicated in the NRC letter of August 8, 1979, tests had been previously run to correlate calculations with field conditions. With Salem Units 1 and 2 and the 500 kV system in an existing mode corresponding to a given loading of the plant distribution system, selected system parameters were monitored over a 24-hour period. An analysis was then performed using the actual load and 500 kV system voltage to obtain a calculated voltage profile and compare to actual measurements. The calculations and field measurements correlated within very reasonable accuracy, thus

POOR ORIGINAL

substantiating our assumptions and the method of calculation. The results are given in Attachment 1. Further, a test on a cold 6000 horsepower, 4.0 kV reactor coolant pump motor was conducted. The bus voltage dropped 15% upon start of this motor. No adverse effects were observed on other operating equipment. The results of this test substantiate the original plant design basis.

The electric power system was reviewed to determine if there are any events or conditions which could result in the simultaneous or consequential loss of required circuits to the offsite network that would violate GDC-17. No potential exists for violation of GDC-17.

If you should have any questions, please do not hesitate to contact us.

Very truly yours,

F. P. Librizzi
Frank P. Librizzi
General Manager -
Electric Production


11/2/80
GLS:hs *[Signature]*

- CC Gen'l Mgr. - Enng.
- Proj. Licensing Mgr. - Salem
- Asst. Gen'l. Solicitor
- Mgr. - Nuc. Oper.
- Mgr. - Plant Maint.
- Mgr. - Salem
- SQAE - Salem
- EPD-QAE
- P. A. Moeller
- N. R. Philipp

Attachment

POOR ORIGINAL

SALEM GENERATING STATION, UNIT 2
 VOLTAGE PROFILE
 FIELD MEASUREMENTS VS. CALCULATIONS



ATTACHMENT 1
 To Response to NRC Letter
 Agency of Station Electric Distribution
 System Voltage - Dated August 8, 1979

Salem 1 & 2
Proposed Design of Degraded
Grid Voltage Protection (70%-90%)

It is our understanding that the proposed design involves addition of UV relays for 90% trip (with appropriate time delays) essentially paralleling the existing 70% loss-of-voltage UV trip scheme. The proposed design, as described during our recent meeting, appears to meet existing criteria. However, we have some concern with its complexity, and particularly with the time delays associated with the automatic bus transfers between the two auxiliary transformers and onto the emergency diesel generators. Therefore, your detailed description of the scheme should specifically include the following:

- 1) For each relay: the number, type, location in the electrical system, set point, associated time delay, actuation logic(s) and function(s) performed.
- 2) A description of the testability of the system and the associated technical specification requirements.
- 3) A positive statement regarding conformance with specific applicable criteria.
- 4) A description of the operation of the UV trip system and the ESF loads assuming a LOCA with concurrent voltage degradation (between 70% and 90%) at the output of both auxiliary (offsite power) transformers; specifically address (1) all interlocks and permissives including the provisions for preventing repetitive auxiliary

POOR ORIGINAL

Bus transfers between auxiliary transformers and transfers with excessive out-of-phase residual bus voltage, and (2) the acceptability of the time delays involved with regard to both accident mitigation and the capability of electrical equipment to operate at degraded voltage for those periods without damage.

- 5) A description as in item (4) except that voltage degradation is assumed to occur at the output of only one auxiliary power transformer.
- 6) A description specifically addressing the operability of AC contactors and the associated control fuses under degraded voltage for the time delay intervals involved.
- 7) The reasons why a less complex design with only one set of BV relays (90% trip with 40 sec. delay) at the emergency buses to initiate trip of offsite power and annihilation of the diesel's cannot or should not be used instead of the proposed scheme.

POOR ORIGINAL

ENCLOSURE 2

SYNOPSIS

Analysis was performed on the Salem Station Electric Distribution System in accordance with NRC letter dated August 8, 1979 and its enclosures (Appendix 1). The following summarizes the results of such analyses. This response serves as the discussion to the results.

The analysis were performed with margin to avoid repetition of this calculation to the future changes. The greatest voltage drop imposed upon the distribution system would be with a severely degraded 500 kV system that results in the minimum expected voltage at Salem simultaneous with the load resulting from a unit trip on No. 1 and a LOCA on Unit 2. The analysis was very conservative as discussed herein. Assumptions made in the load and voltage profile are given.

WSR:bm

701 47-A

CONTENTS

SYNOPSIS

| | | |
|---------------|---|--------|
| APPENDIX I: | NRC letter dated 8/22/79 and PSE&G response | |
| APPENDIX II: | Load Tabulation | Page |
| | Purpose | 1 |
| | Results | 1 |
| | Method and Assumptions | 2 |
| | Load Profile | 3 |
| | Component Load Limitation | 4 |
| | One Line | 5 |
| | Motor Operational Information | 6-11 |
| | Calculations | 12-16 |
| APPENDIX III: | Voltage Profile | |
| | General | 17 |
| | Summary of Results | 18-19 |
| | Discussion | 20 |
| | Component Voltage Limitations | 21 |
| | Voltage Profiles | 22-26 |
| | One Line | 27 |
| | 4160V Profile | 28-35 |
| | Reactor Coolant Pump Start | 36-43 |
| | 460V Profile | 44-48 |
| | 230V Profile | 49-54 |
| | Light Load | 55-57 |
| | RCP Starting Time | 58-61 |
| | Correlation of Field Test Data and Calculations | 62-71 |
| APPENDIX IV: | Relay Coordination | 72-87 |
| APPENDIX V: | Supplement Information and References | 88-137 |

1951

POOR ORIGINAL

PSE&G

Public Service Electric and Gas Company 80 Park Place Newark, N.J. 07101 Phone 201/430-7000

August 22, 1979

*Follow-up
Due By 9/30*

WJR

WJ

WJ

AUG 27 1979

To the Chief Electrical Engineer
Engineering and Construction Department

NRC LETTER DATED AUGUST 8, 1979
ADEQUACY OF STATION ELECTRIC
DISTRIBUTION SYSTEMS VOLTAGES

The NRC letter dated August 8, 1979, with the above title, requires that all licensees review the electric power systems at each of their nuclear power plants to determine analytically if the off-site power systems and on-site distribution system is of sufficient capacity and capability to automatically start as well as operate all required safety loads.

Please make the necessary analysis to comply with the letter, copy attached. This response is due to the NRC within sixty (60) days of the date of the letter. Please have your analysis completed and a response sent to us for concurrence by October 1, 1979.

6

[Signature]
Manager - Plant Maintenance

EMC:kls

CC Mgr. - Nuclear Operations
Electrical Plant Engineer





MOR.-NUCLEAR OPERATIONS

S.M.

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

REC'D AUG 20 1979
To: Mr. [unclear]
From: [unclear]
Subject: [unclear]

August 8, 1979

All Power Reactor Licensees (Except Humboldt Bay)

RE: ADEQUACY OF STATION ELECTRIC DISTRIBUTION SYSTEMS VOLTAGES

We are currently reviewing the licensee's submittals in response to the NRC generic letter of June 2, 1977 regarding undervoltage protection of the safety related electric equipment from loss of capability of redundant safety loads, their control circuitry, and associated electrical components required for performing safety functions as a result of sustained degraded voltage from the offsite electric grid system. This generic action was based on the Millstone Event which occurred on July 5, 1976.

The recent event at the Arkansas Nuclear One (ANO) station on September 16, 1978 brought into question the conformance of the station electric distribution system to GDC-17, in two separate regards. Each of two units at the ANO station has a dedicated startup transformer powered through a single shared autotransformer (common source of offsite power) from the station switchyard. Operation of an autotransformer overcurrent relay caused the loss of the two dedicated startup transformers. The station electrical distribution system thus automatically transferred the full auxiliary loads of both units to the backup startup transformer exceeding its rated capacity and degrading the voltage level at the safety buses. Secondly, during our review of the electrical system at the ANO station, the licensee's analysis indicated that the "immediate access offsite power circuit" (dedicated startup transformer) lacked "sufficient capacity and capability" to accommodate the simultaneous starting demands of the emergency loads concurrent with the full house loads, in the event of a loss of coolant accident (LOCA). The condition would result in all safety loads remaining on the dedicated startup transformer with unacceptably degraded voltage. A voltage degradation during the electrical starting condition becomes a safety concern either if the degradation causes the starting condition to be prolonged so as to become a sustained undervoltage or if the voltage degradation causes frequent spurious shedding of the ESF loads from the preferred power source, the offsite electric grid. This event was described in NRC's IE Information Notice No. 79-04. Additional background information is provided in Enclosure 1.

The IE Information Notice No. 79-04 stated that NRC would follow with specific actions to be taken by licensees. This letter identifies those actions.

Based on the ANO event, the NRC has expanded its generic review of the adequacy of the electric power systems for all operating nuclear power facilities. Specifically, we must now confirm the acceptability of the voltage conditions on the station electric distribution systems with regard to both (1) potential overloading due to transfers of either safety or non-safety loads, and (2) potential starting transient problems in addition to the concerns expressed in our June 2, 1977 correspondence with regard to degraded voltage conditions due to conditions originating on the grid.

Based on the experience at ANO, the NRC is requiring all licensees to review the electric power systems at each of their nuclear power plants to determine analytically if, assuming all onsite sources of AC power are not available, the offsite power system and the onsite distribution system is of sufficient capacity and capability to automatically start as well as operate all required safety loads. Within their required voltage ratings in the event of (1) an anticipated transient (such as unit trip) or (2) an accident (such as a LOCA) regardless of other actions the electric power system is designed to automatically initiate and without the need for manual shedding of any electric loads. Protection of safety loads from undervoltage conditions must be designed to provide the required protection without causing voltages in excess of maximum voltage ratings of safety loads and without causing spurious separations of safety buses from offsite power. NRC should be informed of any required sequential loading of any portion of the offsite power system or the onsite distribution system which is needed to assure that power provided to all safety loads is within required voltage limits for these safety loads. Guidance on evaluating the performance of electric power systems with regard to voltage drops is provided in Enclosure 2.


The adequacy of the onsite distribution of power from the offsite circuits shall be verified by test to assure that analysis results are valid. Please provide: (1) a description of the method for performing this verification, and (2) the test results. If previous tests verify the results of the analysis, then test results should be submitted and additional tests need not be performed.

In addition, you are requested to review the electric power systems of your nuclear station to determine if there are any events or conditions which could result in the simultaneous or consequential loss of both required circuits to the offsite network to determine if any potential exists for violation of GDC-17 in this regard. These reviews should be completed, and a copy of the analyses provided to NRC within 60 days of the date of this letter.

In the event that any violation or potential violations of GDC-17 or voltage requirements of safety loads are discovered remedial action should be taken immediately. You should provide the Commission with Prompt Notification with Written Followup pursuant to the reporting requirements of your Technical Specifications.

If the above required reviews have been completed by you as part of your response to our June 2, 1977 request, NRC should be informed within 30 days of the date of this letter. Approved by GAO, B-180225 (R0072), clearance expires 7/31/80. Approval was given under a blanket clearance specifically for identified generic problems.

Sincerely,



William Gammill, Acting Assistant Director
for Operating Reactors Projects
Division of Operating Reactors

Enclosures:

1. Background Information on ANO Event
2. Guidelines for Voltage Drop Calculations

cc: Service List

BACKGROUND INFORMATION ON ANO EVENT

The event that occurred at the Arkansas Nuclear One station on September 16, 1978, brought into question the conformance of the station electric distribution system design to GDC-17 with regard to the capacity and the capability of the onsite systems.

Each of two units at the ANO station has a dedicated startup transformer connected to a single shared autotransformer (common source of offsite power) from the station switchyard. The incident was initiated by Unit 1 reactor trip concurrent with trip of the unit's turbine-generator. The Unit 1 auxiliary loads were automatically transferred to Startup Transformer 1. The power being supplied to Startup Transformer 3 (Unit 2 dedicated startup transformer), which was feeding Unit 2, and being supplied to Startup Transformer 1 resulted in operation of an autotransformer overcurrent relay and consequent tripping of the incoming circuit breaker of the autotransformer. The autotransformer has the capacity to provide power for both units, but due to an error, the overcurrent relay was still set for the operation of Unit 1 only. Loss of input power to the two Startup transformers automatically transferred the auxiliary loads for both units to the backup Startup Transformer, ST 2. However, this transformer is designed as an alternate supply for one unit and is not designed to carry full auxiliary loads for both units. This overload caused a voltage degradation at the safety buses. The event to this point demonstrated that the design of the offsite power system to the ANO station Units 1 and 2 did not fully meet GDC-17. In the circumstances experienced at ANO the failure of one of the two offsite electric power circuits resulted in failure of the other electric power circuit. GDC-17 requires, in part, that (1) electric power from the transmission network to the onsite distribution system shall be supplied by two physically independent circuits (not necessarily on separate rights of way) designed and located so as to minimize to the extent practical the likelihood of their simultaneous failure under operating and environmental conditions and (2) provision shall be included to minimize the probability of losing electric power from any of the remaining supplies as a result of, or coincident with, the loss of power generated by the nuclear unit, or the loss of power from the transmission network. The ANO did not fully meet these requirements.

Initially, the sequence of events on September 16, 1978 did not indicate any problem with the electrical distribution system of Unit 1. However, subsequent analysis by the licensee indicated that in the event of a LOCA at Unit 1 during which time Startup Transformer No. 1 would be required to provide power to both the non-safety auxiliary electrical

loads and start the safety loads a voltage degradation would result. The safety loads might not transfer to the Unit 1 diesel-generators but could remain on the startup transformer with unacceptably degraded voltage. Although there is margin in the thermal capability of equipment such a situation could result in thermal damage in the safety equipment and/or blown fuses in control circuits for these safety loads. Either event could result in disabling these loads during a LOCA. GDC-17 requires, in part, that electric power supplies for nuclear power plants provide sufficient capacity and capability to assure that certain limits are not exceeded in the event of anticipated operational occurrences and that the core is cooled and containment integrity and other vital functions are maintained in the event of postulated failures. The AND design was not capable of providing the electric power of "sufficient capacity and capability."

GUIDELINES FOR VOLTAGE DROP CALCULATIONS*not app. by...*

1. Separate analyses should be performed assuming the power source to safety buses is (a) the unit auxiliary transformer; (b) the startup transformer; and (c) other available connections to the offsite network one by one assuming the need for electric power is initiated by (1) an anticipated transient (e.g., unit trip) or (2) an accident, whichever presents the largest load demand situation.
2. For multi-unit stations a separate analysis should be performed for each unit assuming (1) an accident in the unit being analyzed and simultaneous shutdown of all other units at that station; or (2) an anticipated transient in the unit being analyzed (e.g., unit trip) and simultaneous shutdown of all other units at that station, whichever presents the largest load demand situation.
3. All actions the electric power system is designed to automatically initiate should be assumed to occur as designed (e.g., automatic bulk or sequential loading or automatic transfers of bulk loads from one transformer to another). Included should be consideration of starting of large non-safety loads (e.g., condensate pumps).
4. Manual load shedding should not be assumed.
5. For each event analyzed, the maximum load necessitated by the event and the mode of operation of the plant at the time of the event should be assumed in addition to all loads caused by expected automatic actions and manual actions permitted by administrative procedures.
6. The voltage at the terminals of each safety load should be calculated based on the above listed considerations and assumptions and based on the assumption that the grid voltage is at the "minimum expected value". The "minimum expected value" should be selected based on the least of the following:
 - a. The minimum steady-state voltage experienced at the connection to the offsite circuit.
 - b. The minimum voltage expected at the connection to the offsite circuit due to contingency plans which may result in reduced voltage from this grid.
 - c. The minimum predicted grid voltage from grid stability analysis. (e.g., load flow studies).

In the report to NRC on this matter the licensee should state planned actions, including any proposed "Limiting Conditions for Operation" for Technical Specifications, in response to experiencing voltage at the connection to the offsite circuit which is less than the "minimum expected value." A copy of the plant procedure in this regard should be provided.

7. The voltage analysis should include documentation for each condition analyzed, of the voltage at the input and output of each transformer and at each intermediate bus between the connection to the offsite circuit and the terminals of each safety load.
8. *See* The analysis should document the voltage setpoint and any inherent or adjustable (with nominal setting) time delay for relays which (1) initiate or execute automatic transfer of loads from one source to another; (2) initiate or execute automatic load shedding; or (3) initiate or execute automatic load sequencing.
9. The calculated voltages at the terminals of each safety load should be compared with the required voltage range for normal operation and starting of that load. Any identified inadequacies of calculated voltage require immediate remedial action and notification of NRC.
10. *See* For each case evaluated the calculated voltages on each safety bus should be compared with the voltage-time settings for the undervoltage relays on these safety buses. Any identified inadequacies in undervoltage relay settings require immediate remedial action and notification of NRC.
11. To provide assurance that actions taken to assure adequate voltage levels for safety loads do not result in excessive voltage, assuming the maximum expected value of voltage at the connection to the offsite circuit, a determination should be made of the maximum voltage expected at the terminals of each safety load and its starting circuit. If this voltage exceeds the maximum voltage rating of any item of safety equipment immediate remedial action is required and NRC shall be notified.
12. Voltage-time settings for undervoltage relays shall be selected so as to avoid spurious separation of safety buses from offsite power during plant startup, normal operation and shutdown due to startup and/or operation of electric loads.
13. Analysis documentation should include a statement of the assumptions for each case analyzed.

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
ENGINEERING AND CONSTRUCTION DEPARTMENT

DATE: October 4, 1979
RESPONSE DUE:

TO: F. P. Librizzi
General Manager - Electric Production

FROM: R. R. Bast
General Manager - Engineering

SUBJECT: RESPONSE TO NRC LETTER
ADEQUACY OF STATION ELECTRIC DISTRIBUTION
SYSTEM VOLTAGES DATED AUGUST 8, 1979

We have performed the analysis on the Salem Generating Station Units Nos. 1 and 2 electric power system in accordance with NRC letter, Adequacy of Station Electric Distribution System Voltages dated August 8, 1979 and its enclosures.

The analysis demonstrates that the offsite power system and the onsite distribution system is of sufficient capacity and capability to automatically start as well as operate all safety loads within their voltage ratings for all anticipated transients and accidents.

Satisfactory results were obtained as a result of the original design considerations. The Salem Generating Station was designed such that the resulting voltage profile was within component voltage limitations, being +5% of transformer secondary voltage and -10% of motor nameplate voltage under steady-state conditions. The system was also designed such that the inrush current associated with the start of a 6000 horsepower, 4.0 kV motor would not cause the bus voltages to drop below 80%. All motors are designed to accelerate their driven equipment with at least 80% motor nameplate voltage applied to its terminals. This was accomplished by optimum selection of transformer impedances, incorporation of no-load taps on all power and unit substation transformers, and a $\pm 10\%$ automatic load tap changer on all the 13.8/4.16 station power transformers. All motor starters have a guaranteed drop out voltage of 70%. All starters were bought with 300 VA control power transformers, regardless of NEMA size, to minimize voltage drop at the contactor coil. Further, consideration was given to cable size and length to limit voltage drop in a feeder.

The analysis showed the worse sustained under-voltage condition imposed upon the distribution system occurred with a severely degraded 500 kV offsite system simultaneous with a concurrent LOCA on Unit 2 and Unit trip on Unit 1 (or vice versa). This under-voltage condition results from the automatic transfer of the group buses from the auxiliary power transformers to the station power transformer and the automatic start of the required vital bus loads. For this condition the lowest voltages at the 4.16 kV, 460V and 230V loads were .917, .923 and .91 per unit respectively. The above analysis indicates that the onsite distribution system and its components will operate within component voltage limitations. The motors are the limiting component under steady-state conditions as they are designed to run continuously at .9 per unit nameplate voltage.

Transient voltage drops due to the starting of motors were analyzed at each voltage level with no adverse effects. This analysis assumed the prestart voltage to be that corresponding to the degraded 500 kV system and the load in parallel with the motor being started equal to the maximum continuous rating of the transformer to which it is connected less the running load of the motor being started. Further, the impedance of the parallel load was conservatively assumed to decrease as the square of the bus voltage to analytically compensate for the additional current drawn by induction motors upon decrease in voltage. The minimum transient voltages obtained on the 4.16 kV, 460V and 230V levels were .86, .86 and .78 per unit, respectively, for a duration of approximately (5) seconds. These transients are within motor and motor starter design capabilities, thereby having no adverse effect on system operation. The results of this analysis were used to re-examine under-voltage protective settings and establish that no spurious separations of the safety buses from offsite power would occur.

The 5 kV power cables that connect the 13.8/4.16 kV station power transformers to the group and vital buses are the load limiting component in the distribution system. The sixteen hour rating of the cable is utilized for the load that results from the concurrent LOCA Unit 2 and Unit trip on Unit 1. There is sufficient margin between the cable rating and the resultant load to allow for implementation of existing station procedures used during the events analyzed and thus, avoid overloading.

As indicated in the NRC letter of August 8, 1979, tests had been previously run to correlate calculations with field conditions. With Salem Units 1 and 2 and the 500 kV system in an existing mode corresponding to a given loading of the plant distribution system, selected system parameters were monitored over a 24-hour period. An analysis was then performed using the actual load and 500 kV system voltage to obtain a calculated voltage profile and compare to actual measurements. The calculations and field measurements correlated within very reasonable accuracy, thus substantiating our assumptions and the method of calculation. The results are given in Attachment 1. Further, a test on a cold 6000 horsepower, 4.0 kV reactor coolant pump motor was conducted. The bus voltage dropped 15% upon start of this motor. No adverse effects were observed on other operating equipment. The results of this test substantiate the original plant design basis.


The electric power system was reviewed to determine if there are any events or conditions which could result in the simultaneous or consequential loss of required circuits to the offsite network that would violate GDC-17. No potential exists for violation of GDC-17.

ORIGINAL SIGNED
R. R. BAST

WJ
WSR:vlf
Attach:

CC R. L. Mittl
D. J. Jagt

SALEM GENERATING STATION, UNIT 2
 VOLTAGE PROFILE
 FIELD MEASUREMENTS VS. CALCULATIONS



ATTACHMENT 1
 To Response to NRC Letter
 Adequacy of Station Electric Distribution
 System Voltage - Dated August 8, 1979

LOAD TABULATION

PURPOSE:

The purpose of the load tabulation is to arrive at a load that reflects the greatest plant loading for use in calculation of the voltage profile.

RESULTS:

The load profile is attached. The greatest load results with a simultaneous LOCA on Unit 2 and unit trip on Unit 1. In addition to initiating loading of the vital buses in Unit 2, the event(s) also initiate transfer of the group bus loads to the station power transformers.

The load limiting component was identified as the 5 kV power cables. Comparison of this to be load profile shows the cable to be within rating with adequate margin.

Further discussion is contained in PSE&G response to NRC 8/22/79 request and may be found in Appendix I.

3Q1 16A

LOAD TABULATION

METHOD AND ASSUMPTIONS


1. Using actual 4 kV motor data from PSBP 140032, 111059, 112305, 112653, 119349, 140042, 124584, 140041, 135633, 135634, 140040 and 112698 and one lines 203001, 203062, 203061, 203002 and 203004 motor quantities, full load horsepower, efficiency and power factor were obtained to calculate motor KVA using the relationship.

$$KVA = \frac{(HP) (.746)}{(PF) (eff)}$$


2. Pump BHP (brake horsepower) was used rather than motor nameplate HP if the former was well defined. Actual running data was used to determine a conservative reactor coolant pump BHP.
3. The attached sheets entitled Motor Operational Information was used as a reference.
4. Individual load KVA was conservatively assumed to be additive.
5. The attached one line shows the switching arrangement.
6. To arrive at a conservative maximum loading it was assumed that No. 1 station power was carrying 4 of 6 vital buses (normal switching it would carry 3) and that the 4 kV loads were aligned to give the maximum.

LOAD PROFILE

No 21 STATION POWER LOAD PROFILE AT THE TIME OF A LOCA



No 11 STATION POWER LOAD PROFILE FOLLOWING A UNIT TRIP



POOR ORIGINAL


Components Load Limitations

The limiting component in the Salem distribution system are the 5kV power cables which are connected between 13.8/4.16 station power transformers and the group and vital buses. Six (6) 1250 MCM cables are connected per phase and are rated as follows:

| Time | Rating |
|---------------|----------|
| Up to 2 Hrs. | 40 MVA |
| Up to 16 Hrs. | 33.5 MVA |
| Up to 24 Hrs. | 30 MVA |
| Continuous | 25 MVA |

SWITCHING ARRANGEMENT

(5)



POOR ORIGINAL

| | |
|---|------------|
| SYSTEM OPERATIONS | REV 6-9-77 |
| SALEM GEN. STATION | H2W |
| PUBLIC SERVICE ELECTRIC & GAS COMPANY ELECTRIC PRODUCTION DEPARTMENT | |

MOTOR OPERATIONAL INFORMATION

- 1. Circulating water pump motor. Six at 2000 Hp each.

Pump BHP under normal full load conditions is 1511 Hp. Run all six during startup, full load, shutdown and LOCA with offsite power. 70% starting voltage.

- 2. Condensate pump motors. Three at 3000 Hp each.

During startup use one initially and add others as it is desired to buildup feedwater pressure. Run three at full load. Ten seconds after the unit trip pumps go into recirculation automatically for which BHP is 1900 Hp. Operator takes out of service about 15 minutes after unit trip. 70% starting voltage.

- 3. Heater drain pump motor. Three at 1000 Hp each.

Use when at load. Connect when at approximately 30% load coming up. Unload automatically two seconds following a unit trip for which BHP is approximately 720 Hp. Operator takes out of service about 3 minutes after unit trip. 70% starting voltage.

- 4. Turbine auxiliary cooling pump motors. Three at 400 Hp each.

One runs most of the time. Run three with unit at full load. Can run two but with additions to TAC system the former is the case. Run at least two approximately 4 hours after a unit trip. 70% starting voltage.

- 5. Air compressor motor. Three at 1000 Hp.

This is a common system between Units 1 and 2. One run continuously per unit with the other motor in automatic standby. 70% starting voltage. BHP is approximately 800 Hp.

X

- 6. Reactor coolant pump motor. Four at 6000 Hp.

Run all four on startup, full load and shutdown. After a LOCA, operator trips all four when reactor pressure drops to 1550 psi. When initially started BHP is approximately 7200. As the water heats up the horsepower drops off to normal running BHP. Normal running BHP used in calculation was 5600 Hp corresponding to the maximum current on No. 13 reactor coolant pump from field test of 11/30-12/1, 1976. 80% starting voltage.

- 7. Service water pump motor. Six at 1000 Hp.

Three are required for full operation but plant usually runs four for startup, full load and unit trip. Minimum of three, one per vital bus for LOCA. Impeller has been changed from original design. BHP during normal full load operation and is approximately 950 Hp.

6. (Reactor coolant supplement.)

Following a LOCA, RCP's are tripped when reactor pressure reaches 1550 psi (E.I. I-4.0). Following a unit trip pumps are operated as follows: 4 (Temp 547-400); 3 (Temp 400 to 350°F); 2 (350 to 250°F) and 11&14 or 12 and 13; > 250°F run 1, 13 or 11 (O.I. I-3.6). See attach P, T vs I and Tech Spec 4.4.1a, 4.4.4.2.

wjr

3M1 41/42

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
ENGINEERING AND CONSTRUCTION DEPARTMENT

THE FOLLOWING: MOTOR LOAD AND VITAL SYSTEMS INFORMATION

REACTIVITY CONTROLS SYSTEMS

(Re: SA-1 Tech Spec 3/4.1-1 628)

One charging pump shall be operable during shutdown. Two charging pumps shall be operable during reactor operation. One boric acid transfer pump shall be operable during the shutdown period. Two boric acid transfer pumps shall be operable during reactor operation.

EMERGENCY CORE COOLING SYSTEMS

(Re: SA-1 Tech Spec 3/4.4-1634)

ECCS Subsystems - T Average greater than or equal to 350°F

Two separate and independent ECCS Subsystems shall be operable with each Subsystem comprised of:

- A. One operable centrifugal charging pump
- B. One operable safety injection pump
- C. One operable residual heat removal pump

ECCS Subsystems - T Average less than 350°F, one ECCS Subsystem comprised of the following shall be operable:

Same as AB&C above.

Containment Cooling System (Re: 3/4.6-15)

Three separate and independently powered groups of containment cooling fans shall be operable with two fans systems to each of two groups and one fan system comprising of the third group. If one group of cooling fans is inoperable, either restore the inoperable fan group to operable status within 48 hours or be in hot shutdown within the next 12 hours.

-2-

Auxiliary Feedwater Pumps (Re: 3/4.7-5)

The Auxiliary Feedwater System in each unit is equipped with two parallel pumping systems for redundancy. The first system is composed of two AC motor driven feedwater pumps each of which is sized to supply cool down water to two of the four steam generators. The second system is composed of one steam turbine driven pump. This pump is sized to supply cool down water to all four steam generators. The unit has to be shutdown with one auxiliary feedwater pump motor out of service.

At least three generator auxiliary feedwater pumps shall be operable with two motor driven feedwater pumps, one steam turbine feedwater pump.

Component Cooling Water (Re: 3/4.7-12)

Three component cooling pumps are provided to circulate the component cooling water. Two independent component cooling water loops shall be operable as a limiting condition for operation.

Service Water System (Re: 3/4.7-15)

Two independent service water loops shall be operable.

Four out of six service water pump motor will be sufficient to run the unit at 100% capacity. We have to lose three motors to require shutdown of the plant.

Control Room Emergency Air Conditioning System
(Re: 3/4.7-16)

The Control Room Emergency Air Conditioning System shall be operable.

Auxiliary Building Exhaust Air Filtration System
(Re: 3/4.7-19)

Three separate and independent auxiliary building exhaust air HEPA filter trains, one charcoal absorber train and three exhaust fans shall be operable. With one auxiliary building exhaust air filter train or one exhaust fan inoperable, restore the inoperable train to operable status within seven days or be in cold shutdown.

Refueling Operations Coolant Circulation

A minimum of one residual heat removal pump shall be operable.

Residual Heat Removal System

The residual heat removal system consists of two independent loops, two residual heat removal pumps rated at 400 HP. Two separate and independent ECCS Subsystems shall be operable within each subsystem comprised of one operable residual heat removal pump. With one ECCS Subsystem inoperable restore the inoperable to operable status within 48 hours or be in hot shutdown within the next 12 hours.

Reactor Coolant System

Four reactor coolant loops are in service during normal operation with one reactor coolant loop and associated pump not in operation reduced thermal power level to 76% of rated thermal power.

Fuel Handling Area Ventilation

Fuel Handling Area Ventilation System should be operable during either fuel movement within the spent fuel storage pool or crane operation with loads over the spent fuel storage pool. Fuel Handling Area Ventilation System shall be operable whenever the irradiated fuel is in the storage pool. Only one supply air unit provided.

Switchgear Room Ventilation System

Three supply air fans to supply air to switchgear room which are located on the elevation 84 and 64 of the Auxiliary Building. Normally two of the three supply fans are operated with the third in standby. Three fans on elevation 84 and the three fans on elevation 64 operate to exhaust switchgear rooms to the return duct.

at

Control Air Conditioning System

Normal system consists of three fans, two normally operating and one standby. Emergency system operates upon actuation of safeguard system consisting of two fans, (one standby).

Safety Injection Pump

SIS this design is to insure that the following minimum SIS equipment per unit operates in the event of an S signal:

One out of two centrifugal charging/safety injection and one out of two safety injection pumps.

WSR:cm

11/14/79

5K2 39/42-A

WSR

GROUP BUS LOAD TABULATION

| | MOTOR | QTY | Full load HP (BHP) | Full load | | KVA | RUNNING KVA | | | |
|----|--|-----|---------------------------|-----------|------|--------|--------------|--------------|------------------------------|--|
| | | | | eff | p-f | | F.L | UNIT TRIP | LOA and UNIT TRIP 250' | |
| 1. | COND | 3 | 3000 | .15 | .116 | 2581 | 7713 | 7713 | 7713 | |
| 2. | HTR DR | 3 | 1000 | .936 | .913 | 873 | 2619 | 2619 | 2619 | |
| 3. | CIRC. WTR | 6 | ²⁰⁰⁰ (1511) | .935 | .916 | (1646) | 9876 | 9876 | 9876 | |
| 4. | R.C.P. | 4 | ⁶⁰⁰⁰ (5600) | .93 | .91 | (4936) | 19715 | 19715 | 19715 | |
| 5. | TAC | 3 | 400 | .925 | .915 | 353 | 1059 | 706 | 706 | |
| 6. | COMP AIR | 1 | 1000 | .957 | .906 | 874 | 874 | 874 | 874 | |
| 7. | UNIT SUBS: | | | | | | | | | |
| | a. E, EP, G, GP | | 1000 | | | | 3400 | 3400 | 3400 | |
| | b. F, H | | 1333 | | | | 2666 | 2666 | 2666 | |
| | c. CIRC. WTR, FL, HL F(230), H(230) | | 750 | | | | | | | |
| | SWYD, BOAT | | | | | | <u>3375</u> | <u>3375</u> | <u>3375</u> | |
| | | | | | | | <u>47982</u> | <u>47629</u> | <u>47629</u> | |
| | | | | | | | TOTAL | | | |

NOTES

1. () Brake horsepower
2. (7a.) KVA totals arrived at by adding 1000 for E, 1800 for EP & GP and 600 for G.
- (7b.) KVA total arrived at by adding 1333 + 1333.
- (7c.) " " " " " " 750 for F, H and 375 for FL, HL circ. wtr, swyd and ferry boat.
3. If BHP used to calculate KVA p-f and eff at actual BHP loads also used.

POOR ORIGINAL

VITAL BUS LOAD TABULATION.

| MOTOR | QTY | Full load HP (BHP) | Full load | | KVA | RUNNING KVA | | |
|---------------|-----|-----------------------|-----------|------|-------|-------------|-------------|----------------------------------|
| | | | eff | p.f. | | F.L. | UNIT TRIP | LOAD AND UNIT TRIP (D.L.C) |
| 1. DEF WTC | 6 | 1000 (750) | .941 | .837 | (850) | 3400 | 3400 | 3400 |
| 2. COMP CLG | 3 | 300 | .927 | .877 | 276 | 552 | 552 | 552 |
| 3. RHR | 2 | 400 (310) | .94 | .9 | (362) | 0 | 0 | 724 |
| 4. SIS | 2 | 400 (375) | .902 | .801 | 337 | 0 | 0 | 674 |
| 5. CONT SP | 3 | 400 (375) | .936 | .901 | (331) | 0 | 0 | 662 |
| 6. AUX FD | 2 | 600 (450) | .94 | .9 | (390) | 0 | 792 | 792 |
| 7. CHARG. PP | 2 | 600 (650) | .942 | .901 | (557) | 533 | 1144 | 1144 |
| 8. UNIT SUBS: | | | | | | | | |
| (a) 750 | 2 | | | | | 1000 | 1000 | 1000 |
| b 300 | 3 | | | | | 900 | 900 | 900 |
| c 1000 | 1 | | | | | 900 | 900 | 900 |
| | | | | | | <u>7285</u> | <u>8673</u> | <u>10748</u> |

NOTES:

1. () indicates BHP

POOR ORIGINAL

LOAD FLOW

GPADP 113 LOAD FLOW

(21)

11 STATION DWR CARRIES E+H GR. BUSES

= 2 COND, 1 HTR DR, 3 CIRG, 1 AIR COMP, 1 TAC, 2 RCP

UNIT SUBS H6, SWVD, H(100), H(230), E, IEP

$$= 2591(2) + 873 + 1646(3) + 874 + 353 + 4936(2) \\ + 375 + 375 + 1333 + 750 + 1000 + 1000 +$$

$$= \underline{25259 \text{ KVA}}$$

$$\text{auto unload } (2591 - 1770)2 + (873 - 650) = 1845 \\ 25259 - 1845 = 23414$$

(22)

12 STATION DWR CARRIES F+G GR. BUSES

= COND, 2 HTR DR, 3 CIRG, 2 TAC, 2 RCP

UNIT SUBS FL, WAT, F(100), F(230), GW, G, GP

$$= 2591 + 873(2) + 1646(3) + 353(2) + 4936(2) \\ + 375 + 200 + 1333 + 750 + 375 + 1000 + 800$$

$$= \underline{24676 \text{ KVA}}$$

POOR ORIGINAL

LOAD FLOW

VITAL BUS LOAD FLOW

NORMAL FULL LOAD

A: COMP CLR, 2 SER WTR, UNIT SUBS

$$276 + 2(850) + 750 + 300 = 3026 \text{ KVA}$$

B: SER WTR + CHRG PP + UNIT SUBS

$$850 + 533 + 750 + 300 = 2433 \text{ KVA}$$

C: SER WTR + UNIT SUBS

$$850 + 1000 + 300 = 2150 \text{ KVA}$$

3026
2150
876

UNIT TRIP

A: COMP CLR, 2 SER WTR, UNIT SUBS + AUX PD

$$276 + 2(850) + 750 + 300 + 337 = 3922$$

B: SER WTR, CHRG PP, UNIT SUBS, COMP CLR, AUX PD

$$850 + 577 + 750 + 300 + 276 + 396 = 3149$$

3922
3149
6571

C: SER WTR + UNIT SUBS, CHRG PP, SIS

$$850 + 1000 + 300 + 577 = 2727$$

LOCA:

A: UNIT TRIP + RIR + CONT SP

$$3759 + 362 + 331 = 4452 \text{ KVA}$$

B: UNIT TRIP + RIR

$$3149 + 362 = 3511 \text{ KVA}$$

C: UNIT TRIP + CONT SP.

$$3069 + 331 = 3395 \text{ KVA}$$

APPENDIX III

POOR ORIGINAL

VOLTAGE PROFILE

General Discussion

The voltage profile with a given plant must be examined for both steady, state and transient conditions.

This voltage profile is largely depended upon two variables, those being the system voltage regulation at the terminals of the plant and the plant load regulation. The steady state profile can be most readily examined by analyzing the end points. The lowest possible steady voltage will result with the lowest attainable system voltage coupled with the greatest plant load. The highest voltage possible will be with the highest attainable system voltage and the least amount of plant load. All other voltage profiles resulting from other plant loads or system conditions would lie between these two points. The resultant profiles must then fall within the component voltage limitations which will be discussed later.

The greatest voltage drop resulting from transient conditions usually results from the start of the largest motor at each voltage level, coupled with the greatest plant load and the lowest system voltage. Bus transfer should also be examined.

WSR:pd

2Q2 39

SUMMARY OF RESULTS

1. The greatest sustained voltage drop results with the 500 kV system degraded to .978 per unit with a simultaneous unit trip on Unit 1 and a LOCA on Unit 2. For this condition the 13.8 kV bus drops to .903 per unit, Units 2, 4.16 kV vital and group buses dropped to .9226 per unit with the voltage at the 4.16 kV, 460 V and 230 V loads dropping to .917, .923, and .91 per unit respectively. This condition lasts for approximately three minutes until the reactor coolant pumps are tripped after which the profile improves. This profile is summarized on page 21. The LTC will also move to improve this condition in 5/8% increments and 30 seconds per increment. (No credit was taken for the LTC action at this time.)
2. The highest voltage results with the 500 kV system voltage at 1.06 per unit and hypothetical loads on each bus.
3. The greatest transient drop on the 4.16 kV vital system results upon the start of a 6,000 hp reactor coolant pump motor. This transient is worse than correction of the vital loads upon the occurrence of a LOCA. Postulating a prestart condition corresponding to the 500 kV voltage degraded to .978, Unit 1, 4.16 kV loaded to the maximum continuous full load rating of the 13.8/4.16 kV station power transformer and the reactor coolant pump motor being started against a transformer which is loaded to its maximum full load rating less the KVA corresponding to the RCP, the voltage on the 4.16 kV group and vital buses drops to .8692 per unit. The voltages at the 460, 230 volt loads dropped to .8692 and .8543 per unit respectively. The 460 volt and 230 volt loads selected were those with the greatest circuit impedance and horsepower representing the greatest drop. This condition lasts for approximately 25 seconds.

82

- 4. The transient analyzed on the 460 volt vital bus was upon the simultaneous start of the chiller, auxiliary building supply and vent fans and the switchgear room supply fans which results upon a LOCA signal. This corresponds to 255 Hp. The prestart condition was with the 4.16 kV sustained voltage condition in 1 above and the 460 volt load hypothetically postulated at the maximum continuous rating of the transformer less the KVA of the motors being started. This transformer also has the greatest per unit impedance of all the 460 volt vital transformers. The resulting 460 bus voltage was .8608 per unit. Individual motor starting times are approximately 5 seconds.

- 5. The transient analyzed on the 230 volt vital bus was the start of a 30 hp motor on feeder 2B3Y. This load was found to be the largest load on the smallest cable, the greatest distance from the source corresponding to the greatest circuit impedance and result in drop (see page 31). The prestart conditions correspond to the sustained 4.16 kV voltage conditioned in 1 above with the transformer upon which the load was being started equal to the maximum rating of the transformer. The resultant MCC voltage was .8739 and .7854 at the load.

WSR:aec

3L1 03/04C

Discussion of Results

The results must be viewed in view of the component voltage limitations which are summarized on the attached sheet.

The calculations were done with a great deal of conservatism.

Conservative factors were:

1. The 500 KV system minimum steady state voltage is under an extremely unlikely combination of circumstances.
2. Credit was not taken for the action of the 13.9/4.10KV station power transformer load tap changer after the event.
3. Margin was added to the actual load KVA.
4. The resultant voltage profile at each voltage level for the limiting case.


The PSE&G response serves as discussion of the results.

Component Voltage Limitations

1. Transformers:
 - A. Plus 10% secondary nameplate voltage at no load.
 - B. Plus 5% secondary nameplate voltage at load.
2. Motors:
 - A. ± 10% nameplate voltage
 - B. Motor breakdown torques minimum of 175% full load torque.
3. Contactors: All contactors are made by GE which have the following characteristics:
 - A. Dropout: 32-58% in 7-12 MS, guarantee 70%.
 - B. Pullin: 56-87% in 13-35MS, guarantee 85%.


VOLTAGE PROFILE

CORRESPONDING TO MAXIMUM LOAD DURING A LOCK ON UNIT 2 AND UNIT TRIP ON UNIT 1 AND SUSTAINED 500KV GRID DEGRADATION. DURATION IS APPROXIMATELY 3 MINUTES.




POOR ORIGINAL

TRANSIENT
VOLTAGE PROFILE
PLEASE CHECK FUSE MOTOR START UNIT &
REVERSE SYSTEM AND PLANT CONDITIONS




POOR ORIGINAL

STEADY STATE
VOLTAGE PROFILE
LIGHT LOAD AND OPTIMUM 400KV VOLTAGE




POOR ORIGINAL

TRANSIENT
VOLTAGE PROFILE
BUS LOADING OF 480V VITAL BUS.




POOR ORIGINAL

TRANSIENT
VOLTAGE PROFILE ON
230V VITAL BUS



POOR ORIGINAL

SWITCHING ARRANGEMENT



POOR ORIGINAL

| | |
|---------------------------------------|------------|
| SYSTEM OPERATIONS | |
| SALEM GEN. STATION | REV 6-9-77 |
| PUBLIC SERVICE ELECTRIC & GAS COMPANY | |
| ELECTRIC PRODUCTION DEPARTMENT | |

4160 V VOLTAGE PROFILE

METHOD AND ASSUMPTIONS

1. One line (attached) shows switching arrangement.
2. All transformer impedance was assumed to be reactive.
3. All transformer impedances were obtained from the transformer nameplates. The greatest impedance of a group of identical transformers were used.
4. Calculations were worked in per unit on a 1 MVA, 500 kV base.
5. Okonite Cable Bulletin was used as a reference to obtain cable impedance data.
6. 4 kV loads were assumed at .91 p.f. This allows some margin.
7. Approximately 2 MVA was added to the loads on 11 and 21 station power transformer for margin.
8. Cable impedances were used.
9. PSE&G memorandum dated 10/31/78, part IV was used to obtain lowest system voltage. This memorandum makes very conservative assumptions of its own. The increase in the load flow into Salem at 500 kV has an insignificant effect on the final result. This memorandum may be found in Appendix.
10. The 500 kV system which is a minimum of approximately 5000 MVA represents a negligible impedance (i.e. $1/5000 = .0002$ against final circuit impedance of 0.017) loading on No. 1, 11, 21 station power transformer.

VOLTAGE STUDY.

d

PER-UNIT DEVELOPMENT

Work on 1MVA, 500KV base.

1. No 1, 2 STA. PWR. 500/13.8KV on no load tap 512.5KV

 $Z = 10.79\%$ on 60MVA (Transformer nameplate)

$$Z_{pu} = \frac{10.79}{60} = j.001798$$

2. No 11, 12, 21, 22 STA. PWR 13.8/416KV on no load tap 13.455KV

Greatest impedance of 4 is 5.8% on 15MVA (Transformer NP)

$$Z_{pu} = \frac{5.8}{15} = j.00386$$

3. MAXIMUM LOADS (Reference load profile and add KVA for margin)

Load on 21 STA. PWR 33,500 KVA @ .91 p.f. (assumed p.f.) (~2100KVA margin)

$$= \frac{1}{33.5} (.91 + j.414) = .0271 + j.0123 = .0297 \angle 24.91$$

Load on 11 STA. PWR 32,000KVA @ .91 p.f. (assumed p.f.) (~2000KVA margin)

$$= \frac{1}{32} (.91 + j.414) = .0284 + j.0129 = .03125 \angle 24.91$$

4. CABLES

13KV: 1750MCM, 450', 15' spere. Per article Bulletin 721, p. 3 and 10

$$X = .074 \Omega / 1000' = .033 \Omega \text{ for } 450'$$

POOR ORIGINAL


VOLTAGE STUDY
PER UNIT DEVELOPMENT CONTINUED

$$R = .00604 \Omega / 1000' = .0027$$

$$Z_{\text{pu}} = \frac{Z_r (kV)^2}{10 (kV)^2} = \frac{Z_r (13.8)}{1000 (13.8)^2} = Z_r (.00525)$$

$$Z_{\text{pu}} = (.0027 + j .033) .00525 = \underline{.000014 + j .00017}$$

4KV cables: Consists of 6 1/2 1250mm² in parallel / ϕ running 350'
 and 3 1/2 1250mm² in parallel / ϕ running 250'



Using Okwile Bulletin 721, p. 3 #10

$$R = .00846 \Omega / 1000'$$

$$X = j .024 \Omega / 1000'$$

$$Z = (.00846 + j .024) .35 = .00296 + j .0084 + .0089 \angle 71^\circ$$

$$Z_{\text{pu}} = .0089 \angle 71^\circ (1/4.16^2) = .0089 \angle 71^\circ (.0577) = .00051 \angle 71^\circ$$

$$Z_{\text{imp parallel}} = .0001 \angle 71 = .000032 + j .00004$$


$$Z_{\text{pu}} = (.00846 + j .024) (.25) (.0577) = .000122 + j .00031 = .00036 \angle 71^\circ$$

$$Z_{\text{imp parallel}} = .0001179 \angle 71.2 = .000039 + j .00011$$

$$\underline{Z_{\text{TRFP}} = .000071 + j .000204}$$

POOR ORIGINAL

Using per unit impedances the following one line is developed



Reducing the one line:

$$j.00017 + j.00386 + j.0002 + .0284 + j.0129 = .0289 + j.01713 = .0331 \angle 31.09$$

$$j.00017 + j.00386 + j.0002 + .0271 + j.0123 = .0271 + j.01653 = .0317 \angle 31.39$$

$$\frac{[.0331 \angle 31.09][.0317 \angle 31.39]}{(.0289 + .0271) + j(.01713 + .01653)} = .01616 \angle 31.24 = .0138 + j.0083$$

$$.0138 + j.0083 + j.001793 = .0138 + j.01 = .0170 \angle 35.92$$

$$|V| = |E| \frac{.01616(.0297)}{.0170(.0311)} = .9505(.9369) = (.8905)$$

Taking N.L. TAPS in ACCOUNT *MULTIPLY BY $\left(\frac{500}{512.5}\right) \left(\frac{13.5}{13.755}\right) = 1.0$
 thus no more offsetting

POOR ORIGINAL

From PSE&E memo dated 10/31/78, part IV the lowest voltage is 97.9% on a 500kV Base.

$$V = .978 (.8905) = .8709$$

The LTC on the 13.8/4.16 station Power transformers will provide an additional 1% correction. The resultant voltage would therefore be $(1.01)(.8709) = .8788$ on a 4.16kV base. LTC would be on R16.

However this represents the final voltage after the LTC had had a chance (time) to correct.

It is needed to know the tap that the LTC would

the event. The load on 21 STA. PWR was:


at .895 p.f. Using 6.0 MVA @ .895 p.f. to allow

the tap can be found as follows:

$$Z_{LOAD} = \frac{1}{6} (.895 + j.446) = .166 \angle 26.43 = (.149 + j.074)$$

NO 1 STA. PWR

13kV cable



This circuit reduces as follows.

$$j.00017 + j.00386 + j.0002 + .149 + j.0743 = .149 + j.0803 = .1692 \angle 28.3^\circ$$

$$.1692 \angle \text{ in parallel with } .1692 \angle = .0846 \angle 28.32 = .0745 + j.0402$$

$$.0745 + j.0402 + j.001798 = .0745 + j.0419 = .0855 \angle 29.31^\circ$$

Apply system voltage of .978 and referencing initial circuit reduction

$$|V| = .978 \left(\frac{.0846}{.0855} \right) \left(\frac{.1166}{.11692} \right) = .974$$

LTC is set to maintain 124V on a 4200/120V potential transformer

Conservatively use 123V due to bandwidth tolerance. The tap

will be

$$\frac{4200}{120} \times \frac{123}{4160} = 1.0348 \text{ pu. voltage}$$

\therefore a correction of $\frac{1.0348}{.974}$ or 1.0629 is required

LTC moves in 5/8% increments so corresponding tap is on R9-R10.

Apply this result the initial voltage at the instant of the transfer is $.8709(1.06) = \underline{\underline{.9226}}$ on a 4160V base.

Note; that this is the initial voltage and every 30 second the LTC will move 5/8% to further correct voltage.

We will not take credit for this at this time else

.9226

POOR ORIGINAL

The 13KV voltage is

$$|V_{13.2}| = .979 \left(\frac{.01616}{.017} \right) \left(\frac{500}{512.5} \right) = .979 (.9505) (.975)$$

$$= .903$$

The 4KV voltage on 11 sta. per is

$$= .979 \frac{.01616}{.017} \left(\frac{103125}{.0331} \right)$$

$$= .8974$$

Similarly LTC on R9 level set @ 1.124V

$$= .8974 (1.0624) = .9528$$

The voltages at the loads is evaluated as follows:

All the 4KV motor loads are connected with 2/0 cable. The longest run (1219') and greatest load (124 Amps) is the service water pump motors. Using the Okamoto Cable Bulletin for 2/0

$R = .0795 \text{ AC/DC} = 1.001 \quad 0.0 = 3.2 \quad 1' \text{ spacing} \quad N = .1$

$Z_{3700} = (.0795(1.001) + j.1) \frac{1219}{1000} = .097 + j.2 = .15 \angle \Omega$

Volt drop = $.15(124) = 18.6 \text{ volts}$ or $.44\%$ on 4160V

Use .5% on vital bus loads.

RCP START

370


1. Actual motor data was used.
2. In order to achieve a conservative result the following method was utilized. (Ref. one line.)

The greatest drop would be obtained when the 500 kV system is at its lowest attainable voltage and the other load running at the time of the RCP start is the greatest. The latter can be attained by assuming this load to be the maximum rating of the station power transformer less the load of the RCP. The running load on the other 13.8/4.16 station transformer is taken as its maximum rating.

Further when starting a large motor which results in a significant bus voltage drop there is an increase in the current drawn by the running motors due to reduction in the torque developed by the motor and slight speed reduction. The results in an additional drop. This relationship is slightly greater than one for one. We have very conservatively assumed that the running load impedance decreases as the square of the bus voltage to analytically model this occurrence.

3Q1 19A

RCP start



RCP data Locked rotor = 4800A @ .17 p.f.


$$MVA_{LR} = 4800 \times .9 \times 1.732 = 26.36 \text{ MVA}$$

@ .176 p.f and correct for 4160V base

$$Z_{LR} = \frac{1}{26.36} (.176 + j .9049) \left(\frac{4160}{4000} \right)^2 = .04255 / 79.93^\circ$$

$$= .0072 + j .0403$$

Pre-start load



POOR ORIGINAL

$$RCP \text{ running MVA} = 4.936 \text{ (Base upon 540 + 5400 off, 575 pf, .9)}$$

$$= \frac{1}{4.936} (.94 + j .414) = .202 / 27.49^\circ$$

$$= .184 + j .033$$

Maximum load on 13.8/416kV Stateline Power would equal maximum continuous rating of the transformer less the RCP.

= 28 - 1.936 = 23.064 MVA @ 0.1 pf.

Z_{L1} = 1/23.064 (.914 + j.114) = .0391 + j.0179 = .0433 / 24.47

Assume other transformers fully loaded @ 28 MVA @ 0.1 pf.

Z_{L2} = 1/28 (.914 + j.114) = .0321 + j.0147 = .0357 / 24.47

Z_{T1} = 1058/15 = j.00386

Z_{T2} = 11079/60 = j.001799

Reducing:

(.04255)(.0321) / 24.47 + 79.86 = .00139 / 53.04 = .0149 + j.0173

(.0072 + .03417) + j(.0179 + .0103)

.0149 + j.0149 + j.00386 = .0149 + j.02366 = .0279 / 57.77


(.0279)(.0357) / 57.77 + 24.47 = .0169 / 43.06 = .01143 + j.01119

(.0149 + .0321) + j(.0147 + .02366)

.01143 + j.01119 + j.001799 = .01143 + j.01298 = .01766 / 47.39

|V| = |I| (.0169 / .01766) (.0279 / .01298) = E (.9286) (.8899) = |E| (.8254)

Prior to start 12V LTC is on TAP!



$$23.00 \text{ mA} \cdot \underbrace{.0359 + j.0179}_{Z_{L2}} + \underbrace{j.00386}_{Z_{T1}} = .0359 + j.02078 = .045 \angle 28.81$$

$$\frac{(.045)(.0357) \angle 28.81 + 24.49}{(.0359 + .0321) + j(.0217 + 0.147)} = .02 \angle 26.98 = .0178 + j.009$$

$$.0178 + j.009 + j.001795 = .0178 + j.0108 = .0208 \angle 31.24$$

$$|V| = |E| \frac{.0208}{.0208} \frac{.0435}{.045} = |E| (.961)(.9672) = |E| (.9246)$$

$$I_A = |E| = .978 \quad |V| = .904$$

$$\text{Current for No load tap} = 1.025 (.978) = 1$$

LTC set to maintain 124V, it will have run out of LTC to R16

$$.904(1.1) = \underline{.9944}$$

Therefore since LTC is on R16 prior to start

$$|V| = .978 (.9254)(1.1) = .9879 \text{ on a 4160V base.}$$

POOR ORIGINAL

But the load connected to the transformer will vary as the voltage varies and if the voltage drops the current will increase or impedance decrease.

$$\frac{Z}{L_1} = \frac{.0433 (1.8875)^2 \angle 24.49^\circ}{24.49} = \frac{.03379 \angle 24.49^\circ}{24.49} = .031 + j .0141$$

2nd Station

$$\text{Reducing } \frac{(.03271)(.04255) \angle 24.86 + 24.49}{(.031 + .0076) + j (.0403 + .0141)} = \frac{.0216 \angle 49.43^\circ}{.0386 + j .0544}$$

$$= .014 + j .0169$$

$$= .014 + j (.0169 + .00386) = .014 + j .0203 = .0246 \angle 55.40^\circ$$

$$\frac{(.02746)(.0257) \angle 55.40 + 24.04}{(.014 + .0321) + j (.0147 + .0205)} = \frac{.015 \angle 42.53^\circ}{.0461 + j .0352} = .011 + j .0101$$

$$.011 + j .0101 + j .001798 = .011 + j .01188 = .0162 \angle 47.20^\circ$$

$$|V| = |E| \frac{.015}{.0162} \frac{.0216}{.0246} = (.9259)(.878)|E| = E(.8129)$$

Correcting for LTC by 1.1 and E: .978

$$|V| = (.978)(1.1)(.8129) = \boxed{.879}$$

POOR ORIGINAL

3rd. Iteration

$$Z_{L1} = .0433 (.874)^2 / 24.49 = .0330 \angle 24.49 = .03 + j .0136$$

$$\text{Reducing } \frac{(.04255)(.033) / 24.49 + 79.96}{(.0072 + .03) + j (.0103 + .0136)} = .0214 \angle 48.96 = .01405 + j .016$$

$$.01405 + j (.016 + .00386) = .01405 + j .01986 = .0243 \angle 54.72$$

$$\frac{(.0243)(.0357) / 24.49 + 54.72}{(.01405 + .0321) + j (.0147 + .01986)}$$

$$= .0111 + j (.0105 + .001748) = .0111 + j .0123 = .01656 \angle 47.93$$

$$|V| = |E| \left(\frac{.01506}{.01656} \right) \left(\frac{.0214}{.0243} \right) = (.9099)(.88)|E| = .8008 |E|$$

Correct for LTC by 1.1 and E: .978

$$V = .978(1.1)(.8008) = \underline{\underline{.8692}}$$

4th iteration

$$z_{L1} = .0433 (.8692)^2 \angle 29.44^\circ + .10327 \angle 29.49^\circ = .0297 + j .0135$$

$$\text{Reducing: } \frac{(.00255)(.0327) \angle 29.49 + 12.35}{(.0072 + .0247) + j(.0135 + .0403)} = .0213 \angle 48.4^\circ = .014 + j .016$$

$$.014 + j(.016 + .00386) = .014 + j .01986 = .0243 \angle 54.81^\circ$$

approach same magnitude and angle
as last iteration

POOR ORIGINAL

With full load on the 4160/480V unit substation the voltage would drop to:

$$|E| = .8692$$

$$|V|_{480} = |E| (.954) (1.025) = .8692 (.954) (1.025) = .8499$$

$$|V|_{460} = \frac{480}{110} (.8499) = .8868 \text{ less cable drop of } .027$$

$$= \boxed{.8598}$$

With full load on the 4160/240V unit substation the voltage would drop to:

$$E = .8692$$

$$|V|_{240} = (E) (.975) (1.025) = .8692 (.975) (1.025)$$

$$|V|_{240} = .8686$$

$$|V|_{230} = \frac{240}{230} (.8686) = .9063 \text{ less cable drop of } .052$$

$$= \boxed{.8543}$$

POOR ORIGINAL

460 V VOLTAGE PROFILE

The 460V voltage profile was approached so as to allow margins as follows:

1. B vital bus was selected as typical. Of the 3, 480 V vital buses A&B represent the greatest per unit impedance as they are 750 KVA, 5.75% where as C is 1000 KVA, 5.75%.
2. The load assumed connected to the 480V bus was equal to the maximum continuous rating of its transformer. i.e. B is rated 750/1000 KVA AA/FA. 1000 KVA was used and assumed at .8 p.f.
3. The cable voltage drop was approached as follows. List all the B bus loads with their full load amps, cable length and size, and determine the individual drops. From this select the greatest drop and apply in all cases. Thus for any feeder where the voltage drop is examined further, we can obtain less drop by referring to this calculation (i.e. the RMS was looked at further applying the 8V drop. Had we had trouble we could have used the actual drop of 1.41.)
4. The worst transient was with the simultaneous connection of the safety related loads that are block loaded. The transient was analyzed similarly to the 4160 V, that is, using the running load prior to the start of this block connected load as the maximum continuous rating of the transformer to which it is connected. The 4160 V pre-start voltage was that corresponding to the degraded 500 kV system condition.
5. The motor locked rotor currents were assumed equal to 5 time full load amps and a .2 p.f.

3Q1 20A


480V FEEDER VOLTAGE DROP

45

| BKE Position | LOAD | FULL LOAD AMPS | Cable length and size | Impedance / 1000' | actual Z | volt drop |
|--------------|--------------------|----------------|-----------------------|-------------------|----------|-----------|
| 2B2X | CONT FN | 206A | 140' of 350 | .0539 | .01 | 2.28 |
| 2B4X | | 333A | 240' of 500 | .0551 | .011 | 3.66 |
| 2B5X | 22 FUEL HOOL | 25 | 240' of 6 | .513 | .129 | 3.1 |
| 2B4X | HT TRANS | 170 | 190 of 6 | .513 | .1097 | 6.79 |
| 2B10X | SUGR FN | 30.7 | 605 of 2/0 | .11 | .107 | 1.25 |
| 2411X | 27AB SUP FN | 65 | 270 of 6 | .513 | .112 | 7.28 |
| 2B12X | 27AB Lx FN | 96 | 205 of 2 | .207 | .1042 | 4.03 |
| 2B13X | Chiller | 116 | 175 of 2 | .207 | .1036 | 4.17 |
| 2B14X | SP. fuel oil pp | 114 | 150 of 2 | .207 | .1031 | 3.53 |
| 2B15X | H ₂ Rec | 94 | 50 of 2/0 | .11 | .1005 | 1.97 |
| 2B16X | PMS | 94 | 140 of 2/0 | .11 | .1015 | 1.41 |

7.28 volts is greatest drop. Use 8 volts as feeder drop.

POOR ORIGINAL



$$Z_L = \frac{1}{1} (.8 + j.6) =$$

$$Z_T = j \cdot 10575/750 = j \cdot 0.766$$

$$Z = .8 + j \cdot 0.676 = 1.04$$

$$|V| = |E| \frac{1.0}{1.04} = .954 (E)$$

Correct for tap position and system voltage $E = .972$

$$|V| = 1.025 (.972) (.954) = .901$$

$$\text{ON } 400\text{V tap} = .901 \left(\frac{480}{400} \right) = .94$$


This allows $.04(400)$ 16.4V drop which is more than acceptable.

Actual maximum is 7.28 use $E = 8/400 = .0177$

$$.94 - .017 =$$

.923

POOR ORIGINAL



Worst transient would be at start of 2 Condiment Facilities
 would be simultaneous start of assuming they were not running previously

| | | | | | | |
|------------------------|-------------|-----------|----------------------------|---------------------------|-----------|----------|
| Switchgear nm. ex. fr. | 30HP, 36.7A | = | $\frac{30(.75)}{.8(.85)}$ | = | 33.26 kVA | |
| " | " Supply fr | 50HP, 65A | = | $\frac{50(.75)}{.8(.85)}$ | = | 55.5 kVA |
| aux. bldg exhaust fr | 75HP, 96A | = | $\frac{75(.75)}{.8(.85)}$ | = | 83.25 kVA | |
| chiller | 100HP, 116A | = | $\frac{100(.75)}{.8(.85)}$ | = | 111 kVA | |

Motor Z @ LR equal $5(FLA)\sqrt{3}(460)$ assume starting pf = .2

$$36.7(1.732)(460)(5) = .146 \text{ MVA}, Z = \frac{1}{.146}(.2 + j.979) = 1.36 + j6.70$$

$$65(1.732)(460)(5) = .259 \text{ MVA}, Z = \frac{1}{.259}(.2 + j.979) = .772 + j3.77$$

$$96(1.732)(460)(5) = .382 \text{ MVA}, Z = \frac{1}{.382}(.2 + j.979) = .523 + j2.56$$

$$116(1.732)(460)(5) = .462 \text{ MVA}, Z = \frac{1}{.462}(.2 + j.979) = .432 + j2.119$$

$$\text{Combining} = .6581 \angle 78.16^\circ = .127 + j.624$$

Assume 750kVA is fully loaded less these motors at start

Pic. stated load

$$1000 - 33.26 - 55.5 - 83.25 - 111 = 716.99$$

$$1/.717 (.8 + j.6) = 1.394 (.8 + j.6) = 1.115 + j.8369$$

Reducing

$$\frac{(.6391)(1.394) \angle 36.84 + 78.44}{(.127 + 1.115) + j(.8564 + .621)} = .463 \angle 65.69 = .1906 + j.421$$

$$Z_T = .0575 / 750 = j.0766$$

$$Z_T = .1906 + j(.421 + .0766) = .1906 + j.497 = .53 \angle$$

$$|V| = |E| \frac{.463}{.53} = |E| (.873)$$

E = .922 and currents for tap = 61.025

$$|V| = .825$$

on 460v base $|V| = \frac{460}{460} (.825) = .86$

230 V VOLTAGE PROFILE

The 230V voltage profile was approached so as to allow margins as follows:

1. B vital bus was selected as typical.
2. The following data was compiled as follows for each MCC feed: The actual cable size and length, the connected load (assumed all MCC feeders closed and no diversity), the cable impedance/1000' from which the actual cable impedance was determined. The actual impedance was multiplied by the connected load amps to determine the voltage drops between the unit substation and MCC. The greatest voltage drop between the MCC and the load was determined for each MCC in the same manner. These two drops were then arithmetically added to arrive at the worse case voltage drop.
3. The load connected to the 230 V bus was assumed to be equal to the maximum continuous rating of its transformer or 300 KVA. A .8 p.f. was also assumed.
4. The worse transient was with the start of a 30 HP motor. The transient was analyzed similarly to the 4160 V, that is using the running load prior to the start of this block connected load as the maximum continuous rating of the transformer to which it is connected. The 4160 V pre-start voltage was that corresponding to the degraded 500 kV system condition. Motor locked rotor was assumed equal to 6X F.L. at .2 p.f.

MCC TO LOAD VOLTAGE DROPS

2B84 221 STP WIP. 5HP, 15.2A 3C12 - 50' $1.62(.05)(15.2) = 1.23V$

2B74 2B A/C 2HP, 4.7A 3C2 85' $.207(.285)(72) = 4.24V$

2B44 2B Diesel 1" 3HP, 6.7A 3C12 - 110' $6.7(1.62)(.11) = 1.19$

2B34 | VWS West 225T49 41A, 3C2 240' $.41(.207)(1.244) = 2.47$

VWS East 225T54 59A, 3C2 250' $59(.207)(.341) = 4.14$

21BF13 240, 3C6 450' $.34.8(.513)(.05) = 8.03$

2B134 2B Vent & A/C 10HP, 27.2A 3C6, 124' $27.2(.513)(.224) = 3.15$

7 1/2 HP, 27A, 3C6, 506' $22(.513)(.506) = 5.71V$

2B154 2B2 SW 1, 3.2A, 3C12, 150' $3.2(1.62)(.15) = .77$

2 SW26 16A, 3C6, 75' $16(.513)(.075) = .61$


POOR ORIGINAL

VOLT DROP - UNIT SUBSTATION TO MCC.

| UNIT SUB. TO MCC FOR. | Cable size and actual length | Connected amps | cable Z /1000' | Z actual | UNIT SUB MCC Volt Drop | MCC to load drop |
|--------------------------|---------------------------------|-------------------|---------------------|--------------|---------------------------------|---------------------------|
| 2B3Y | 3T350 - 261' 3T350 - 268' | 255 269 | .0539 | .014 .015 | 3.57 3.96 | 8.03 |
| 2B4Y | 3T350 - 474' | 216 | .0539 | .025 | 5.4 | 11.9 |
| 2B7Y | 3T00 - 325' | 149 | .11 | .035 | 5.2 | 4.24 |
| 2B8Y | 3T00 - 1185' | 22 | .11 | .13 | 2.86 | 1.23 |
| 2B13Y | 3T00 - 325' | 131.8 | .11 | .035 | 4.61 | 5.71 |
| 2B15Y | 4C00 - 1093' | 38 | .11 | .120 | 4.56 | 1.77 |

Greatest drop is 12V.

POOR ORIGINAL



$$Z_T = .05/3 = j.166$$

$$Z_L = 1/300 (.8 + j.6) = 333(.8 + j.6) = 2.66 + j2.0$$

$$Z_{total} = 2.66 + j2.16 = 3.42$$

$$|V| = |E| \frac{3.33}{3.42} = |E| (.975)$$

If $E = .922$ amp correct for tap.

$$|V| = .922(.975)(.975) = .922 \text{ on } x4m2 \text{ base}$$


$$= .962 \text{ on motor base } = 6230V$$

Max Voltage drop between unit sub bus and lamp is 17V or 5.2%
 it still have margin

$$.962 - .052 = \boxed{.91}$$

POOR ORIGINAL

230V VOLTAGE PROFILE - 30HP MOTOR START i 53
 BASED ON FDR 2834



$$Z_T = .05 / .3 = j .1666$$

$$Z_{C1} = Z_{C \text{ 3T350}} = .0378 + j .0373 \times 1000'$$

$$Z_{P.U.} = \frac{Z_r}{.21^2} = 17.36 Z_r$$

$$Z_{P.U.} = 17.36 \left(\frac{.289}{1000} \right) (.0378 + j .0373) = .189 + j .186$$

$$Z_{C2} \quad 285' \text{ of } 302$$

$$17.36 \left(\frac{.285}{1000} \right) (-.202 + j .0123) = .998 + j .073$$

$$Z_{L1} = 270 \text{ KVA } @ .8 \text{ pf} = 1/.27 (.8 + j .6) = 3.7 / 36.86 = 2.96 + j 2.22$$

$$Z_{L2} = \frac{30 \text{ HP } \times .75 \text{ KW/HP}}{.8 \times .85} = 33.26 \times 6 = 199.56 \text{ KVA } @ .8 \text{ pf}$$

$$Z_{L2} = \frac{1}{199.56} (.2 + j .179) = 5.01 / 76.41 = 1.002 + j 4.90$$

Reduce $Z_{C1} + Z_{C2} + Z_{L2} = .188 + j .186 + .998 + j .073 + 1.002 + j 4.90$
 $= 2.188 + j 5.109 = 5.999 / 66.81$

POOR ORIGINAL

Reduce

$$\frac{(5.171)(3.7) \angle 65.41^\circ}{2.188 + 2.14 + j(2.22 + 5.134)} = \frac{2.48 \angle 18.76^\circ}{1.63 + j 7.354} = 1.631 + j 1.869$$

$$1.631 + j 1.869 + j 1.56 = 1.63 + j 3.429 = 3.60 \angle$$

$$|V| = |E| \left(\frac{2.48}{2.60} \right) \left(\frac{5.01}{5.471} \right) = |E| (0.954) (0.915) = |E| (0.873)$$

JFE = $\boxed{9226}$ and current of tap 1.025

$$|V| = 0.873 \text{ on } 240V = 0.873 \left(\frac{240}{230} \right) = \boxed{0.905}$$

McC base $Z_{L2} + Z_{L1} = 1.002 + j 4.90 + 0.975 + j 0.73$
 $= 2 + j 5.635 = 5.313$

$$\frac{5.313}{2.477} = 0.0056 (1.025) (0.9270) = 0.837$$

on 230V base = $0.8374 \left(\frac{240}{230} \right)$
 $0.8374 = \boxed{0.8738}$

POOR ORIGINAL

LIGHT LOAD

The voltage profile was also examined to ascertain that the distribution system voltage profile was within upper voltage limitations. This was done by making the following conservative assumptions.



1. All cable impedance was neglected.
2. The 500 kV system practicable upper voltage limitation was determined to be 1.06 p.u. at the Salem terminals.
3. The loads on the 4.16 kV, 460 V and 230 V levels were assumed at 3 MVA, .91 p.f.; 300 KVA @ .8 p.f. and 100 KVA @ .8 p.f. respectively.
4. The upper tolerance of the 13.8/4.16 kV B.W. adjustment was assumed.

3Q1 22A

LIGHT LOAD

Neglect all cable Z, account only for load and transformer Z.

No 1 Station Purz



No 1 Station Purz - $Z_{T1} = j.001719$

No 11 (or) Station Purz $Z_{T2} = j.00386$

Assumed @ 3MVA load

$$Z_{L1} = Z_{L2} = \frac{1}{3} (.91 + j.114) = .30 + j.136$$

Reducing

$$.33 + j.136 + j.00386 = .33 + j.1398 = .3584 \angle 22.95^\circ$$

Combining

$$.1792 \angle 22.95 = .165 + j.0698 = .1791 \angle$$

$$.165 + j.0698 + j.001719 = .165 + j.0716 = .1798 \angle$$

$$|V| = |E| \left(\frac{.1791}{.1798} \right) \left(\frac{.333}{.3584} \right) = |E| (.9961) (.9291) = |E| .9255$$

Correction for NL Taps $1.025 (.975) = 1$

If |E| maximum = 1.06 pu.

$V = .981$

LTC set to maintain $124V \dots = 125 \times \frac{9200}{110} = 10375$ or 1.051 pu.

POOR ORIGINAL


of LTC will result current j07

$$\begin{array}{r} 1.051 \\ 931 \\ \hline 2.070 \end{array}$$

$$\frac{.07}{.00625} = 11.2 \quad L11-L12$$

at 460V.

$$\begin{array}{r} 1.998 \\ 10760 \\ \hline 2.0758 \end{array}$$




$$4 + j3$$

$$4 + 3 \cdot 0.766$$

Impedance: $2.66 + j1.993 + j0.766 = 2.66 + j2.076 = 3.373 \angle$

$$|V| = (E) \frac{3.393}{3.373} (1.075) = 1.012|E| = 1.012(1.05) = 1.06 \text{ on bus.}$$

at 230V



Impedance: $8 + j6 + j.1666 = 8 + j6.1666 = 20.10$

$$|V| = |E| \frac{70}{20.1} (1.075) (1.05) = 1.07 \text{ on bus.}$$

POOR ORIGINAL

RCP STARTING TIME

58

PURPOSE:

The purpose of this calculation is to determine the reactor coolant pump starting times with the pump load under cold and hot conditions. Actual RCP cold start times are available for comparison of results.

METHOD & ASSUMPTIONS:

1. Actual motor and pump speed torque curves were used (attached).
2. The starting interval was divided into ten increments and the mean of each increment used in the analysis. The results of each increment were then summed.
3. Based upon previous analysis the motor terminal voltage was assumed at 85% at 4160 V for 95% of the total starting time.

RESULTS:

A RCP cold accelerating time was 25.46 seconds and hot was 18.33 seconds. Test results indicated an RCP starting times of 22-26 seconds.

3Q1 24A

RCP STARTING TIME

59

| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) |
|-------------|--------------|--------------|--------------|----------------|-----------|--------------------|------------|
| Increment % | Motor Wtts % | P.U. Motor T | #-ft Motor T | P.U. Load Cold | #-ft Load | $(4-6) \Delta T_c$ | t |
| 0-10 | 85 | .90 | 17231 | .08 | 2120 | 15111 | 1.05 |
| 10-20 | 85 | .92 | 17614 | .06 | 1540 | 16024 | 1.9 |
| 20-30 | 85 | .94 | 17997 | .08 | 2120 | 15877 | 2.0 |
| 30-40 | 85 | .98 | 18763 | .14 | 3710 | 15053 | 2.1 |
| 40-50 | 85 | 1.02 | 19529 | .26 | 6840 | 12639 | 2.5 |
| 50-60 | 85 | 1.08 | 20677 | .38 | 10070 | 10607 | 3.0 |
| 60-70 | 85 | 1.2 | 22975 | .54 | 14310 | 8665 | 3.1 |
| 70-80 | 85 | 1.44 | 27570 | .7 | 18550 | 9020 | 3.5 |
| 80-90 | 85 | 1.90 | 36377 | .9 | 23850 | 12527 | 2.5 |
| 90-95 | 85 | 2.30 | 44036 | 1.06 | 28090 | 15746 | 1.5 |
| 96-100 | 90 | 1.80 | 33463 | 1.18 | 31270 | 3193 | <u>2.0</u> |

25.

1. #-ft motor T = $(.85)^2(26,500) = .7225(26,500)$

2. $WK^2 = 82,000 \text{ #-ft}^2$

3. use attached (W) curve - columns: 1, 3, 4, 5, 6

4. 1200 rpm

4. $t = \frac{\text{rpm} \times WK^2}{308 \Delta T}$ - column 8


POOR ORIGINAL

| (9) | (10) | (11) | (12) |
|-----------------|------------------|--------------|-------------|
| P.u Load Hot | *-ft Load Hot | ΔT_H | t |
| .06 | 1590 | 15641 | 1.02 |
| .09 | 1060 | 16551 | 1.92 |
| .06 | 1590 | 16407 | 1.95 |
| .10 | 2650 | 16113 | 1.98 |
| .18 | 4770 | 16879 | 1.89 |
| .26 | 6890 | 13789 | 2.32 |
| .38 | 10070 | 12905 | 2.47 |
| .5 | 13250 | 14320 | 2.23 |
| .62 | 16430 | 19947 | 1.60 |
| .74 | 19610 | 24426 | 1.33 |
| .82 | 21730 | 12733 | <u>1.62</u> |
| | | | 16.33 |

POOR ORIGINAL

POOR ORIGINAL

STARTING PERFORMANCE
100% VOLTAGE



88

CORRELATION OF FIELD TEST DATA AND CALCULATIONS

PURPOSE:

The purpose of those calculations was to use actual 500 kV system voltage and plant load data in the calculation of a plant load profile. The same procedure applied in the previous calculations was utilized. The results of this calculation were then composed with actual measurements.


METHOD & ASSUMPTIONS:

The field data was monitored over a 24 hour period by Maplewood Laboratory personnel and is attached. Readings at 1600 hours were arbitrarily selected to use in the calculations.

RESULTS:

As shown on the attached sheet, the results of measured and calculated compare favorably.





SALEM GENERATING STATION, UNIT 2
VOLTAGE PROFILE
FIELD MEASUREMENTS VS. CALCULATIONS



ATTACHMENT 1
To Response to NRC Letter
Accuracy of Station Electric Distribution
System Voltage - Dated August 8, 1979

ONE LINE OF PLANT DURING FIELD TEST

49



| | |
|---------------------------------------|-----------------------|
| SYSTEM OPERATIONS | |
| SALEM GEN. STATION | |
| PUBLIC SERVICE ELECTRIC & GAS COMPANY | |
| ELECTRIC PRODUCTION DEPARTMENT | |
| | REV 6-7-77 J.W. |

SALEM NUCLEAR GEN STA

ECSchwartz
RGMP² Lewis

N22 GEN - Control Room Metering

| Date | Time | N21 Sta Tur X Finr | | | N22 Sta Tur X Finr | | | |
|---------|---------|--------------------|---------|----------|--------------------|---------|----------|---------|
| | | Local Top Position | Amps | Maxwatts | Local Top Position | Amps | Maxwatts | |
| 12-6-78 | 1000 | 3 Raise | 2000 | 16.2 | 1 Lower | 2000 | 12.5 | |
| | 1100 | 3 Raise | 2600 | 16.5 | 1 Lower | 2000 | 12.4 | |
| | 1200 | 3 Raise | 2620 | 16.4 | 1 Lower | 2030 | 12.8 | |
| | 1300 | 3 Raise | 2600 | 16.4 | 1 Lower | 2030 | 12.8 | |
| | 1400 | 3 Raise | 2500 | 16.1 | 1 Lower | 2020 | 12.8 | |
| | 1500 | 3 Raise | 2650 | 16.5 | 1 Lower | 2050 | 12.8 | |
| | 1600 | 3 Raise | 2650 | 16.5 | 1 Lower | 2100 | 13.0 | |
| | 1700 | 3 Raise | 2650 | 16.4 | 1 Raise | 2050 | 13.0 | |
| | 1800 | 3 Raise | 2650 | 16.5 | 1 Raise | 2080 * | 13.0 ** | |
| | 1900 | 3 Raise | 2600 | 16.3 | 1 Lower | 2050 * | 13.0 ** | |
| | 2000 | 3 Raise | 2600 | 16.2 | 1 Lower | 2000 * | 13.0 ** | |
| | 2100 | 3 Raise | 2600 | 16.2 | 1 Lower | 2050 * | 13.0 ** | |
| | 2200 | 3 Raise | 2600 | 16.3 | 1 Lower | 2000 | 12.7 | |
| | 2300 | 3 Raise | 2620 | 16.3 | 1 Lower | 2020 | 12.7 | |
| | Mid | 2400 | 3 Raise | 2600 | 16.3 | 1 Lower | 2070 * | 13.0 ** |
| | 12-7-78 | 0100 | 3 Raise | 2610 | 16.3 | 1 Lower | 2010 | 12.7 |
| | | 0200 | 3 Raise | 2600 | 16.3 | 1 Lower | 2000 | 12.6 |
| 0300 | | 1 Raise | 2400 | 15.0 | 1 Lower | 2000 | 12.6 | |
| 0400 | | 1 Raise | 2390 | 15.0 | 1 Lower | 2000 | 12.5 | |
| 0500 | | 1 Raise | 2400 | 15.0 | 1 Lower | 2000 | 12.6 | |
| 0600 | | 2 Raise | 2600 | 16.1 | 1 Lower | 2000 | 12.5 | |
| 0700 | | 0 | 2590 | 16.0 | 1 Lower | 2000 | 12.6 | |
| 0800 | | 3 Raise | 2550 | 16.1 | 0 | 2050 * | 12.6 ** | |
| 0900 | | 3 Raise | 2570 | 16.2 | 1 Lower | 2000 | 12.6 | |
| 1000 | | 2 Raise | 2580 | 16.2 | 2 Lower | 2020 | 12.5 | |
| 1100 | | 2 Raise | 2560 | 16.1 | 2 Lower | 2020 | 12.7 | |

* Sharp changes from 2000 Amperes to Maximum as indicated above.

* Sharp changes from 12.6 Megawatts to Maximum as indicated above.

POOR ORIGINAL

SALEM NUCLEAR GEN STA

ECC Schwabach
 ROOM Locam

No 2 GEN - Control Room Metering

| Date | Time | (Reading) 5015 | 13KV | | 4KV | | | |
|---------|------|-------------------|-------|-------|------|------|------|------|
| | | | Sec 1 | Sec 4 | 2B | 2C | 2G | 2H |
| 12-6-78 | 1515 | 522 | 13.3 | 13.5 | | | | |
| | 1600 | 520 | 13.3 | 13.5 | 4.19 | 4.23 | 4.20 | 4.20 |
| | 1700 | 515 | 13.4 | 13.3 | 4.20 | 4.22 | 4.20 | 4.20 |
| | 1800 | 523 | 13.5 | 13.4 | 4.19 | 4.25 | 4.20 | 4.20 |
| | 1900 | 523 | 13.6 | 13.5 | 4.20 | 4.27 | 4.20 | 4.20 |
| | 2000 | 525 | 13.6 | 13.4 | 4.20 | 4.25 | 4.20 | 4.21 |
| | 2100 | 524 | 13.5 | 13.4 | 4.22 | 4.28 | 4.22 | 4.24 |
| | 2200 | 525 | 13.6 | 13.5 | 4.21 | 4.27 | 4.21 | 4.22 |
| | 2300 | 521 | 13.5 | 13.4 | 4.22 | 4.28 | 4.22 | 4.25 |
| Wed | 2400 | 525 | 13.3 | 13.5 | 4.20 | 4.26 | 4.20 | 4.20 |
| 12-7-78 | 0100 | 522 | 13.3 | 13.6 | 4.21 | 4.27 | 4.20 | 4.21 |
| | 0200 | 524 | 13.4 | 13.5 | 4.20 | 4.26 | 4.20 | 4.22 |
| | 0300 | 522 | 13.4 | 13.5 | 4.21 | 4.28 | 4.22 | 4.22 |
| | 0400 | 522 | 13.4 | 13.5 | 4.20 | 4.26 | 4.21 | 4.20 |
| | 0500 | 523 | 13.4 | 13.5 | 4.20 | 4.27 | 4.21 | 4.20 |
| | 0600 | 522 | 13.4 | 13.5 | 4.20 | 4.26 | 4.21 | 4.20 |
| | 0700 | 520 | 13.3 | 13.4 | 4.20 | 4.25 | 4.21 | 4.20 |
| | 0800 | 520 | 13.3 | 13.5 | 4.20 | 4.25 | 4.21 | 4.20 |
| | 0900 | 523 | 13.4 | 13.6 | 4.18 | 4.25 | 4.20 | 4.20 |
| | 1000 | 525 | 13.4 | 13.5 | 4.20 | 4.26 | 4.21 | 4.22 |
| | 1100 | 525 | 13.4 | 13.6 | 4.21 | 4.27 | 4.20 | 4.20 |
| | | | | | 4.21 | 4.26 | 4.20 | 4.20 |

POOR ORIGINAL


SALEM NUCLEAR GEN STA

DATA

E.C. Schwaster 8/
 R.G. McLean
 12-6-75

NO 2 GEN - Vital & Group Bus Measurements

| Tap Positions | | 2G 460V <u>Co Bus</u> | 2C 230V <u>Vital</u> | 2B 230V <u>Vital</u> | 2B 460V <u>Vital</u> | 2H 460V <u>Co Bus</u> | |
|---------------|----------|-----------------------------|----------------------------|----------------------------|----------------------------|-----------------------------|-------------------|
| 21st Pos | 22nd Pos | * 480V | * 237V | * 239V | * 470V | * 480V | * OA-B or P1-2 |
| 3 Raise | 1 Lower | 480v | 237v | 237v | 470v | 475v | |
| 3 Raise | 1 Lower | 480v | 237v | 238v | 470v | 478v | |
| 1 Raise | 1 Lower | 480v | 239v | 235v | 467v | 475v | |
| 2 Raise | 1 Lower | 0 | 238v | 235v | 465v | 475v | |
| 0 | 1 Lower | 0 | 238v | 237v | 467v | 478v | |
| 3 Raise | 0 | 0 | 237v | 238v | 467v | 477v | |
| 3 Raise | 1 Lower | 0 | 237v | 235v | 467v | 477v | |
| Raise | 2 Lower | 0 | 238v | 237v | 469v | 478v | |



03

At 1600 hrs.


$I = 2650A \quad V = 4.2$

$kVA = 19.277 \quad @ .93 pf \approx .85 + j .5267$

Assume Unit 1, No 11 SP @ 5MVA @ (.85 + j .567)

$\frac{1}{19.27} (.85 + j .5267) = .0518 (.85 + j .5267) = .04403 + j .0272 = .0517 \angle$

$\frac{1}{5} (.85 + j .5267) = .2 (.85 + j .5267) = .17 + j .105$



Reducing

$j.00386 + .044 + j.0272 = .044 + j.03106 = .05385 \angle 35.21^\circ$

$j.0033 + .17 + j.105 = .17 + j.1088 = .2013 \angle 32.61^\circ$

$\frac{(.05385)(.2013) \angle 35.21 + 32.61}{(.044 + .17) + j(.03106 + .1088)} = \frac{.0108 \angle 1010^\circ}{.214 + j.13986} = \frac{.0108 \angle 1010^\circ}{.25 \angle 165.55^\circ}$

$= .0432 \angle 67.82^\circ = .0432 \angle 34.62^\circ = .0432 (.8231 + j .5678)$

$= .0355 + j .0245$

Using chart 500kV voltage & existing NL and LTC tap settings

$$E_{13.8} = \frac{118}{115} \times \frac{500}{512.5} \times \frac{.0432}{.0355 + j(.0245 + .001798)} = 13.42 \text{ kV}$$

$$F_{4160} = \left(\frac{13.42}{13.8} \right) \left(\frac{4238}{4160} \right) \left(\frac{13.8}{13.455} \right) \left(\frac{.0517}{.0535} \right) = 4076 \text{ volts}$$

Chart 4160 measurement was 4090 volts.

Using meter, 500kV voltage & existing NL & LTC tap settings.

$$E_{13.8} = \frac{520}{500} \left(\frac{500}{512.5} \right) \left(\frac{.0432}{.0355 + j(.0245 + .001798)} \right) = 13.68 \text{ kV}$$

$$F_{4160} = \frac{13.68}{13.8} \left(\frac{4238}{4160} \right) \left(\frac{13.8}{13.455} \right) \left(\frac{.0517}{.0535} \right) = 4156 \text{ volts}$$

Meter 4160 reading was 4190 to 4200 volts.

2B 460V UNIT SUB

| | connected | est. running |
|-----------------------|------------|--------------|
| H ₂ Preamb | 94 | - |
| Sp. Fuel pp | 114 | - |
| 22 Chiller | 116 | 116 |
| 22 Aux Bldg Ex Fn | 71.6 | 71.6 |
| Aux Bldg Sup Fn | 46.5 | 46.5 |
| Surgr. Rm Sup Fn | 36.7 | 36.7 |
| Vt. Ht. Trac. Xfmr | 141 | 70 |
| 22 Fuel Hdt. Ex Fn | 25 | 25 |
| 2A Fn CC | 333 | 333 |
| 22 Fn CC | <u>333</u> | <u>-</u> |
| | 1310 | 658.8 |

$$\text{Load} = 658.8 \times 1.732 \times 480 = \underline{580 \text{ KVA}}$$

$$Z_L = \frac{1000}{580} = 1.724$$

$$Z_T = .0575 \frac{1000}{750} = .0766$$

$$\text{Load Reg} = \frac{1.724}{1.724 + .0766} = .957$$

$$V_{480} = V_{4160} \left(\frac{480}{4160} \right) (1.1025) (.957) = V_{4160} (.1131)$$

Using previous calculated $V_{4160} = 4076$ & 4156 corresponding to chart of meter 500V voltages.

$$V_{480} = (.1131) 4076 = 461 \text{ V}$$

$$V_{480} = (.1131) 4156 = 470 \text{ V}$$

Measured voltages were 465-470

ZB 230V UNIT SUB LOADING.

| | connected | estimated running |
|------------|------------|-------------------|
| ZB Diesel | 195.9 A | 30 A |
| ZB1 S.W. | 26.0 | 20 |
| ZB2 S.W. | 38.0 | 30 |
| ZB vent | 13.8 | 100 |
| ZB A.C. | 149.0 | 125 |
| ZB E.Valus | 262 | 25 |
| ZB W.Valus | <u>239</u> | <u>25</u> |
| | 1041 amps | 355 amps. |

Actual KVA @ transf. rated = $355 \times 1.732 \times 240 = \underline{147 \text{ KVA}}$

use 150 KVA

Load $Z_L = \frac{1000}{150} = 6.66$; Transf. $Z_T = .05 \times \frac{1000}{300} = .1666$

Load Reg:

$$\frac{6.66}{6.66 + .1666} = .9755$$

$$V_{240} = V_{4160} \times \frac{240}{4160} \times 1.025 (.9755) = V_{4160} (.0576)$$

Using previous calculated $V_{4160} = 4076$ and 4156 corresponding to chart and metered source voltages

$$V_{4160} = 4076 (.0576) = 235.1 \text{ V}$$

$$V_{4160} = 4156 (.0576) = \underline{239.4 \text{ V}}$$

Measured voltages were 235-239 on all three phases

APPENDIX IV

POOR ORIGINAL

RELAY COORDINATION


The attached overload protective devices show that there were no spurious trips due to overload.

The existing under voltage protection is shown and also shows no spurious trips. (Second level of undervoltage protection will follow under separate cover.)

Relays setting sheets and characteristic relay curves were used to plot due attachments.


TIME - CURRENT CHARACTERISTICS

TIME IN SECONDS X 10



CURRENT IN AMPERES X 100 @ 4,160V

TIME - CURRENT CHARACTERISTICS



4KV Vial Bus O.L. FACS3 Tap 6 TD1.3 use curve for TD=1
 CT 240/1 Ref. Diag. 203117 BL 4917

| | | |
|-------|-----|-------|
| Relay | T | 1440 |
| 1.5 | 3 | 2160 |
| 4.5 | .3 | 6480 |
| 7 | .2 | 10080 |
| 50 | .11 | 72000 |

4KV Group Bus O.L. FACS3 Tap 10 TD 6
 CT 600/1 Ref. Diag. 203123, 222786

| | | |
|-------|-----|--------|
| Relay | T | 6000 |
| 1.5 | 20 | 9000 |
| 3 | 3.5 | 18000 |
| 10 | .9 | 60000 |
| 50 | .55 | 300000 |
| 1 | | |
| 3.2 | | |





FIG. 9 (08880270-3) 60HZ-TIME CURRENT CHARACTERISTICS FOR THE TYPES IAC53 AND IAC54 RELAYS

TIME-CURRENT CHARACTERISTICS



CURRENT IN AMPERES x 100 © 4.16




Fig. 12. Typical Time Curves of the Type CO-9 Relay.

418249

Co-9.

Tap 12, TD-11

CT = 240/1, Shunt Pwr Transf = 13.8/4.16

$$4.16 \text{ kV amps} = (\text{Rating})(12)(240)(13.8/4.16) = 9553 \text{ A}$$

| Tap Value | Time | $\times 9553$ |
|-----------|------|---------------|
| 3.1 | 7 | 29619 |
| 4.3 | 9 | 41077 |
| 8 | 2 | 76924 |
| 15 | 1.4 | 143715 |
| 20 | 1.3 | |

$$\text{Inst. } 80/12 \times 9553 = 63686$$

11, 12, 21 Same as

DATE FEB. 3, 1976

AT 13.5/14.16 KV

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
ELECTRIC DISTRIBUTION DEPARTMENT
RELAY TEST ORDER

THE DIVISION SUPERINTENDENT CAMDEN DIVISION

#22
STATION POWER

CASE DO THE FOLLOWING WORK AT JALEM GEN. STATION ON H.H.H.F. LINE TO

| REGULAR RELAYS | CT RATIO | RELAY DATA | | | | SETTING DATA | | | | | | | | | | | | | | | |
|----------------|----------|------------|----------|-------|------------|--------------|--------------|------------|-----|---|------|---------------|---------|---------|-------|------|--------------|---------------|----------|-----|--|
| | | REC | TEST AUX | RELAY | STOCK CODE | RANGE | ELEMENT ZONE | CON-DITION | I Z | B | TAP | WATTS / SLOPE | %R CALC | CURRENT | VOLTS | TEST | ANGLE ° LEAD | VOLTS PICK UP | CROP OUT | SEC | |
| 1 | 100% | AKV | | BDD | | | | φ | | | 3.5 | | | | | | | | | | |
| 2 | 100% | | | | | | | | | | 3.5 | | | | | | | | | | |
| 3 | 100% | | | | | | | | | | 5.0 | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | CC-9 | | A-12 | | φ | | | 12.0 | | | | | | | | | | |
| 6 | | | | CC-2 | | 20 80 125 | | | | | 1.0 | | | | | | | | | | |
| 7 | | | | CHC | | | | | | | | | | | | | | | | | |
| 8 | | | | TD-5 | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | |
| 13 | | | | | | | | | | | | | | | | | | | | | |
| 14 | | | | | | | | | | | | | | | | | | | | | |
| 15 | | | | | | | | | | | | | | | | | | | | | |
| 16 | | | | | | | | | | | | | | | | | | | | | |
| 17 | | | | | | | | | | | | | | | | | | | | | |
| 18 | | | | | | | | | | | | | | | | | | | | | |
| 19 | | | | | | | | | | | | | | | | | | | | | |
| 20 | | | | | | | | | | | | | | | | | | | | | |
| 21 | | | | | | | | | | | | | | | | | | | | | |
| 22 | | | | | | | | | | | | | | | | | | | | | |
| 23 | | | | | | | | | | | | | | | | | | | | | |
| 24 | | | | | | | | | | | | | | | | | | | | | |
| 25 | | | | | | | | | | | | | | | | | | | | | |
| 26 | | | | | | | | | | | | | | | | | | | | | |
| 27 | | | | | | | | | | | | | | | | | | | | | |
| 28 | | | | | | | | | | | | | | | | | | | | | |
| 29 | | | | | | | | | | | | | | | | | | | | | |
| 30 | | | | | | | | | | | | | | | | | | | | | |
| 31 | | | | | | | | | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | | |
| 34 | | | | | | | | | | | | | | | | | | | | | |
| 35 | | | | | | | | | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | | | |
| 37 | | | | | | | | | | | | | | | | | | | | | |
| 38 | | | | | | | | | | | | | | | | | | | | | |
| 39 | | | | | | | | | | | | | | | | | | | | | |
| 40 | | | | | | | | | | | | | | | | | | | | | |
| 41 | | | | | | | | | | | | | | | | | | | | | |
| 42 | | | | | | | | | | | | | | | | | | | | | |
| 43 | | | | | | | | | | | | | | | | | | | | | |
| 44 | | | | | | | | | | | | | | | | | | | | | |
| 45 | | | | | | | | | | | | | | | | | | | | | |
| 46 | | | | | | | | | | | | | | | | | | | | | |
| 47 | | | | | | | | | | | | | | | | | | | | | |
| 48 | | | | | | | | | | | | | | | | | | | | | |
| 49 | | | | | | | | | | | | | | | | | | | | | |
| 50 | | | | | | | | | | | | | | | | | | | | | |

SON FOR SETTING CHANGE: NEW INSTALL. REARRANGEMENT

IMPEDANCE CHANGE REARRANGEMENT

LOADABILITY LINE: 2 HR WINTER RATING: _____ MVA _____ AMPS _____ AMPS

LOADABILITY: _____ MVA _____ AMPS _____ AMPS

TRANSFORMER: MVA ON _____ TRF BANKS

MVA ON _____ TRF BANKS

MVA ON _____ TRF BANKS

checked the pickup of the C.C. 8 ground
by its coordination with the feeder relay

GENERAL SUPERINTENDENT OF DISTRIBUTION: _____

GENERAL SUPERINTENDENT OF DISTRIBUTION: _____

675
 F. M. ...
 1/12/78

REFER TO

PREPARED BY

SUBJECT

COMPUTATION SHEET

DATE


FILE

CHECKED BY

ESTIMATE

DATE

VITAL BUS UNDERVOLTAGE



| | | | | | | | |
|--|------|------|------|------|------|----|---|
| 110 | 100 | 90 | 80 | 70 | 60 | 50 | 4 |
| 92.5 | 84.1 | 75.7 | 67.3 | 58.9 | 50.5 | 42 | 3 |
| ABSOLUTE SECONDARY VOLTAGE - L-L PER CENT BUS VOLTAGE 4160V | | | | | | | |

REFER TO _____

PREPARED BY _____

SUBJECT _____

COMPUTATION SHEET

DATE _____

FILE _____

CHECKED BY _____

ESTIMATE _____

DATE _____

PT ratio = 4200/120 = 35/1

I_{AV} 74 1/2 TD.

| | | | |
|--------|----|-----|------|
| x 83.2 | %V | 1/2 | 4 |
| 0 | 0 | .5 | 2.4 |
| 41.6 | 50 | .6 | 3.2 |
| 66.56 | 80 | 1 | 6.6 |
| 74.88 | 90 | 1.6 | 11.4 |

PT ratio 4200/120 = 35

Bus voltage 1.0 pu = 1160 * $\frac{1160}{35} = 118.85 = 100\%$

| V | r ₀ |
|------|----------------|
| 110 | .925 |
| 100 | .841 |
| 90 | .757 |
| 83.2 | .70 |
| 80 | .673 |
| 70 | .589 |
| 60 | .505 |
| 50 | .42 |
| 40 | .337 |

106.2 .90

95.08 80

101.02 85



INSTRUCTIONS


GEH-1768B
Supersedes GEH-1768A

53

UNDERVOLTAGE RELAYS

Types

- LAV54E
- LAV54F LAV55F
- LAV54H LAV55H
- LAV55C LAV55J



POOR ORIGINAL

POWER SYSTEMS MANAGEMENT DEPARTMENT

GENERAL  ELECTRIC

PHILADELPHIA, PA.

UNDERVOLTAGE RELAYS

TYPE IAV

INTRODUCTION

These relays are of the induction-disk construction. The disk is actuated by a potential operating coil on a laminated U-magnet. The disk shaft carries the moving contact which completes the trip or alarm circuit when it touches the stationary contact or contacts. The disk shaft is restrained by a spiral spring to give the proper contact-closing voltage and its motion is retarded by permanent magnets acting on the disk to give the correct time delay.

There is a seal-in unit mounted to the left of the shaft as shown in Fig. 1. This unit has its coil in series and its contacts in parallel with the main contacts such that when the main contacts close, the seal-in unit picks up and seals in. When the seal-in unit picks up, it raises a target into view which latches up and remains exposed until released by pressing a button beneath the lower-left corner of the cover.

The relays are all mounted in single-unit double-end cases. The case has studs for external connections at both ends. The electrical connections between the relay and the case are made through stationary molded inner and outer blocks between which rests a removable connecting plug which completes the circuits. The molded outer blocks carry the studs for the external connections while the inner blocks carry the terminals for the internal connections. The operating coil is connected in parallel with both the upper and the lower inner molded blocks while the trip circuit is connected in series with these blocks. In this way, insertion of either the upper or lower connecting plug will energize the operating coil but the trip circuit will not be completed until the second connecting plug is inserted. For relays which have contacts closed when the relay is de-energized but open under normal operating conditions, the double connecting plug feature allows the relay contacts to open before the trip circuit is completed, thus minimizing the possibility of incorrect tripping when returning the relay to service after tests and inspection.

APPLICATION

These relays are protective devices designed to close trip or alarm circuits whenever the voltage applied to their operating coils reaches some predetermined value. The functions are described in greater detail in the following paragraphs.

OPERATING CHARACTERISTICS

The Type IAV54E relay has a single circuit-closing contact which closes when the voltage is reduced to some predetermined value. Thus, the contacts are closed at zero volts. This relay is a time undervoltage relay with inverse time characteristics which are shown in Fig. 2.




Figure 2. (362A648-0) Time-Voltage Curves for Relay Types IAV54E and IAV55C

The Type IAV54F relay is similar to the Type IAV54E relay except that it has a longer operating time. The time characteristics are shown in Fig. 3.

The Type IAV54H relay is also similar to the Type IAV54F relay except that it has much longer operating time than either the Type IAV54E or the Type IAV54F relays. The time characteristics are shown in Fig. 4.

The Type IAV55C relay is similar to the Type IAV54E relay except that it has two circuit-closing contacts.

The Type IAV55F relay is similar to the Type IAV54F relay except that it has two circuit-closing contacts.

The Type IAV55H relay is similar to the Type IAV54H relay except that it has two circuit-closing contacts.

The Type IAV55J relay is similar to the Type IAV55H relay except that it is provided with two separate seal-in units; one for each set of normally closed contacts.

Cover (8007476)

These instructions do not purport to cover all details or variations in equipment nor to provide for every possible contingency to be met in connection with installation, operation or maintenance. Should further information be desired or should particular problems arise which are not covered sufficiently for the purchaser's purposes, the matter should be referred to the General Electric Company.

VOLTAGE SETTINGS

The voltage at which the contacts operate may be changed by changing the position of the tap plug in the tap block at the top of the relay. The range of this adjustment is from 55 to 140 volts on the 115 volt ratings, 110 to 230 volts on the 230 volt ratings, and 220 to 500 volts on the 460 volt ratings. Screw the tap plug firmly into the tap marked for the desired voltage (above which the relay is not to operate).

The tap settings indicate voltage values at which the contacts will close. A spring adjusting ring is provided for a sensitive adjustment of the relay operation. If the factory adjustment has been disturbed; the desired operating value may be obtained by inserting a tool in the notches around the edge of the ring (see Fig. 9) and turning the ring to the desired position. This adjustment also permits any desired setting between the taps. The relay has been adjusted at the factory to close its contacts, from any time-dial position, at a voltage within 5 per cent of the tap-plug setting. For example: If the tap plug setting is 55 volts, the contacts will close when the voltage is reduced from a higher value down to 55 volts. The relay contacts will open at 110 per cent of the tap setting. For the 55 volt tap setting, the contacts will open when the voltage is increased approximately 61 volts.

TIME SETTINGS

The time of operation of the relay is determined primarily by the setting of the time dial. Further adjustment is obtained by moving the permanent magnet along its supporting shelf; moving the magnet in toward the back of the relay decreases the time while moving it out increases the time.

Figs. 2, 3, and 4 show the time-voltage characteristics of the various relays with the time-dial settings for obtaining each characteristic. To make time settings, set the time dial to the number required (to give the desired characteristics) by turning it until the number lines up with the notch in the adjacent frame. The time indicated by the curves is the time required to close the relay contacts when the voltage is suddenly decreased from operating value or above to the value on the curve.

The time voltage curves are plotted in per cent thus making them applicable for all tap settings.

INSPECTION

At the time of installation, the relay should be inspected for tarnished contacts, loose screws, or other imperfections. If any trouble is found, it should be corrected in the manner described under MAINTENANCE.




Figure 9. (6154392-5) Connections for Testing Relay Types IAV54 and IAV55

OPERATION

Before the relay is put in service, it should be given a partial check to determine that factory adjustments have not been disturbed. On relays which have time dials, the dials will be set at zero before the relay leaves the factory. It is necessary to change this setting so that the relay contacts may be opened.

The drop-out voltage should be checked on one or more taps making certain that the contacts close.

The time voltage curves should be checked for

one or more settings.

Recommended test connections for the above tests are shown in Fig. 8.

The relay may be tested while mounted on the panel, either from its own or another source of power, by inserting separate testing plugs in place of the connecting plugs. Or, the cradle can be drawn out and replaced by another which has been laboratory tested.

MAINTENANCE

These relays are adjusted at the factory and it is advisable not to disturb the adjustments. If for any reason, they have been disturbed, the following points should be observed in restoring them:

DISK AND BEARINGS

The lower jewel may be tested for cracks by exploring its surface with the point of a fine needle. The jewel should be turned up until the disk is centered in the air gap, after which it should be locked in position by the set screw provided for the purpose.

CONTACT CLEANING

For cleaning fine silver contacts, a flexible burnishing tool should be used. This consists of a flexible strip of metal with an etched roughened

surface, resembling in effect, a superfine file. The polishing action is so delicate that no scratches are left, yet corroded material will be removed rapidly and thoroughly. The flexibility of the tool insures the cleaning of the actual points of contact. Sometimes an ordinary file cannot reach the actual points of contact because of some obstruction from some other part of the relay.

Fine silver contacts should not be cleaned with knives, files, or abrasive paper or cloth. Knives or files may leave scratches which increase arcing and deterioration of the contacts. Abrasive paper or cloth may leave minute particles of insulating abrasive material in the contacts and thus prevent closing.

The burnishing tool described above can be obtained from the factory.

RENEWAL PARTS

It is recommended that sufficient quantities of renewal parts be carried in stock to enable the prompt replacement of any that are worn, broken, or damaged.

When ordering renewal parts, address the nearest Sales Office of the General Electric Company, specifying the quantity required and describing the parts by catalogue numbers as shown in Renewal Parts Bulletin No. GEF-3897.

POOR ORIGINAL

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
ELECTRIC TRANSMISSION AND DISTRIBUTION DEPARTMENT
RELAY TEST ORDER

5-1-74-11-
FILE Co. FILE COPY
DATE OCT. 19, 1976

TO THE DIVISION SUPERINTENDENT CAMDEN DIVISION _____ AT _____ KV
PLEASE DO THE FOLLOWING WORK AT SALEM GEN STATION ON #1A VITAL BUS LINE TO _____

| PRI | SEC | TEST | MAX. INCH | RELAY DATA | | | SETTING DATA | | | | | | | | | | | | | |
|-------|-------|------|-----------|------------|----------------|---------|---|---------|-------|---|---|-------------|----------|---------|-------|------|-------------|---------|----------|-----|
| | | | | RELAY | STOCK CODE 93- | RANGE | COND. ZONE | CURRENT | VOLTS | S | % | WATTS SLOPE | % R CALC | CURRENT | VOLTS | TEST | ANGLE °LEAD | PICK UP | DROP OUT | TIM |
| 24011 | 11A5D | | | IAC53A | 3624 | 4-16 | VITAL BUS OVERLOAD P.D. GROUND | 6.0 | | | | | | | | | | | | |
| | | | | IAC54A | 3639 | 0.1-0.4 | | 0.4 | | | | | | | | | | | | |
| | | | | IAC74A | 3643 | 55-140 | | | | | | | | | | | | | | |
| | | | | TD-5 | 6902 | | | | | | | | | | | | | | | |
| | | | | KET 230 | 7561 | | VITAL BUS UV TRAMP. - VITAL BUS 1 V. TRIP | | | | | | | | | | | | | |
| | | | | IAC74A | 3643 | 55-140 | | | | | | | | | | | | | | |
| | | | | IAC53A | 3624 | 4-16 | | 6.0 | | | | | | | | | | | | |
| | | | | IAC54A | 3639 | 0.1-0.4 | | 0.4 | | | | | | | | | | | | |
| | | | | IAC74A | 3643 | 55-140 | | | | | | | | | | | | | | |
| | | | | TD-5 | 6902 | | | | | | | | | | | | | | | |
| | | | | IAC66B | 3612 | 2.5-5 | Auxiliary Feed Pump Motor | 3.5 | | | | | | | | | | | | |
| | | | | IAC55A | 3609 | 1.5-6 | | 2.5 | | | | | | | | | | | | |

REASON FOR SETTING CHANGE: CT RATIO CHANGE UPDATE SETTING REARRANGEMENT
 IMPEDANCE CHANGE NEW INSTALL.

11A5D, 12A5D & 1A4D IAC74 RELAY SETTINGS CHANGES
 PER DCR-IEC-0394

LOADABILITY: _____ MVA ON _____ TRF BANKS
 _____ MVA ON _____ TRF BANKS
 _____ MVA ON _____ TRF BANKS

LINE: 4 HR RATING _____ AMPS
 30 MIN RATING _____ AMPS
 LOADABILITY _____ MVA _____ AMPS

TRANSFORMER:
 MVA ON _____ TRF BANKS
 MVA ON _____ TRF BANKS
 MVA ON _____ TRF BANKS

TO GENERAL MANAGER—ELECTRIC TRANSMISSION AND DISTRIBUTION:
 M L G *[Signature]* DATE 4/26/79 BY 1103

WORK COMPLETED: SIGNED _____

GENERAL MANAGER—ELECTRIC TRANSMISSION AND DISTRIBUTION: _____

APPENDIX II

POOR ORIGINAL

CALL FROM _____ TO _____

DATE _____

TIME _____

SUBJECT DATA

JOB NO. _____

ORDER NO. _____

| <u>Station Power Transformers</u> | No 1, | No 2 | No 21 - | No 2: |
|------------------------------------|--------------|--------------|------------|------------|
| Rating - Base | 60 | 60 | 15 | 15 |
| Voltage Ratio | 500/13.8 | 500/13.8 | 13.8/4.16 | 13.8/4.1 |
| Impedance | 10.79% #2 | 10.51% #2 | 5.8% #4 | 5.7% #4 |
| No load position (p.u Z - 1MVA) | (512.5) | (512.5) | (13,455) | (13,455) |
| | .001798 | .001756 | .00386 | .0039 |

Unit Substation Transformers

| xfrmr | 2HL | 2H-400 | 2H-230 | 2A-400 | 2A-230 |
|------------------------|----------|----------|----------|----------|----------|
| Rating - Base | 750 | 1000 | 750 | 750 | 300 |
| Voltage Ratio | 4160/208 | 4160/400 | 4160/240 | 4160/480 | 4160/240 |
| Impedance | 5.8% | 5.34% | 6.59% | 5.75% | 5% |
| Tap (p.u Z 1MVA) | .0773 | | | | |

| xfrmr | 2FL | 2F-400 | 2F-230 | 2C-400 | 2C-230 |
|---------------|----------|----------|----------|--------|--------|
| Rating - Base | 750 | 1000 | 750 | | |
| Voltage Ratio | 4160/208 | 4160/480 | 4160/240 | | |
| Impedance | 5.78% | 5.46% | 6.71% | 5.41% | 5% |
| Tap | | | | | |

CALL FROM TO _____

DATE 12/4/78

TIME _____

SUBJECT DATA.

JOB NO. _____

ORDER NO. _____

| XFMR | NLTC | LTC tap | Dragneedle range | Bal | BW | TD | R | Counter | Z on 15,00 |
|------|------|---------|------------------|-----|-----|------------|----|---------|------------|
| 7K | 4 | 4R | 14R to 16L | 124 | -22 | 30L 30R | 0 | 11348 | 5.8% |
| 12 | 4 | 1R | 12L to 16R | 124 | 2 | 30 | 0 | 10726 | 5.7% |
| 21 | 4 | 2R | 16L to 16R | 120 | 2 | 30 | 0 | 3201 | 5.8% |
| 22 | 4 | 3L | 5R to 16L | 120 | -2 | 30 | 16 | 3005 | 5.7% |

← (tab runs up @ down to do ratios)

NLTC = 13,455 volts. 1L = 4.34 1R = 4.86

No 1 NLTC = 2 10.79% on 64,000 NLTC = 512500

No 2 NLTC = 2 10.54% on 64,000

ACTUAL MEASUREMENTS FROM METERS (NO 2 CR)

| | CR | | |
|----------------|-------|---------------|-------|
| Keeney Line | 520KV | 1.8 A | 300mW |
| No 21 Sto. Pwr | - | 2600 | 16.2 |
| 22 Sto Pwr | - | 1700 | 10.8 |
| 13KV | 13.4 | | |
| vitals | 4200± | 4100 (local) | |
| group | 4180± | 4100± (local) | |

Note CR meters agree the LTC setting

SWITCHING ALL

500KV - all closed but 9-10, 1-9

13KV - normal

AKV: 21 carrying E, H, A, B

22 carrying G, F, C

W. R. [Signature] 12-4-78

Notes of Meeting

Attendees: J. Hebson
B. Daloy
W. Raughley
J. Popvich - System Planning

— Per our request System Planning ran studies to find the maximum 500 kV voltage at Salem.

The maximum practicable voltage on the 500 kV at Salem is 1.06 p.u. For this condition Salem 1 & 2 are on line with a 450 MVAR/Unit output. This condition will occur when system is going from a light load condition to a high load condition. This is done by boosting the VAR output of the base load units and putting the other units on line. Such a condition usually exists on late Sunday night-early Monday morning when the system is being built up. Otherwise, the highest voltage is 1.04 p.u.

WSR:aec

3Q1 25

IV. SALEM GENERATING STATION
MINIMUM EXPECTED STEADY-STATE
VOLTAGE CONDITIONS

Salem unit #2, scheduled for service in May, 1979, will be connected to the 500-kV transmission system as shown in Exhibit 4, including transmission line impedance data. Of concern in this section is the minimum steady-state voltage condition at Salem for the most critical yet extremely unlikely combination scheduled and sudden outage situation. Exhibit 5 is a power flow transcription of an all in peak load condition simulating a PSE&G capacity emergency power import level. Exhibit 6 is a condition which simulates the maintenance outage of Salem unit #1 along with the New Freedom-Deans 500-kV line.

In Exhibit 7, in addition to the previously described maintenance outages a sudden loss of the Salem-Keeney 500-kV line complicated with a stuck breaker at Salem, causes Salem unit #2 to trip leaving the auxiliary load of 44 MW at Salem to be fed radially from the New Freedom 230-kV bus. The resulting voltage shows a total reduction by 5.8% from the initial 103.6% on the 500-kV at Salem.

The attached calculation looks at the voltage transient resulting from connection of vital loads following a LOCA. This transient is not as severe as would be obtained under restart of an RCP under the event analyzed.

Start SI, charging, RTR, CS

BBC bus wire loading

$$\frac{1060}{13.10}$$

$$375 + 650 + 410 + 375 = 1810 + P$$

Assume .91 pf. .95 eff

$$KVA = \frac{1810(.746)}{.91(.95)} = 1595 KVA$$

assume .2 p.f.

$$Z = \frac{1}{1595} (.2 + j.9797) = .6269 (.2 + j.9797) = .6269 / 78.4$$

$$= .1253 + j.614$$

other load = 5 MVA @ .85 p.f.

$$= \frac{1}{6} (.855 + j.496) = .1425 / 26.48 = (.109 + j.079)$$

Reducing: $\frac{(.6269)(.1425) (\angle 78.46 + 26.48)}{(.1253 + .109) + j(.614 + .079)} = \frac{.1104 / 104.94}{.274 + j.688} = \frac{.1104 / 104.9}{.7405 / 68.2}$

$$= .1404 / 36.74 = .1125 + j.0839$$

plus transformer Z and cable Z

$$.1125 + j.0839 + j.0002 + j'.00366 + j.00017$$

$$= .1125 + j.0882 = .1429 / 38.09$$

assume some bus tapping in other end.

$$.0715 / 38.09 = .0562 + j.0441$$

$$.0562 + j.0441 + j.001798 = .0562 + j.0458 = .0725 \angle$$

$$V = E \left(\frac{.0715}{.0725} \right) \left(\frac{.1409}{.1429} \right) = E (.9862) (.9825) = E (.9689)$$

If system @ .978, taps offsetting.

$$V = .978 (.9689) = \underline{.9476}$$

Taking into account LTC which is set @ 1.0348 p.u.

Setting correspondingly to no-load is $\sim R9 - R10$ \therefore

$$.9476 (1.0624) = 1.006$$

During normal operation, the Safety Injection Pumps, Residual Heat Removal Pumps and Containment Spray Pumps are not operating except for tests. Up to five fan coolers are operating, depending upon the needs of the moment. At least one component cooling pump is operating.

During normal operation, an "S" signal may be generated in error. As soon as it is discovered that the "S" signal is false, the operator must defeat the signal and secure operation of the pumps to limit or prevent lifting of the pressurizer relief valves and eventual release of reactor coolant to the containment. The operator is locked out for performing any action for up to 2 minutes following receipt of the "S" signal until the start sequence is completed.

3.2 Abnormal Conditions

General

The design of the Salem Safeguard System includes the requirements that the station must be safely shut down during the occurrence of a loss of coolant accident (LOCA) and a coincident loss of offsite power (blackout). All electrical equipment needed during a LOCA is powered by the vital AC system which can be energized by standby diesel generator. The Safeguards Equipment Control (SEC) provides the necessary logic capable of initiating proper actions for any accident conditions (with possible continuation of events) assumed by the design of the station.

The SEC system is comprised of three independent control systems for each unit which determines the need for accident and/or blackout safety equipment, and start and load this equipment on the vital electrical system. Each SEC is independent and isolated from the others, and is associated with its own diesel generator.

Rev. 3

Each SEC can control safety loads according to four modes of operation described below:

3.2.1 Injection Phase

3.2.1.1 Mode 1 LOCA (with Off-Site Power Available)

Should a LOCA occur, the Solid State Protection System (SSPS) will send safety injection ("S") signal to the SEC system. The SEC initiates the following actions automatically:

-58a-

- a) Lockout manual control of safety-related loads.
- b) Start diesel generators (the diesels are not connected to the bus since off-site power is available).
- c) Automatically load all the following safety related loads to the vital bus.

- 240-480V Breaker (230V Control Center Loads)

- Start SI Charging Pumps ~

- Start Safety Injection Pumps

- Start Residual Heat Removal Pumps

- Start Containment Spray Pumps (If the "P" signal-high pressure in containment occur)

- Start service water pumps (alternate SW pump if the other fails to start)

- Start at least four Containment Fan Coolers (low speed operation) (20 TD. from HS to LS)

- Start Auxiliary Feedwater Pumps

- Start Chillers

- Start Emergency Control Air Compressors

- Start Aux. Bldg. Supply and Exhaust Fans

- Start Swgr. Room Supply Fans

The following valves will be operated to prepare for Emergency Core Cooling:

- The motor-operated valves at the inlet to (SJ 4 and 5) and discharge from (SJ 12 and 13) the Boron Injection Tank will be opened.

- The motor-operated valves in the normal charging paths (CV 139 and 140; CV 68 and 69; CV 40 and 41) will be closed; those in the seal water return line from the reactor coolant pump seals will be left open. Seal water return will be isolated on a "P" signal indicating high containment pressure.

800 2 (400)

1200 2 (600)

800 2 (400)

Running

460V

Rev.

B&C

- The valves on the line from the RWST to the Centrifugal Charging/Safety Injection Pump suction (SJ 1 and 2) will be opened.
- The valves in the concentrated boric acid circulating lines from the CVCS (SJ 108, SJ 78 and 70) will be closed.
- Any closed accumulator valves (SJ 54) will be opened.

3.2.1.2 Mode II - Blackout

If power should be lost to the 4 kV vital busses, each SEC receives inputs from undervoltage relays on each vital bus. The undervoltage signals are combined in a two-out-of-three logic matrix in each SEC. If an accident has not occurred, the SEC performs the following logic sequence summarized below:

- a) Trip all 460 V and 4160 V vital bus breakers.
- b) Start diesel generators.
- c) Lockout manual control of all bus loads until the automatic loading sequence is complete
- d) Close the diesel generator ACB
- e) Sequence the loading of safeguard equipment required for blackout conditions as shown below:
 - 240-480V Breaker (230V Control Center Loads)
 - Start SI Charging Pumps
 - Start Component Cooling Water Pumps
 - Start Auxiliary Feedwater Pumps
 - Start Service Water Pumps (Alternate SW pump if previous fails to operate)
 - Start Emergency Control Air Compressor
 - Start Chillers
 - Start Aux. Bldg. Supply and Exhaust Fans
 - Start Swgr. Rooms Supply Fans

Rev. 3

OPERATING INSTRUCTIONS
 1-3.6
 NOT STANDBY TO COLD SHUTDOWN

1.0 PURPOSE

- 1.1 This instruction outlines the sequence in which systems are placed in service for plant shutdown from Hot Standby (Mode 3) to Cold Shutdown (Mode 5). Specific operating details and valve positions are found in the referenced operating instructions.
- 1.2 In the event plant conditions require a delay during some part of this procedure, the Section Supervisor/Shift Supervisor shall advise the Supervisor/Shift Supervisor of the delay and the procedure is suspended or interrupted.
- 1.3 At the conclusion of the procedure prior to completion, the Section Supervisor/Shift Supervisor shall note the reason, time and date of the completion of each check off sheet which has been entered. He will then file these check off sheets in the normal manner.
- 1.4 All steps of this instruction, with an asterisk, are to be signed off on the appropriate check off sheets.
- 1.5 Procedural steps may be completed, initial conditions may be satisfied in any order.

2.0 INITIAL CONDITIONS

- *2.1 The plant is in Hot Standby with the control rods banks completely inserted and shutdown rod banks position and PCB boron concentration as specified in Fig. 20(b) of the Reactor Engineering Manual.
- *2.2 System temperature is being maintained approximately at the setpoint T_{avg} (547°F) by use of the Steam Dump System in the MAIN STEAM PRESS CONT mode or by use of the Atmospheric Steam Relief (MSLR) Valves.
- *2.3 Steam Generator water levels are being maintained at $\pm 10\%$ by operating the Auxiliary Feedwater System.
- 2.4 Four (4) Reactor Coolant Pumps are in operation to provide circulation through the core and minimize temperature differentials among the loops.
- *2.5 At least one Source Range Channel is operational and the SR HIGH FLOW AT SHUTDOWN alarm is operational and is NOT BLOCKED.

3.0 PRECAUTIONS

- 3.1 Temperatures and Pressures.

POOR ORIGINAL

- 1.1.1 The residual heat removal loop must not be placed in service until the reactor coolant system pressure is below 100 psia and the pressure is ≤ 100 psia.
- 1.1.2 The reactor coolant pumps must not be operated when the RCS pressure is not enough to maintain a differential pressure greater than 200 psia across the RCP's No. 1 seal or when the volume control tank pressure is less than 15 psia.
- 1.1.3 When the RCS is solid and under control of reactor pressure control valve 15V13, an increase in RCS pressure should be expected whenever an RHR pump is stopped. Likewise, a decrease in pressure will result from starting an RHR pump.
- 1.1.4 When starting an RHR pump with the RCS solid and at least one RCP in operation, special attention must be given the precautions in 01-1-3.1.1, "Initiating Residual Heat Removal", to prevent decreasing the RCS pressure below the minimum required for RCP operation (RCS solid).
- 1.1.5 The reactor core should always be supplied with a flow of water for cooling, and reliable temperature indications, therefore, when the Reactor Coolant System temperature is below 150°F, at least one Residual Heat Removal Pump or one Reactor Coolant Pump should be operation.



NOTE

Under abnormal conditions, when coolant cannot be supplied to the reactor core, a backup means of temperature detection is available to the in-core thermocouples.

- 1.1.6 When starting a Reactor Coolant Pump, special attention must be given the precautions in 01-1-3.1.1, "Reactor Coolant Pump Operation", to prevent over-pressurization of the RHR system or the RCS.
- 1.1.7 The Reactor Coolant Pump No. 1 seal bypass valve, 15V114, must be closed when the RCS pressure has been decreased to 100 psia.
- 1.1.8 The Reactor Coolant Pump seal water temperature must not exceed 140°F.
- 1.1.9 Component cooling to the Reactor Coolant Pumps must be supplied any time a Reactor Coolant Pump is operating and should not be secured to an idle pump until the RCS has been cooled below 150°F and the pump has been idle for at least 1/2 hour.
- 1.1.10 The pressurizer sprays must not be used, if the temperature differential between the pressurizer and the spray fluid is greater than 120°F.
- 1.1.11 The RCS temperature should be maintained at least 50°F lower than the pressurizer during cooldown.



3.1.12 Plot on Operations Log No. 4, the RCS cooldown rate on at least a 10 minute interval maintaining the cooldown rate $\geq 100^\circ\text{F}/\text{hour}$ and within the limits of the operating envelope curve in safety Technical Specification Surveillance 4.4.9.1.B.

3.1.13 Plot on Operations Log No. 5, the pressurizer cooldown rate on at least a 10 minute interval maintaining the cooldown rate $\geq 100^\circ\text{F}/\text{hour}$ in safety Technical Specification Surveillance 4.4.9.2.

3.1.14 Do not remove the Rod Drive Vent Fans from service while the control rod drive mechanisms are energized.

3.1.15 Do not remove the Reactor Shield Ventilation Fans or the Mobile Support Fans from service until the RCS temperature is $< 145^\circ\text{F}$.

3.1.16 During cooldown of the RCS from 315°F to less than 200°F , the number of running RCP's is as follows:

| <u>RCS TEMP.</u> | <u>RCP'S IN-SERVICE</u> |
|--|---|
| 315°F TO 400°F | 4 |
| 400°F TO 350°F | 3 |
| 350°F TO 250°F | (2) 11 RCP and 11 RCP OR 12 RCP and 12 RCP |
| LESS THAN 200°F | (1) 11 RCP OR 11 RCP OR NO RCP'S RUNNING AND RCP IN-SERVICE |

NOTES

- No. 11 or No. 12 RCP should be operated to maintain pressurizer spray.
- Operation of RCP's, other than specified above, can result in uneven RCS temperatures among the loops and create conditions in the S/C's leading to inadvertent safety injections created by S/C differential pressures.

3.1.17 Maintain at least one Reactor Coolant Pump in service during the degassing and borating operations.

POOR ORIGINAL

- 3.1.18 DO NOT exceed the 1000 psi to 1100 psi range for steam generator tube stress.
- 3.1.19 When in the S/G standby condition, the rate of steam generator addition to a Steam Generator is limited to 2.0×10^4 gpm. Whenever the S/G level is 100% narrow range.
- 3.1.20 When the RCS temperature (as indicated by 1009 11 or 1009 12) increases to 115°F and the RCS pressure is reduced to less than 110 psia, the Westinghouse Overpressure Protection System (WOPS) must be armed.
- 3.1.21 During the cooldown of the RCS, avoid the use of the Atmospheric Relief Valves when the condenser is available.

NOTE

Use of the Atmospheric Relief Valves warrants close operator monitoring of 11-14 steam generator pressures (observed on the S/G Protection Channels) in order to avoid S/G differential pressures resulting in inadvertent safety injections.

3.2 Chemistry

- 3.2.1 The flow rate of reactor coolant shall be greater than 3000 gpm whenever a change in reactor coolant system boron concentration is being made.
- 3.2.2 When changing RCS boron concentration, Westinghouse sprays should be utilized to minimize the differential between Westinghouse and loop boron concentration. The use of spray flow should continue until the difference is less than 30 gpm.
- 3.2.3 Before placing the RCS system in service, its boron concentration must be such that in the RCS case at that concentration, the minimum shutdown margin requirements would be met.
- 3.2.4 The hydrogen concentration in the reactor coolant should be reduced to less than 5 cc/kg prior to being opened for maintenance or repair.

3.3 Reactivity Control

- 3.3.1 A minimum of one source range channel shall be in operation any time the reactor is shutdown.
- 3.3.2 The RCS must be borated, prior to start of cooldown, to insure the minimum SDM is maintained. Refer to Fig. 30(a) of the Reactor Engineering Manual for the RCS boron concentration required for cold shutdown mode of operation.

NOTE

Approximately 46,000 gallons (> 10.5%) of primary water (30,000 gallons above low level alarm) and 1,000 gallons of concentrated boric acid (in excess of the 5106 gallons required by the Technical Specifications) must be available for cooldown makeup.

2.3.2 The Radio Count Rate Channel should be in operation any time the reactor is shutdown.

4.0 CHECK OFF SHEETS

4.1 Plant Cooldown

5.0 PROCEDURE

5.1 If the Reactor Coolant System is to be opened for repair ~~or~~, increase the pressurizer rate to its maximum rate, however, do not exceed 100 gpm.

5.2 If required, begin the degassing of the RCS IAW of II-1.1.11, "Volume Control Tank Degassing/Flotation".

NOTE

Cold Shut-Down Concentration

Degassing and cooldown may be accomplished concurrently.

5.3 Set the RCS to a concentration described from Figure 201a of the Reactor Engineering Manual. Set the IAW of II-1.1.6, "RCS Concentration Control". Perform a shutdown Margin Calculation IAW the Reactor Engineering Manual prior to entering Mode 3 for the above conditions.

5.4 De-energize all Pressurizer heaters after the Pressurizer boron concentration has been verified to be within 50 ppm of the concentration in the reactor coolant loops.

NOTE

If outage is going to be of short duration and the bubble maintained in the Pressurizer, the following steps pertaining to Pressurizer cooldown are to be marked N/A (not applicable) on Check Off Sheet 4.1: Steps 5.4, 5.11, 5.27, 5.28 and 5.30.

5.5 Notify Technical Supervisor-Chemistry of impending plant cooldown and the need to sample the RCS per the Chemistry Department requirements.

WILL BE IN AUTO WHEN CR IS EVACUATED - CONT ADJUST BLEND LOCALLY




5.6 Place the Make-Up Mode Selector in AUTO and adjust the blend.

5.7 Verify that a normal level in the Volume Control Tank is being maintained during the cooldown, except during degassing operations.

POOR ORIGINAL

5.9.1 Increase the rate of steam dump by lowering the pressure controller in
 steam dump pressure controller, or place the main steam dump pressure controller in
 MANUAL and periodically adjust the setting of the controller to maintain the
 rate of steam dump. If the condenser is unavailable for dumping steam, the use of the 11-14 MS10
 Atmospheric Relief Valve in AUTO or MANUAL is authorized. Refer to Operations Log No. 5
 for the cooldown rate on at least 30 minute intervals maintaining the cooldown rate 100°F/hr
 and within the limits of the pressure-temperature curve.

CAUTION



Cooldown of the RCS via the 11-14 MS10 Atmospheric
 Relief Valves requires close operator monitoring
 of the S/C pressure so that S/C or inadvertent
 safety injections will not occur. **TOO BAD!**

(332)

- 5.9.1 Maintain Steam Generator levels in the normal operating range.
- 5.9 Maintain four (4) RCP's in service when the RCS temperature is between 517°F and 400°F.

5.10 When the RCS temperature reaches the setpoint of the 7-13 Temperature (517°F) as indi-
 cated by the LOW T_{avg} (1/4 Low-Low T_{avg}) light on the RCP status panel:

CAN'T DO

- 5.10.1 Depress the TRAIN "A" and TRAIN "B" STEAMLINE PRESSURE BY BLOCK pushbuttons
 to block the high steam flow coincident with low steam pressure or Low-Low
 T_{avg} safety injection signal.
- 5.10.2 Depress the STEAM DUMP INTERTRIP and the BYPASS T_{avg} pushbuttons to bypass
 the Low-Low T_{avg} steam dump block to allow the cooldown to continue.

CAUTION

These blocks will automatically reset above 517°F,
 should temperature then decrease below 517°F the
 actions described above must be repeated.

*SI WILL CAUSE
 MAJOR VALVE REALIGN'G IN
 PLANT AND FREQUENT PUMPS TO
 STALL
 MANUAL CONTROL
 OF CHARGING USING CVSS*

As cooldown progresses, adjust charging flow to gradually increase pressurizer level
 to approximately 70%.

NOTE

Readjust No. 13 Charging Pump low speed stop to
 maintain minimum seal injection flow as
 pressure is decreased.

WOW?

5.12 Transfer the controllers for the spray valves to MANUAL and slowly open the spray
 valves to begin the cooldown and depressurization of the pressurizer. Observe presur-
 izer 5.1.10. Refer to Operations Log No. 5 the cooldown rate on at least a 30 minute
 interval maintaining the cooldown rate ≤ 100°F/hour.

POOR ORIGINAL

When the RCS pressure has been reduced below 1015 psig, manually block the low pressure pressure controller with low pressurizer level safety injection signal by depressing the TRIP "A" and TRIP "B" pushbutton positions or block pushbuttons.

CAUTION

The low pressurizer pressure controller with low pressurizer level safety injection signal will automatically reset should pressure increase above 1015 psig and must be reblocked when pressure once again decreases below 1015 psig.

~~WESTINGHOUSE SAYS WE MAY NOT HAVE TO DO THIS IF LOWER 400. 3RD TEMPERATURE STAYS DOWN (200°F)?~~

5.14 When the seal leakage from any operating Reactor Coolant Pump No. 1 seal decreases to 1 gpm or the RCS pressure is \leq 1500 psig, open Reactor Coolant Pump Seal Bypass Valve 15C114. Record valve status in Valve Deviation List.

5.15 Open additional letdown orifice isolation valves, as necessary, to maintain letdown flow rate. *ch*

5.16 When the steam generator's pressure has decreased to \leq 500 psig (3 and 4) the condensate pumps may be used to maintain steam generator levels and for continuing the cooldown (the auxiliary heat pumps may be secured at this time).

5.17 When the RCS pressure decreases below 1000 psig, close Accumulator Outlet Valves 11, 12, 13 and 15C101, and cut the electrical supplies to the valve motors. ~~SHUT MANUALLY @ VALVE~~ *CONTR*
Record valve status in Valve Deviation List.

5.18 When the RCS temperature has been reduced below 400°F, reduce the running RCP's to three (3). No. 11 RCP or 13 RCP should remain in operation to provide pressurizer spray flow. ~~Keep monitoring of each RCP verify the respective RCP breaker open status lights on RCP status panel extinguish.~~

5.19 When the RCS temperature has been reduced below 350°F and pressure is \leq 1015, place the RHR System in service IAW 01-5.1.2, "Initiating Residual Heat Removal".

5.20 When the RCS temperature is below 350°F. *done? @ SI INITIATION (OR NEED SI BLOCKS)*

5.20.1 Cut the electrical supplies to both Safety Injection Pumps: rack the 4KV breakers out and turn off the SC Control power. Close 11 and 15C134 and 15C135. Record the position change in the Valve Deviation List for 01-4.3.1, "616 Normal Operation".

POOR ORIGINAL

5.20.1 Shut the electrical supply to one Centrifugal Charging Pump; back the 4KV breaker out and turn on the DC Control Power.

NOTE

A minimum of one Centrifugal Charging Pump must remain operable as a part of an RCS subsystem until RCS temperature is below 200°F as required by the Technical Specifications.



5.20.2 Cut the electrical supplies to both motor driven Auxiliary Feedwater Pumps; back the 4KV breakers out and turn on the DC Control Power.

NOTE

It is necessary or desirable to use the Auxiliary Feed Pump(s) to maintain Steam Generator levels, clearing and loading may be delayed until the pump(s) is no longer required.

5.20.3 Close and lock all air locks, the steam supply valve to No. 11 Auxiliary Feedwater Pump. Record valve status in the Valve Deviation List.

5.20.4 Reduce the running RCP's to two (2) in the following combinations:

- a) 11 RCP and 14 RCP
- OR
- b) 13 RCP and 12 RCP

Upon stopping of each RCP verify the respective RCP breaker open status light on the status panel energizes.

5.20.5 Test the RCS low pressure protection system (as indicated by 100% 11 or 100% 12 Valve Status) by manually closing the RCP and RCP.

5.20.6 When the RCS temperature reaches 315°F (as indicated by 100% 11 or 100% 12 Valve Status) reduce RCS pressure to less than 175 psia (as indicated by 100% 11 or 100% 12 Valve Status) with RCS pressure less than 175 psia and RCS temperature at 315°F, turn the RCP's by depressing Channel 1 and 11 controllers to the "ON" position.



5.20.7 When the RCS temperature reaches 300°F and water chemistry has been adjusted, place the Steam Generators in "Hot Layup" (MAX OF 11-9.3.3, "Hot Layup and Venting the Steam Generators").

NOTE

In the absence of a hot layup, placing the Steam Generators in "Hot Layup" is not required.

POOR ORIGINAL

5.20.8 With the RCS temperature 250°F, the number of running RCP's can be reduced to one (1). No. 13 RCP should remain in service to provide minimum spray flow. Upon stopping of each RCP verify the respective RCP breaker open status light on the status panel energizes.

5.21 When a pressurizer is to be replaced, break vacuum and remove the reactor coolant system from service, as desired.

5.24 If the S/D's will not be put in "Hot Layup", open wide 11-14X610 Atmospheric Relief Valves to facilitate S/D heat removal.

5.26 When the RCS temperature is below 200°F:

- * 5.26.1 Cut the electrical supplies to both Centrifugal Spray Pumps; rack the 4KV breakers out and turn off the DC Control Power.
- * 5.26.2 Cut the electrical supply to remaining Centrifugal Charging Pump; rack the 4KV breaker out and turn off the DC Control Power. If the other Centrifugal Charging Pump has not been made inoperable, cut its electrical supply, rack the 4KV breaker out and turn its DC Control Power off.

5.28 If the shutdown is to be of long duration, log as the Generator IAW of 17-2.3.2, "Generator Gas System - Normal Operation".

5.27 If the Pressurizer is to be filled solid, establish a continuous bleed through the sample system IAW 4D-1.6.3.04, "Pressurizer System Spare Sampling", to vent off non-condensable gases. Take the Reactor Coolant System solid IAW of 11-1.3.4, "Filling and Venting the RCS".

5.28 When the Pressurizer is solid, slowly open 1501 and/or 1502, Pressurizer Spray Valves to obtain a uniform cooldown of the Pressurizer.

5.29 When the Cold Shutdown, Mode 5, RCS temperature has been achieved, continue operation in Mode 5 with:

- 5.29.1 One RCS in service
- 5.29.2 Pressurizer bubble exists
- 5.29.3 RCVS "ON"
- 5.29.4 RMR System in service for temperature control.

NOTE

This is the normal, preferred operation of the RCS for cold shutdown, Mode 5. Possibility of a RCS overpressurization is minimized. The RCS accumulators may remain pressurized above their MPT limit of 70°F (Refer to CI 11-4.3.4). Planned deviations from the above must be authorized by the Chief Engineer or Station Operating Engineer.

* 5.30 To continue the cooldown of the pressurizer as required by maintenance or refueling outage:

- 5.10.1 Open Pressurizer Auxiliary Spray Stop Valve 10V76. Record valve status in the Valve Deviation List.
- 5.10.2 Close Charging Line Stop Valve 10V77. Record valve status in the Valve Deviation List.
- 5.10.3 Adjust the Recirculating Charging Pump speed to obtain the desired cooldown of the Pressurizer.
- 5.10.4 Continue to circulate through the auxiliary spray line until the Pressurizer temperature has been reduced to its desired temperature.

5.11 When to maintain the RCS pressure below 100 psia close the RCS Seal Bypass Valve 10V114.

- 5.12 When to maintain RCS pressure less than 25 psia:
 - 5.12.1 Open 10V1 or 10V2 to the WHI.
 - 5.12.2 Open the WHI to the sprayer (approx. 10A).
 - 5.12.3 Continue cooldown of the Pressurizer to the desired temperature using auxiliary spray flow.

NOTE

Nitrogen makeup to the WHI with 10V1 or 10V2 open will occur to maintain the RCS at a positive pressure (approx.).

CAUTION

Abnormal or sudden pressurizer level increases are indicative of vacuum formation.

- 5.12.4 If the RCS is to be drained below the level range of the Pressurizer Cold Calibrated Channel, refer to OI 11-1.0.6, "Draining the RCS".
- 5.12.5 If the RCS is to be drained LOW of 11-1.0.6, "Draining the RCS", cut the electrical power to 10K1 and 10K2 and limit RSC pump operation to one (1).

5.11 Maintain RCS temperature >30°F unless sensor is relieved from reactor head studs.

Prepared by E. P. Gushchinski

H. J. [Signature]
 Manager - Salem Generating Station
 Date 3/14/78

SCRC Meeting No. 50-78

POOR ORIGINAL

CHECK OFF SHEET 4.1

PLANT SHUTDOWN

| NO. | ITEM | SIGNATURE | DATE |
|--------|--|-----------|------|
| 2.1 | Set standby Mode of operation | | |
| 2.2 | S/G level at 1.024 | | |
| 2.3 | Four RCP's in service | | |
| 2.4 | Source Range Channel Operable | | |
| 2.5 | Degas RCB | | |
| 2.6 | RCB connected for X _{all} 4.39 | | |
| 2.7 | Pressurizer heaters ON | | |
| 2.8 | Commanded RCB Sampling | | |
| 2.9 | CVCS - Makeup Control in AUTO | | |
| 2.10 | Four RCP's in service (347°F to 400°F) | | |
| 2.10.1 | Pressure Pressure at Block (P-11) | | |
| 2.10.2 | Steam Drum Interlock Bypass T _{avg} | | |
| 2.11 | Pressure level increased to 1704 | | |
| 2.12 | Pressurizer spray valves MANUAL OPEN | | |
| 2.13 | Pressurizer pressure at block (P-11) | | |
| 2.14 | RCB seal bypass valve open | | |
| 2.17 | Accumulator Outlet Valves Closed | | |
| 2.18 | Three (3) RCP's in service (4100°F) | | |
| 2.19 | Initiate RHR | | |
| 2.20.1 | CR Safety Injection Pumps | | |
| 2.20.2 | CR Containment Charging Pump | | |
| 2.20.3 | CR Motor Driven Auxiliary Feedwater Pumps | | |
| 2.20.4 | LI & LIMSIS Closed and CR | | |
| 2.20.5 | Two (2) RCP's in service (4350°F) | | |
| 2.20.6 | Test RCBs | | |
| 2.21 | RCPs "ON" | | |
| 2.22 | S/G's in Wet Layup | | |
| 2.22.1 | One (1) RCP in service (4350°F) | | |
| 2.22.2 | CR Containment Spray Pumps | | |

*NOTE: If the bubble is to be maintained in the Pressurizer, these steps may be marked N/A

NOTE: If the outage is of short duration, this step may be marked N/A (Not Applicable).

POOR ORIGINAL

CHECK LIST SHEET 4.1
PLANT COLLECTION

| <u>NO.</u> | <u>ITEM</u> | <u>INITIALS</u> | <u>DATE</u> |
|------------|--|-----------------|-------------|
| 01 | Old Reservoirs Completely Empty | | |
| 02 | Water Pressures, 1/2 way 200 psi | | |
| 03 | Concrete Reservoirs Collected | | |
| 04 | 2nd. Bubble, 2000 B. One 200 Observation | | |
| 05 | Complete Reservoirs Collected | | |
| 06 | Old 1981 and 1982 | | |

POOR ORIGINAL

*NOTE: If the above is to be performed in the presence, these steps may be marked N.A.
 *NOTE: If the above is of short duration, this step may be marked N.A. (Not Applicable)

Reviewed by _____ Date _____
 SENIOR PLANT SUPERVISOR, PLANT SUPERVISOR

EMERGENCY INSTRUCTION
I-4.0
SAFETY INJECTION INITIATION

1.0 PURPOSE

- 1.1 This instruction is provided to present the immediate automatic and manual actions required to be performed on the receipt of any Safety Injection actuation, regardless of the cause.
- 1.2 This instruction contains the information required to direct the operator to the appropriate Emergency Instruction to cope with the existing plant conditions.

2.0 INITIAL CONDITIONS

- 2.1 Safety Injection has initiated.

3.0 IMMEDIATE ACTIONS

- 3.1 Verify the following automatic actions have occurred.

3.1.1 Reactor trip by verifying all control rods are fully inserted by checking the individual rod position indications and rod bottom lights.

1. If any control rods do not indicate full insertion, initiate a manual reactor trip.

3.1.2 Accident loading of the Safeguards Equipment has taken place and the following equipment is running by observing the indicating lights on the status panel on RP-4 and by observing the control bezels for each of the following:

1. Centrifugal Charging Pumps
2. Safety Injection Pumps
3. Residual Heat Removal Pumps
4. Auxiliary Feedwater Pumps (Motor Driven)
5. Service Water Pumps
6. Containment Fan Coil Units in slow speed
7. Diesel Generators

3.1.3 Reactor Coolant temperature is decreasing to or being maintained at 547°F by either steam dump or atmospheric steam relief.

3.1.4 Within two minutes reduce Auxiliary Feedwater Flow to the Steam Generators to limit the rate of rise to <1.2 in/min by monitoring the wide range level recorders (<0.2%/min on the wide range until the level is > 10% on the narrow range indication for all Steam Generators not affected by the failure. Then re-establish maximum Auxiliary Feedwater Flow.

NOTE

This limitation applies to Unit 1 only.

3.1.5 Turbine trip by verifying the following:

1. Unit Trip light on the EH Console
2. Turbine speed decreasing

If the turbine does not indicate a tripped condition, initiate a manual trip from the control console.

3.1.6 Main Feed Pumps tripped by observing the indications on the control bezel. If either pump has not tripped, trip it manually.

3.1.7 Feedwater isolation by observing the indicating lights on the Feedwater section of RP4.

3.2 Verify Safety Injection Pump flow to the Cold Legs from the operating Safety Injection Pump(s) by observing the discharge flow meters on the control console. When RCS pressure decreases to <1550 psig as read on the Wide Range Indicators on the control console, stop all Reactor Coolant Pumps.

3.3 Verify Containment Phase A isolation has taken place by observing the indicating lights on the status panel RP-4.

3.4 Announce over the Station PA System twice: UNIT 1(2) REACTOR TRIP, SAFETY INJECTION.

4.0 SUBSEQUENT ACTIONS

4.1 Verify Safety Injection is in progress by checking each of the following. If any equipment or valve is not in the desired condition or position attempt to establish the desired condition at the individual bezel on the control console.

CAUTION

DO NOT attempt to reset the Safety Injection or SEC in order to place equipment in the desired condition. System design is such that sufficient redundancy is provided to overcome single failures.

4.1.1 Verify, utilizing console and/or 1(2)RP4 status panel indications, that the loads listed on Table I have been loaded onto the vital busses.

4.1.2 Verify that the Containment Fan Coolers meet the following conditions upon starting:

- a. Fan Coolers have decreased speed
- b. Fan Coolers service water flow has increased from 700 gpm to 2500 gpm
- c. Roughing filter dampers have closed
- d. HEPA inlet dampers have opened
- e. HEPA outlet dampers have opened

4.1.3 Check that the following valves have opened by observing the status panel. If any valve fails to open, attempt to manually open from the control console

- | | |
|----------|-----------------------------------|
| 1(2)SJ4 | Boron Injection Tank Inlet Valve |
| 1(2)SJ5 | Boron Injection Tank Inlet Valve |
| 1(2)SJ12 | Boron Injection Tank Outlet Valve |
| 1(2)SJ13 | Boron Injection Tank Outlet Valve |

- 1(2)SJ1 Charging Pump Suction From RWST
- 1(2)SJ2 Charging Pump Suction from RWST

4.1.4 Check that the following valves have closed. If any valve fails to close, attempt to close the valve from the control console.

- 1(2)SJ78 Recirc to Boric Acid Tank
- 1(2)SJ79 Recirc to Boric Acid Tank
- 1(2)SJ108 Recirc to Boron Injection Tank
- 1(2)CV68 Charging System Stop Valve
- 1(2)CV69 Charging System Stop Valve
- 1(2)CV139 Charging Pump Disch to SWHX
- 1(2)CV140 Charging Pump Disch to SWHX
- 1(2)CV40* Volume Control Tank Discharge Valve
- 1(2)CV41* Volume Control Tank Discharge Valve
- 1(2)CV3 Orifice Isolation Valve (Letdown)
- 1(2)CV4 Orifice Isolation Valve (Letdown)
- 1(2)CV5 Orifice Isolation Valve (Letdown)
- 1(2)CV7 CVCS Letdown Line
- 1(2)CV116 Reactor Coolant Pump Seal Water Discharge
- 1(2)CV284 Reactor Coolant Pump Seal Water Discharge
- 11(21)SW20 Turbine Generator Area Supply Valve
- 11(21)SW20 Turbine Generator Area Supply Valve
- 1(2)SW26 Turbine Generator Area Isolation Valve

NOTE

*These valves will not close until either 1(2)SJ1 or 1(2)SJ2 is fully open.

4.2 Verify that Phase "A" Containment Isolation has taken place by checking that the valves listed in Table II are closed. Should a valve fail to close, attempt to close it from the control console.

4.3 Verify that Feedwater Isolation has taken place due to the Safety Injection.

4.3.1 Check that the following valves have closed by observing the status panel and/or the console bezel. If any valve has failed to close, attempt to close it from the control console.

- 11(21)BF13 Feedwater Inlet Stop Valve
- 11(21)BF19 Feedwater Control Valve
- 11(21)BF40 Feedwater Bypass Valve
- 12(22)BF13 Feedwater Inlet Stop Valve
- 12(22)BF19 Feedwater Control Valve
- 12(22)BF40 Feedwater Bypass Valve

- 13(23)BF13 Feedwater Inlet Stop Valve
- 13(23)BF19 Feedwater Control Valve
- 13(23)BF40 Feedwater Bypass Valve
- 14(24)BF13 Feedwater Inlet Stop Valve
- 14(24)BF19 Feedwater Control Valve
- 14(24)BF40 Feedwater Bypass Valve

4.4 Verify that the 4160 V Group Busses have transferred from the No. 1(2) Auxiliary Power Transformer to No. 11(12) and No. 12(22) Station Power Transformers.

4.4.1 Check that the following 4160 V breakers have opened and acknowledge them on the appropriate control console bezel:

- 1(2)BGGD
- 1(2)BFGD
- 1(2)AEGD
- 1(2)AHGD

4.4.2 Check that the following 4160 V breakers have closed and acknowledge them on the appropriate console bezel:

- 12(22)GSD
- 12(22)FSD
- 11(21)ESD
- 11(21)HSD

4.5 Verify the following fans have stopped by observing the indications as noted. If any fans are still running, attempt to stop them manually.

- No. 11 & 12 (21 & 22) Iodine Removal, Control Console
- No. 11, 12, 13, 14 (21, 22, 23, 24) Nozzle Support, Control Console
- No. 11 & 12 (21 & 22) Reactor Shield, Control Console
- No. 11, 12, 13, 14 (21, 22, 23, 24) Control Rod Drive, Control Console
- No. 11 & 12 (21 & 22) RHR Pump Room Coolers, RP2
- No. 11 & 12 (21 & 22) Charging Pump Room Coolers, RP2
- No. 11 & 12 (21 & 22) Containment Spray Pump Room Coolers, RP2

4.6 Verify Control Area Air Conditioning has shifted to the ACCIDENT - INSIDE AIR mode of operation and the following actions have occurred by observing the status panel on RP2. If any actions do not occur, manually initiate them IAW OI II-17.3.2, "Control Room Ventilation Operation", Section 5.3.

NOTE

Control Room Ventilation Isolation of Unit No. 1(2) will also isolate Unit No. 2(1) Control Room, however, its green NORMAL mode indicator will remain illuminated.

- 4.6.1 No. 11, 12, 13 (21, 22, 23) Chillers are running.
- 4.6.2 No. 11 & 12 (21 & 22) Chilled Water Pumps are running
- 4.6.3 No. 11, 12, 13 (21, 22, 23) Control Area Supply Fans are running
- 4.6.4 No. 11 & 12 (21 & 22) Emergency Control Area Supply Fans are running.
- 4.6.5 Battery Exhaust Fan has stopped.
- 4.6.6 Control Valves 1(2)CH30 and 1(2)CH151 close to isolate the Administrative Building.
- 4.6.7. Control Area Dampers positioned as follows:

| | | | | |
|---------------|----------------|----------------|----------------|----------------|
| CAA1 - Closed | CAA4 - Closed | CAA17 - Open | CAA20 - Closed | CAA33 - Closed |
| CAA2 - Closed | CAA5 - Open | CAA18 - Closed | CAA31 - Closed | |
| CAA3 - Closed | CAA14 - Closed | CAA16 - Closed | CAA32 - Closed | |

5.0 IDENTIFICATION OF FOLLOW-UP ACTIONS

5.1 If RCS Pressure decreased rapidly with no other indications of primary or secondary leakage, verify the following are closed or isolated at their individual control bezels.

5.1.1 Pressurizer Spray Valves (PS-1&3)

- 1. If PS1 or PS3 is open and will not close, trip the Reactor Coolant Pump in the associated loop.

- 1(2)PS1 - Trip 11(21) RCP
- 1(2)PS3 - Trip 13(23) RCP

5.1.2 Pressurizer Power Operated Relief Valves (PRL & 2)

5.1.3 Pressurizer Overpressure Protection Valves (PR 47 & 48 on Unit 2 only)


5.2 If RCS Pressure has stabilized after the initial decrease which initiated Safety Injection and Containment Isolation, the problem may be in an area or system which has been subsequently isolated. Investigate the following:

5.2.1 Auxiliary Building for:

- 1. Increases in Radiation
- 2. Unexplained accumulations of water

5.2.2 Pressurizer Auxiliary Spray Valve (CV75). Ensure it is closed.

5.3 Utilize the following matrix in order to determine which subsequent Emergency Instruction to follow.



Prepared by J.V. Bailey
 Reviewed by J.M. Zupko
 BORC Meeting No. 56-79

H.J. Widen
 Manager - Salem Generating Station
 Date 7/6/79

"BLACKOUT WITH SAFETY INJECTION" LOADING SEQUENCE

| #11(21) DIESEL GENERATOR | #12(22) DIESEL GENERATOR | #13(23) DIESEL GENERATOR |
|--|--|--|
| 1(2)A | 1(2)B | 1(2)C |
| 240/480V Breaker | 240/480V Breaker | 240/480V Breaker |
| 11(21) SI Pump | 11(21) Charging Pump | 12(22) Charging Pump |
| 11(21) RHR Pump | 12(22) RHR Pump | 12(22) SI Pump |
| 15(21) SW Pump | 14(24) SW Pump | 11(25) SW Pump |
| 16(22) SW Pump | 13(23) SW Pump | 12(26) SW Pump |
| 11(21) Containment Fan (Low Speed) | 12(22) Containment Fan (Low Speed) | 13(23) Containment Fan (Low Speed) |
| 11(21) Auxiliary Feed Pump | 14(24) Containment Fan (Low Speed) | 15(25) Containment Fan (Low Speed) |
| 11(21) Auxiliary Building Exhaust Fan | 12(22) Auxiliary Feed Pump | Emergency Air Compressor |
| 11(21) Chiller | 12(22) Auxiliary Building Supply Vent Fan | 11(21) Auxiliary Building Supply Vent Fan |
| 11(21) SWGR Room Supply Fan | 12(22) Auxiliary Building Exhaust Fan | 13(23) Auxiliary Building Exhaust Fan |
| | 12(22) Chiller | 13(23) Chiller |
| | 12(22) SWGR Room Supply Fan | 13(23) SWGR Room Supply Fan |

NOTE

This sequence is initiated on any Safety Injection actuation with or without a blackout, only in a blackout condition will the Diesel Generator breakers close after first stripping the bus and the loads will then be sequenced onto the bus. This sequence is also initiated with a Safety Injection coincident with undervoltage on one 4kV vital bus.

*NOTE

Only the lead Service Water Pump will start, however, if the lead pump fails to start the backup pump breaker will close.

TABLE II
PHASE "A" ISOLATION

1. Waste Disposal System

| | |
|-----------|---------------------------------|
| 1(2)WL12 | RCDT PUMP DISCHARGE |
| 1(2)WL13 | RCDT PUMP DISCHARGE |
| 1(2)WL16 | CONTAINMENT SUMP PUMP DISCHARGE |
| 1(2)WL17 | CONTAINMENT SUMP PUMP DISCHARGE |
| 1(2)WL96 | GAS ANALYZER FROM RCDT |
| 1(2)WL97 | GAS ANALYZER FROM RCDT |
| 1(2)WL98 | RCDT VENT |
| 1(2)WL99 | RCDT VENT |
| 1(2)WL108 | N ₂ SUPPLY TO RCDT |

2. Sampling System

| | |
|------------|---|
| 1(2)SS27 | ACCUMULATOR SAMPLE |
| 1(2)SS33 | HOT LEG SAMPLE |
| 1(2)SS49 | SAMPLE FROM PZR WATER SPACE |
| 1(2)SS64 | SAMPLE FROM PZR STEAM SPACE |
| 1(2)SS103 | ACCUMULATOR SAMPLE |
| 1(2)SS104 | HOT LEG SAMPLE |
| 1(2)SS107 | SAMPLE FROM PZR WATER SPACE |
| 1(2)SS110 | SAMPLE FROM PZR STEAM SPACE |
| 11(21)SS94 | SAMPLE FROM NO. 11(21) STM GEN BLOWDOWN |
| 12(22)SS94 | SAMPLE FROM NO. 12(22) STM GEN BLOWDOWN |
| 13(23)SS94 | SAMPLE FROM NO. 13(23) STM GEN BLOWDOWN |
| 14(24)SS94 | SAMPLE FROM NO. 14(24) STM GEN BLOWDOWN |

3. Component Cooling

| | |
|-----------|--|
| 1(2)CC113 | EXCESS LETDOWN HEAT EXCHANGER COOLING WATER OUTLET |
| 1(2)CC215 | EXCESS LETDOWN HEAT EXCHANGER COOLING WATER INLET |

4. Steam Generator Drains and Blowdown

| | |
|-----------|-----------------------------|
| 11(21)GB4 | STEAM GEN OUTLET NO. 11(21) |
| 12(22)GB4 | STEAM GEN OUTLET NO. 12(22) |
| 13(23)GB4 | STEAM GEN OUTLET NO. 13(23) |
| 14(24)GB4 | STEAM GEN OUTLET NO. 14(24) |

5. Pressurizer Relief Tank

| | |
|----------|------------------------------|
| 1(2)WR80 | PRIMARY WATER SUPPLY TO PRT |
| 1(2)PR17 | GAS ANALYZER FROM PRT |
| 1(2)PR18 | GAS ANALYZER FROM PRT |
| 1(2)NT25 | N ₂ SUPPLY TO PRT |

6. Accumulators

1(2)NT32 ACCUMULATOR N₂ SUPPLY

7. Containment Ventilation

1(2)VC1 PURGE SUPPLY
 1(2)VC2 PURGE SUPPLY
 1(2)VC3 PURGE EXHAUST
 1(2)VC4 PURGE EXHAUST
 1(2)VC5 CONT PRESS VAC RELIEF ISOLATION VALVE
 1(2)VC6 CONT PRESS VAC RELIEF ISOLATION VALVE
 1(2)VC7 CONTAINMENT RADIATION SAMPLE OUTLET
 1(2)VC8 CONTAINMENT RADIATION SAMPLE OUTLET
 1(2)VC11 CONTAINMENT RADIATION SAMPLE INLET
 1(2)VC12 CONTAINMENT RADIATION SAMPLE INLET

8. Demineralized Water

1(2)DR29 DM WATER TO FLUSHING CONNECTIONS

9. Fire Protection

1(2)FP147 FIRE PROTECTION WATER SUPPLY

10. Safety Injection

1(2)SJ123 ACCUM TEST STOP VALVE
 1(2)SJ60 ACCUM DISCH TEST STOP
 1(2)SJ53 SJ HDR TEST STOP VALVE

11. Control Air

11(21)CA330 A HDR ISOLATION VALVE
 12(22)CA330 B HDR ISOLATION VALVE

12. Containment Ventilation - the following sample valves receive no automatic isolation signal, however, they should be verified closed.

1(2)VC9 Containment Radiation Sample Outlet Backup
 1(2)VC10 Containment Radiation Sample Outlet Backup
 1(2)VC13 Containment Radiation Sample Inlet Backup
 1(2)VC14 Containment Radiation Sample Inlet Backup

EMERGENCY INSTRUCTION
I-4.3
REACTOR TRIP

1.0 PURPOSE

- 1.1 A reactor trip is initiated automatically by the Reactor Protection System if unsafe operating conditions are approached. It may also be initiated manually from the control console. This instruction provides the actions required to ensure the reactor is in a safe shutdown condition.
- 1.2 In addition to de-energizing the shutdown and control rod drive mechanisms, a reactor trip signal will initiate a turbine trip and, in conjunction with a low T_{avg} (554°F) initiate a feedwater isolation signal. This instruction delineates the actions required to ensure both of these have occurred.

2.0 INITIAL CONDITIONS

- 2.1 Any of the following conditions will lead to a reactor trip and to an automatic plant shutdown. The condition causing the trip will be back lighted in red on the first out overhead annunciator panel (Section F).

| REACTOR TRIP | SETPOINT | COINCIDENCE | INTERLOCK |
|--|---|---|---------------------------|
| 1. Manual | None | 1/2 | None |
| 2. Pwr. Range, High Neutron Flux | Low Setpoint - 25% of rated thermal pwr. | 2/4 | P-10 |
| | High Setpoint - 109% of rated thermal pwr. | 2/4 | None |
| 3. Pwr. Range, High Flux Rate Trip | + 5% of rated thermal pwr. in 2 sec. | 2/4 | None |
| 4. Intermediate Range, High Neutron Flux | Current equivalent to 25% of full pwr. | 1/2 | P-10 |
| 5. Source Range, High Neutron Flux | 10^5 counts per sec. | 1/2 | P-6 Interlocked with P-10 |
| 6. Overtemperature ΔT | Variable Setpoint | 2/4 | None |
| 7. Overpower ΔT | Variable Setpoint | 2/4 | None |
| 8. Low Reactor Coolant Pressure | 1865 psig | 2/4 | P-7 |
| 9. High Reactor Coolant Pressure | 2385 psig | 2/4 | None |
| 10. High Pressurizer | 92% Level | 2/3 | P-7 |
| 11. Low Reactor Coolant Flow | 90% of Normal Flow | 2/3/Loop | P-7 & P-8 |
| 12. Reactor Coolant Pump Under Voltage | 75% of Normal Voltage with a 0.2 sec. time delay | 1/2 Taken Twice | P-7 |
| 13. Reactor Coolant Pump Under Frequency | 56.5 Hertz with a 0.1 second time delay | 1/2 Taken Twice | P-7 |
| 14. Reactor Coolant Pump Breaker Open | 10% Pwr. 2 Bkr. Open | 1/Pump | P-7 & P-8 |
| | 36% Pwr. 1 Bkr. Open | | |
| 15. Low Feedwater Flow | 1.4×10^6 Stm. Flow greater than feedwater flow & 25% S/G level | 1/2 Flow Mismatch, in coincidence with 1/2 low wtr level, per loop. | None |

| REACTOR TRIP | SETPOINT | COINCIDENCE | INTERLOCK |
|---------------------------------------|--|---|-----------|
| 16. Low-Low Steam Generator Wtr. Lvl. | 5% Level per S/G | 2/3 per S/G | None |
| 17. Turbine-Generator Trip | 45 psig Auto Stop Oil Pressure or all four Stop Valves closed | 2/3 4/4 | P-7 |
| 18. Safety Injection (Actuation) | 1. Manual | 1/2 | None |
| | 2. Pressurizer at 1765 psig | 2/3 | None |
| | 3. Containment at 4.7 psig | 2/3 High Containment pressure | None |
| | 4. Any one S/G 100 psig lower than any other two S/G's | 1/2 Steam Pressure on any S/G Lower than 1/2 Steam Pressures on 2/3 of the other loops. | None |
| | 5. Variable: Steam line flow 1.4 X 10 ⁶ #/hr. 0-20% load, increasing to 4.0 X 10 ⁶ #/hr at 100% pwr. in coincidence with Low TAVG 543°F or Low Stm. Press. 500 psig. | 1/2 High Steamflow on 2/4 Steam Gen. in coincidence with 2/4 LOW TAVG or 2/4 low steam line pressure. | None |
| 19. General Alarm | Logic Train "A" & Train "B" in test simultaneously. | | |

NOTE

The General Alarm trip is not alarmed on the first out annunciator.

20. Trip Bypass Bkrs. Racking in, or attempting to rack in, both Reactor Trip Bypass Bkrs at the same time.

NOTE

The Bypass Breaker trip is not alarmed on the first out annunciator.

3.0 IMMEDIATE ACTIONS3.1 Automatic

- 3.1.1 Reactor Trip
- 3.1.2 Turbine Trip
- 3.1.3 Generator Trip

3.2 Manual

- 3.2.1 Verify that a reactor trip has taken place:

- 1) Check that all full length rods are fully inserted by checking individual rod position indicators and rod bottom lights.
- 2) If any full length control rod does not indicate fully inserted, manually initiate a reactor trip.

- 3) If all full length control rods are not then fully inserted, RAPID BORATE by 150 ppm (approximately 8 minutes) for each rod not inserted IAW OI II-3.3.8, "Rapid Boration".

3.2.2 Verify turbine trip by checking the following:

- 1) UNIT TRIP light on E/H console illuminated.
- 2) Turbine Stop Valves, Governor Valves, Interceptor Valves and Reheat Stop Valves closed.
- 3) Turbine speed decreasing.

3.2.3 Within 2 minutes reduce Aux. Feedwater Flow to each Steam Generator to approximately 2.3×10^6 lb/hr.

NOTE

This limitation applies to Unit No. 1 only.

3.2.4 Verify that T_{avg} is decreasing toward or is being maintained at 547°F by either steam dump or atmospheric steam relief.

3.2.5 Verify that Feedwater Isolation has taken place when T_{avg} decreases to 554°F.

3.2.6 Announce over the plant PA system twice: UNIT NO. 1(2) REACTOR TRIP.

4.0 SUBSEQUENT ACTIONS

4.1 Check that nuclear power is decreasing by observing the nuclear instrumentation.

4.1.1 Check that the Source Range high voltage is reinstated below 5×10^{-11} amps on both Intermediate Range Channels. This should normally occur in approximately 15-18 minutes on a trip from the power range.

- 1) If the Source Range high voltage does not energize automatically, manually depress the RESET SOURCE RANGE "A" and RESET SOURCE RANGE "B" pushbuttons on the control console.

4.1.2 Switch the Nuclear Power Recorder (NR-45) to read one Intermediate Range channel and one Source Range Channel.

4.1.3 Notify the Performance Department that a reactor trip has occurred and that the compensating voltage on the Intermediate Range detectors should be adjusted. This adjustment is desirable but is not required.

4.2 Verify that the Pressurizer pressure and level are within limits, and under control.

4.3 Verify that the 4160V Group Busses have transferred from the No. 1(2) Auxiliary Power Transformer to No. 11(12) & No. 12(22) Station Power Transformers.

4.3.1 Check that the following 4160V breakers have opened and acknowledge them on the appropriate control console bezel:

- 1(2) BGGD
- 1(2) BFGD
- 1(2) AEGD
- 1(2) AHGD

4.3.2 Check that the following 4160V breakers have closed and acknowledge them on the appropriate control console bezel:

- 12(22) GSD
- 12(22) PSD
- 11(21) ESD
- 11(21) HSD

4.4 Verify that T_{avg} is decreasing toward or is being maintained at 547°F due to steam dump operation.

4.4.1 Check the following steam dump indication:

- 1) Steam dump valve indication
- 2) Steam dump demand meter.

4.4.2 Transfer steam dump control from the AVERAGE TEMPERATURE CONTROL mode to the MAIN STEAM PRESSURE CONTROL mode. Ensure that the MAIN STEAM PRESSURE SP (setpoint) is set to maintain the reactor coolant temperature at a no load T_{avg} temperature of 547°F . (Approximately 1005 psig steam pressure).

NOTE

If condenser steam dump is not available, atmospheric steam relief must be used for the removal of residual heat.

4.5 Verify that Feedwater Isolation has taken place due to the reactor trip in coincidence with low T_{avg} (554°F).

4.5.1 Check that the following valves have closed by observing their appropriate bezel indication:

- 11(21)BF19 Feedwater Control Valve
- 12(22)BF19 Feedwater Control Valve
- 13(23)BF19 Feedwater Control Valve
- 14(24)BF19 Feedwater Control Valve
- 11(21)BF40 Feedwater Bypass Valve
- 12(22)BF40 Feedwater Bypass Valve
- 13(23)BF40 Feedwater Bypass Valve
- 14(24)BF40 Feedwater Bypass Valve

4.6 Return the levels in the Steam Generators to normal (~ 33%) as follows:

4.6.1 Limit the rate of rise to less than 1.2 in/min whenever level is below 10% on the Narrow Range.

4.6.2 Monitor the following computer points and maintain the rate of rise to < 0.8%/min on the narrow range and < 0.2%/min. on the wide range.

| <u>S/G</u> | <u>Narrow Range</u> | <u>Wide Range</u> |
|------------|----------------------------|-------------------|
| 11(21) | L0400A or L0401A or L0402A | L0403A |
| 12(22) | L0420A or L0421A or L0422A | L0423A |
| 13(23) | L0440A or L0441A or L0442A | L0443A |
| 14(24) | L0460A or L0461A or L0462A | L0463A |

NOTE

If the computer is not available, monitor the narrow range indication on the Control Console and the Wide range recorders on RP-4.

4.6.3 Control Flow to the Steam Generators as required by controlling the following valves.

1. 11-14(12-24)AF11 if No. 13(23) Auxiliary Feedwater Pump is in operation.
2. 11-14 (21-24)AF21 if No. 11 & 12 (21 & 22) Auxiliary Feedwater Pumps are in operation.

4.7 Establish and maintain the Hot Standby condition IAW OI I-3.5, "Minimum Load to Hot Standby" and OI I-3.8, "Maintaining Hot Standby".

4.8 If Rx trip was from >15% Rx Power, have the Chem. Dept. perform an I^{131} , I^{133} , I^{135} isotopic analysis between 2 and 6 hours following the Rx trip.

4.9 Obtain a sample of the Reactor Coolant System and determine boron concentration. Adjust boron concentration as required IAW OI II-3.3.6, "Boron Concentration Control".

4.10 As per Administrative Procedure No. 5:

4.10.1 Notify the Station Operating Engineer or Chief Engineer of the reactor trip and;

4.10.2 Initiate an Operational Incident Report IAW AP-6 and forward it to the station Operating Engineer.

4.11 If, at this time, it becomes necessary, take the plant to the Cold Shutdown Condition IAW OI I-3.6, "Hot Standby to Cold Shutdown".

4.12 As authorized by AP-5, withdraw the shutdown banks as follows:

4.12.1 Reset the flux rate trip by momentarily taking the RATE MODE switches, on each NIS POWER RANGE A drawer, to the RESET position.

4.12.2 Depress the CLOSE pushbutton, on the control console, for REACTOR TRIP BKR A, verifying the breaker does close.

4.12.3 Depress the CLOSE pushbutton, on the control console, for REACTOR TRIP BKR B, verifying the breaker does close.

4.12.4 Depress the STARTUP pushbutton, on the control console, and verify each Shutdown and Control Rod Step Counter resets to zero.

4.12.5 Commence withdrawing Shutdown Bank A, B, C and D, in that order, to their fully withdrawn position.

4.13 When the cause of the trip has been determined and corrected, obtain the permission of the Station Operating Engineer or the Chief Engineer, IAW AP-5, to take the reactor critical.

4.14 With Steam Generator levels within their normal operating bands and just prior to commencing the recovery startup, perform the following:

4.14.1 Place the Steam Generator Feedwater Controls in MANUAL and run the valve demand to zero.

4.14.2 Reset the Feedwater Isolation signal by depressing the Train "A" and Train "B" FEEDWATER ISOLATION RESET pushbuttons on the control console.

4.14.3 Maintain Steam Generator levels within their normal operating bands by manually controlling Feedwater Bypass Valves 11, 12, 13 and 14 (21, 22 23 and 24) BF40.

4.14.4 Return the Auxiliary Feedwater System to its normal at power lineup IAW OI III-10.3.1, "Auxiliary Feedwater System Operation".

4.15 Return to Power Operation IAW OI I-3.3, "Hot Standby to Minimum Load", and OI I-3.4, "Power Operation".

Prepared by J.V. Bailey

N.J. [Signature]
Manager - Salem Generating Station

Reviewed by J.P. Kovacsofsky

SORC Meeting No. 56-79

Date 7/16/79

Frederick W. Schneider
Vice President
Production

Public Service Electric and Gas Company, 80 Park Avenue, New York, N.Y. 10017

August 29, 1979

SALEM GEN. STATION
31 AUG 29 07 0
LAST
SO, AE file/follow
F. Johnson
J. Nichols
C. Lunn
J. Lloyd
Oll-24
issued 8/30/79

Mr. Boyce H. Grier, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

NRC IE BULLETIN NO. 79-06C
NO. 1 UNIT
SALEM GENERATING STATION

Pursuant to the subject bulletin, we hereby, submit the following response:

Short-Term Actions

Item 1

- A. Station Emergency Procedures have been revised such that Reactor Coolant Pumps are immediately tripped upon Reactor Trip with initiation of Safety Injection caused by low reactor coolant system pressure.
- B. A station operating memo has been issued requiring the presence of two licensed operators in the control room during operation in Modes 1, 2 and 3.

Item 2

A series of Loss of Coolant Accident (LOCA) analyses for a range of break sizes and a range of time lapses between initiation of break and pump trip applicable to the 2, 3 and 4 loop plants has been performed by the Westinghouse Owners' Group. A report summarizing the results of the analysis of delayed Reactor Coolant Pump trip during small loss of coolant accidents for Westinghouse NSSS will be submitted to Mr. D. F. Ross

by Mr. Cordell Reed on August 31, 1979. In the report, maximum PCT's for each break size considered and pump shutoff times have been provided. The report concludes that if the reactor coolant pumps are tripped prior to the reactor coolant system pressure reaching 1250 psia, the resulting peak clad temperatures are less than or equal to those reported in the FSAR. In addition, it is shown that there is a finite range of break sizes and RCP trip times in all cases 10 minutes or later, which will result in PCT's in excess of 2200°F. as calculated with conservative Appendix K models. The operator in any event would have at least 10 minutes to trip the RCP's following a small break LOCA, especially in light of the conservatism in the calculations. This is appropriate for manual rather than automatic action, based on the guidelines for termination of RCP operation presented in WCAP-9600.

Item 3

The Westinghouse Owners' Group has developed guidelines which were submitted to the NRC in Section 6 and Appendix A of WCAP 9600. The analyses provided as the response to Item 2 are consistent with the guidelines in WCAP 9600. No changes to these guidelines are needed for both LOCA and non-LOCA transients.

Item 4

The Owners' Group effort to revise emergency procedures covers many issues, including operation of the Reactor Coolant Pumps. The action taken in response to item 1 is sufficient as an interim measure in regards to these pumps. The expected schedule for revising the LOCA, steamline break and steam generator tube rupture emergency procedures is the following:

Mid-October: Guidelines which have been reviewed by the NRC will be provided to each utility. Appropriate utility personnel associated with writing procedures will meet with the Owners' Group Subcommittee on Procedures and Westinghouse to provide the background for revising their emergency procedures.

Boyce H. Grier, Director

8-29-79

1 to 2 months Plant specific procedures will be revised.
from: Mid-October.

1 to 4 months Revised procedures will be implemented and operators trained.
from: Mid-October


Item 5

Analyses related to inadequate core cooling and definition of conditions under which a restart of the RCP's should be attempted will be performed. Resolution of the requirements for the analyses and an acceptable schedule for providing the analyses and guidelines and procedures resulting from the analyses will be arrived at between the Westinghouse Owners' Group and the NRC staff.

Long Term Actions

As discussed in our response to short-term item 2, we do not believe that automatic tripping of the RCP's is a required function based on the analyses that have been performed and the guidelines that have been developed for manual RCP tripping. We propose that this item be discussed with the NRC staff following their review of the Owners' Group Submittal.

If you have any further questions on this matter we will be pleased to discuss them with you.

Sincerely,



Handwritten notes:
JH
EG
WB:hs
WJX
M

CC: Director, Office of Inspection and Enforcement
USNRC
Washington, DC 20555

Director, Office of Nuclear Reactor Regulation
USNRC
Washington, DC 20555

221065 B 9545-2

GENERATOR PROTECTION TRIPS



| NO. | DATE | DESCRIPTION | BY | CHKD |
|-----|------|-------------|----|------|
| 1 | | | | |
| 2 | | | | |
| 3 | | | | |
| 4 | | | | |
| 5 | | | | |
| 6 | | | | |
| 7 | | | | |
| 8 | | | | |
| 9 | | | | |
| 10 | | | | |


REV. NOTE 0

- A- INDICATED 55PS EQUIPMENT AND ADDED RELAY DESIGNATIONS FOR 33PS OUTPUT
- B- ADDED ALARM 'TURBINE TRIP & P-7 REACTOR TRIP', REMOVED ROD DROP & ROD BOTTOM SIGNALS, TURBINE IMPULSE CHAMBER PRESSURE SIGNALS (PC805B L, PC805B & NOTE 4 (PER 3651 DII, 04 16 64 BUB 3))

REV. NOTE 1

- ADDED: 1- GEN PROT TRIP/AUTO STOP OIL TO THE EMERGENCY TRIP FLUID
- 2- GEN TRIP FROM 63/TB & 63/A
- A-1 AND NOTE 4 / HOLD


TURBINE POWER
(TURBINE IMPULSE CHAMBER PRESSURE)



ISSUED FOR CONSTRUCTION
REVISION 1 CONSTRUCTION 8071
PUBLIC SERVICE ELECTRIC & GAS CO.
APR 26 1978

REVISIONS FROM ISSUED CONTRACT
REVISIONS SHALL NOT BE PERMITTED
WITHOUT PRIOR DOCUMENTED APPROVAL OF
SPONSOR ENGINEER.

TURBINE RUNBACK
VIA LOAD REFERENCE



NOTES:

- 1- THESE SIGNALS INDICATE THE CLOSING OF THE STOP VALVES. POSITION DETECTION IS ACCOMPLISHED BY 2 SWITCHES PER STOP VALVE, ONE FOR EACH TRAIN.
- 2- REDUNDANCY IS INDICATED IN REGARDS TO (V) REQUIREMENTS ONLY.
- 3- THIS SHEET IS IDENTICAL FOR UNITS 1 & 2 EXCEPT FOR THE TAG NUMBERS WHICH ARE PRECEDED BY 10R1 FOR UNIT 1 OR 2 RESPECTIVELY (HERE INDICATED FOR UNIT 1 ONLY).
- 4- THE 'AND' LOGIC AND THE ASSOCIATED PRESSURE SWITCHES (65/TB AND 65/AT) MUST BE TESTED PERIODICALLY WHILE ON LINE AT POWER WITHOUT PLANT TRIP TEST VALVES AND TEST LIGHTS ARE REQUIRED TO PROVIDE THOROUGH TESTING AND TO VERIFY PRESSURE SWITCH CONTACT STATUS.

TRIP
CIRCUIT
IS ZONE

GENERAL NOTES
USE POINTS OF LATEST REVISION ONLY
DO NOT SCALE. SEE DIMENSIONS ONLY
FOR LIST OF DELETED DIMENSIONS SEE
DRAWING BY T.M. RYAN, JR.
FOR SHEET LIST SEE
FOR SHEET LIST SEE
THIS DRAWING SUPERSEDES P.S. 221065-1
THIS DRAWING IS SHEET NO. 1 OF 1 SHEETS

SALEM NUCLEAR GENERATING STATION
NO. 1 & 2 UNITS
REACTOR PROTECTION SYSTEM
TURBINE TRIP, RUNBACK & OTHER SIGNALS
LOGIC DIAGRAM SH. 12 CONTROLS

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
ELECTRIC ENGINEERING DEPARTMENT
NEWARK, N.J.
I. GALE, ENGINEER
M. F. R. 12, 37, 10/10/78
AUTH. 6-26-78

221065 B 9545-2

Part 12

TESTS AND PERFORMANCE AC FRACTIONAL- AND INTEGRAL-HORSEPOWER MOTORS

MG 1-12.30 Test Methods

Tests to determine performance characteristics shall be made in accordance with the following:

1. For single-phase motors—IEEE Std 114, *Test Procedure for Single-phase Induction Motors*.
2. For polyphase induction motors—IEEE Std 112, *Test Procedure for Polyphase Induction Motors and Generators*.

NEMA Standard 7-7-1965.

MG 1-12.30.a Performance Characteristics

When performance characteristics are provided, they should be expressed as follows:

1. Current in amperes or percent of rated current.
2. Torque in pound-feet, pound-inches, ounce-feet, ounce-inches or percent of full-load torque.
3. Output in horsepower or percent of rated horsepower.
4. Speed in revolutions per minute or percent of synchronous speed.
5. Efficiency in percent.
6. Power factor in percent.
7. Voltage in volts or percent of rated voltage.
8. Input power in watts or kilowatts.

NOTE—If SI units are used, they should be in accordance with ISO Publication No. R-1000.

Authorized Engineering Information 5-12-1975.

MG 1-12.31 Torque Characteristics of Single-phase General-purpose Induction Motors

A. BREAKDOWN TORQUE

The breakdown torque of general-purpose single-phase fractional- and integral-horsepower induction motors shall be the higher figure in each torque range as given in the table in MG 1-10.33, subject to tolerances in manufacturing and all other conditions given in MG 1-10.33.

B. LOCKED-ROTOR TORQUE OF FRACTIONAL-HORSEPOWER MOTORS

The locked-rotor torque of single-phase general-purpose fractional-horsepower motors, with rated voltage and frequency applied, shall be not less than the following:

| Hp | Minimum Locked-rotor Torque, Ounce-feet | | | | | |
|-----|---|--------------|--------------|------------------------|--------------|-------------|
| | 60-hertz Speed, Rpm | | | 50-hertz Speed, Rpm | | |
| | 3600 3450 | 1800 1725 | 1200 1140 | 3000 2850 | 1500 1425 | 1000 950 |
| 1/8 | .. | 24 | 32 | .. | 29 | 39 |
| 1/6 | 15 | 33 | 43 | 18 | 39 | 51 |
| 1/4 | 21 | 46 | 59 | 25 | 55 | 70 |
| 1/3 | 26 | 57 | 73 | 31 | 69 | 88 |
| 1/2 | 37 | 85 | 100 | 44 | 102 | 120 |
| 3/4 | 50 | 119 | ... | 60 | 143 | ... |
| 1 | 61 | ... | ... | 73 | ... | ... |

C. LOCKED-ROTOR TORQUE OF INTEGRAL-HORSEPOWER MOTORS

The locked-rotor torque of single-phase general-purpose integral-horsepower motors, with rated voltage and frequency applied, shall be not less than the following:

| Hp | Minimum Locked-rotor Torque, Pound-feet | | |
|-------|---|-------------|------|
| | 3600 | Rpm 1800 | 1200 |
| 3/4 | ... | ... | 8.0 |
| 1 | ... | 9.0 | 9.5 |
| 1 1/2 | 4.5 | 12.5 | 13.0 |
| 2 | 5.5 | 16.0 | 16.0 |
| 3 | 7.5 | 22.0 | 23.0 |
| 5 | 11.0 | 33.0 | ... |
| 7 1/2 | 16.0 | 45.0 | ... |

D. PULL-UP TORQUE OF INTEGRAL-HORSEPOWER MOTORS

The pull-up torque of single-phase general-purpose alternating-current integral-horsepower motors, with rated voltage and frequency applied, shall be not less than the rated load torque.

NEMA Standard 11-11-1948, revised 6-24-1949, 5-17-1953; 11-11-1965; 11-16-1967.

MG 1-12.32 Locked-rotor Current of Single-phase Fractional-horsepower Motors

A. The locked-rotor current of 60-hertz, single-phase motors shall not exceed the values given in the following table:

2-, 4-, 6- AND 8-POLE, 60-HERTZ MOTORS, SINGLE PHASE

| Hp | Locked-rotor Current, Amperes | | | |
|-----------------|-------------------------------|----------|-----------|----------|
| | 115 Volts | | 230 Volts | |
| | Design O | Design N | Design O | Design N |
| 1/6 and smaller | 50 | 20 | 25 | 12 |
| 1/4 | 50 | 26 | 25 | 15 |
| 1/3 | 50 | 31 | 25 | 18 |
| 1/2 | 50 | 45 | 25 | 25 |
| 3/4 | .. | 61 | .. | 35 |
| 1 | .. | 80 | .. | 45 |

B. The locked-rotor currents of single-phase general-purpose fractional-horsepower motors shall not exceed the values for Design N motors.

NEMA Standard 10-29-1943, revised 11-14-1957; 5-21-1962; 11-12-1964; 11-21-1968.

MG 1-12.33 Locked-rotor Current of Single-phase Integral-horsepower Motors, Designs L and M

The locked-rotor current of single-phase, 60-hertz, Design L and M motors of all types, when measured with rated voltage and frequency impressed and with the rotor locked, shall not exceed the following values:

| Hp | Locked-rotor Current, Amperes | | |
|-------|-------------------------------|-----------|-----------------|
| | Design L Motors | | Design M Motors |
| | 115 Volts | 230 Volts | 230 Volts |
| 1/2 | 45 | 25 | .. |
| 3/4 | 61 | 35 | .. |
| 1 | 80 | 45 | .. |
| 1 1/2 | .. | 50 | 40 |
| 2 | .. | 65 | 50 |
| 3 | .. | 90 | 70 |
| 5 | .. | 135 | 100 |
| 7 1/2 | .. | 200 | 150 |
| 10 | .. | 260 | 200 |
| 15 | .. | 390 | 300 |
| 20 | .. | 520 | 400 |

NEMA Standard 8-7-1947; revised 1-23-1951; 11-21-1968.

MG 1-12.34 Locked-rotor Current of 3-phase 60-hertz Integral-horsepower Squirrel-cage Induction Motors Rated at 230 Volts

The locked-rotor current of single-speed, 3-phase, constant-speed induction motors rated at 230 volts, when measured with rated voltage and frequency impressed and with rotor locked, shall not exceed the following values:

| Hp | Locked-rotor Current, Amperes* | Design Letters |
|-------|--------------------------------|----------------|
| 1/2 | 20 | E, D |
| 3/4 | 25 | B, D |
| 1 | 30 | B, D |
| 1 1/2 | 40 | B, D |
| 2 | 50 | B, D |
| 3 | 64 | B, C, D |
| 5 | 92 | B, C, D |
| 7 1/2 | 127 | B, C, D |
| 10 | 162 | B, C, D |
| 15 | 232 | B, C, D |
| 20 | 290 | B, C, D |
| 25 | 365 | B, C, D |
| 30 | 435 | B, C, D |
| 40 | 580 | B, C, D |
| 50 | 725 | B, C, D |
| 60 | 870 | B, C, D |
| 75 | 1085 | B, C, D |
| 100 | 1450 | B, C, D |
| 125 | 1815 | B, C, D |
| 150 | 2170 | B, C, D |
| 200 | 2900 | B, C |
| 250 | 3650 | B |
| 300 | 4400 | B |
| 350 | 5100 | B |
| 400 | 5800 | B |
| 450 | 6500 | B |
| 500 | 7250 | B |

* The locked-rotor current of motors designed for voltages other than 230 volts shall be inversely proportional to the voltages.

Suggested Standard for Future Design 7-7-1965, revised 8-20-1966; 11-17-1966, NEMA Standard 11-21-1968.

MG 1-12.35 Locked-rotor Current of 3-phase 50-hertz Integral-horsepower Squirrel-cage Induction Motors Rated at 380 Volts

The locked-rotor current of single-speed, 3-phase, constant-speed induction motors rated at 380 volts, when measured with rated voltage and frequency impressed and with rotor locked, shall not exceed the values shown in Table 12-1.

NEMA Standard 11-21-1968, revised 7-16-1969.

MG 1-12.36 Torque Characteristics of Polyphase Fractional-horsepower Motors

The breakdown torque of a general-purpose polyphase squirrel-cage fractional-horsepower motor, with rated voltage and frequency applied, shall be not less than 140 percent of the breakdown torque of a single-phase general-purpose fractional-horsepower motor of the same horsepower and speed rating given in MG 1-12.31.

NOTE—The speed at breakdown torque is ordinarily much lower in fractional-horsepower polyphase motors than in fractional-horsepower single-phase motors. Higher breakdown torques are required for polyphase motors so that polyphase and single-phase motors will have interchangeable running characteristics, rating for rating, when applied to normal single-phase motor loads.

NEMA Standard 6-4-1948, revised 6-24-1949; 11-13-1969.

85%

TABLE 12-1 (SEE MG 1-12.35)

| Hp | Locked-rotor Current, Amperes* | Design Letters | Hp | Locked-rotor Current, Amperes* | Design Letters |
|-----------|--------------------------------|----------------|-----|--------------------------------|----------------|
| 1 or less | 20 | B, D | 30 | 289 | B, C, D |
| 1½ | 27 | B, D | 40 | 387 | B, C, D |
| 2 | 34 | B, D | 50 | 482 | B, C, D |
| 3 | 43 | B, C, D | 60 | 578 | B, C, D |
| 5 | 61 | B, C, D | 75 | 722 | B, C, D |
| 7½ | 84 | B, C, D | 100 | 965 | B, C, D |
| 10 | 107 | B, C, D | 125 | 1207 | B, C, D |
| 15 | 154 | B, C, D | 150 | 1441 | B, C, D |
| 20 | 194 | B, C, D | 200 | 1927 | B, C |
| 25 | 243 | B, C, D | | | |

* The locked-rotor current of motors designed for voltages other than 380 volts shall be inversely proportional to the voltages.

MG 1-12.37 Locked-rotor Torque of Single-speed Polyphase Squirrel-cage Integral-horse-power Motors with Continuous Ratings

A. The locked-rotor torque of Design A and B, 60- and 50-hertz, single-speed, polyphase squirrel-cage motors, with rated voltage and frequency applied, shall be in accordance with the following values which are expressed in percent of full-load torque and represent the upper limit of the range of application for these motors. For applications involving higher torque requirements, see the locked-rotor torque values for Design C and D motors.

| Hp | Synchronous Speed, Rpm | | | | | | | |
|-----|------------------------|------|------|------|-----|-----|-----|-----|
| | 60 hertz | 3600 | 1800 | 1200 | 900 | 720 | 600 | 514 |
| | 50 hertz | 3000 | 1500 | 1000 | 750 | ... | ... | ... |
| 1/2 | ... | ... | ... | 140 | 140 | 115 | 110 | 110 |
| 3/4 | ... | ... | 175 | 155 | 135 | 115 | 110 | 110 |
| 1 | ... | 275 | 170 | 135 | 135 | 115 | 110 | 110 |
| 1½ | 175 | 250 | 165 | 130 | 130 | 115 | 110 | 110 |
| 2 | 170 | 235 | 160 | 130 | 125 | 115 | 110 | 110 |
| 3 | 160 | 215 | 155 | 130 | 125 | 115 | 110 | 110 |
| 5 | 150 | 185 | 150 | 130 | 125 | 115 | 110 | 110 |
| 7½ | 140 | 175 | 150 | 125 | 120 | 115 | 110 | 110 |
| 10 | 135 | 165 | 150 | 125 | 120 | 115 | 110 | 110 |
| 15 | 130 | 160 | 140 | 125 | 120 | 115 | 110 | 110 |
| 20 | 130 | 150 | 135 | 125 | 120 | 115 | 110 | 110 |
| 25 | 130 | 150 | 135 | 125 | 120 | 115 | 110 | 110 |
| 30 | 130 | 150 | 135 | 125 | 120 | 115 | 110 | 110 |
| 40 | 125 | 140 | 135 | 125 | 120 | 115 | 110 | 110 |
| 50 | 120 | 140 | 135 | 125 | 120 | 115 | 110 | 110 |
| 60 | 120 | 140 | 135 | 125 | 120 | 115 | 110 | 110 |
| 75 | 105 | 140 | 135 | 125 | 120 | 115 | 110 | 110 |
| 100 | 105 | 125 | 125 | 125 | 120 | 115 | 110 | 110 |
| 125 | 100 | 110 | 125 | 120 | 115 | 115 | 110 | 110 |
| 150 | 100 | 110 | 120 | 120 | 115 | 115 | ... | ... |
| 200 | 100 | 100 | 120 | 120 | 115 | ... | ... | ... |
| 250 | 70 | 80 | 100 | 100 | ... | ... | ... | ... |
| 300 | 70 | 80 | 100 | ... | ... | ... | ... | ... |
| 350 | 70 | 80 | 100 | ... | ... | ... | ... | ... |
| 400 | 70 | 80 | ... | ... | ... | ... | ... | ... |
| 450 | 70 | 80 | ... | ... | ... | ... | ... | ... |
| 500 | 70 | 80 | ... | ... | ... | ... | ... | ... |

(Continued)

133

B. The locked-rotor torque of Design C, 60- and 50-hertz, single-speed, polyphase squirrel-cage motors, with rated voltage and frequency applied, shall be in accordance with the following values which are expressed in percent of full-load torque and represent the upper limit of the range of application for these motors:

| Hp | Synchronous Speed, Rpm | | | |
|-------------------|------------------------|------|------|-----|
| | 60 hertz | 1800 | 1200 | 900 |
| | 50 hertz | 1500 | 1000 | 750 |
| 3 | | ... | 250 | 225 |
| 5 | | 250 | 250 | 225 |
| 7.5 | | 250 | 225 | 200 |
| 10 | | 250 | 225 | 200 |
| 15 | | 225 | 200 | 200 |
| 20-200, inclusive | | 200 | 200 | 200 |

C. The locked-rotor torque of Design D, 60- and 50-hertz, 4-, 6- and 8-pole, single-speed, polyphase squirrel-cage motors rated 150 horsepower and smaller, with rated voltage and frequency applied, shall be 275 percent, expressed in percent of full-load torque, which represents the upper limit of application for these motors.

NEMA Standard 8-7-1947, revised 6-24-1949; 11-17-1955; 11-17-1966; 7-18-1969.

MG 1-12.38 Breakdown Torque of Single-speed Polyphase Squirrel-cage Integral-horsepower Motors with Continuous Ratings

A. The breakdown torque of Design A* and B, 60- and 50-hertz, single-speed, polyphase squirrel-cage motors, with rated voltage and frequency applied, shall be in accordance with the following values which are expressed in percent of full-load torque and represent the upper limit of the range of application for these motors:

| Hp | Synchronous Speed, Rpm | | | | | | | |
|--------------------|------------------------|------|------|------|-----|-----|-----|-----|
| | 60 hertz | 3600 | 1800 | 1200 | 900 | 720 | 600 | 514 |
| | 50 hertz | 3000 | 1500 | 1000 | 750 | ... | ... | ... |
| 1/2 | ... | ... | ... | ... | 225 | 200 | 200 | 200 |
| 3/4 | ... | ... | ... | 275 | 220 | 200 | 200 | 200 |
| 1 | ... | ... | 300 | 265 | 215 | 200 | 200 | 200 |
| 1 1/2 | ... | 250 | 280 | 250 | 210 | 200 | 200 | 200 |
| 2 | ... | 240 | 270 | 240 | 210 | 200 | 200 | 200 |
| 3 | ... | 230 | 250 | 230 | 205 | 200 | 200 | 200 |
| 5 | ... | 215 | 225 | 215 | 205 | 200 | 200 | 200 |
| 7 1/2 | ... | 200 | 215 | 205 | 200 | 200 | 200 | 200 |
| 10-125, inclusive | ... | 200 | 200 | 200 | 200 | 200 | 200 | 200 |
| 150 | ... | 200 | 200 | 200 | 200 | 200 | 200 | ... |
| 200 | ... | 200 | 200 | 200 | 200 | 200 | ... | ... |
| 250 | ... | 200 | 200 | 200 | 200 | 200 | ... | ... |
| 300-350 | ... | 175 | 175 | 175 | 175 | ... | ... | ... |
| 400-500, inclusive | ... | 175 | 175 | ... | ... | ... | ... | ... |

* Design A values are in excess of values shown above.

B. The breakdown torque of Design C, 60- and 50-hertz, single-speed, polyphase squirrel-cage motors, with rated voltage and frequency applied, shall be in accordance with the following values which are expressed in percent of full-load torque and represent the upper limit of the range of application for these motors:

| Hp | Synchronous Speed, Rpm | | | |
|----------------------|------------------------|------|------|-----|
| | 60 hertz | 1800 | 1200 | 900 |
| | 50 hertz | 1500 | 1000 | 750 |
| 3 | | ... | 225 | 200 |
| 5 | | 200 | 200 | 200 |
| 7 1/2-200, inclusive | | 190 | 190 | 190 |

NEMA Standard 1-26-1948, revised 6-24-1949; 11-17-1955; 11-17-1966; 7-18-1969.

Part 20

LARGE APPARATUS—INDUCTION MOTORS

RATINGS

MG 1-20.05 Basis of Rating

Induction motors covered by this Part 20 shall be rated on a continuous-duty basis unless otherwise specified. The output rating shall be expressed in horsepower available at the shaft at a specified speed, frequency and voltage.

NEMA Standard 5-20-1974.

MG 1-20.10 Horsepower and Speed Ratings

Horsepower ratings and synchronous speed ratings shall be as follows:

| Hp Ratings | | | | | |
|------------|------|------|-------|-------|--------|
| 100 | 600 | 2500 | 9000 | 19000 | 45000 |
| 125 | 700 | 3000 | 10000 | 20000 | 50000 |
| 150 | 800 | 3500 | 11000 | 22500 | 55000 |
| 200 | 900 | 4000 | 12000 | 25000 | 60000 |
| 250 | 1000 | 4500 | 13000 | 27500 | 65000 |
| 300 | 1250 | 5000 | 14000 | 30000 | 70000 |
| 350 | 1500 | 5500 | 15000 | 32500 | 75000 |
| 400 | 1750 | 6000 | 16000 | 35000 | 80000 |
| 450 | 2000 | 7000 | 17000 | 37500 | 90000 |
| 500 | 2250 | 8000 | 18000 | 40000 | 100000 |

| Synchronous Speed Ratings, Rpm at 60 hertz* | | | |
|--|-----|-----|-----|
| 3600 | 720 | 400 | 277 |
| 1800 | 600 | 360 | 257 |
| 1200 | 510 | 327 | 240 |
| 900 | 450 | 300 | 225 |

* At 60 hertz, the speeds are $\frac{1}{2}$ of the 60-hertz speeds.
NOTE—It is not practical to build motors of all horsepower ratings at all speeds.

NEMA Standard 11-15-1956, revised 7-13-1967.

MG 1-20.10.a Horsepower Ratings of Multispeed Motors

The horsepower ratings of multispeed motors shall be selected as follows:

A. CONSTANT HORSEPOWER

The horsepower rating for each rated speed shall be selected from MG 1-20.10.

B. CONSTANT TORQUE

The horsepower rating for the highest rated speed shall be selected from MG 1-20.10. The horsepower rating for each lower speed shall be determined by multiplying the horsepower rating at the highest speed by the ratio of the lower synchronous speed to the highest synchronous speed.

C. VARIABLE TORQUE

The horsepower rating for the highest rated speed shall be selected from MG 1-20.10. The horsepower rating for each lower speed shall be determined by multiplying the horsepower rating at the highest speed by the square of the ratio of the lower synchronous speed to the highest synchronous speed.

NEMA Standard 7-17-1974.

MG 1-20.11 Voltages

Voltages shall be 200, 230, 460, 575, 2300, 4000, 4600, 6600 and 13200 volts. These voltage ratings apply to 60-hertz circuits only.

NOTE—It is not practical to build motors of all horsepower ratings for all of these voltages.

NEMA Standard 11-15-1956, revised 7-13-1967; 7-16-1969.

MG 1-20.12 Frequencies

The frequencies shall be 50* and 60 hertz.

* For export.

NEMA Standard 5-17-1955.

MG 1-20.13 Service Factor

When operated at rated voltage and frequency, induction motors covered by this Part 20 and having a rated temperature rise in accordance with MG 1-20.40 shall have a service factor of 1.0.

NEMA Standard 7-13-1967.

In those applications requiring an overload capacity, the use of a higher horsepower rating as given in MG 1-20.10 is recommended to avoid exceeding the temperature rises for the class of insulation used and to provide adequate torque capacity.

Authorized Engineering Information 5-24-1960.

135

TESTS AND PERFORMANCE

MG 1-20.40 Temperature Rise

The observable temperature rise under rated-load conditions of each of the various parts of the induction motor, above the temperature of the cooling air, shall not exceed the values given in the following table. The temperature of the cooling air* is the temperature of the external air as it enters the ventilating openings of the machine, and the temperature rises given in the table are based on a maximum temperature of 40°C for this external air. Temperatures shall be determined in accordance with the latest revision of IEEE Std 112, *Test Procedure for Polyphase Induction Motors and Generators*.

| Item | Machine Part | Method of Temperature Determination | Temperature Rise, Degrees C | | | |
|------|--|-------------------------------------|-----------------------------|----|-----|-----|
| | | | Class of Insulation System | | | |
| | | | A | B | F | H |
| 1 | Insulated windings | | | | | |
| | a. All horsepower ratings | Resistance | 60 | 80 | 105 | 125 |
| | b. 1500 horsepower and less | Embedded detector† | 70 | 90 | 115 | 140 |
| | c. Over 1500 horsepower | | | | | |
| | (1) 7000 volts and less | Embedded detector† | 65 | 85 | 110 | 135 |
| | (2) Over 7000 volts | Embedded detector† | 60 | 80 | 105 | 125 |
| 2 | Cores, squirrel-cage windings and mechanical parts, such as collector rings and brushes, may attain such temperatures as will not injure the machine in any respect. | | | | | |

* For totally-enclosed water-air-cooled machines, the temperature of the cooling air is the temperature of the air leaving the coolers. See Note 1.
† Embedded detectors are located within the slot of the machine and can be either resistance elements or thermocouples. For motors equipped with embedded detectors, this method shall be used to demonstrate conformity with the standard.

NOTE 1—Totally-enclosed water-air-cooled machines are normally designed for the maximum cooling water temperature encountered at the location where each machine is to be installed. With a cooling water temperature not exceeding that for which the machine is designed:

- a. On machines designed for cooling water temperatures up to 30°C—the temperature of the air leaving the coolers shall not exceed 40°C.
- b. On machines designed for higher cooling water temperatures—the temperature of the air leaving the coolers may exceed 40°C provided the temperature rises of the machine parts are then limited to values less than those given in the table by the number of degrees that the temperature of the air leaving the coolers exceeds 40°C.

NOTE 2—For motors which operate under prevailing barometric pressure and which are designed not to exceed the specified temperature rise at altitudes from 3300 feet (1000 meters) to 13000 feet (4000 meters), the temperature rises, as checked by tests at low altitudes, shall be less than those listed in the foregoing table by 1 percent of the specified temperature rise for each 330 feet (100 meters) of altitude in excess of 3300 feet (1000 meters).

Suggested Standard for Future Design 5-24-1960, revised 11-15-1962, NEMA Standard 11-11-1965, revised 8-20-1966; 7-16-1969; 11-8-1973.

NOTE 3—Temperature rises in the foregoing table are based upon a reference ambient temperature of 40°C. However it is recognized that induction motors may be required to operate in an ambient temperature higher than 40°C. For successful operation of the motors in ambient temperatures higher than 40°C, it is recommended that the temperature rises of the motors given in the foregoing table be reduced, as indicated below, for the ranges of ambient temperature given. (Exception—for totally-enclosed water-air-cooled machines, see NOTE 1.)

| Ambient Temperature, Degrees C | Values by which Temperature Rises in the Foregoing Table Should be Reduced, Degrees C |
|---------------------------------|---|
| Above 40 up to and including 50 | 10 |
| Above 50 up to and including 60 | 20 |

Authorized Engineering Information 5-24-1960; revised 11-8-1973.

MG 1-20.41 Torques

The torques*, with rated voltage and frequency applied, shall be not less than the following:

| Torques* | Percent of Rated Full-load Torque |
|--------------|-----------------------------------|
| Locked rotor | 60 |
| Pull-up | 60 |
| Breakdown | 175 |

In addition, the developed torque at any speed up to that at which breakdown torque occurs, with rated voltage and frequency applied, shall be at least 1.3 times the torque obtained from a curve that varies as the square of the speed and is equal to 100 percent of rated full-load torque at rated speed.

* See Part 1 for definitions.

