

**ATTACHMENT 1**

Limerick Generating Station  
Unit 1

NPSH Analysis  
Residual Heat Removal System

9802100043 980202  
PDR ADOCK 05000352  
P PDR

Effective Date: 8-19-96

Exhibit NE-C-420-6, Rev. 2

Page 1 of 1

RAS/mak

PORC	NO
SQR	NO
QR	NO
50.59	NO
RESP MGR	YES

CONTROLLED COPY

Source Calc. # M-51-62 Rev. 4

ECR # LG 97-03058 Rev. Ø

CALCULATION REVISION SHEET



INTERIM REVISION



MARGIN REVISION

THIS CALCULATION HAS BEEN IMPACTED PER THIS REVISION SHEET AS FOLLOWS:

This Revision is Applicable To Unit 1 Only. This Calculation is Revised To DETERMINE THE WORST CASE RHR SYSTEM NPSHA AND TO CALCULATE NPSHA Margin As A RESULT OF THE INSTALLATION OF NEW LARGE CAPACITY PASSIVE STRAINERS ON THE RHR SUCTION PIPING. Per PECO DIRECTION THE ANALYSIS PERFORMED BY REVISION 4 WILL BE DELETED AND THE MODE A-1, MODE A-2, AND MODE B ANALYSIS WILL BE RETAINED, INCORPORATING THE NEW STRAINER PRESSURE DROPS.

PAGES REVISED: 2b, 2a, 3, 4, 8, 11, 13, 15-20

PAGES ADDED: 3A, 21-31

Prepared By: Joseph T. Schilt (SWE) Date: 1/13/98  
Reviewed By: mD Haasan (SWE) Date: 1/13/98  
Approved By: John J. Yule for N.B. Cusick Date: 1/15/98

Effective Date: 8-19-96

Exhibit NE-C-420-3, Rev. 2

Page 1 of 1

RAS/mak

## CONTROLLED COPY

Source Calc. # M-51-62 Rev. 4

ECR # LG 970305B Rev. Ø

CALCULATION REVIEW CHECKLIST

<u>MANUAL CALC.</u>	<u>COMPUTER CALC.</u>		<u>YES or N/A</u>
X	X	Calculation is the appropriate basis for the activity	Yes
X	X	Calculation assumptions, considerations, and methodology conform to applicable design requirements	Yes
X	X	Sources of data and formulas were reviewed and verified to be correct and complete	Yes
X	X	Input data is correct and used properly	Yes
X		The analytical method used in the calculation has been considered and is proper for the intended use	Yes
X		Mathematical accuracy has been checked and is correct (indicate method used)	Yes
	a)	Complete check of each calculation	Yes
	b)	Spot check of selected calculations	N/A
	c)	Performance of alternate or approximation calculation (attached)	N/A
X	X	Calculation results were checked against applicable design criteria and were found to be in compliance	Yes
X	X	Existing calculations requiring revision as a result of this calculation have been identified and documented	N/A
X	X	The analytical methods described in the computer calculation summary are proper for the intended use	N/A
X	X	All system and topic numbers associated with the calculation are listed	Yes
X		Computational accuracy has been checked and is correct (indicate method used)	N/A
	b)	Check sample calculation using data other than that used in the sample	N/A
	b)	Performance of alternate or approximation calculation (attached)	N/A
	c)	Describe other method used:	N/A
X		Program used is appropriate, input is valid, and output is reasonable considering the input	N/A
X	X	Base calculation has been reviewed against current drawing revisions and posted DCDs to identify significant differences	Yes *

The criteria listed above are the minimum criteria to be considered and are not intended to limit the initiative of the reviewer to consider other criteria.

Attributes applicable to manual and computer calculations are noted by an "X" in the appropriate column.

List the documents used to support this review. \* Drawings/documents not affected by MOD P00280 are not reviewed to verify if their revisions are current.

Prepared By: m/Ortaçan (SWE) Date: 1/13/98

NUCLEAR  
GROUP

DOCTYPE 061

# CALCULATION COVER SHEET

1. Calculation No. 51-62  
followed by  
Page 1 Pg 10

2.  LGS  
 PBAPS

3. UNIT(S) 1+2

4. MOD/NCR/ECR No.:  
Other: PEP I0004457

5. Responsible Branch: SEEM

6. Last Page No: 20

7.  Safety Related  
 Non-Safety Related

8. Description: RHR SYSTEM NPSHA FROM S.P.

9. System/Topic No: 051, III

Structure: NA

Component: NA

## RECORD OF REVISIONS

10. Rev. No.	11. Description of Revision	12. Vendor Calc.		13. Assumptions		14. Signatures		
		Number	Rev.	Yes	No	Preparer	Reviewer	Approver/Date
4	<p>CHANGE MAX ALLOWABLE SUCTION STRAINER DP FROM 2.0 PSID to 5.0 PSID. CALC WORST-CASE NPSHA FROM S.P. ALSO PROVIDE 'ACTION' VALUE FOR SYSTEM TEST. RENUMBERED PAGES AND ADDED PAGES 15-20. SEE PAGE 15 FOR SUMMARY OF RESULTS.</p> <p>REVISION 4 DOES NOT IMPACT Power Rate or Performance.</p> <p>REVISION 4 DOES NOT IMPACT STATION ADMIN &amp; IMPLM. PROCEDURES. REV 4 DOES IMPACT SURVEILLANCE TESTS, THE RHR DBD (L-S-9), AND THE LGS SAR.</p>	NA			X	(S10) (SRIF DRAFT)	John N (Concurrent Reviewer)	George J. Hether 11/1995

15. Related Calc. Numbers	Provides Info to:	<u>LM-0571</u>						16. <input checked="" type="checkbox"/> Manual <input type="checkbox"/> Computer Computer program and version
	Receives Info from:	<u>MISC-62</u>						
17. Provides Info to UFSAR/ Tech.Spec.:	<u>JPSAR - 6.3</u>	<u>T.S. 3/4.5.1</u>	<u>T.S. 3/4.5.2</u>	<u>T.S. 3/4.6.2.2</u>	<u>3/4.6.2.3</u>			18. Total Pages: (DS Use)



# CALCULATION COVER SHEET

PROJECT Limerick Gen. Station Unit 1 & 2 JOB NO. 8031 DISCIPLINE Mechanical  
 SUBJECT EHR SYSTEM NPSH FILED AND PAGE 1b FOLLOWED BY 1c  
CALC. NO. M-51-62  
NO. OF SHEETS 4+TA COVER SHEET 50

## RECORD OF ISSUES

NO.	OPTION	BY	DATE	CHKD	DATE	APPRD	DATE
1							
2							
3							
4	SEE NEW COVER SHEET						
5	Final calc. Revised for calc. screening only. Added sheet <u>1A</u> , list of MDCPs, DCPs etc. reviewed. Added New Cover Sheet	<u>SP</u>	<u>1/3/90</u>	<u>SSK</u>	<u>2/1/90</u>	<u>1/11/90</u>	<u>2/3/90</u>
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
43							
44							
45							
46							
47							
48							
49							
50							
51							
52							
53							
54							
55							
56							
57							
58							
59							
60							
61							
62							
63							
64							
65							
66							
67							
68							
69							
70							
71							
72							
73							
74							
75							
76							
77							
78							
79							
80							
81							
82							
83							
84							
85							
86							
87							
88							
89							
90							
91							
92							
93							
94							
95							
96							
97							
98							
99							
100							
101							
102							
103							
104							
105							
106							
107							
108							
109							
110							
111							
112							
113							
114							
115							
116							
117							
118							
119							
120							
121							
122							
123							
124							
125							
126							
127							
128							
129							
130							
131							
132							
133							
134							
135							
136							
137							
138							
139							
140							
141							
142							
143							
144							
145							
146							
147							
148							
149							
150							
151							
152							
153							
154							
155							
156							
157							
158							
159							
160							
161							
162							
163							
164							
165							
166							
167							
168							
169							
170							
171							
172							
173							
174							
175							
176							
177							
178							
179							
180							
181							
182							
183							
184							
185							
186							
187							
188							
189							
190							
191							
192							
193							
194							
195							
196							
197							
198							
199							
200							
201							
202							
203							
204							
205							
206							
207							
208							
209							
210							
211							
212							
213							
214							
215							
216							
217							
218							
219							
220							
221							
222							
223							
224							
225							
226							
227							
228							
229							
230							
231							
232							
233							
234							
235							
236							
237							
238							
239							
240							
241							
242							
243							
244							
245							
246							
247							
248							
249							
250							
251							
252							
253							
254							



# CALCULATION COVER SHEET

~~842A \* T-1-1-1-1-1-1~~  
~~55152402~~

4

PROJECT LIMERICK UNIT 1 & 2 JOB NO. 8031\* DISCIPLINE MECH  
 SUBJECT RHR SYSTEM NPSH FILED NO. PAGE 1a FOLLOWED BY PG 2  
 ORIGINATOR R. M. VITANGCOL CALC. NO. M-51-62  
 CHECKER KRIS + NARAYAN DATE 10/4/88 NO. OF SHEETS # 40 SHL &  
 DATE 10/5/88 | 4

RECORD OF ISSUES								
NO.	DESCRIPTION	BY	DATE	CHKD	DATE	APPRD	DATE	DATE FILMED
0	FINAL CALC	RMV	10/4/88	Kris Narayan	10/5/88	J/M/Pad	11/1/88	10-31-88 PP-6641
1	REVISED TO REFLECT LOWEST SF WL PER CALC. #MISC.-62 REV1 (REF. 2)	RMV	11/30/88	Kris Narayan	12/1/88	J/M/Pad	12/16/88	
2	FINAL	↓	↓	↓	↓	↓	↓	
2	REVISED TO REFLECT CALC #MISC-62 REV.3 (REF. 2) - REVISED PAGE 2 - FINAL	RMV	12/29/88	Kris Narayan	12/29/88	J/M/Pad	1/3/89	1-10-89 19-0-0
3	New Calc Cover Sheet							
	PRELIMINARY CALC. <input type="checkbox"/>						COMMITTED PRELIMINARY DESIGN CALC. <input type="checkbox"/>	
	SUPERSEDED CALC. <input type="checkbox"/>						FINAL CALC. <input checked="" type="checkbox"/>	

NOTE: THIS CALC. SUPERSEDES CALCULATION  
 NO. 8031-M-51-9, Rev. 2 AND NO. 8031-  
 M-51-10, Rev. 2.

&lt;

CALC. # M-51-62 REV. 4  
PAGE 2 FOLLOWED BY PAGE 2b

## CALCULATION REVIEW CHECKLIST

<u>MANUAL CALC.</u>	<u>COMPUTER CALC.</u>	<u>YES or N/A</u>
X	X	CALCULATION IS THE APPROPRIATE BASIS FOR THE ACTIVITY
X	X	CALCULATION ASSUMPTIONS, CONSIDERATIONS, AND METHODOLOGY CONFORM TO APPLICABLE DESIGN REQUIREMENTS
X	X	SOURCES OF DATA AND FORMULAS WERE REVIEWED AND VERIFIED TO BE CORRECT AND COMPLETE
X	X	INPUT DATA IS CORRECT AND USED PROPERLY
X	X	THE ANALYTICAL METHOD USED IN THE CALCULATION HAS BEEN CONSIDERED AND IS PROPER FOR THE INTENDED USE
X	X	MATHEMATICAL ACCURACY HAS BEEN CHECKED AND IS CORRECT (INDICATE METHOD USED)
	A)	COMPLETE CHECK OF EACH COMPUTATION
	B)	SPOT CHECK OF SELECTED COMPUTATIONS
	C)	PERFORMANCE OF ALTERNATE OR APPROXIMATION CALCULATION (ATTACHED)
X	X	CALCULATION RESULTS WERE CHECKED AGAINST APPLICABLE DESIGN CRITERIA AND WERE FOUND TO BE IN COMPLIANCE
X	X	EXISTING CALCULATIONS REQUIRING REVISION AS A RESULT OF THIS CALCULATION HAVE BEEN IDENTIFIED & DOCUMENTED
X	X	THE ANALYTICAL METHODS DESCRIBED IN THE COMPUTER CALCULATION SUMMARY IS PROPER FOR THE INTENDED USE
X	X	ALL SYSTEM AND TOPIC NUMBERS ASSOCIATED WITH THE CALCULATION ARE LISTED
X	X	COMPUTATIONAL ACCURACY HAS BEEN CHECKED AND IS CORRECT (INDICATE METHOD USED)
	A)	CHECK SAMPLE CALCULATION USING DATA OTHER THAN THAT USED IN THE SAMPLE
	B)	PERFORMANCE OF ALTERNATE OR APPROXIMATION CALCULATION (ATTACHED)
	C)	DESCRIBE OTHER METHOD USED:
X	X	PROGRAM USED IS APPROPRIATE, INPUT IS VALID, AND OUTPUT IS REASONABLE CONSIDERING THE INPUT
X	X	BASE CALCULATION HAS BEEN REVIEWED AGAINST CURRENT DRAWING REVISIONS AND POSTED DCDs TO IDENTIFY SIGNIFICANT DIFFERENCES

The criteria listed above are the minimum criteria to be considered and are not intended to limit the initiative of the reviewer to consider other criteria.

Attributes applicable to manual and computer calculations are noted by an "X" in the appropriate column.

List the documents used to support this review. Crane Technical paper 410  
Pump Curves M1-EII-1002- J - 12 to 19, System flow diagram M1-EII-1020. G002

REVIEWED BY: Edwin Auk DATE: 10-23-95

Checklist Note: Methodology used to combining 24" and 30" piping losses slightly overstates piping losses. The result is conservative and acceptable.



# CALCULATION SHEET

ORIGINATOR W.E. Purcell DATE 1-31-70 CHECKED SSkak REV. NO. 3  
PROJECT LGS Units 1 & 2 JOB NO. 8031 DATE 2/1/90  
SUBJECT RHR System UPSH SHEET NO. 20 1A followed by 14  
pg 2b

The Following MDCPs, DCPs, Design Documents, and Pre-Op Test Results Were Reviewed.

Circled items relate specifically to this calculation.

MDCP		DCP		PCR/PCN	
UNIT 1	UNIT 2	UNIT 1	UNIT 2	UNIT 1	UNIT 2
0024-1	0815-1	5579-2	68	2006	5
0035-1	0831-1	6006-2	76	2014	80
0047-1	5010-1		78	2015	84
0133-1	5042-1		81	2021	86
0171-1	5054-1		109	2044	116
0176-1	5178-1		115	2083	121
0193-1	5228-1		117	2088	248
0302-1	5261-1		139	2092	620
0303-1	5579-1		156	2095	6005
0363-1	5650-1		239	2103	6080
0397-1	5658-1		289		6084
0494-1	5663-1		367		6116
0522-1	5716-1		493		6121
0680-1	5770-1		558		6171
0696-1	5709-1		559		6208
0793-1	5791-1		563		6240
0801-1	5906-1		2014		6241
			2015		6306
			2021		6331
			2083		6354
			2088		6373
			2092		6494
			2095		6569
			2103		6620
Other Design Documents					



# CALCULATION SHEET

ORIGINATOR R. M. VITANGCOL DATE 10/4/88 RMV 11/30/88 □  
PROJECT LIMERICK UNIT 1 E2  
SUBJECT RHR SYSTEM NPSH

CALC. NO. M-51-62 REV. NO. 00 1  
CHECKED Kris Narayan DATE 10/15/88  
JOB NO. 2031  
SHEET NO. 2b FOLLOW BY PG 2a □  
4

## PURPOSE

The purpose of this calculation is to determine whether an adequate NPSH is available in the RHR system during Post Accident operating MODES A-1, A-2 and B (Ref. 1) when the suppression pool water level drops to EL. 199'-11 1/2" (SP Depth = 18.04') (REF 2) from the current design minimum level at elev. 203'-11" (SP Depth = 22'-0") (REF 8). IN ADDITION, THE NPSHA MARGIN FOR MODE B IS CALCULATED BASED ON THE ACTUAL DIRTY STRAINER PRESSURE DROP.

THIS  
ECR

## ASSUMPTIONS

1. The suppression pool water level is at minimum level elevation of 203'-11" at the time of the accident. Since the downcomers are raised above the drywell floor, the water level in the suppression pool may drop to EL 199'-11 1/2" □ before recirculation is achieved.  
(Unit 1&2)
2. The longest suction pipe routing is considered in this calculation i.e. Suction piping of Pump ZAP202 or ZBP202 which are identical.
3. Pipe lengths are gross distance between fitting centerlines. Fitting dimensions were not deducted.
4. Maximum suppression pool suction strainer losses of 2.0\* psid as specified in Ref 9 is used.

9 THIS  
ECR

\* THE ORIGINAL PURCHASE ORDER SPECIFIED A MAX dP ACROSS A SINGLE STRAINER @ FULL FLOW OF NO MORE THAN 2.0 PSID. FOR REV 4 OF THIS CALC A MAX dP OF 5.0 PSID IS USED TO ESTABLISH OPERABILITY CRITERIA. SEE REV 4 PAGES 15-20.



# CALCULATION SHEET

ORIGINATOR R. M. JITANGCOL DATE 10/4/88  
PROJECT LIMERICK UNIT 1&2  
SUBJECT RHR SYSTEM NPSH

CALC. NO. M-51-62 REV. NO. 2  
CHECKED Kris Narayan DATE 10/11/88  
JOB NO. 8031  
SHEET NO. 2a FOLLOWED BY PG 3 4

## ASSUMPTIONS (Cont.)

checked by: Kris Narayan  
12/11/88 4

5. Pump/suction nozzle & elevation is assumed to be the same as the pump impeller eye. 2 4
6. Flow is assumed to be thru one suction leg only.
7. Velocity head is not considered.
8. MAXIMUM ALLOWABLE DIRTY STRAINER PRESSURE DROP IS  
12 ft H<sub>2</sub>O AT 212.5°F AS SPECIFIED IN REFERENCE 11 THIS  
AND REFERENCE 13. ECL

## REFERENCES

1. G.E. Process Diagrams For Residual Heat Removal System.
  - a). Dwg. No. 761E292AD Sh. 1, Rev. 1, Bechtel No. 8031-M-1-E11-1020-G-002(1) 10 EX THIS
  - b). Dwg. No. 761E292AD Sh. 3, Rev. 7, Bechtel No. 8031-M-1-E11-1020-G-002(3). 1
2. Calculation No. 8031-MISC-62, Rev. 3 (Intermediate Break Accident, IBA at 600 seconds, Worst Case) 2
3. Bechtel Drawings, Piping Isometric
  - HBB-117-1, Rev. 16
  - HBB-118-4, Rev. 13
  - HBB-117-2, Rev. 16
  - HBB-118-5, Rev. 11
  - HBB-117-3, Rev. 17
  - HBB-118-6, Rev. 11



# CALCULATION SHEET

ORIGINATOR R. M. VITANGCOL DATE 10/4/88 CALC. NO. M-51-62 REV. NO. 0  
PROJECT LIMERICK UNIT 1 & 2 CHECKED Kris Narayan DATE 10/5/88  
SUBJECT RHR SYSTEM NPSH JOB NO. 8031  
SHEET NO. 3 OF 14 4

## REFERENCES (Cont)

3. HBB-117-4, Rev. 15  
HBB-118-7, Rev. 11  
HBB-217-1, Rev. 14  
HBB-218-4, Rev. 9  
HBB-217-2, Rev. 14  
HBB-218-5, Rev. 8  
HBB-217-3, Rev. 12  
HBB-218-6, Rev. 8  
HBB-217-4, Rev. 13  
HBB-218-7, Rev. 8

4. Bechtel Drawings, Piping Spools marked as follows:

- HBB-117-1-1, Rev. 2
- HBB-117-2-1, Rev. 2
- HBB-117-3-1, Rev. 2
- HBB-117-4-1, Rev. 2
- HBB-217-1-1, Rev. 0
- HBB-217-2-1, Rev. 5
- HBB-217-3-1, Rev. 4
- HBB-217-4-1, Rev. 5

5. Crane Technical Paper #410, Sixth Printing
6. Crane Technical Paper #410, 1982 Printing
7. Cameron Hydraulic Data, IR, Sixteenth Edition
8. Bechtel Drawg. 8031-M-247, Rev. 23
9. Specification No. 8031-M-162, Rev. 3 | THIS ECR
10. RHR Pump Performance Test Curve, IR No. N-693, Rev. 0 FOR a BP202.; Bechtel No. 8031-M1-E11-C002-J-1B.1.

All PUMP CURVES WERE CONSIDERED. E11-C002-J-12 THROUGH J-19. | 4

REFERENCES CONTINUED ON PAGE 3A

| THIS ECR

ED-69 (5/76)

REFERENCES (CONTINUED)

11. Specification No. NE-265, Revision 1, Specification for ECCS Suction Strainers.
12. Bechtel Drawing 8031-M-277, Revision 66.
13. SDOC NE-265-00037, Revision 0: ABB Calculation 599-PENG-CALC-060, Revision 0, Limerick ECCS Strainer Sizing for Debris Loading and Pressure Drops.
14. SDOC NE-265-18, Revision 0: ABB Calculation MISC-PENG-CALC-062, Revision 0, Evaluation of Predictions and Data for Prototype Strainer.



## CALCULATION SHEET

RMV 11/30/88 □

CALC. NO. M-51-62 REV. NO. 201

ORIGINATOR R. M. VITANGCOL DATE 10/4/88

CHECKED Kris Narayan DATE 10/15/88

PROJECT LIMERICK UNIT 1&amp;2

JOB NO. 8031

SUBJECT RHR SYSTEM NPSH

SHEET NO. 4 OF 14 □

SUMMARY OF RESULTS\*checked by: Kris Narayan □  
12/11/88

<u>MODE</u>	<u>NPSHA</u>	<u>NPSHR</u>	<u>REF. SH. NO</u>	<u>THIS ECR</u>
A-1	35.44 <del>38.14 FT</del> A	5 FT.	23 18	1
A-2	25.72 <del>34.17 FT</del>	6 FT	25 12	
B	10.62 <del>17.54 FT</del>	5 FT **	27 14	4

\*\* SEE PAGE 27 FOR ADDITIONAL DISCUSSION REGARDING NPSH REQUIREMENTS  
SPECIFIED BY REFERENCE 1. SEE PAGE 30 FOR NPSHA MARGIN FOR MODE B  
BASED ON ACTUAL DIRTY STRAINER AP

CONCLUSION\*

The calculated NPSHA shows that the system provides sufficient margin over the required NPSH during accident modes at a lower suppression pool water level as stated in assumption 1. A higher NPSH margin is expected in the actual operation due to conservatism included in the calc. as stated in assumptions 3, 4, 6 and 7.

\* THESE RESULTS ARE BASED ON THE ORIGINAL DESIGN BASIS FOR THE SUCTION STRAINERS OR NO MORE THAN 2.0 PSID ACROSS ONE STRAINER AT FULL FLOW (THE OTHER STRAINER FULLY FOULED, I.E., THE UNIT BEING 50% FOULED). IN REV 4 OF THIS CALC, THE DESIGN BASIS FOR THE SYSTEM IS CHANGED TO ALLOW A MAXIMUM OF 5.0 PSID ACROSS THE STRAINER. ADEQUATE NPSHA IS PROVEN IN REV 4 PAGES 15-20. THE RESULTS AND CONCLUSIONS ON THIS PAGE ARE THEREFORE NO LONGER VALID.

A

THIS ECR

\* SEE PAGES 24, 26, 29 and 31. NOTE RESULTS FOR MODE A-2 & B ARE BASED ON MAXIMUM ALLOWABLE DIRTY STRAINER ΔP.



# CALCULATION SHEET

ORIGINATOR R. M. VITANGCOL DATE 10/4/88 CAL.C. NO. M-51-62 REV. NO. 0  
 PROJECT LIMERICK UNIT 1 & 2 CHECKED Kris Narayan DATE 10/5/88  
 SUBJECT RHR SYSTEM NPSH JOB NO. 8031  
 SHEET NO. 5 OF 10 4

## RHR PUMP SUCTION MATERIAL TAKE-OFF (REFERENCES 3 and 4)

PUMP NOS.

24" LINE 1AP202 1BP202 1CP202 1DP202 2AP202 2BP202 2CP202 2DP202

70	STR PIPE	49.5'	49.5'	49.0'	49.0'	53.0'	53.0'	48.5'	48.5'
80	90° Elbow	3	3	3	3	4	4	3	3
90	Tee, Br	1	1	1	1	1	1	1	1
10	Tee FT	1	1	1	1	1	1	1	1
11	Gate Valve	1	1	1	1	1	1	1	1
12	24" x 30" EXP	1	1	1	1	1	1	1	1
13 LN									

## 30" LINE

14	STR. PIPE	5.25'	5.25'	5.25	5.25	5.25	5.25	5.25	5.25
15	90° ELBOW	2	2	2	2	2	2	2	2
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
32									
33									
34									
35									
36									

BASED ON THE ABOVE, THE LONGEST SUCTION LINE IS EITHER PUMP #2AP202 OR 2BP202. THIS WILL BE USED AS THE BASIS FOR THIS NPSHA CALCULATION.

## EQUIVALENT PIPE LENGTHS (Ref. 5 )

<u>24" LINE</u>	ID	L/D	EQ. L. (FT)
STR. PIPE	23.25"	—	53
4- 90° ELBOW		30	233.0
1- Tee Br		60	116.0
1- Tee F.T.		20	39.0
1- Gate Va		13	25.0
1- 24" x 30" EXP.		4.35	8.5 (SEE SH. 7)
TOTAL EQ. L.			474.5



# CALCULATION SHEET

RMV 11/30/88 □

CALC. NO. M-51-62 REV. NO. 01

ORIGINATOR R. M. VITANGCOL DATE 10/4/88

CHECKED Kris Narayan DATE 10/15/88

PROJECT LIMERICK UNIT 1 &amp; 2

JOB NO. 8031

SUBJECT RHR SYSTEM NPSH

SHEET NO. 6 OF 14 □


checked by: Kris Narayan □  
12/11/8830" LINE

ID L/D EQ. L.

STR. PIPE	29.25"	—	5.25
2 - 90° ELBOW	29.25	30	<u>146.25</u>

TOTAL EQ. L. 151.50'

SAY 152'






## CALCULATION SHEET

ORIGINATOR R. M. VITANGCOL DATE 10/4/88  
PROJECT LIMERICK UNIT 1 & 2  
SUBJECT RHR SYSTEM NPSH

CALC. NO. M-51- REV. NO. 0  
CHECKED Kris Narayan DATE 10/15/88  
JOB NO. 8031  
SHEET NO. 7 OF 14 A

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
CALCULATE L/D FOR 24" x 30" INCREASER (Ref 6)



$$K = 2.6 \sin \frac{\phi}{2} (1 - \beta^2)^2 \quad (\text{smaller pipe dia. is referenced})$$

$$\beta = \frac{d_1}{d_2} = \frac{23.25}{29.25} = 0.795$$

$$\phi/2 = \tan^{-1} \left[ \frac{f(d_2 - d_1)/2}{L} \right] = \tan^{-1} \left[ \frac{(29.25 - 23.25)}{2 \times 20} \right] = 8.53^\circ$$

$$K = 2.6 (\sin 8.53) (1 - 0.795^2)^2 \\ = 0.0522$$

$$h_f = \left( f \frac{L}{D} \right) \frac{V^2}{2g} \quad K = f \frac{L}{D}$$

$$L/D = \frac{K}{f} \\ = \frac{0.0522}{0.012} = 4.35$$

where  $f = 0.012$  (for 18"-24" pipe)  
(Ref. 6)



# CALCULATION SHEET

RMV 11/30/88

CALC. NO. M-51-62 REV. NO. 1

ORIGINATOR R. M. VITANGCOL

DATE 10/14/88

CHECKED Kris Narayan

PROJECT LIMERICK UNIT 1 &amp; 2

DATE 10/15/88

SUBJECT RHR SYSTEM NPSH

JOB NO. 8031

SHEET NO. 8 OF 142 A

checked by: Kris Narayan 10/11/88

## CALCULATE NPSHA FOR MODE "A-1" (REF. 1)

SEE PAGE 21 FOR MODE A-1

~~Mode A-1 is NOT NPSH LIMITING,  
AND IS NOT RECALCULATED FOR  
REV 4 CHANGES~~

### OPERATING CONDITIONS

Flow - 10,150 GPM

Temperature - 170 °F

Specific Wt @ 170°F ( $\rho$ ) = 60.79 #/ft³ (ρ) (Ref. 7)Min. Supp. Pool W.L. Depth = 18.04' } REF. 2  
ELEV. = 199-11 1/2" }

Pressure @ Suppression Pool = 14.7 psia (Ref. 1)

Vapor pressure @ 170°F = 5.99 psia (Ref. 7)

Pump Suction Elevation - 174'-0 1/2" or 174.875' (Ref.)

$$NPSH = h_a - h_{vpa} + h_{st} - h_{fs} \quad (\text{Ref. 7})$$

where  $h_a$  = absolute pressure (in ft of liquid)  
on the surface of liquid supply level

$h_{vpa}$  = head (in feet) corresponding to  
to the vapor pressure of the liquid  
being pumped.

$h_{st}$  = static head of liquid above  
centerline of impeller eye.

$h_{fs}$  = suction line friction losses.  
(in feet)



# CALCULATION SHEET

CALC. NO. M-51-62 REV. NO. 0

ORIGINATOR R. M. VITANGCOL DATE 10/4/88 CHECKED *Krisenbraun* DATE 10/15/88  
PROJECT LIMERICK UNIT 1 & 2 JOB NO. 8031  
SUBJECT RHR SYSTEM NPSH SHEET NO. 9 OF 14 4

Calculate suction line losses ( $\Delta P$ )

$$\Delta P = 0.000216 \frac{f L \rho Q^2}{d^5} \quad (\text{Ref 5}) \quad \triangle 4$$

where  $\Delta P$  = friction losses in psi.

$Q$  = Flow in gpm

$L$  = Length of Pipe /in ft

$d$  = Internal diameter of pipe, inches

$\rho$  = Wt. density of fluid, #/FT<sup>3</sup>

$f$  = friction factor.

$Re$  (Reynolds No. of Flow in Pipe) (Ref 5)

$$Re = 50.6 \frac{Q \mu}{d \nu}$$

$\nu$  = absolute (dynamic) viscosity, in centipoise.

= 0.4 @ 170°F

(Ref 5)

$\Delta P$  @ 24" Line

$$Re = \frac{50.6 \times 10,150 \times 60.79}{23.25 \times 0.4} = 3.35 \times 10^6$$

$$\frac{\epsilon}{D} \quad (\text{Relative pipe roughness}) \quad 24'' \phi, \text{ commercial steel pipe (Ref 5)}$$

= 0.000072

$$f = 0.0115 \quad (\text{Ref 5})$$

$$\Delta P_{24''\phi} = \frac{2.16 \times 10^{-4} \times 0.0115 \times 474.5 \times 60.79 \times (10,150)^2}{(23.25)^5}$$
$$= 1.09 \text{ PSI}$$



## CALCULATION SHEET

RMV 11/30/88 △

CALC. NO. M-51-62 REV. NO. 1

ORIGINATOR R. M. VITANGCOL

DATE 10/4/88

CHECKED Kris Narayanan DATE 10/15/88

PROJECT LIMERICK UNIT 1 E 2

JOB NO. 8031

SUBJECT RHR SYSTEM NPSH

SHEET NO. 10 OF 14 △

△P @ 30" LINEchecked by: Kris Narayanan △  
12/11/88

$$Re = \frac{50.6 \times 10,150 \times 60.79}{29.25 \times 4} = 2.66 \times 10^6$$

1/0 (30" comm. steel Pipe) = 0.00006 (Ref 5)

f = 0.0118

$$\Delta P = \frac{2.16 \times 10^{-4} \times 0.0118 \times 152 \times 60.79 \times (10,150)^2}{(29.25)^5}$$

= 0.113 psi

$$h_{fs} = \Delta P_{24"} + \Delta P_{30"} + \Delta P_{\text{STRAINER}}$$

$$= (11.09 + 0.113 + 2.0) \frac{144}{60.79}$$

= 7.58 ft

$$h_{ST} = \text{Min. W.L. @ Suppression Pool} - \text{Elev. @ } \frac{1}{4} \text{ of Pump Suction Nozzle.}$$

= 199.96 - 174.875

= 25.085 ft ✓

S.71

$$\text{NPSHA (MODE A-1)} = \frac{144}{60.79} (14.7 - 5.99) + 25.085 - 7.58$$

= 38.137 ft. SAY 38.14

RHR PUMP TYPICAL NPSHR @ 10,150 gpm = 5 ft.  
(Ref 10)



# CALCULATION SHEET

RMV 11/30/88 □

CALC. NO. M-51-62 REV. NO. ✓ 1

ORIGINATOR R. M. VITANGCOL DATE 10/4/88

CHECKED Krishnamoorthy DATE 10/15/88

PROJECT LIMERICK UNIT 1 &amp; 2

JOB NO. 8031

SUBJECT RHR SYSTEM NPSH

SHEET NO. 11 GE 142 □

checked by: Krishnamoorthy 12/11/88

CALCULATE NPSHA FOR MODE A-2 (Ref. 1)

TMS TEC

OPERATING CONDITIONS

→ See Pg 25 For Mode A-2

Mode A-2 is not NPSH

LIMITING ANGLES NOT RE-CALC'D  
FOR REV 4.

FLOW - 11,000 gpm

Temperature - 180°F

Sp. Wt. @ 180°F ( $\rho$ ) = 60.57 #/ft<sup>3</sup> (Ref. 7)

Vapor Pressure @ 180°F = 7.511 psia (Ref. 7)

Pressure @ Suppression Pool - 14.7 psia (Ref. 1)

Min. W.L. @ Suppression Pool - EL 199'-11 1/2" (Ref. 2)

Pump Suction &amp; elevation - EL 174-10 1/2" (Ref. 3)

NOTE: USE EQUATIONS IN MODE A-1

 $\Delta P$  @ 24" LINE

$$R_s = \frac{50.6 \times 11,000 \times 60.57}{23.25 \times .35}$$

 $\mu = 0.35$  centipoise  
@ 180°F  
(Ref. 5)

$$= 4.14 \times 10^6$$

$$e/D = 0.000672 \text{ (Ref. 5)}$$

$$f = 0.0113 \text{ (Ref. 5)}$$

$$\Delta P_{24''} = \frac{2.16 \times 10^{-4} \times .0113 \times 474.5 \times 60.57 (15000)^2}{(23.25)^5}$$

$$= 1.25 \text{ psi}$$



# CALCULATION SHEET

RMV 11/30/88

CALC. NO. M-51-62 REV. NO. 061

ORIGINATOR R. M. VITANGCOL

DATE 10/4/88

CHECKED

Kris Navarrete DATE 10/15/88

PROJECT LIMERICK UNIT 1 &amp; 2

JOB NO.

8031

SUBJECT RHR SYSTEM NPSH

SHEET NO.

12 OF 144

 $\Delta P @ 30'' LINE$ 

$$R_e = \frac{50.6 \times 11,000 \times 60.57}{29.25 \times .35} = 3.29 \times 10^6$$

% (30" Comm. S.H. Pipe) = 0.00006 (Ref. 5)

$$f = 0.0113$$

$$\Delta P = \frac{2.16 \times 10^{-4} \times .0113 \times 152 \times 60.57 \times (11,000)^2}{(29.25)^5}$$

$$= 0.127 \text{ PSI}$$

$$\begin{aligned} h_{fs} &= \Delta P_{24''} + \Delta P_{30''} + \Delta P_{STRAINER} (\text{Ref. 9}) \\ &= (1.25 + 0.127 + 2.0) \frac{144}{60.57} \\ &= \underline{\underline{8.0 \text{ ft}}.} \end{aligned}$$

$$h_{ST} = 199.96 - 174.875 = 25.085 \text{ ft}$$

$$\begin{aligned} NPSHA \text{ (Mode A-2)} &= \frac{144}{60.57} (14.7 - 7.511) + 25.085 - 8.0 \\ &= \underline{\underline{34.17 \text{ ft}}.} \end{aligned}$$

RHR PUMP TYPICAL NPSHR @ 16,000 gpm = 6 ft. (Ref. 10)



# CALCULATION SHEET

ORIGINATOR R.M. VITANGCOL DATE 10/4/88  
PROJECT LIMERICK UNIT 1 & 2  
SUBJECT RHR SYSTEM NPSH

CALC. NO. M-51-62 REV. NO. 1

CHECKED Kris Narayanan DATE 10/15/88

JOB NO. 8031

SHEET NO. 13 OF 142 4

checked by: Kris Narayanan 12/11/88

## CALCULATE NPSHA FOR MODE "B" (Ref 1)

### OPERATING CONDITIONS

Flow — 10,000

Temperature — 212°F

SP. WT ( $\rho$ ) @ 212°F = 59.81 (Ref 7)

Vapor Pressure @ 212°F = 14.696 psig (Ref. 7)

Pressure @ Suppression Pool = 14.7 psia (Ref. 1)

Min. W.L. @ " " = EL. 199'-11 1/2" (Ref. 2)

Pump Suction & Elevation = EL. 179'-10 1/2" (Ref 3)

Note: Equations used as in MODE A-1

SEE Pg 27 FOR MODE B | TMIS ECR

MODE B IS NPSH LIMITTING

AND IS RECALC'D ON  
PAGES 15-20 FOR REV 4.

### $\Delta P$ @ 24" LINE

$$Re = \frac{50.6 \times 10,000 \times 59.81}{23.25 \times 0.29}$$
$$= 4.49 \times 10^6$$

$\mu = 0.29$  @ 212°F  
(Ref 5)

$$e/d = 0.000072, (Ref. 5)$$

$$f = 0.0115 / (Ref. 5)$$

$$\Delta P_{24''} = \frac{2.16 \times 10^{-4} \times 0.0115 \times 474.5 \times 59.81 \times (10,000)^2}{(23.25)^5}$$

$$= 1.03 \text{ PSI}$$

4



# CALCULATION SHEET

RMV 11/30/88  $\Delta$   
 ORIGINATOR R. M. VITANGCOL DATE 10/4/88  
 PROJECT LIMERICK UNIT 1 & 2  
 SUBJECT RHR SYSTEM NPSH

CALC. NO. M-51-62 REV. NO. 83  
 CHECKED Kris Namayan DATE 10/15/88  
 JOB NO. 8031  
 SHEET NO. 14 OF 14 C  $\Delta$

$\Delta P @ 30^\circ$  LINE

checked by: Kris Namayan  $\Delta$   
 12/11/88

$$R_2 = \frac{50.6 \times 10,000 \times 59.81}{29.25 \times 0.29} = 3.57 \times 10^6$$

$$\text{e/D } (30^\circ \text{ Comm. stl. pipe}) = 0.00006 \text{ (Ref. 5)}$$

$$f = 0.0113$$

$$\Delta P_{30^\circ\phi} = \frac{2.16 \times 10^{-4} \times 0.0113 \times 152 \times 59.81 \times (10,000)^2}{(29.25)^5}$$

$$= 0.103 \text{ psi}$$

$$h_{fs} = \Delta P_{24^\circ\phi} + \Delta P_{30^\circ\phi} + \Delta P_{\text{strainer}} \text{ (Ref. 9)}$$

$$= (1.03 + 0.103 + 2.0) \frac{144}{59.81}$$

$$= 7.54 \text{ ft.}$$

$$h_{st} = 199.96 - 174.875 = 25.085 \text{ ft}$$

$$\underline{\text{NPSHA (Mode B)}} = \frac{144}{59.81} (14.7 - 14.7) + 25.085 - 7.54$$

$$= \underline{\underline{17.54}} \text{ ft}$$

RHR PUMP TYPICAL NPSHR @ 10,000 gpm = 5 ft. (Ref 10)

$\Delta$   
4

PECO ENERGY  
NUCLEAR GROUP**CALCULATION SHEET**

CALC NO.: M-51-62

PAGE: 15

Revision 4

## REVISION 4

Purpose

To re-evaluate the net positive suction head available (NPSHA) for the residual heat removal (RHR) system with suction aligned from the suppression pool (SP) under the worst expected conditions and with an increase in the maximum allowable differential pressure across the suction strainer of 5.0 psid (the original design was 2.0 psid).

During the regular pump valve and flow tests, measurements will be taken of the pressure at the pump suction (PP-51-102A-D and PP-51-202A-D) with suction aligned to the SP and with no flow (static) and with design rated (10,000 gpm) flow (dynamic). The purpose of these measurements is to show loop capability for LGS Technical Specification requirements. An additional purpose of this calculation is to establish the maximum value for the difference between these two measured pressures beyond which the loop may not satisfy its safety function.

Results

With suction aligned from the SP, under worst expected conditions (212°F and 1 atm), with a pump flow rate of 11,000 gpm, a SP level of 199' 1 1/2", and a maximum allowable differential pressure across the suction strainer of 5.0 psid, the calculated net positive suction head available is

$$\text{NPSHA} = 7.97 \text{ feet}$$

The margin to the net positive suction head required by the pump is,

$$\text{Margin} = 2.0 \text{ feet}$$

With a system test (SP to SP) flow rate of 10,000 gpm, the maximum allowed change in suction pressure measured at PP-51-1(2)02A(-D) is 6.3 psid.

$$P_{\text{static}} - P_{\text{dynamic}} > 6.3 \text{ psid}$$

Max. Allowed

These results are applicable to both LGS Unit 1 and Unit 2.

Inputs

T	=	212	°F
P	=	45	psia (only used to determ ρ and μ)
ρ	=	59.81992	lbm/cuft
μ	=	0.28222	cp
P <sub>a</sub>	=	1	atm
P <sub>v</sub>	=	1	atm
Q	=	11,000	gpm
d	=	23.25	inches
L <sub>eq</sub> (24")	=	474.5	feet
L <sub>eq</sub> (30")	=	151.5	feet
Z <sub>SP</sub>	=	199.95833	feet
Z <sub>pump</sub>	=	174.87500	feet
NPSHR	=	6.0	feet @ 11,000 gpm

THIS ECR

PECO ENERGY  
NUCLEAR GROUP**CALCULATION SHEET**

CALC NO.: M-51-62

PAGE: 16

Revision 4

CalculationsTHIS  
EQR**NET POSITIVE SUCTION HEAD AVAILABLE**

Flow losses (not including strainer), from page 3-2 of References 5 &amp; 6,

$$Re = 50.65929 \frac{Q \rho}{\mu d}$$

$$= 5.08 E+06$$

To account for 40 year life, assume a roughness factor of 0.00085 feet (equivalent to cast iron)

From page A-24 of References 5 &amp; 6

$$f = 0.0163^{**1}$$

From page 3-2 Equation 3-5 of Reference 5 &amp; 6

$$\Delta P_f = 2.161037233E-4 \frac{f \rho Q^2}{d^5} L_{eq}$$

$$L_{eq} = 474.5 + 151.5 \times \left( \frac{23.25}{29.25} \right)^5$$

$$= 522.57 \text{ feet}$$

$$\Delta P_f = 2.161037233E-4 \frac{(0.0163351)(59.81992)(522.57)(11000)^2}{(23.25)^5}$$

$$= 1.965 \text{ psid}$$

PECO ENERGY  
NUCLEAR GROUP

## CALCULATION SHEET

CALC NO.: M-51-62  
PAGE: 17  
Revision 4Calculations (Cont'd)Calculating the NPSHA, with  $P_a = P_v$ ,

$$\text{NPSHA} = \frac{144}{\rho} (P_a - P_v - \Delta P_f - \Delta P_{\text{strainer}}) + Z_{SP} - Z_{\text{pump}}$$

$$= 199.95833 - 174.875 - \frac{144}{59.81992} (1.965 + 5.0)$$

$$= 8.317 \text{ feet } @ \rho = 59.81992 \text{ lbm/cuft}$$

$$= 8.317 \times \frac{59.81992}{62.4}$$

$$= 7.97 \text{ feet } @ \rho = 62.4 \text{ lbm/cuft}$$

Thus,

NPSHA	=	7.97	feet
NPSHR	=	6.00	feet (@ 11,000 gpm. Ref 10)
Margin	=	2.00	feet

TMS  
FCR

PECO ENERGY  
NUCLEAR GROUP

## CALCULATION SHEET

CALC NO.: M-51-62  
PAGE: 18  
Revision 4Calculations (Cont'd)TMS  
EZR

## MAXIMUM VALUE

The pressure loss due to flow calculated above considered the longest suction line from the SP and assumed a roughness factor of 0.00085 to account for a 40 year life. The equivalent length calculated is therefore conservative for the calculation of NPSHA, but should not be used to evaluate a maximum value for a measured difference in suction pressure between static and dynamic conditions because it would attribute more measured flow dP to the line itself and less to the strainer. Thus a conservatively LOW value of equivalent length should be used for this part of the calculation.

It is conservative to assume the hottest SP temperature expected during the test, that of the maximum SP temperature allowable by Technical Specification during normal plant operation, 95°F.

T	=	95	°F
P	=	45	psia
p	=	62.06687	lbf/in <sup>2</sup>
$\mu$	=	0.71955	cp
Q	=	10,000	gpm

Calculating the Reynold's Number for these input parameters yields,

$$Re = 50.65929 \frac{Q p}{\mu d}$$

$$= 1.88 E+06$$

and using clean pipe with a roughness factor of 0.00015, we get a friction factor of,

$$f = 0.0124405$$

Re-evaluating the a total equivalent line length using shorter line lengths of,

$L_A(24")$	=	450	feet
$L_{eq}(30")$	=	100	feet

$$L_{eq} = 450 + 100 \times \left( \frac{23.25}{29.25} \right)^5$$

$$= 481.73 \text{ feet}$$

PECO ENERGY  
NUCLEAR GROUP

## CALCULATION SHEET

CALC NO.: M-51-62

PAGE: 19

Revision 4

Calculations (Cont'd)

Evaluating the line losses (not including the suction strainer),

$$\Delta P_f = 2.161037233E-4 \frac{(0.0124405)(62.06687)(481.73)(10000)^2}{(23.25)^5}$$

= 1.183 psid

The difference between the pressure at the pump suction (PP) at static conditions and at dynamic conditions can be expressed as,

$$\Delta P = P_{\text{static}} - P_{\text{dynamic}}$$

$$= \Delta P_f + \Delta P_v + \Delta P_{\text{strainer}}$$

where,

$P_{\text{static}}$	= pressure at the pump suction with no flow
$P_{\text{dynamic}}$	= pressure at the pump suction with flow
$\Delta P_f$	= pressure loss due to flow (not including the suction strainer)
$\Delta P_v$	= pressure loss due to velocity (i.e. the velocity head in psid)
$\Delta P_{\text{strainer}}$	= maximum allowable pressure drop across the strainer (5.0 psid)

The pressure loss due to velocity is evaluated, using the 30" suction pipe (since the pressure tap is in the 30" portion of the suction line) as,

$$\Delta P_v = 1.80086E-5 \frac{\rho Q^2}{d^4}$$

$$= 1.80086E-5 \frac{(62.06687)(10000)^2}{(29.25)^4}$$

= 0.1527 psid

THIS ECR

PECO ENERGY  
NUCLEAR GROUP

## CALCULATION SHEET

CALC NO.: M-51-62

PAGE: 20

Revision 4

Calculations (Cont'd)

Thus the difference between the measured suction pressure at static conditions and at dynamic conditions becomes,

$$\Delta P = \Delta P_f + \Delta P_v + \Delta P_{strainer}$$

$$= 1.18 + 0.15 + 5.00$$

$$= 6.3 \text{ psid} \quad \text{Max. Allowed}$$

TMS  
ECA

1. CALCULATE NPSHA FOR MODE "A-1" (REF. 1)Operating Conditions

Flow = 10,150 gpm

Temperature = 170°F

Specific Weight @ 170°F = 60.79 lb/ft<sup>3</sup> (Ref 7)

Minimum Suppression Pool W.L. Depth = 18.04 ft (Ref 2)

Minimum Suppression Pool W.L. Elevation = 199'-11½" (Ref 2)

Pressure @ Suppression Pool = 14.7 psia (Ref 1)

Vapor Pressure @ 170°F = 5.99 psia (Ref 7)

Pump Suction Elevation = 174.875 ft (Ref 3)

$$\text{NPSHA} = h_a - h_{vpa} + h_{st} - h_{fs}$$

where,

 $h_a$  = absolute pressure (in feet of liquid) on the surface of liquid supply level $h_{vpa}$  = head (in feet) corresponding to the vapor pressure of the liquid being pumped $h_{st}$  = static head (in feet) of liquid above centerline of impeller eye $h_{fs}$  = suction line friction losses (in feet)Calculate Suction Line Losses ( $\Delta P$ )

$$\Delta P = 0.000216 \frac{f L \rho Q^2}{d^5} \quad (\text{Ref 5})$$

where,

 $\Delta P$  = friction losses, psi $Q$  = flow, gpm $L$  = length of pipe, ft $d$  = internal diameter of pipe, inches $\rho$  = weight density of fluid, lb/ft<sup>3</sup> $f$  = friction factor

Reynolds Number of Flow in Pipe

$$Re = 50.6 \frac{Q \rho}{d \mu} \quad (\text{Ref 5})$$

where,

$\mu$  = absolute (dynamic) viscosity in centipoise = 0.4 @ 170 °F (Ref 5)

 $\Delta P$  @ 24" Line

$$Re = \frac{(50.6)(10,150)(60.79)}{(23.25)(0.4)} = 3.35 \times 10^6$$

$\epsilon/D$  (Relative Pipe Roughness)

Use Cast Iron Pipe to account for Pipe Aging  
24" DIA, Cast Iron Pipe = 0.0004 (Ref 5)

$f = 0.016$  (Ref 5)

$$\Delta P_{24"} = 0.000216 \frac{(0.016)(474.5)(60.79)(10150)^2}{(23.25)^5}$$

$$= 1.51 \text{ psi}$$

 $\Delta P$  @ 30" Line

$$Re = \frac{(50.6)(10,150)(60.79)}{(29.25)(0.4)} = 2.66 \times 10^6$$

$\epsilon/D$  (Relative Pipe Roughness)

Use Cast Iron Pipe to account for Pipe Aging  
30" DIA, Cast Iron Pipe = 0.00034 (Ref 5)

$f = 0.015$  (Ref 5)

$$\Delta P_{30"} = 0.000216 \frac{(0.015)(152)(60.79)(10150)^2}{(29.25)^5}$$

$$= 0.144 \text{ psi}$$

ΔP of Suction Strainer

Dirty  $\Delta P$  @ 11,000 gpm @ 180°F = 7.11 ft (Ref 13)

For Mode A-1 the strainer  $\Delta P$  @ 10,150 gpm @ 170°F is needed.

The 10°F difference in temperature between Mode A-1 conditions and Reference 13 is addressed in the note on page 24.

The dirty strainer  $\Delta P$  given in Reference 13 consists of normal system losses and bed losses (the layer of debris consisting of fiber and corrosion products). When adjusting the  $\Delta P$  for various flow rates the system losses are proportional to the square of the flow rates , while the bed losses have a linear relationship to the flow rates (Reference 14).

From Reference 13 the actual system losses are 2.85 ft and the bed losses are 4.26 ft @ 11,000 gpm @ 180°F.

Therefore, the dirty  $\Delta P$  @ 10,150 gpm @ 180°F is:

$$(2.85 \text{ ft})\left(\frac{10,150}{11,000}\right)^2 + (4.26 \text{ ft})\left(\frac{10,150}{11,000}\right) = 6.36 \text{ ft H}_2\text{O}$$

Total Suction Line Friction Losses

$$h_{fs} = \Delta P_{24^\circ} + \Delta P_{30^\circ} + \Delta P_{\text{STRAINER}}$$

$$h_{fs} = (1.51 + 0.144)(144/60.79) + 6.36 = 10.28 \text{ ft H}_2\text{O}$$

Static Head

$$h_{st} = \text{Min W.L. @ Suppression Pool - Elevation @ Center Line of Pump Suction Nozzle}$$

$$h_{st} = 199.96 \text{ ft} - 174.875 \text{ ft} = 25.085 \text{ ft}$$

MODE A-1 NPSHA

$$\text{NPSHA} = h_a - h_{vpa} + h_{st} - h_{fs}$$

$$\text{NPSHA} = (14.7 - 5.99)(144/60.79) + 25.085 - 10.28 = 35.44 \text{ ft H}_2\text{O}$$

RHR Pump NPSHR @ 10,150 gpm = 5 ft H<sub>2</sub>O (Ref 10)

NPSHA > NPSHR

NOTE - the dirty strainer  $\Delta P$  used is for 180°F. Based on Reference 14 the strainer  $\Delta P$  will be slightly greater at 170°F (from 180°F to 100°F the strainer  $\Delta P$  only increases by approximately 2 ft). Since the NPSHA @ 180°F is greater than the NPSHR by approximately 30 ft the slight increase in strainer  $\Delta P$  from 180°F to 170°F will not result in the NPSHA being less than the NPSHR for Mode A-1.

2. CALCULATE NPSHA FOR MODE "A-2" (REF. 1)Operating Conditions

Flow = 11,000 gpm

Temperature = 180°F

Specific Weight @ 180°F = 60.57 lb/ft<sup>3</sup> (Ref 7)Specific Weight @ 212°F = 59.81 lb/ft<sup>3</sup> (Ref 7)

Minimum Suppression Pool W.L. Depth = 18.04 ft (Ref 2)

Minimum Suppression Pool W.L. Elevation = 199'-11½" (Ref 2)

Pressure @ Suppression Pool = 14.7 psia (Ref 1)

Vapor Pressure @ 180°F = 7.511 psia (Ref 7)

Pump Suction Elevation = 174.875 ft (Ref 3)

NOTE: Equations for NPSHA,  $\Delta P$ , and Reynolds Number are defined in the section of this calculation evaluating Mode A-1 (see page 21 and page 22).

 $\Delta P$  @ 24" Line

$\mu$  = absolute (dynamic) viscosity in centipoise = 0.35 @ 180°F (Ref 5)

$$Re = \frac{(50.6)(11,000)(60.57)}{(23.25)(0.35)} = 4.14 \times 10^6$$

$\epsilon/D$  (Relative Pipe Roughness)

Use Cast Iron Pipe to account for pipe aging.

24" DIA, Cast Iron Pipe = 0.0004 (Ref 5)

f = 0.016 (Ref 5)

$$\Delta P_{24"} = 0.000216 \frac{(0.016)(474.5)(60.57)(11000)^2}{(23.25)^5}$$

$$= 1.77 \text{ psi}$$

 $\Delta P$  @ 30" Line

$$Re = \frac{(50.6)(11,000)(60.57)}{(29.25)(0.35)} = 3 \times 10^6$$

$\epsilon/D$  (Relative Pipe Roughness)

Use Cast Iron Pipe to account for pipe aging.

30" DIA, Commercial Steel Pipe = 0.00034 (Ref 5)

f = 0.015 (Ref 5)

$$\Delta P_{30^\circ} = 0.000216 \frac{(0.015)(152)(60.57)(11000)^2}{(29.25)^5}$$

$$= 0.169 \text{ psi}$$

 $\Delta F$  of Suction Strainer

Actual Dirty  $\Delta P$  @ 11,000 gpm @ 180°F = 7.11 ft H<sub>2</sub>O (Ref 13)

Maximum Allowable Dirty  $\Delta P$  @ 11,000 gpm @ 212°F = 12 ft H<sub>2</sub>O (Ref 11 and Ref 13)  
 Converted to 180°F = (12)(59.81/60.57) = 11.85 ft H<sub>2</sub>O

Total Suction Line Friction Losses

$$h_{fs} = \Delta P_{24^\circ} + \Delta P_{30^\circ} + \Delta P_{\text{STRAINER}}$$

Based on Actual Strainer Dirty  $\Delta P$ :

$$h_{fs} = (1.77 + 0.169)(144/60.57) + 7.11 = 11.72 \text{ ft H}_2\text{O}$$

Based on Maximum Allowable Strainer Dirty  $\Delta P$ :

$$h_{fs} = (1.77 + 0.169)(144/60.57) + 11.85 = 16.46 \text{ ft H}_2\text{O}$$

Static Head

$h_{st}$  = Min W.L. @ Suppression Pool - Elevation @ Center Line of Pump Suction Nozzle

$$h_{st} = 199.96 \text{ ft} - 174.875 \text{ ft} = 25.085 \text{ ft}$$

MODE A-2 NPSHA

$$\text{NPSHA} = h_a - h_{vpa} + h_{st} - h_{fs}$$

NPSHA Based on Actual Strainer Dirty  $\Delta P$ =

$$(14.7 - 7.511)(144/60.57) + 25.085 - 11.72 = 30.46 \text{ ft H}_2\text{O}$$

NPSHA Based on Maximum Allowable Strainer Dirty  $\Delta P$ =

$$(14.7 - 7.511)(144/60.57) + 25.085 - 16.46 = 25.72 \text{ ft H}_2\text{O}$$

RHR Pump NPSHR @ 11,000 gpm = 6 ft H<sub>2</sub>O (Ref 10)

NPSHA > NPSHR

3. CALCULATE NPSHA FOR MODE "B" (REF. 1)Operating Conditions

Flow = 10,000 gpm

Temperature = 212°F

Specific Weight @ 212°F = 59.81 lb/ft<sup>3</sup> (Ref 7)

Minimum Suppression Pool W.L. Depth = 18.04 ft (Ref 2)

Minimum Suppression Pool W.L. Elevation = 199'-11½" (Ref 2)

Pressure @ Suppression Pool = 14.7 psia (Ref 1)

Vapor Pressure @ 212°F = 14.696 psia (Ref 7)

Pump Suction Elevation = 174.875 ft (Ref 3)

NOTE: Equations for NPSHA, ΔP, and Reynolds Number are defined in the section of this calculation evaluating Mode A-1 (see page 21 and page 22).

ΔP @ 24" Line

$\mu$  = absolute (dynamic) viscosity in centipoise = 0.29 @ 212°F (Ref 5)

$$Re = \frac{(50.6)(10,000)(59.81)}{(23.25)(0.29)} = 4.49 \times 10^6$$

$\epsilon/D$  (Relative Pipe Roughness)

Use Cast Iron Pipe to account for pipe aging.

24" DIA, Cast Iron Pipe = 0.0004 (Ref 5)

f = 0.016 (Ref 5)

$$\Delta P_{24"} = 0.000216 \frac{(0.016)(474.5)(59.81)(10,000)^2}{(23.25)^5}$$

$$= 1.44 \text{ psi}$$

ΔP @ 30" Line

$$Re = \frac{(50.6)(10,000)(59.81)}{(29.25)(0.29)} = 3.57 \times 10^6$$

$\epsilon/D$  (Relative Pipe Roughness)

Use Cast Iron Pipe to account for pipe aging.

30" DIA, Commercial Steel Pipe = 0.00034 (Ref 5)

f = 0.015 (Ref 5)

$$\Delta P_{30''} = 0.000216 \frac{(0.015)(152)(59.81)(10,000)^2}{(29.25)^5}$$

$$= 0.138 \text{ psi}$$

ΔP of Suction Strainer

Maximum Allowable Dirty ΔP @ 212.5 °F @ 11,000 gpm = 12 ft H<sub>2</sub>O (Ref 11 and Ref 13)

For Mode B the strainer pressure drop @ 212 °F @ 10,000 gpm is needed.

The ΔP associated with the strainer consists of normal system losses and bed losses (the layer of debris consisting of fiber and corrosion products). When adjusting the ΔP for various flow rates the system losses are proportional to the square of the flow rates while the bed losses have a linear relationship to the flow rates (Ref 14).

From Reference 13 the actual system losses are 2.85 ft @ 213 °F @ 11,000 gpm. Therefore it is assumed the maximum specified dirty ΔP of 12 ft from Reference 11 allows for 9.15 ft for bed losses.

Therefore the Maximum Dirty ΔP @ 212 °F @ 10,000 gpm is:

$$(2.85 \text{ ft})\left(\frac{10,000}{11,000}\right)^2 + (9.15 \text{ ft})\left(\frac{10,000}{11,000}\right) = 10.67 \text{ ft } H_2O$$

NOTE: The strainer ΔP obtained from Reference 11 is based on 212.5 °F and 11,000 gpm. The actual system losses obtained from Reference 13 is based on 213 °F and 11,000 gpm. The Mode B operating temperature is 212 °F (Reference 1). The difference in temperature is considered negligible based on the insignificant change in water properties between 212 °F, 212.5 °F, and 213 °F which would have no impact on NPSHA.

Total Suction Line Friction Losses

$$h_{fs} = \Delta P_{24''} + \Delta P_{30''} + \Delta P_{STRAINER}$$

$$h_{fs} = (1.44 + 0.138)(144/59.81) + 10.67 \text{ ft} = 14.47 \text{ ft } H_2O$$

Static Head

$h_{st}$  = Min W.L. @ Suppression Pool - Elevation @ Center Line of Pump Suction Nozzle

$$h_{st} = 199.96 \text{ ft} - 174.875 \text{ ft} = 25.085 \text{ ft}$$

MODE B NPSHA

$$\text{NPSHA} = h_s - h_{vpe} + h_{st} - h_{fs}$$

$$\text{NPSHA} = (14.7 - 14.7)(144/59.81) + 25.085 - 14.47 = 10.62 \text{ ft H}_2\text{O}$$

RHR Pump NPSHR @ 10,000 gpm = 5 ft H<sub>2</sub>O (Ref 10)

NPSHA > NPSHR

The GE RHR Process Diagram (Reference 1) requires the NPSHA at the pump suction nozzle to be  $\geq 10.3$  ft plus the difference in elevation between a reference location and the centerline of the pump suction nozzle. Reference 1 defines the reference location as 2 ft above the pump mounting flange. From Reference 12, the RHR pump mounting flange is at Elevation 177 ft. Therefore, based on the requirements of Reference 1, the NPSHA must be  $\geq 14.43$  ft ( $177 + 2 - 174.875 + 10.3$ ). From above, the RHR piping arrangement only provides 10.62 ft. Although the NPSHA does not meet the generic design requirements specified in Reference 1, NPSHA is considered acceptable based on the actual as-built pump vendor requirements in accordance with Reference 10.

#### 4. NPSHA Margin For Mode B Based On Actual Dirty Strainer ΔP

The RHR System operating in Mode B is the limiting accident mode for NPSH, therefore the NPSHA margin based on the Actual dirty strainer  $\Delta P$  will be based on Mode B conditions.

RHR Mode B NPSHA = 10.62 ft H<sub>2</sub>O @ 10,000 gpm @ 212 °F (page 29 of this calculation)

The above NPSHA is based on the maximum allowable  $\Delta P$  for the new large capacity passive strainers. The purpose of this calculation is to determine the NPSH margin based on the actual dirty strainer  $\Delta P$ . Therefore, the above NPSHA will be adjusted to obtain the NPSHA based on the actual dirty strainer  $\Delta P$ :

$$\text{NPSHA}_{\text{Actual Dirty}} = \text{NPSHA}_{\text{Page 29}} + \text{Maximum Allowable Dirty Strainer } \Delta P - \text{Actual Dirty Strainer } \Delta P$$

Maximum Allowable Dirty Strainer  $\Delta P$  @ 10,000 gpm @ 212 °F = 10.67 ft H<sub>2</sub>O (Page 28)

The Actual Dirty Strainer  $\Delta P$  is obtained from Table 3 of Reference 11:

Actual Dirty Strainer  $\Delta P$  @ 11,000 gpm @ 213 °F = Strainer System Losses + Strainer Bed Losses

Actual Dirty Strainer  $\Delta P$  @ 11,000 gpm @ 213 °F = 2.85 ft + 3.75 ft = 6.60 ft H<sub>2</sub>O

NOTE: The Actual Dirty Strainer  $\Delta P$  obtained from Reference 13 is based on 213 °F, however the actual Mode B temperature is 212 °F. This 1 °F difference is considered to have an insignificant affect on the strainer  $\Delta P$  based on the insignificant change in water properties from 212 °F to 213 °F.

Adjusting Actual Dirty Strainer  $\Delta P$  adjusted to 10,000 gpm:

As previously stated the actual dirty strainer  $\Delta P$  consists of strainer system losses and strainer bed losses. From Reference 14 the system losses are proportional to the square of the flow rates while the bed losses have a linear relationship to the flow rates.

Therefore the Actual Dirty Strainer  $\Delta P$  adjusted to 10,000 gpm:

$$(2.85 \text{ ft})\left(\frac{10,000}{11,000}\right)^2 + (3.75 \text{ ft})\left(\frac{10,000}{11,000}\right) = 5.76 \text{ ft H}_2\text{O}$$

Therefore,

$$\text{NPSHA}_{\text{Actual Dirty}} = 10.62 \text{ ft} + 10.67 \text{ ft} - 5.76 \text{ ft} = 15.53 \text{ ft H}_2\text{O}$$

Determine NPSHA Margin:

$$\text{NPSHA Margin} = \text{NPSHA}_{\text{Actual Dirty}} - \text{NPSHR}$$

NPSHR = 5 ft H<sub>2</sub>O @ 10,000 gpm (Reference 10)

Therefore,

$$\text{NPSHA Margin} = 15.53 \text{ ft} - 5 \text{ ft} = 10.53 \text{ ft H}_2\text{O}$$

Therefore, there is sufficient margin between the RHR Pump NPSHA and the NPSHR when considering the actual dirty strainer ΔP of the new large capacity passive strainers.