



Sunnyslope Water District

Annual Report

2020

Sunnyslope County Water District

3570 Airline Highway
Hollister, California 95023-9702

Phone (831) 637-4670
Fax (831) 637-1399

January 29, 2021

California Regional Water Quality Control Board
Central Coast Region
Attn: Monitoring and Reporting Review Section
895 Aerovista Pl Ste 101
San Luis Obispo CA 93401-8725

RE: Ridgemark Estates Wastewater Treatment Facilities – Annual Monitoring Report


Dear Review Section,

Enclosed please find the Sunnyslope County Water Districts 2020 Fourth Quarter Monitoring Report and the 2020 Annual Wastewater Report for Ridgemark Estates Wastewater Treatment Facilities WDR R3-2004-0065 in a searchable PDF Format.

- ◆ 2020 Fourth Quarter Monitoring Report
- ◆ 2020 Annual Wastewater Report including,
- ◆ 2020 Annual Salt Management Report
- ◆ 2020 Annual Engineering Technical Report

If you have any questions, or need further information, please do not hesitate to contact this office.

Sincerely



Drew A. Lander; P.E.
General Manager

DAL/jjr



January 29, 2021

California Regional Water Quality Control Board
Central Coast Region
Attn: Monitoring and Reporting Review Section
895 Aerovista Place, Suite 101
San Luis Obispo, CA 93401

Dear Monitoring and Reporting Review Section:

Facility Name: Sunnyslope County Water District
Ridgemark Estates Subdivision

Address: 3570 Airline Highway
Hollister, CA 95023

Contact Person: Drew A. Lander P.E.
Job Title: General Manager
Phone Number: 831-637-4670

**WDR/NPDES
Order Number:** WDR R3-2004-0065

WDID Number: _____

Type of Report (circle one): Monthly Quarterly Semi-Annual Annual

Month(s) (circle applicable months*): JAN FEB MAR APR MAY JUN

JUL AUG SEP OCT NOV DEC

*Annual Reports (circle the first month of the reporting period)

Year: 2020

Violation(s)

(Place an X by the appropriate choice): No (there are no violations to report)
 Yes (If Yes is marked (complete a-g))

a) Parameter(s) in Violation: **RMI SBR:** Sodium, Chloride

**b) Section(s) of WDR/NPDES
Violated:** **RMI SBR:** Section B) item 2, Table 6
6=Sodium, Chloride

c) Reported Value(s): **RMI SBR:** Sodium - 220, 230
Chloride - 260, 230, 240, 260,
240, 250, 280, 255, 270,
310, 280, 270

**d) WDR/NPDES
Limit/Condition:** **RMI SBR:** Sodium - 200
Chloride - 200

e) Dates of Violations(s)

(reference page of report/data sheet): **RMI SBR:** Sodium - 09/20, 10/20
Chloride- 01/20, 2/20, 3/20, 4/20, 5/20,
6/20, 7/20, 8/20, 9/20, 10/20, 11/20,
12/20

Data Sheet – RMI SBR Effluent Monitoring

f) Explanation of Cause(s):

Chlorides and Sodium,

The Hollister Urban Area Water Plan (HUAWP) has been completed and included the upgrade of the existing Lessalt Water Treatment Plant and the construction of a new surface water treatment plant called the West Hills Water Treatment Plant. These two facilities, associated pipelines, and pump stations will allow high quality drinking water to be delivered throughout the Hollister Urban Area. Sunnyslope County Water District (SSCWD) has meet all other discharge requirements, yet it has not been able to meet the discharge requirements for chlorides due to the continued use of brine discharging water softeners within the district. Sodium levels where exceeded in the month of September and October due to water quality and minor maintenance issues at the Lessalt Water Treatment Facility. Those issues caused the Lessalt Water Treatment Facility to be off for half of the month. Sequentially the districts wells operated longer than anticipated causing higher salinity water throughout the districts distribution system.

g) Corrective Actions(s):


Chlorides and Sodium

Sunnyslope continues to make progress with meeting the salinity requirements of the WDRs. The addition of higher quality surface water deliveries to customers, providing rebates for the removal of salt discharging water softeners, and adopting an ordinance banning the installation of new salt discharging water softeners is bringing the District closer to compliance. The District is in compliance for Sodium annual rolling average. As previously stated, the wells where operated for extended periods of time causing higher Sodium levels in the previous mentioned months. The surface waters facility is now back in operation, which has brought down those levels in the subsequent months. The District will continue its outreach and education of customers in partnership with the City of Hollister and San Benito County Water District to promote the improvement of drinking water quality and the removal of salt discharging water softeners which will further help in meeting salinity requirements.


In accordance with the Standard Provisions and Reporting Requirements, I certify under penalty of law that this document and all attachments were prepared under my direction or supervision following a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my knowledge of the person(s) who manage the system, or those directly responsible for data gathering, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

If you have any questions or require additional information, please contact me at the number provided above.

Sincerely,



Drew A Lander P.E.
General Manager



Jose J. Rodriguez
Water/Wastewater Superintendent
Chief Plant Operator

California Regional Water Quality Control Board
Central Coast Region
895 Aerovista Place, Suite 101
San Luis Obsipo, CA 93401

Document
Date: 1/29/2021

Submit this Self Monitoring Report to: centralcoast@waterboards.ca.gov

FACILITY NAME: RidgeMark Estates Wastewater

FACILITY ADDRESS: 10 Georges Dr.
Hollister CA 95023

CONTACT PERSON: Jose J. Rodriguez

JOB TITLE: Water/Wastewater Superintendent

PHONE NUMBER: 831-637-4670

EMAIL: jose@sscwd.org

WDR ORDER (Permit) Number: WDR# R3-2004-0065

WDID NUMBER: _____

PERMITTED FLOW (see facility WDR Permit): 370,000 gpd

AVERAGE WASTEWATER FLOW (over monitoring period): 167,226 gpd

TYPE OF REPORT: Annual Semiannual Quarterly
 Monthly Other: _____

REPORTING PERIOD: 1-1-2020 TO 12-31-2020

MONITORING PERFORMED DURING THIS PERIOD (check all that apply):

Groundwater Lab Reports Recycled Water
 Treatment System Effluent Solids Disposal Disposal Area
 Treatment System Influent Water Supply Use Area
 Source Water Monitoring Other: _____

Violation(s) during this monitoring period? YES NO

Parameter(s) in Violation: Pursuant to Standard Provisions¹ see footnote on next page, monitoring reports must contain date of violation, explanation of cause and corrective actions planned or taken to prevent recurrence. Please include parameter(s) and date(s) of violation in space provided below. If space is insufficient, include an independent discussion containing explanation of cause and corrective action within monitoring report.

SSCWD has not been able to meet the discharge requirements for chlorides due to the continued use of brine discharging water softeners within the district. At times, Sodium levels are exceeded due to source water being the main water source in part of facility maintenance..

Discharger Comments:

Sunnyslope continues to make progress with meeting the salinity requirements of the WDRs. The District will continue its outreach and education of customers in partnership with the City of Hollister and San Benito County Water District to promote the improvement of drinking water quality and the removal of salt discharging water softeners.

Submit this self-monitoring report to centralcoast@waterboards.ca.gov in searchable PDF format. Include attached cover sheet and signature page. DO NOT submit via US mail.

In accordance with the Standard Provisions¹ and Reporting Requirements, I certify under penalty of law that this document and all attachments were prepared under my direction or supervision following a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my knowledge of the person(s) who manage the system, or those directly responsible for data gathering, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Print Name: Drew A. Lander

Title: General Manager

Signature: 

Date: 1/29/2021

*All reports shall be signed by one of the following:

- a. For a corporation: by a principle executive officer of at least the level of vice president.
- b. For a partnership or sole proprietorship: by a general partner or the proprietor, respectively.
- c. For a public agency: by either a principle executive officer or ranking elected official.
- d. For a LLC: either a member or manager given signing authority by the operating agreement of LLC.
- e. a "duly authorized representative" of one of the above.

¹ Electronic access to Standard Provisions: [https://www.waterboards.ca.gov/centralcoast/board decisions/docs/wdr standard provisions 2013.pdf](https://www.waterboards.ca.gov/centralcoast/board%20decisions/docs/wdr_standard_provisions_2013.pdf)



Sunnyslope Water District

Introduction

Sunnyslope County Water District

3570 Airline Highway
Hollister, California 95023-9702
Phone (831) 637-4670
Fax (831) 637-1399

Treatment Objectives

The main goal of the Ridgemark Area Wastewater Treatment is to meet a series of effluent quality criteria specified by a new WDR permit from the RWQCB. The permit requirements also apply to the RM II WWTP. The nature of these requirements required an upgrade to secondary treatment with biological nutrient removal. Table 1 summarizes the effluent water quality requirements for discharge.

Table 1 - RWQCB Discharge Requirements

Parameter	WDR Discharge Requirement
Nitrate as Nitrogen (mg/L) ^a	5
Ammonia as Nitrogen (mg/L)	5
BOD5 (mg/L)	30
TSS (mg/L)	30
pH	6.5 – 8.4
TDS (mg/L)	1,200
Sodium (mg/L)	200
Chloride (mg/L)	200

The first five parameters listed in Table 1 are standard wastewater treatment constituents that are addressed through biological/secondary treatment process. The secondary treatment process is a biochemical oxidation process that uses microorganism to stabilize organic matter, measured by a reduction in BOD. The secondary treatment process was also designed to remove nitrogen by converting ammonia to nitrate (nitrification) and then to nitrogen gas (denitrification) which is released to the atmosphere. TSS (including biomass) will settle out of the wastewater and are removed as a waste solids product.

Dissolved solids, sodium, and chloride were not addressed through the wastewater treatment improvements project but will instead be addressed through improvements to the potable water supply. Removal of dissolved solids and hardness from potable water will reduce the reliance on home water softeners. Through the regeneration process, water softeners discharge a concentrated solution of sodium chloride to the sewer system further increasing the concentrations at the wastewater treatment plant. The improvements in the potable water quality are expected to result in improved wastewater quality that will meet the WDR permit requirements for TDS, sodium, and chloride.

Sunnyslope County Water District


3570 Airline Highway
 Hollister, California 95023-9702
 Phone (831) 637-4670
 Fax (831) 637-1399

Sequence Batch Reactor

An SBR provides secondary treatment to remove BOD, TSS, and nitrogen to meet WDR effluent limitations. The SBR performs as an equalization, biological treatment, and secondary clarification in one basin compared to conventional processes with separate basins for each process. A typical SBR process includes multiple operational phases including mixed-fill, aerated-fill, reaction, settling, and decant. Figure 1 shows an example of the sequential phases of the SBR process.

Figure 1: SBR Cycle

Dual Mode 2-Basin NDN Normal Cycle: 288 minutes (4.8 hours)



The SBR system has been designed to meet the RWQCB WDR effluent limits allowing for disposal to the percolation ponds.

Existing Pond Disposal

The principal objective of pond disposal is to percolate secondary effluent into the ground. The historic RMK I site consisted of 5 ponds, labeled Pond 1 thru Pond 5. Pond 1 and Pond 2 were used as treatment ponds while Ponds 3-5 were used for disposal. A sixth pond 6 is located to the northwest of the facility and provides additional disposal. The wastewater treatment improvements constructed new treatment facilities in Pond 2 and a portion of Pond 3. A portion of Pond 3 can be used for percolation. Pond 4, Pond 5, and Pond 6 will continue to provide disposal capacity. Pond 1 is still filled with solids and is ultimately envisioned to be decommissioned and turned into a disposal pond.

Solids Storage Tank and Drying Bed

The solids generated by the SBR is transferred to the solids storage tank using a waste activated sludge (WAS) pump that discharge into a solids storage tank. The storage tank has a surface aerator and is operated like a facultative pond with an aerobic zone up top and an anaerobic zone below.

The concrete tank provides approximately 60 days of solids retention time at buildout flow (note: retention time is longer initially) allowed solids to be stored during the winter months when air drying in the drying beds would be minimal. Solids will settle from the fluid and the supernatant will be removed from the top of the basin through a decant mechanism while the solids will be removed from the bottom of the basin using a fixed pipe system that allow solids to be discharged to an adjoining pump well.

A vertical progressive cavity pump can then convey solids to the drying beds for air drying.

Sunnyslope County Water District

3570 Airline Highway
Hollister, California 95023-9702
Phone (831) 637-4670
Fax (831) 637-1399

As acknowledged in the Waste Discharge Requirement Order R3-2004-0065 the Ridgemark Estate Subdivision Wastewater Treatment Plant is a sequencing batch reactor (SBR) facility which can treat up to 370,000 gallons per day. The SBR process allows the unit processes of react, settle, and discharge to occur sequentially in one basin. The treated effluent is discharged into one of four percolation ponds. The wastewater facility limits and parameters are:

ADWF (Average Day Flow)	-	370,000 gpd
Maximum Day Flow	-	430,000 gpd
PDWF	-	725,156 gpd
PWWF (Peak 3 Hour Flow*)	-	967,000 gpd
Design BODs Cone. (at 20°C)	-	338 mg/L
Design BOD Loading	-	987 lbs./day
Design TSS Cone.	-	338 mg/L
Design TSS Loading	-	987 lb./day
Design TKN Cone.	-	54 mg/L
Design TKN Loading	-	158 lb./day
Alkalinity required (minimum)	-	159 mg/L
Wastewater Temperature, Min	-	16 °C
Wastewater Temperature, Max	-	20 °C
Ambient Air Temperature	-	0 to 32 °C
pH Range	-	6.5 to 8.5 SU
Site Elevation - above sea level	-	520 ft



Sunnyslope Water District

Section A

Data Tables and Graphs



SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # 3 35100001
Discharge Self-Monitoring Report
Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision Wastewater Treatment Plant

Sequencing Batch Reactor (SBR) INFLUENT MONITORING

DATE	RM # 1 SBR		RM # 2		COMBINED
	DAILY FLOW METERED GPD	30 Day Running Average GPD	DAILY FLOW METERED GPD	30 Day Running Average GPD	30 Day Running Average GPD
January 1, 2020	158,000	155,233	Flowing to RM 1 SBR for Treatment		
January 2, 2020	151,000	155,333	Flowing to RM 1 SBR for Treatment		
January 3, 2020	145,000	155,300	Flowing to RM 1 SBR for Treatment		
January 4, 2020	155,000	155,200	Flowing to RM 1 SBR for Treatment		
January 5, 2020	172,000	155,700	Flowing to RM 1 SBR for Treatment		
January 6, 2020	147,000	156,967	Flowing to RM 1 SBR for Treatment		
January 7, 2020	139,000	156,700	Flowing to RM 1 SBR for Treatment		
January 8, 2020	149,000	155,333	Flowing to RM 1 SBR for Treatment		
January 9, 2020	134,000	155,467	Flowing to RM 1 SBR for Treatment		
January 10, 2020	143,000	155,233	Flowing to RM 1 SBR for Treatment		
January 11, 2020	158,000	155,233	Flowing to RM 1 SBR for Treatment		
January 12, 2020	179,000	155,900	Flowing to RM 1 SBR for Treatment		
January 13, 2020	146,000	156,633	Flowing to RM 1 SBR for Treatment		
January 14, 2020	144,000	157,000	Flowing to RM 1 SBR for Treatment		
January 15, 2020	149,000	155,767	Flowing to RM 1 SBR for Treatment		
January 16, 2020	155,000	155,067	Flowing to RM 1 SBR for Treatment		
January 17, 2020	127,000	156,333	Flowing to RM 1 SBR for Treatment		
January 18, 2020	150,000	155,433	Flowing to RM 1 SBR for Treatment		
January 19, 2020	170,000	155,800	Flowing to RM 1 SBR for Treatment		
January 20, 2020	159,000	156,133	Flowing to RM 1 SBR for Treatment		
January 21, 2020	141,000	156,400	Flowing to RM 1 SBR for Treatment		
January 22, 2020	140,000	155,733	Flowing to RM 1 SBR for Treatment		
January 23, 2020	138,000	155,067	Flowing to RM 1 SBR for Treatment		
January 24, 2020	140,000	152,833	Flowing to RM 1 SBR for Treatment		
January 25, 2020	149,000	151,767	Flowing to RM 1 SBR for Treatment		
January 26, 2020	181,000	150,833	Flowing to RM 1 SBR for Treatment		
January 27, 2020	148,000	151,733	Flowing to RM 1 SBR for Treatment		
January 28, 2020	140,000	151,267	Flowing to RM 1 SBR for Treatment		
January 29, 2020	140,000	150,100	Flowing to RM 1 SBR for Treatment		
January 30, 2020	141,000	149,900	Flowing to RM 1 SBR for Treatment		
January 31, 2020	145,000	149,600	Flowing to RM 1 SBR for Treatment		
February 1, 2020	160,000	149,167	Flowing to RM 1 SBR for Treatment		
February 2, 2020	172,000	149,467	Flowing to RM 1 SBR for Treatment		
February 3, 2020	153,000	150,367	Flowing to RM 1 SBR for Treatment		
February 4, 2020	146,000	150,300	Flowing to RM 1 SBR for Treatment		
February 5, 2020	141,000	149,433	Flowing to RM 1 SBR for Treatment		
February 6, 2020	149,000	149,233	Flowing to RM 1 SBR for Treatment		
February 7, 2020	124,000	149,567	Flowing to RM 1 SBR for Treatment		
February 8, 2020	152,000	148,733	Flowing to RM 1 SBR for Treatment		
February 9, 2020	181,000	149,333	Flowing to RM 1 SBR for Treatment		
February 10, 2020	145,000	150,600	Flowing to RM 1 SBR for Treatment		
February 11, 2020	151,000	150,167	Flowing to RM 1 SBR for Treatment		
February 12, 2020	134,000	149,233	Flowing to RM 1 SBR for Treatment		
February 13, 2020	152,000	148,833	Flowing to RM 1 SBR for Treatment		
February 14, 2020	128,000	149,100	Flowing to RM 1 SBR for Treatment		
February 15, 2020	146,000	148,400	Flowing to RM 1 SBR for Treatment		
February 16, 2020	152,000	148,100	Flowing to RM 1 SBR for Treatment		
February 17, 2020	157,000	148,933	Flowing to RM 1 SBR for Treatment		
February 18, 2020	146,000	149,167	Flowing to RM 1 SBR for Treatment		
February 19, 2020	138,000	148,367	Flowing to RM 1 SBR for Treatment		
February 20, 2020	140,000	147,667	Flowing to RM 1 SBR for Treatment		
February 21, 2020	133,000	147,633	Flowing to RM 1 SBR for Treatment		
February 22, 2020	147,000	147,400	Flowing to RM 1 SBR for Treatment		
February 23, 2020	174,000	147,700	Flowing to RM 1 SBR for Treatment		
February 24, 2020	148,000	148,833	Flowing to RM 1 SBR for Treatment		
February 25, 2020	136,000	148,800	Flowing to RM 1 SBR for Treatment		
February 26, 2020	130,000	147,300	Flowing to RM 1 SBR for Treatment		
February 27, 2020	137,000	146,700	Flowing to RM 1 SBR for Treatment		
February 28, 2020	133,000	146,600	Flowing to RM 1 SBR for Treatment		
February 29, 2020	151,000	146,367	Flowing to RM 1 SBR for Treatment		
March 1, 2020	179,000	146,700	Flowing to RM 1 SBR for Treatment		
March 2, 2020	147,000	147,833	Flowing to RM 1 SBR for Treatment		
March 3, 2020	141,000	147,400	Flowing to RM 1 SBR for Treatment		
March 4, 2020	140,000	146,367	Flowing to RM 1 SBR for Treatment		
March 5, 2020	154,000	145,933	Flowing to RM 1 SBR for Treatment		
March 6, 2020	131,000	146,200	Flowing to RM 1 SBR for Treatment		
March 7, 2020	150,000	145,867	Flowing to RM 1 SBR for Treatment		
March 8, 2020	177,000	145,900	Flowing to RM 1 SBR for Treatment		
March 9, 2020	152,000	147,667	Flowing to RM 1 SBR for Treatment		
March 10, 2020	149,000	147,667	Flowing to RM 1 SBR for Treatment		
March 11, 2020	154,000	146,600	Flowing to RM 1 SBR for Treatment		
March 12, 2020	141,000	146,900	Flowing to RM 1 SBR for Treatment		
March 13, 2020	144,000	146,567	Flowing to RM 1 SBR for Treatment		
March 14, 2020	171,000	146,900	Flowing to RM 1 SBR for Treatment		
March 15, 2020	187,000	147,533	Flowing to RM 1 SBR for Treatment		
March 16, 2020	144,000	149,500	Flowing to RM 1 SBR for Treatment		
March 17, 2020	165,000	149,433	Flowing to RM 1 SBR for Treatment		
March 18, 2020	158,000	149,867	Flowing to RM 1 SBR for Treatment		
March 19, 2020	158,000	149,900	Flowing to RM 1 SBR for Treatment		
March 20, 2020	169,000	150,300	Flowing to RM 1 SBR for Treatment		
March 21, 2020	155,000	151,333	Flowing to RM 1 SBR for Treatment		
March 22, 2020	171,000	151,833	Flowing to RM 1 SBR for Treatment		
March 23, 2020	169,000	153,100	Flowing to RM 1 SBR for Treatment		
March 24, 2020	156,000	153,833	Flowing to RM 1 SBR for Treatment		
March 25, 2020	154,000	153,233	Flowing to RM 1 SBR for Treatment		
March 26, 2020	161,000	153,433	Flowing to RM 1 SBR for Treatment		
March 27, 2020	163,000	154,267	Flowing to RM 1 SBR for Treatment		
March 28, 2020	158,000	155,367	Flowing to RM 1 SBR for Treatment		
March 29, 2020	175,000	156,067	Flowing to RM 1 SBR for Treatment		
March 30, 2020	172,000	157,467	Flowing to RM 1 SBR for Treatment		
March 31, 2020	155,000	156,167	Flowing to RM 1 SBR for Treatment		

127,000	Daily Flow Minimum GPD
181,000	Daily Flow Maximum GPD
149,452	Daily Flow Average GPD
4,633,000	Total Monthly Flow Gallons

-	Daily Flow Minimum GPD
-	Daily Flow Maximum GPD
-	Daily Flow Average GPD
-	Total Monthly Flow Gallons

-	Daily Flow Maximum GPD
---	------------------------

GPD	Daily Flow Limit
300,000	May through October
310,000	November through April

124,000	Daily Flow Minimum GPD
181,000	Daily Flow Maximum GPD
146,759	Daily Flow Average GPD
4,256,000	Total Monthly Flow Gallons

-	Daily Flow Minimum GPD
-	Daily Flow Maximum GPD
-	Daily Flow Average GPD
-	Total Monthly Flow Gallons

-	Daily Flow Maximum GPD
---	------------------------

GPD	Daily Flow Limit
300,000	May through October
310,000	November through April

131,000	Daily Flow Minimum GPD
187,000	Daily Flow Maximum GPD
158,065	Daily Flow Average GPD
4,900,000	Total Monthly Flow Gallons

-	Daily Flow Minimum GPD
-	Daily Flow Maximum GPD
-	Daily Flow Average GPD
-	Total Monthly Flow Gallons

-	Daily Flow Maximum GPD
---	------------------------

GPD	Daily Flow Limit
300,000	May through October
310,000	November through April



SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # 3 351000001
Discharge Self-Monitoring Report
Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision Wastewater Treatment Plant

Sequencing Batch Reactor (SBR) INFLUENT MONITORING

DATE	RM # 1 SBR		RM # 2		COMBINED
	DAILY FLOW METERED GPD	Running Average GPD	DAILY FLOW METERED GPD	Running Average GPD	Running Average GPD
July 1, 2020	163,000	161,767	Flowing to RM I SBR for Treatment		
July 2, 2020	166,000	162,033	Flowing to RM I SBR for Treatment		
July 3, 2020	162,000	162,233	Flowing to RM I SBR for Treatment		
July 4, 2020	170,000	162,333	Flowing to RM I SBR for Treatment		
July 5, 2020	168,000	162,667	Flowing to RM I SBR for Treatment		
July 6, 2020	165,000	163,100	Flowing to RM I SBR for Treatment		
July 7, 2020	154,000	162,933	Flowing to RM I SBR for Treatment		
July 8, 2020	164,000	161,900	Flowing to RM I SBR for Treatment		
July 9, 2020	161,000	162,067	Flowing to RM I SBR for Treatment		
July 10, 2020	169,000	162,300	Flowing to RM I SBR for Treatment		
July 11, 2020	170,000	162,833	Flowing to RM I SBR for Treatment		
July 12, 2020	164,000	162,967	Flowing to RM I SBR for Treatment		
July 13, 2020	162,000	163,200	Flowing to RM I SBR for Treatment		
July 14, 2020	155,000	163,100	Flowing to RM I SBR for Treatment		
July 15, 2020	165,000	162,533	Flowing to RM I SBR for Treatment		
July 16, 2020	158,000	162,800	Flowing to RM I SBR for Treatment		
July 17, 2020	162,000	162,800	Flowing to RM I SBR for Treatment		
July 18, 2020	166,000	162,867	Flowing to RM I SBR for Treatment		
July 19, 2020	171,000	163,267	Flowing to RM I SBR for Treatment		
July 20, 2020	161,000	163,933	Flowing to RM I SBR for Treatment		
July 21, 2020	160,000	163,867	Flowing to RM I SBR for Treatment		
July 22, 2020	157,000	163,267	Flowing to RM I SBR for Treatment		
July 23, 2020	155,000	163,100	Flowing to RM I SBR for Treatment		
July 24, 2020	152,000	163,033	Flowing to RM I SBR for Treatment		
July 25, 2020	164,000	162,867	Flowing to RM I SBR for Treatment		
July 26, 2020	187,000	163,200	Flowing to RM I SBR for Treatment		
July 27, 2020	162,000	164,267	Flowing to RM I SBR for Treatment		
July 28, 2020	158,000	164,000	Flowing to RM I SBR for Treatment		
July 29, 2020	161,000	163,333	Flowing to RM I SBR for Treatment		
July 30, 2020	170,000	163,133	Flowing to RM I SBR for Treatment		
July 31, 2020	145,000	163,400	Flowing to RM I SBR for Treatment		
August 1, 2020	166,000	162,800	Flowing to RM I SBR for Treatment		
August 2, 2020	181,000	162,800	Flowing to RM I SBR for Treatment		
August 3, 2020	160,000	163,433	Flowing to RM I SBR for Treatment		
August 4, 2020	156,000	163,100	Flowing to RM I SBR for Treatment		
August 5, 2020	161,000	162,700	Flowing to RM I SBR for Treatment		
August 6, 2020	160,000	162,567	Flowing to RM I SBR for Treatment		
August 7, 2020	192,000	162,767	Flowing to RM I SBR for Treatment		
August 8, 2020	141,000	163,700	Flowing to RM I SBR for Treatment		
August 9, 2020	175,000	163,033	Flowing to RM I SBR for Treatment		
August 10, 2020	172,000	163,233	Flowing to RM I SBR for Treatment		
August 11, 2020	154,000	163,300	Flowing to RM I SBR for Treatment		
August 12, 2020	173,000	162,967	Flowing to RM I SBR for Treatment		
August 13, 2020	157,000	163,333	Flowing to RM I SBR for Treatment		
August 14, 2020	161,000	163,400	Flowing to RM I SBR for Treatment		
August 15, 2020	155,000	163,267	Flowing to RM I SBR for Treatment		
August 16, 2020	179,000	163,167	Flowing to RM I SBR for Treatment		
August 17, 2020	147,000	163,733	Flowing to RM I SBR for Treatment		
August 18, 2020	150,000	163,100	Flowing to RM I SBR for Treatment		
August 19, 2020	160,000	162,400	Flowing to RM I SBR for Treatment		
August 20, 2020	154,000	162,367	Flowing to RM I SBR for Treatment		
August 21, 2020	156,000	162,167	Flowing to RM I SBR for Treatment		
August 22, 2020	167,000	162,133	Flowing to RM I SBR for Treatment		
August 23, 2020	182,000	162,533	Flowing to RM I SBR for Treatment		
August 24, 2020	158,000	163,533	Flowing to RM I SBR for Treatment		
August 25, 2020	157,000	163,333	Flowing to RM I SBR for Treatment		
August 26, 2020	155,000	162,333	Flowing to RM I SBR for Treatment		
August 27, 2020	150,000	162,100	Flowing to RM I SBR for Treatment		
August 28, 2020	146,000	161,833	Flowing to RM I SBR for Treatment		
August 29, 2020	162,000	161,333	Flowing to RM I SBR for Treatment		
August 30, 2020	179,000	161,067	Flowing to RM I SBR for Treatment		
August 31, 2020	159,000	162,200	Flowing to RM I SBR for Treatment		
September 1, 2020	158,000	161,967	Flowing to RM I SBR for Treatment		
September 2, 2020	153,000	161,200	Flowing to RM I SBR for Treatment		
September 3, 2020	154,000	160,967	Flowing to RM I SBR for Treatment		
September 4, 2020	161,000	160,900	Flowing to RM I SBR for Treatment		
September 5, 2020	164,000	160,900	Flowing to RM I SBR for Treatment		
September 6, 2020	143,000	161,033	Flowing to RM I SBR for Treatment		
September 7, 2020	158,000	159,400	Flowing to RM I SBR for Treatment		
September 8, 2020	164,000	159,967	Flowing to RM I SBR for Treatment		
September 9, 2020	151,000	159,600	Flowing to RM I SBR for Treatment		
September 10, 2020	157,000	158,900	Flowing to RM I SBR for Treatment		
September 11, 2020	165,000	159,000	Flowing to RM I SBR for Treatment		
September 12, 2020	161,000	158,733	Flowing to RM I SBR for Treatment		
September 13, 2020	183,000	158,867	Flowing to RM I SBR for Treatment		
September 14, 2020	158,000	159,600	Flowing to RM I SBR for Treatment		
September 15, 2020	152,000	159,700	Flowing to RM I SBR for Treatment		
September 16, 2020	152,000	158,800	Flowing to RM I SBR for Treatment		
September 17, 2020	156,000	158,967	Flowing to RM I SBR for Treatment		
September 18, 2020	150,000	159,167	Flowing to RM I SBR for Treatment		
September 19, 2020	168,000	158,833	Flowing to RM I SBR for Treatment		
September 20, 2020	182,000	159,300	Flowing to RM I SBR for Treatment		
September 21, 2020	158,000	160,167	Flowing to RM I SBR for Treatment		
September 22, 2020	153,000	159,867	Flowing to RM I SBR for Treatment		
September 23, 2020	146,000	158,900	Flowing to RM I SBR for Treatment		
September 24, 2020	151,000	158,500	Flowing to RM I SBR for Treatment		
September 25, 2020	154,000	158,300	Flowing to RM I SBR for Treatment		
September 26, 2020	163,000	158,267	Flowing to RM I SBR for Treatment		
September 27, 2020	167,000	158,700	Flowing to RM I SBR for Treatment		
September 28, 2020	156,000	159,400	Flowing to RM I SBR for Treatment		
September 29, 2020	153,000	159,200	Flowing to RM I SBR for Treatment		
September 30, 2020	148,000	158,333	Flowing to RM I SBR for Treatment		

RMK1	
145,000	Daily Flow Minimum GPD
187,000	Daily Flow Maximum GPD
162,806	Daily Flow Average GPD
5,047,000	Total Monthly Flow Gallons

RMK2	
-	Daily Flow Minimum GPD
-	Daily Flow Maximum GPD
-	Daily Flow Average GPD
-	Total Monthly Flow Gallons

COMBINED 30 DAY RUNNING AVERAGE	
-	Daily Flow Maximum GPD

GPD Daily Flow Limit	
300,000	May through October
310,000	November through April

RMK1	
141,000	Daily Flow Minimum GPD
192,000	Daily Flow Maximum GPD
162,097	Daily Flow Average GPD
5,025,000	Total Monthly Flow Gallons

RMK2	
-	Daily Flow Minimum GPD
-	Daily Flow Maximum GPD
-	Daily Flow Average GPD
-	Total Monthly Flow Gallons

COMBINED 30 DAY RUNNING AVERAGE	
-	Daily Flow Maximum GPD

GPD Daily Flow Limit	
300,000	May through October
310,000	November through April

RMK1	
143,000	Daily Flow Minimum GPD
183,000	Daily Flow Maximum GPD
157,967	Daily Flow Average GPD
4,739,000	Total Monthly Flow Gallons

RMK2	
-	Daily Flow Minimum GPD
-	Daily Flow Maximum GPD
-	Daily Flow Average GPD
-	Total Monthly Flow Gallons

COMBINED 30 DAY RUNNING AVERAGE	
-	Daily Flow Maximum GPD

GPD Daily Flow Limit	
300,000	May through October
310,000	November through April



SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # 3 351090001
 Discharge Self-Monitoring Report
 Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision Wastewater Treatment Plant

Sequencing Batch Reactor (SBR) INFLUENT MONITORING

DATE	RM # 1 SBR		RM # 2		COMBINED
	DAILY FLOW METERED GPD	30 Day Running Average GPD	DAILY FLOW METERED GPD	30 Day Running Average GPD	30 Day Running Average GPD
October 1, 2020	152,000	157,967	Flowing to RM 1 SBR for Treatment		
October 2, 2020	155,000	157,767	Flowing to RM 1 SBR for Treatment		
October 3, 2020	154,000	157,833	Flowing to RM 1 SBR for Treatment		
October 4, 2020	173,000	157,833	Flowing to RM 1 SBR for Treatment		
October 5, 2020	160,000	158,233	Flowing to RM 1 SBR for Treatment		
October 6, 2020	159,000	158,100	Flowing to RM 1 SBR for Treatment		
October 7, 2020	152,000	158,633	Flowing to RM 1 SBR for Treatment		
October 8, 2020	155,000	158,433	Flowing to RM 1 SBR for Treatment		
October 9, 2020	166,000	158,133	Flowing to RM 1 SBR for Treatment		
October 10, 2020	162,000	158,633	Flowing to RM 1 SBR for Treatment		
October 11, 2020	173,000	158,800	Flowing to RM 1 SBR for Treatment		
October 12, 2020	157,000	159,067	Flowing to RM 1 SBR for Treatment		
October 13, 2020	151,000	158,933	Flowing to RM 1 SBR for Treatment		
October 14, 2020	158,000	157,867	Flowing to RM 1 SBR for Treatment		
October 15, 2020	160,000	157,867	Flowing to RM 1 SBR for Treatment		
October 16, 2020	171,000	158,133	Flowing to RM 1 SBR for Treatment		
October 17, 2020	173,000	158,767	Flowing to RM 1 SBR for Treatment		
October 18, 2020	175,000	158,333	Flowing to RM 1 SBR for Treatment		
October 19, 2020	159,000	160,167	Flowing to RM 1 SBR for Treatment		
October 20, 2020	154,000	159,867	Flowing to RM 1 SBR for Treatment		
October 21, 2020	152,000	158,933	Flowing to RM 1 SBR for Treatment		
October 22, 2020	159,000	158,733	Flowing to RM 1 SBR for Treatment		
October 23, 2020	150,000	158,933	Flowing to RM 1 SBR for Treatment		
October 24, 2020	168,000	159,067	Flowing to RM 1 SBR for Treatment		
October 25, 2020	183,000	159,633	Flowing to RM 1 SBR for Treatment		
October 26, 2020	159,000	160,600	Flowing to RM 1 SBR for Treatment		
October 27, 2020	157,000	160,467	Flowing to RM 1 SBR for Treatment		
October 28, 2020	155,000	160,133	Flowing to RM 1 SBR for Treatment		
October 29, 2020	158,000	160,100	Flowing to RM 1 SBR for Treatment		
October 30, 2020	155,000	160,267	Flowing to RM 1 SBR for Treatment		
October 31, 2020	178,000	160,500	Flowing to RM 1 SBR for Treatment		
November 1, 2020	172,000	161,367	Flowing to RM 1 SBR for Treatment		
November 2, 2020	175,000	161,933	Flowing to RM 1 SBR for Treatment		
November 3, 2020	155,000	162,633	Flowing to RM 1 SBR for Treatment		
November 4, 2020	151,000	162,033	Flowing to RM 1 SBR for Treatment		
November 5, 2020	154,000	161,733	Flowing to RM 1 SBR for Treatment		
November 6, 2020	178,000	161,567	Flowing to RM 1 SBR for Treatment		
November 7, 2020	154,000	162,433	Flowing to RM 1 SBR for Treatment		
November 8, 2020	167,000	162,400	Flowing to RM 1 SBR for Treatment		
November 9, 2020	158,000	162,433	Flowing to RM 1 SBR for Treatment		
November 10, 2020	164,000	162,300	Flowing to RM 1 SBR for Treatment		
November 11, 2020	151,000	162,000	Flowing to RM 1 SBR for Treatment		
November 12, 2020	155,000	161,800	Flowing to RM 1 SBR for Treatment		
November 13, 2020	163,000	161,933	Flowing to RM 1 SBR for Treatment		
November 14, 2020	155,000	161,767	Flowing to RM 1 SBR for Treatment		
November 15, 2020	179,000	161,600	Flowing to RM 1 SBR for Treatment		
November 16, 2020	155,000	161,867	Flowing to RM 1 SBR for Treatment		
November 17, 2020	156,000	161,267	Flowing to RM 1 SBR for Treatment		
November 18, 2020	151,000	160,633	Flowing to RM 1 SBR for Treatment		
November 19, 2020	159,000	160,367	Flowing to RM 1 SBR for Treatment		
November 20, 2020	150,000	160,533	Flowing to RM 1 SBR for Treatment		
November 21, 2020	166,000	160,467	Flowing to RM 1 SBR for Treatment		
November 22, 2020	180,000	160,700	Flowing to RM 1 SBR for Treatment		
November 23, 2020	183,000	161,700	Flowing to RM 1 SBR for Treatment		
November 24, 2020	165,000	162,200	Flowing to RM 1 SBR for Treatment		
November 25, 2020	162,000	161,600	Flowing to RM 1 SBR for Treatment		
November 26, 2020	192,000	161,700	Flowing to RM 1 SBR for Treatment		
November 27, 2020	168,000	162,867	Flowing to RM 1 SBR for Treatment		
November 28, 2020	176,000	163,300	Flowing to RM 1 SBR for Treatment		
November 29, 2020	181,000	163,900	Flowing to RM 1 SBR for Treatment		
November 30, 2020	160,000	164,767	Flowing to RM 1 SBR for Treatment		
December 1, 2020	158,000	164,167	Flowing to RM 1 SBR for Treatment		
December 2, 2020	159,000	163,700	Flowing to RM 1 SBR for Treatment		
December 3, 2020	152,000	163,167	Flowing to RM 1 SBR for Treatment		
December 4, 2020	163,000	163,067	Flowing to RM 1 SBR for Treatment		
December 5, 2020	164,000	163,467	Flowing to RM 1 SBR for Treatment		
December 6, 2020	172,000	163,800	Flowing to RM 1 SBR for Treatment		
December 7, 2020	158,000	163,600	Flowing to RM 1 SBR for Treatment		
December 8, 2020	150,000	163,733	Flowing to RM 1 SBR for Treatment		
December 9, 2020	156,000	163,167	Flowing to RM 1 SBR for Treatment		
December 10, 2020	158,000	163,100	Flowing to RM 1 SBR for Treatment		
December 11, 2020	158,000	162,900	Flowing to RM 1 SBR for Treatment		
December 12, 2020	161,000	163,133	Flowing to RM 1 SBR for Treatment		
December 13, 2020	186,000	163,333	Flowing to RM 1 SBR for Treatment		
December 14, 2020	165,000	164,433	Flowing to RM 1 SBR for Treatment		
December 15, 2020	156,000	164,767	Flowing to RM 1 SBR for Treatment		
December 16, 2020	156,000	164,000	Flowing to RM 1 SBR for Treatment		
December 17, 2020	162,000	164,033	Flowing to RM 1 SBR for Treatment		
December 18, 2020	158,000	164,233	Flowing to RM 1 SBR for Treatment		
December 19, 2020	170,000	164,467	Flowing to RM 1 SBR for Treatment		
December 20, 2020	186,000	164,833	Flowing to RM 1 SBR for Treatment		
December 21, 2020	167,000	166,033	Flowing to RM 1 SBR for Treatment		
December 22, 2020	166,000	166,067	Flowing to RM 1 SBR for Treatment		
December 23, 2020	178,000	166,600	Flowing to RM 1 SBR for Treatment		
December 24, 2020	191,000	166,433	Flowing to RM 1 SBR for Treatment		
December 25, 2020	177,000	166,300	Flowing to RM 1 SBR for Treatment		
December 26, 2020	179,000	166,800	Flowing to RM 1 SBR for Treatment		
December 27, 2020	193,000	166,367	Flowing to RM 1 SBR for Treatment		
December 28, 2020	170,000	167,200	Flowing to RM 1 SBR for Treatment		
December 29, 2020	170,000	167,000	Flowing to RM 1 SBR for Treatment		
December 30, 2020	164,000	166,633	Flowing to RM 1 SBR for Treatment		
December 31, 2020	181,000	166,767	Flowing to RM 1 SBR for Treatment		

RMK1	
150,000	Daily Flow Minimum GPD
183,000	Daily Flow Maximum GPD
161,065	Daily Flow Average GPD
4,993,000	Total Monthly Flow Gallons

RMK2	
-	Daily Flow Minimum GPD
-	Daily Flow Maximum GPD
-	Daily Flow Average GPD
-	Total Monthly Flow Gallons

COMBINED 30 DAY RUNNING AVERAGE	
-	Daily Flow Maximum GPD

GPD	Daily Flow Limit
300,000	May through October
310,000	November through April

RMK1	
150,000	Daily Flow Minimum GPD
192,000	Daily Flow Maximum GPD
164,167	Daily Flow Average GPD
4,925,000	Total Monthly Flow Gallons

RMK2	
-	Daily Flow Minimum GPD
-	Daily Flow Maximum GPD
-	Daily Flow Average GPD
-	Total Monthly Flow Gallons

COMBINED 30 DAY RUNNING AVERAGE	
-	Daily Flow Maximum GPD

GPD	Daily Flow Limit
300,000	May through October
310,000	November through April

RMK1	
160,000	Daily Flow Minimum GPD
193,000	Daily Flow Maximum GPD
167,226	Daily Flow Average GPD
5,184,000	Total Monthly Flow Gallons


RMK2	
-	Daily Flow Minimum GPD
-	Daily Flow Maximum GPD
-	Daily Flow Average GPD
-	Total Monthly Flow Gallons

COMBINED 30 DAY RUNNING AVERAGE	
-	Daily Flow Maximum GPD

GPD	Daily Flow Limit
300,000	May through October
310,000	November through April



**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
Influent Sequencing Batch Reactor (SBR)
Flow Totals Chart**





SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # 3 35100001
Discharge Self-Monitoring Report
Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision RM - I Sequencing Batch Reactor (SBR) Wastewater Treatment Plant POND # 6 WASTEWATER FLOW - RM-I PERCOLATION & EVAPORATION

DATE	RMK # 1 SBR INFLUENT FLOW		POND # 6 EFFLUENT FLOW		PERCOLATED and EVAPORATED 30 Day Running Average RM-I Calculated Daily Percolation and Evaporation GPD	HISTORICAL EVAPORATION ESTIMATE MONTHLY AVERAGE RM-I GALLONS OF EVAPORATION PER DAY GPD	PERCOLATION ESTIMATE ESTIMATED GALLONS OF PERCOLATION PER DAY GPD	
	DAILY FLOW METERED GPD	30 Day Running Average GPD	DAILY FLOW METERED GPD	30 Day Running Average GPD				
January 1, 2020	156,000	155,233	0	0	155,233	3,100	152,124	
January 2, 2020	151,000	155,333	0	0	155,333	3,100	152,224	RMK1
January 3, 2020	145,000	155,300	0	0	155,300	3,100	152,191	127,000 Daily Flow Minimum GPD
January 4, 2020	155,000	155,200	0	0	155,200	3,100	152,091	181,000 Daily Flow Maximum GPD
January 5, 2020	172,000	155,700	0	0	155,700	3,100	152,591	148,452 Daily Flow Average GPD
January 6, 2020	147,000	156,987	0	0	156,987	3,100	153,587	4,833,000 Total Monthly Flow Gallons
January 7, 2020	139,000	156,700	0	0	156,700	3,100	153,591	
January 8, 2020	149,000	155,333	0	0	155,333	3,100	152,224	POND # 6
January 9, 2020	134,000	155,467	0	0	155,467	3,100	152,357	- Daily Flow Minimum GPD
January 10, 2020	143,000	155,233	0	0	155,233	3,100	152,124	- Daily Flow Maximum GPD
January 11, 2020	158,000	155,233	0	0	155,233	3,100	152,124	- Daily Flow Average GPD
January 12, 2020	179,000	155,900	0	0	155,900	3,100	152,791	- Total Monthly Flow Gallons
January 13, 2020	146,000	156,633	0	0	156,633	3,100	153,524	
January 14, 2020	144,000	157,000	0	0	157,000	3,100	153,891	
January 15, 2020	149,000	155,787	0	0	155,787	3,100	152,657	POND # 6 - 30 DAY RUN AVG
January 16, 2020	155,000	155,867	0	0	155,867	3,100	152,757	- Maximum GPD
January 17, 2020	127,000	156,333	0	0	156,333	3,100	153,224	PERCOLATION AND EVAPORATION (5.3 Acre Surface Area)
January 18, 2020	150,000	155,433	0	0	155,433	3,100	152,324	149,800 Daily Minimum GPD
January 19, 2020	170,000	155,800	0	0	155,800	3,100	152,891	157,000 Daily Maximum GPD
January 20, 2020	159,000	156,133	0	0	156,133	3,100	152,891	154,574 Daily Average GPD
January 21, 2020	141,000	156,400	0	0	156,400	3,100	153,291	4,791,800 Total Monthly Gallons
January 22, 2020	140,000	155,733	0	0	155,733	3,100	152,624	
January 23, 2020	138,000	155,067	0	0	155,067	3,100	151,957	PERCOLATION ESTIMATE
January 24, 2020	140,000	152,833	0	0	152,833	3,100	148,724	148,491 Daily Minimum GPD
January 25, 2020	149,000	151,787	0	0	151,787	3,100	148,657	153,891 Daily Maximum GPD
January 26, 2020	181,000	150,833	0	0	150,833	3,100	147,724	151,465 Daily Average GPD
January 27, 2020	148,000	151,733	0	0	151,733	3,100	148,624	4,895,400 Total Monthly Gallons
January 28, 2020	140,000	151,267	0	0	151,267	3,100	148,157	
January 29, 2020	140,000	150,100	0	0	150,100	3,100	148,991	
January 30, 2020	141,000	149,900	0	0	149,900	3,100	148,791	
January 31, 2020	145,000	148,600	0	0	148,600	3,100	148,491	
February 1, 2020	160,000	149,167	0	0	149,167	3,100	148,057	RMK1
February 2, 2020	172,000	149,467	0	0	149,467	3,100	148,357	124,000 Daily Flow Minimum GPD
February 3, 2020	153,000	150,367	0	0	150,367	3,100	147,257	181,000 Daily Flow Maximum GPD
February 4, 2020	146,000	150,300	0	0	150,300	3,100	147,191	146,758 Daily Flow Average GPD
February 5, 2020	141,000	149,433	0	0	149,433	3,100	146,324	4,256,000 Total Monthly Flow Gallons
February 6, 2020	149,000	149,233	0	0	149,233	3,100	146,124	
February 7, 2020	124,000	149,567	0	0	149,567	3,100	146,457	
February 8, 2020	152,000	148,733	0	0	148,733	3,100	145,624	POND # 6
February 9, 2020	181,000	149,333	0	0	149,333	3,100	148,224	- Daily Flow Minimum GPD
February 10, 2020	145,000	150,600	0	0	150,600	3,100	147,491	- Daily Flow Maximum GPD
February 11, 2020	161,000	150,167	0	0	150,167	3,100	147,057	- Daily Flow Average GPD
February 12, 2020	134,000	149,233	0	0	149,233	3,100	146,124	- Total Monthly Flow Gallons
February 13, 2020	162,000	148,833	0	0	148,833	3,100	145,724	
February 14, 2020	128,000	149,100	0	0	149,100	3,100	145,991	POND # 6 - 30 DAY RUN AVG
February 15, 2020	146,000	148,400	0	0	148,400	3,100	145,291	- Maximum GPD
February 16, 2020	152,000	148,100	0	0	148,100	3,100	144,991	
February 17, 2020	157,000	148,933	0	0	148,933	3,100	145,824	PERCOLATION AND EVAPORATION (5.3 Acre Surface Area)
February 18, 2020	146,000	149,167	0	0	149,167	3,100	148,057	146,367 Daily Minimum GPD
February 19, 2020	138,000	148,367	0	0	148,367	3,100	145,257	150,600 Daily Maximum GPD
February 20, 2020	140,000	147,867	0	0	147,867	3,100	144,557	148,672 Daily Average GPD
February 21, 2020	133,000	147,833	0	0	147,833	3,100	144,524	4,311,500 Total Monthly Gallons
February 22, 2020	147,000	147,400	0	0	147,400	3,100	144,291	
February 23, 2020	174,000	147,700	0	0	147,700	3,100	144,591	PERCOLATION ESTIMATE
February 24, 2020	148,000	148,833	0	0	148,833	3,100	145,724	143,257 Daily Minimum GPD
February 25, 2020	136,000	148,800	0	0	148,800	3,100	145,891	147,491 Daily Maximum GPD
February 26, 2020	130,000	147,300	0	0	147,300	3,100	144,191	145,563 Daily Average GPD
February 27, 2020	137,000	146,700	0	0	146,700	3,100	143,591	4,221,328 Total Monthly Gallons
February 28, 2020	133,000	146,600	0	0	146,600	3,100	143,491	
February 29, 2020	151,000	146,367	0	0	146,367	3,100	143,257	
March 1, 2020	179,000	146,700	0	0	146,700	3,100	143,591	RMK1
March 2, 2020	147,000	147,833	0	0	147,833	3,100	144,724	131,000 Daily Flow Minimum GPD
March 3, 2020	141,000	147,400	0	0	147,400	3,100	144,291	187,000 Daily Flow Maximum GPD
March 4, 2020	140,000	148,367	0	0	148,367	3,100	143,257	158,065 Daily Flow Average GPD
March 5, 2020	154,000	145,833	0	0	145,833	3,100	142,824	4,900,000 Total Monthly Flow Gallons
March 6, 2020	131,000	146,200	0	0	146,200	3,100	143,091	
March 7, 2020	150,000	145,867	0	0	145,867	3,100	142,757	
March 8, 2020	177,000	145,900	0	0	145,900	3,100	142,791	POND # 6
March 9, 2020	152,000	147,667	0	0	147,667	3,100	144,557	- Daily Flow Minimum GPD
March 10, 2020	149,000	147,867	0	0	147,867	3,100	144,557	- Daily Flow Maximum GPD
March 11, 2020	154,000	146,600	0	0	146,600	3,100	143,491	- Daily Flow Average GPD
March 12, 2020	141,000	146,900	0	0	146,900	3,100	143,791	- Total Monthly Flow Gallons
March 13, 2020	144,000	146,567	0	0	146,567	3,100	143,457	
March 14, 2020	171,000	146,900	0	0	146,900	3,100	143,791	POND # 6 - 30 DAY RUN AVG
March 15, 2020	187,000	147,533	0	0	147,533	3,100	144,424	- Maximum GPD
March 16, 2020	144,000	149,500	0	0	149,500	3,100	148,391	
March 17, 2020	165,000	149,433	0	0	149,433	3,100	146,324	PERCOLATION AND EVAPORATION (5.3 Acre Surface Area)
March 18, 2020	158,000	149,867	0	0	149,867	3,100	146,757	145,887 Daily Minimum GPD
March 19, 2020	158,000	149,900	0	0	149,900	3,100	146,791	158,167 Daily Maximum GPD
March 20, 2020	168,000	150,300	0	0	150,300	3,100	147,191	149,972 Daily Average GPD
March 21, 2020	155,000	151,333	0	0	151,333	3,100	148,224	4,849,133 Total Monthly Gallons
March 22, 2020	171,000	151,833	0	0	151,833	3,100	148,724	
March 23, 2020	168,000	153,100	0	0	153,100	3,100	149,991	PERCOLATION ESTIMATE
March 24, 2020	156,000	153,833	0	0	153,833	3,100	150,724	142,757 Daily Minimum GPD
March 25, 2020	154,000	153,233	0	0	153,233	3,100	150,124	155,057 Daily Maximum GPD
March 26, 2020	161,000	153,433	0	0	153,433	3,100	150,324	146,863 Daily Average GPD
March 27, 2020	163,000	154,267	0	0	154,267	3,100	151,157	4,552,742 Total Monthly Gallons
March 28, 2020	158,000	155,367	0	0	155,367	3,100	152,257	
March 29, 2020	175,000	156,067	0	0	156,067	3,100	152,957	
March 30, 2020	172,000	157,467	0	0	157,467	3,100	154,357	
March 31, 2020	155,000	158,167	0	0	158,167	3,100	155,057	



SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # 3 35100001
Discharge Self-Monitoring Report
Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision RM - I Sequencing Batch Reactor (SBR) Wastewater Treatment Plant POND # 6 WASTEWATER FLOW - RM-I PERCOLATION & EVAPORATION

DATE	RMK #1 SBR INFLUENT FLOW		POND #6 EFFLUENT FLOW		PERCOLATED and EVAPORATED 30 Day Running Average RM-I Calculated Daily Percolation and Evaporation GPD	HISTORICAL EVAPORATION ESTIMATE MONTHLY AVERAGE RM-I GALLONS OF EVAPORATION PER DAY GPD	PERCOLATION ESTIMATE ESTIMATED GALLONS OF PERCOLATION PER DAY GPD	
	DAILY FLOW METERED GPD	30 Day Running Average GPD	DAILY FLOW METERED GPD	30 Day Running Average GPD				
April 1, 2020	151,000	157,367	0	0	157,367	3,109	154,257	RMK1
April 2, 2020	173,000	157,500	0	0	157,500	3,109	154,391	151,000 Daily Flow Minimum GPD
April 3, 2020	157,000	158,567	0	0	158,567	3,109	155,457	179,000 Daily Flow Maximum GPD
April 4, 2020	166,000	159,133	0	0	159,133	3,109	156,024	164,700 Daily Flow Average GPD
April 5, 2020	172,000	159,533	0	0	159,533	3,109	156,424	4,941,000 Total Monthly Flow Gallons
April 6, 2020	166,000	160,900	0	0	160,900	3,109	157,791	
April 7, 2020	154,000	161,433	0	0	161,433	3,109	158,324	POND # 6
April 8, 2020	166,000	160,667	0	0	160,667	3,109	157,557	- Daily Flow Minimum GPD
April 9, 2020	164,000	161,133	0	0	161,133	3,109	158,024	- Daily Flow Maximum GPD
April 10, 2020	157,000	161,633	0	0	161,633	3,109	158,524	- Daily Flow Average GPD
April 11, 2020	174,000	161,733	0	0	161,733	3,109	158,624	- Total Monthly Flow Gallons
April 12, 2020	178,000	162,833	0	0	162,833	3,109	159,724	
April 13, 2020	168,000	163,967	0	0	163,967	3,109	160,857	
April 14, 2020	156,000	163,867	0	0	163,867	3,109	160,757	POND # 6 - 30 DAY RUN AVG
April 15, 2020	161,000	162,833	0	0	162,833	3,109	159,724	- Maximum GPD
April 16, 2020	160,000	163,400	0	0	163,400	3,109	160,291	PERCOLATION AND EVAPORATION (5.3 Acre Surface Area)
April 17, 2020	166,000	163,233	0	0	163,233	3,109	160,124	157,367 Daily Minimum GPD
April 18, 2020	173,000	163,500	0	0	163,500	3,109	160,381	165,433 Daily Maximum GPD
April 19, 2020	179,000	164,000	0	0	164,000	3,109	160,891	162,817 Daily Average GPD
April 20, 2020	164,000	164,333	0	0	164,333	3,109	161,224	4,878,500 Total Monthly Gallons
April 21, 2020	158,000	164,833	0	0	164,833	3,109	161,524	
April 22, 2020	161,000	164,200	0	0	164,200	3,109	161,091	PERCOLATION ESTIMATE
April 23, 2020	161,000	163,933	0	0	163,933	3,109	160,824	154,257 Daily Minimum GPD
April 24, 2020	172,000	164,100	0	0	164,100	3,109	160,991	162,324 Daily Maximum GPD
April 25, 2020	169,000	164,700	0	0	164,700	3,109	161,591	159,507 Daily Average GPD
April 26, 2020	177,000	164,967	0	0	164,967	3,109	161,857	4,785,218 Total Monthly Gallons
April 27, 2020	158,000	165,433	0	0	165,433	3,109	162,324	
April 28, 2020	160,000	165,433	0	0	165,433	3,109	162,324	
April 29, 2020	162,000	164,933	0	0	164,933	3,109	161,824	
April 30, 2020	158,000	164,800	0	0	164,800	3,109	161,491	
May 1, 2020	157,000	164,700	0	0	164,700	3,109	161,591	RMK1
May 2, 2020	173,000	164,900	0	0	164,900	3,109	161,791	145,000 Daily Flow Minimum GPD
May 3, 2020	186,000	164,900	0	0	164,900	3,109	161,791	186,000 Daily Flow Maximum GPD
May 4, 2020	167,000	165,867	0	0	165,867	3,109	162,757	167,871 Daily Flow Average GPD
May 5, 2020	163,000	165,900	0	0	165,900	3,109	162,791	5,204,000 Total Monthly Flow Gallons
May 6, 2020	179,000	165,600	0	0	165,600	3,109	162,491	
May 7, 2020	162,000	166,033	0	0	166,033	3,109	162,924	POND # 6
May 8, 2020	167,000	166,300	0	0	166,300	3,109	163,191	- Daily Flow Minimum GPD
May 9, 2020	181,000	166,333	0	0	166,333	3,109	163,224	- Daily Flow Maximum GPD
May 10, 2020	177,000	166,000	0	0	166,000	3,109	163,791	- Daily Flow Average GPD
May 11, 2020	174,000	167,567	0	0	167,567	3,109	164,457	- Total Monthly Flow Gallons
May 12, 2020	162,000	167,567	0	0	167,567	3,109	164,457	
May 13, 2020	164,000	167,033	0	0	167,033	3,109	163,924	POND # 6 - 30 DAY RUN AVG
May 14, 2020	164,000	166,900	0	0	166,900	3,109	163,791	- Maximum GPD
May 15, 2020	166,000	167,167	0	0	167,167	3,109	164,067	PERCOLATION AND EVAPORATION (5.3 Acre Surface Area)
May 16, 2020	174,000	167,333	0	0	167,333	3,109	164,224	164,700 Daily Minimum GPD
May 17, 2020	186,000	167,800	0	0	167,800	3,109	164,691	168,467 Daily Maximum GPD
May 18, 2020	167,000	168,467	0	0	168,467	3,109	165,357	166,918 Daily Average GPD
May 19, 2020	155,000	168,267	0	0	168,267	3,109	165,157	5,174,467 Total Monthly Gallons
May 20, 2020	175,000	167,467	0	0	167,467	3,109	164,357	
May 21, 2020	145,000	167,833	0	0	167,833	3,109	164,724	
May 22, 2020	164,000	167,400	0	0	167,400	3,109	164,291	PERCOLATION ESTIMATE
May 23, 2020	167,000	167,500	0	0	167,500	3,109	164,391	161,591 Daily Minimum GPD
May 24, 2020	168,000	167,700	0	0	167,700	3,109	164,591	165,357 Daily Maximum GPD
May 25, 2020	177,000	167,567	0	0	167,567	3,109	164,457	163,809 Daily Average GPD
May 26, 2020	149,000	167,833	0	0	167,833	3,109	164,724	5,076,076 Total Monthly Gallons
May 27, 2020	162,000	166,900	0	0	166,900	3,109	163,791	
May 28, 2020	159,000	167,033	0	0	167,033	3,109	163,824	
May 29, 2020	167,000	167,000	0	0	167,000	3,109	163,891	
May 30, 2020	169,000	167,167	0	0	167,167	3,109	164,057	
May 31, 2020	178,000	167,533	0	0	167,533	3,109	164,424	
June 1, 2020	155,000	168,233	0	0	168,233	3,109	165,124	RMK1
June 2, 2020	160,000	167,833	0	0	167,833	3,109	164,524	151,000 Daily Flow Minimum GPD
June 3, 2020	158,000	168,767	0	0	168,767	3,109	163,657	185,900 Daily Flow Maximum GPD
June 4, 2020	160,000	166,500	0	0	166,500	3,109	163,381	161,767 Daily Flow Average GPD
June 5, 2020	155,000	166,400	0	0	166,400	3,109	163,291	4,853,000 Total Monthly Flow Gallons
June 6, 2020	170,000	165,600	0	0	165,600	3,109	162,491	
June 7, 2020	165,000	165,867	0	0	165,867	3,109	162,757	POND # 6
June 8, 2020	159,000	166,467	0	0	166,467	3,109	163,357	- Daily Flow Minimum GPD
June 9, 2020	154,000	165,733	0	0	165,733	3,109	162,824	- Daily Flow Maximum GPD
June 10, 2020	153,000	164,967	0	0	164,967	3,109	161,857	- Daily Flow Average GPD
June 11, 2020	166,000	164,267	0	0	164,267	3,109	161,157	- Total Monthly Flow Gallons
June 12, 2020	157,000	164,400	0	0	164,400	3,109	161,291	
June 13, 2020	165,000	164,167	0	0	164,167	3,109	161,057	POND # 6 - 30 DAY RUN AVG
June 14, 2020	172,000	164,200	0	0	164,200	3,109	161,091	- Maximum GPD
June 15, 2020	157,000	164,400	0	0	164,400	3,109	161,291	PERCOLATION AND EVAPORATION (5.3 Acre Surface Area)
June 16, 2020	158,000	163,833	0	0	163,833	3,109	160,724	161,633 Daily Minimum GPD
June 17, 2020	160,000	162,900	0	0	162,900	3,109	159,791	168,233 Daily Maximum GPD
June 18, 2020	154,000	162,667	0	0	162,667	3,109	159,557	164,050 Daily Average GPD
June 19, 2020	151,000	162,633	0	0	162,633	3,109	159,524	4,921,767 Total Monthly Gallons
June 20, 2020	163,000	161,833	0	0	161,833	3,109	158,724	
June 21, 2020	178,000	162,433	0	0	162,433	3,109	159,324	
June 22, 2020	162,000	162,900	0	0	162,900	3,109	159,791	PERCOLATION ESTIMATE
June 23, 2020	157,000	162,733	0	0	162,733	3,109	159,624	158,524 Daily Minimum GPD
June 24, 2020	157,000	162,367	0	0	162,367	3,109	159,257	165,124 Daily Maximum GPD
June 25, 2020	154,000	161,700	0	0	161,700	3,109	158,591	160,950 Daily Average GPD
June 26, 2020	155,000	161,867	0	0	161,867	3,109	158,757	4,828,485 Total Monthly Gallons
June 27, 2020	170,000	161,633	0	0	161,633	3,109	158,524	
June 28, 2020	178,000	162,000	0	0	162,000	3,109	158,891	
June 29, 2020	167,000	162,367	0	0	162,367	3,109	159,257	
June 30, 2020	162,000	162,300	0	0	162,300	3,109	159,191	



SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # 3 35180001
Discharge Self-Monitoring Report
Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision RM - I Sequencing Batch Reactor (SBR) Wastewater Treatment Plant POND # 6 WASTEWATER FLOW - RM-I PERCOLATION & EVAPORATION

DATE	RMK # 1 SBR INFLUENT FLOW		POND # 6 EFFLUENT FLOW		PERCOLATED and EVAPORATED 30 Day Running Average RM-I Calculated Daily Percolation and Evaporation GPD	HISTORICAL EVAPORATION ESTIMATE MONTHLY AVERAGE RM-I GALLONS OF EVAPORATION PER DAY GPD	PERCOLATION ESTIMATE ESTIMATED GALLONS OF PERCOLATION PER DAY GPD	
	DAILY FLOW METERED GPD	30 Day Running Average GPD	DAILY FLOW METERED GPD	30 Day Running Average GPD				
August 1, 2020	166,000	162,800	0	700	162,100	3,109	158,991	RMK1
August 2, 2020	181,000	162,800	36000	700	162,100	3,109	158,991	141,000 Daily Flow Minimum GPD
August 3, 2020	160,000	163,433	9000	1900	161,533	3,109	158,424	192,000 Daily Flow Maximum GPD
August 4, 2020	158,000	163,100	96000	2200	160,900	3,109	157,791	162,097 Daily Flow Average GPD
August 5, 2020	181,000	162,700	19000	5400	157,300	3,109	154,191	5,025,000 Total Monthly Flow Gallons
August 6, 2020	160,000	162,567	0	6033	156,533	3,109	153,424	
August 7, 2020	192,000	162,767	0	6033	156,733	3,109	153,624	POND # 6
August 8, 2020	141,000	163,700	0	6033	157,667	3,109	154,557	- Daily Flow Minimum GPD
August 9, 2020	175,000	163,033	0	6033	157,000	3,109	153,891	96,000 Daily Flow Maximum GPD
August 10, 2020	172,000	163,233	27000	6033	157,200	3,109	154,091	18,433 Daily Flow Average GPD
August 11, 2020	154,000	163,300	50000	6633	156,367	3,109	153,257	553,000 Total Monthly Flow Gallons
August 12, 2020	173,000	162,667	15000	8600	154,367	3,109	151,257	
August 13, 2020	157,000	163,333	22000	9100	154,233	3,109	151,124	POND # 6 - 30 DAY RUN AVG
August 14, 2020	161,000	163,400	0	9833	153,567	3,109	150,457	19,793 Maximum GPD
August 15, 2020	155,000	163,267	0	9833	153,433	3,109	150,324	PERCOLATION AND EVAPORATION (5.3 Acre Surface Area)
August 16, 2020	179,000	163,167	0	9833	153,333	3,109	150,224	141,540 Daily Minimum GPD
August 17, 2020	147,000	163,733	59000	9833	153,900	3,109	150,791	162,100 Daily Maximum GPD
August 18, 2020	150,000	163,100	31000	11600	151,300	3,109	148,191	152,285 Daily Average GPD
August 19, 2020	160,000	162,400	12000	12833	149,567	3,109	146,457	4,720,823 Total Monthly Gallons
August 20, 2020	154,000	162,367	0	13233	149,133	3,109	146,024	
August 21, 2020	156,000	162,167	0	13233	148,933	3,109	145,824	PERCOLATION ESTIMATE
August 22, 2020	167,000	162,133	0	13233	148,900	3,109	145,791	138,431 Daily Minimum GPD
August 23, 2020	182,000	162,533	13233	149,300	149,300	3,109	146,161	158,991 Daily Maximum GPD
August 24, 2020	158,000	163,533	52000	13690	149,844	3,109	146,734	149,175 Daily Average GPD
August 25, 2020	157,000	163,333	42000	15483	147,851	3,109	144,741	4,624,432 Total Monthly Gallons
August 26, 2020	155,000	162,333	45000	16931	145,402	3,109	142,293	
August 27, 2020	150,000	162,100	38000	18483	143,617	3,109	140,508	
August 28, 2020	146,000	161,833	0	19793	142,040	3,109	138,931	
August 29, 2020	162,000	161,333	0	19793	141,540	3,109	138,431	
August 30, 2020	179,000	161,067	0	19089	141,998	3,109	138,888	
August 31, 2020	150,000	162,200	0	19089	143,131	3,109	140,022	RMK1
September 1, 2020	158,000	161,967	0	19089	142,898	3,109	139,788	143,000 Daily Flow Minimum GPD
September 2, 2020	153,000	161,200	0	18464	142,736	3,109	139,626	183,000 Daily Flow Maximum GPD
September 3, 2020	154,000	160,967	0	18143	142,824	3,109	139,714	157,967 Daily Flow Average GPD
September 4, 2020	161,000	160,900	0	15259	145,641	3,109	142,531	4,739,000 Total Monthly Flow Gallons
September 5, 2020	164,000	160,900	0	14558	146,344	3,109	143,235	
September 6, 2020	143,000	161,033	0	14556	146,478	3,109	143,368	PERCOLATION ESTIMATE
September 7, 2020	158,000	159,400	57000	14556	144,844	3,109	141,735	137,977 Daily Minimum GPD
September 8, 2020	164,000	159,967	36000	16667	143,300	3,109	140,191	146,478 Daily Maximum GPD
September 9, 2020	151,000	159,600	15000	18074	141,526	3,109	138,417	142,566 Daily Average GPD
September 10, 2020	157,000	158,900	14000	17630	141,270	3,109	138,161	4,276,989 Total Monthly Gallons
September 11, 2020	185,000	159,000	0	16296	142,704	3,109	139,594	
September 12, 2020	181,000	158,733	0	15741	142,993	3,109	139,663	PERCOLATION AND EVAPORATION (5.3 Acre Surface Area)
September 13, 2020	183,000	158,867	0	14926	143,941	3,109	140,831	137,977 Daily Minimum GPD
September 14, 2020	158,000	159,600	34000	15500	144,100	3,109	140,991	146,478 Daily Maximum GPD
September 15, 2020	152,000	159,700	44000	16808	142,892	3,109	139,783	142,566 Daily Average GPD
September 16, 2020	152,000	158,600	30000	16500	140,300	3,109	137,191	4,276,989 Total Monthly Gallons
September 17, 2020	156,000	158,967	44000	17385	141,582	3,109	136,473	
September 18, 2020	150,000	159,167	0	17885	141,282	3,109	136,173	PERCOLATION ESTIMATE
September 19, 2020	168,000	158,833	0	17423	141,410	3,109	136,301	134,868 Daily Minimum GPD
September 20, 2020	182,000	159,300	0	17423	141,877	3,109	136,766	143,368 Daily Maximum GPD
September 21, 2020	158,000	160,167	52000	18120	142,047	3,109	136,937	139,457 Daily Average GPD
September 22, 2020	153,000	159,867	39000	20200	138,667	3,109	136,557	4,183,707 Total Monthly Gallons
September 23, 2020	146,000	158,900	0	20923	137,977	3,109	134,868	
September 24, 2020	151,000	158,500	0	18623	139,577	3,109	136,468	
September 25, 2020	154,000	158,300	0	18000	140,300	3,109	137,191	
September 26, 2020	163,000	158,267	0	16200	142,067	3,109	138,957	
September 27, 2020	167,000	158,700	0	14680	144,020	3,109	140,911	
September 28, 2020	156,000	159,400	0	15292	144,108	3,109	140,999	
September 29, 2020	153,000	159,200	0	15292	143,908	3,109	140,799	
September 30, 2020	148,000	158,333	19000	15657	142,377	3,109	139,267	



SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # J 35100001
Discharge Self-Monitoring Report
Monitoring and Reporting Program # R3-2004-0065


Ridgemark Estates Subdivision RM - I Sequencing Batch Reactor (SBR) Wastewater Treatment Plant POND # 6 WASTEWATER FLOW - RM-I PERCOLATION & EVAPORATION

DATE	RMK # 1 SBR INFLUENT FLOW		POND # 6 EFFLUENT FLOW		PERCOLATED and EVAPORATED 30 Day Running Average RM-I Calculated Daily Percolation and Evaporation GPD	HISTORICAL EVAPORATION ESTIMATE MONTHLY AVERAGE RM-I GALLONS OF EVAPORATION PER DAY GPD	PERCOLATION ESTIMATE ESTIMATED GALLONS OF PERCOLATION PER DAY GPD	
	DAILY FLOW METERED GPD	30 Day Running Average GPD	DAILY FLOW METERED GPD	30 Day Running Average GPD				
October 1, 2020	152,000	157,967	119000	16783	141,184	3,100	138,075	RMK1
October 2, 2020	155,000	157,767	175000	21042	136,726	3,100	133,616	150,000 Daily Flow Minimum GPD
October 3, 2020	154,000	157,833	0	28333	129,500	3,100	126,391	183,000 Daily Flow Maximum GPD
October 4, 2020	173,000	157,833	57000	27200	130,633	3,100	127,524	161,085 Daily Flow Average GPD
October 5, 2020	160,000	158,233	213000	29490	128,763	3,100	125,644	4,993,000 Total Monthly Flow Gallons
October 6, 2020	159,000	158,100	220000	38000	120,100	3,100	118,991	
October 7, 2020	152,000	158,633	175000	46890	111,833	3,100	108,724	POND # 6
October 8, 2020	155,000	158,433	0	51520	106,913	3,100	103,804	- Daily Flow Minimum GPD
October 9, 2020	166,000	158,133	0	50000	106,133	3,100	105,024	288,000 Daily Flow Maximum GPD
October 10, 2020	162,000	158,633	0	40400	109,233	3,100	106,124	96,581 Daily Flow Average GPD
October 11, 2020	173,000	158,800	148000	48840	109,660	3,100	106,551	2,994,000 Total Monthly Flow Gallons
October 12, 2020	157,000	159,067	257000	54880	104,387	3,100	101,277	
October 13, 2020	151,000	158,933	168000	64960	93,973	3,100	90,864	
October 14, 2020	158,000	157,867	99000	68923	88,944	3,100	85,834	POND # 6 - 30 DAY RUN AVG
October 15, 2020	160,000	157,867	138000	71423	86,444	3,100	83,334	103,897 Maximum GPD
October 16, 2020	171,000	158,133	164000	75038	83,095	3,100	79,995	
October 17, 2020	173,000	158,767	0	80192	78,574	3,100	75,465	PERCOLATION AND EVAPORATION (5.3 Acre Surface Area)
October 18, 2020	175,000	159,333	83000	78500	80,633	3,100	77,724	56,203 Daily Minimum GPD
October 19, 2020	159,000	160,187	114000	61892	78,474	3,100	75,365	141,184 Daily Maximum GPD
October 20, 2020	154,000	159,867	288000	48077	73,790	3,100	70,680	90,141 Daily Average GPD
October 21, 2020	152,000	158,933	38000	93556	65,376	3,100	62,268	2,794,375 Total Monthly Gallons
October 22, 2020	159,000	158,733	0	92963	65,770	3,100	62,661	PERCOLATION ESTIMATE
October 23, 2020	150,000	158,933	0	91519	67,415	3,100	64,305	53,094 Daily Minimum GPD
October 24, 2020	168,000	159,067	0	91519	67,548	3,100	64,439	138,075 Daily Maximum GPD
October 25, 2020	183,000	159,633	189000	88250	71,383	3,100	68,274	87,032 Daily Average GPD
October 26, 2020	159,000	160,600	242000	95000	65,600	3,100	62,491	2,687,984 Total Monthly Gallons
October 27, 2020	157,000	160,467	111000	103643	56,824	3,100	53,714	
October 28, 2020	155,000	160,133	0	103897	56,237	3,100	53,127	
October 29, 2020	158,000	160,100	0	103897	56,203	3,100	53,094	
October 30, 2020	155,000	160,287	0	100433	59,833	3,100	56,724	
October 31, 2020	178,000	160,500	0	99800	60,700	3,100	57,591	
November 1, 2020	172,000	161,367	0	95833	65,533	3,100	62,424	RMK1
November 2, 2020	175,000	161,933	376000	90000	71,933	3,100	68,824	150,000 Daily Flow Minimum GPD
November 3, 2020	155,000	162,833	0	102533	60,100	3,100	56,991	192,000 Daily Flow Maximum GPD
November 4, 2020	151,000	162,033	149000	106633	61,400	3,100	58,291	164,167 Daily Flow Average GPD
November 5, 2020	154,000	161,733	106000	98500	63,233	3,100	60,124	4,925,000 Total Monthly Flow Gallons
November 6, 2020	178,000	161,567	0	94700	66,867	3,100	63,757	
November 7, 2020	154,000	162,433	0	88867	73,567	3,100	70,457	POND # 6
November 8, 2020	167,000	162,400	315000	88867	73,533	3,100	70,424	- Daily Flow Minimum GPD
November 9, 2020	158,000	162,433	91000	99367	63,067	3,100	59,957	526,000 Daily Flow Maximum GPD
November 10, 2020	164,000	162,300	0	102400	59,800	3,100	56,791	105,800 Daily Flow Average GPD
November 11, 2020	151,000	162,000	214000	97533	64,467	3,100	61,357	3,174,000 Total Monthly Flow Gallons
November 12, 2020	155,000	161,800	212000	96100	65,700	3,100	62,591	
November 13, 2020	153,000	161,933	0	97567	64,367	3,100	61,257	
November 14, 2020	155,000	161,767	0	94267	67,500	3,100	64,391	POND # 6 - 30 DAY RUN AVG
November 15, 2020	179,000	161,600	0	89667	71,933	3,100	68,824	102,533 Maximum GPD
November 16, 2020	155,000	161,867	125000	84200	77,667	3,100	74,557	PERCOLATION AND EVAPORATION (5.3 Acre Surface Area)
November 17, 2020	156,000	161,267	0	88367	72,900	3,100	69,791	59,900 Daily Minimum GPD
November 18, 2020	151,000	160,633	217000	85600	75,033	3,100	71,924	83,467 Daily Maximum GPD
November 19, 2020	159,000	160,367	0	89033	71,333	3,100	68,224	70,289 Daily Average GPD
November 20, 2020	150,000	160,533	0	79433	81,100	3,100	77,991	2,108,667 Total Monthly Gallons
November 21, 2020	166,000	160,467	0	78233	82,233	3,100	79,124	
November 22, 2020	180,000	160,700	0	78233	82,467	3,100	79,357	
November 23, 2020	163,000	161,700	528000	78233	83,467	3,100	80,357	PERCOLATION ESTIMATE
November 24, 2020	165,000	162,200	278000	95767	66,433	3,100	63,324	56,791 Daily Minimum GPD
November 25, 2020	162,000	161,800	0	98733	82,867	3,100	79,757	80,357 Daily Maximum GPD
November 26, 2020	192,000	161,700	0	90667	71,033	3,100	67,924	67,180 Daily Average GPD
November 27, 2020	168,000	162,867	0	86967	75,900	3,100	72,791	2,015,385 Total Monthly Gallons
November 28, 2020	176,000	163,300	188000	86967	76,333	3,100	73,224	
November 29, 2020	181,000	163,900	162000	93233	70,667	3,100	67,557	
November 30, 2020	160,000	164,767	215000	98633	86,133	3,100	83,024	
December 1, 2020	158,000	164,187	254000	105800	58,387	3,100	55,257	RMK1
December 2, 2020	159,000	163,700	111000	114267	49,433	3,100	46,324	150,000 Daily Flow Minimum GPD
December 3, 2020	152,000	163,187	133000	105433	57,733	3,100	54,624	193,000 Daily Flow Maximum GPD
December 4, 2020	163,000	163,087	0	109867	53,200	3,100	50,091	187,226 Daily Flow Average GPD
December 5, 2020	164,000	163,467	0	104900	58,567	3,100	55,457	5,184,000 Total Monthly Flow Gallons
December 6, 2020	172,000	163,800	120000	101367	62,433	3,100	59,324	
December 7, 2020	158,000	163,600	86000	105367	58,233	3,100	55,124	POND # 6
December 8, 2020	150,000	163,733	153000	107567	56,167	3,100	53,057	- Daily Flow Minimum GPD
December 9, 2020	156,000	163,187	241000	102167	61,000	3,100	57,891	254,000 Daily Flow Maximum GPD
December 10, 2020	158,000	163,100	172000	107167	55,933	3,100	52,824	47,710 Daily Flow Average GPD
December 11, 2020	158,000	162,900	0	112900	50,000	3,100	46,891	1,479,000 Total Monthly Flow Gallons
December 12, 2020	161,000	163,133	0	105767	57,387	3,100	54,257	
December 13, 2020	186,000	163,333	0	98700	64,633	3,100	61,524	
December 14, 2020	165,000	164,433	223000	98700	65,733	3,100	62,824	POND # 6 - 30 DAY RUN AVG
December 15, 2020	156,000	164,767	6000	106133	58,633	3,100	55,524	114,267 Maximum GPD
December 16, 2020	156,000	164,000	0	106333	57,667	3,100	54,557	
December 17, 2020	162,000	164,033	0	102167	61,867	3,100	58,757	PERCOLATION AND EVAPORATION (5.3 Acre Surface Area)
December 18, 2020	158,000	164,233	0	102167	62,067	3,100	58,957	49,433 Daily Minimum GPD
December 19, 2020	170,000	164,467	0	94933	69,533	3,100	66,424	117,467 Daily Maximum GPD
December 20, 2020	186,000	164,833	0	94933	69,900	3,100	66,791	71,494 Daily Average GPD
December 21, 2020	167,000	166,033	0	94933	71,100	3,100	67,991	2,218,300 Total Monthly Gallons
December 22, 2020	166,000	166,067	0	94933	71,133	3,100	68,024	
December 23, 2020	175,000	165,800	0	94933	70,667	3,100	67,557	PERCOLATION ESTIMATE
December 24, 2020	161,000	165,433	0	77400	68,033	3,100	64,824	48,324 Daily Minimum GPD
December 25, 2020	177,000	166,300	0	68133	98,187	3,100	95,057	114,357 Daily Maximum GPD
December 26, 2020	179,000	166,800	0	68133	98,667	3,100	95,557	68,364 Daily Average GPD
December 27, 2020	193,000	166,367	0	68133	98,233	3,100	95,124	2,119,909 Total Monthly Gallons
December 28, 2020	170,000	167,200	0	68133	99,067	3,100	95,957	
December 29, 2020	170,000	167,000	0	61867	105,133	3,100	102,024	
December 30, 2020	164,000	168,633	0	56467	110,187	3,100	107,057	
December 31, 2020	181,000	168,767	0	49300	117,467	3,100	114,357	



Sunnyslope County
Water District

Sunnyslope County Water District Ridgemark Estates Wastewater Treatment RM I Sequencing Batch Reactor (SBR) Influent - Pond 6 - Percolation/Evaporation Chart





SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # 3 35100001
 Discharge Self-Monitoring Report

Ridgemark Estates Subdivision RM - I Wastewater Treatment Plant Ponds pH MONITORING

Effluent Limits	
6.5	Minimum
8.4	Maximum

Date	Grab Samples											
	Results in mg/l Pond 1			Results in mg/l Pond 3			Results in mg/l Pond 4			Results in mg/l Pond 5		
	pH Sample Site			pH Sample Site			pH Sample Site			pH Sample Site		
	A	B	C	A	B	C	A	B	C	A	B	C
January 1, 2020												
January 2, 2020												
January 3, 2020												
January 4, 2020												
January 5, 2020	7.68	7.65	7.70	Empty			7.43	7.41	7.42	Empty		
January 6, 2020												
January 7, 2020												
January 8, 2020												
January 9, 2020												
January 10, 2020												
January 11, 2020												
January 12, 2020	7.56	7.55	7.62	Empty			7.52	7.44	7.40	Empty		
January 13, 2020												
January 14, 2020												
January 15, 2020												
January 16, 2020												
January 17, 2020												
January 18, 2020												
January 19, 2020	7.69	7.69	7.68	Empty			7.48	7.44	7.49	Empty		
January 20, 2020												
January 21, 2020												
January 22, 2020												
January 23, 2020												
January 24, 2020												
January 25, 2020												
January 26, 2020	7.61	7.66	7.66	Empty			7.46	7.40	7.42	Empty		
January 27, 2020												
January 28, 2020												
January 29, 2020												
January 30, 2020												
January 31, 2020												
February 1, 2020												
February 2, 2020	7.66	7.64	7.67	Empty			7.46	7.42	7.43	Empty		
February 3, 2020												
February 4, 2020												
February 5, 2020												
February 6, 2020												
February 7, 2020												
February 8, 2020												
February 9, 2020	7.71	7.74	7.73	Empty			7.47	7.39	7.44	Empty		
February 10, 2020												
February 11, 2020												
February 12, 2020												
February 13, 2020												
February 14, 2020												
February 15, 2020												
February 16, 2020	7.79	7.86	7.92	Empty			7.47	7.42	7.42	Empty		
February 17, 2020												
February 18, 2020												
February 19, 2020												
February 20, 2020												
February 21, 2020												
February 22, 2020												
February 23, 2020	8.17	8.12	8.27	Empty			7.43	7.35	7.33	Empty		
February 24, 2020												
February 25, 2020												
February 26, 2020												
February 27, 2020												
February 28, 2020												
February 29, 2020												
March 1, 2020	8.24	8.44	8.40	Empty			7.51	7.44	7.41	Empty		
March 2, 2020												
March 3, 2020												
March 4, 2020												
March 5, 2020												
March 6, 2020												
March 7, 2020												
March 8, 2020	8.40	8.53	8.49	Empty			7.56	7.45	7.51	Empty		
March 9, 2020												
March 10, 2020												
March 11, 2020												
March 12, 2020												
March 13, 2020												
March 14, 2020	8.11	8.10	8.32	Empty			7.41	7.37	7.36	Empty		
March 15, 2020												
March 16, 2020												
March 17, 2020												
March 18, 2020												
March 19, 2020												
March 20, 2020												
March 21, 2020												
March 22, 2020	7.92	7.96	7.99	Empty			7.47	7.41	7.36	Empty		
March 23, 2020												
March 24, 2020												
March 25, 2020												
March 26, 2020												
March 27, 2020												
March 28, 2020	7.89	7.87	7.89	Empty			7.61	7.57	7.56	Empty		
March 29, 2020												
March 30, 2020												
March 31, 2020												

See RM - I Lab Sample Site Sheet		
A	=	Effluent Site
B	=	Influent Site
C	=	Third Site

	pH Limit	Exceeded
All Pond Samples	Minimum 6.5	0
All Pond Samples	Maximum 8.4	0

	pH Limit	Exceeded
All Pond Samples	Minimum 6.5	0
All Pond Samples	Maximum 8.4	0

	pH Limit	Exceeded
All Pond Samples	Minimum 6.5	0
All Pond Samples	Maximum 8.4	3



SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # 3 351000001
 Discharge Self-Monitoring Report

Ridgemark Estates Subdivision RM - I Wastewater Treatment Plant Ponds pH MONITORING

Effluent Limits	
6.5	Minimum
8.4	Maximum

Grab Samples

See RM - I Lab Sample Site Sheet		
A	=	Effluent Site
B	=	Influent Site
C	=	Third Site

Date	Results in mg/l			Results in mg/l			Results in mg/l			Results in mg/l		
	Pond 1			Pond 3			Pond 4			Pond 5		
	pH Sample Site			pH Sample Site			pH Sample Site			pH Sample Site		
	A	B	C	A	B	C	A	B	C	A	B	C
April 1, 2020												
April 2, 2020												
April 3, 2020												
April 4, 2020												
April 5, 2020												
April 6, 2020	8.00	8.03	8.05	Empty			7.67	7.74	7.67	Empty		
April 7, 2020												
April 8, 2020												
April 9, 2020												
April 10, 2020												
April 11, 2020	8.19	8.28	8.26	Empty			7.67	7.61	7.64	Empty		
April 12, 2020												
April 13, 2020												
April 14, 2020												
April 15, 2020												
April 16, 2020												
April 17, 2020												
April 18, 2020												
April 19, 2020	8.70	8.24	8.52	Empty			7.50	7.47	7.45	Empty		
April 20, 2020												
April 21, 2020												
April 22, 2020												
April 23, 2020												
April 24, 2020												
April 25, 2020												
April 26, 2020	8.76	8.75	7.67	Empty			7.73	7.65	7.65	Empty		
April 27, 2020												
April 28, 2020												
April 29, 2020												
April 30, 2020												
May 1, 2020												
May 2, 2020												
May 3, 2020												
May 4, 2020												
May 5, 2020	8.59	8.62	8.73	Empty			7.25	7.21	7.26	Empty		
May 6, 2020												
May 7, 2020												
May 8, 2020												
May 9, 2020												
May 10, 2020	8.70	8.80	8.84	Empty			7.45	7.38	7.45	Empty		
May 11, 2020												
May 12, 2020												
May 13, 2020												
May 14, 2020												
May 15, 2020												
May 16, 2020												
May 17, 2020	8.76	8.81	8.86	Empty			7.42	7.35	7.39	Empty		
May 18, 2020												
May 19, 2020												
May 20, 2020												
May 21, 2020												
May 22, 2020												
May 23, 2020												
May 24, 2020	9.26	9.22	9.29	Empty			7.40	7.33	7.36	Empty		
May 25, 2020												
May 26, 2020												
May 27, 2020												
May 28, 2020												
May 29, 2020												
May 30, 2020												
May 31, 2020	9.53	9.60	9.62	Empty			7.48	7.44	7.51	Empty		
June 1, 2020												
June 2, 2020												
June 3, 2020												
June 4, 2020												
June 5, 2020												
June 6, 2020												
June 7, 2020	9.72	9.77	9.71	Empty			7.77	7.85	7.82	Empty		
June 8, 2020												
June 9, 2020												
June 10, 2020												
June 11, 2020												
June 12, 2020												
June 13, 2020												
June 14, 2020	10.35	10.36	10.38	Empty			7.90	8.08	8.14	Empty		
June 15, 2020												
June 16, 2020												
June 17, 2020												
June 18, 2020												
June 19, 2020												
June 20, 2020												
June 21, 2020	11.12	11.24	11.20	Empty			8.35	8.51	8.51	Empty		
June 22, 2020												
June 23, 2020												
June 24, 2020												
June 25, 2020												
June 26, 2020												
June 27, 2020												
June 28, 2020	7.18	8.21	7.29	7.56	7.56	7.62	8.75	8.78	9.23	Empty		
June 29, 2020												
June 30, 2020												

All Pond Samples
 All Pond Samples

pH Limit	Exceeded
Minimum 6.5	0
Maximum 8.4	4

All Pond Samples
 All Pond Samples

pH Limit	Exceeded
Minimum 6.5	0
Maximum 8.4	15

All Pond Samples
 All Pond Samples

pH Limit	Exceeded
Minimum 6.5	0
Maximum 8.4	14



SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # 3 35100001
 Discharge Self-Monitoring Report

Ridgemark Estates Subdivision RM - I Wastewater Treatment Plant Ponds pH MONITORING

Effluent Limits	
6.5	Minimum
8.4	Maximum

Date	Grab Samples											
	Pond 1			Pond 3			Pond 4			Pond 5		
	pH Sample Site			pH Sample Site			pH Sample Site			pH Sample Site		
	A	B	C	A	B	C	A	B	C	A	B	C
July 1, 2020												
July 2, 2020												
July 3, 2020												
July 4, 2020												
July 5, 2020	8.66	8.74	8.77	7.74	7.71	7.82	8.81	8.88	8.95	Empty		
July 6, 2020												
July 7, 2020												
July 8, 2020												
July 9, 2020												
July 10, 2020												
July 11, 2020												
July 12, 2020	10.37	9.13	9.96	7.94	7.84	7.83	7.84	8.31	8.25	Empty		
July 13, 2020												
July 14, 2020												
July 15, 2020												
July 16, 2020												
July 17, 2020												
July 18, 2020												
July 19, 2020	10.06	10.12	9.99	7.66	7.62	7.59	8.30	8.30	8.34	Empty		
July 20, 2020												
July 21, 2020												
July 22, 2020												
July 23, 2020												
July 24, 2020												
July 25, 2020												
July 26, 2020	9.94	9.99	9.97	7.60	7.58	7.62	8.41	8.38	8.41	Empty		
July 27, 2020												
July 28, 2020												
July 29, 2020												
July 30, 2020												
July 31, 2020												
August 1, 2020												
August 2, 2020	10.05	10.10	10.13	7.81	7.77	7.77	8.29	8.50	8.35	Empty		
August 3, 2020												
August 4, 2020												
August 5, 2020												
August 6, 2020												
August 7, 2020												
August 8, 2020												
August 9, 2020	10.13	10.11	10.04	7.67	7.69	7.68	8.36	8.54	8.45	Empty		
August 10, 2020												
August 11, 2020												
August 12, 2020												
August 13, 2020												
August 14, 2020												
August 15, 2020												
August 16, 2020	9.83	8.61	9.82	7.70	7.72	7.68	8.48	8.48	8.51	Empty		
August 17, 2020												
August 18, 2020												
August 19, 2020												
August 20, 2020												
August 21, 2020												
August 22, 2020												
August 23, 2020	9.71	9.72	8.69	7.57	7.57	7.55	8.24	8.28	8.14	Empty		
August 24, 2020												
August 25, 2020												
August 26, 2020												
August 27, 2020												
August 28, 2020												
August 29, 2020												
August 30, 2020	9.72	9.74	9.69	7.57	7.58	7.63	8.46	8.50	8.54	Empty		
August 31, 2020												
September 1, 2020												
September 2, 2020												
September 3, 2020												
September 4, 2020												
September 5, 2020												
September 6, 2020	9.59	9.68	9.53	7.58	7.54	7.56	8.23	8.72	8.76	Empty		
September 7, 2020												
September 8, 2020												
September 9, 2020												
September 10, 2020												
September 11, 2020												
September 12, 2020												
September 13, 2020	9.52	9.56	9.53	7.62	7.67	7.64	8.22	8.50	8.46	Empty		
September 14, 2020												
September 15, 2020												
September 16, 2020												
September 17, 2020												
September 18, 2020												
September 19, 2020												
September 20, 2020	9.70	9.73	9.63	7.56	7.53	7.53	8.39	8.25	8.38	Empty		
September 21, 2020												
September 22, 2020												
September 23, 2020												
September 24, 2020												
September 25, 2020												
September 26, 2020												
September 27, 2020	9.65	9.67	9.61	7.53	7.53	7.55	8.29	8.24	8.24	Empty		
September 28, 2020												
September 29, 2020												
September 30, 2020												

See RM - I Lab Sample Site Sheet		
A	=	Effluent Site
B	=	Influent Site
C	=	Third Site

All Pond Samples
 All Pond Samples

	pH Limit	Exceeded
Minimum	6.5	0
Maximum	8.4	17

All Pond Samples
 All Pond Samples

	pH Limit	Exceeded
Minimum	6.5	0
Maximum	8.4	23

All Pond Samples
 All Pond Samples

	pH Limit	Exceeded
Minimum	6.5	0
Maximum	8.4	16



SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # 3 35100001
 Discharge Self-Monitoring Report

Ridgemark Estates Subdivision RM - I Wastewater Treatment Plant Ponds pH MONITORING

Effluent Limits	
6.5	Minimum
8.4	Maximum

Date	Grab Samples											
	Pond 1			Pond 3			Pond 4			Pond 5		
	pH Sample Site			pH Sample Site			pH Sample Site			pH Sample Site		
	A	B	C	A	B	C	A	B	C	A	B	C
October 1, 2020												
October 2, 2020												
October 3, 2020												
October 4, 2020	9.38	8.99	9.45	7.65	7.62	7.64	8.15	8.14	8.17	Empty		
October 5, 2020												
October 6, 2020												
October 7, 2020												
October 8, 2020												
October 9, 2020												
October 10, 2020												
October 11, 2020	9.45	9.42	9.38	7.62	7.63	7.63	Empty			Empty		
October 12, 2020												
October 13, 2020												
October 14, 2020												
October 15, 2020												
October 16, 2020												
October 17, 2020												
October 18, 2020	9.73	9.69	9.62	7.60	7.59	7.57	Empty			Empty		
October 19, 2020												
October 20, 2020												
October 21, 2020												
October 22, 2020												
October 23, 2020												
October 24, 2020												
October 25, 2020	9.60	9.23	9.69	7.63	7.64	7.63	Empty			Empty		
October 26, 2020												
October 27, 2020												
October 28, 2020												
October 29, 2020												
October 30, 2020												
October 31, 2020												
November 1, 2020	9.85	9.88	9.84	7.66	7.64	7.64	Empty			Empty		
November 2, 2020												
November 3, 2020												
November 4, 2020												
November 5, 2020												
November 6, 2020												
November 7, 2020												
November 8, 2020	9.85	9.88	9.88	7.64	7.62	7.59	Empty			Empty		
November 9, 2020												
November 10, 2020												
November 11, 2020												
November 12, 2020												
November 13, 2020												
November 14, 2020												
November 15, 2020	9.82	9.82	9.76	7.61	7.62	7.64	Empty			Empty		
November 16, 2020												
November 17, 2020												
November 18, 2020												
November 19, 2020												
November 20, 2020												
November 21, 2020												
November 22, 2020	9.44	9.50	9.53	7.65	7.67	7.63	Empty			Empty		
November 23, 2020												
November 24, 2020												
November 25, 2020												
November 26, 2020												
November 27, 2020												
November 28, 2020												
November 29, 2020	9.33	9.37	9.37	7.64	7.67	7.69	Empty			Empty		
November 30, 2020												
December 1, 2020												
December 2, 2020												
December 3, 2020												
December 4, 2020												
December 5, 2020												
December 6, 2020	9.08	9.05	9.02	7.59	7.60	7.64	Empty			Empty		
December 7, 2020												
December 8, 2020												
December 9, 2020												
December 10, 2020												
December 11, 2020												
December 12, 2020												
December 13, 2020	8.71	8.40	8.76	7.70	7.67	7.71	Empty			Empty		
December 14, 2020												
December 15, 2020												
December 16, 2020												
December 17, 2020												
December 18, 2020												
December 19, 2020												
December 20, 2020	8.46	8.49	8.49	8.32	8.29	8.29	Empty			Empty		
December 21, 2020												
December 22, 2020												
December 23, 2020												
December 24, 2020												
December 25, 2020												
December 26, 2020												
December 27, 2020	8.45	8.46	8.44	8.38	8.40	8.41	Empty			Empty		
December 28, 2020												
December 29, 2020												
December 30, 2020												
December 31, 2020												

See RM - I Lab Sample Site Sheet		
A	=	Effluent Site
B	=	Influent Site
C	=	Third Site

All Pond Samples
 All Pond Samples

pH Limit	Exceeded
Minimum 6.5	0
Maximum 8.4	12


All Pond Samples
 All Pond Samples

pH Limit	Exceeded
Minimum 6.5	0
Maximum 8.4	15


All Pond Samples
 All Pond Samples

pH Limit	Exceeded
Minimum 6.5	0
Maximum 8.4	17


Sunnyslope County Water District Ridgemark Estates Wastewater Treatment RM I - Pond 1 - pH




Sunnyslope County Water District
 Ridgemark Estates Wastewater Treatment
RM I - Pond 3 - pH



Sunnyslope County Water District
 Ridgemark Estates Wastewater Treatment
RM I - Pond 4 - pH



Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I - Pond 5 - pH





SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # 3 351000001
 Discharge Self-Monitoring Report
 Monitoring and Reporting Program # R3-2004-0065

See RM - I Lab Sample Site Sheet		
A	=	Effluent Site
B	=	Influent Site
C	=	Third Site

Ridgemark Estates Subdivision
 RM - I Wastewater Treatment Plant Ponds
DISSOLVED OXYGEN MONITORING

DATE	Results in mg/l Pond 1 DO Sample Site			Grab Samples Results in mg/l Pond 3 DO Sample Site			Results in mg/l Pond 4 DO Sample Site			Results in mg/l Pond 5 DO Sample Site		
	A	B	C	A	B	C	A	B	C	A	B	C
	January 1, 2020											
January 2, 2020												
January 3, 2020												
January 4, 2020												
January 5, 2020	5	5	6	Empty			6	6	6	Empty		
January 6, 2020												
January 7, 2020												
January 8, 2020												
January 9, 2020												
January 10, 2020												
January 11, 2020												
January 12, 2020	5	5	5	Empty			6	6	7	Empty		
January 13, 2020												
January 14, 2020												
January 15, 2020												
January 16, 2020												
January 17, 2020												
January 18, 2020												
January 19, 2020	5	4	5	Empty			7	7	7	Empty		
January 20, 2020												
January 21, 2020												
January 22, 2020												
January 23, 2020												
January 24, 2020												
January 25, 2020												
January 26, 2020	4	5	4	Empty			7	7	7	Empty		
January 27, 2020												
January 28, 2020												
January 29, 2020												
January 30, 2020												
January 31, 2020												
February 1, 2020												
February 2, 2020	3	3	3	Empty			6	6	6	Empty		
February 3, 2020												
February 4, 2020												
February 5, 2020												
February 6, 2020												
February 7, 2020												
February 8, 2020												
February 9, 2020	5	5	5	Empty			7	7	7	Empty		
February 10, 2020												
February 11, 2020												
February 12, 2020												
February 13, 2020												
February 14, 2020												
February 15, 2020												
February 16, 2020	7	7	7	Empty			7	6	7	Empty		
February 17, 2020												
February 18, 2020												
February 19, 2020												
February 20, 2020												
February 21, 2020												
February 22, 2020												
February 23, 2020	10	12	12	Empty			7	6	7	Empty		
February 24, 2020												
February 25, 2020												
February 26, 2020												
February 27, 2020												
February 28, 2020												
February 29, 2020												
March 1, 2020	7	9	9	Empty			6	7	6	Empty		
March 2, 2020												
March 3, 2020												
March 4, 2020												
March 5, 2020												
March 6, 2020												
March 7, 2020												
March 8, 2020	7	7	9	Empty			7	7	7	Empty		
March 9, 2020												
March 10, 2020												
March 11, 2020												
March 12, 2020												
March 13, 2020												
March 14, 2020	8	9	9	Empty			7	7	7	Empty		
March 15, 2020												
March 16, 2020												
March 17, 2020												
March 18, 2020												
March 19, 2020												
March 20, 2020												
March 21, 2020												
March 22, 2020	7	7	7	Empty			5	6	6	Empty		
March 23, 2020												
March 24, 2020												
March 25, 2020												
March 26, 2020												
March 27, 2020												
March 28, 2020	7	7	8	Empty			7	6	7	Empty		
March 29, 2020												
March 30, 2020												
March 31, 2020												



SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # 3 351000061
 Discharge Self-Monitoring Report
 Monitoring and Reporting Program # R3-2004-0065

See RM - I Lab Sample Site Sheet		
A	=	Effluent Site
B	=	Influent Site
C	=	Third Site

Ridgemark Estates Subdivision RM - I Wastewater Treatment Plant Ponds DISSOLVED OXYGEN MONITORING

DATE	Results in mg/l Pond 1 DO Sample Site			Grab Samples Results in mg/l Pond 3 DO Sample Site			Results in mg/l Pond 4 DO Sample Site			Results in mg/l Pond 5 DO Sample Site		
	A	B	C	A	B	C	A	B	C	A	B	C
April 1, 2020												
April 2, 2020												
April 3, 2020												
April 4, 2020												
April 5, 2020												
April 6, 2020	6	5	6	Empty			7	7	6	Empty		
April 7, 2020												
April 8, 2020												
April 9, 2020												
April 10, 2020												
April 11, 2020	6	7	6	Empty			7	6	6	Empty		
April 12, 2020												
April 13, 2020												
April 14, 2020												
April 15, 2020												
April 16, 2020												
April 17, 2020												
April 18, 2020												
April 19, 2020	7	6	7	Empty			5	5	4	Empty		
April 20, 2020												
April 21, 2020												
April 22, 2020												
April 23, 2020												
April 24, 2020												
April 25, 2020												
April 26, 2020	4	5	5	Empty			5	5	5	Empty		
April 27, 2020												
April 28, 2020												
April 29, 2020												
April 30, 2020												
May 1, 2020												
May 2, 2020												
May 3, 2020												
May 4, 2020												
May 5, 2020	7	7	8	Empty			5	5	5	Empty		
May 6, 2020												
May 7, 2020												
May 8, 2020												
May 9, 2020												
May 10, 2020	5	6	7	Empty			6	5	5	Empty		
May 11, 2020												
May 12, 2020												
May 13, 2020												
May 14, 2020												
May 15, 2020												
May 16, 2020												
May 17, 2020	6	7	7	Empty			3	6	4	Empty		
May 18, 2020												
May 19, 2020												
May 20, 2020												
May 21, 2020												
May 22, 2020												
May 23, 2020												
May 24, 2020	9	11	12	Empty			6	6	5	Empty		
May 25, 2020												
May 26, 2020												
May 27, 2020												
May 28, 2020												
May 29, 2020												
May 30, 2020												
May 31, 2020	9	9	10	Empty			5	4	6	Empty		
June 1, 2020												
June 2, 2020												
June 3, 2020												
June 4, 2020												
June 5, 2020												
June 6, 2020												
June 7, 2020	6	7	7	Empty			4	5	5	Empty		
June 8, 2020												
June 9, 2020												
June 10, 2020												
June 11, 2020												
June 12, 2020												
June 13, 2020												
June 14, 2020	8	10	10	Empty			4	5	5	Empty		
June 15, 2020												
June 16, 2020												
June 17, 2020												
June 18, 2020												
June 19, 2020												
June 20, 2020												
June 21, 2020	8	9	9	Empty			4	5	5	Empty		
June 22, 2020												
June 23, 2020												
June 24, 2020												
June 25, 2020												
June 26, 2020												
June 27, 2020												
June 28, 2020	10	4	9	4	4	4	5	4	5	Empty		
June 29, 2020												
June 30, 2020												



SUNNYSLOPE COUNTY WATER DISTRICT

Waste Discharge Identification # 3 35100001
 Discharge Self-Monitoring Report
 Monitoring and Reporting Program # R3-2004-0065

See RM - I Lab Sample Site Sheet		
A	=	Effluent Site
B	=	Influent Site
C	=	Third Site

Ridgemark Estates Subdivision RM - I Wastewater Treatment Plant Ponds DISSOLVED OXYGEN MONITORING

DATE	Results in mg/l Pond 1 DO Sample Site			Grab Samples Results in mg/l Pond 3 DO Sample Site			Results in mg/l Pond 4 DO Sample Site			Results in mg/l Pond 5 DO Sample Site		
	A	B	C	A	B	C	A	B	C	A	B	C
July 1, 2020												
July 2, 2020												
July 3, 2020												
July 4, 2020												
July 5, 2020	6	4	5	7	6	7	5	4	4	Empty		
July 6, 2020												
July 7, 2020												
July 8, 2020												
July 9, 2020												
July 10, 2020												
July 11, 2020												
July 12, 2020	7	4	9	7	7	7	4	4	3	Empty		
July 13, 2020												
July 14, 2020												
July 15, 2020												
July 16, 2020												
July 17, 2020												
July 18, 2020												
July 19, 2020	6	6	5	4	4	4	4	5	6	Empty		
July 20, 2020												
July 21, 2020												
July 22, 2020												
July 23, 2020												
July 24, 2020												
July 25, 2020												
July 26, 2020	5	4	4	4	3	4	4	5	5	Empty		
July 27, 2020												
July 28, 2020												
July 29, 2020												
July 30, 2020												
July 31, 2020												
August 1, 2020												
August 2, 2020	7	7	5	4	4	5	6	5	4	Empty		
August 3, 2020												
August 4, 2020												
August 5, 2020												
August 6, 2020												
August 7, 2020												
August 8, 2020												
August 9, 2020	8	8	6	5	5	6	4	5	6	Empty		
August 10, 2020												
August 11, 2020												
August 12, 2020												
August 13, 2020												
August 14, 2020												
August 15, 2020												
August 16, 2020	6	3	6	6	7	6	5	5	4	Empty		
August 17, 2020												
August 18, 2020												
August 19, 2020												
August 20, 2020												
August 21, 2020												
August 22, 2020												
August 23, 2020	4	4	4	5	4	6	3	3	3	Empty		
August 24, 2020												
August 25, 2020												
August 26, 2020												
August 27, 2020												
August 28, 2020												
August 29, 2020												
August 30, 2020	7	7	5	6	5	6	4	6	5	Empty		
August 31, 2020												
September 1, 2020												
September 2, 2020												
September 3, 2020												
September 4, 2020												
September 5, 2020												
September 6, 2020	3	4	3	5	4	5	3	6	5	Empty		
September 7, 2020												
September 8, 2020												
September 9, 2020												
September 10, 2020												
September 11, 2020												
September 12, 2020												
September 13, 2020	6	6	5	4	5	4	3	5	5	Empty		
September 14, 2020												
September 15, 2020												
September 16, 2020												
September 17, 2020												
September 18, 2020												
September 19, 2020												
September 20, 2020	7	6	6	4	5	5	5	6	5	Empty		
September 21, 2020												
September 22, 2020												
September 23, 2020												
September 24, 2020												
September 25, 2020												
September 26, 2020												
September 27, 2020	4	5	5	4	4	5	4	5	5	Empty		
September 28, 2020												
September 29, 2020												
September 30, 2020												



SUNNYSLOPE COUNTY WATER DISTRICT


Waste Discharge Identification # 3 35100001
 Discharge Self-Monitoring Report
 Monitoring and Reporting Program # R3-2004-0065

See RM - I Lab Sample Site Sheet		
A	=	Effluent Site
B	=	Influent Site
C	=	Third Site

Ridgemark Estates Subdivision RM - I Wastewater Treatment Plant Ponds DISSOLVED OXYGEN MONITORING


DATE	Results in mg/l Pond 1 DO Sample Site			Grab Samples Results in mg/l Pond 3 DO Sample Site			Results in mg/l Pond 4 DO Sample Site			Results in mg/l Pond 5 DO Sample Site		
	A	B	C	A	B	C	A	B	C	A	B	C
	October 1, 2020											
October 2, 2020												
October 3, 2020												
October 4, 2020	4	3	5	4	4	5	3	4	4	Empty		
October 5, 2020												
October 6, 2020												
October 7, 2020												
October 8, 2020												
October 9, 2020												
October 10, 2020												
October 11, 2020	4	4	4	6	7	7	Empty			Empty		
October 12, 2020												
October 13, 2020												
October 14, 2020												
October 15, 2020												
October 16, 2020												
October 17, 2020												
October 18, 2020	10	9	8	3	3	4	Empty			Empty		
October 19, 2020												
October 20, 2020												
October 21, 2020												
October 22, 2020												
October 23, 2020												
October 24, 2020												
October 25, 2020	4	5	4	5	4	5	Empty			Empty		
October 26, 2020												
October 27, 2020												
October 28, 2020												
October 29, 2020												
October 30, 2020												
October 31, 2020												
November 1, 2020	10	11	11	6	6	7	Empty			Empty		
November 2, 2020												
November 3, 2020												
November 4, 2020												
November 5, 2020												
November 6, 2020												
November 7, 2020												
November 8, 2020	7	9	10	4	4	5	Empty			Empty		
November 9, 2020												
November 10, 2020												
November 11, 2020												
November 12, 2020												
November 13, 2020												
November 14, 2020												
November 15, 2020	7	7	6	5	5	5	Empty			Empty		
November 16, 2020												
November 17, 2020												
November 18, 2020												
November 19, 2020												
November 20, 2020												
November 21, 2020												
November 22, 2020	7	6	6	7	7	7	Empty			Empty		
November 23, 2020												
November 24, 2020												
November 25, 2020												
November 26, 2020												
November 27, 2020												
November 28, 2020												
November 29, 2020	5	7	6	5	6	6	Empty			Empty		
November 30, 2020												
December 1, 2020												
December 2, 2020												
December 3, 2020												
December 4, 2020												
December 5, 2020												
December 6, 2020	3	3	3	5	5	7	Empty			Empty		
December 7, 2020												
December 8, 2020												
December 9, 2020												
December 10, 2020												
December 11, 2020												
December 12, 2020												
December 13, 2020	4	4	5	8	8	8	Empty			Empty		
December 14, 2020												
December 15, 2020												
December 16, 2020												
December 17, 2020												
December 18, 2020												
December 19, 2020												
December 20, 2020	4	4	4	13	16	17	Empty			Empty		
December 21, 2020												
December 22, 2020												
December 23, 2020												
December 24, 2020												
December 25, 2020												
December 26, 2020												
December 27, 2020	5	5	6	14	9	10	Empty			Empty		
December 28, 2020												
December 29, 2020												
December 30, 2020												
December 31, 2020												

Sunnyslope County Water District
 Ridgemark Estates Wastewater Treatment
RM I - Pond 1 - DO




MRP # R3-2004-0065
 1/23/2021


Sunnyslope County Water District
 Ridgemark Estates Wastewater Treatment
RM I - Pond 3 - DO



Sunnyslope County Water District
 Ridgemark Estates Wastewater Treatment
RM I - Pond 4 - DO



Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I - Pond 5 - DO





Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision

RM - I Sequencing Batch Reactor (SBR) WWTP

Influent Monitoring Results - 24 Hour Composite Sample - mg/l

	Influent 30 Day Average	Influent 30 Day Average	Influent 30 Day Average	Influent 30 Day Average	Influent 30 Day Average	Influent 30 Day Average	Influent 30 Day Average	Influent 30 Day Average	Influent 30 Day Average	Influent 30 Day Average	Influent 30 Day Average	Influent 30 Day Average	Influent 30 Day Average
	Lab	Lab	Lab	Lab	Lab	Lab	Lab	Lab	Lab	Lab	Lab	Lab	Lab
	30 Day Average pH Influent	30 Day Average BOD5 Influent mg/l	30 Day Average Ammonia NH3-N Influent mg/l	30 Day Average Nitrate NO3-N Influent mg/l	30 Day Average Total Kjeldahl TKN Influent mg/l	30 Day Average Total Nitrogen Influent mg/l	30 Day Average Total Suspended Solids TSS Influent mg/l	30 Day Average Sodium Influent mg/l	30 Day Average Chloride Influent mg/l	30 Day Average Total Dissolved Solids TDS Influent mg/l	30 Day Average Nitrite as N Influent mg/l	30 Day Average Sulfate Influent mg/l	30 Day Average Boron Influent mg/l
1/31/2020	7.40	290	NA	NA	54.00	54.00	390	200	330	1400	NA	NA	NA
2/29/2020	7.54	160	NA	NA	69.00	NA	340	170	240	730	NA	NA	NA
3/31/2020	7.53	170	NA	NA	58.00	58.00	140	160	240	750	NA	60.00	0.50
4/30/2020	7.81	360	NA	NA	68.00	68.00	270	200	320	840	NA	NA	NA
5/31/2020	7.48	160	NA	NA	54.00	54.00	100	210	260	890	NA	NA	NA
6/30/2020	7.71	260	NA	NA	54.00	54.00	280	230	320	1000	NA	NA	NA
7/31/2020	7.92	410	NA	NA	61.00	61.00	410	210	330	960	NA	NA	NA
8/31/2020	7.79	200	NA	NA	58.50	58.50	123	230	335	960	NA	NA	NA
9/30/2020	7.84	160	NA	NA	57.00	57.00	110	220	270	1100	NA	180.00	1.10
10/31/2020	7.83	300	NA	NA	53.00	53.00	310	230	290	1100	NA	NA	NA
11/30/2020	7.92	240	NA	NA	72.00	72.00	290	300	490	1200	NA	NA	NA
12/31/2020	7.65	200	NA	NA	62.00	62.00	110	190	290	880	NA	NA	NA
Average	7.70	243	NA	NA	60.04	59.23	239	213	310	984	NA	120.00	0.80



Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065


Ridgemark Estates Subdivision

RM - I Sequencing Batch Reactor (SBR) WWTP


Effluent Monitoring Results - 24 Hour Composite Sample - mg/l

Effluent Limits													
pH	BOD5	Ammonia	Nitrate	TSS			Sodium	Chloride	TDS				
6.5 - 8.4	30	5	5	30			200	200	1,200				
Effluent 30 Day Average	Effluent 30 Day Average	Effluent 30 Day Average	Effluent 30 Day Average	Effluent 30 Day Average	Effluent 30 Day Average	Effluent 30 Day Average	Effluent 30 Day Average	Effluent 30 Day Average	Effluent 30 Day Average	Effluent 30 Day Average	Effluent 30 Day Average	Effluent 30 Day Average	
30 Day Average pH Effluent	30 Day Average BOD5 Effluent mg/l	30 Day Average Ammonia NH3-N Effluent mg/l	30 Day Average Nitrate NO3-N Effluent mg/l	30 Day Average Total Suspended Solids TSS Effluent mg/l	30 Day Average Total Kjeldahl Nitrogen Effluent mg/l	30 Day Average Total Nitrogen Effluent mg/l	30 Day Average Sodium Effluent mg/l	30 Day Average Chloride Effluent mg/l	30 Day Average Total Dissolved Solids (TDS) Effluent mg/l	30 Day Average Nitrite as N Effluent mg/l	30 Day Average Sulfate Effluent mg/l	30 Day Average Boron Effluent mg/l	
1/31/2020	7.60	2.70	0.53	0.29	ND	NA	NA	180	260	730	NA	NA	NA
2/29/2020	7.37	3.70	0.60	0.26	ND	1.90	NA	180	230	670	NA	NA	NA
3/31/2020	7.38	4.00	1.20	0.38	ND	2.90	3.60	160	240	690	NA	64	NA
4/30/2020	7.52	7.50	2.40	0.25	ND	3.80	4.00	180	260	780	NA	NA	NA
5/31/2020	7.48	4.70	1.50	0.32	ND	2.50	2.80	190	240	850	NA	NA	NA
6/30/2020	7.70	3.40	0.53	0.60	ND	1.60	2.20	200	250	820	NA	NA	NA
7/31/2020	7.64	3.40	0.34	0.60	ND	2.00	2.70	200	280	640	0.10	NA	NA
8/31/2020	7.72	2.45	0.44	0.81	ND	1.35	2.25	180	255	845	0.03	NA	NA
9/30/2020	7.76	2.80	0.24	0.67	ND	1.50	2.40	220	270	970	0.22	150	0.83
10/31/2020	7.77	1.00	0.40	0.82	ND	3.00	3.90	230	310	1100	NA	NA	NA
11/30/2020	7.74	5.50	2.30	0.73	6.80	3.70	4.40	190	280	910	NA	NA	NA
12/31/2020	7.51	6.70	0.81	0.54	5.00	3.50	4.20	200	270	880	0.13	NA	NA
Average	7.60	3.99	0.94	0.52	5.90	2.52	3.25	193	262	824	0.12	107	0.83

**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




■ 30 Day Average Total Suspended Solids TSS Influent mg/l ● 30 Day Average Total Suspended Solids TSS Effluent mg/l


**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**



**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




■ 30 Day Average Nitrate NO3-N Influent mg/l

● 30 Day Average Nitrate NO3-N Effluent mg/l


**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**



**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




■ 30 Day Average Total Dissolved Solids TDS Influent mg/l ● 30 Day Average Total Dissolved Solids (TDS) Effluent mg/l


**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart



**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**



Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart





Sunnyslope County Water District

Waste Discharge Identification # 3.351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Effluent Limits									
30 Day Avg- mg/l	TDS	Sodium	Chloride	Nitrate	Ammonia	BODs	TSS	pH Lower	pH Upper
Current Limits	No Interim Limits	No Interim Limits	No Interim Limits	No Interim Limits	No Interim Limits	No Interim Limits	No Interim Limits	6.50	9.50
1/30/08	1,500	300.00	300	10.00	10	60.00	60.00	6.50	9.00
1/30/10	1,200	200.00	200	5.00	5	30.00	30.00	6.50	8.40


Ridgemark Estates Subdivision

RM - I Wastewater Treatment Plant


Pond Final Effluent Monitoring Results - Grab Sample - mg/l

Date	Pond Eff Chloride	Pond Eff Total Dissolved Solids	Pond Eff Nitrite Nitrogen (NO2-N)	Pond Eff Nitrate Nitrogen (NO3-N)	Pond Eff BOD	Pond Eff Soluble BOD	Pond Eff Carbonate Alkalinity	Pond Eff Total Suspended Solids	Pond Eff Sulfate	Pond Eff Boron	Pond Eff Sodium (Na)	Pond Eff Total Nitrogen (as N)	Pond Eff pH	Pond Eff Ammonia as Nitrogen	Pond Eff Total Kjeldahl Nitrogen (TKN)
1/10/2020	260	770	ND	0.44	1.10			0.00			180	1.50	7.60	1.10	1.10
2/1/2020	240	750	ND	0.43	1.40			0.00			190		7.44	0.51	1.90
3/1/2020	250	710	ND	0.48	0.70			0.00	68	0.50	170	3.20		0.70	2.30
4/6/2020	260	790		0.52	6.50			0.00			190	3.30	7.50	1.50	2.70
5/5/2020	260	820	0.18	0.67	2.20			0.00			200	2.90	7.58	1.50	2.00
6/3/2020	270	880	ND	0.27	13.00			9.40			240	2.00	7.76	0.52	1.70
7/2/2020	280	900	0.10	0.50	1.40			7.60			200	2.30	7.58	0.00	1.70
7/2/2020	310	950	0.05	0.00	1.60			0.00			220	1.90	8.21	0.13	1.80
8/7/2020	270	960	0.11	0.91	1.20			0.00			210	2.30	7.66	0.30	1.30
8/29/2020	260	840	0.06	0.61	0.00			0.00			170	0.00	7.90	0.00	0.00
9/27/2020	270	950	0.10	0.92	1.80			ND	140	0.74	190	2.40	7.56	0.12	1.40
10/26/2020	310	1100	ND	0.82	3.00			0.00			230	3.90		0.49	3.00
11/17/2020	280	940	ND	0.72	2.80			ND			200	3.60	7.60	1.70	2.90
12/16/2020	290	970	ND	0.37	16.00			29.00			210	3.40	8.24	ND	3.00
Average	272	881	0.10	0.55	3.76			3.83	104	0.62	200	2.52	7.72	0.66	1.91


**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart




Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart




**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**




**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**



**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**



**Sunnyslope County Water District
Ridgemark Estates Wastewater Treatment
RM I Sequencing Batch Reactor (SBR)
Lab Results 30 Day Average
Chart**





Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision Wastewater Treatment Plant Wastewater Monitoring Water Supply

	Flow Well 5 GPD	Flow Well 8 GPD	LESSALT GPD	Total GPD
1/1/2020	130,964	59,590	576,000	766,484
1/2/2020	182,386	40,000	557,000	779,386
1/3/2020	147,922	25,000	559,000	731,922
1/4/2020	147,922	25,000	564,000	736,922
1/5/2020	147,922	25,000	557,000	729,922
1/6/2020	236,003	42,000	507,000	785,003
1/7/2020	158,673	32,000	591,000	781,673
1/8/2020	169,320	27,000	463,000	659,320
1/9/2020	135,651	48,000	567,000	750,651
1/10/2020	337,645	36,333	552,000	925,978
1/11/2020	337,645	36,333	578,000	951,978
1/12/2020	337,645	36,333	180,000	553,978
1/13/2020	474,713	18,000	203,000	695,713
1/14/2020	365,721	19,000	260,000	644,721
1/15/2020	529,419	28,000	210,000	767,419
1/16/2020	44,643	68,000	482,000	594,643
1/17/2020	81,464	50,000	553,000	684,464
1/18/2020	81,464	50,000	552,000	683,464
1/19/2020	81,464	50,000	644,000	775,464
1/20/2020	179,807	91,000	519,000	789,807
1/21/2020	146,377	57,000	567,000	770,377
1/22/2020	146,700	89,000	569,000	804,700
1/23/2020	202,155	112,000	570,000	884,155
1/24/2020	44,537	39,333	647,000	730,870
1/25/2020	44,537	39,333	687,000	770,870
1/26/2020	44,537	39,333	709,000	792,870
1/27/2020	24,797	18,000	635,000	677,797
1/28/2020	21,084	18,000	578,000	617,084
1/29/2020	22,369	11,000	655,000	688,369
1/30/2020	27,768	28,000	689,000	744,768
1/31/2020	36,864	18,667	662,000	717,530
2/1/2020	36,864	18,667	745,000	800,530
2/2/2020	36,864	18,667	805,000	860,530
2/3/2020	16,120	18,000	781,000	815,120
2/4/2020	16,575	18,000	804,000	838,575
2/5/2020	15,438	18,000	765,000	798,438
2/6/2020	34,262	36,000	827,000	897,262
2/7/2020	51,073	33,000	829,000	913,073
2/8/2020	51,073	33,000	811,000	895,073
2/9/2020	51,073	33,000	716,000	800,073
2/10/2020	54,891	30,000	915,000	999,891
2/11/2020	14,629	31,000	853,000	898,629
2/12/2020	15,301	23,000	804,000	842,301
2/13/2020	16,097	19,000	945,000	980,097
2/14/2020	23,156	17,750	921,000	961,906
2/15/2020	23,156	17,750	804,000	844,906
2/16/2020	23,156	17,750	940,000	980,906
2/17/2020	23,156	17,750	1,005,000	1,045,906
2/18/2020	39,945	32,000	939,000	1,010,945
2/19/2020	15,314	18,000	862,000	895,314
2/20/2020	9,040	31,000	935,000	975,040
2/21/2020	15,962	31,667	930,000	977,629
2/22/2020	15,962	31,667	959,000	1,005,629
2/23/2020	15,962	31,667	968,000	1,045,629
2/24/2020	16,137	32,000	900,000	948,137
2/25/2020	15,906	25,000	919,000	959,906
2/26/2020	16,156	32,000	919,000	967,156
2/27/2020	24,811	33,000	950,000	1,007,811
2/28/2020	41,973	32,000	878,000	951,973
3/1/2020	41,973	32,000	1,097,000	1,170,973
3/2/2020	14,407	32,000	1,008,000	1,054,407
3/3/2020	13,055	32,000	850,000	895,055
3/4/2020	15,365	47,000	936,000	998,365
3/5/2020	16,317	34,000	889,000	939,317
3/6/2020	16,282	35,333	924,000	975,615
3/7/2020	16,282	35,333	958,000	1,009,615
3/8/2020	16,282	35,333	946,000	997,615
3/9/2020	15,223	33,000	934,000	982,223
3/10/2020	9,536	32,000	882,000	923,536
3/11/2020	14,143	36,000	958,000	1,008,143
3/12/2020	16,459	32,000	951,000	999,459
3/13/2020	48,146	32,667	888,000	968,812
3/14/2020	48,146	32,667	945,000	1,025,812
3/15/2020	48,146	32,667	948,000	1,028,812
3/16/2020	6	32,000	933,000	965,006
3/17/2020	-	18,000	801,000	819,000
3/18/2020	-	32,000	983,000	1,015,000
3/19/2020	7,370	33,000	1,061,000	1,101,370
3/20/2020	10,558	18,667	736,000	765,225
3/21/2020	10,558	18,667	892,000	921,225
3/22/2020	10,558	18,667	596,000	625,225
3/23/2020	485,190	103,000	180,000	768,190
3/24/2020	550,066	34,000	326,000	910,066
3/25/2020	157,715	271,000	308,000	736,715
3/26/2020	112,633	379,000	337,000	828,633
3/27/2020	38,283	676,333	284,000	998,616
3/28/2020	38,283	676,333	-	714,616
3/29/2020	38,283	676,333	33,000	747,616
3/30/2020	19,665	81,000	898,000	988,665
3/31/2020	24,358	31,000	792,000	847,358

28%	% Ground
72%	% Surface

Total Flow Gallons

5,069,116	Well 5
1,276,167	Well 8
16,642,000	LESSALT
22,987,283	Total

22%	Well 5	% of Flow
6%	Well 8	% of Flow
72%	LESSALT	% of Flow

6%	% Ground
94%	% Surface

Total Flow Gallons

729,549	Well 5
731,333	Well 8
24,447,000	LESSALT
25,907,883	Total

3%	Well 5	% of Flow
3%	Well 8	% of Flow
94%	LESSALT	% of Flow

19%	% Ground
81%	% Surface

Total Flow Gallons

1,869,722	Well 5
3,614,000	Well 8
23,422,000	LESSALT
28,905,722	Total

6%	Well 5	% of Flow
13%	Well 8	% of Flow
81%	LESSALT	% of Flow



Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision Wastewater Treatment Plant Wastewater Monitoring Water Supply

	Flow Well 5 GPD	Flow Well 8 GPD	LESSALT GPD	Total GPD
7/1/2020	39,336	247,000	945,000	1,231,336
7/2/2020	56,886	239,750	1,067,000	1,363,636
7/3/2020	56,886	239,750	1,014,000	1,310,636
7/4/2020	56,886	239,750	1,154,000	1,450,636
7/5/2020	56,886	239,750	1,143,000	1,439,636
7/6/2020	67,637	275,000	1,107,000	1,449,637
7/7/2020	38,486	290,000	1,126,000	1,454,486
7/8/2020	83,191	253,000	1,165,000	1,501,191
7/9/2020	82,356	331,000	1,076,000	1,489,356
7/10/2020	67,202	235,000	1,113,000	1,415,202
7/11/2020	67,202	235,000	983,000	1,285,202
7/12/2020	67,202	235,000	937,000	1,239,202
7/13/2020	8,211	208,000	1,144,000	1,360,211
7/14/2020	57,530	367,000	1,045,000	1,469,530
7/15/2020	39,853	225,000	1,049,000	1,313,853
7/16/2020	16,472	326,000	1,075,000	1,417,472
7/17/2020	16,002	273,333	1,049,000	1,338,336
7/18/2020	16,002	273,333	905,000	1,194,336
7/19/2020	16,002	273,333	1,202,000	1,491,336
7/20/2020	86,713	273,000	1,046,000	1,405,713
7/21/2020	232,270	600,000	525,000	1,357,270
7/22/2020	482,463	763,000	-	1,245,463
7/23/2020	476,924	747,000	-	1,223,924
7/24/2020	299,466	865,000	-	1,164,466
7/25/2020	299,466	865,000	-	1,164,466
7/26/2020	299,466	865,000	-	1,164,466
7/27/2020	338,632	769,000	243,000	1,350,632
7/28/2020	466,838	760,000	-	1,226,838
7/29/2020	475,955	770,000	-	1,245,955
7/30/2020	432,023	759,000	108,000	1,299,023
7/31/2020	40,826	152,000	731,000	923,826
8/1/2020	40,826	152,000	993,000	1,185,826
8/2/2020	40,826	152,000	1,108,000	1,300,826
8/3/2020	32,074	278,000	1,136,000	1,446,074
8/4/2020	38,877	83,000	1,168,000	1,269,877
8/5/2020	32,611	56,000	1,141,000	1,229,611
8/6/2020	14,744	64,000	1,175,000	1,253,744
8/7/2020	206,099	903,333	-	1,109,432
8/8/2020	206,099	903,333	-	1,109,432
8/9/2020	206,099	903,333	-	1,109,432
8/10/2020	52,282	338,000	887,000	1,277,282
8/11/2020	20,245	159,000	959,000	1,138,245
8/12/2020	15,395	85,000	1,050,000	1,150,395
8/13/2020	25,438	205,000	1,036,000	1,266,438
8/14/2020	20,678	210,000	1,172,000	1,402,678
8/15/2020	20,678	210,000	1,040,000	1,270,678
8/16/2020	20,678	210,000	1,211,000	1,441,678
8/17/2020	25,818	412,000	1,098,000	1,535,818
8/18/2020	16,768	286,000	1,191,000	1,493,768
8/19/2020	16,370	250,000	1,124,000	1,390,370
8/20/2020	15,998	237,000	1,160,000	1,412,998
8/21/2020	16,620	210,000	1,186,000	1,411,620
8/22/2020	16,620	210,000	1,168,000	1,394,620
8/23/2020	16,620	210,000	1,163,000	1,389,620
8/24/2020	15,887	244,000	1,196,000	1,455,887
8/25/2020	11,206	227,000	1,139,000	1,377,206
8/26/2020	19,911	167,000	1,130,000	1,316,911
8/27/2020	33,034	100,000	1,167,000	1,300,034
8/28/2020	16,039	50,333	1,256,000	1,322,373
8/29/2020	16,039	50,333	1,152,000	1,218,373
8/30/2020	16,039	50,333	1,157,000	1,223,373
8/31/2020	15,984	221,000	1,072,000	1,308,984
9/1/2020	224,007	774,000	403,000	1,401,007
9/2/2020	448,285	835,000	-	1,283,285
9/3/2020	494,625	865,000	-	1,359,625
9/4/2020	193,967	931,750	-	1,125,717
9/5/2020	193,967	931,750	-	1,125,717
9/6/2020	193,967	931,750	-	1,125,717
9/7/2020	193,967	931,750	-	1,125,717
9/8/2020	579,904	911,000	-	1,490,904
9/9/2020	350,778	736,000	-	1,086,778
9/10/2020	41,180	217,000	706,000	964,180
9/11/2020	30,683	100,333	867,000	1,118,016
9/12/2020	30,683	100,333	846,000	977,016
9/13/2020	30,683	100,333	952,000	1,083,016
9/14/2020	32,622	187,000	1,007,000	1,226,622
9/15/2020	31,743	268,000	856,000	1,155,743
9/16/2020	34,272	119,000	933,000	1,086,272
9/17/2020	33,346	324,000	802,000	1,159,346
9/18/2020	33,180	281,667	847,000	1,161,846
9/19/2020	33,180	281,667	770,000	1,084,846
9/20/2020	33,180	281,667	806,000	1,120,846
9/21/2020	41,950	375,000	850,000	1,266,950
9/22/2020	34,825	333,000	798,000	1,165,825
9/23/2020	114,648	357,000	792,000	1,263,648
9/24/2020	345,177	675,000	268,000	1,288,177
9/25/2020	266,343	886,667	-	1,153,010
9/26/2020	266,343	886,667	-	1,153,010
9/27/2020	266,343	886,667	-	1,153,010
9/28/2020	487,369	845,000	-	1,332,369
9/29/2020	470,941	723,000	-	1,193,941
9/30/2020	378,830	874,000	-	1,252,830

44%	% Ground
56%	% Surface

Total Flow Gallons	
4,871,215	Well 5
13,342,000	Well 8
23,241,000	LESSALT
41,454,215	Total

12%	Well 5	% of Flow
32%	Well 8	% of Flow
56%	LESSALT	% of Flow

23%	% Ground
77%	% Surface

Total Flow Gallons	
1,287,438	Well 5
7,768,000	Well 8
31,083,000	LESSALT
40,148,438	Total

3%	Well 5	% of Flow
19%	Well 8	% of Flow
77%	LESSALT	% of Flow

61%	% Ground
39%	% Surface

Total Flow Gallons	
5,548,142	Well 5
16,298,000	Well 8
13,695,000	LESSALT
35,541,142	Total

18%	Well 5	% of Flow
46%	Well 8	% of Flow
39%	LESSALT	% of Flow



Sunnyslope County Water District

Waste Discharge Identification # 3. 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision Wastewater Treatment Plant Wastewater Monitoring Water Supply

	Flow Well 5 GPD	Flow Well 8 GPD	LESSALT GPD	Total GPD
10/1/2020	538,934	784,000	-	1,322,934
10/2/2020	337,400	834,667	-	1,172,066
10/3/2020	337,400	834,667	-	1,172,066
10/4/2020	337,400	834,667	-	1,172,066
10/5/2020	389,547	964,000	-	1,353,547
10/6/2020	490,862	772,000	-	1,262,862
10/7/2020	365,372	855,000	172,000	1,422,372
10/8/2020	310,821	736,000	-	1,046,821
10/9/2020	342,863	857,000	-	1,199,863
10/10/2020	342,863	857,000	-	1,199,863
10/11/2020	342,863	857,000	-	1,199,863
10/12/2020	484,425	698,000	-	1,182,425
10/13/2020	415,887	661,000	-	1,076,887
10/14/2020	532,200	790,000	-	1,322,200
10/15/2020	404,183	866,000	-	1,270,183
10/16/2020	327,963	828,667	-	1,156,629
10/17/2020	327,963	828,667	-	1,156,629
10/18/2020	327,963	828,667	-	1,156,629
10/19/2020	355,283	950,000	-	1,305,283
10/20/2020	456,697	763,000	-	1,219,697
10/21/2020	232,911	914,000	683,000	1,828,911
10/22/2020	119,511	155,000	469,000	743,511
10/23/2020	52,914	511,333	496,000	1,060,247
10/24/2020	52,914	511,333	489,000	1,053,247
10/25/2020	52,914	511,333	462,000	1,026,247
10/26/2020	108,772	585,000	501,000	1,194,772
10/27/2020	74,793	364,000	718,000	1,156,793
10/28/2020	91,105	506,000	748,000	1,345,105
10/29/2020	66,183	305,000	756,000	1,127,183
10/30/2020	48,054	371,000	718,000	1,137,054
10/31/2020	48,054	371,000	778,000	1,197,054
11/1/2020	48,054	371,000	796,000	1,215,054
11/2/2020	102,149	426,000	729,000	1,257,149
11/3/2020	72,270	360,000	771,000	1,203,270
11/4/2020	82,340	459,000	779,000	1,319,340
11/5/2020	62,077	337,000	768,000	1,167,077
11/6/2020	63,962	287,667	749,000	1,100,628
11/7/2020	63,962	287,667	774,000	1,125,628
11/8/2020	63,962	287,667	657,000	1,008,628
11/9/2020	68,165	408,000	791,000	1,267,165
11/10/2020	76,592	246,000	756,000	1,078,592
11/11/2020	76,592	246,000	791,000	1,113,592
11/12/2020	65,491	88,000	770,000	923,491
11/13/2020	55,398	184,667	783,000	1,023,065
11/14/2020	55,398	184,667	774,000	1,014,065
11/15/2020	55,398	184,667	744,000	984,065
11/16/2020	47,614	322,000	778,000	1,147,614
11/17/2020	32,239	70,000	790,000	892,239
11/18/2020	40,628	198,000	724,000	962,628
11/19/2020	37,256	43,000	800,000	880,256
11/20/2020	32,326	222,333	779,000	1,033,659
11/21/2020	32,326	222,333	782,000	1,036,659
11/22/2020	32,326	222,333	754,000	1,008,659
11/23/2020	56,819	279,000	763,000	1,104,819
11/24/2020	46,748	180,000	775,000	1,001,748
11/25/2020	63,023	230,200	816,000	1,109,223
11/26/2020	63,023	230,200	735,000	1,028,223
11/27/2020	63,023	230,200	769,000	1,062,223
11/28/2020	63,023	230,200	768,000	1,061,223
11/29/2020	63,023	230,200	766,000	1,059,223
11/30/2020	87,742	290,000	750,000	1,127,742
12/1/2020	53,073	184,000	770,000	1,007,073
12/2/2020	74,901	334,000	790,000	1,198,901
12/3/2020	76,086	386,000	770,000	1,232,086
12/4/2020	57,184	311,000	773,000	1,141,184
12/5/2020	57,184	311,000	758,000	1,126,184
12/6/2020	57,184	311,000	784,000	1,152,184
12/7/2020	81,340	363,000	767,000	1,211,340
12/8/2020	70,315	252,000	738,000	1,060,315
12/9/2020	63,515	322,000	763,000	1,148,515
12/10/2020	114,568	301,000	744,000	1,159,568
12/11/2020	42,012	114,333	801,000	957,345
12/12/2020	42,012	114,333	764,000	920,345
12/13/2020	42,012	114,333	757,000	913,345
12/14/2020	41,838	54,000	734,000	829,838
12/15/2020	0	12,000	714,000	726,000
12/16/2020	-	-	732,000	732,000
12/17/2020	8,781	86,000	754,000	848,781
12/18/2020	13,741	128,000	815,000	956,741
12/19/2020	13,741	128,000	736,000	877,741
12/20/2020	13,741	128,000	770,000	911,741
12/21/2020	-	218,000	769,000	987,000
12/22/2020	33,788	203,000	764,000	1,000,788
12/23/2020	29,758	159,000	773,000	961,758
12/24/2020	42,011	152,750	714,000	908,761
12/25/2020	42,011	152,750	822,000	1,016,761
12/26/2020	42,011	152,750	767,000	961,761
12/27/2020	42,011	152,750	812,000	1,006,761
12/28/2020	67,254	160,000	764,000	991,254
12/29/2020	67,042	139,000	784,000	990,042
12/30/2020	70,286	168,000	770,000	1,008,286
12/31/2020	47,965	98,000	781,000	926,965

83%	% Ground
17%	% Surface

Total Flow Gallons	
9,077,887	Well 5
22,008,000	Well 8
6,212,000	LESSALT
37,297,887	Total

24%	Well 5	% of Flow
59%	Well 8	% of Flow
17%	LESSALT	% of Flow

29%	% Ground
71%	% Surface

Total Flow Gallons	
1,739,257	Well 5
7,639,000	Well 8
23,006,000	LESSALT
32,384,257	Total


5%	Well 5	% of Flow
24%	Well 8	% of Flow
71%	LESSALT	% of Flow

24%	% Ground
76%	% Surface

Total Flow Gallons	
1,447,140	Well 5
5,902,000	Well 8
23,723,000	LESSALT
31,072,140	Total

5%	Well 5	% of Flow
19%	Well 8	% of Flow
76%	LESSALT	% of Flow

Sunnyslope County Water District
Wastewater Water Supply Monitoring
Well 5 & 8, LESSALT



Sunnyslope County Water District

Waste Discharge Identification # 3 351000001
 Discharge Self-Monitoring Report
 Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision RM - I SBR Wastewater Treatment Plant Wastewater Monitoring Water Supply Well # 5

Grab Sample mg/l

Date	Nitrate as (N)	Sulfate	Boron	Total Hardness	Chloride	Residual Filterable TDS @ 180 c	Sodium	Total Gallons Supplied	% Supplied
January 31, 2020								5,032,253	22
February 28, 2020								688,194	3
March 31, 2020								729,566	3
Total Flow Sampled 3-4-2020	2.6	180	0.97		130	790	130	6,450,013	8
April 30, 2020								988,749	3
May 31, 2020								1,643,947	4
June 30, 2020								1,683,959	4
Total Flow Apr May June								4,316,656	4
July 31, 2020								4,871,215	12
August 31, 2020								1,287,439	3
September 30, 2020								5,548,142	16
Total Flow Sampled 9-2-2020	2.3	190	1		120	790	130	11,706,796	10
October 31, 2020								9,077,887	24
November 30, 2020								1,739,257	5
December 31, 2020								1,447,140	5
Total Flow Oct Nov Dec								12,264,284	12
Average	4	197	1		125	789	130	6,246,977	18

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001
 Discharge Self-Monitoring Report
 Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision RM - I SBR Wastewater Treatment Plant Wastewater Monitoring Water Supply Well # 8

Grab Sample mg/l

Date	Nitrate as (N)	Sulfate	Boron	Total Hardness	Chloride	Residual Filterable TDS @ 180 c	Sodium	Total Gallons Supplied	% Supplied
January 31, 2020								1,276,167	6
February 28, 2020								731,333	3
March 31, 2020								3,645,000	13
Total Flow Sampled 3-4-2020	1.4	210	1.00		95	770	120	5,652,500	7
April 30, 2020								2,547,000	8
May 31, 2020								6,432,333	17
June 30, 2020								8,047,667	20
Total Flow Apr May June								17,027,000	16
July 31, 2020								13,342,000	32
August 31, 2020								7,768,000	19
September 30, 2020								16,298,000	46
Total Flow Sampled 9-2-2020	2.7	190	0.92		130	820	120	37,408,000	32
October 31, 2020								22,008,000	59
November 30, 2020								7,639,000	24
December 31, 2020								5,902,000	19
Total Flow Oct Nov Dec								35,549,000	35
Average	4	191	1		122	787	113	16,589,023	49

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001
 Discharge Self-Monitoring Report
 Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision RM - I SBR Wastewater Treatment Plant Wastewater Monitoring Water Supply **LESSALT WTP**

Grab Sample mg/l

Date	Nitrate as (N)	Sulfate	Boron	Total Hardness	Chloride	Residual Filterable TDS @ 180 c	Sodium	Total Gallons Supplied	% Supplied
January 31, 2020								16,642,000	73
February 28, 2020								24,447,000	95
March 31, 2020								23,422,000	84
Total Flow Sampled 3-4-2020	0.25	35	0.18		82	280	57	64,511,000	84
April 30, 2020								26,478,000	88
May 31, 2020								29,525,000	79
June 30, 2020								30,932,000	76
Total Flow Apr May June								86,935,000	80
July 31, 2020								23,241,000	56
August 31, 2020								31,093,000	77
September 30, 2020								13,695,000	39
Total Flow Sampled 9-2-2020	0	32	0.2		69	250	52	68,029,000	58
October 31, 2020								6,212,000	17
November 30, 2020								23,006,000	71
December 31, 2020								23,723,000	76
Total Flow Oct Nov Dec								52,941,000	53
Average	0	38	0		91	288	63	29,532,250	77

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001
 Discharge Self-Monitoring Report
 Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision RM - I SBR Wastewater Treatment Plant Wastewater Monitoring Water Supply Flow Proportional Results mg/l

Grab Sample mg/l

Date	Nitrate as (N)	Sulfate	Boron	Total Hardness	Chloride	Residual Filterable TDS @ 180 c	Sodium
January 31, 2020							
February 28, 2020							
March 31, 2020							
Total Flow Sampled 3-4-2020	0.53	60	0.31		87	359	68
April 30, 2020							
May 31, 2020							
June 30, 2020							
Total Flow Apr May June							
July 31, 2020							
August 31, 2020							
September 30, 2020							
Total Flow Sampled 9-2-2020	1.09	98	0.51		94	486	82
October 31, 2020							
November 30, 2020							
December 31, 2020							
Total Flow Oct Nov Dec							
Average	3.18	142	0.64		108	639	99



Sunnyslope Water District

Section B

Compliance and Performance


Sunnyslope County Water District

3570 Airline Highway
Hollister, California 95023-9702
Phone (831) 637-4670
Fax (831) 637-1399

Compliance and Performance

The Ridgemark WWTP has consistently treated wastewater effluent for Biochemical Oxygen Demand (BOD), Total Suspended Solids (TSS), Ammonia, Nitrites and Nitrates as specified by the WDR permit from the RWQCB. The secondary treatment process is a biochemical oxidation process that uses microorganism to stabilize organic matter, measured by a reduction in BOD. The secondary treatment process was also designed to remove nitrogen by converting ammonia to nitrate (nitrification) and then to nitrogen gas (denitrification) which is released to the atmosphere. TSS (including biomass) will settle out of the wastewater and are removed as a waste solids product. Overloading a wastewater pond with BOD constituents can result in nuisance odor generation. Source control of BOD constituents, additional pretreatment prior to discharge to the pond was practiced in preventing a pond from generating nuisance odors. The Biological Oxygen Demand (BOD) and Total Suspended Solids (TSS) percent removal efficiency throughout the year were proficient on average of 98.4% and 99.6% removal efficiency respectively for the calendar year of 2020.

Ridgemark WWTP treatment process and effluent water quality are meeting all permit requirements including the above mentioned along with TDS and Sodium with the exception of Chlorides. The treatment process is not designed to remove Total Dissolved Solids (TDS), Sodium, or Chlorides so the main strategy for salinity control is by reducing influent salinity through reducing water softener use.



Sunnyslope County Water District

3570 Airline Highway
Hollister, California 95023-9702
Phone (831) 637-4670
Fax (831) 637-1399

Noncompliance


Chlorides

SSCWD has not been able to meet the discharge requirements for chlorides due to delays encountered in the building of a potable water supply which has lower hardness and eliminates and/or reduces the need for customers to use brine discharging water softeners. After considering groundwater treatment and receiving opposition from other agencies, SSCWD joined San Benito County Water District, the City of Hollister, and San Benito County in the development of the Hollister Urban Area Water Plan (HUAWP). The HUAWP was completed and included the upgrade of the existing Lessalt Water Treatment Plant and the construction of a new surface water treatment plant called the West Hills Water Treatment Plant. These two facilities, associated pipelines, and pump stations will allow high quality drinking water to be delivered throughout the Hollister Urban Area.

Corrective Actions(s):

Chlorides

Sunnyslope continues to make progress with meeting the salinity requirements of the WDRs. The addition of higher quality surface water deliveries to customers, providing rebates for the removal of salt discharging water softeners, and adopting an ordinance banning the installation of new salt discharging water softeners is bringing the District closer to compliance. The District is now in compliance with TDS, Sodium and we are continuing our efforts to reduce chloride levels in the system. The District will continue its outreach and education of customers in partnership with the City of Hollister and San Benito County Water District to promote the improvement of drinking water quality and the removal of salt discharging water softeners.





BOD					TSS					Ammonia				
	RM I	RM I	mg/l	Removal Efficiency		RM I	RM I	mg/l	Removal Efficiency		RM I	RM I	mg/l	Removal Efficiency
	Average Monthly Flow	Influent	Effluent	Percent		Average Monthly Flow	Influent	Effluent	Percent		Average Monthly Flow	Influent	Effluent	Percent
Date	MGD	BOD	BOD		Date	MGD	Total Suspended Solids (TSS)	Total Suspended Solids		Nitrite as N	MGD	Start Time	Ammonia (NH3-N)	
January 1, 2020	0.149452	290	3	99.1%	January 1, 2020	0.149452	390	0	100.0%	January 1, 2020	0.149452	72.40	0.53	99%
February 1, 2020	0.146759	160	4	97.7%	February 1, 2020	0.146759	340	0	100.0%	February 1, 2020	0.146759	62.80	0.60	99%
March 1, 2020	0.158065	170	4	97.6%	March 1, 2020	0.158065	140	0	100.0%	March 1, 2020	0.158065	44.50	1.20	97%
April 1, 2020	0.164700	360	8	97.9%	April 1, 2020	0.164700	270	0	100.0%	April 1, 2020	0.164700	55.90	2.40	96%
May 1, 2020	0.167871	160	5	97.1%	May 1, 2020	0.167871	100	0	100.0%	May 1, 2020	0.167871	48.40	1.50	97%
June 1, 2020	0.161767	260	3	98.7%	June 1, 2020	0.161767	280	0	100.0%	June 1, 2020	0.161767	69.00	0.53	99%
July 1, 2020	0.162806	410	3	99.2%	July 1, 2020	0.162806	410	0	100.0%	July 1, 2020	0.162806	73.50	0.34	100%
August 1, 2020	0.162097	200	2	98.8%	August 1, 2020	0.162097	123	0	100.0%	August 1, 2020	0.162097	69.90	0.44	99%
September 1, 2020	0.157967	160	3	98.3%	September 1, 2020	0.157967	110	0	100.0%	September 1, 2020	0.157967	69.80	0.24	100%
October 1, 2020	0.161065	300	1	99.7%	October 1, 2020	0.161065	310	0	100.0%	October 1, 2020	0.161065		0.40	
November 1, 2020	0.164167	240	6	97.7%	November 1, 2020	0.164167	290	7	97.7%	November 1, 2020	0.164167		2.30	
December 1, 2020	0.167226	200	7	96.7%	December 1, 2020	0.167226	110	5	95.5%	December 1, 2020	0.167226		0.80	
	1.923939	2910	48	98.4%		1.923939	2873	12	99.6%		1.923939	566	11	98.0%



Chloride						TDS					Nitrate				
	RM I	RM II	RM I	mg/l	Removal Efficiency		RM I	RM I	mg/l	Removal Efficiency		RM I	RM I	mg/l	Removal Efficiency
	Average Monthly Flow	Average Monthly Flow	Influent	Effluent	Percent		Average Monthly Flow	Influent	Effluent	Percent		Average Monthly Flow	Influent	Effluent	Percent
Date	MGD		Chloride (Cl)	Chloride		Date	MGD	Total Dissolved Solids (TDS)	Total Dissolved Solids (TDS)		Date	MGD	Nitrate (NO3-N + NO2-N)	Nitrate Nitrogen (NO3-N)	
January 1, 2020	0.149452	0	330	260	21%	January 1, 2020	0.149452	1400	730	47.9%	January 1, 2020	0.149452	0.00	0.29	
February 1, 2020	0.146759	0	240	230	4%	February 1, 2020	0.146759	730	670	8.2%	February 1, 2020	0.146759	0.00	0.26	
March 1, 2020	0.158065	0	240	240	0%	March 1, 2020	0.158065	750	690	8.0%	March 1, 2020	0.158065	0.00	0.36	
April 1, 2020	0.1647	0	320	260	19%	April 1, 2020	0.164700	840	780	7.1%	April 1, 2020	0.164700	0.00	0.25	
May 1, 2020	0.167871	0	360	240	33%	May 1, 2020	0.167871	890	850	4.5%	May 1, 2020	0.167871	0.00	0.32	
June 1, 2020	0.161767	0	320	250	22%	June 1, 2020	0.161767	1000	820	18.0%	June 1, 2020	0.161767	0.00	0.60	
July 1, 2020	0.162806	0	330	280	15%	July 1, 2020	0.162806	960	640	33.3%	July 1, 2020	0.162806	0.62	0.60	3%
August 1, 2020	0.162097		335	255	24%	August 1, 2020	0.162097	960	845	12.0%	August 1, 2020	0.162097	0.00	0.81	
September 1, 2020	0.157967		270	270	0%	September 1, 2020	0.157967	1100	970	11.8%	September 1, 2020	0.157967	0.00	0.67	
October 1, 2020	0.161065		290	340	-17%	October 1, 2020	0.161065	1100	1100	0.0%	October 1, 2020	0.161065	0.00	0.82	
November 1, 2020	0.164167		490	280	43%	November 1, 2020	0.164167	1200	910	24.2%	November 1, 2020	0.164167	0.00	0.73	
December 1, 2020	0.167226		290	270	7%	December 1, 2020	0.167226	880	880	0.0%	December 1, 2020	0.167226	0.00	0.54	
	1.923939		3815	3175	16.8%		1.923939	11810	9885	16.3%		1.923939	1	6	-906.4%

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision

Wastewater Treatment Plant

Wastewater Monitoring Well # 1

MG/L - Location: next to Pond # 6 (WWMW Pond 6N)

Units mg/l

Date	Nitrate as Nitrogen (NO3-N + NO2-N)	Chloride (CL)	Residual Filterable TDS @ 180 c	Sodium (NA)	pH	Boron	Sulfate (SO4)	Nitrite (NO2-N)	Total Nitrogen (as N)	Total Kjeldahl Nitrogen (TKN)	Depth to Water (Feet) 500 Above Sea Level
3/3/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	250
6/3/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	250
9/1/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	237
12/1/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	235
Average	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	243

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision

Wastewater Treatment Plant

Wastewater Monitoring Well # 2

MG/L - Location: Southside Road

Units mg/l

Date	Nitrate as Nitrogen (NO3-N + NO2-N)	Chloride (CL)	Residual Filterable TDS @ 180 c	Sodium (NA)	pH	Boron	Sulfate (SO4)	Nitrite (NO2-N)	Total Nitrogen (as N)	Total Kjeldahl Nitrogen (TKN)	Depth to Water (Feet) 380 Above Sea Level
3/3/2020	6	220	840	96	7.66	0.48	60	ND	6	ND	44
6/3/2020	5.5	230	780		7.58			ND	5.5	ND	45
9/2/2020	6.4	210	700	92	7.49	0.48	49	ND	6.4	ND	45
12/8/2020	6.6	220	710	96	7.41			ND	6.6	ND	46
Average	6.13	220	757.5	95	7.54	0.48	54.5	ND	6.13	ND	45

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision

Wastewater Treatment Plant

Wastewater Monitoring Well # 3

Location: RM - II - next to Pond 4-3

Units mg/l

Date	Nitrate as Nitrogen (NO3-N + NO2-N)	Chloride (CL)	Residual Filterable TDS @ 180 c	Sodium (NA)	pH	Boron	Sulfate (SO4)	Nitrite (NO2-N)	Total Nitrogen (as N)	Total Kjeldahl Nitrogen (TKN)	Depth to Water (Feet) 548 Above Sea Level
3/3/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	115
6/3/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	115
9/1/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	115
12/1/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	116
Average	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	115

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report
Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision
Wastewater Treatment Plant

Wastewater Monitoring Well # 4

Location: Pond 6 South by Gate

Units mg/l

Date	Nitrate as Nitrogen (NO3-N + NO2-N)	Chloride (CL)	Residual Filterable TDS @ 180 c	Sodium (NA)	pH	Boron	Sulfate (SO4)	Nitrite (NO2-N)	Total Nitrogen (as N)	Total Kjeldahl Nitrogen (TKN)	Depth to Water (Feet) 507 Above Sea Level
3/3/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	119
6/3/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	119
9/2/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	119
12/1/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	119
Average	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	119

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision

Wastewater Treatment Plant

Wastewater Monitoring Well # 5

Location: RM - 1 - next to Pond 4 & 5

Units mg/l

Date	Nitrate as Nitrogen (NO3-N + NO2-N)	Chloride (CL)	Residual Filterable TDS @ 180 c	Sodium (NA)	pH	Boron	Sulfate (SO4)	Nitrite (NO2-N)	Total Nitrogen (as N)	Total Kjeldahl Nitrogen (TKN)	Depth to Water (Feet) 526 Above Sea Level
3/3/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	192
6/3/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	192
9/2/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	192
12/1/2020	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	192
Average	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	Dry	192

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision

Wastewater Treatment Plant

Wastewater Monitoring Well # 6

Location: RM - II - next to Pond 2

Units mg/l

Date	Nitrate as Nitrogen (NO3-N + NO2-N)	Chloride (CL)	Residual Filterable TDS @ 180 c	Sodium (NA)	pH	Boron	Sulfate (SO4)	Nitrite (NO2-N)	Total Nitrogen (as N)	Total Kjeldahl Nitrogen (TKN)	Depth to Water (Feet) 528 Above Sea Level
3/3/2020	3.3	560	1300	190	7.67	0.47	31	ND	3.3	ND	86
6/3/2020	3.2	560	1300		7.48			ND	3.2	ND	86
9/2/2020	3.9	590	1200	220	7.5	0.54	36	ND	3.9	ND	86
12/8/2020	3.5	550	1200		7.48			ND	3.5	ND	86
Average	3.48	565	1250	205	7.53	0.51	33.5	ND	3.5	ND	86

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision Wastewater Treatment Plant Wastewater Monitoring Wells

Depth to Water in Feet

	Monitoring Well # 1 (500 feet Above Sea Level)	Monitoring Well # 2 (380 feet Above Sea Level)	Monitoring Well # 3 (548 feet Above Sea Level)	Monitoring Well # 4 (507 feet Above Sea Level)	Monitoring Well # 5 (526 feet Above Sea Level)	Monitoring Well # 6 (528 feet Above Sea Level)
3/3/2020	250	44	115	119	192	86
6/3/2020	250	45	115	119	192	86
9/1/2020	237	45	115	119	192	86
12/1/2020	235	46	115	119	192	86

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

**Ridgemark Estates Subdivision
Wastewater Treatment Plant
Wastewater Monitoring Wells
pH Monitoring Results mg/l**

Grab Sample

	Monitoring Well # 1	Monitoring Well # 2	Monitoring Well # 3	Monitoring Well # 4	Monitoring Well # 5	Monitoring Well # 6
3/3/2020	Dry	7.66	Dry	Dry	Dry	8
6/3/2020	Dry	7.58	Dry	Dry	Dry	7
9/1/2020	Dry	7.49	Dry	Dry	Dry	8
12/1/2020	Dry	7.41	Dry	Dry	Dry	7

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision

Wastewater Treatment Plant

Wastewater Monitoring Wells

TDS Monitoring Results mg/l

Grab Sample

	Monitoring Well # 1	Monitoring Well # 2	Monitoring Well # 3	Monitoring Well # 4	Monitoring Well # 5	Monitoring Well # 6	Water Supply
3/3/2020	Dry	840	Dry	Dry	Dry	1300	
6/3/2020	Dry	780	Dry	Dry	Dry	1300	
9/1/2020	Dry	700	Dry	Dry	Dry	1200	
12/1/2020	Dry	710	Dry	Dry	Dry	1200	

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision

Wastewater Treatment Plant

Wastewater Monitoring Wells

Sodium Monitoring Results mg/l

Grab Sample

	Monitoring Well # 1	Monitoring Well # 2	Monitoring Well # 3	Monitoring Well # 4	Monitoring Well # 5	Monitoring Well # 6	Water Supply
3/3/2020	Dry	96	Dry	Dry	Dry	190	
6/3/2020	Dry		Dry	Dry	Dry		
9/1/2020	Dry	92	Dry	Dry	Dry	220	
12/1/2020	Dry	96	Dry	Dry	Dry		

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision

Wastewater Treatment Plant

Wastewater Monitoring Wells

Chloride Monitoring Results mg/l

Grab Sample

	Monitoring Well # 1	Monitoring Well # 2	Monitoring Well # 3	Monitoring Well # 4	Monitoring Well # 5	Monitoring Well # 6	Water Supply
3/3/2020	Dry	220	Dry	Dry	Dry	560	
6/3/2020	Dry	230	Dry	Dry	Dry	560	
9/1/2020	Dry	210	Dry	Dry	Dry	590	
12/1/2020	Dry	220	Dry	Dry	Dry	550	

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision

Wastewater Treatment Plant

Wastewater Monitoring Wells

Boron Monitoring Results mg/l

	Grab Sample						Water Supply
	Monitoring Well # 1	Monitoring Well # 2	Monitoring Well # 3	Monitoring Well # 4	Monitoring Well # 5	Monitoring Well # 6	
3/3/2020	Dry	0	Dry	Dry	Dry	0	
6/3/2020	Dry		Dry	Dry	Dry		
9/1/2020	Dry	0	Dry	Dry	Dry	1	
12/1/2020	Dry		Dry	Dry	Dry		

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision

Wastewater Treatment Plant

Wastewater Monitoring Wells

Sulfate Monitoring Results mg/l

	Grab Sample						Water Supply
	Monitoring Well # 1	Monitoring Well # 2	Monitoring Well # 3	Monitoring Well # 4	Monitoring Well # 5	Monitoring Well # 6	
3/3/2020	Dry	60.0	Dry	Dry	Dry	31	38.8
6/3/2020	Dry		Dry	Dry	Dry		
9/1/2020	Dry	49.0	Dry	Dry	Dry	36	67.1
12/1/2020	Dry		Dry	Dry	Dry		

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

**Ridgemark Estates Subdivision
Wastewater Treatment Plant
Wastewater Monitoring Wells
Nitrite (as N) Monitoring Results mg/l**

Grab Sample

	Monitoring Well # 1	Monitoring Well # 2	Monitoring Well # 3	Monitoring Well # 4	Monitoring Well # 5	Monitoring Well # 6
3/3/2020	Dry	ND	Dry	Dry	Dry	ND
6/3/2020	Dry	ND	Dry	Dry	Dry	ND
9/1/2020	Dry	ND	Dry	Dry	Dry	ND
12/1/2020	Dry	ND	Dry	Dry	Dry	ND

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report
Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision Wastewater Treatment Plant Wastewater Monitoring Wells Nitrate (as N) Monitoring Results mg/l

	Grab Sample						
	Monitoring Well # 1	Monitoring Well # 2	Monitoring Well # 3	Monitoring Well # 4	Monitoring Well # 5	Monitoring Well # 6	Water Supply
3/3/2020	Dry	6.00	Dry	Dry	Dry	3	
6/3/2020	Dry	5.50	Dry	Dry	Dry	3	
9/1/2020	Dry	6.40	Dry	Dry	Dry	4	
12/1/2020	Dry	6.60	Dry	Dry	Dry	4	

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

**Ridgemark Estates Subdivision
Wastewater Treatment Plant
Wastewater Monitoring Wells**

Total Kjeldahl Nitrogen (TKN) (as N) Monitoring Results mg/l

Grab Sample

	Monitoring Well # 1	Monitoring Well # 2	Monitoring Well # 3	Monitoring Well # 4	Monitoring Well # 5	Monitoring Well # 6
3/3/2020	Dry	ND	Dry	Dry	Dry	ND
6/3/2020	Dry	ND	Dry	Dry	Dry	ND
9/1/2020	Dry	ND	Dry	Dry	Dry	ND
12/1/2020	Dry	ND	Dry	Dry	Dry	ND

Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

**Ridgemark Estates Subdivision
Wastewater Treatment Plant
Wastewater Monitoring Wells**

Total Nitrogen (as N) Monitoring Results mg/l

Grab Sample

	Monitoring Well # 1	Monitoring Well # 2	Monitoring Well # 3	Monitoring Well # 4	Monitoring Well # 5	Monitoring Well # 6
3/3/2020	Dry	6	Dry	Dry	Dry	3
6/3/2020	Dry	6	Dry	Dry	Dry	3
9/1/2020	Dry	6	Dry	Dry	Dry	4
12/1/2020	Dry	7	Dry	Dry	Dry	4



Sunnyslope Water District

Section C

Flow Evaluation

Engineering Technical Report

Sunnyslope County Water District

Subject: 2020 Annual Engineering Technical Report
Prepared For: Regional Water Quality Control Board
Certified by: Drew Lander, P.E. 79561 (Expires 9/30/2022), General Manager
Prepared by: Rob Hillebrecht, P.E. 88972 (Expires 9/30/2022), Associate Engineer
Reviewed by: Jose Rodriguez, Water & Wastewater Superintendent
Date: January 21, 2021

The purpose of this Technical Memorandum (TM) is to meet the Annual Engineering Report requirements of the Regional Water Quality Control Board (RWQCB) Waste Discharge Requirement (WDR) Order No. R3-2004-0065 (December 3, 2004).

Annual Engineering Reports must be submitted by January 30th every year commencing in 2006. The report will evaluate the performance and capacity of the wastewater treatment and disposal system. The report shall contain a hydraulic balance analysis of facility inputs and outputs including influent flow, precipitation, infiltration/percolation, and evaporation for the facility and shall quantify disposal capacity of the facility based on actual operating data. The reports shall be prepared and certified by, or under the supervision/review of a registered professional engineer registered in California and possessing applicable experience in wastewater engineering and planning.

1	Introduction	1
2	Capital Project Activities	1
3	Hydraulic Balance Analysis	2
3.1	Influent Flows	3
3.2	Precipitation and Evaporation	3
3.3	Percolation	5
3.4	Water Balance Summary	7
4	Treatment Process Performance	8
5	Past and Future Steps	9

1 Introduction

As identified in Section E, paragraph 7, of WDR R3-2004-0065 for the Sunnyslope County Water District (SSCWD), an annual engineering technical report shall be submitted to the Regional Water Quality Control Board (RWQCB) to evaluate the performance and capacity of the wastewater treatment and disposal system for the Ridgemark Wastewater Treatment Plant (Ridgemark WWTP) facility. The main aspect of this annual report is a water balance analysis. The following sections of this document summarize the information required by the RWQCB for the annual reports.

2 Capital Project Activities

In 2011 Percolation Pond 3 at Ridgemark I (RM I) was retired in order to prepare for the construction of the Ridgemark WWTP sequential batch reactors where a portion of Percolation Pond 3 had been located.

Construction of these sequential batch reactors were completed and began wastewater treatment at the end of 2012. Treatment Pond 2 at RM I was then retired from service and construction began on the sludge treatment and drying beds where Treatment Pond 2 had been. At the end of 2012, Treatment Pond 1 was also retired from wastewater treatment service and placed into service as a sludge storage and treatment pond until the new wastewater sludge treatment and drying facilities at RM I were completed. In 2013 the sludge treatment tank and drying beds were completed and Treatment Pond 1 was retired from sludge treatment. Treatment Pond 1 remains as an emergency overflow sludge disposal site.

In 2013, Ridgemark II (RM II) Treatment Ponds 1 & 2 and Percolation Ponds 3 & 4 were decommissioned as part of the consolidation of the two wastewater treatment sites at the Ridgemark Wastewater Treatment Plant (Ridgemark WWTP) on the RM I site.

Rehabilitation activities on percolation ponds from 2005 through 2020 are summarized in Table 2-1. These activities ensure that adequate percolation rates are maintained to effectively dispose of treated wastewater.

Table 2-1: Ridgemark I Maintenance Activities

Date	Item
2005	RM I, Ponds 3 & 4 drained, dried and solids removed
1/4/06 – 1/12/06	Pumping from Pond 4 at RM II to Pond 4 at RM I
July-Aug 2006	Bypass pumping from Pond 2 at RM I to Pond 4
10/30/06 – 12/3/06	Pumping from Pond 4 at RM II to Pond 4 at RM I
November 2006	Sludge removed from bottom of Pond 5 at RM I. Pond bottom ripped
November 2007	Ponds 3 & 4 at Ridgemark I. Pond bottoms ripped.
Jan-Dec 2007	Pumping effluent from Pond 4 at RM II to Pond 4 at RM I
August 2008	Ponds 3 & 4 at Ridgemark I. Pond bottoms ripped.
August 2009	Percolation Pond 4 was ripped to improve its percolation rates.
August 2010	Percolation Ponds 4 & 5 were ripped to improve their percolation rates.
September 2013	Percolation Ponds 4 & 6 were ripped to improve their percolation rates.
June 2014	Percolation Pond 5 was ripped to improve its percolation rates.
July 2015	Percolations Pond 3 & 4 were ripped to improve their percolation rates.
October 2015	Percolation Pond 5 was ripped to improve its percolation rates.
October 2016	Percolation Ponds 3 & 4 were ripped to improve their percolation rates.
August 2017	Percolation Pond 5 was ripped to improve its percolation rates.
December 2017	Percolation Pond 4 was ripped to improve its percolation rates.
November 2018	Percolation Pond 3 was ripped to improve its percolation rates.
December 2020	Percolation Pond 4 was ripped to improve its percolation rates.

3 Hydraulic Balance Analysis

The hydraulic balance analysis is performed for the period spanning January 2020 through December 2020. The following sections describe the data used in the water balance and summarize the results.

January 2020

C:\Users\jose\AppData\Local\Microsoft\Windows\NetCache\Content.Outlook\1XN2290N\2020 Annual Engineer Technical Report.docx

3.1 Influent Flows

Influent flows are based on the magnetic flow meter data at the headworks of the Ridgemark WWTP. The total annual influent flow to the Ridgemark WWTP in 2020 was 180.14 acre-feet per year (AFY). This represents a 6.8% increase in annual influent flow as a direct result of the Covid-19 pandemic and the large number of individuals working from home. It is expected that after the pandemic passes, influent flows will subside and return closer to their historic average of about 170 AFY.

Table 3-1: Facility Influent Flows (Monthly Average) to Influent SBR

Month	Ridgemark WWTP Influent (gpd)	Ridgemark WWTP Influent (gallons)
Jan-20	149,452	4,633,000
Feb-20	146,759	4,256,000
Mar-20	158,065	4,900,000
Apr-20	164,700	4,941,000
May-20	167,871	5,204,000
Jun-20	161,767	4,853,000
Jul-20	162,806	5,047,000
Aug-20	162,097	5,025,000
Sep-20	157,967	4,739,000
Oct-20	161,065	4,993,000
Nov-20	164,167	4,925,000
Dec-20	167,226	5,184,000
Annual Total (Gallons)		58,700,000
Annual Total (Acre Feet)		180.14
Annual Average(gpd)	160,328	

Note: Influent flow rate is the average daily value over each month.

3.2 Precipitation and Evaporation

Precipitation data for the water balance is based on the California Irrigation Management Information System (CIMIS) station #126 located at the San Benito County Water District (SBCWD) offices (approximately 3-miles from the Ridgemark WWTP). The monthly precipitation for 2020 is shown in Table 3-2.

January 2020

C:\Users\jose\AppData\Local\Microsoft\Windows\NetCache\Content.Outlook\1XN2290N\2020 Annual Engineer Technical Report.docx

Table 3-2: 2020 Precipitation Data

Month	Precipitation (in)
January 2020	1.39
February 2020	0
March 2020	2.79
April 2020	1.18
May 2020	0.41
June 2020	0.24
July 2020	0.14
August 2020	0.02
September 2020	0.00
October 2020	0.00
November 2020	0.42
December 2020	0.75
Annual Total	7.34

Evaporation data from CIMIS Station 126 Table 3-4 presents pan evaporation data for 2020. Pond evaporation rates are assumed to be 75% of pan evaporation rates to compensate for the extra heat transmitted to water through a pan's metal sides. Pond evaporation is thus calculated at 39.00 inches per year. With precipitation during 2020 being 7.34 inches as shown in Table 3-2, the annual net pond evaporation was 31.66 inches.

Table 3-4: Pan and Pond Evaporation Data

Month	Pan Evaporation (in)*	Pond Evaporation (in)
January 2020	1.60	1.20
February 2020	2.80	2.10
March 2020	3.15	2.36
April 2020	4.54	3.41
May 2020	6.52	4.89
June 2020	7.16	5.37
July 2020	6.97	5.23
August 2020	6.24	4.68
September 2020	4.80	3.60
October 2020	4.14	3.11
November 2020	2.26	1.70
December 2020	1.82	1.37
Annual Total	52.00	39.00

*Source: CIMIS Station 126 for 2020

Pond 4 was in operation from Jan.-May during which period it experienced 5.77 inches of rain and 13.96 inches of evaporation. The pond was partially full with an average surface area of 0.6 acres. The equation below demonstrates the volume of evaporated water during this period.

January 2020

C:\Users\jose\AppData\Local\Microsoft\Windows\NetCache\Content.Outlook\1XN2290N\2020 Annual Engineer Technical Report.docx

$$(13.96 \text{ in} - 5.77 \text{ in}) \times \frac{1 \text{ ft}}{12 \text{ in}} \times 0.6 \text{ ac} = 0.41 \text{ ac ft}$$

Pond 3 filled from June-Oct. 2020 and was full from Oct.-Dec. During this time it experienced 1.75 inches of rain and 25.06 inches of evaporation. Being as Pond 3 is rather small and the surface area does not significantly change with its fullness, the minor changes in surface area as the pond filled can be neglected. Therefore, Pond 3 is assumed to have a water surface area of 0.3 acres through this whole period. The equation below demonstrates the volume of evaporated water during this period.

$$(25.06 \text{ in} - 1.75 \text{ in}) \times \frac{1 \text{ ft}}{12 \text{ in}} \times 0.3 \text{ ac} = 0.58 \text{ ac ft}$$

Pond 6 received some water from Oct.-Dec. but did not fill and had at most 0.1 acres of water surface. During this time it experienced 1.17 inches of rain and 6.18 inches of evaporation. The equation below demonstrates the volume of evaporated water during this period.

$$(6.18 \text{ in} - 1.75 \text{ in}) \times \frac{1 \text{ ft}}{12 \text{ in}} \times 0.1 \text{ ac} = 0.04 \text{ ac ft}$$

Therefore, the water balance regarding precipitation and evaporation is a net removal of approximately **1.76** acre feet of treated effluent in 2020.

3.3 Percolation

Operation in 2020

The primary means of wastewater disposal for the Ridgemark facilities is through percolation of the treated wastewater via disposal ponds. The Ridgemark WWTP facility has 4 disposal ponds and the decommissioned RM II facility has 2 disposal ponds. The Ridgemark WWTP disposal ponds are operated on a rotation schedule rather than all being simultaneously active. This allows for regular ripping and other maintenance to be done on ponds not in service.

From January 1st, 2020 – May 28th, 2020 treated effluent was directed to Pond 4 for percolation while the other ponds remained dry. Then starting on May 29th, 2020 effluent from the Ridgemark WWTP was directed to Pond 3 to allow Pond 4 to dry and be ripped. By October 6th, 2020 Pond 3 had filled and the excess water beyond the percolation capacity of Pond 3 was pumped to Pond 6. Effluent was redirected to Pond 4 on December 15, 2020 after it had been ripped to maintain its high percolation rate.

Historical Background

From the commissioning of the RM I ponds in 1974 until 2005 the percolation ponds at RM I were never drained or ripped to maintain high percolation rates. As the percolation rates slowly decreased due to plugging of the pores in the soil, the District developed additional percolation ponds to dispose of the effluent. Percolation Pond 5 was constructed in 1984 directly south of Ponds 3 and 4. Percolation Pond 6 was later constructed in 1992 for additional percolation capacity. In 2006, Sunnyslope hired RMC to conduct a Long-term Wastewater Management Plan as there were continuing percolation capacity issues. A key determination of this study was the need to improve the percolation rates in Sunnyslope's existing ponds through regular ripping and regular maintenance. Prior to maintenance that was performed on RM I Ponds 3 and 4 in 2005, the percolation rate for Ponds 3, 4, and 5 at RM I was estimated to be only 0.34 inches/day (SSCWD *Long-Term Wastewater Management Plan*, RMC 2006). This was mainly due to

decades of accumulated solids which largely sealed the bottom of the ponds and hindering the natural percolation rates of the soil.

However, after Ponds 3 and 4 were drained, dried, and had the solids removed Pond 4 was observed to have a percolation rate of 5.97 in/day in August 2006. Ponds 3 and 5 were estimated to have percolation rate of 3 in/day. While the Pond 6 percolation rate was originally estimated to be the maximum observed percolation rate of 3.82 in/day based on the Water Balance in the *Long-Term Wastewater Management Plan*, subsequent percolation monitoring in Pond 6 was performed that indicated a percolation rate range between 1.0 in/day and 3.0 in/day depending on level in the pond. An average Pond 6 percolation rate of 1.75 in/day (SSCWD *Long-term Wastewater Management Plan*) was assumed for the capacity analysis. RM II Ponds 3 and 4 have an estimated percolation capacity of 1.37 in/day (SSCWD *Long-Term Wastewater Management Plan*) but have been decommissioned since 2013.

Updated Percolation Analysis

The improved quality of the treated wastewater with the operation of the Ridgemark WWTP and the continued ripping of Percolation Ponds 3, 4, and 5 have significantly improved the percolation rates of these ponds.

Pond 4 operated as the single percolation pond for a 148-day period from January through May of 2020 when it disposed of approximately 23.4 million gallons or 71.8 acre-feet. Over this time period approximately 0.4 acre-feet was lost to evaporation as shown in Section 3.2. The water level in the pond had minimal variation indicating that flow into the pond roughly equaled the volume of water leaving via percolation and evaporation. Therefore, approximately 71.4 acre-feet percolated. Pond 4 was partially full for an effective surface area of about 0.6 acres. The equation below calculates the daily percolation rate.

$$\frac{71.4 \text{ AF}}{148 \text{ day}} \times \frac{1}{0.6 \text{ ac}} \times \frac{12 \text{ in}}{1 \text{ ft}} = 9.7 \frac{\text{in}}{\text{day}}$$

In 2018 immediately following ripping of Pond 4, a percolation rate of 22.3 in/day was calculated by this method. The significant decrease in percolation rate indicates the sealing of soil pores. This highlights the importance of regular maintenance ripping in the ponds. Thus an average percolation rate of 16 in/day is used for capacity analysis in Table 3-3.

Pond 3 was operated from late May through mid-December. During this 201 day period, approximately 26.3 million gallons or 80.7 acre-feet was disposed of with 0.6 acre-feet attributable to evaporation. Thus it is assumed that 80.1 acre-feet percolated in Pond 3. The effective surface area of Pond 3 is 0.3 acres, neglecting the minor surface area variations as the pond filled. The equation below calculates the daily percolation rate for Pond 3.

$$\frac{80.1 \text{ AF}}{201 \text{ day}} \times \frac{1}{0.3 \text{ ac}} \times \frac{12 \text{ in}}{1 \text{ ft}} = 15.9 \frac{\text{in}}{\text{day}}$$

Pond 3 had been ripped before being placed in operation so this percolation rate is assumed to be its maximum. A slightly more conservative percolation rate of 12 in/day is used for the capacity analysis in Table 3-3.

Though approximately 9.0 million gallons or 27.6 acre-feet were directed to Pond 6 over a 168 day period, a sufficient water level equilibrium was never achieved to conduct this form of percolation rate calculation. Therefore, the percolation rate of 1.75 inches/day from the 2006 Long-Term Wastewater Management Plan

January 2020

will be assumed for Table 3-3. Pond 5 was not operated in 2020 but the a similar percolation rate calculation conducted in 2018 revealed a percolation rate of 8.5 in/day.

Disposal Capacity

Table 3-3 summarizes the maximum surface areas, percolation rates, and annual maximum percolation capacities for each disposal pond.

Table 3-3: Ridgemark Disposal Pond Maximum Surface Area

Pond	Max Surface Area (acres)	Percolation Rate (in/day)	Annual Max Capacity (AFY)
Pond 3	0.3	12	110
Pond 4	0.7	16.0	340
Pond 5	1.2	8.5	310
Pond 6	2.1	1.75 *	110
RM II Pond 3 (not used)	1.1	1.37	45
RM II Pond 4 (not used)	1.1	1.37	45

* Percolation Rate for Percolation Pond 6 has not been recalculated since the Ridgemark WWTP sequential batch reactor plant upgrade and continued pond ripping. Thus the percolation rates may be significantly higher than shown.

The Annual Maximum Capacity for each percolation pond was determined using the equation below.

$$\text{Max Surface Area acres} \times \text{Percolation Rate} \frac{\text{in}}{\text{day}} \times 365 \frac{\text{days}}{\text{year}} \times \frac{\text{foot}}{12 \text{ in}} = \text{Annual Max Capacity AFY}$$

By adding the annual maximum capacity of Ridgemark WWTP Ponds 3, 4, 5, and 6, the cumulative maximum percolation capacity is approximately **870 AFY**. RM II Ponds 3 and 4 are no longer in active operation and therefore are not considered in the cumulative annual maximum percolation capacity but could be utilized with minor infrastructural changes.

3.4 Water Balance Summary

The purpose of the water balance analysis was to identify the 2020 disposal balance and assess the disposal capacity of the facilities. Table 3-5 summarizes the actual influent and disposal quantities for Ridgemark WWTP in 2020.

Table 3-5: 2020 Water Balance Summary

Site	Total Influent Raw WW Flow (AF)	Net Evaporation (AF)	Treated WW Effluent Pond Percolation (AF)
Ridgemark WWTP	180.14	1.76	178.38
RM II (Decommissioned)	N/A	N/A	N/A

Using the percolation information from Table 3-3, the total disposal capacity at Ridgemark WWTP is 870 AF per year. In 2020, only 20% of overall percolation capacity was utilized. The District will continue to monitor and observe percolation rates in 2021 to further refine the estimated percolation rates. Substantially higher percolation rates have been observed in Ponds 3, 4, and 5 since the completion of the Sequential Batch Reactor Treatment Plant and with regular ripping of the ponds. This has likely also significantly increased percolation rate in 6 as well, but this pond has not yet been utilized to the point of percolation equilibrium which is necessary for the analysis.

In the third quarter 2013, the RM II facility was decommissioned, and all wastewater flows were redirected to the Ridgemark WWTP. The total disposal capacity for the RM II facility is calculated at 90 AFY based on the RM II Pond 3 and 4 percolation rate of 1.37 in/day. Some infrastructure improvements would be required to utilize these ponds for percolation. Treatment Pond 1 at the Ridgemark II facility was converted to a Ridgemark II lift station emergency overflow holding pond while Treatment Pond 2 was abandoned.

4 Treatment Process Performance

Table 4-1 summarizes the average influent and effluent water quality at the Ridgemark WWTP facility and summarizes WDR water quality regulations that are in effect since 2010. Ridgemark WWTP treatment process and effluent water quality are meeting all permit requirements with the exception of Chlorides.

Table 4-1: 2020 Average Influent and Effluent Water Quality

Existing Water Quality Parameter	RM I SBR Influent	RM I SBR Effluent	RM I % Removal	2010 Permit Requirement
TDS (mg/L)	984	824	N/A	1,200
Sodium (mg/L)	213	193	N/A	200
Chloride (mg/L)	310	262	N/A	200
Nitrate as N (mg/L)	NA	0.52	N/A	5
Ammonia as Nitrogen (mg/L)	NA	0.94	N/A	5
Total Nitrogen (mg/L)	59.23	3.25	94.5%	
BOD ₅ (mg/L)	242.5	3.99	98.4%	30
TSS (mg/L)	239.38	0.98	99.6%	30
pH	7.70	7.60	N/A	6.5-8.4

Data is average of 12 monthly sampling events from Jan – Dec 2020.

The Ridgemark Wastewater Treatment Plant's SBR treatment process has consistently treated the wastewater effluent to within regulation standards for Nitrate, Ammonia, BOD₅, TSS, and pH since it began operation at the end of 2012. The treatment process is not designed to remove TDS, Sodium, or Chlorides so the main strategy for salinity control is by reducing influent salinity through reducing water softener use.

The District achieved compliance with TDS regulations in 2015 and has continued to remain under the limit through 2020. The effluent TDS has been drastically reduced from previous concentrations that were

consistently above 1,600mg/L in 2014, to a current annual average concentration of 824 mg/L. This is a decrease of 48.5% in six years.

In 2018, treated wastewater effluent met the regulatory limit for Sodium of 200mg/l and has continued to meet it through 2020. This is a significant accomplishment as Sodium concentrations were as much as 400mg/l in 2014 and have decreased by over 50% to meet the regulation. Sodium concentrations in the effluent have been on a consistent downward trend correlating to the District's salinity management efforts.

Along with the Sodium and TDS levels, the effluent Chloride concentration has been steadily declining from 580mg/L in 2014 to 262mg/L in 2020. This represents a decrease of 55% and shows significant progress toward achieving compliance. However, this decrease in Chlorides is beginning to slow as many salinity management measures are already being practiced. Thus, Sunnyslope will redouble its efforts to reduce residential water softener use. Water softeners remain the largest contributor to Chlorides in the wastewater influent and effluent. Based on the current trend from 2014 through 2020, it is projected that the effluent quality may be in full compliance with the Chloride regulation as early as 2023.

5 Past and Future Steps

In order to reduce the Ammonia, BOD₅, and TSS levels in the treated wastewater at the RM I and II wastewater treatment plants, a new SBR treatment plant designed and built as Ridgemark WWTP. The construction contract was awarded in May 2011 and the Sequential Batch Reactors were operational by the end of 2012. Construction of the sludge treatment and drying beds was completed in 2013. RM II influent flow was rerouted to Ridgemark WWTP for treatment in the third quarter of 2013 to consolidate all wastewater treatment at that site. Since its construction, the Ridgemark WWTP has always met all Ammonia, BOD₅, and TSS regulations.

In order to address the salinity regulations, the District has worked with the City of Hollister, San Benito County Water District, San Benito County, and other stakeholders to develop agreement on the preferred regional projects and strategies. In 2008, SSCWD joined the Governance Committee of the Hollister Area Urban Water and Wastewater Management Plan in order to become an integral part of this regional effort to improve potable water and wastewater quality. The strategy laid out through this plan was to increase treatment and distribution of softer high quality surface water, thus reducing the regions reliance on the hard groundwater. Therefore, domestic customers in Sunnyslope and Hollister could remove or reduce the use of their water softeners. These water softeners are a significant source of salt for the wastewater stream and a primary reason for the salinity issues with wastewater effluent.

In June 2013, Sunnyslope County Water District, the City of Hollister, and San Benito County Water District entered into a Water Supply and Treatment Agreement to implement the entire Hollister Urban Area Water and Wastewater Master Plan and Coordinated Water Supply and Treatment Plan. The three major water supply and treatment components for the Coordinated Water Supply and Treatment Plan were to upgrade the Lessalt Surface Water Treatment Plant, to construct a new West Hills Surface Water Treatment Plant along with the Crosstown Pipeline, and to build a North (San Benito) County Groundwater Bank to supply these two surface water treatment plants in time of drought.

The Upgrade to the Lessalt Water Treatment Plant, pump station, and a potable water pipeline connecting the Lessalt surface water treatment plant to the Ridgemark Pressure Zone was completed in December 2014. These facilities now allow the Ridgemark Pressure Zone (which includes most Ridgemark WWTP customers) to receive softer surface water from Lessalt.

The West Hills Water Treatment Plant was constructed and began operation in 2017. This plant can supply up to 4.5 MGD of soft surface water to customers in Hollister. This will significantly improve the salinity parameters at the Hollister Regional Domestic Water Reclamation Facility. The Crosstown Pipeline was completed in September 2019 and began moving treated water from West Hills to

January 2020

C:\Users\jose\AppData\Local\Microsoft\Windows\NetCache\Content.Outlook\1XN2290N\2020 Annual Engineer Technical Report.docx

Sunnyslope's Middle Pressure Zone. This can provide softer water to the remaining Ridgemark WWTP customers who were not receiving water from Lessalt. Additionally, most Middle Zone customers add to the Hollister Water Reclamation Facility sewer stream. Improved water quality for them can thus further improve salinity at that facility.

The North County Groundwater Bank project is intended to ensure sufficient high quality surface water is available to the Lessalt and West Hills water treatment plants. The Phase 1 Feasibility study began in late 2019 to evaluate the potential water quality and quantity from this project. Additionally, it considers various engineering, financing, environmental, and political issues and opportunities that could be solved with this regional project.

Because of the benefits provided by these projects, Sunnyslope has been in cooperation with the Water Resources Association of San Benito County (WRA) has been conducting a significant educational campaign through door hanger distribution, website posts, direct outreach at community events, and in the annual Drinking Water Quality Report. The main goal of this outreach is to reduce the use of self-regenerating water softeners. These water softeners are a significant source of TDS, Sodium, and Chloride in the wastewater stream. Rebates of \$250-\$300 for customers who remove their brine discharging water softeners have been applied to 21 sewer customers in 2020. At least 237 customers, (representing approximately 20% of total sewer customers) have removed their water softeners through the program since the Lessalt WTP Upgrade in 2014. Additionally, in February 2015 the District adopted new codes prohibiting the replacement and/or installation of brine discharging water softeners.

Section D

Operator Certification



**Sunnyslope County
Water District**



Sunnyslope County Water District

Certification Renewal Dates

Name	Certificate	Renewal Date	Expiration Date	Grade	Cert. #	Operator #	From This Date
Jose J. Rodriguez	W/W Treatment	12/14/2023	12/14/2023	5	V-9646		
Dee J. Burbank, Jr	W/W Treatment	1/2/2022	1/2/2022	3	III-43830		
Adan Cervantes	W/W Treatment	12/15/2023	12/15/2023	3	III-28756		
Luis Vasquez-Herrera	W/W Treatment	7/1/2019	7/1/2022	3	41555		
Abel Alvarez	W/W Treatment	2/8/2023	2/8/2023	2	I-39670		
Kevin Castro	W/W Treatment	7/26/2021	7/27/2021	2	II-39672		
Bazilio Hernandez	W/W Treatment	3/11/2019	3/11/2022	1	44153		
David Padilla	W/W Treatment	6/30/2021	6/30/2021	1	I-10194		
Manuel T. Chavez	W/W Treatment	6/30/2023	6/30/2023	2	II-10633		
Ernie Eclarin	W/W Treatment	2/3/2023	2/3/2023	2	I-10632		
Scott Watson	W/W Treatment	3/9/2021	3/9/2021	2	I-39671		
Troy E. Quick	W/W Treatment	1/17/2022	1/17/2022	1			
Diego Perez-Bribiesca	W/W Treatment	4/23/2023	4/23/2023	OIT			
Michael Vargas-Garcia	W/W Treatment	6/7/2022	6/7/2022	OIT			
Dee J. Burbank, Jr	CWEA - Collection	10/31/2021	10/31/2021	2	1308219739		5/1/2017
Jose J. Rodriguez	CWEA - Collection	8/31/2021	8/31/2021	1	1308220684		
Michael Vargas-Garcia	CWEA - Collection	9/30/2021	9/30/2021	1	1308221190		
Abel Alvarez	CWEA - Collection	10/31/2021	10/31/2021	1	1308231303		
Diego Perez-Bribiesca	CWEA - Collection	10/31/2021	10/31/2021	1	1308231511		
Dee J. Burbank, Jr	CWEA - Mechanical Technologist	6/30/2021	6/30/2021	1	1308220413		
Jose J. Rodriguez	CWEA - Industrial Waste Treatment Plant	8/31/2021	8/31/2021	1	1308214672		
Adan Cervantes	CWEA - Laboratory 1	5/31/2021	5/31/2021	1	80731013		
Luis Vasquez-Herrera	CWEA - Laboratory 1	4/30/2021	5/1/2021	1	120431002		



Sunnyslope Water District

Section E

Operation and Maintenance

Operational Description

**Dual Mode SBR (Sequencing Batch Reactor) /
ICEAS[®]
(Intermittent Cycle Extended Aeration System)
NDN Process**

**Ridegemark I WWTP
Sunnyslope, California USA**

Project No. 09-7087A

**ITT Water & Wastewater
Sanitaire Products
Brown Deer, Wisconsin, USA**

July 2011



Issue, Revision, and Approval Record

Issue	Date	Sections Changed	Description of Changes	Changes Made By	Approved By
A	07/12/2011	na	na	SOS	FBM; 7/25/11
B	09/13/2011	5.1, 5.3	Plant Design Parameters, WAS Set Point	SOS	FBM; 9/15/11

Table of Contents

1.0	Introduction	1
2.0	Abbreviations	2
3.0	SBR and ICEAS Process.....	3
3.1	Basin Design	3
3.2	Process Overview.....	4
3.3	Basin Layers	5
3.4	Basin Hydraulics and Loading	5
3.5	Nitrification-Denitrification Process Operation.....	5
3.6	Cycle Time – NDN Process, 2 Basins	5
3.7	Storm Cycle Transitions	7
4.0	Equipment Operation	8
4.1	Control System.....	8
4.2	Decanters.....	8
4.3	Blowers.....	8
4.4	Air Valves.....	9
4.5	Aeration Systems	9
4.6	Influent Valves	9
4.7	Mixers.....	9
4.8	Waste Activated Sludge (WAS) Pumps.....	9
4.9	Level Sensing Equipment.....	10
4.10	Dissolved Oxygen (DO) Control System	10
4.11	SBR Scum Valves	10
4.12	Utility Water Spray Control Valves	10
5.0	Plant Specifics.....	11
5.1	Plant Design Parameters	11
5.2	Dissolved Oxygen Control Set Points	12
5.3	Waste Activated Sludge (WAS) Pump Set Points	13
5.4	Unit Processes Preceding The Sanitaire System.....	13
5.5	Unit Processes Following The Sanitaire System	13

1.0 Introduction

ITT Water & Wastewater – Sanitaire Products is the provider of the Sanitaire process and associated equipment. This Operational Description describes the basic operation of the process and is specific to the following plant:

Project Name:	Ridgemark I WWTP
Project Location:	Sunnyslope, CA USA
Sanitaire Number:	09-7087A
Process, Basins:	NDN, 2-Basin

This document will be used in conjunction with the Functional Design Specification (FDS) for the system. This document is a process overview, whereas, the FDS will describe in detail the control of each system component, interlocks between components, operating ranges and how to change control set points.

2.0 Abbreviations

The following abbreviations apply to this Operational Description and the FDS for the control logic for the plant.

ADWF	Average Dry Weather Flow	NDNP	Nitrification/Denitrification/Phosphorus Process
Auto	Automatic Control	NH ₃ -N	Ammonia - Nitrogen
BOD	Biochemical Oxygen Demand	NIT	Nitrification Process
BOD ₅	Biochemical Oxygen Demand - 5 day test	NO ₂ -N	Nitrite - Nitrogen
BWL	Bottom Water Level	NO ₃ -N	Nitrate - Nitrogen
CBOD	Carbonaceous Oxygen Demand	COAO	Close-Off-Auto-Open
COD	Chemical Oxygen Demand	ORP	Oxidation-Reduction Potential
DO	Dissolved Oxygen	PID	Proportional Integral Derivative
EQ	Equalization	P&ID	Piping and Instrumentation Diagram
ETM	Elapsed Time Meter	PC	Personal Computer
FDS	Functional Design Specification	PD	Positive Displacement
F/M	Food to Microorganism Ratio	PDWF	Peak Dry Weather Flow
FS	Float Switch	PLC	Programmable Logic Controller
ft	feet	PWWF	Peak Wet Weather Flow
gpd	gallons per day	RAS	Return Activated Sludge
HMI	Human-Machine Interface	SBR	Sequencing Batch Reactor
HOA	Hand-Off-Auto	SCADA	Supervisory Control and Data Acquisition
HOR	Hand-Off-Remote	SOR	Standard Oxygen Requirements
HRT	Hydraulic Retention Time	SOTE	Standard Oxygen Transfer Efficiency
I/O	Inputs/Outputs	SRT	Sludge Retention Time
ICEAS	Intermittent Cycle Extended Aeration System	SSV	Settled Sludge Volume
kg	kilogram	SVI	Sludge Volume Index
lb	pound	SWD	Side Water Depth
Lps	Liters per second	TKN	Total Kjeldahl Nitrogen
LT	Level Transducer	TN	Total Nitrogen
m	meter	TP	Total Phosphorus
m ³ /day	cubic meters per day	TWL	Top Water Level
MCC	Motor Control Center	VFD	Variable Frequency Drive
mg/L	milligrams per Liter (parts per million, ppm)	WAS	Waste Activated Sludge
MLSS	Mixed Liquor Suspended Solids	WWTP	Wastewater Treatment Plant
MLVSS	Mixed Liquor Volatile Suspended Solids	°C	degrees Celcius
NDN	Nitrification/Denitrification Process		

3.0 SBR and ICEAS Process

The sequencing batch reactor (SBR) process is a modification of a conventional activated sludge plant. The SBR process allows the unit processes of react, settle, and discharge to occur sequentially in one basin. As a result, the "footprint" of a SBR is typically much smaller than that of a conventional activated sludge plant. The Intermittent Cycle Extended Aeration System (ICEAS) process is a modification of a conventional SBR.

The ICEAS process allows continuous inflow of wastewater into the treatment basins during all phases of the cycle. The continuous inflow is an advantage over conventional SBRs in that it optimizes biological treatment by supplying a constant food source for the process and equalizes the flow loadings in multiple-basin systems. A cycle consists of different phases (react, settle, and decant) during which treatment takes place. The cycles operate continuously in each basin to meet the treatment goals of the plant.

The Ridgemark I WWTP has the capability to operate as either an SBR process or ICEAS process. If the SBR mode is selected, the influent valves will alternate positions to allow inflow of wastewater into one (1) basin at a time. If the ICEAS mode is selected, the influent valves will remain open to allow continuous inflow at all times in the cycle.

3.1 Basin Design


An ICEAS basin has two compartments: a pre-react zone and a main-react zone. The pre-react zone acts as a biological selector and receives the continuous influent flow. The two compartments are separated by a baffle wall that spans the tank width and has openings at the basin floor. The baffle wall prevents short circuiting and allows the two zones to be hydraulically connected as it directs the flow to enter the main-react zone at the bottom of the basin.

3.2 Process Overview

The following is a brief process overview of the three phases common to all Sanitaire cycles:


1.) React, 2.) Settle, and 3.) Decant.

React Phase




During the react phase, raw wastewater flows into the pre-react zone continuously to react with the mixed liquor suspended solids. Depending on the process scheme, the basin contents are aerated, anoxically mixed, allowed to react anaerobically, or a combination thereof. As the basin continues to fill, biological oxidation/reduction reactions take place simultaneously to treat the wastewater.

Settle Phase



During the settle phase, basin agitation from the react phase (i.e. aeration or mixing) is stopped to allow the solids to settle to the bottom of the basin. Raw wastewater continues to flow into the pre-react zone as the main-react zone settles. As the solids settle, a clear layer of water will remain on top of the basin.

Decant Phase



During the decant phase, the decanter rotates downward to draw off the clarified supernatant and discharge it to the effluent line. Raw wastewater continues to flow into the pre-react zone as the main-react zone is decanted. Sludge is typically wasted from the basin during this phase in the cycle.

3.3 Basin Layers

The picture illustrates the three stratified layers that are formed in each basin at the end of the settle phase and beginning of the decant phase. The sludge blanket forms on the bottom of the basin as the mixed liquor suspended solids (MLSS) settle. A buffer zone of three feet acts to buffer the sludge blanket from the volume that will be removed during the decant phase. The drawdown is the top layer of clear liquid that remains after the MLSS settle and is the maximum volume that will be drawn off during the decant phase.



3.4 Basin Hydraulics and Loading

In the SBR cycle, raw influent (usually screened and degritt) flows into one basin at a time with the use of motorized influent valves. During all phases of the ICEAS cycle, raw influent (usually screened and degritt) flows into the basins. To allow equal loading, flow is split equally to all basins by a splitter box. Since influent flow is continuous, the ICEAS process can be operated in a single basin allowing for basins to be taken out of service for maintenance or during low flow/loading conditions.

The SBR/ICEAS basins are designed to handle the average dry weather flow (ADWF), the peak dry weather flow (PDWF), and the peak wet weather flow (PWWF) as specified in the design parameters. Flow enters the basin either in batches or continuously and the treated effluent leaves the basin intermittently (only during the decant phase). Two time-based cycles are used to hydraulically process the flow. The normal cycle will process the ADWF and the PDWF. The storm cycle has time periods that are 25 percent shorter than the normal cycle to process flows above the PDWF up to the PWWF.

3.5 Nitrification-Denitrification Process Operation

The nitrification-denitrification (NDN) process operates to remove BOD, TSS, ammonia-nitrogen ($\text{NH}_3\text{-N}$) through nitrification, and nitrite-nitrogen ($\text{NO}_2\text{-N}$)/nitrate-nitrogen ($\text{NO}_3\text{-N}$) through denitrification. In the NDN process, the react phase consists of all alternating periods of aeration and anoxic mixing. The aeration periods supply oxygen to the biomass for BOD oxidation and nitrification. The anoxic mixing periods provide minimal oxygen and mixing of the biomass for denitrification.

3.6 Cycle Time – NDN Process, 2 Basins

The SBR/ICEAS process will complete one normal cycle every 288 minutes or 4.8 hours. Each cycle is divided into 168 minutes of react phase, 60 minutes of settle phase, and 60 minutes of decant phase. The react phase is divided into seven 24-minute periods that alternate anoxic mix and aeration. There are five periods of aeration or "air on", which have adjustable blower run times. The second and sixth periods are anoxic or "air off" periods, which have adjustable mixer

3.7 Storm Cycle Transitions

The system switches from normal cycle operation to storm cycle operation when the level sensing equipment in a basin detects a water level that corresponds to a flow that is above PDWF. After the storm cycle is initiated, the system will stay in the storm cycle until the basin that indicated a storm event has completed its cycle (end of decant phase) and completed another full storm cycle.

At the completion of the full storm cycle for that basin, the system will switch back to normal cycle operation if no basins are indicating water levels that correspond to a flow above PDWF. If a basin detects high water levels that indicate a flow above PDWF, the system will stay in the storm cycle until normal cycle water levels return. The system can switch into the storm cycle at any time during the normal cycle. The system cannot, however, switch from storm back to normal cycle until the completion of the storm cycle for the initiating basin.

4.0 Equipment Operation

The following sections contain brief descriptions of the equipment operation for the ICEAS process. More detailed descriptions are found in the FDS.

4.1 Control System

The control system for the ICEAS NDN process has a control panel, which contains the programmable logic controller (PLC), a human-machine interface (HMI), control switches, indicator lights, power connection, etc. The motor starters and variable frequency drives (VFDs) for the equipment are housed in a separate motor control center (MCC). The PLC contains the logic to operate the process equipment when the equipment is in automatic control. Local and/or remote control switches are provided for equipment operation when taken out of automatic control. The HMI is an operator interface that communicates with the PLC to display system status, allow set point adjustments, and perform alarm handling.

4.2 Decanters

Each basin has a decanter installed on the wall opposite the pre-react zone. The decanter operates to remove clarified effluent from the top layer of the basin (drawdown) during the decant phase of the cycle. The drawdown is defined by the top water level (TWL) and the bottom water level (BWL). When the decanter is not operating, it remains in a parked position above the TWL, which eliminates the possibility of solids carryover during other phases in the cycle. In the park position, the decanter can act as a clarifier weir in the event of a power outage.

The decanter is mechanically operated by the use of an electro-mechanical actuator that is mounted on the basin walkway for easy access. The actuator moves the decanter between the top and bottom limit switches whenever the decanter is in operation. The decanter speed is controlled through the use of a variable frequency drive (VFD). As a result, the decanter discharge rate will be relatively constant from the time the decanter enters the water to the time it reaches the BWL.

During the end of the settle phase, the decanter will travel from the park position to the TWL. When decant phase is started, the decanter will travel from the TWL to the BWL in the allotted time to remove the drawdown volume from the basin. Since influent flow to the plant varies, the water level in the basin at the start of each decant phase will be at differing levels above BWL. Consequently, during the decant phase, the decanter will travel downward for a period of time before reaching the water surface. Also mounted on the decanter in front of the weir is a floatable scum guard that operates to exclude floating material during the decant phase.

4.3 Blowers

Three turbo blowers can operate to supply air to the aeration systems in the basins. Each blower is capable of delivering between 50 percent and 100 percent of the air requirements to the process in one basin at a time. One blower operates as the "Duty" blower and the other two

operate as the "Standby" blowers, in the event that the "Duty" blower is not available. The "Duty" blower can alternate duty on a weekly basis.

4.4 Air Valves

Each basin has a motorized air valve, which will operate to allow air to enter one basin at a time. The two air valves will operate in an alternating sequence during blower operation; when one valve is open, the other one is closed, etc. The air valves divert air between the two basins when blower operation is required in the cycle. At certain times in the cycle, both basins will have the air valves closed. This will occur when one basin is in the settle or decant phase and the other basin is in an "air off" period of the react phase.

4.5 Aeration Systems

Each basin has two fine bubble aeration systems (one in the pre-react zone and one in the main react zone), which operates to deliver diffused air to the process. The aeration system only receives air when the air valve for the basin is open. A solenoid valve connected to the aeration system periodically opens and closes to allow the aeration system to purge and depressurize. The duration that the solenoid valve is open for purging and depressurizing is operator adjustable through the HMI. In addition to the automatic purge, the aeration system has a manual purge valve that the operator can use as needed.

4.6 Influent Valves

Each basin will have a motorized influent valve which, when open, will operate to allow influent wastewater to enter one basin at a time when "SBR mode" is selected. The two influent valves will operate in an alternating sequence; when one valve is open, the other is closed, etc. This allows continuous inflow of wastewater to one of the two basins during the cycle. Refer to the cycle charts, which show when the basin's influent valve is open. In the "ICEAS mode", all of the influent valves will be open all the time to allow for equal loading to all the basins.

4.7 Mixers

Each basin has two mixers installed in the main-react zone, which operate during the "air off" periods of the react phase. The operator can enable or disable the mixer during each "air off" period through the HMI. If a reduced "air on" time is selected for an air period or if the air shuts off due to the DO control system, the operator can select to run the mixers for these time periods as well. The aeration and mixers cannot be operating at the same time.

4.8 Waste Activated Sludge (WAS) Pumps

Each basin has a submersible pump, which operates to waste sludge from the basin during the decant phase of the cycle. The waste activated sludge (WAS) pump start and run times are adjustable through the HMI located on the ICEAS control panel to adjust the amount of sludge wasted.

4.9 Level Sensing Equipment

A level transducer and float switch are installed in each basin. The level transducer continuously indicates the basin water level at the HMI. The PLC uses the water level reading to calculate the corresponding flow rate into the basin. If the basin water level indicates that a flow above the PDWF is entering the basin, the system will transition into the storm cycle.

There are two float switches in each basin, a lower and upper float switch. The lower float switch has two functions. One function is to signal a high level in the basin and force the system into a settle phase to allow a minimum of 30 minutes of settle time prior to the water level overtopping the decanter. The second function is to signal that the system must transition into the storm cycle if the level transducer has not already signaled this to take place. The upper float switch is used in SBR mode to confirm water level in the basin after the fill cycle is completed. If the basin water level is below TWL after the fill cycle is complete, the system will be allowed to continue normal cycle operation, if the water level is at or above TWL, the cycle will remain in the forced settle mode of operation. The upper float switch is not used in ICEAS mode of operation.

4.10 Dissolved Oxygen (DO) Control System

The dissolved oxygen (DO) control system regulates the DO in the basin by controlling the blower operation. Each basin has a DO probe and analyzer. The analyzer sends the signal received from the probe in the basin to the PLC indicating the DO concentration in parts per million (ppm), which is the same as milligrams per liter (mg/L). High, low, and target DO set points in ppm are selected and entered at the HMI. Blower operation is regulated by the PLC based on the DO set points. When the high DO set point has been reached, there is a time delay before the blower will respond that is operator adjustable through the HMI. The goal of the system is to achieve a constant DO concentration without over- or under-aerating the process during the aeration periods in the react phase.

4.11 SBR Scum Valves

Each basin will have a motorized scum valve which, when open, will operate to allow floating scum to be removed from a basin by gravity. The two scum valves will operate independently, and will be controlled by the PLC, via inputs on the HMI. The valves will be controlled based on basin water level, cycle time, and duration of opening.

4.12 Utility Water Spray Control Valves

Each basin will have a motorized utility water spray valve which, when open, will operate to allow water through the spray header. Nozzles on the spray header will spray water towards the adjustable weir scum trough. The spray control valve can operate in manual or automatic mode. In automatic mode, the duration of the valve being open is operator selectable. The utility water spray valve will not open unless the scum valve is also open.

5.0 Plant Specifics

The specifics for the Ridgemark I WWTP are briefly described in this section. Refer to the Contract Documents for more details regarding the overall process at the plant.

5.1 Plant Design Parameters

The Ridgemark I WWTP has been designed based on the following influent wastewater characteristics and site conditions. These parameters have been used for basin design and the process criteria.

ADWF (Average Day Flow)	350,000	gpd
Maximum Day Flow	430,000	gpd
PDWF	725,156	gpd
PWWF (Peak 3 Hour Flow*)	967,000	gpd
Design BOD ₅ Conc. (at 20°C)	338	mg/L
Design BOD Loading	987	lb/day
Design TSS Conc.	338	mg/L
Design TSS Loading	987	lb/day
Design TKN Conc.	54	mg/L
Design TKN Loading	158	lb/day
Alkalinity required (minimum)	159	mg/L
Wastewater Temperature, Min	16	°C
Wastewater Temperature, Max	20	°C
Ambient Air Temperature	0 to 32	°C
pH Range	6.5 to 8.5	SU
Site Elevation - above sea level	520	ft

*Includes plant recycle flow of 150,000 gpd

The ICEAS NDN process has been designed to meet the following effluent requirements on a 30-day arithmetic average.

BOD ₅ Conc. (at 20°C)	30	mg/L
TSS Conc.	30	mg/L
NH ₃ -N Conc.	5	mg/L
Nitrate Conc.	5	mg/L

To meet the effluent requirements, the ICEAS NDN process has the following basin design.

Number of Basins	2	basins
Basin Length	77.0	ft
Basin Width	30.0	ft
TWL	18.5	ft
BWL	14.3	ft
Basin Volume at BWL	246,758	gallons
Basin Volume at TWL	319,680	gallons

To meet the effluent requirements, the ICEAS NDN process has been designed with the following parameters for each basin.

F/M Ratio	0.048	lb BOD/lb MLSS-day
SVI (after 30 min settle)	150	mL/gm (max)
MLSS (at BWL, design loading)	4,922	mg/L
MLSS (at TWL, design loading)	3,978	mg/L
HRT	1.56	days
SRT	28	days
Normal Decant Rate (ICEAS Mode)	1,293	gpm
Normal Decant Rate (SBR Mode)	1,209	gpm
Peak Decant Rate	2,418	gpm
WAS Produced (mass)	349	lb/day
WAS Produced @ 0.85% solids	4,928	gpd

5.2 Dissolved Oxygen Control Set Points

For nitrification to occur, it is important to maintain DO concentrations in the basin around 2 ppm during the aeration periods in the react phase. The following DO Set Points are recommended for design conditions and can be adjusted by the operator through the HMI.

Parameter	Set Point Value
Enable/Disable DO Control	On
High DO Set Point	3.0 ppm
Target DO Set Point	2.0 ppm
Low DO Set Point	1.0 ppm
High DO Off Delay	2 minutes

More information on changing set points is located in the controls FDS.

Unit Process	Comments
Effluent Wet Well	Controlled by others.
Storage Ponds	Controlled by others.

During the decant phase, the treated flow will leave the basins through the decanter and discharge into the effluent wet well. The flow will then be pumped through the effluent pipe into the disposal/storage ponds.



Sunnyslope Water District

Section F

Laboratory Information



**Sunnyslope County
Water District**

Name	Address	Certification
<u>CM Analytical Inc.</u>	6700 Brem Ln. Suite #10 Gilroy, CA 95020	1423 Exp. 7/31/2021
BSK Associates	1414 Stanislaus St Fresno CA 93706	1180 Exp. 4/30/2021



Sunnyslope Water District

Section G

Sludge Management

Sunnyslope County Water District


3570 Airline Highway
Hollister, California 95023-9702
Phone (831) 637-4670
Fax (831) 637-1399

Process Description

The solids storage tank holds biosolids wasted from the sequencing batch reactor process. A waste activated sludge (WAS) pump discharges the biosolids into the solids storage tank. This concrete tank provides approximately 60 days of solids retention time at buildout flows and loads. Storing the solids allows the WAS pumping to be de-coupled from the solids drying bed and provides flexibility in the operation of the solids handling systems. The storage tank is designed to mimic a facultative system with a surface aerator maintaining an aerobic zone on the top of the tank to minimize odors and a lower zone of anaerobic conditions.

As WAS is conveyed to tank, the water level will rise and the tank water level will need to be periodically decanted. During a decant step, the surface aerator should be turned off and solids will be allowed to settle. Supernatant can then be removed from the top of the tank with the telescoping valve and conveyed to the Plant Drain Pump Station (PDPS). Solids will periodically be removed from the bottom of the tank and conveyed to the solids drying beds for drying. Figure 8-1 shows a photo of the tank and the aerator in use.

Figure 8-1: Solids Storage Tank Photo



Sunnyslope County Water District

3570 Airline Highway
Hollister, California 95023-9702
Phone (831) 637-4670
Fax (831) 637-1399

Purpose and Intent

The principal objective of the solids storage tank is to support wasting of solids from the SBR. WAS from the SBR is pumped into the solids storage tank to maintain an optimal biomass in the SBR process. The solids storage tank then stores, continues to breakdown, and to provides separation of the supernatant from the solids. Periodically (primarily during dry weather periods), solids are removed from the bottom of the tank to the solids drying beds for drying and disposal.

Wastewater Characteristics

Solids concentration and volume in the solids storage tank will vary depending on discharge of solids to the drying bed, breakdown of solids in the tank, and WAS wasting rates (dependent on influent load).

Design Criteria

Table 8-1 summarizes the solids storage tank design criteria.

Table 8-1: Solids Storage Tank Design Criteria

Parameter	Value	Units
Tank Diameter	52	ft
Side Water Depth	20	ft
Total Liquid Volume	337,000	gals
Solids Storage Capacity	55,800	lbs
Solids Retention Time	60	days
Aeration Type	Surface Aerators	
Number	1	(existing)
Aerator Motor Size	7.5 ^a	hp
Impeller Motor Size	5	hp

Footnotes:

- District has several different sized aerators that can be used.

Process Overview

The solids drying beds receives solids from the storage tank for drying. The solids from the tank will be pumped to the drying beds and will primarily be water (~0.5% to 2% solids). Once in the drying bed, solids will be allowed to settle and the telescoping valve will be used to decant supernatant off the top. Supernatant from the top layer of the solid drying beds will be diverted to the plant drain pump station and pumped back to headworks. The solids are then allowed to dry in the drying beds for an extended amount of time before it is hauled away.

Figure 9-1 shows a solids drying bed when it is empty and Figure 9-2 provides a plan view of the three beds.

Sunnyslope County Water District

3570 Airline Highway
Hollister, California 95023-9702
Phone (831) 637-4670
Fax (831) 637-1399

Figure 9-1: Solids Drying Bed #1 (Empty)



Purpose and Intent

The principal objective of the solid drying beds is to air dry solids from the solids storage tank. Four solids drying beds are available to receive batches of solids from the storage tank. The solids content will be increased to approximately 15% solids and can be removed from the drying beds twice per year and hauled off site.

Solids Characteristics

Solids drying beds will receive solids drawn off the bottom of the solids storage tank and is expected to include a mix of anaerobic and facultative solids.

Sunnyslope County Water District

3570 Airline Highway
 Hollister, California 95023-9702
 Phone (831) 637-4670
 Fax (831) 637-1399

Anticipated Performance

Please refer to Table 9-1 for the solids drying beds design criteria.

Table 9-1: Solids Drying Beds Design

Parameter	Value	Units
No. of Beds	4	
Area per Bed	5,775	square feet (sf)
Total Area	23,100	sf
Surface Type	Concrete	
Months of Operation	March to October	
Net Evaporation	29.2	inches
Number of Removals	4	Per year
Cake Depth	Up to 2	ft
Average Solids from Storage Tank	2%	
Average Final Solids Concentration	15%	

General Operations

Under initial Phase 1 flows, solids from the storage tank are envisioned to be pumped to the drying bed from March through October for drying. Table 9-4 summarizes net evaporation rates (approximately 29.2 inches per year) used in the dry bed design. Prior to filling solids drying beds, check that mud valves are closed and telescoping valves are in the full upright positions. Confirm that influent plugs valves are open and/or closed as desired for the drying beds that will be filled. The bed(s) are now ready to be filled.

The solids drying beds will receive batches of solids pumped from the solids storage tank over several days (Note: pumping over several days will allow the solids from the bottom of the solids tank to be removed more effectively from the 3 draw off locations).

As solids/flow is conveyed to the beds, it spreads out over the bed area to facilitate evaporation. The beds are designed for up to two feet of solids but can be operating initial at lower levels to enhance drying. Once flow has been batched into the basin solids should be allowed to settle before decanting the supernatant off using the telescoping valves. This would minimize the solids return to the plant drain pump station.

Sunnyslope County Water District

3570 Airline Highway
Hollister, California 95023-9702
Phone (831) 637-4670
Fax (831) 637-1399

Table 9-4: Historic Net Evaporation for Drying Bed Operation

Month	Rainfall (in)	Evaporation (in)	Net Evaporation (in)
Jan	1.31	1.54	
Feb	4.21	1.62	
Mar	0.57	2.39	1.82
Apr	0.26	3.63	3.37
May	0.08	4.43	4.35
Jun	0	4.69	4.69
Jul	0	5.49	5.49
Aug	0	4.52	4.52
Sep	0.1	3.75	3.65
Oct	1.95	3.28	1.33
Nov	0.54	2.07	
Dec	3.45	1.42	
Total			29.2

It may be advantageous to maintain a water cap on the solids depending on the characteristics of the solids from the basin. The water cap would help to minimize odors and provide a period for aerobic conditions to establish. Once aerobic conditions have established, the water can be decanted from the top of the solids.

The solids will then be allowed to air dry over a couple months and should be disked or turned over periodically to enhance drying and minimize odors. The basins were designed for a small loader to be used to turn solids over. Once the solids percent has been achieved, solids would be off hauled to a landfill or other approved site.

At build out flows, it was envisioned that dewatering equipment would be implemented to dewater solid before sending solids to the drying beds. This would allow for a 50% solids cake to be achieved for disposal therefore minimizing the weight and frequency of hauling.



Sunnyslope County Water District

Waste Discharge Identification # 3 351000001

Discharge Self-Monitoring Report

Monitoring and Reporting Program # R3-2004-0065

Ridgemark Estates Subdivision

Wastewater Treatment Plant

RM I SBR Wastewater Sludge Disposal

Sludge Disposal from Drying Beds, Tons										
2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
70.71	62.76	33.62	55.61	36.42	47.32	31.35				
Disposal at the John Smith Land Fill Hollister California										

Certificate of Analysis

Sample ID: ADG2205-05
 Sampled By: Abel Alvarez
 Sample Description: Composite of Drying Bed 1 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28
 Matrix: Solid
 Sample Type: Composite
 Composite Start: 07/20/2020 - 10:28

BSK Associates Laboratory Fresno
 General Chemistry

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Nitrate as N, DI Extract	EPA 300.0	17	2.3	mg/kg	1	ADG1594	07/28/20	07/29/20	
Percent Solids	SM 2540B	82	0.10	% by Weight	1	ADG1356	07/23/20	07/24/20	
Total Kjeldahl Nitrogen	EPA 351.2	50000	9700	mg/kg	387	ADG1753	07/30/20	08/05/20	MS1.3

Metals

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Antimony	EPA 6020	ND	10	mg/kg	1	ADG1629	07/28/20	07/29/20	
Arsenic	EPA 6020	3.1	2.5	mg/kg	1	ADG1629	07/28/20	07/29/20	
Barium	EPA 6020	230	6.3	mg/kg	1	ADG1629	07/28/20	07/29/20	
Beryllium	EPA 6020	ND	1.3	mg/kg	1	ADG1629	07/28/20	07/29/20	
Cadmium	EPA 6020	ND	1.3	mg/kg	1	ADG1629	07/28/20	07/29/20	
Chromium	EPA 6020	19	13	mg/kg	1	ADG1629	07/28/20	07/29/20	
Cobalt	EPA 6020	ND	13	mg/kg	1	ADG1629	07/28/20	07/29/20	
Copper	EPA 6020	310	5.0	mg/kg	1	ADG1629	07/28/20	07/29/20	
Lead	EPA 6020	ND	6.3	mg/kg	1	ADG1629	07/28/20	07/29/20	
Mercury	EPA 6020A	ND	0.50	mg/kg	1	ADG1629	07/28/20	07/29/20	
Molybdenum	EPA 6020	ND	13	mg/kg	1	ADG1629	07/28/20	07/29/20	
Nickel	EPA 6020	ND	13	mg/kg	1	ADG1629	07/28/20	07/29/20	
Selenium	EPA 6020	6.6	2.5	mg/kg	1	ADG1629	07/28/20	07/29/20	SD1.1
Silver	EPA 6020	ND	13	mg/kg	1	ADG1629	07/28/20	07/29/20	MS1.2
Thallium	EPA 6020	ND	2.0	mg/kg	1	ADG1629	07/28/20	07/29/20	
Vanadium	EPA 6020	14	13	mg/kg	1	ADG1629	07/28/20	07/29/20	
Zinc	EPA 6020	620	63	mg/kg	1	ADG1629	07/28/20	07/29/20	

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Organochlorine Pesticides by GC-ECD									
4,4'-DDD	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	CV0.0
4,4'-DDE	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
4,4'-DDT	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	CV2.0
Aldrin	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
alpha-BHC	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
beta-BHC	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Chlordane (Technical)	EPA 8081A	ND	50	ug/kg	50	ADG1229	07/22/20	07/27/20	CV0.0
delta-BHC	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Dieldrin	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Endosulfan I	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Endosulfan II	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Endosulfan Sulfate	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Endrin	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Certificate of Analysis

Sample ID: ADG2205-05
 Sampled By: Abel Alvarez
 Sample Description: Composite of Drying Bed 1 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28
 Matrix: Solid
 Sample Type: Composite

Composite Start: 07/20/2020 - 10:28

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Organochlorine Pesticides by GC-ECD									
Endrin Aldehyde	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Heptachlor	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Heptachlor Epoxide	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Lindane	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Methoxychlor	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	CV2.0
Toxaphene	EPA 8081A	ND	50	ug/kg	50	ADG1229	07/22/20	07/27/20	CV0.0
Surrogate: TCMX	EPA 8081A	57 %	Acceptable range: 10-138 %						
Polychlorinated Biphenyls (PCBs) by GC-ECD									
Aroclor-1016	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Aroclor-1221	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Aroclor-1232	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Aroclor-1242	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Aroclor-1248	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Aroclor-1254	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Aroclor-1260	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Surrogate: Decachlorobiphenyl	EPA 8082	92 %	Acceptable range: 50-150 %						
Volatile Organics (Standard List) by GC-MS									
Total Xylenes	EPA 8260B	ND	25	ug/kg					
Volatile Organics (Standard List) by GC-MS									
1,1,1,2-Tetrachloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,1,1-Trichloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,1,2,2-Tetrachloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,1,2-Trichloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,1-Dichloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,1-Dichloroethene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,1-Dichloropropene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2,3-Trichlorobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2,3-Trichloropropane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2,4-Trichlorobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2,4-Trimethylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2-Dibromoethane (EDB)	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2-Dichlorobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2-Dichloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2-Dichloropropane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,3,5-Trimethylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,3-Dichlorobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,3-Dichloropropane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,4-Dichlorobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
2,2-Dichloropropane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
2-Chlorotoluene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
2-Hexanone	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Certificate of Analysis

Sample ID: ADG2205-05
 Sampled By: Abel Alvarez
 Sample Description: Composite of Drying Bed 1 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28
 Matrix: Solid
 Sample Type: Composite

Composite Start: 07/20/2020 - 10:28

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Volatile Organics (Standard List) by GC-MS									
4-Chlorotoluene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
4-Methyl-2-pentanone	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Benzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Bromobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Bromochloromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Bromodichloromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Bromoform	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Bromomethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Carbon disulfide	EPA 8260B	34	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Carbon Tetrachloride	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Chlorobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Chloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Chloroform	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Chloromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
cis-1,2-Dichloroethene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
cis-1,3-Dichloropropene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Dibromochloromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Dibromochloropropane (DBCP)	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Dibromomethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Dichlorodifluoromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Dichloromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Ethylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Hexachlorobutadiene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Hexachloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Iodomethane	EPA 8260B	ND	50	ug/kg	5	ADG1034	07/21/20	07/21/20	
Isopropylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
m,p-Xylenes	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Methyl-t-butyl ether	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Naphthalene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
n-Butylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
n-Propylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
o-Xylene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
p-Isopropyltoluene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
sec-Butylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Styrene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
tert-Butylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Tetrachloroethene (PCE)	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Toluene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
trans-1,2-Dichloroethene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
trans-1,3-Dichloropropene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Trichloroethene (TCE)	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Trichlorofluoromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Vinyl Chloride	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Certificate of Analysis

Sample ID: ADG2205-05
 Sampled By: Abel Alvarez
 Sample Description: Composite of Drying Bed 1 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28
 Matrix: Solid
 Sample Type: Composite
 Composite Start: 07/20/2020 - 10:28

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Surrogate: 1,2-Dichloroethane-d4	EPA 8260B	112 %							
Surrogate: Bromofluorobenzene	EPA 8260B	112 %							
Surrogate: Toluene-d8	EPA 8260B	108 %							

Semi-Volatile Organics (Standard List) by GC-MS

Analysis Qualifier(s): DL1.0

1,2,4-Trichlorobenzene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,2'-oxybis(1-chloropropane)	⁽²⁾ EPA 8270C	ND	2000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,4,5-Trichlorophenol	EPA 8270C	ND	4000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,4,6-Trichlorophenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,4-Dichlorophenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,4-Dimethylphenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,4-Dinitrophenol	EPA 8270C	ND	2000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,4-Dinitrotoluene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,6-Dinitrotoluene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2-Chloronaphthalene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2-Chlorophenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2-Methylphenol (o-cresol)	EPA 8270C	ND	2000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2-Nitrophenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
3,3-Dichlorobenzidine	EPA 8270C	ND	10000	ug/kg	20	ADG1227	07/22/20	07/24/20	
3-MPhenol/4-MPhenol	EPA 8270C	ND	4000	ug/kg	20	ADG1227	07/22/20	07/24/20	
4,6-Dinitro-2-methylphenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
4-Bromophenyl phenyl ether	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
4-Chloro-3-methylphenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
4-Chlorophenyl phenyl ether	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
4-Nitrophenol	EPA 8270C	ND	2000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Acenaphthene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Acenaphthylene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Anthracene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Benzo(a)anthracene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Benzo(a)pyrene	EPA 8270C	ND	400	ug/kg	400	ADG1227	07/22/20	07/30/20	
Benzo(b)fluoranthene	EPA 8270C	ND	400	ug/kg	400	ADG1227	07/22/20	07/30/20	
Benzo(g,h,i)perylene	EPA 8270C	ND	400	ug/kg	400	ADG1227	07/22/20	07/30/20	
Benzo(k)fluoranthene	EPA 8270C	ND	400	ug/kg	400	ADG1227	07/22/20	07/30/20	
Bis(2-chloroethoxy)methane	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Bis(2-chloroethyl) ether	EPA 8270C	ND	2000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Bis(2-ethylhexyl) phthalate	EPA 8270C	5200	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Butyl benzyl phthalate	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Chrysene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Dibenzo(a,h)anthracene	EPA 8270C	ND	400	ug/kg	400	ADG1227	07/22/20	07/30/20	
Diethyl phthalate	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Dimethyl phthalate	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Di-n-butyl phthalate	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Di-n-octyl phthalate	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Fluoranthene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Certificate of Analysis

Sample ID: ADG2205-05
 Sampled By: Abel Alvarez
 Sample Description: Composite of Drying Bed 1 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28

Matrix: Solid

Sample Type: Composite

Composite Start: 07/20/2020 - 10:28

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Semi-Volatile Organics (Standard List) by GC-MS						Analysis Qualifier(s): DL1.0			
Fluorene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Hexachlorobenzene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Hexachlorobutadiene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Indeno(1,2,3-cd)pyrene	EPA 8270C	ND	400	ug/kg	400	ADG1227	07/22/20	07/30/20	
Isophorone	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Naphthalene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Nitrobenzene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
N-Nitrosodi-n-propylamine (NDPA)	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
N-Nitrosodiphenylamine (as DPA)	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Pentachlorophenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Phenanthrene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Phenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Pyrene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Surrogate: 2,4,6-Tribromophenol	EPA 8270C	%	<i>Acceptable range: 41-200 %</i>						
Surrogate: 2-Fluorobiphenyl	EPA 8270C	118 %	<i>Acceptable range: 46-144 %</i>						
Surrogate: 2-Fluorophenol	EPA 8270C	155 %	<i>Acceptable range: 30-155 %</i>						
Surrogate: Nitrobenzene-d5	EPA 8270C	119 %	<i>Acceptable range: 30-149 %</i>						
Surrogate: Phenol-d6	EPA 8270C	84 %	<i>Acceptable range: 40-162 %</i>						
Surrogate: p-Terphenyl-d14	EPA 8270C	154 %	<i>Acceptable range: 45-161 %</i>						

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Certificate of Analysis

Sample ID: ADG2205-05RE1
Sampled By: Abel Alvarez
Sample Description: Composite of Drying Bed 1 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28
Matrix: Solid
Sample Type: Composite
Composite Start: 07/20/2020 - 10:28

BSK Associates Laboratory Fresno
Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
<u>Volatile Organics (Standard List) by GC-MS</u>									
2-Butanone	EPA 8260B	380	50	ug/kg	10	ADG1284	07/22/20	07/22/20	
Surrogate: 1,2-Dichloroethane-d4	EPA 8260B	112 %							<i>Acceptable range: 70-130 %</i>
Surrogate: Bromofluorobenzene	EPA 8260B	109 %							<i>Acceptable range: 70-130 %</i>
Surrogate: Toluene-d8	EPA 8260B	102 %							<i>Acceptable range: 70-130 %</i>

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Certificate of Analysis

Sample ID: ADG2205-05RE2
Sampled By: Abel Alvarez
Sample Description: Composite of Drying Bed 1 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28
Matrix: Solid
Sample Type: Composite
Composite Start: 07/20/2020 - 10:28

BSK Associates Laboratory Fresno
Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
<u>Volatile Organics (Standard List) by GC-MS</u>									
Acetone	EPA 8260B	ND	500	ug/kg	50	ADG1292	07/30/20	07/30/20	
Surrogate: 1,2-Dichloroethane-d4	EPA 8260B	96 %							<i>Acceptable range: 70-130 %</i>
Surrogate: Bromofluorobenzene	EPA 8260B	112 %							<i>Acceptable range: 70-130 %</i>
Surrogate: Toluene-d8	EPA 8260B	98 %							<i>Acceptable range: 70-130 %</i>

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Certificate of Analysis

Sample ID: ADG2205-06
Sampled By: Abel Alvarez
Sample Description: Composite of Drying Bed 4 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28
Matrix: Solid
Sample Type: Composite

Composite Start: 07/20/2020 - 10:28

BSK Associates Laboratory Fresno
General Chemistry

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Nitrate as N, DI Extract	EPA 300.0	12	2.3	mg/kg	1	ADG1594	07/28/20	07/29/20	MS1.2
Percent Solids	SM 2540B	91	0.10	% by Weight	1	ADG1356	07/23/20	07/24/20	
Total Kjeldahl Nitrogen	EPA 351.2	53000	9800	mg/kg	391	ADG1753	07/30/20	08/05/20	

Metals

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Antimony	EPA 6020	ND	10	mg/kg	1	ADG1629	07/28/20	07/29/20	
Arsenic	EPA 6020	3.4	2.5	mg/kg	1	ADG1629	07/28/20	07/29/20	
Barium	EPA 6020	270	6.3	mg/kg	1	ADG1629	07/28/20	07/29/20	
Beryllium	EPA 6020	ND	1.3	mg/kg	1	ADG1629	07/28/20	07/29/20	
Cadmium	EPA 6020	ND	1.3	mg/kg	1	ADG1629	07/28/20	07/29/20	
Chromium	EPA 6020	19	13	mg/kg	1	ADG1629	07/28/20	07/29/20	
Cobalt	EPA 6020	ND	13	mg/kg	1	ADG1629	07/28/20	07/29/20	
Copper	EPA 6020	320	5.0	mg/kg	1	ADG1629	07/28/20	07/29/20	
Lead	EPA 6020	6.3	6.3	mg/kg	1	ADG1629	07/28/20	07/29/20	
Mercury	EPA 6020A	ND	0.50	mg/kg	1	ADG1629	07/28/20	07/29/20	
Molybdenum	EPA 6020	ND	13	mg/kg	1	ADG1629	07/28/20	07/29/20	
Nickel	EPA 6020	15	13	mg/kg	1	ADG1629	07/28/20	07/29/20	
Selenium	EPA 6020	6.8	2.5	mg/kg	1	ADG1629	07/28/20	07/29/20	
Silver	EPA 6020	ND	13	mg/kg	1	ADG1629	07/28/20	07/29/20	
Thallium	EPA 6020	ND	2.0	mg/kg	1	ADG1629	07/28/20	07/29/20	
Vanadium	EPA 6020	14	13	mg/kg	1	ADG1629	07/28/20	07/29/20	
Zinc	EPA 6020	680	63	mg/kg	1	ADG1629	07/28/20	07/29/20	

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Organochlorine Pesticides by GC-ECD									
4,4'-DDD	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	CV0.0
4,4'-DDE	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
4,4'-DDT	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	CV2.0
Aldrin	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
alpha-BHC	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
beta-BHC	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Chlordane (Technical)	EPA 8081A	ND	50	ug/kg	50	ADG1229	07/22/20	07/27/20	CV0.0
delta-BHC	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Dieldrin	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Endosulfan I	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Endosulfan II	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Endosulfan Sulfate	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Endrin	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

ADG2205 FINAL 08062020 1342

Certificate of Analysis

Sample ID: ADG2205-06
 Sampled By: Abel Alvarez
 Sample Description: Composite of Drying Bed 4 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28
 Matrix: Solid
 Sample Type: Composite

Composite Start: 07/20/2020 - 10:28

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Organochlorine Pesticides by GC-ECD									
Endrin Aldehyde	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Heptachlor	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Heptachlor Epoxide	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Lindane	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	
Methoxychlor	EPA 8081A	ND	5.0	ug/kg	50	ADG1229	07/22/20	07/27/20	CV2.0
Toxaphene	EPA 8081A	ND	50	ug/kg	50	ADG1229	07/22/20	07/27/20	CV0.0
Surrogate: TCMX	EPA 8081A	67 %	Acceptable range: 10-138 %						
Polychlorinated Biphenyls (PCBs) by GC-ECD									
Aroclor-1016	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Aroclor-1221	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Aroclor-1232	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Aroclor-1242	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Aroclor-1248	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Aroclor-1254	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Aroclor-1260	EPA 8082	ND	0.25	mg/kg	50	ADG1229	07/22/20	07/27/20	
Surrogate: Decachlorobiphenyl	EPA 8082	89 %	Acceptable range: 50-150 %						
Volatile Organics (Standard List) by GC-MS									
Total Xylenes	EPA 8260B	ND	25	ug/kg					
Volatile Organics (Standard List) by GC-MS									
1,1,1,2-Tetrachloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,1,1-Trichloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,1,2,2-Tetrachloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,1,2-Trichloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,1-Dichloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,1-Dichloroethene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,1-Dichloropropene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2,3-Trichlorobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2,3-Trichloropropane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2,4-Trichlorobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2,4-Trimethylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2-Dibromoethane (EDB)	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2-Dichlorobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2-Dichloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,2-Dichloropropane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,3,5-Trimethylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,3-Dichlorobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,3-Dichloropropane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
1,4-Dichlorobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
2,2-Dichloropropane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
2-Chlorotoluene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
2-Hexanone	EPA 8260B	30	25	ug/kg	5	ADG1034	07/21/20	07/21/20	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Certificate of Analysis

Sample ID: ADG2205-06
 Sampled By: Abel Alvarez
 Sample Description: Composite of Drying Bed 4 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28

Matrix: Solid

Sample Type: Composite

Composite Start: 07/20/2020 - 10:28

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Volatiles Organics (Standard List) by GC-MS									
4-Chlorotoluene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
4-Methyl-2-pentanone	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Benzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Bromobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Bromochloromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Bromodichloromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Bromoform	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Bromomethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Carbon disulfide	EPA 8260B	30	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Carbon Tetrachloride	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Chlorobenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Chloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Chloroform	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Chloromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
cis-1,2-Dichloroethene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
cis-1,3-Dichloropropene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Dibromochloromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Dibromochloropropane (DBCP)	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Dibromomethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Dichlorodifluoromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Dichloromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Ethylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Hexachlorobutadiene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Hexachloroethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Iodomethane	EPA 8260B	ND	50	ug/kg	5	ADG1034	07/21/20	07/21/20	
Isopropylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
m,p-Xylenes	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Methyl-t-butyl ether	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Naphthalene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
n-Butylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
n-Propylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
o-Xylene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
p-Isopropyltoluene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
sec-Butylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Styrene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
tert-Butylbenzene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Tetrachloroethene (PCE)	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Toluene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
trans-1,2-Dichloroethene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
trans-1,3-Dichloropropene	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Trichloroethene (TCE)	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Trichlorofluoromethane	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	
Vinyl Chloride	EPA 8260B	ND	25	ug/kg	5	ADG1034	07/21/20	07/21/20	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Certificate of Analysis

Sample ID: ADG2205-06
 Sampled By: Abel Alvarez
 Sample Description: Composite of Drying Bed 4 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28
 Matrix: Solid
 Sample Type: Composite
 Composite Start: 07/20/2020 - 10:28

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Surrogate: 1,2-Dichloroethane-d4	EPA 8260B	108 %							
Surrogate: Bromofluorobenzene	EPA 8260B	114 %							
Surrogate: Toluene-d8	EPA 8260B	110 %							

Semi-Volatile Organics (Standard List) by GC-MS

Analysis Qualifier(s): DL1.0

1,2,4-Trichlorobenzene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,2'-oxybis(1-chloropropane)	⁽²⁾ EPA 8270C	ND	2000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,4,5-Trichlorophenol	EPA 8270C	ND	4000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,4,6-Trichlorophenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,4-Dichlorophenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,4-Dimethylphenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,4-Dinitrophenol	EPA 8270C	ND	2000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,4-Dinitrotoluene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2,6-Dinitrotoluene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2-Chloronaphthalene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2-Chlorophenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2-Methylphenol (o-cresol)	EPA 8270C	ND	2000	ug/kg	20	ADG1227	07/22/20	07/24/20	
2-Nitrophenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
3,3-Dichlorobenzidine	EPA 8270C	ND	10000	ug/kg	20	ADG1227	07/22/20	07/24/20	
3-MPhenol/4-MPhenol	EPA 8270C	ND	4000	ug/kg	20	ADG1227	07/22/20	07/24/20	
4,6-Dinitro-2-methylphenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
4-Bromophenyl phenyl ether	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
4-Chloro-3-methylphenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
4-Chlorophenyl phenyl ether	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
4-Nitrophenol	EPA 8270C	ND	2000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Acenaphthene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Acenaphthylene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Anthracene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Benzo(a)anthracene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Benzo(a)pyrene	EPA 8270C	ND	400	ug/kg	400	ADG1227	07/22/20	07/30/20	
Benzo(b)fluoranthene	EPA 8270C	ND	400	ug/kg	400	ADG1227	07/22/20	07/30/20	
Benzo(g,h,i)perylene	EPA 8270C	ND	400	ug/kg	400	ADG1227	07/22/20	07/30/20	
Benzo(k)fluoranthene	EPA 8270C	ND	400	ug/kg	400	ADG1227	07/22/20	07/30/20	
Bis(2-chloroethoxy)methane	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Bis(2-chloroethyl) ether	EPA 8270C	ND	2000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Bis(2-ethylhexyl) phthalate	EPA 8270C	4300	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Butyl benzyl phthalate	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Chrysene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Dibenzo(a,h)anthracene	EPA 8270C	ND	400	ug/kg	400	ADG1227	07/22/20	07/30/20	
Diethyl phthalate	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Dimethyl phthalate	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Di-n-butyl phthalate	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Di-n-octyl phthalate	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Fluoranthene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Certificate of Analysis

Sample ID: ADG2205-06
 Sampled By: Abel Alvarez
 Sample Description: Composite of Drying Bed 4 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28
 Matrix: Solid
 Sample Type: Composite
 Composite Start: 07/20/2020 - 10:28

Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Semi-Volatile Organics (Standard List) by GC-MS						Analysis Qualifier(s): DL1.0			
Fluorene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Hexachlorobenzene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Hexachlorobutadiene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Indeno(1,2,3-cd)pyrene	EPA 8270C	ND	400	ug/kg	400	ADG1227	07/22/20	07/30/20	
Isophorone	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Naphthalene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Nitrobenzene	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
N-Nitrosodi-n-propylamine (NDPA)	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
N-Nitrosodiphenylamine (as DPA)	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Pentachlorophenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Phenanthrene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Phenol	EPA 8270C	ND	1000	ug/kg	20	ADG1227	07/22/20	07/24/20	
Pyrene	EPA 8270C	ND	100	ug/kg	20	ADG1227	07/22/20	07/24/20	
Surrogate: 2,4,6-Tribromophenol	EPA 8270C	%	<i>Acceptable range: 41-200 %</i>		<i>Qualifiers - SR4.1</i>				
Surrogate: 2-Fluorobiphenyl	EPA 8270C	114 %	<i>Acceptable range: 46-144 %</i>						
Surrogate: 2-Fluorophenol	EPA 8270C	135 %	<i>Acceptable range: 30-155 %</i>						
Surrogate: Nitrobenzene-d5	EPA 8270C	111 %	<i>Acceptable range: 30-149 %</i>						
Surrogate: Phenol-d6	EPA 8270C	80 %	<i>Acceptable range: 40-162 %</i>						
Surrogate: p-Terphenyl-d14	EPA 8270C	153 %	<i>Acceptable range: 45-161 %</i>						

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Certificate of Analysis

Sample ID: ADG2205-06RE1
Sampled By: Abel Alvarez
Sample Description: Composite of Drying Bed 4 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28

Matrix: Solid

Sample Type: Composite

Composite Start: 07/20/2020 - 10:28

BSK Associates Laboratory Fresno
Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
<u>Volatile Organics (Standard List) by GC-MS</u>									
2-Butanone	EPA 8260B	330	50	ug/kg	10	ADG1284	07/22/20	07/22/20	
Surrogate: 1,2-Dichloroethane-d4	EPA 8260B	112 %	<i>Acceptable range: 70-130 %</i>						
Surrogate: Bromofluorobenzene	EPA 8260B	107 %	<i>Acceptable range: 70-130 %</i>						
Surrogate: Toluene-d8	EPA 8260B	102 %	<i>Acceptable range: 70-130 %</i>						

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Certificate of Analysis

Sample ID: ADG2205-06RE2
Sampled By: Abel Alvarez
Sample Description: Composite of Drying Bed 4 (Front and Back)

Sample Date - Time: 07/20/2020 - 10:28

Matrix: Solid

Sample Type: Composite

Composite Start: 07/20/2020 - 10:28

BSK Associates Laboratory Fresno
Organics

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
<u>Volatile Organics (Standard List) by GC-MS</u>									
Acetone	EPA 8260B	ND	500	ug/kg	50	ADG1292	07/30/20	07/30/20	
Surrogate: 1,2-Dichloroethane-d4	EPA 8260B	96 %							Acceptable range: 70-130 %
Surrogate: Bromofluorobenzene	EPA 8260B	112 %							Acceptable range: 70-130 %
Surrogate: Toluene-d8	EPA 8260B	97 %							Acceptable range: 70-130 %



Sunnyslope Water District

Section H

Pretreatment

Not Applicable



Sunnyslope Water District

Section I

Salt and Nutrient Management Plan

Technical Memorandum

Sunnyslope County Water District

Subject: 2020 Annual Salt Management Report
Prepared For: Regional Water Quality Control Board
Certified by: Drew Lander, P.E. 79561 (Expires 9/30/2022), General Manager
Prepared by: Rob Hillebrecht, P.E. 88972 (Expires 9/30/2022), Associate Engineer
Reviewed by: Jose Rodriguez, Water & Wastewater Superintendent
Date: January 25, 2021

The purpose of this Technical Memorandum (TM) is to meet the Annual Salt Management Report requirements of the Regional Water Quality Control Board (RWQCB) Waste Discharge Requirement (WDR) Order No. R3-2004-0065 (December 3, 2004). Annual Salt Management Reports must be submitted by January 30th every year commencing in 2006. The report shall include, at a minimum:

- a. Calculations of annual salt mass discharged to the wastewater treatment system and disposal ponds with an accompanying analysis of contributing sources;
- b. Analysis of wastewater evaporation/salt concentration effects;
- c. Analysis of groundwater monitoring results related to salt constituents;
- d. Analysis of potential impacts of salt loading on the groundwater basin;
- e. A summary of existing salt reduction measures; and,
- f. Recommendations and time schedules for implementation of any additional salt reduction measures.

The TM is organized as follows:


1	Background	2
2	Salinity	3
2.1	Sources of Salt.....	3
2.2	Salt Mass Balance.....	7
2.3	Groundwater Impacts.....	8
3	Salinity Reduction Measures	8
3.1	Water Softeners.....	8
3.2	LESSALT Water & West Hills Water Treatment Plants.....	9
3.3	Groundwater Desalination.....	10
3.4	Hollister Urban Area Water and Wastewater Master Plan.....	10
3.5	Water Resources Association Groundwater Management Plan.....	10
3.6	Summary of Salt Reduction Options.....	11
4	Next Steps	12

1 Background

The Sunnyslope County Water District (SSCWD) in Hollister, California, operates one wastewater treatment plant (WWTP) shown in Figure 1-1 that serve the residences and a few commercial businesses near the Ridgemark Golf Course. The facility is known as Ridgemark WWTP. In prior years SSCWD operated a second facility known as Ridgemark II (RM II). The RM II facility was decommissioned in the third quarter of 2013 after completion of the new wastewater treatment facilities at Ridgemark WWTP and has not been in use since.

Prior to 2014, wastewater effluent from Ridgemark WWTP contained salinity levels exceeding State effluent limits. Salinity concentrations in surrounding area groundwater used to supply water service are already relatively high but a noted increase occurred through normal municipal use. Salinity was further increased by the widespread use of residential water softeners in the service area to soften the hard groundwater. Salt buildup in the groundwater basin is a significant long-term concern. Thus, salinity management measures are being implemented to preserve the long-term quality and beneficial use of groundwater resources in the region.

Figure 1-1: Ridgemark WWTP and Facilities



The WDR permit adopted in December 2004 includes a phased regulatory schedule to meet salinity water quality regulations. Beginning in January 2008, TDS, sodium, and chloride concentrations in the WWTP effluent were subject to WDR limits shown in Table 1-1. Stricter limits were phased in two years later to require the final concentration limits by January 30, 2010.

Table 1-1: Salinity Waste Discharge Requirements in 2008 and 2010

Effective Date	30-Day Average Limitations (mg/L)		
	Interim	January 30, 2008	January 30, 2010
TDS	No Limit	1,500	1,200
Sodium	No Limit	300	200
Chloride	No Limit	300	200

The 2020 average influent and effluent wastewater quality shown in Table 1-2 meets the limits for TDS and sodium but still exceeds the January 2010 limit for chloride. Efforts taken to reduce salinity are working and salinity management measures must continue to be implemented to meet WDR limits. This report will summarize the salt sources contributing to salinity in the wastewater effluent and will present salt management and reduction measures to address high salinity concentrations.

Table 1-2: Existing 2020 Average Wastewater Quality

Parameter	RM I SBR Influent *	RM I SBR Effluent
TDS (mg/L)	984	824
Sodium (mg/L)	212	193
Chloride (mg/L)	310	262

Data consists of averages from 12 monthly sampling events from January 2020 through December 2020.

* Discrepancies between Influent salinity and Effluent salinity values are a result of sample timing and not specifically a result of the treatment process.

The average TDS for 2020 is about 100 mg/L higher than in 2019 mainly due to increased use of potable groundwater to the Ridgemark WWTP customers. This is further discussed in Section 2.1.1.

2 Salinity

The effluent from Ridgemark WWTP has higher concentrations of TDS, sodium, and chloride than would normally be expected relative to the salinity of the local potable water supply. This section highlights the sources of these salt constituents and summarizes the results of a mass balance analysis that was performed on the system.

2.1 Sources of Salt

High effluent salinity concentrations stem from three primary factors. The first is the base salinity in the potable supply. The second is normal municipal and industrial (M&I) contributions as water is used. And the third is operation of residential self-regenerating water softeners. The salinity concentration in the Ridgemark WWTP percolation ponds may increase negligibly due to evaporation during warm weather periods, but this does not increase salt loading in the wastewater effluent. The contributions of each of these sources to concentrations observed in the effluent are noted in the following documentation.

2.1.1 Water Supply

Groundwater from wells and surface water from the Lessalt surface water treatment plant are the source of potable water supply for the sanitary sewer service area served by Ridgemark WWTP. Groundwater contains relatively high concentrations of salts and minerals contributing to hardness, while treated surface water has lower concentrations of salts and hardness. Table 2.1 shows the average TDS, sodium, chloride, and hardness concentrations for groundwater, surface water, and the proportional blend between these two sources. Since treated wastewater ultimately percolates back into the groundwater basin, the groundwater salinity mass load passes through the water and wastewater systems and returns to the basin. Therefore, groundwater salinity does not contribute additional salt load to the basin, but simply cycles it. Surface water from the Lessalt WTP however does contribute to the salt loading as the water and salinity dissolved in it are imported from outside the basin.

Table 2-1: Existing 2020 Potable Water Quality

Constituent	Groundwater Concentration (mg/L)	Lessalt Surface Water Concentration (mg/L)	Proportional Mix Concentration (mg/L)
TDS	792	265	436
Total Hardness, CaCO ₃	395	102	197
Sodium	125	55	78
Chloride	119	76	90

Source: 2020 SSCWD Biannual Water Quality Report Wells 5 & 8 & LESSALT WTP

Due to higher than usual water demand in the pressure zone serving most of Sunnyslope's wastewater customers, more groundwater was used than in previous years. This increase in water demand can be partially attributed to the COVID-19 pandemic as residents were required to stay at home as much as possible. Sunnyslope experienced about a 6-7% increase in potable water use due to the pandemic. Another factor for the higher water demand was significant construction water use as two large developments purchased and drew water from the same pressure zone as most Ridgemark WWTP customers. As Lessalt has limited capacity, the extra water demand was supplied by wells. Additionally, the Lessalt treatment plant was down due to repairs in August and then again for most of October due to very poor source water quality which the plant was unable to adequately treat. During these periods, all water was supplied by our groundwater wells.

Due to these two factors, about 32.4% of water to that pressure zone was supplied by wells compared to only 7.3% in 2019. However, it is understood that the Ridgemark WWTP likely received more than 32.4% groundwater. This is because the wells are located within that area while Lessalt is on the other side of the pressure zone. Water produced by the wells will first be used by Ridgemark WWTP customers and water produced by Lessalt will first be used by non-Ridgemark WWTP customers. However, we have no means to calculate the proportional mix beyond production data.

Overall, the increased use of groundwater accounts for at least 100 mg/L high average TDS simply from the water supply.

2.1.2 Municipal Use and Water Softeners

A significant amount of salt is added through customer use. Normal municipal use can add from 150-300 mg/l of TDS. Prior to 2014, very hard groundwater had been the only source for potable water. Due to this, most customers used residential water softeners. Though much of the water supply is now softer surface water from Lessalt, there is still widespread utilization of water softeners. These add a significant source of salt to the wastewater stream during self-regeneration cycles.

In 2020, the total TDS contribution from municipal use was approximately 388 mg/l based on the difference between source water quality data (436 mg/l from calculated Proportional Flow) and the effluent water quality leaving the Ridgemark WWTP (824 mg/l). This is well above the normal salt contribution for standard domestic use and reflects the significant impact of water softeners have on wastewater salinity in the Ridgemark WWTP service area.

Water softeners remove the calcium and magnesium ions that are responsible for hardness. The water softener resin must be regenerated periodically through washing with a concentrated brine solution of sodium chloride or potassium chloride. This brine water is then discharged into the sewer system during regeneration cycles and adds a substantial amount of salinity to the wastewater stream. Estimates of the amount of salinity added by water softener use can vary based on the hardness of the water, amount of water used, and the extent of water softener use in the area. The type of softener, its efficiency, and operational settings can also impact the regeneration frequency and result in elevated salt loads to the Ridgemark WWTP influent.

Older water softeners generally have their regeneration cycles based on a timer, in which the user sets a number of days between cycles regardless of the volume of water softened. This can impact the efficiency of the softener as it may regenerate early during periods of low water use. For this reason, timer-based softeners can have efficiencies as low as 1,500 grains of hardness removed per pound of salt (1 grain = 17.1 mg/l hardness). Demand Initiated Regeneration (DIR) softeners regenerate based on actual water use and have efficiencies ranging from 2,000-3,350 grains of hardness removed per pound of salt.

For both versions to operate efficiently, the source water hardness must remain the same as when the softener operational settings were programmed. The source water hardness for customers within the Ridgemark WWTP service area has dropped substantially due to the Lessalt Upgrade and pipeline constructed in 2014 to provide primarily higher quality surface water to these customers. Because many customer water softeners were set based off the groundwater hardness rather than the hardness of the surface water currently being provided, they are now operating at lowered efficiencies and regenerating more often than is necessary. An average water softener efficiency of 1,900 grains removed per pound of salt was estimated for Water Softener Analysis as it brought the final salinity calculation within reasonable range of observed testing. Simply reprogramming all water softener settings to account for the improved source water quality could considerably increase the softener efficiencies and reduce wastewater salt loading.

To determine an estimate for the water softener component of added salinity, an analysis was performed using assumed values for the parameters listed in Table 2-2.

Table 2-2: Assumptions in the Water Softener Analysis

Parameter	Value
Potable Water Hardness ^a	197 mg/l as CaCO ₃
Total % of households using water softeners ^b	47%
% of households using NaCl water softeners ^b	37%
% of household using KCl water softeners ^b	5%
% of households using off site regeneration ^b	5%
Household Indoor Use ^c	136 gpd
Average Water Softener Efficiency ^d	1,900 grains removed / lb. salt

a) Potable water hardness based on Proportional Mix from Table 2-1

b) Based on previous Annual Salt Management Reports and water softener removal rebates.

c) 160,328 gpd (average daily wastewater flows plus 5% for indoor water use not discharged to the sewer) divided by 1240 accounts = 136 gpd indoor use per day per account

d) Average water softener efficiency was adjusted so that calculated total TDS would equal the actual effluent TDS recorded.

According to the analysis, the estimated contribution to TDS from water softeners for the Ridgemark WWTP service area is approximately 182 mg/l for 2020.

2.1.3 Evaporation

Evaporation and precipitation do not play a significant role regarding salinity. When treatment ponds were used to treat the wastewater prior to the operation of the Ridgemark WWTP, it was mistakenly thought that evaporation had a notable concentrating effect on treatment pond salinity. This attempted to explain differences between influent and effluent salinity. However, these differences were due to grab samples not being representative of salinity variability in the influent sewer stream rather than evaporative effects.

Now with the operation of the Ridgemark WWTP, evaporation is even less significant. The small open surface area of the treatment basins and the short retention times within those basins eliminate any potential for salinity concentration due to evaporation.

2.1.4 Summary of Salinity Contributions to Ridgemark WWTP Final Effluent

TDS concentrations are high in the potable groundwater supply for the service area at approximately 792 mg/l. Lessalt Surface water TDS concentration is approximately 265 mg/l. The 2020 influent flow was 32.4% groundwater and 67.6% surface water. As this water is utilized in the service area the salinity concentrations increase through normal M&I use and through the regeneration of water softeners. After use, the water is discharged to the sewer collection system. Influent wastewater to Ridgemark WWTP has TDS concentrations of 730-1400 mg/l. Evaporation represents a miniscule element of the salinity concentration and has no effect on salt mass load percolated into the basin.

Table 2-3 reflects the relative contributions of various sources to TDS, Sodium, and Chloride.

Table 2-3: Estimated Municipal Use Contributions for Salt Constituents and Comparison to Actual WWTP Influent When Using Groundwater as the Potable Water Supply

Parameter	Potable Water Concentrations (1) Footnote (a)	Est. Water Softener Contribution (2) Footnote (b)	Est. Normal M&I Use Contribution (3) Footnote (c)	Est. Wastewater Concentrations (1)+(2)+(3)	Actual 2020 Average Effluent Footnote (d)
TDS (mg/L)	436	182	200	818	824
Sodium (mg/L)	78	96	50	195	193
Chloride (mg/L)	90	106	65	261	262

- a) Potable water quality data based on SSCWD biannual monitoring in 2020 of Wells 5 & 8 and Lessalt WTP.
- b) Water softener contribution based upon assumptions in Table 2-2.
- c) TDS, sodium, and chloride additions from normal M&I use was estimated to be 200mg/l, 50mg/l and 65mg/l respectively for Ridgemark WWTP distribution area. Generally accepted TDS additions for normal M&I use range from 150 to 300mg/l so these estimates are reasonable.
- d) Actual 2020 WWTP average effluent quality based upon Ridgemark WWTP effluent testing.

By providing a primarily surface water supply combined with customers' significant reductions in the use of brine discharging water softeners, the District has drastically improved wastewater effluent salinity since 2014. Concentrations of all salinity parameters have been reduced by over 50% since 2014 and continue trending downward. Wastewater effluent is now below the regulatory limit for both TDS and Sodium. However, to come into compliance with the 200 mg/l effluent limit for chloride the contributions from

water softeners must still be reduced by nearly an additional 50%. It is likely that it will take time for the District’s exerted education campaign to influence enough customers to adjust or discontinue using their self-regenerating water softeners. Nevertheless, if the current trend persists through the continued educational and outreach efforts, chlorides may come into compliance with the RWQCB requirements as early as 2025.

2.2 Salt Mass Balance

Salt concentrations from Table 1-2 in conjunction with 2020 proportional source water blend of 32.4% groundwater and 67.6% surface water were used to estimate the salinity mass loads shown in Table 2-5. The existing groundwater salinity contributes to a baseline salt load in the wastewater effluent of about 62.7 tons per year. This represents salt that passes through from groundwater extraction, use and percolation back into the groundwater basin. It therefore does not add salinity to the groundwater basin as this salinity was already present. Approximately 43.8 tons of salt were added to the basin as a result of the imported surface water salinity.

In 2020, typical M&I use is assumed to have contributed approximately 200 mg/L of TDS to the wastewater stream. This accounts for an added 48.9 tons of salt. Residential water softeners added an additional 182 mg/L TDS resulting in 44.4 tons of salt discharged into the basin.

The total salt added to the basin from imported surface water salinity, municipal and industrial use, and water softeners is 137.1 tons in 2020.

Table 2-5: 2018 Annual Salt Mass Loads

	Ridgemark WWTP
Annual Average Influent Flow Total (gpd)	160,328
Average Effluent TDS Concentration (mg/L)	824
Total Annual Salt to Disposal Ponds (tons)	201.4
Annual Salt from Potable Groundwater (tons) ^a	62.7
Annual Salt Load from Surface Water (tons)	43.8
Annual Salt Load from Normal M&I Use (tons)	48.9
Annual Salt Load from Water Softeners (tons)	44.4
Total Salt Added to Basin in 2020 (tons) ^b	137.1

Footnotes:

- a) Salt associated with the groundwater supply is a pass through. Salt in groundwater is returned to groundwater basin.
- b) Salt Added to Basin excludes Annual Salt from Potable Groundwater as it is a pass through of previously existing salt rather than new salt in the basin.

Notes:

- 1) Mass Load = Daily Flow * TDS Concentration * (days/year) * (L/gal) * (ton/mg)
- 2) 365 days/year, 3.79 L/gal, 1.102 x 10⁻⁹ ton/mg
- 3) Groundwater Daily Flow = 160,328gpd * 0.324 as groundwater was only 32.4% of total supply water. Groundwater TDS Concentration = 792mg/L based on biannual testing at Well #5 & #8
- 4) Surface Water Daily Flow = 160,328gpd * 0.676 as surface water was 67.6% of total supply water. Surface water TDS Concentration = 265mg/L based on biannual testing at Lessalt WTP.
- 5) Normal M&I Use TDS Concentration = 200mg/L based on Water Softener Analysis assumptions and salt balance.
- 6) Water Softener TDS Concentration = 182mg/L based on Water Softener Analysis.

2.3 Groundwater Impacts

SSCWD has six monitoring wells located around the disposal ponds to monitor groundwater conditions. Details on groundwater monitoring well installation and evaluation of groundwater conditions are described in the *Groundwater Monitoring Well Installation Report* by Todd Engineers. A summary of the data collected from these wells in 2020 is included in Table 2-6. Groundwater wells 1, 3, 4, and 5 were dry and were not able to be sampled. Monitoring well 2 appears to be monitoring mostly background groundwater. Monitoring Well 6 may be detecting legacy salinity from the operation of RM II.

Table 2-6: 2020 Wastewater Monitoring Well Average Water Quality

	MW 1 (Pond 6)	MW 2 (RM WWTP)	MW 3 (RM II)	MW 4 (Pond 6)	MW 5 (RM WWTP)	MW 6 (RM II)
TDS (mg/L)	Dry	758	Dry	Dry	Dry	1250
Chloride (mg/L)	Dry	220	Dry	Dry	Dry	565
Sodium (mg/L)	Dry	95	Dry	Dry	Dry	205
pH	Dry	7.54	Dry	Dry	Dry	7.53
Total Nitrogen (mg/L)	Dry	6.13	Dry	Dry	Dry	3.5
Notes	Dry for all 4 sampling rounds	-	Dry for all 4 sampling rounds	Dry for all 4 sampling rounds	Dry for all 4 sampling rounds	-

Notes: Average for 2020 quarterly data.

3 Salinity Reduction Measures

SSCWD is involved in a variety of programs and efforts to reduce salt loading to the groundwater basin. These programs include water softener education activities, a water softener removal rebate program, and water supply alternatives such as increased Central Valley Project (CVP) surface water treatment or potential future groundwater desalination. Additionally, there are many regional efforts being conducted by SSCWD, San Benito County Water District (SBCWD), City of Hollister, and San Benito County with the goal of reducing salinity throughout the entire groundwater basin. These cooperative efforts are critical towards developing efficient salt management solutions for all water purveyors and users in the region.

3.1 Water Softeners

A major goal of SSCWD's program is to reduce the amount of salts added by water softeners in its service area. SSCWD, SBCWD, and the City of Hollister all cooperate through the San Benito Water Resources Association (WRA) to develop programs to enhance customer knowledge and change customer behavior regarding water issues. One of the programs focuses on water softener removal through a rebate program, an educational campaign, and enforcing local ordinances banning the installation or replacement of all salt discharging water softeners.

Water Softener Rebate Program

Residential customers of SSCWD can participate in a water softener rebate program that is administered by the WRA. The program offers a \$250 rebate for replacement of a self-regenerating water softener with a cartridge style water softener and requires a minimum one-year contract with an offsite regeneration service. Customers who fully remove or demolished their water softeners are eligible for a \$300 rebate.

There were 38 SSCWD sewer customers who participated in the water softener rebate program in 2020. Since the Lessalt Upgrade in December 2014, 275 Ridgemark WWTP customers have received rebates through this program, representing approximately 22% of all sewer customers. It is unknown exactly how many SSCWD customers have removed or quit using their water softeners without applying for the rebates although the Water Softener Analysis suggests that more softeners have been removed than rebates have been given.

Water Softener Education Programs

SSCWD is conducting an educational campaign to inform its customers on the impact of water softeners on wastewater quality through website posts, distributing door hanger, and in the annual Drinking Water Quality Report. Educational literature also provides information on how to properly operate and adjust water softeners according to water quality. This is important as many softeners are no longer operating efficiently due to the improved source water quality. The WRA also promotes public education, distributes informational literature, and take surveys on water softener use at local events such as the San Benito County Fair and Farmers' Market.

Water Softener Ordinance

The Regional Water Quality Control Board took action to allow Sunnyslope County Water District and other local agencies to restrict the salinity discharge to the wastewater system from brine discharging water softeners. In February 2015, SSCWD adopted a new District Code prohibiting the replacement of salt discharging water softeners and prohibiting the installation of new salt discharging water softeners. The District also participates in a coordinated program with the City of Hollister and San Benito County Water District to limit the salinity discharge from water softeners by providing softer surface water to customers so that they no longer need a water softener.

3.2 LESSALT Water & West Hills Water Treatment Plants

As a joint effort with the City of Hollister, and SBCWD, Sunnyslope treats Central Valley Project (CVP) surface water from the San Felipe Project and delivers this softer potable water to customers. CVP water has lower salinity levels than local groundwater and has considerably lower hardness as shown in Table 3-1. The higher quality supply reduces the need for water softening, which results in a reduction of salt added to the groundwater basin.

Table 3-1: LESSALT WTP vs. Groundwater Water Quality

	Average TDS (mg/l)	Sodium (mg/L)	Chloride (mg/L)	Average Hardness, CaCO ₃ (mg/l)
Surface Water Quality	265	55	76	102
Groundwater Quality	793	125	119	395

Prior to 2014, less than one third of SSCWD's customers received an intermittent supply of CVP water. None of the customers in the area served by Ridgemark WWTP receive this treated surface water.

As part of the Hollister Urban Area Coordinated Water Supply and Treatment Plan, the Lessalt Water Treatment Plant was upgraded and went into operation in December, 2014. This upgrade included a pump station and associated pipeline from the Lessalt WTP to the Ridgemark area. SSCWD's wastewater customers are now largely supplied with surface water. As part of this Plan, a second surface water treatment plant called the West Hills Water Treatment Plant was constructed and began operation in 2017. The combination of these two surface water treatment plants has increased the delivery of high quality

drinking water to SSCWD and City of Hollister water customers. This results in reduced TDS, chlorides, and sodium being discharged from the two agencies' wastewater treatment plants.

In the spring of 2015 Sunnyslope began an extensive education and outreach program to inform all the residents of Ridgemark area of the improved water quality. SSCWD has continued these efforts through 2020 and observed major results. The reduction and/or elimination of the water softeners significantly reduced salinity in the wastewater discharge levels such that SSCWD is now in compliance with TDS and sodium discharge regulations. Chloride levels remain over the limit but have decreased by over 50% since the Lessalt WTP Upgrade in December 2014. This shows noteworthy progress toward achieving compliance for the final wastewater salinity parameter. The District will continue its salinity management campaign to make further reductions in sodium, chloride and TDS concentrations.

3.3 Groundwater Desalination

Groundwater desalination is a potential salt management solution but due to cost it is not anticipated until after other strategies have been significantly developed. Groundwater treatment is appealing from a long-term point of view as salt can be removed permanently from the San Benito County groundwater basin. However, the cost for disposal of the concentrated brine and the high electrical use are major drawbacks to this solution.

3.4 Hollister Urban Area Water and Wastewater Master Plan

In 2004, the City of Hollister, SBCWD, and San Benito County signed a Memorandum of Understanding (MOU) to develop the Hollister Urban Area Water and Wastewater Master Plan (HUAWWMP). In December 2007 the Board of SSCWD adopted the MOU Amendment, and formally joined the Governance Committee in 2009. The HUAWWMP ensures that stringent standards for wastewater management will be maintained to protect groundwater resources in the basin. The HUAWWMP study encompasses the SSCWD service area and developed a comprehensive plan for water supply and wastewater treatment and disposal within the Hollister urban area. Updates on HUAWWMP were completed in 2010 and 2017 with the publication of the implementation plan. The HUAWWMP identifies programs and projects to achieve the stated objectives of having drinking water with less than 500 mg/l TDS and between 120 to 150 mg/l hardness. Targeted recycled water objectives would provide a reclaimed water supply with less than 500 mg/l TDS or a maximum of 700 TDS if such water quality objectives can be achieved at a reasonable cost. In January 2010, the Hollister Urban Area Coordinated Water Supply and Treatment Plan were completed.

Sunnyslope County Water District, the City of Hollister, and San Benito County Water District have executed a Water Supply and Treatment Agreement to implement the Hollister Urban Area Water and Wastewater Master Plan and Coordinated Water Supply and Treatment Plan. The three major water supply and treatment components for the Coordinated Water Supply and Treatment Plan were to upgrade the Lessalt Surface Water Treatment Plant to 2.5 MGD, to construct the new 4.5 MGD West Hills Surface Water Treatment Plant, and to build a North (San Benito) County Groundwater Bank to supply water to these two treatment plants in time of drought. The Lessalt Upgrade was completed in 2014 and West Hills was completed in 2017. A feasibility study for the North County Groundwater project is ongoing.

3.5 Water Resources Association Groundwater Management Plan

WRA has developed a comprehensive Groundwater Management Plan (GMP) Update that addresses a number of groundwater quality and quantity issues. The GMP Update integrates salinity management into the broader basin plan and identifies a number of recommended programs for addressing salinity on a region wide basis. These programs are summarized in Table 3-2.

Table 3-2: Salinity Management Programs in the Groundwater Management Plan

Program	Description
Salinity Education Program	Salinity education of both agricultural and M&I users.
Water Softener Ordinance	Public education on the impact of water softeners, retrofit ordinance and water softener conversion rebate programs.
Industrial Salt Control	Cooperative reduction efforts with food processors and other industrial dischargers whose operations contribute elevated salt levels
Surface Water Importation and Treatment	Construction of surface water treatment delivery and storage facilities to supply a total of 6 to 9 MGD in a phased program.
Groundwater Treatment and Concentrate Disposal	Construction of demineralization facilities could reduce salt loads up to 2,270 tons per year for the basin. Concentrate disposal options are considered

SSCWD, SBCWD, City of Hollister, and San Benito County are continuing to work toward implementation of these programs and projects. Section 3.4 of the HUAWWMP further evaluated reclaimed wastewater and locations for utilizing reclaimed wastewater from the City of Hollister’s expanded wastewater treatment plant. SBCWD has constructed a recycled water pipeline that delivers treated wastewater from the City of Hollister’s wastewater treatment plant to farmers north of the City of Hollister. Additional recycled water projects are being contemplated and planned for future years.

The WRA also initiated development of a water softener ordinance that has been adopted by the City of Hollister and SSCWD. In 2012 the Regional Water Quality Control Board granted SSCWD and other local agencies the authority to regulate salinity discharge into its sewerage system. Continued implementation of these salinity control efforts is envisioned in future years.

3.6 Summary of Salt Reduction Options

The salt reduction options available to SSCWD include education programs, water softener ordinances and rebates, increased treatment and distribution of potable surface water, and ultimately groundwater desalination.

Currently, the most immediate method to reduce wastewater salinity is to promote the removal or reprogramming of water softeners in the Ridgemark WWTP service area. Elimination of all water softener use (or replacement of all brine discharging water softeners with cartridge type softeners, which use off-site softener regeneration services) has the potential to remove up to 182 mg/L TDS from wastewater effluent and achieve compliance with chloride limits.

The treatment and distribution of surface water has significantly impact improved regional salinity issues. These efforts continue to bring Sunnyslope closer to compliance as the overall water supply quality improves. Ultimately some form of groundwater desalination or softening may be required long term. However it is currently cost prohibitive while there are other potentially cheaper alternatives.

Finally, SSCWD is continuing an education program to convince Ridgemark customers to remove salt discharging water softeners, or at minimum reprogram their softener settings to operate efficiently for the improved water quality.

4 Next Steps

Based on current projections, Sunnyslope County Water District may begin meeting the requirements for chloride as early as 2025. This will be achieved by continuing to educate its wastewater customers about the improved water quality and reprogramming or eliminating the customers' brine discharging water softeners. Beginning in early 2015 and continuing throughout 2020, SSCWD has strived to inform its wastewater customers of the improved water quality that they began receiving in December, 2014. Additional efforts include offering rebates for the permanent removal of softeners or replacement with cartridge type softeners that are regenerated off site also continued. These have been successful at reducing wastewater TDS, sodium, and chloride concentrations by over 50% since 2014.

SSCWD intends to continue efforts in partnership with the WRA, SBCWD, and City of to increase potable surface water delivered to its customers. It will continue public outreach efforts to educate customers and reduce and/or eliminate the use of water softeners in the Hollister Urban Area.



Sunnyslope Water District

Section J

Collection System Management Plan

Sunnyslope County Water District


Sewer System Management Plan (SSMP)

2020




Legally Responsible Official Certification


I certify under penalty of law that this Sewer System Management Plan and all referenced attachments herein incorporated were prepared under Sunnyslope County Water District direction or supervision. Qualified personnel have properly gathered and evaluated the all information submitted. Based on inquiries of the persons who manage the sewer system and are directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. This document was presented to the Sunnyslope County Water District Board of Directors and approved on April 21st, 2020.




Drew A. Lander, General Manager
Legally Responsible Official



Date



Jose Rodriguez, Water/Wastewater Superintendent
Legally Responsible Official



Date

Table of Contents

Legally Responsible Official Certification	2
Table of Contents	3
Definitions and Abbreviations	5
Introduction.....	6
System Overview & Description	7
Section I. Goals.....	9
A. Regulations.....	9
B. Best Management Practices (BMP)	9
C. Employee Training.....	9
D. CCTV Investigation	9
E. CIP Projects.....	9
F. Capacity	9
G. Safety.....	9
Section II. Organization.....	10
A. Board of Directors.....	10
B. General Manager	10
C. Associate Engineer	10
D. Water/Wastewater Superintendent.....	10
E. Operations/Maintenance Crew Chief.....	10
F. Water/Wastewater Utility Maintenance	10
G. Communication Chain and Duties	11
Section III. Legal Authority.....	12
A. Prevent Illicit Discharges	12
B. Public and Private Sewage Disposal	12
C. Proper Design and Construction	12
D. Limit Types of Discharges	12
E. Enforcement	12
Section IV. SSSMP Implementation and Maintenance Program	13
A. Standard Operating Procedures (SOPs)	13
B. Sewer System Maps	13
C. Record & Evaluate Information	13
D. Preventative Maintenance	13
E. Capital Improvement Plan.....	14
F. Training	14
G. Equipment Inventory.....	14
Section V. Design and Performance Provisions	15
A. Sewer Standard Details and Specifications.....	15
B. Development Plan Review, Approval, Inspection, & Acceptance	15
C. Sewer Lateral Repair Permits.....	15
Section VI. Overflow Emergency Response Plan (OERP)	16
A. Initial Notification	16
B. Primary Response.....	16
C. Written Reporting.....	16
D. Investigation	16
E. Evaluate Overall Response.....	17

Section VII. Fats, Oils, and Greases (FOG) Control Program.....	18
A. FOG Elimination at the Source	18
B. FOG Hotspot Cleaning & Maintenance	18
Section VIII. System Evaluation and Capacity Assurance Plan.....	19
A. Data Collection.....	19
B. Maximum Capacity Analysis.....	19
C. New Developments	19
D. Capital Improvement Plan.....	19
E. Flow Monitoring	19
Section IX. Monitoring, Measurement, and Program Modifications	20
A. Information Collection	20
B. Data Analysis	20
C. Adapt and Modify Practices.....	20
Section X. Sanitary Sewer Management Plan Audits.....	21
A. Annual Review	21
B. Biennial Audit	21
C. Five Year Update and Approval.....	21
Section XI. Communication Program.....	22
A. Informing Employees.....	22
B. Public Outreach.....	22
1. Board Meetings.....	22
2. Website Links	22
3. Bill Inserts.....	22
4. Direct Customer Communication.....	22
SSMP Update Log	23

Definitions and Abbreviations

BMP – Best Management Practices

CCTV – Closed Circuit Television

CIP – Capital Improvement Plan

CMMS – Computerized Maintenance Management System

FOG – Fats, Oils, and Greases

GIS – Geographic Information System

I&I – Infiltration and Inflow

NPDES – National Pollutant Discharge Elimination System

OERP – Overflow Emergency Response Plan

OES – Office of Emergency Services

PVC – Polyvinyl Chloride Plastic

PPE – Personal Protection Equipment

RWQCB – Regional Water Quality Control Board

SCADA – Supervisory Control and Data Acquisition

SOP – Standard Operating Procedures

SSCWD – Sunnyslope County Water District

SSMP – Sanitary Sewer Management Plan

SSO – Sanitary Sewer Overflow

SWRCB – California State Water Resources Control Board

VCP – Vitrified Clay Pipe

WDR – Waste Discharge Requirement

WWTP – Wastewater Treatment Plant

Introduction

The California State Water Resources Control Board (SWRCB) approved order No. 2006-003, Statewide General Waste Discharge Requirements (WDR) for Wastewater Collection Agencies, in May 2006. This regulation requires that Sunnyslope County Water District (SSCWD) along with all other wastewater agencies develop, maintain, and implement a Sewer System Management Plan (SSMP) and submit specified monitoring and reporting of these measures to the SWRCB. The SSCWD Board of Directors approved the first SSMP on September 13, 2007. There have been regular reviews and updates of the plan to ensure that it remains up to date so as to incorporate and reflect any changes to the 11 key elements addressed in the SSMP.

The District has successfully operated its sewer collection system and continually strives to improve the reliability, affordability, and safety of sewer service for its customers. This document provides a summary of the core policies, processes, and practices which have enabled SSCWD accomplish this. For more detailed information regarding specific items, bracketed and italicized references to other specific District documents are provided at the end of various sections which further address those subjects.

[State Water Resources Control Board – Waste Discharge Requirements]

System Overview & Description

Sunnyslope County Water District was incorporated on December 14th, 1954 to provide drinking water and fire protection water services to then unincorporated portions of San Benito County east of Hollister. With the construction of the Ridgemark country club in the 1970's, SSCWD agreed to provide sanitary sewer service for the development and some neighboring properties as shown in the map below.

Figure 1. Map of Sunnyslope County Water District Wastewater Service Area



This sewer service area has developed such that SSCWD currently provides sewer service to approximately 4,000 people through about 1,240 residential homes in a 1.4 square mile area. This entire area is in the unincorporated portion of San Benito County, just southeast of Hollister. SSCWD also provides drinking water and fire protection water to all its wastewater customers along with about 5,000 other homes which receive sewer service from the City of Hollister.

The Sunnyslope sewer system is composed of approximately 20 miles of sewer mains, 315 manholes, 4 sewer lift stations, and the sequential batch reactor Ridgemark Wastewater Treatment Plant (WWTP). Approximately 10% of the gravity sewer mains are made of 6" or 8" vitrified clay pipe (VCP) installed in the early to mid-1970s. The remaining 90% is predominantly 8" polyvinyl chloride (PVC) plastic pipe from the 1980s through 1990s. Average wastewater flow to the Ridgemark WWTP is about 150,000

gallons per day (GPD) with maximum daily flows of up to 195,000 GPD. However this is well within the Ridgemark WWTP a treatment capacity of 350,000 GPD.

Due to the relatively young age of the sewer system and the high quality materials it was constructed from along with SSCWD's proactive maintenance and cleaning practices, there have been very few Sanitary Sewer Overflows (SSO), sewer main breaks, or other issues. Additionally infiltration and inflow (I&I) during storm events does not cause a noticeable increase in flow, attesting to the good condition of the sewer collection system.

All four SSCWD sewer lift stations are equipped with the District's Supervisory Control and Data Acquisition (SCADA) system allowing for operators to remotely monitor and control the status of these stations. Alarms programmed into the SCADA are active 24/7 and will alert operators of issues at key set points. Each station also has primary and backup submersible pumps in the wet wells to ensure that they can continue operation even if one pump is damaged. Two lift stations have permanent onsite backup power generators. The other two lift stations have adequate wet well storage to give staff sufficient time to respond and connect the District's portable generators to the lift stations.

Section I. Goals

The primary goal of the SSMP is primarily to protect the health and safety of the public by preventing SSO occurrences and properly mitigating any SSO to a safe level. To realize this, SSCWD intends to meet the following goals:

A. Regulations

In order to comply with all state and federal regulations and requirements including NPDES and WDR, SSCWD will continue to maintain zero occurrences of SSOs over the next five year period.

B. Best Management Practices (BMP)

Always employ BMPs in the planning, management, operation, and maintenance activities for the sewer collection system as shown through detailed SOPs, well documented decision-making, and accurate record keeping in the CMMS.

C. Employee Training

Provide effective and continuing employee training to ensure that all operations staff are competent and knowledgeable in the collection system maintenance and operation. This could include employee cross-training, obtaining of AWWA and CWEA certifications, attendance at industry conferences and events, or other opportunities.

D. CCTV Investigation

Initiate a Closed Circuit Television (CCTV) investigation program by 2021 which will have videoed the full collections system by 2024 to better evaluate the internal condition of the sewer main. The information from this investigation will be used to inform future CIPs.

E. CIP Projects

Create a detailed Capital Improvement Plan (CIP) by 2022 to identify and address collection system deficiencies or opportunities to better maintain and improve system performance. SSCWD shall coordinate with potential developments to implement various CIP projects jointly to minimize cost and disruption to the sewer collection system.

F. Capacity

Continue to maintain sufficient capacity in the collection system to convey maximum anticipated peak wastewater flows effectively to the Ridgemark WWTP and assure that additional development within the sewer collection system does not exceed that capacity. Also SSCWD intends to continue monitoring I&I to insure that it does not exceed 20% of normal daily flows.

G. Safety

Maintain a record of zero work related injuries for the next 5 years through regular safety training, enforcement of safety protocols, identifying potential hazards, and addressing safety concerns in a timely manner to minimize risk of injury.

Section II. Organization

Sunnyslope County Water District has been organized to provide clear management direction and to minimize confusion or miscommunication, especially during emergencies. Management structure includes a chain of authority to effectively delegate responsibilities and assures a chain of accountability for work performance.

A. Board of Directors

SSCWD is governed by a five member Board of Directors directly elected by the constituents living within the District boundary in general elections. The Board provides general policy direction to the District and serves as the final governing authority.

B. General Manager

The General Manager (GM) has ultimate responsibility for all SSCWD operations and activities. The GM answers to the Board of Directors for administrative, managerial, and operational compliance and reporting in regards to external and internal regulations and policies. When appropriately licensed the GM also serves as the District Engineer.

C. Associate Engineer

The Associate Engineer is responsible for the planning, design, and inspection of new and existing facilities within the sewer collection system as well as managing the CIP to improve the system functionality and prevent SSOs or other emergencies. The Associate Engineer may act as the District Engineer when appropriately licensed and the responsibility has been delegated by the GM.

D. Water/Wastewater Superintendent

The Water/Wastewater Superintendent is responsible for managing all field staff for all daily and emergency operation of the sewer collection system including recordkeeping and reporting as regulations require.

E. Operations/Maintenance Crew Chief

The Crew Chief is responsible for the daily management of the computerized maintenance management system (CMMS), assignment of work orders, and the employee safety and training programs.

F. Water/Wastewater Utility Maintenance

The Water/Wastewater Utility Maintenance staff are responsible for the daily maintenance and operational activities as assigned. They are generally the first responders to any sewer system issues and conduct the onsite work to resolve such issues. They also provide on-call service for 24/7 emergency response and monitor the sewer system via the District's SCADA.

[Organization Chart]

[Emergency Response Plan District Personnel]

[Job Descriptions of Pertinent Positions]

G. Communication Chain and Duties

The following list identifies the proper order of who is to be notified of an SSO.

1. **SSCWD District Office**.....(831) 637-4670
 - Receives initial notification from the public and begins internal notifications
2. **On-Call Maintenance Staff**.....(831) 801-5817
 - Receives initial notification outside business hours
 - Immediately responds to the SSO site to evaluate situation
 - Communicates to supervisor the situation & assistance or equipment needed
 - Starts addressing the SSO to resolve it and mitigate as directed
3. **General Manager**.....(831) 917-6696
 - Responsible for properly reporting to other agencies the occurrence of an SSO
 - Requests assistance from other agencies via mutual aid agreements if needed
 - Spokesperson to local news media and decides on extent of public notification
 - Ensures that proper written reporting is submitted to RWQCB on time
4. **Water/Wastewater Superintendent**.....(831) 524-0382
 - Responsible for calling upon and coordinating emergency response crew
 - Determines method to resolve SSO and mitigate all effects of it
 - Gathers needed information and field reports for written reporting to RWQCB
5. **Crew Chief**.....(408) 396-2320
 - Manages the on-site response activities to an SSO event
 - Determines what safety precautions & measures are necessary for staff
 - Considers public safety such as traffic control & minimizing public exposure
6. **San Benito County Communications**.....(831) 636-1400
 - Disseminates information to key County Departments like Sherriff and OES
 - Provides aid in notifying public and mass emergency communication
7. **San Benito County Health Department**.....(831) 637-5367
 - Advises on methods to minimize public exposure
 - Inspects all mitigation measures to ensure everything is sanitary
8. **California Fish & Game**.....(408) 649-2870
 - Must be contacted immediately if spill reaches a State Water Body
 - Evaluates the environmental damage and advises on mitigation
 - Inspects mitigation measures to ensure protection of environment
9. **Office of Emergency Services**.....(800) 852-7550
 - Must be notified within 2 hours if spill reaches surface water or drainage
 - Determines extent of damage to water body and containment options
 - Institutes temporary public safety measures such as closing access to water
10. **Regional Water Quality Control Board**.....(805) 549-3147
 - Must be notified within 24 hours of SSO
 - Regulatory authority over District
 - Advises on response strategy and implementation
 - Receives, reviews, and files the final written report
 - Determines whether fines or other enforcement measures are issued
11. **Board President**.....(831) 261-4451
 - Evaluates response actions taken and performance by General Manager
 - Considers expenditures and may call Special Board Meetings to address them

Section III. Legal Authority

District Code Title 4, provides SSCWD the legal authority to enforce the following rights and requirements to ensure public health and safety concerning the sewer collection system.

A. Prevent Illicit Discharges

Any discharge into the SSCWD sewer collection system that does not comply with all requirements of the District Code Title 4 is considered an illicit discharge and is subject to all legal enforcement measures as described in Code 4.40.

B. Public and Private Sewage Disposal

District Code 4.10 dictates that any property requiring sewer disposal within the District connect to the public sewer system unless specific exemptions detailed in Code 4.15 apply to permit a private sewage disposal system. This is intended to prevent unsanitary disposal of sewage which could be harmful to human and environmental health.

C. Proper Design and Construction

District Code 4.20 requires that all sewer facilities and connections be properly designed, constructed, tested, and inspected according to District standards. Additionally it ensures SSCWD has full access to all facilities for maintenance, repair, and replacement.

D. Limit Types of Discharges

District Code 4.25 prohibits various types of discharge to the sewer system including storm water drainage, garbage, debris, fat oil and grease (FOG), hazardous chemicals, new self-regenerating water softener brine, and other illicit discharges. This is to prevent blockages within the sewer collection system and disruption to the sewer treatment process at the Ridgemark WWTP.

E. Enforcement

District Code 4.40 provides the means and methods through which SSCWD may enforce these regulations. Avenues available for such enforcement include inspection, notice of violation, sewer disconnection, water discontinuance, fines, and assessment of civil and criminal proceedings.

[Sunnyslope County Water District Code]

Section IV. SSSMP Implementation and Maintenance Program

Sunnyslope County Water District staff engage in daily operation and maintenance of the sewer collection system in order to ensure the good performance and condition of the facilities. By incorporating these maintenance strategies into the regular operational procedures, staff effectively minimize the likelihood of SSOs and other emergencies by resolving issues before they cause larger problems.

A. Standard Operating Procedures (SOPs)

Staff shall develop and follow comprehensive and clear SOPs to describe all details of each operational procedure. This guarantees consistent methods are used between various maintenance personnel and is especially key when training new staff. Consistency is vital so that all equipment and facilities are evaluated according to the same standard and receive the same level of care.

B. Sewer System Maps

The Associate Engineer maintains accurate and updated mapping of the sewer collection system including all gravity and force main sewer lines, manholes, lift stations, and other facilities. This map data is stored in the geographic information system (GIS) along with the age, material, elevation, slope, and other pertinent information for each asset. Annual updates to these maps shall be distributed to replace any outdated sheets and ensure that all maps are current.

[Sewer System Maps]

C. Record & Evaluate Information

The District records and evaluates relevant information to identify trends and evaluate the collection system performance. This information is then used to give insight on potential issues and the measures taken to prevent them. Implementation of the CMMS program will significantly aid in the collection and filing of this data so that it is easily accessible and utilized.

D. Preventative Maintenance

Staff are proactive in conducting routine preventative maintenance of the collection system facilities and equipment to ensure their reliability and consistent performance. This includes daily monitoring of lift stations, regular clearing lift stations of debris, and scheduled sewer pipe cleaning and flushing. Specific cleaning is done in target areas of historic concern and issues. The Crew Chief assigns the various maintenance activities from an Excel-based CMMS program which schedules and creates work orders. Once these work orders are completed, the Crew Chief updates the program and assesses if further maintenance work is required. SSCWD intends to transition from the Excel-based CMMS to using the NexGen Asset Management program in the coming years. This is a much more robust CMMS system which will more easily analyze maintenance activities. Such analysis will enable SSCWD to become even more proactive in preventative maintenance by studying various trends, costs, and lifecycles of the system assets.

E. Capital Improvement Plan

The District is developing a CIP for the sewer collection system which identifies the structural deficiencies within the system and proposes long term solutions to resolve those problems. Often, these solutions involve the rehabilitation or replacement of existing facilities at risk of failure. However it may also include new projects which may resolve longstanding maintenance matters that cause recurring problems. The CIP is informed by historical information and condition assessments of the facilities.

[Sewer System CIP]

F. Training

The District is committed to providing regular training and continuing education to all of its staff. This may include on-the-job cross-training between various employees, group training sessions, or more formalized training classes. Staff are encouraged to pursue specialized training and SSCWD has adopted personnel policies to accommodate and reimburse many training and certificate opportunities. Certain compensation step advancements are conditioned on obtaining specific certificates or licenses to further motivate employees. To demonstrate this emphasis on employee training, SSCWD budgets appropriately for professional development.

G. Equipment Inventory

SSCWD maintains a robust inventory of parts and equipment necessary for emergencies and repairs. This includes identification of critical specialty parts which must always have a spare replacement in the District's possession for immediate repair. Such inventory provides assurance that the sewer collection system remains operational even in the event of unexpected equipment failure. Staff routinely evaluate and update the inventory to ensure the system's resiliency.

Section V. Design and Performance Provisions

Sunnyslope County Water District requires all new, rehabilitated, and replacement sewer facilities to conform to the District's adopted design details and specifications. These design requirements provide assurance that the collections system is properly constructed and is consistent in the application and installation of facilities. District design details are regularly reviewed and updated.

A. Sewer Standard Details and Specifications

SSCWD keeps sewer standard details and specifications which must be adhered to in the design and construction of all additions or alterations to the sewer collection system. These standards are regularly reviewed to ensure that they remain updated and utilize reliable and state of the art technology. Maintenance staff are also encouraged to provide feedback and recommendations for improvements upon the standard designs.

[Sewer Standard Construction Details and Specifications]

B. Development Plan Review, Approval, Inspection, & Acceptance

All proposals for new developments that are to obtain sewer service from SSCWD must submit Improvement Plans for the District's review and comments. In reviewing these plans, SSCWD staff consider conformance to District standards, long term system maintenance, capacity, future growth, access, and several other factors. Once all District comments have been satisfactorily addressed, the General Manager signs approval of the Improvement Plans. A standard agreement for facilities and service between the developer and the District with Board approval. During construction, SSCWD staff inspect and test the installation of the sewer system to ensure that the standards are properly followed. Upon completion of the sewer system construction, the District accepts ownership of it from the developer and assumes responsibility at that point for all operation and maintenance activities for that addition to the sewer system.

C. Sewer Lateral Repair Permits

Sewer laterals extending from the sewer main in the street to the private home are owned and maintained by the property owner, and they are responsible for any repairs or replacements needed. However, SSCWD requires that a permit be obtained from the District for any repairs or replacements of the lateral prior to any work. District staff shall inspect the sewer lateral and its repairs prior to burial to insure proper installation and workmanship. SSCWD will work closely with the San Benito County Building Department to coordinate the sewer lateral permits alongside any other county permits the homeowner is required to obtain.

Section VI. Overflow Emergency Response Plan (OERP)

The OERP is intended to protect public and environmental health and safety in the event of a sanitary sewer overflow (SSO) and to mitigate any danger posed by a SSO as quickly and safely as possible.

A. Initial Notification

SSCWD personnel are generally first notified of a SSO by phone. During business hours (8am-5pm Mon-Fri) office staff answering the phone will take down all pertinent information from the caller including the address and location, time, SSO severity, and other key information. They will immediately dispatch maintenance staff to respond. Outside of business hours, the public can indicate there is an emergency (SSO) happening through the District's answering machine, which then transfers them to the 24/7 on-call maintenance staff cell phone. The on-call employee will take the relevant information and immediately respond to the situation. All the sewer lift stations also have high level alarms which through SCADA will automatically call out to the maintenance staff cell phone when triggered. This provides some advanced notice before a lift station overflows.

B. Primary Response

A copy of the OERP is in the Emergency Response Plan and Operations & Maintenance Procedures Binders which are located in each service vehicle and various District facilities. The OERP lays out the procedures for notification and response to a SSO through step by step instructions. The 24/7 on-site response time is always to be one hour or less from the time of the first notification call. All anticipated equipment necessary to address the SSO is to be retrieved so SSO containment, mitigation, and clean-up can start immediately. The OERP also indicates the regulatory agencies that must be contacted and timelines for that contact. Once on site, staff follow the OERP guidelines for effectively and safely containing the spill, resolving the blockage or other issue causing the SSO, and mitigating the site. Maintenance staff annually review the OERP so that they are prepared to effectively respond and follow its guidelines.

[Overflow Emergency Response Plan]

C. Written Reporting

The on-site staff responsible for the SSO containment, cleanup, and mitigation must prepare a written field report using the Field Spill Report Form within 24 hours of the spill. This report should include all pertinent information including the time, location, estimated volume of the spill, names of responders, measures taken to contain and resolve the spill, and mitigation measures enacted. Additional reporting shall be conducted and submitted to the proper regulatory agencies as required.

[Field Spill Report Form]

D. Investigation

All SSO incidents shall be thoroughly investigated to determine the cause for the spill. Corrective action based upon the results of this investigation shall be taken to prevent

future spills. Such actions may include increased sewer cleaning in the location, FOG enforcement action, CIP projects to rehabilitate sewer mains, or other actions.

E. Evaluate Overall Response

After all aspects of a SSO have been completed from initial response through the final investigation and reporting, staff conduct thorough evaluation of the overall response and all actions taken. Every step and decision of the event is critiqued to determine what was or was not effective. The goal is to learn from the real-world experiences and situations to improve future responses to similar emergencies by determining what strategies were or were not helpful and effective. Using this information, appropriate changes or revisions to the OERP shall be proposed and implemented to improve the response.

General categories for the critique include:

1. Initial notification and communication
2. Response time and preparedness
3. Initial determination of SSO scope and damage potential
4. Coordination and dispatching of emergency crew
5. Determination and gathering of parts & equipment
6. Containment and bypassing of SSO wastewater
7. Safety of public and employees (traffic, PPE, lights, unsanitary exposure, etc.)
8. Clearing of the plug or issue to restore normal flow
9. Site cleanup and restoration/mitigation
10. Notification of other agencies and following of Chain of Communication
11. Investigation of SSO cause and actions taken to address the determined cause
12. Writing and submitting of the required reports

Section VII. Fats, Oils, and Greases (FOG) Control Program

Fats, oils, and greases from cooking and food preparation that enter the sewer system can congeal and fall out of solution. As FOG is not water soluble, they can continue to build up on the inside of the sewer pipes and eventually cause blockages that contribute to SSOs. In an attempt to eliminate this issue from its sewer collection system, SSCWD has implemented the FOG Control Plan here summarized.

A. FOG Elimination at the Source

The most effective means of combatting FOG is preventing it from ever entering the sewer collection system. To accomplish this, the FOG Control Program includes the following key elements.

1. Identification of FOG Sources
2. Legal Enforcement Authority
3. FOG Removal Device Requirements/Specifications
4. Inspection & Monitoring
5. Record Keeping of Best Management Practices (BMPs)
6. Public Education & Outreach

[FOG Control Program]

B. FOG Hotspot Cleaning & Maintenance

While the main contribution of FOG to SSCWD's sewer system is from food service establishments, the accumulation of FOG from individual residences can also contribute to SSOs and must be addressed. Historical maintenance data has been used to identify various hotspot areas that need to be addressed more regularly. Below is the maintenance schedule for these areas.

Weekly Flushing

- 1) Joes Lane south to Donald Drive
- 2) Club House to Donna Lane
- 3) Cheri Court to Ridgemark Estates Wastewater Treatment Ponds II

Semi-monthly Flushing

- 1) Helen Court (every second week)

Monthly Hydro Cleaning

- 1) Club House to Donna Lane

Semi-annual Hydro Cleaning

- 1) Joes Lane south to Donald Drive
- 2) Helen Court
- 3) Club House to Donna Lane
- 4) Paullus Drive to Ridgemark Estates Wastewater Treatment Ponds II

Section VIII. System Evaluation and Capacity Assurance Plan

Sufficient sewer collection system capacity is key to preventing SSOs from occurring due to peak instantaneous flow conditions.

A. Data Collection

In 2012 SSCWD hired Wallace Group to compile GPS data on all the collection system facilities and compile the data into a GIS format. The data collected included the coordinate location, elevation, depth, and invert of all manholes along with the gravity sewer pipe material, size, and slope. All this information was made easily accessible for analysis of the sewer system capacity. New developments are required to provide AutoCAD files to the District to update GIS format.

B. Maximum Capacity Analysis

In 2020 SSCWD staff created an Excel spreadsheet with the information obtained from the Wallace Group study to calculate the design free flow maximum capacity for each section of sewer pipe in the collections system. The design capacity is determined as 75% full pipe flow using the Manning equation for open-channel flow. By establishing the design capacity as 75% full pipe flow, factor of safety is incorporated as a buffer for I&I and other factors such as FOG accumulation, root intrusion, and for preventing potential system damage caused by syphoning. This analysis has revealed areas within the existing sewer collection system of inadequate design capacity, although still within the full pipe flow capacity. These areas receive prioritized attention for cleaning and maintenance as well as consideration for upsizing through CIP or new development projects.

[Sewer Capacity Analysis]

C. New Developments

Whenever a new development is proposed to receive sewer service from SSCWD, an analysis is conducted to determine the downstream effects of the additional sewer flow. If that additional flow from the new development causes a section of gravity sewer main to be over design capacity for peak hour flow, that development must upsize that section prior to receiving sewer service.

D. Capital Improvement Plan

In areas where the flows main are over the gravity sewer design capacity at peak hour flow, SSCWD shall consider upsizing of those pipes as part of the CIP. These lines shall be evaluated to consider risk of failure, cost of replacement or upsizing, constructability, and other factors to prioritize the projects. SSCWD will also look for opportunities to incorporate such pipe upsizing projects into proposed development projects.

E. Flow Monitoring

SSCWD staff shall perform routine evaluation of sewer system flow conditions by analyzing pumping trends at the four lift stations. In this way, comparisons can be made between estimated peak hour flows and real observed flow rates experienced in the sewer mains. This information shall then be used to revise the sewer capacity evaluation.

Section IX. Monitoring, Measurement, and Program Modifications

The success of SSCWD's SSMP is continually monitored and evaluated through several methods and measurements. These serve to inform staff of the effectiveness of the various implementation strategies and provide valuable feedback for improvement.

A. Information Collection

SSCWD staff collect and record key data which is maintained in the Excel CMMS for easy access and analysis. This data includes regular maintenance activities like cleaning lines, unclogging lift station pumps, servicing motors, chemical dosages, power usage, lift station levels, and other relevant routine information. It also includes all non-routine data such as SSO events, system repairs, emergency call-outs, mitigation measures taken, overtime hours, and any other key data. SSCWD intends to transition from the Excel CMMS to the NexGen Asset Management CMMS program. NexGen is a much more robust CMMS system that will enhance the District's ability to better analyze trends, costs, equipment lifecycles, and other key aspects. Moreover, it can enable predictive planning of equipment repair and replacement for budgetary purposes.

B. Data Analysis

Reports summarizing all the collections system data are regularly created for the Water/Wastewater Superintendent, Associate Engineer, and General Manager to review. Noteworthy information is reported to the Board of Directors at monthly general board meetings. Staff use these reports to inform decisions regarding the effectiveness of current preventative maintenance and corrective measures taken as well as opportunities to improve upon them.

C. Adapt and Modify Practices

After evaluation of the data collected and analyzed, SSCWD staff consider whether any changes or modifications to the SSMP are necessary or useful to further the goal of eliminating SSO occurrences and improving the overall sewer collection system performance. Maintenance staff are always encouraged to suggest ideas for new and better practices and these ideas are seriously considered. Such new concepts or methods can be tested in pilot projects or trial periods and closely monitored to determine whether they should be implemented system wide and incorporated into the SSMP.

Section X. Sanitary Sewer Management Plan Audits

This SSMP is meant to be a living document which is regularly reviewed and updated as circumstances and situations around it change. As such, it is regularly reviewed and audited.

A. Annual Review

The SSMP undergoes yearly review by the General Manager, Water/Wastewater Superintendent, Associate Engineer, Crew Chief, and all Maintenance staff during the Operations and Emergency Response Training. This training generally takes place in January and is required for all relevant management and field staff.

B. Biennial Audit

A full internal audit of the SSMP is conducted by management staff at least once every two years evaluating the effectiveness of SSMP implementation measures. This audit shall focus on the previous two years, but also consider the long-term progress in achieving the SSMP goals.

C. Five Year Update and Approval

At least once every five years, a full update of the SSMP shall be conducted to incorporate all changes and modifications. This update shall then be taken before the Board of Directors for their approval.

Section XI. Communication Program

It is critical to the success of this SSMP that the information contained within it be clearly and effectively communicated to SSCWD employees, sewer customers, and the public.

A. Informing Employees

All management and field staff are required to review the SSMP during the annual Operations and Emergency Response Training. This training is also to be provided to new employees within 2 weeks of their start date. Through this review, SSCWD ensures that field staff understand the requirements, procedures, and practices of the SSMP so that they can be successfully implemented in the daily operation of the collection system. Additionally, the SSMP shall be periodically reviewed with office staff so that they too understand the SSMP goals and purpose. This is key as they are often the first contact with customers and must be prepared to provide them clear and accurate information.

B. Public Outreach

SSCWD is dedicated to providing its sewer customer and the general public with clear, accurate, and easily accessible information regarding the SSMP and the sewer collection system in general. Several public outreach strategies outlined below have been implemented to disseminate this information and to advise customers on how they can participate in safeguarding the sewer collection system.

1. Board Meetings

SSCWD Board Meetings are fully open to the public and agendas of each meeting are posted on the District's website. At these meetings, regular reports are given on the status and operations of the sewer collection system.

2. Website Links

The approved SSMP is posted through a link on the SSCWD website (sscwd.org) and can easily be located and read through. The website also houses board meeting minutes and other general information.

3. Bill Inserts

Monthly bills are delivered to all SSCWD customers which often include bill insert fliers informing customers of District news and programs.

4. Direct Customer Communication

The most effective means for informing customers of the elements of the SSMP is through direct face to face or phone conversation. Concerned customers often call the SSCWD office and the office staff can take advantage of this opportunity to answer their questions and give them accurate information. They can also make certain that the customer truly understands and appreciates the importance of controlling what they dispose of into the sewer system. Equally effective is the face to face interaction that customers may have with field staff as they conduct routine and emergency maintenance. Employees can take advantage of the customer's curiosity to educate them about the sewer system and ways the customer can help prevent SSOs.

SSMP Update Log

Original Approval September 13th, 2007

Audit Review & Update September 10th, 2009

Audit Review & Update March 2nd, 2012

Current Audit Review & Update April 21st, 2020

Sunnyslope County Water District Board Approved this Sewer System Management Plan at the Regular Board Meeting on April 21st, 2020.



Sunnyslope Water District

Section K

Mercury Seals

Not Applicable



Sunnyslope Water District

Section L

Figures


Figure 2-1: Ridgemark I Facilities (Photo taken during construction March 2013)




MONITORING WELL LOCATIONS



Figure 6-2: SBR Plan



RM – I Ridgemark Estates Wastewater Treatment Ponds
 Sequencing Batch Reactor (SBR) Lab Sample Site Sheet



Revised 12-2013

- All Disposal Pond Monitoring Sites for Weekly Lab pH, Dissolved Oxygen (DO) Monitoring 1 foot depth at 3 locations in each of the 4 ponds.
- Starting the Fourth Quarter 2012 Sampling the Influent and Treated Effluent will be from the SBR Head Works and Decant Equalization Tank .

Figure 2-2: Ridgemark I Site Plan

