

Wyoming State Fire Marshal



Occupancy: **Building Blocks Daycare PR 20175 FA ; 20227 EO
(Electrical completed)**

Occupancy ID: **1058**

Address: **319 W 4th
Rawlins WY 823018230**

Inspection Type: **Reinspection**

Inspection Date: **2/15/2022** By: **Rood, AI (0000017106)**

Time In: **15:23** Time Out: **15:42**

Authorized Date: **02/15/2022** By: **Rood, AI (0000017106)**

Next Inspection Date: **03/15/2022 Reinspection**

Form: Maintenance E

Inspection Description:

Educational Group Occupancies includes, among others, the use of a building or structure, or a portion thereof, by 6 or more persons at any one time for educational purposes through the 12th grade.

Inspection Topics:

Exits

1008.3.1,2; Means of egress illuminated at all times. emergency power supply

In the event of power supply failure in rooms and spaces that require two or more means of egress an emergency electrical system shall automatically illuminate all of the following areas: In the event of power supply failure, in buildings that require two or more means of egress, an emergency electrical system shall automatically illuminate all of the following areas: The emergency power system shall provide power for a duration of not less than 90 minutes and shall consist of storage batteries, unit equipment or an on-site generator. The installation of the emergency power system shall be in accordance with Section 2702 of the International Building Code.

Status: PASS

Notes: 1. Repair/replace the following egress lights

- a. Main entrance wall pack (Dead Battery)
- b. North side gym battery is failing
- c. East side gym battery is failing

02-15-2022: Completed
Thank You

Fire Protection Systems

901.6, Table; Inspection, testing and maintenance- fire extinguishers-annually w/tags attached

Fire protection systems shall be inspected, tested and maintained in accordance with the referenced standards listed in Table 901.6.1.

Status: PASS

Notes: Rawlins fire extinguisher was called while on site the extinguishers were due in December

02-15-2022: Completed
Thank You



901.6; Inspection, testing and maintenance

Fire detection and alarm systems, emergency alarm systems, gas detection systems, fire-extinguishing systems, mechanical smoke exhaust systems and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection systems and equipment shall be inspected, tested and maintained or removed.

Status: PASS

Notes: Note:

The Fire Alarm Annual was Done on 11-10-2021 by Dean Jackett with Rocky Mountain Fire Systems I called Dean and requested a copy of the report.

Housekeeping

Please correct the following Housekeeping code violations

IFC

Status: General Site Comments


Notes: Treat all window curtains with flame retardant

Note:

Make labels for each individual curtain with the following information

1. Chemical used
2. By who treated
3. Date treated

Cheryl has been approved for a grant and will be tinting the windows



Additional Time Spent on Inspection:

Category	Start Date / Time	End Date / Time
----------	-------------------	-----------------

Notes: No Additional time recorded

Total Additional Time: 0 minutes

Inspection Time: 19 minutes

Total Time: 19 minutes

Summary:


Overall Result: Passed

Maintenance and plan review projects when no corrections are needed and all inspections are completed.

Inspector Notes:

Inspector:

Name: Rood, Al
Rank: Fire Inspector
Mobile Phone(s): 307-851-0278
Email(s): al.rood@wyo.gov
Rood, Al:




Signed on: 02/15/2022 15:32

Signature

Date

Representative Signature:

Signature of: Cheryl Hulme on 02/15/2022 15:35



Signature

Date