

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference maybe from a previous version of the section and no longer cited. The primary source should always be checked.

AP-42 Section Number: 1.3

Reference Number: 13

Title: Emission Test Reports, Docket No. OAQPS-78-1, Category II-I-257 through 265

Office of Air Quality Planning and Standards

US EPA

1972

0ARPS-78-1
7615-II-I 261

FUEL
OIL COMBUSTION
AP-42 Section 1.3
Reference Number
24

7


4193 Ref 21

Emission Test Report
Steel Point Station Stack No. 1
Steam Generator Nos. 1-6

1
1923

The United Illuminating Company
Steel Point Station
43 East Main Street
Bridgeport, Connecticut
06608

Approved by:

E. W. Somerville 
Vice President, Engineering and Planning

Submitted by:

M. R. McCraven 
Director of Environmental Engineering

Emission Test Report

Steel Point Station Stack No. 1
Steam Generator Nos. 1-6
(Ref. "Intent to Test" Form Number 720059)

Test Conducted By
The United Illuminating Company
Development and Test Laboratory
80 Temple Street
New Haven, Connecticut
06506

United Illuminating Company Personnel Present
J. Sombati
J. Hotchkiss
J. Macknis

and by

York Research Corporation
One Research Drive
Stamford, Connecticut
06906

York Research Corporation Personnel Present
R. Epstein
J. Jasko

Prepared by:

J. S. Sombati: *J. Sombati*
Development and Test Laboratory Supervisor
J. W. Hotchkiss *J. W. Hotchkiss*
Assistant Mechanical Engineer

Checked by:

J. F. Crowe *James F. Crowe*
Chief Mechanical Engineer

Test Results

Steel Point Station Steam Generator
Nos. 1-6

Test Conducted On
November 13 and 14, 1973

Introduction

Emission tests for particulates and nitrogen oxides were conducted as required by Connecticut State Law on the United Illuminating Company Steel Point Station Steam Generator Nos. 1-6, stack No. 1, located in Bridgeport, Connecticut. Testing was conducted on November 13 and 14, 1973.

Particulate testing was performed in accordance with test methods and procedures as prescribed in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. Testing was performed by York Research Corporation of Stamford, Connecticut, using a sampling train as described in Appendix A.

Particulate emission test No. 3 was not completed on this source due to a steam leak in Boiler No. 5 which started midway through test No. 2. In telephone conversation, on November 14, 1973, with Mr. Carl Dodge of the State of Connecticut Department of Environmental Protection, the test would be accepted as valid.

Nitrogen oxide emission testing was performed by the United Illuminating Company Development and Test Laboratory using a Dynascience Model P-101 NO_x Analyzer. Field data is included in Appendix B.

Tests were also conducted to determine stack gas velocity, moisture content, and flue gas analysis. The procedures used in determining these various parameters, except for flue gas analysis, are those found in the above mentioned Federal Register. The stack flue gas was analyzed by using an Analytical Instrument Development Model 512 Portable Gas Chromatograph.

York Research Corporation was retained to perform particulate tests, together with a preliminary velocity traverse, moisture determination, and fuel oil analysis. The United Illuminating Company was responsible for the flue gas analysis, nitrogen oxide analysis, and for accumulating boiler operating data.

This test report includes the information required for item numbers III, IV, V, VI, VII, VIII, IX, X, XI, XII, and XIII from the Department of Environmental Protection's Intent to Test form in compliance with the Department of Environmental Protection's new Source Test Guidelines and Procedures, (received April 3, 1973).

TABLE I

SUMMARY OF TEST RESULTS

STEAM GENERATOR NOS. 1, 2, 3, 4, 5, 6

STACK NO. 1

<u>Component</u>	<u>Sampling Duration</u>		<u>Number of Tests</u>	<u>Measured Concentrations</u>	<u>Method Employed to Determine Concentration</u>
	<u>Minutes per point</u>	<u>Total test time</u>			
1) NOX		15 min	3	0.28 lb/10 ⁶ BTU	Dynascience Model P-101 NOX Analyzer
2) Particu- lates	5	100	3	0.09 lb/10 ⁶ BTU	Method 5*
3) Moisture	5	100	3	9.7%	Method 4*
4) Gas Analysis		15 min	3	42% Excess Air	A. I. D. Model 512 Portable Gas Chromatograph
5) Velocity	1/2	15 min	3	0.12" H ₂ O to 0.34" H ₂ O**	Method 2*

* Federal Register, Vol. 36, No. 247, December 23, 1971

** Range of S-type Pitot - Tube Differential

TABLE II

SUMMARY OF RESULTS

STEAM GENERATOR NOS. 1, 2, 3, 4, 5, 6

STACK NO. 1

Test	<u>1</u>	<u>2</u>	<u>3</u>	<u>Average</u>
Date	11/13/73	11/14/73	11/14/73	
Stack Flow, ACFM	306,897	288,252	296,381	297,177
Stack Flow, SCFM	141,886	126,730	124,858	131,158
Stack Flow, lb/hr	656,572	588,408	578,164	607,715
% Excess O ₂ at Test Point	8.50	8.29	8.47	8.42
Particulate Emissions				
gr/SCF	0.010	0.026	0.057	0.031
lb/hr	12.6	28.3	60.7	33.9
lb/MBTU	0.03	0.07	0.16	0.09
Nitrogen Oxide Emissions				
ppm	114	120	114	116
lb/hr	115.7	108.8	101.8	108.8
lb/MBTU	0.30	0.28	0.27	0.28

partic: 33.9 lb/hr = 12.4 lb / 10⁶ gal | 0.37% excess
2.721 lb/hr
NOx: 109.4 lb/hr = 40 lb / 10⁶ gal

TABLE III

AVERAGE BOILER OPERATING DATA FOR TEST PERIODS

STEAM GENERATOR NOS. 1, 2, 3, 4, 5, 6

STACK NO. 1

	<u>1</u>	<u>2</u>	<u>3</u>
Test	11/13/73	11/14/73	11/14/73
Date	2651	2808	2719
Oil Flow (Total) gal/hr	386.7	395.6	383.0
Heat Input (Total), MBTU/hr	625.8	626.5	618.5
Stack Gas Temperature °F	0.038	0.038	0.038
Gas Density, lb/ft ³			

TABLE IV

FUEL OIL ANALYSIS

STEAM GENERATOR NOS. 1, 2, 3, 4, 5, 6

STACK NO. 1

	<u>1</u>	<u>2</u>	<u>3</u>
Date	11/13/73	11/14/73	11/14/73
	<u>Composition (% by Weight)</u>		
Carbon	85.93	86.06	86.06
Hydrogen	12.78	12.75	12.75
Nitrogen	<0.1	<0.1	<0.1
Ash	0.020	0.017	0.017
Sulfur	0.39	0.36	0.36
Specific Gravity	0.900	0.892	0.892
BTU/lb	19,458	18,959	18,959
BTU/gal	145,876	140,872	140,872

1. Sampling Train Information
(Ref. Item VIII, "Intent To Test" Form)

a. Schematic diagram and description of sampling train:

See Appendix A

b. Media type used to determine gas stream components:

1. Nitrogen Oxides: Dynascience Model P-101 NOx Analyzer
2. Particulates: Tared glass fiber filter.
3. Flue Gas Analysis: Analytical Instrument Development Model 512 Portable Gas Chromatograph

c. Sampling Probes:

1. Nitrogen Oxides: Stainless steel tube.
2. Particulates: See Appendix A.
3. Flue Gas Analysis: Stainless steel tube
4. Probe cleaning method: See Appendix A.

2. Field Data Sheets
(Ref. Item IX, "Intent To Test" Form)

See Appendices A, B, C, D.

3. Description of Operation
(Ref. Item X, "Intent To Test" Form)

The operation tested was Steel Point Station Steam Generator Nos. 1, 2, 3, 4, 5, and 6, stack No. 1, Registration Number St. Pt. 1-6, stack 1, having a total BTU/hr rating of 388.4 MBTU (averaged over test period), burning No. 6 residual fuel oil at an average rate of 2726 gal/hr for all six boilers, and having a gas flow of 297,177 ACFM average for the test period. See Table IV for fuel oil analysis.

4. Sampling Area Description
(Ref. Item XI, "Intent To Test" Form)

Emission sampling was performed in the stack 150 feet above the stack foundation (7 stack diameters above the breeching inlet and 2 stack diameters down from the top). Emission sampling was performed

4. Sampling Area Description (Cont'd.)

using four - 4" diameter sampling ports spaced 90° apart on the stack circumference. A total of twenty sampling points (5 per sampling port) were used in the test for particulates. The inside diameter of the stack at the sampling location was found to be 12'-7" I.D.

a. Stack Configuration:

See Appendix A

b. Sampling Port Location:

See Appendix A

c. Sampling Point Position:

See Appendix A

5. Stack and Vent Description

(Ref. Item XII, "Intent To Test" Form)

Six Babcock and Wilcox Three Drum Sterling Boilers discharge flue gas into a common breeching which enters the stack approximately 60 feet above the stack foundation. These boilers do not have any precipitators connected to the flue gas ducts.

6. Operational Parameters

(Ref. Item XIII, "Intent To Test" Form)

Electric utility steam generators burning No. 6 residual fuel oil having rated capacities as registered.

APPENDIX A

PARTICULATE TEST

V. SAMPLING METHODS

1. Port Location

The test port locations and the number of points samples were calculated from the guidelines in the Federal Register, Volume 36, Number 247, December 23, 1971. Enough points were used to assure accurate measurement of particulate emissions, temperature and velocity over the cross-sectional area of each stack. (See Figures 1 to 4.)

2. Velocity and Temperature

Velocity was determined by pitot tube in accordance with EPA Method 2. An "S"-Type Pitot Tube (2) and thermocouple (3) are rigidly attached to the sampling probe (See Figure 5). A preliminary velocity traverse was made to establish isokinetic sampling rates using EPA Method 5 sampling techniques.

3. Flue Gas Analysis

Gas analysis for CO₂ and O₂ was conducted by UI using an Orsat apparatus. Readings for each test are reported in the Summary of Results.

4. Particulate Sampling Methods - EPA Method 5

The sampling apparatus consisted of a nine (9) foot probe heated filter, four impingers, dry gas meter, vacuum pump, and calibrated orifice as shown in Figure 5. The stainless steel, button-hook type probe tip (1) was equipped with a 5/8 inch diameter fitting connected by a stainless steel coupling (2) with asbestos packing to the probe. The probe (3) consisted of 1/2 inch inside diameter medium-wall stainless steel tube with a ground steel joint on one end. The probe was logarithmically wound from the entrance end with 26-gauge nickel-chromium wire. During sampling, the wire was connected to a variable transformer to maintain a gas temperature of 300°F in the probe. The wire wound tube was wrapped with fiber glass tape and encased in a 1-inch-OD stainless steel tube for protection. The end of the steel tube that does not have the balljoint protruding has a nut welded to it for connection to the stainless steel coupling used to attach the nozzle. The probe connects to a very coarse fritted glass filter holder (4) which holds a tared glass fiber filter. The filter holder was contained in an electrically heated enclosed box (5) which is thermostatically maintained at 250-300°F to prevent water condensation. Attached to the heated box was an ice bath (7) containing four impingers connected in series with vacuum hose. The first impinger (8) receives the gas stream from

the filter. This impinger is of the Greenburg-Smith design modified by replacing the tip with a 1/2 inch ID glass tube extending to 0.5 inch from the bottom of the flask. This impinger was initially filled with 100 milliliters of distilled water. The second impinger (9) is a Greenburg-Smith impinger with tip, and also filled with 100 milliliters of distilled water. The third impinger modified like the first, with no water. The fourth impinger (11) is also a Greenburg-Smith type modified like the first and contained 300 grams of dry indicating silica gel.

From the fourth impinger (11) the effluent stream flows through a dial thermometer (12), a check valve (13); flexible rubber vacuum tubing (14); vacuum gauge (15); a valve (16); a leakless vacuum pump (17), rated at 4 cubic feet per minute at 0 inches of mercury gauge pressure and 0 cubic feet per minute at 26 inches of mercury gauge pressure, and connected in parallel with a bypass needle valve (18); and a dry gas meter rated at .1 cubic foot per revolution (19). A calibrated orifice (20) completes the train and was used to measure instantaneous meter flow rates. The three thermometers (12) are dial type with a range of 25° to 125°F. A fourth thermometer in the heated portion of the box has a range up to 500°F. The dual manometer (21) across the calibrated orifice is an inclined-vertical type graduated in hundredths of an inch of water from 0 to 1.0 inch and in tenths from 1 to 10 inches.

5. Test Procedure

Prior to the start of a test series for each stack, the pressure, temperature, and range of velocity pressures were determined during preliminary pitot tube and temperature traverse.

During each test the following readings were taken at each point:

1. Point Designation
2. Clock Time
3. Dry gas meter reading (CF)
4. Velocity head (ΔP in inches water)
5. Desired pressure drop across orifice (ΔH in inches of water)
6. Actual pressure drop across orifice (ΔH in inches of water)
7. Dry gas temperature (°F) gas meter inlet
8. Dry gas temperature (°F) gas meter outlet
9. Vacuum pump gauge reading (in. Hg)
10. Filter box temperature (°F).
11. Dry gas temperature (°F) at the discharge of last impinger.
12. Stack temperature (°F)

The relationship of ΔP reading with the ΔH reading is a function of the following variables:

1. Orifice calibration factor
2. Gas meter temperature
3. % moisture in the flue gas
4. Ratio of flue gas pressure to barometric pressure
5. Stack temperature
6. Sampling nozzle diameter

A nomograph was used to correlate all the above variables such that a direct relationship between ΔP and ΔH could be determined by the sampler within fifteen seconds and isokinetic conditions maintained throughout the test.

6. Basic Laboratory Procedure

The following paragraph briefly describes the methods used in the laboratory to obtain the raw data used in the calculations of our results as reported in Section III of this report.

The clean up is done in the field according to EPA test procedure. The filters were previously tare weighed and recorded at the laboratory. Upon return they are dried, cooled in a dessicator, then weighed on an analytical balance and the amount of particulate collected is the difference in the two weights. The particulate wash solution (taken from the train in front of the filter) is placed in a tared beaker, the wash solution is evaporated with an Infra-Red Heat Lamp and the beaker weighed again. The difference in weight is the weight of the particulate in the wash. This is combined with the filter catch as the weight of the sample.

The impinger condensate is measured for moisture determination.


7. Calibration of Sampling Equipment

The equipment used on this assignment was calibrated one week prior to field testing and recalibrated upon equipment return after testing. York Research calibration is traceable to the National Bureau of Standards.

TEST TEAM


Robert S. Epstein
John Jasko

Prepared By:



Robert J. Larkin
Test Engineer

Reviewed By:



Robert S. Epstein
Project Director

Approved By:

Roy S. Egdall
Manager-Engineering Services

York Research CorporationPitot Tube Calibration

ΔP_{std}	ΔP_s	$\frac{\Delta P_{std}}{\Delta P_s}$	F_s
.08	.11	.727	.853
.19	.27	.704	.839
.45	.66	.682	.826
.64	.91	.703	.839
.72	1.01	.713	.844

$$F_s = \sqrt{\frac{\Delta P_{std}}{\Delta P_s}}$$

Pitot Tube # 14 $F_s =$.84 $F_{std} = 1.00$ Calibrated by R. Jones
Date 11/5/73

Oil OK
 Quick Connects OK Valves OK
 Meters OK
 Test Meter _____
 Orifices OK
 S _____
 Electrical Check - Amphenol OK
 C _____
 Man Gauge OK
 Check at 27" hg. - OK
 Tests _____

Label each item when checked and write in any remarks.

Calibration - Orifice and Meter

11/5/73 Box No. 51563 P_b 29.9

Orifice	CF _w	CF _d	T _w	IT _d	OT _d	T _d Avg.	Time t
5	5	5.15	67	85	75	80	12.73
10	5	5.06	67	85.5	77.6	87.5	9.012
10	10	10.16	68	88.8	79.5	84.1	13.2
10	10	10.03	68	89.0	79.6	87.3	93.06
10	10	10.05	68	92.8	80.3	86.5	7.67
10	10						

Calculate Y & H₂ at man. 2.0

$$Y = \frac{CF_w P_b (T_d \text{ avg.} + 460)}{CF_d (P_b + 0.147(T_w + 460))}$$

$$\Delta H_{20} = \frac{0.0634 P_b (OT_d + 460)}{CF_w} \left(\frac{(T_w + 460)}{(T_d + 460)} \right)^2$$

Tolerances

$$Y = 0.99 - \frac{1.00}{1.84} - 1.01$$

$$\Delta H_{20} = 1.6 - \frac{1.84}{2.1}$$

	Man. II@
$(T_w + 460)t^2$	
CF_w	
$P_b (OT_d + 460)$	
0.01585	.5
$29.9 (75 + 460)$	1.78
0.0317	1.0
$29.9 (77.6 + 460)$	1.77
0.0634	2.0
$29.9 (79.5 + 460)$	1.90
0.1268	4.0
$29.9 (79.6 + 460)$	1.89
0.1902	6.0
$29.9 (80.3 + 460)$	1.93
0.2536	8.0

	Man.	Y.
$CF_w P_b (T_d \text{ avg.} + 460)$		
$CF_d P_b + \frac{\text{Man. Orifice}}{13.6} (T_w + 460)$		
$5 \times 29.9 (80 + 460)$.5	.993
$5.15 (29.9 + 0.0368) (67 + 460)$		
$5 \times 29.9 (81.5 + 460)$	1.0	1.01
$5.06 (29.9 + 0.0737) (67 + 460)$		
$10 \times 29.9 (84.1 + 460)$	2.0	1.00
$10.16 (29.9 + 0.147) (68 + 460)$		
$10 \times 29.9 (84.3 + 460)$	4.0	1.01
$10.03 (29.9 + 0.294) (68 + 460)$		
$10 \times 29.9 (86.5 + 460)$	6.0	1.0
$10.05 (29.9 + 0.431) (68 + 460)$		
$\times (+ 460)$		
$(+ 0.588) (+ 460)$		

Y-8278-11
FIELD DATA

PROBE LENGTH AND TYPE 100" S.S.
 NOZZLE I.D. 3.125
 ASSUMED MOISTURE % 10.0
 SAMPLE BOX NUMBER N.A.
 METER BOX NUMBER S-1563
 METER AIR 1.90
 C FACTOR 99
 PROBE HEATER SETTING 250
 HEATER BOX SETTING 250
 REFERENCE SP 35

PLANT UT - Steel Pt. Egypt
 DATE 11/13/73
 SAMPLING LOCATION Stack #1
 SAMPLE TYPE Particulate
 RUN NUMBER 1
 OPERATOR JJ Rife
 AMBIENT TEMPERATURE 115
 BAROMETRIC PRESSURE 30.05
 STATIC PRESSURE (P_s) 36.1120
 FILTER NUMBER (s) FA-276



SCHEMATIC OF TRAVERSE POINT LAYOUT
 READ AND RECORD ALL DATA EVERY 6 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (V _m , ft ³)	VELOCITY HEAD (V ₉₅), in. H ₂ O	ORIFICE DIFFERENTIAL (ΔH), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
				DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F			
	0	345.646									< 70
A1	6	352.21	.24	1.20	1.20	620	58	58	4	255	
				1.24	1.24	625	61	61	4	270	
B1	12	356.09	.26	1.24	1.24	625	63	63	4	300	
				1.24	1.24	625	65	65	4	250	
A2	18	363.46	.24	1.20	1.20	625	67	67	4	280	
				1.24	1.24	625	78	78	5	260	
B2	24	366.33	.20	1.50	1.50	625	83	78	5	270	
				1.53	1.53	625	83	79	5	250	
A3	30	370.29	.31	1.50	1.50	625	86	78	5	300	
				1.50	1.50	625	89	79	4.5	250	
B3	36	374.28	.30	1.41	1.41	625	64	66	4.5	250	
				1.45	1.45	625	62	64	4	250	
A4	42	378.62	.29	1.45	1.45	625	70	66	4	250	
				1.45	1.45	625	76	68	4	250	
B4	48	382.41	.28	1.41	1.41	625	80	70	4	200	
				1.41	1.41	625	83	70	4	200	
A5	54	385.936	.24	1.20	1.20	625	66	68	3.5	300	
				1.24	1.24	625	66	68	3.5	295	
B5	60	389.67	.26	1.24	1.24	625	70	68	4	300	
				1.24	1.24	625	85	68	4	300	
A6	66	392.11	.27	1.45	1.45	625	78	70	4	295	
				1.45	1.45	625	77	70	4	300	
B6	72	396.05	.23	1.05	1.05	625					
				1.05	1.05	625					
A7	78	401.05	.23	1.00	1.00	625					
				1.00	1.00	625					
B7	84	404.428	.23	1.05	1.05	625					
				1.05	1.05	625					
A8	90	408.14	.23	1.05	1.05	625					
				1.05	1.05	625					
B8	96	411.55	.23	1.05	1.05	625					
				1.05	1.05	625					
A9	102	415.32	.23	1.05	1.05	625					
				1.05	1.05	625					
B9	108	418.74	.23	1.00	1.00	625					
				1.00	1.00	625					
A10	114	422.226	.23	1.00	1.00	625					
				1.00	1.00	625					
B10	120										

ES-041

COMMENTS:

1-00010
FIELD DATA

PLANT WT-Steel Pt. Brgpt.
 DATE 11/14/73
 SAMPLING LOCATION Stack #41
 SAMPLE TYPE Particulate
 PUM NUMBER 2
 OPERATOR J.T. RSE
 AMBIENT TEMPERATURE 57
 BAROMETRIC PRESSURE 30.86
 STATIC PRESSURE (P_s) -36" H₂O
 FILTER NUMBER (s) FL-334

PROBE LENGTH AND TYPE 100" S.S.
 NOZZLE I.D. 3.135
 ASSUMED MOISTURE, % 10
 SAMPLE BOX NUMBER N/A
 METER BOX NUMBER S-1563
 METER AN₆ 1.911
 C FACTOR .85
 PROBE HEATER SETTING 250
 HEATER BOX SETTING 250
 REFERENCE sp 18



SCHEMATIC OF TRAVERSE POINT LAYOUT
 READ AND RECORD ALL DATA EVERY 6 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (V _m ft ³)	VELOCITY HEAD (V _{sp}), in. H ₂ O	ORIFICE PRESSURE DIFFERENTIAL (ΔH), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGING TEMPERATURE, °F
				DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F			
	0	422.156									
D 1	6	435.62	24	1.10	1.10	620	65	65	5	250	270
2	12	434.13	26	1.27	1.27	630	73	67	5		
3	18	432.55	26	1.27	1.27	630	78	68	5		
4	24	435.22	24	1.10	1.10	625	81	70	5		
5	30	438.839	17	.85	.85	625	84	72	5		
C 1	36	443.24	26	1.27	1.27	625	66	68	5.5		
2	42	445.83	26	1.27	1.27	625	73	68	5.5		
3	48	449.29	26	1.27	1.27	625	78	70	5.5		
4	54	453.63	21	1.03	1.03	620	80	72	5		
5	60	455.589	15	.77	.77	620	84	68	5.5		
B 1	66	459.03	26	1.27	1.27	635	74	69	6		
2	72	462.71	27	1.35	1.35	630	80	70	6		
3	78	466.21	26	1.27	1.27	630	84	74	5		
4	84	469.46	30	2.2	2.2	635	82	74	4.5		
5	90	472.212	13	.65	.65	625	73	70	6.5		
A 1	96	476.14	28	1.35	1.35	630	76	70	6.5		
2	102	479.84	26	1.25	1.25	630	80	72	6		
3	108	483.44	26	1.17	1.17	630	80	74	5.5		
4	114	486.58	22	.92	.92	630	80	74	5		
5	120	489.438	16	.72	.72	625	80	74	5		


COMMENTS:

ES-041

1-8210-1
FIELD DATA

PLANT MI - Steel Pt Bqpt
 DATE 11/19/73
 SAMPLING LOCATION Stack #1
 SAMPLE TYPE Recalculated
 RUN NUMBER 3
 OPERATOR J.I. RNF
 AMBIENT TEMPERATURE 75
 BAROMETRIC PRESSURE 29.83
 STATIC PRESSURE, (P_s) 36
 FILTER NUMBER (S) CEL-426

PROBE LENGTH AND TYPE 100" S.S.
 NOZZLE I.D. 3/32"
 ASSUMED MOISTURE, % 12
 SAMPLE BOX NUMBER AA
 METER BOX NUMBER S-1583
 METER ΔH_P 1.90
 C FACTOR 59
 PROBE HEATER SETTING 210
 HEATER BOX SETTING 210
 REFERENCE ΔP 38





SCHEMATIC OF TRAVERSE POINT LAYOUT
 READ AND RECORD ALL DATA EVERY 6 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (V _m) ft ³	VELOCITY HEAD (top), in. H ₂ O	ORIFICE PRESSURE DIFFERENTIAL (ΔH _i in. H ₂ O)		STACK TEMPERATURE (T _s) °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
				DESIRED	ACTUAL		INLET (T _{m in}) °F	OUTLET (T _{m out}) °F			
	0	496.487				630	71	71	11	250	~70
A1	6	500.17	1.34	1.18	1.31	630	72	71	6		
2	12	503.59	1.35	1.31	1.30	630	80	73	8		
3	18	507.15	1.37	1.30	1.11	635	76	76	6		
4	24	510.53	1.33	1.11	1.11	635	78	77	7		
5	30	513.30	1.18	1.11	1.11	635	75	75	10		
B1	36	517.54	1.34	1.11	1.11	635	82	76	10		
2	42	521.39	1.31	1.11	1.11	635	83	77	10		
3	48	525.10	1.28	1.11	1.11	635	86	79	2.5		
4	54	528.40	1.20	1.11	1.11	635	86	80	6		
5	60	531.067	1.13	1.11	1.11	635					
			test stopped due to steam leak								

COMMENTS:

ES-041



TRAVEL POINT NO.	DISTANCE FROM WALL
5	3.6"
4	11.8"
3	21.0"
2	32.5"
1	49.3"

THE UNITED ILLUMINATING CO.
 NEW HAVEN, CONN.
 STACK CONFIGURATION AND
 SAMPLING POINT LOCATION
 STACK No. 1
 STEEL POINT STATION

REVISIONS

DRAWN BY P.E.S. DATE 3-20-21

TRACED BY DATE

APPROVED BY W.H. DATE 4-1-21

SCALE AS SHOWN DRAWING NO. 21212-12

APPENDIX B

NITROGEN OXIDE TEST

FLUE GAS ANALYSIS

TEST 1

THE UNITED ILLUMINATING COMPANY

ORSAT DATA & CALCULATION SHEET

Date Nov 13, 1973

Stack Identification Number Steel Point Stack 1

Boiler Number Boilers 1, 2, 3, 4, 5, 6

Plant Location Steel Point Station, 43 E Main St, BPT. CON.

Sampling Point Location Stack

Time _____

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt/mole (dry)
CO ₂ , % vol (dry)	9.00	8.87			8.935	44/100	3.9314
CO, % vol (dry)	0.00	0.00			0.00	28/100	+ 0.00
O ₂ , % vol (dry)	8.15	8.55			8.50	32/100	+ 2.720
N ₂ , % vol (dry)	82.55	82.58			82.565	28/100	+ 23.1182
Avg. molecular wt. of dry stack gas =							29.77

TEST 2

THE UNITED ILLUMINATING COMPANY

ORSAT DATA & CALCULATION SHEET

Date Nov 14, 1973

Stack Identification Number Steel Pit Stack 1

Boiler Number Boilers 1, 2, 3, 4, 5, 6

Plant Location Steel Pit Station, 43 E. Main St, Port Can.

Sampling Point Location Stack

Time _____

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt/mole. (dry)
CO ₂ , % Vol (dry)	9.75	9.50	9.62		9.6233	44/100	4.234
CO, % Vol (dry)	0.00	0.00	0.00		0.00	28/100	+ 0.00
O ₂ , % Vol (dry)	8.24	8.34	8.29		8.29	32/100	+ 2.653
N ₂ , % Vol (dry)	82.01	82.16	82.09		82.0866	28/100	+ 22.984
Avg. molecular wt. of dry stack gas =							29.87

TEST 3

THE UNITED ILLUMINATING COMPANY

ORSAT DATA & CALCULATION SHEET

Stack Identification Number Steel Point Stack 1 Date Nov 14, 1973

Boiler Number Boilers 1, 2, 3, 4, 5, 6 Time 3:30 PM

Plant Location Steel Point Station A3 E. Main St. Bpt. Conn

Sampling Point Location Stack

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt/mole. (dry)
CO ₂ , % Vol (dry)	9.25	8.93	8.93		9.0366	44/100	3.9761
CO, % Vol (dry)	0.00	0.00	0.00		0.00	28/100	+ 0.00
O ₂ , % Vol (dry)	8.33	8.54	8.54		8.47	32/100	+ 2.7104
N ₂ , % Vol (dry)	82.42	82.53	82.53		82.4933	28/100	+ 23.0981
Avg. molecular wt. of dry stack gas =							29.79

TEST NO. 1

Steel Point Station

Stack No 1

Test No 1

11/13/73

~~ZERO~~ OK ✓

70% OK

1210 - SAMPLE END - CALIB CHECK

1205

1200 NOx = 19% = 114 PPM

SAMPLE START 1157

11:53 AM

70% OK
PPM
NO


ZERO

NO. TEST #1
CALIB

STEEL POINT
STACK # 1

11-13-73

CHIB



TEST NO. 2

Steel Point Station

Stack No 1

Test No 2

11/14/73

zero
check
2nd 11:05

11:00 AM

sample
20% = 120 ppm

10:15

~ SAMPLE IN @ 10:15
20%

CALIB
70% = 120 ppm

NOx Test #2

Nov. 14, 1973

St. Pt. Stack 1

CO₂ SIC

Sample #2-1
stack #1

CO₂ SIC
6.74%

H₂S SIC

ORF 256

CO₂ SIC

Calibrate 11:15 AM

Test #2 stack #1

Nov. 14, 1973


stack #1

Steel Point station

stack No 1

Test No 2

11/14/73



outlet

outlet

Calibrated
11:30 AM

No Co
+ 16

outlet

outlet

outlet

Sample # 2-1

outlet

outlet

outlet

Sample # 2-2

outlet


952x60

0
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20



215/112

TEST NO. 3



CALIB CHECK

1510

Sample 1976 11/14 PPM

1505


Steel Point Sta

Stack No 1

Test No 3

11/14/73

SAMPLE IN @ 1458




70%

= 420 PPM

CALIB

NDR TEST #3
11-14-73

ST. PT
STACK 1



CO2 28

CO2 512

CO2 512

CO2 512

Calibrate 3:30 PM

Test #3

Nov. 14, 1973


Steel PT
stack #1

Steel Point Station

stack No 1

Test # 3

11/14/73



Calibrate 3.45911

O₂ x 512

O₂ x 256

O₂ x 512

O₂ x 512

O₂ x 256

O₂ x 512

Sample # 3-3

O₂ x 512

O₂ x 256

Sample # 3-2

O₂ x 512

O₂ x 256

O₂ x 512

Sample # 3-1

APPENDIX C

BOILER OPERATING DATA

Date Nov 13. 1973

Stack Identification Number 57001

Boiler Number 1-6 LP

Plant Location STNA PUMP

BAROMETER 30.05

TEST # 1

Parameters	1113	1221	1356	1511	1659
Gross Load (MW)					
Net Load (MW)					
Fuel Flow (gal/hr) oil meter (oil)	52118	55126	57339	62603	67404
Steam-Flow (lb/hr) ^{7th oil flow #1}	435	435	425	425	440
Feed-Water-Flow (lb/hr) 11 2	430	430	440	450	460
Air-Flow 11 3	385	380	420	375	400
Excess Air (%) 11 4	430	425	380	415	430
Excess O ₂ (%) 11 5	330	370	420	385	380
Excess O ₂ (%) 11 6	405	395	425	410	380
SCOT Blowing					
Boiler Inlet Feed Water Temp (°F)					
Boiler Exit Steam Press. (psig)	210	210	210	215	220
Boiler Exit Steam Temp (°F)					
Reheat Inlet Steam Press. (psig) 11 INLET PRESS	5.9	5.9	5.8	6.2	7.3
Reheat Inlet Steam Temp (°F)					
Reheat Exit Steam Press. (psig)					
Reheat Exit Steam Temp (°F)					
Boiler Pressure (in-Hg)					

Date April 14, 1973

Stack Identification Number

Boiler Number

Plant Location

Stack

BAC-UNIT # 29886

TEST # 2

Parameters	0838	0953	1132	1307
Gross Load (MW)				
Net Load (MW)	1058.8	1094.05	1140.53	1154.52
Fuel Flow (gal/hr) oil motor	370	367	380	465
Steam-Flow (lb/hr) #1	470	470	450	450
Seed-Water-Flow (lb/hr) #2	430	470	430	470
Air-Flow #3	410	430	410	430
Excess Air (%) #4	425	470	425	470
Excess O2 (%) #5	460	385	460	380
Soot Flowing				
Boiler Inlet Feed Water Temp (OF)	210	215	210	210
Boiler Exit Steam Press. (psig)				
Boiler Exit Steam Temp (OF)				
Reheat Inlet Steam Press. (psig) #1	6.3	6.0	6.3	6.3
Reheat-Inlet Steam Temp (OF)				
Reheat-Exit Steam Press. (psig)				
Reheat-Exit Steam Temp (OF)				

Date 1 Nov 14, 1973

Boiler Identification Number

SWP 1

Boiler Number

1-6 LP

Plant Location

STEEL

Room No. 2180

TEST 3

Parameters	1/185	1537	1633
Gross Load (MW)			
Net Load (MW)	100570	105402	107920
Fuel Flow (gal/hr) OIL METR	415	417	417
Oil Flow (lb/hr) gph	430	430	430
Steam Flow (lb/hr)	410	410	410
Feed-Water-Flow (lb/hr)	420	420	420
Air-Flow	450	390	390
Excess Air (%)	37%	37%	37%
Excess O ₂ (%)			
Soot Blowing			
Boiler Inlet Feed Water Temp (OF)	210	210	210
Boiler Exit Steam Press. (psig)			
Boiler Exit Steam Temp (OF)			
Reheat Inlet Steam Press. (psig)	6.3	6.3	6.3
Reheat Inlet Steam Temp (OF)			
Reheat Exit Steam Press. (psig)			
Reheat Exit Steam Temp (OF)			

APPENDIX D

SAMPLE CALCULATIONS

SAMPLE CALCULATIONS

NOTE: All equations used in these calculations are found in the Federal Register, Vol. 36, No. 247, dated December 23, 1971.

Calculations representative of Test #1.

1. Dry Gas Volume

$$\begin{aligned} V_{mstd} &= \left(17.71 \frac{^{\circ}R}{\text{in.Hg.}} \right) V_m \left(\frac{P_{\text{bar}} + \frac{\Delta H}{13.6}}{T_m} \right) && \text{eq. 5-1} \\ &= 17.71 \frac{^{\circ}R}{\text{in.Hg.}} \quad 73.430 \text{ ft}^3 && \left(\frac{30.05 \text{ In.Hg.} + \frac{1.322 \text{ in. H}_2\text{O}}{13.6}}{532.0 \text{ }^{\circ}R} \right) \\ &= 73.693 \text{ ft}^3 \end{aligned}$$

2. Volume of Water Vapor

$$\begin{aligned} V_{wstd} &= \left(0.0474 \frac{\text{ft}^3}{M} \right) V_{lc} && \text{eq. 5-2} \\ &= \left(0.0474 \frac{\text{ft}^3}{M} \right) \quad 95.6 \text{ ml} \\ &= 4.531 \text{ ft}^3 \end{aligned}$$

3. Moisture Content

$$\begin{aligned} B_{ws} &= \frac{V_{wstd}}{V_{wstd} + V_{mstd}} \\ &= \frac{4.531 \text{ ft}^3}{4.531 \text{ ft}^3 + 73.693 \text{ ft}^3} \\ &= .0579 \times 100\% = 5.6\% \end{aligned}$$

4. Molecular Weight (drv)

$$\begin{aligned} M_d &= 0.44 (\% \text{ CO}_2) + 0.32 (\% \text{ O}_2) && \text{eq. 3-2} \\ &+ 0.28 (\% \text{ N}_2) + 0.28 (\% \text{ CO}) \\ &= 0.44 (8.93) + 0.32 (8.50) + 0.28 (82.57) \\ &\quad + 0.28 (0.00) \\ &= 29.77 \text{ lb/lb-mole} \end{aligned}$$

5. Molecular Weight (wet)

$$\begin{aligned} M_s &= M_d (1 - B_{ws}) + 18 B_{ws} \\ &= 29.77 (1 - .056) + 18 (.056) \\ &= 29.11 \text{ lb/lb-mole} \end{aligned}$$

6. Stack Gas Velocity

$$\begin{aligned} V_s &= K_p C_p \sqrt{\Delta P} \left(\frac{T_s}{P_s \times M_s} \right)^{1/2} && \text{eq. 2-2} \\ &= (85.48) (.84) (.514) \left(\frac{1085.8}{30.02 \times 29.11} \right)^{1/2} \\ &= 41.15 \text{ F.P.S.} \end{aligned}$$

7. Gas Volumetric Flow Rate, ACFM

$$\begin{aligned} \text{ACFM} &= V_s \times A_s \times 60 \text{ sec/min} \\ &= 41.15 \times 124.3 \text{ ft}^2 \times 60 \text{ sec/min} \\ &= 306,897 \text{ ACFM} \end{aligned}$$

8. Gas Volumetric Flow Rate, SCFM

$$\begin{aligned} Q_s &= 60 (1 - B_{ws}) V_s A_s \left(\frac{T_{std}}{T_s} \right) \left(\frac{P_s}{P_{std}} \right) && \text{eq. 2-3} \\ &= 60 (1 - .056) (41.15) (124.3) \left(\frac{530}{1085.8} \right) \left(\frac{30.02}{29.92} \right) \\ &= 141,886 \text{ SCFM} \end{aligned}$$

9. Gas Volumetric Flow Rate, lb/hr

$$\begin{aligned}
 W_s &= Q_s \times \frac{60 \text{ min}}{\text{hr}} \times \frac{M_d}{386 \text{ ft}^3} \\
 &= 141,886 \text{ SCFM} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{29.77 \text{ lb/lb-mole}}{386 \text{ ft}^3} \\
 &= 656,572 \text{ lb/hr}
 \end{aligned}$$

10. Particulate Concentrations, gr/SCF

$$\begin{aligned}
 C's &= \left(0.0154 \frac{\text{gr.}}{\text{mg.}} \right) \frac{M_n}{V_{mstd}} && \text{eq. 5-4} \\
 &= \left(0.0154 \frac{\text{gr.}}{\text{mg.}} \right) \frac{49.60 \text{ mg.}}{73.693 \text{ ft}^3} \\
 &= 0.0103 \text{ gr/SCF}
 \end{aligned}$$

11. Particulate Concentrations. lb/ft³

$$\begin{aligned}
 C_s &= \left(\frac{1}{453600} \frac{\text{lb.}}{\text{mg.}} \right) \frac{M_n}{V_{mstd}} && \text{eq. 5-5} \\
 &= \left(\frac{1}{453600} \frac{\text{lb.}}{\text{mg.}} \right) \frac{49.60 \text{ mg.}}{73.693 \text{ ft}^3} \\
 &= 1.48 \times 10^{-6} \text{ lb/SCF}
 \end{aligned}$$

12. Particulate Concentrations, lb/hr

$$\begin{aligned}
 C_w &= C_s Q_s \times \frac{60 \text{ min}}{\text{hr}} \\
 &= (1.48 \times 10^{-6} \text{ lb/SCF}) (141,886 \text{ SCFM}) \frac{60 \text{ min}}{\text{hr}} \\
 &= 12.60 \text{ lb/hr}
 \end{aligned}$$

13. Particulate Concentrations, lb/MBTU

$$\begin{aligned}
 Er &= \frac{C_w}{\text{Heat Input}} \\
 &= \frac{12.60 \text{ lb/hr}}{386.7 \times 10^6 \text{ BTU/hr}} \\
 &= 0.033 \text{ lb/MBTU}
 \end{aligned}$$

14. % Isokinetic Sampling

$$I = \frac{\bar{T}_s \left(1.667 \frac{\text{min}}{\text{sec}} \right) \left((0.00267) V_{lc} + \frac{V_m}{T_m} \left(P_{\text{bar}} + \frac{\Delta \bar{H}}{13.6} \right) \right)}{\ominus V_s P_s A_n}$$

eq. 5-6

$$I = \frac{1085.8 (1.667) \left((0.00267) (95.6) + \frac{73.43}{532.0} \left(30.05 + \frac{1.322}{13.6} \right) \right)}{(120) (41.15) (30.02) (5.324 \times 10^{-4})}$$

$$= 101.3\%$$

15. NO_x Concentrations, lb/hr

$$\begin{aligned}
 \text{lb/hr} &= \text{ppm} \times \frac{M_w (\text{NO}_2)}{M_d} \times W_s \\
 &= \frac{114}{10^6} \times \frac{46 \text{ lb/lb-mole}}{29.77 \text{ lb/lb-mole}} \times 656,572 \frac{\text{lb}}{\text{hr}} \\
 &= 115.7 \text{ lb/hr}
 \end{aligned}$$

16. NO_x Concentrations, lb/MBTU

$$\begin{aligned}
 \text{lb/MBTU} &= \frac{\text{lb/hr}}{\text{Heat Input}} \\
 &= \frac{115.7 \text{ lb/hr}}{386.7 \times 10^6 \text{ BTU/hr}} \\
 \text{lb/MBTU} &= \frac{0.299 \text{ lb}}{10^6 \text{ BTU}}
 \end{aligned}$$

17. Stack Pressure (Absolute) in.Hg.

$$P_s = P_b + \frac{P_d}{13.6} = 30.05 + \frac{(-0.36)}{13.6} = 30.02 \text{ in.Hg.}$$

18. Nozzle Area (ft²)

$$A_n = \pi D^2/4 = 0.785 (0.3125/12)^2 = 5.324 \times 10^{-4} \text{ ft}^2$$

19. Stack Area (ft²)

$$A_s = \pi D^2/4 = 0.785 (151/12)^2 = 124.3 \text{ ft}^2$$

20. Heat Input, MBTU

$$\text{Sp. Gr.} \times 8.33 \text{ lb/gal} \times \text{BTU/lb} \times \text{gal/hr}$$

$$0.900 \times 8.33 \times 19,458 \times 2651 = 386.7 \text{ MBTU}$$

21. Gas Density, lb/ft³

$$\text{Gas Density} = \frac{\text{mol wt gas (md)}}{386 \text{ ft}^3} \times \frac{T_{\text{std}}}{T_s} \times \frac{P_{\text{bar}}}{P_{\text{std}}}$$

$$= \frac{29.77}{386} \times \frac{530 \text{ }^{\circ}\text{R}}{1085.8} \times \frac{30.05}{29.92} = 0.0378 \text{ lb/ft}^3$$

THE UNITED ILLUMINATING COMPANY
SOURCE TESTING CALCULATION FORMS

Test No. Steel Point #1 No. Runs 2-1/2
 Name of Firm The United Illuminating Company
 Location of Plant 43 East Main Street, Bridgeport, Connecticut
 Type of Plant Steam Generating Station
 Control Equipment None
 Sampling Point Locations Stack
 Pollutants Sampled Particulates, Nitrogen Oxides
 Time of Particulate Test:
 Run No. 1 Date 11/13/73 Begin 11:51 End 16:40
 Run No. 2 Date 11/14/73 Begin 9:19 End 12:55
 Run No. 3 Date 11/14/73 Begin 14:41 End 16:33

PARTICULATE EMISSION DATA

Run No.	1	2	3	
$K_p = 85.48 \frac{\text{ft}}{\text{sec}} \left(\frac{\text{lb.}}{\text{lb mole-OR}} \right)^{1/2}$	85.48	85.48	85.48	
$C_p = \text{Pitot tube coefficient (calib.)}$	0.84	0.84	0.84	
$\bar{V}_{AP} = \text{Average velocity head of stack gas, inches H}_2\text{O}$	0.514	0.478	0.488	
$\bar{T}_s = \text{Average stack temp., } ^\circ\text{R}$	1085.8	1086.5	1078.5	
$P_b = \text{Barometric pressure, "Hg Abs.}$	30.05	29.86	29.82	
$P_d = \text{Gas duct pressure, "H}_2\text{O}$	-0.36	-0.36	-0.36	
$P_s = \text{Absolute stack gas pressure, inches Hg}$	30.02	29.83	29.79	
$B_{ws} = \% \text{ moisture in stack gas, by volume}$	5.6	9.6	13.9	
$M_d = \text{Molecular weight of stack gas, dry}$	29.77	29.87	29.79	
$M_s = \text{Molecular weight of stack gas}$	29.11	28.73	28.15	

V_s = Stack gas velocity, F.P.S.	41.15	38.65	39.74	
% CO ₂	8.93	9.62	9.04	
% O ₂	8.50	8.29	8.47	
% CO	0.00	0.00	0.00	
% N ₂	82.57	82.09	82.49	
Vlc = Total volume of liquid collected in impingers and silica gel, ml.	95.6	150.6	115.7	
Vm = Volume of dry gas sampled at meter conditions, FT ³	73.430	67.272	34.580	
Vstd = Volume of dry gas sampled at STP, FT ³	73.693	66.877	34.087	
Tm = Average dry gas meter temp., °R	532.0	533.4	537.3	
ΔH = Average pressure drop across orifice, inches H ₂ O	1.322	1.112	1.179	
θ = Total Sampling Time, min.	120	120	60	
Dn = Nozzle dia., inches	0.3125	0.3125	0.3125	
An = Nozzle area, FT ² x 10 ⁻⁴	5.324	5.324	5.324	
I = % of isokinetic sampling	101.3	102.7	106.2	
Qs = Stack gas volume at STP (SCFM)	141,886	126,730	124,858	131,158
Qa = Stack gas volume at stack conditions (ACFM)	306,897	288,252	296,381	297,177
Ws = Stack gas mass flow lbs/hr	656,572	588,408	578,164	607,715
Mp = Particulate-probe, washings, mg	-	-	-	
Mf = Particulate-filter (mg)	-	-	-	
Mn = Particulate-total (mg)	49.60	113.10	127.20	
C's = Particulate Concentrations gr/scf	0.010	0.026	0.057	0.031
Cw = Particulate total emission lb/hr	12.6	28.3	60.7	33.9
Er = Particulate emission rate, lb/10 ⁶ BTU	0.033	0.072	0.158	0.098
C = NO _x concentrations, PPM	114	120	114	116
Cn = NO _x lb/10 ⁶ BTU	0.30	0.28	0.27	0.28

EMISSION TEST REPORT

Stack No. B.H.S. 1
Steam Generator No. 1

0AQPS - 78-1

II-I-262

1957

CO₂ 7.5%
25% extra

*
FUEL
OIL COMBUSTION
AP-42 Section 1.3
Reference Number
24

4193 Ref 21

The United Illuminating Company
Bridgeport Harbor Station
10 Henry Street
Bridgeport, Connecticut
06604

Approved by:

E.W. Somerville *E. W. Somerville*
Vice President, Engineering and Planning

Submitted by:

M.R. McCraven *M. R. McCraven*

Stack No. B.H.S. 1
Steam Generator No. 1
(Ref. "Intent to Test" Form Number 720049)

Test Conducted By
The United Illuminating Company
Development and Test Laboratory
80 Temple Street
New Haven, Connecticut
06506

United Illuminating Personnel Present

J. Sombati
J. Hotchkiss
J. Macknis
T. McAlee

Prepared by:

J.S. Sombati *J. S. Sombati*
Development & Testing Laboratory Supervisor

J.W. Hotchkiss *J. W. Hotchkiss*
Assistant Mechanical Engineer

Checked by:

D.W. Hoskinson *D. W. Hoskinson*
Chief Mechanical Engineer

TEST RESULTS

Steam Generator No. 1

Tests Conducted On
April 12, 13, 16, 1973

Introduction

Emission tests for particulate and nitrogen oxides were conducted as required by Connecticut State Law on The United Illuminating Company Bridgeport Harbor Station Steam Generator No. 1 located in Bridgeport, Connecticut. Testing was conducted on April 12, 13 and 16, 1973.

Source sampling was performed in accordance with test methods and procedures as prescribed in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. These tests were conducted on the stack four diameters downstream of the breeching inlet.

The primary contaminants tested for were particulates and nitrogen oxides. Tests were also conducted to determine stack gas velocity, moisture content and flue gas analysis. The procedures used in determining these various parameters, except for flue gas analysis and nitrogen oxides, are those found in the above mentioned Federal Register. Flue gas analysis was performed by using an Analytical Instrument Development Model 512 Portable Gas Chromatograph, and nitrogen oxide emissions were found by using a Dynascience Model P-101 NO_x Analyzer.

This test report includes the information required for Items III, IV, V, VI, VII, VIII, IX, X, XI, XII and XIII from the Department of Environmental Protection's Intent to Test form in compliance with the DEP's new Source Test Guidelines and Procedures, (received April 3, 1973).

1. Sampling Train Information

(Ref. Item VIII "Intent to Test" Form)

a.) Schematic diagram of Sampling Train:

See Figure 1

Sampling Train used:

Research Appliance Corporation Stacksampler
Model 2343-5, Serial No. 1399, purchased
April 4, 1972.

b.) Media type used to determine gas stream components:

NO_x: Dynascience Model P-101 NO_x analyzer

Particulates: Reeve Angel 900AF 11 CM
diameter glass fiber filter

Flue Gas Analysis: Analytical Instrument
Development Model 512 Portable Gas
Chromatograph

c.) Sampling tube:

Preliminary Moisture: Heated pyrex tube

NO_x: Stainless steel tube

Particulates: 12 foot stainless steel tube

Flue Gas Analysis: Stainless steel tube

d.) Probe cleaning method:

The probe was first washed with acetone, after
which two to three pre-weighed gun patches were
pushed through the probe, followed by another
washing of the probe with acetone.

2. Field Data Sheets

(Ref. Item IX "Intent to Test" Form)

See Appendix C

3. Description of Operations
(Ref. Item X "Intent to Test" Form)

The operation tested was Bridgeport Harbor Station Steam Generator 1, Registration Number B.H.S. 1, Stack 1, having a BTU/hr rating of 895×10^6 (averaged over test period), burning No. 6 residual fuel oil at an average rate of 6277 gal/hr, and having a gas flow of 263,335 ACFM, average for test period. See Table IV for fuel oil analysis.

4. Sampling Area Description
(Ref. Item XI "Intent to Test" Form)

Emission sampling was performed in the stack 43'-3" above the breeching inlet and 126'-6" down from the top of the stack. Sampling was done through two 4" diameter sampling ports spaced 90° apart on the stack circumference. Eighteen sampling points per port were used in the test for particulates. The diameter of the stack at the sampling location was found to be 8'-6".

a.) Stack Configuration

See Figure 2

b.) Sampling Port Location

See Figure 2

c.) Sampling Point Positions

See Figure 3

5. Stack and Vent Descriptions
(Ref. Item XII "Intent to Test" Form)

Connected to this boiler is a Research-Cottrell electrostatic precipitator having an estimated collection efficiency of 75% when burning No. 6 residual fuel oil. The precipitator outlet duct connects into the 201' stack at elevation 55'-3".

6. Operational Parameters
(Ref. Item XIII "Intent to Test" Form)

Electric utility steam generator burning No. 6 residual fuel oil and having rated capacities as registered.

Table 1

Summary of Test Results

Steam Generator No. 1

<u>Component</u>	<u>Sampling Duration</u>		<u>Number of tests</u> (minimum of 3)	<u>Measured Concentrations</u>	<u>Method employed to Determine Concentration</u> i.e., material balance, emission factor, reference, (specify) etc
	<u>minutes per point</u>	<u>total test time</u>			
NOx		10 min.	3	0.19 lb/106 BTU	Dynascience Model P-101
Particulates	5	180 min.	3	0.006 lb/106 BTU	Method 5*
Moisture	5	180 min.	3	9.8	Method 4*
Gas Analysis		10 min.	3	32% Excess Air	AID Model 512 Portable Gas Chromatograph
Velocity	4	30 min.	3	1.1" to 2.0" H ₂ O	Method 2*

*Federal Register, Vol. 36, No. 247, December 23, 1971

Table II

Summary of Results
Steam Generator No. 1

	<u>Test 1</u>	<u>Test 2</u>	<u>Test 3</u>	<u>Average</u>
Date	4/12/73	4/13/73	4/16/73	
Stack Flow, ACFM	266,811	261,580	261,614	263,335
Stack Flow, SCFM	171,038	171,145	169,546	170,576
Stack Flow, lb/hr	797,853	801,544	788,784	796,060
% Excess O ₂ @ Test Point	5.05	5.89	7.99	6.31
Particulate Emissions				
gr/SCF	0.003	0.002	0.006	0.004
lb/hr	3.9	3.3	8.2	5.1
lb/MBTU	0.004	0.004	0.009	0.006
Nitrogen Oxide Emissions				
PPM	234	219	167	207
lb/MBTU	0.21	0.20	0.15	0.19

Collection for 1.457

0.19 x 1.457 = 0.279

part: 5.1 lb / 6.27 x 10³ gal = 0.8 lb / 10³ gal

NO_x: 0.19 lb / 143,000,000 BTU = 27 lb / 10³ gal

Table III

Average Boiler Operating Data For Test Periods

Steam Generator No. 1

	<u>Test 1</u>	<u>Test 2</u>	<u>Test 3</u>
Date	4/12/73	4/13/73	4/16/73
Gross Load MW	89.5	88.6	89.4
Steam Flow lb/hr	658,000	652,000	656,000
Oil Flow, gal/hr	6343	6257	6231
Heat Rate, MBTU/hr	906.4	891.7	887.8
Stack Gas Temp. OF	285.5	275.0	286.6
Gas Density, lb/ft ³	0.055	0.057	0.056
Additive Rate ("CHESSCO")	2000:1	2000:1	2000:1

TABLE IV(a)

Analysis Of
Representative Fuel Oil Sample

April 27, 1973

DATE

FUEL ENGINEERING COMPANY

254979

REPORT NUMBER

FUEL TESTING DEPARTMENT

TEST REPORT

API Gravity @60°F 27.3
Specific Gravity @60°F 0.8911
Sulfur 0.44%
Heating Value 19255 BTU per Pound
142895 BTU per Gallon

On Sample Marked Unit #1, Oil-1DR
10:15 A.M.
4/12/73
Your P.O. No.
Sample Taken by You
Us

Received from United Illuminating Company
80 Temple Street
New Haven, Connecticut 06506
Attn: Mr. J. Sombati

Fuel Engineering Company of New York

by *H. O. Courtney*

TABLE IV(b)

Ultimate Analysis Of
Representative Fuel Oil Sample

May 5, 1975

DATE

FUEL ENGINEERING COMPANY

254978

REPORT NUMBER

FUEL TESTING DEPARTMENT

TEST REPORT

Ultimate:

Carbon	84.95%
Hydrogen	12.65%
Sulfur	0.43%
Nitrogen	0.18%
Ash	0.036%
Oxygen	1.77%

BTU per Pound	19257
BTU per Gallon	142521

On Sample Marked Unit #1 Oil-^{Flow}HR
11:30 A.M.
4/15/73 Sample Taken by You
Us.

Received from United Illuminating Co.
80 Temple Street
New Haven, Connecticut 06506
Attn: Mr. J. Sombati

Fuel Engineering Company of New York

by: *Howard O Courtnay / H/B*

TABLE IV(c)

Analysis Of
Representative Fuel Oil Sample

April 27, 1973

DATE

FUEL ENGINEERING COMPANY

FUEL TESTING DEPARTMENT

254980

REPORT NUMBER

TEST REPORT

API Gravity @60°F . 27.5
Specific Gravity @60°F 0.8899
Sulfur 0.46%
Heating Value 19226 BTU per Pound
142484 BTU per Gallon


On Sample Marked Oil Sample For Test #3 BUS #1
1:00 P.M. From Unit #2 HDR Discharge
4/17/73
Your P.O. No.
Sample Taken by Us

Received from United Illuminating Company
80 Temple Street
New Haven, Connecticut 06506
Attn: Mr. J. Sombati

Fuel Engineering Company of New York

by:

H.O. Courtney




- 1) Probe
- 2) Box Thermometer
- 3) Gas Thermometer
- 4) Particulate Filter
- 5) Impingers (Greenburg-Smith)
- 6) Thermometer
- 7) Check Valve
- 8) Umbilical Cord
- 9) Vacuum Gage
- 10) Course Flow Adjust Valve
- 11) Fine Flow Adjust Valve
- 12) Orif
- 13) Vacuum Pump
- 14) Filter
- 15) Dry Gas Meter
- 16) Orifice Tube
- 17) Incline Manometer
- 18) Solenoid Valves
- 19) Pilot
- 20) Thermocouple
- 21) Leeds & Northrup 8595-2 I.C. Temperature Potentiometer

THE UNITED ILLUMINATING COMPANY
TYPICAL SAMPLING TRAIN
FIGURE 1

UNITED ILLUMINATING CO
BPT. HARBOR STA
UNIT # 1
STACK CONFIGURATION,
SAMPLING PORT LOCATION

EI 225'-0"

7'-6"
I.D.




2 SAMPLING PORTS
SPACED 90° APART

EI 98'-6"

8'-6"
I.D.

NEW SAMPLING
PLATFORM



RESEARCH-COTTRELL
ELECTROSTATIC
PRECIPITATOR

EI 55'-3"

STACK

← FROM SLR

AIR HTG

EI 23'-6"

FIGURE 2

SAMPLING POINT
POSITIONS

(STACK DIA. CROSS-SECTION)




FIGURE 3-A

B.H.S. UNIT # 1

Sampling Point Positions

Stack Diameter: 8'-6" = 102"

Pipe Length: 36"

<u>POINT</u>	<u>FACTOR</u>	<u>DISTANCE</u>	<u>DISTANCE + PIPE LENGTH</u>
1	1.4	1.4"	37.4"
2	4.4	4.5"	40.5"
3	7.5	7.7"	43.7"
4	10.9	11.1"	47.1"
5	14.6	14.9"	50.9"
6	18.8	19.2"	55.2"
7	23.6	24.1"	60.1"
8	29.6	30.2"	66.2"
9	38.2	39.0"	75.0"
10	61.8	63.0"	99.0"
11	70.4	71.8"	107.8"
12	76.4	77.9"	113.9"
13	81.2	82.8"	118.8"
14	85.4	87.1"	123.1"
15	89.1	90.9"	126.9"
16	92.5	94.4"	130.4"
17	95.6	97.5"	133.5"
18	98.6	100.6"	136.6"

Figure 3-B

Bridgeport Harbor Station Unit No. 1

Test 1

April 12, 1973

SAMPLE CALCULATIONS

NOTE: All equations used in these calculations are found in the Federal Register, Vol. 36, No. 247, Dated December 23, 1971.

Calculations representative of Test #1.

1) Dry Gas Volume

$$\begin{aligned}
 V_{mstd} &= \left(17.71 \frac{\text{OR}}{\text{inHg}} \right) V_m \left(\frac{P_{\text{bar}} + \frac{\Delta H}{13.6}}{T_m} \right) && \text{eq. 5-1} \\
 &= \left(17.71 \frac{\text{OR}}{\text{inHg}} \right) \cdot 173.64 \text{ ft}^3 \left(\frac{29.94 \text{ in Hg} + \frac{3.56 \text{ in H}_2}{13.6}}{529.1 \text{ OR}} \right) \\
 &= 175.53 \text{ ft}^3
 \end{aligned}$$

2) Volume of Water Vapor

$$\begin{aligned}
 V_{wstd} &= \left(0.0474 \frac{\text{FT}^3}{\text{M}} \right) V_{lc} && \text{eq. 5-2} \\
 &= \left(0.0474 \frac{\text{FT}^3}{\text{M}} \right) 403.6 \text{ Ml} \\
 &= 19.13 \text{ FT}^3
 \end{aligned}$$

3) Moisture Content

$$\begin{aligned}
 B_{ws} &= \frac{V_{wstd}}{V_{wstd} + V_{mstd}} \\
 &= \frac{19.13 \text{ FT}^3}{19.13 \text{ FT}^3 + 175.53 \text{ FT}^3} \\
 &= .098 \times 100\% = 9.8\%
 \end{aligned}$$

4) Molecular Weight (dry)

$$\begin{aligned} M_d &= 0.44 (\% \text{ CO}_2) + 0.32 (\% \text{ O}_2) \\ &\quad + 0.28 (\% \text{ N}_2) + 0.28 (\% \text{ CO}) \qquad \text{eq. 3-2} \\ &= 0.44 (11.33) + 0.32 (5.05) + 0.28 (83.62) \\ &\quad + 0.28 (0.00) \\ &= 30.01 \text{ lb/lb-mole} \end{aligned}$$

5) Molecular Weight (wet)

$$\begin{aligned} M_s &= M_d (1 - B_{ws}) + 18 B_{ws} \\ &= 30.01 (1 - .098) + 18 (.098) \\ &= 28.83 \text{ lb/lb-mole} \end{aligned}$$

6) Stack Gas Velocity

$$\begin{aligned} V_s &= K_p C_p \sqrt{\Delta P} \left(\frac{T_s}{P_s M_s} \right)^{\frac{1}{2}} \qquad \text{eq. 2-2} \\ &= (85.48) (0.783) (1.26) \left(\frac{745.5}{29.91 \times 28.83} \right)^{\frac{1}{2}} \\ &= (85.48) (0.783) (1.26) (0.930) \\ &= 78.4 \text{ F.P.S.} \end{aligned}$$

7) Gas Volumetric Flow Rate, ACFM

$$\begin{aligned} \text{ACFM} &= V_s \times A \times 60 \text{ sec/min} \\ &= 78.4 \times 56.72 \text{ FT}^2 \times 60 \text{ sec/min} \\ &= 266,811 \text{ ACFM} \end{aligned}$$

8) Gas Volumetric Flow Rate, SCFM

$$Q_s = 60 (1-Bws) V_s A \left(\frac{T_{std}}{T_s} \right) \left(\frac{P_s}{P_{std}} \right) \quad \text{eq. 2-3}$$

$$= 60 (1-.098) (78.4) (56.72) \left(\frac{530}{745.5} \right) \left(\frac{29.91}{29.92} \right)$$

$$= 171,038 \text{ SCFM}$$

9) Gas Volumetric Flow Rate, lb/hr

$$W_s = Q_s \times \frac{60 \text{ min}}{\text{hr}} \times \frac{M_d}{386 \text{ FT}^3}$$

$$= 171,038 \text{ SCFM} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{30.01 \text{ lb/lb-mole}}{386 \text{ FT}^3}$$

$$= 797,853 \text{ lb/hr}$$

10) Particulate Concentrations, gr/SCF

$$C's = \left(0.0154 \frac{\text{gr}}{\text{mg}} \right) \frac{M_n}{V_{mstd}} \quad \text{eq. 5-4}$$

$$= \left(0.0154 \frac{\text{gr}}{\text{mg}} \right) \frac{30.6 \text{ mg}}{175.53 \text{ FT}^3}$$

$$= 0.003 \text{ gr/SCF}$$

11) Particulate Concentrations, lb/FT³

$$C_s = \frac{\left(\frac{1}{453600} \frac{\text{lb}}{\text{mg}} \right) m_n}{V_{mstd}} \quad \text{eq. 5-5}$$

$$= \frac{\left(\frac{1}{453600} \frac{\text{lb}}{\text{mg}} \right) 30.6 \text{ mg}}{175.53 \text{ FT}^3}$$

$$= 0.38 \times 10^{-6} \text{ lb/SCF}$$

12) Particulate Concentrations, lb/hr

$$\begin{aligned}
 C_w &= C_s Q_s \times \frac{60 \text{ min}}{\text{hr}} \\
 &= (0.38 \times 10^{-6} \text{ lb/SCF}) (171,038 \text{ SCFM}) \frac{60 \text{ min}}{\text{hr}} \\
 &= 3.9 \text{ lb/hr}
 \end{aligned}$$

13) Particulate Concentrations, lb/MBTU

$$\begin{aligned}
 E_r &= \frac{C_w}{\text{Heat Input}} \\
 &= \frac{3.9 \text{ lb/hr}}{906.4 \times 10^6 \text{ BTU/hr.}} \\
 &= .004 \text{ lb/MBTU}
 \end{aligned}$$

14) % Isokinetic Sampling

$$\begin{aligned}
 I &= \frac{T_s (1.667 \frac{\text{min}}{\text{sec}}) \left((0.00267) V_{lc} + \frac{V_m}{T_m} \left(P_{\text{bar}} + \frac{\Delta \bar{H}}{13.6} \right) \right)}{\ominus \quad V_s \quad P_s \quad A_n} \quad \text{eq. 5-6} \\
 I &= \frac{745.5 (1.667) \left((0.00267) (403.6) + \frac{173.64}{529.1} \left(29.94 + \frac{3.56}{13.6} \right) \right)}{(180) (78.4) (29.91) (0.000325)} \\
 &= 99.54\%
 \end{aligned}$$

15) NO_x Concentrations, lb/hr

$$\begin{aligned}
 \text{lb/hr} &= \text{PPM} \times \frac{M_w (\text{NO})}{M_d} \times W_s \\
 &= \frac{234}{10^6} \times \frac{30 \text{ lb/lb-mole}}{30.13 \text{ lb/lb-mole}} \times 797853 \frac{\text{lb}}{\text{hr}} \\
 &= 185.9 \text{ lb/hr}
 \end{aligned}$$

16) NO_x Concentrations, lb/MBTU

$$\begin{aligned} \text{lb/MBTU} &= \frac{\text{lb/hr}}{\text{Heat Input}} \\ &= \frac{185.9}{906.4 \times 10^6 \text{ BTU/hr}} \end{aligned}$$

$$\text{lb/MBTU} = \frac{0.21 \text{ lb}}{10^6 \text{ BTU}}$$

17) Stack Pressure

$$P_s = P_b - \frac{P_d}{13.6} = 29.94 - \frac{0.40'' \text{ H}_2\text{O}}{13.6} = 29.91$$

18) Nozzle Area

$$A_n = \frac{\pi D^2}{4} = 0.785 \left(\frac{0.244}{12} \right)^2 = 3.25 \times 10^{-4} \text{ ft}^2$$

19) Stack Area

$$A_s = \frac{\pi D^2}{4} = .785 \left(\frac{102}{12} \right)^2 = 56.7 \text{ FT}^2$$

20) Heat Input: 6343.3 gal/hr x 142,895 BTU/gal = 906.4 MBTU

THE UNITED ILLUMINATING COMPANY

SOURCE TESTING CALCULATION FORMS

Test No. B.H.S. 1, Stack 1 No. Runs 3

Name of Firm The United Illuminating Company

Location of Plant 10 Henry Street, Bridgeport, Connecticut

Type of Plant Steam Generating Station

Control Equipment Electrostatic Precipitator

Sampling Point Locations Stack

Pollutants Sampled Particulates, Nitrogen Oxides

Time of Particulate Test:

Run No. <u>1</u>	Date <u>4/12/73</u>	Begin <u>1402</u>	End <u>1719</u>
Run No. <u>2</u>	Date <u>4/13/73</u>	Begin <u>1300</u>	End <u>1609</u>
Run No. <u>3</u>	Date <u>4/16/73</u>	Begin <u>1326</u>	End <u>1637</u>

PARTICULATE EMISSION DATA

Run No.	1	2	3	
$K_p = 85.48 \frac{ft}{sec} \left(\frac{lb.}{lb \text{ mole-}^\circ R} \right)^{1/2}$	85.48	85.48	85.48	
$C_p =$ Pitot tube coefficient (calib.)	0.783	0.783	0.783	
$\bar{V}_{AP} =$ Average velocity head of stack gas, inches H ₂ O	1.26	1.25	1.24	
$\bar{T}_s =$ Average stack temp., °R	745.5	735.0	746.6	
$P_b =$ Barometric pressure, "Hg Abs.	29.94	30.10	30.38	
$P_d =$ Gas duct pressure, "H ₂ O	-0.40	-0.52	-0.48	
$P_s =$ Absolute stack gas pressure, inches Hg	29.91	30.06	30.35	
$B_{ws} =$ % moisture in stack gas, by volume	9.8	9.7	10.0	
$M_d =$ Molecular weight of stack gas, dry	30.01	30.13	29.93	
$M_s =$ Molecular weight of stack gas	28.83	28.95	28.74	

Run NO.	1	2	3
Vs = Stack gas velocity, F.P.S.	78.4	76.9	76.9
% CO ₂	11.33	11.85	10.09
% O ₂	5.05	5.89	7.99
% CO	0.00	0.00	0.00
% N ₂	83.62	82.26	81.92
Vlc = Total volume of liquid collected in impingers and silica gel, ml.	403.6	400.5	366.6
Vm = Volume of dry gas sampled at meter conditions, FT ³	173.639	170.381	153.761
Vstd = Volume of dry gas sampled at STP, FT ³	175.53	175.29	154.85
Tm = Average dry gas meter temp., °R	529.1	522.5	537.8
ΔH = Average pressure drop across orifice, inches H ₂ O	3.56	3.46	2.75
θ = Total Sampling Time, min.	180	180	180
Dn = Nozzle dia., inches	0.244	0.244	0.242
An = Nozzle area, FT ²	0.000325	0.000325	0.000318
I = % of isokinetic sampling	99.54	99.37	90.58
Qs = Stack gas volume at STP (SCFM)	171,038	171,145	169,546
Qa = Stack gas volume at stack conditions (ACFM)	266,811	261,580	261,614
Ws = Stack gas mass flow lbs/hr	797,853	801,544	788,784
Mp = Particulate-probe, washings, mg	15.9	14.8	43.7
Mf = Particulate-filter (mg)	14.7	11.1	13.3
Mn = Particulate-total (mg)	30.6	25.9	57.0
C's = Particulate Concentrations gr/scf	0.003	0.002	0.006
Cw = Particulate total emission lb/hr	3.9	3.3	8.2
Er = Particulate emission rate, lb/10 ⁶ BTU	0.004	0.004	0.009
C = NO _x concentrations, PPM	234	219	167
Cn = NO _x lb/10 ⁶ BTU	0.21	0.20	0.15

APPENDIX C

STACK SAMPLING : HARBOR STATION : UNIT #1

Test #1:

PARTICULATE wgt. ON FILTER: 14.7 mg

PARTICULATE wgt. IN WASHINGS: 15.9 mg

Total particulate wgt. : 30.6 mg

Test #2:

PARTICULATE wgt. ON FILTER: 11.1 mg

PARTICULATE wgt. IN WASHINGS: 14.8 mg

Total particulate wgt. : 25.9 mg

Test #3:

PARTICULATE wgt. ON FILTER: 13.3 mg

PARTICULATE wgt. IN WASHINGS: 43.7 mg

Total particulate wgt. : 57.0 mg

Gas Density

$$\text{Gas Density} = \frac{m_d}{386 \text{ FT}^3} \times \frac{T_{std}}{T} \times \frac{P_{bar}}{P_{std}}$$

$$1) \text{ Gas Density} = \frac{30.01}{386} \times \frac{530}{745.5} \times \frac{29.94}{29.92} = \\ = 0.055$$

$$2) \text{ Gas Density} = \frac{30.13}{386} \times \frac{530}{735.0} \times \frac{30.10}{29.92} = \\ = 0.057$$

$$3) \text{ Gas Density} = \frac{29.93}{386} \times \frac{530}{746.6} \times \frac{30.38}{29.92} = \\ = 0.056$$

Probe Measurements

CALCULATED DISTANCES.


STACK DIAMETER = 102" = 8'-6"

POINT	FACTOR	DISTANCE + NIPPLE	PROBE INCHES
1	1.4	1.43 + 36 =	37.4
2	4.4	4.5	40.5
3	7.5	7.7	43.7
4	10.9	11.1	47.1
5	14.6	14.9	50.9
6	18.8	19.2	55.2
7	23.6	24.1	60.1
8	29.6	30.2	66.2
9	38.2	39.0	75.0
10	61.8	65.0	99.0
11	70.4	71.8	107.8
12	76.4	77.9	113.9
13	81.0	82.8	118.8
14	85.4	87.1	123.1
15	89.1	90.9	126.9
16	92.5	94.4	130.4
17	95.6	97.5	133.5
18	98.6	100.6	136.6

37.4 inches is distance from center of
 pitot tube to first mark on probe,
 Accounting for 36" long sampling
 port nipple.

60-26

244. Preliminary Velocity Traverse



127 1/2
25 1/2
102"

SLACK PRESS - 0.75" H₂O

Point	Factor		+ A			B
1	1.4	1.43	25.5 - 26.9	1.5	1.4	1.3
2	4.4	4.44	30.0	1.4	1.5	1.4
3	7.5	7.55	33.1	1.4	1.3	1.4
4	10.9	11.0	36.5	1.4	1.3	1.5
5	14.6	14.7	40.2	1.4	1.3	1.5
6	18.8	19.0	44.5	1.3	1.3	1.5
7	23.6	23.8	49.3	1.4	1.3	1.4
8	29.6	29.9	55.4	1.4	1.3	1.4
9	38.2	38.5	64.0	1.6	1.5	1.4
10	61.8	62.3	87.8	1.6	1.5	1.5
11	70.4	71.0	96.5	1.7	1.6	1.6
12	76.4	77.0	102.5	1.7	1.7	1.6
13	81.2	82.0	107.5	1.6	1.7	1.6
14	85.4	86.0	111.5	1.4	1.7	1.5
15	89.1	90.0	115.5	1.4	1.6	1.5
16	92.5	93.4	118.9	1.4	1.6	1.5
17	95.6	96.5	122.0	1.5	1.5	1.4
18	98.6	99.5	125.0	1.5	1.5	1.3

PARTICULATE FIELD DATA

Stack Identification Number 1
 Ambient Temp OF 40
 Boiler Number 1
 Bar. Press. "Hg 29.74 - 29.94
 Plant Harbor Station
 Assumed Moisture % 10
 Run No. 1
 Heater Box Setting, OF 275
 Location Stack
 Probe Tip Dia., In. 2.14
 Date 4-12-73
 Probe Length 121
 Operator Somvarti
 Probe Heater Setting 801
 Meter ΔH 1.82
 Avg $\sqrt{\Delta P}$ 1.26 Avg. ΔH 3.56
 C Factor 27.26
 Stack Pressure -0.40" H₂O
 % Isokinetic 99.5

Point	Clock Time	Dry Gas Meter, CF	Pitot in H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. OF		Pump Vacuum In. Hg Gauge	Box Temp. OF	Impinger Temp OF	$\sqrt{\Delta P}$	Stack Temp OF
				Desired	Actual	Inlet	Outlet					
1	1402	387.303	1.1	2.6	2.6	50	66	75	200	50	1.05	271
2	1407	396.57	1.3	3.0	3.0	68	68	75	200	55	1.14	272
3	1411	395.87	1.3	3.0	3.0	70	69	95	200	50	1.04	288
4	1417	404.31	1.3	3.0	3.0	70	69	10	260	50	1.04	283
5	1421	408.56	1.7	3.1	3.1	85	85	10	270	50	1.18	281
6	1427	409.00	1.35	2.95	2.95	87	82	10	300	50	1.16	288
7	1430	412.45	1.4	3.1	3.1	82	87	16	265	50	1.18	287
8	1437	417.95	1.65	3.15	3.15	80	81	16	270	50	1.20	287
9	1440	422.96	1.5	3.0	3.0	80	80	12	250	50	1.22	282
10	1447	427.18	1.7	3.8	3.8	80	80	13.5	272	50	1.30	282
11	1450	428.35	1.8	3.95	3.95	80	80	14.0	270	50	1.34	282
12	1457	437.12	1.9	4.2	4.2	88	89	15.0	270	50	1.33	281
13	1502	447.00	2.0	4.35	4.35	88	88	15.5	270	50	1.41	285
14	1509	447.70	2.0	4.35	4.35	86	61	16.0	285	50	1.41	286
15	1510	453.00	2.0	4.35	4.35	87	61	16.0	280	50	1.41	286
16	1517	458.32	2.0	4.35	4.35	83	61	16.0	277	50	1.41	282

Point	Clock Time	Dry Gas Meter, CF	Pitot in H2O Δ P	Orifice Δ H in H2O		Dry Gas Temp. OF		Pump Vacuum In. Hg Gauge	Box Temp. OF	Impinger Temp. OF	VAP.	Stat Temp. OF
				Desired	Actual	Inlet	Outlet					
17	15:22	463.65	1.0	3.16	4.2	51	16	285	50	1.38	285	
18	15:31	468.21	1.2	3.2	4.1	51	16	285	50	1.38	285	
19	15:40	472.80	1.2	3.16	4.1	51	16	285	50	1.10	285	
20	15:49	477.44	1.4	3.1	4.1	51	16	285	50	1.18	285	
21	15:58	482.00	1.4	3.1	4.1	51	16	285	50	1.18	285	
22	16:07	487.44	1.6	3.5	4.7	51	16	285	50	1.26	285	
23	16:16	492.80	1.7	3.7	4.7	51	16	285	50	1.30	285	
24	16:25	497.80	1.7	3.7	4.7	51	16	285	50	1.30	285	
25	16:34	502.16	1.7	3.7	4.7	51	16	285	50	1.30	285	
26	16:43	507.16	1.7	3.7	4.7	51	16	285	50	1.30	285	
27	16:52	512.16	1.6	3.5	4.7	51	16	285	50	1.36	285	
28	17:01	517.16	1.7	3.7	4.7	51	16	285	50	1.30	285	
29	17:10	522.16	1.7	3.7	4.7	51	16	285	50	1.30	285	
30	17:19	527.16	1.7	3.7	4.7	51	16	285	50	1.30	285	
31	17:28	532.16	1.7	3.7	4.7	51	16	285	50	1.30	285	
32	17:37	537.16	1.7	3.7	4.7	51	16	285	50	1.30	285	
33	17:46	542.16	1.7	3.7	4.7	51	16	285	50	1.30	285	
34	17:55	547.16	1.7	3.7	4.7	51	16	285	50	1.30	285	
35	18:04	552.16	1.6	3.5	4.5	51	16	285	50	1.26	285	
36	18:13	557.16	1.4	3.1	4.1	51	16	285	50	1.18	285	
STOP	17:17	561.16										
		173.629		3.56		80.36					1.26	285

BHS # 1 TEST 1

WEIGHT OF PARTICULATE COLLECTED
mg

Container Number	Final Weight	Tare Weight	Weight Gain
16	.6171	.6318	.0147
1 Filter 2 Washings Total			

VOLUME OF LIQUID WATER COLLECTED
ml

Impinger	1	2	3	4
Final Vol.	292	224	29	
Initial Vol.	100	100	0	
Liquid Collected	192	124	29	58.6 ml 9
				403.6 ml

Unit 1 4-12-73

RUN # 1

199.5
37.0

162.5
196.1

358.6

233.1
37.0

196.1



22
192
124
29
58.6

403.6

St. #1 Harbor 4/73

Filter: (#16)

0.6318
0.6171
0.0147 mg

P.S.H.: (#7)

66.1601
66.1492
0.0109 mg

PATCHES: (#10)

0.3710
0.3659
0.0021

(#9)

0.3719
0.3650
0.0029

WASHINGS:

10.9

2.1

2.9

15.9 mg

TOTAL:

15.9

14.7

30.6 mg

Stack Identification Number _____ Ambient Temp OF 44

Boiler Number BHS / _____ Bar. Press. "Hg 30.12 - 30.07

Plant _____ Assumed Moisture % 10

Run No. 2 Heater Box Setting, OF 275

Location Stack Probe Tip Dia., In. .25

Date 4-13-73 Probe Length 12'

Operator J. Scambati Probe Heater Setting 70%

Meter ΔH 1.82 Avg. ΔP 1.25 Avg. ΔH 3.46

C Factor .7% Stack Pressure -0.52" H₂O

% Isokinetic _____

Point	Clock Time	Dry Gas Meter, CF	Pitot in H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. OF		Pump Vacuum In. Hg Gauge	Box Temp. OF	Impinger Temp OF	$\sqrt{\Delta P}$	Stack Temp OF
				Desired	Actual	Inlet	Outlet					
1	1300	574.31	1.15	2.5	2.5	41	41	4	275	50	1.67	260
2	1305	570.37	1.25	2.7	2.7	60	45	4.2	270	50	1.12	270
3	1310	574.52	1.3	2.9	2.9	61	46	4.2	270	50	1.19	265
4	1315	573.71	1.35	3.0	3.0	66	46	4.5	270	50	1.16	272
5	1320	582.90	1.35	3.0	3.0	65	46	4.5	260	50	1.14	270
6	1325	577.62	1.35	3.0	3.0	70	50	4.7	275	50	1.16	275
7	1330	573.22	1.35	3.0	3.0	71	51	4.8	270	50	1.16	270
8	1335	601.42	1.35	3.0	3.0	71	52	5.0	270	50	1.16	271
9	1340	600.55	1.5	3.2	3.2	73	53	4.9	260	50	1.22	271
10	1345	605.13	1.7	3.8	3.8	74	54	5.8	260	50	1.30	272
11	1350	610.38	1.7	3.8	3.8	78	55	5.5	260	50	1.30	270
12	1355	615.33	1.8	3.9	3.9	77	55	6.0	260	50	1.34	275
13	1359	620.37	1.85	4.0	4.0	73	55	6.2	260	50	1.36	275
14	1355	625.27	1.85	4.0	4.0	73	55	6.3	260	50	1.36	273
15	1359	629.34	1.85	4.0	4.0	71	55	6.2	260	50	1.36	273
16	1355	635.62	1.85	4.0	4.0	72	54	6.2	260	50	1.36	270

RHS 1, TEST 2, 4/13/73

WEIGHT OF PARTICULATE COLLECTED
mg

Container Number	Final Weight	Tare Weight	Weight Gain
18	.6320	.6209	0.0111
1 Filter 2 Washings Total			

VOLUME OF LIQUID WATER COLLECTED
ml

Impinger	1	2	3	4
Final Vol.	323	201	22	454.5
Initial Vol.	100	100	0	400
Liquid Collected	223	101	22	54.5 ml
			TOTAL	400.5

Run #2 4-13-73
Patches ~~1112~~ 1112

TEST #2 : HARDOZ 4/73

FILTER (#18):

0.6320
0.6209

0.0111 mg

WASHINGS: DIAL (#X):

60.9799
60.9714

0.0085 mg

PATCHES: (#11)

0.3423
0.3324

0.0099 mg

(#12)

0.3418
0.3394

0.0024

WASHINGS:

8.5

3.9

2.4

14.8 mg

TOTAL:

14.8

11.1

25.9 mg

PARTICULATE FIELD DATA

Stack Identification Number _____
 Boiler Number 1
 Plant BHS
 Run No. 3
 Location Stack
 Date 4-16-73
 Operator J. Sombati
 Meter ΔH 1.82
 C Factor .76

Ambient Temp OF 64
 Bar. Press. "Hg 30.38 - 30.38
 Assumed Moisture % 10
 Heater Box Setting, OF 300
 Probe Tip Dia., In. .242
 Probe Length 12'
 Probe Heater Setting 85%
 Avg. ΔP 1.24 Avg. ΔH 2.75
 Stack Pressure -0.13" H₂O

% Isokinetic _____

Point	Clock Time	Dry Gas Meter, CF	Pitot in H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. OF		Pump Vacuum In. Hg Gauge	Box Temp. OF	Impinger Temp OF	$\sqrt{\Delta P}$	Sta Temp OF
				Desired	Actual	Inlet	Outlet					
1	13:26	737.07	1.15	2.4	2.4	66	69	16.5	269	50	1.07	27
2	13:31	740.97	1.25	2.65	2.65	75	69	18.2	250	50	1.12	28
3	13:36	745.07	1.3	2.75	2.75	88	66	21.0	250	50	1.14	28
4	13:41	747.57	1.35	2.8	2.8	92	68	22.5	249	50	1.16	28
5	13:46	753.67	1.4	3.1	3.1	94	70	24.0	251	50	1.18	28
6	13:51	757.17	1.4	3.2	3.2	94	72	24.0	255	50	1.18	28
7	13:56	762.31	1.4	3.3	3.3	92	72	22.0	241	50	1.15	28
8	14:01	766.91	1.4	3.4	3.4	92	72	22.2	235	50	1.15	28
9	14:06	771.04	1.5	3.5	3.5	95	73	22.2	230	50	1.15	28
10	14:11	775.07	1.7	3.6	3.6	94	73	22.2	215	50	1.22	28
11	14:16	779.87	1.75	3.7	3.7	90	70	20.5	215	50	1.30	28
12	14:21	784.23	1.75	3.7	3.7	89	70	20.5	218	50	1.32	28
13	14:26	788.57	1.75	3.7	3.7	90	73	20.7	230	50	1.32	28
14	14:31	792.87	1.8	3.7	3.9	90	73	20.7	235	50	1.34	28
15	14:36	797.25	1.8	3.8	3.9	90	73	21.0	230	50	1.34	28
16	14:41	801.75	1.8	3.8	3.7	90	72	21.0	230	50	1.34	28

port
A

BHS 1, TEST 3

2/16/73

WEIGHT OF PARTICULATE COLLECTED
mg

Container Number = 9	Final Weight	Tare Weight	Weight Gain
1 Filter # 2 Washings	.6176	.6043	0.01339
Total			

VOLUME OF LIQUID WATER COLLECTED
ml

	1	2	3	4
Impinger				
Final Vol.	299	187	23	
Initial Vol.	100	100	0	58.6 ml
Liquid Collected	<u>199</u>	<u>87</u>	<u>23</u>	366.6

Patches 13, 14

TEST 3: HARBOUR 4/73

FILTER: (#9) 0.6176
0.6043
0.0133 mg

WASHING: DWH (#10) 63.1310
63.0998
0.0312 mg

PATCHES: (#13) 0.3597 (#14) 0.3512
0.3551 0.3433
0.0046 0.0099

WASHINGS: 31.2
4.6
7.9
43.7 mg

TOTAL: 43.7
13.3
57.0

COX 28

BRIDGEPORT HARBOR STATION

UNIT # 1

April 12, 1973

ORSAT ANALYSIS

TEST # 1

N₂X 512

O₂X 256

CO₂X 512

Calibrate

N₂X 512


O₂X 256

CO₂X 512

sample 44

N₂X 512

U.S. GOVERNMENT PRINTING OFFICE: 1969 O 348-100



sample #3

CO₂ x 512

N₂ x 512

O₂ x 256

CO₂ x 512

sample #2

N₂ x 32

N₂ x 512


O₂ missed

CO₂ x 512

sample #1

TEST 1

ORSAT ANALYSIS



$$3' \text{ } 72.5 \text{ } 76.3$$

$$2 = 1.5 \times 75.4 = 75.4$$

$$\frac{15.3}{78} = \frac{y}{14.2}$$

$$0.2 \times 25 = 7.2$$

$$\text{CO}_2 = 15.970 \quad 60.0$$

$$\text{CO} = 6.670$$

$$\text{O}_2 = 4.670 \quad 41.0$$

$$\text{CO}_2: \frac{41.5 + 43.5 + 43.5 + 42.5}{4} = 42.75$$

$$\text{O}_2: \frac{45.5 + 44.0 + 45.5}{3} = 45.0$$

$$\text{O}_2 \quad \frac{4.6}{4.1} = \frac{x}{45} = 5.05 \quad \text{O}_2$$

$$\text{CO}_2 \quad \frac{15.9}{60} = \frac{x}{42.75} = 11.33$$

$$\begin{array}{r} 5.05 \\ 11.33 \\ \hline 16.38 \end{array}$$

$$\text{N}_2 = 83.62$$

Co x 128


BRIDGEPORT HARBOR STA.

UNIT # 1




TEST # 2.

APRIL 13, 1973

ORSAT ANALYSIS



05112-5011 (REV. 10-64)



BHS. # 1

TEST 2

ORSAT ANALYSIS

CALIBRATION

CO₂: 60 DIVISIONS, 15.9%

O₂: 41.5, 4.67%

TEST DATA: SAMPLES 2, 3, & 4

CO₂: $\frac{44.5 + 44.5 + 44.5}{3} = 44.67$


O₂: $\frac{54 + 52.5 + 53}{3} = 53.16$

CO₂ $\frac{15.9}{60} = \frac{x}{44.67} = 11.85$


O₂ $\frac{4.6}{41.5} = \frac{x}{53.16} = 5.89$

17.74

N₂ = 100 - 17.74 = 82.26



sample 1



sample 2


BRIDGEPORT HARBOR STA.

UNIT # 1


TEST # 3

APRIL 16, 1973

OBSAT ANALYSIS



UNIT NO. 105-1103
UNIT NO. 105-1103
UNIT NO. 105-1103



x512

BAD SAMPLE

X512

Sample 1

CO

X128
X512

X512


N2

X650

CON

X572

CALIB



BHS # 1

TEST # 3

ORSAT ANALYSIS

CALIBRATION

CO₂ 15.9% 61

O₂ 4.6% 40

TEST DATA

CO₂ $\frac{38.5 + 47.2 + 35.5}{3} = 38.7$

O₂ $\frac{70.5 + 59.5 + 78.5}{3} = 69.5$

CO₂ $\frac{15.9}{61} = \frac{x}{38.7}$ $x = 10.09$

O₂ $\frac{4.6}{40} = \frac{x}{69.5}$ $x = 7.99$
18.08

N₂ = 100 - 18.08 = 81.92

BRIDGEPORT HARBOR STATION

UNIT # 1

APRIL 12, 1973

NOX ANALYSIS

TEST # 1

4:47 end blr. sample

(SO₂ = 32%)

4:45 PM

.99
602
234.00

(SO₂ = 32.5%)

NOX = 39% = 234 PPM

4:36 PM

RUN # 1 ON Unit # 1

4/12/73

0-100% = 0-600 PPM NOX

SPAN OK

zero reset
to 4.75

SPAN Pt = 757

SPAN GAS
420 PPM NOx
= 70%

Range 0-100% = 0-600 PPM

0 = 4.82
turns

NOx Calib.


4-12-23

UNIT #1

TEST #2

APRIL 13, 1973

NOx TEST



zero right on

NOx Calib.

Span 7.57 adj. To 7.35

calibrate gas
420 ppm should
read 707.
0.6 bottom probe

100-7-73

BRIDGEPORT HARBOR STA.

APR 13 1973

100-7-73

recheck calib
4:15 PM
26.5%

zero ✓ blr. sample #2 4:09 PM

readjust span
4.78

recheck calib
4:00 PM
27.8% NOx on 0-600 ppm scale

$$27.8\% \times 600 = 167 \text{ PPM}$$

blr. sample #1 3:50 PM
4-16-73


BRIDGEPORT HARBOR STA.

UNIT # 1

TEST # 3

APRIL 16, 1973

NOx ANALYSIS



span 70%
= 4.20 ppm
4.73 turns

— 0 = 4.75 turns
CALIB.

4-16-73
NOx TEST #3
Harbor Unit 1

BOILER OPERATING CONDITIONS

Stack Identification Number 1

Date 4/12/73

Boiler Number BRIDGEMONT

TEST 1

Plant Location _____

<u>Parameters</u>	<u>145</u>	<u>245</u>	<u>400</u>	<u>445</u>
Gross Load (MW)	<u>89.5</u>	<u>89.5</u>	<u>89.5</u>	<u>89.5</u>
Net Load (MW)	<u>140</u>	<u>240</u>	<u>350</u>	<u>440</u>
Fuel Flow (gal/hr)	<u>360,609</u>	<u>366,950</u>	<u>374,352</u>	<u>379,639</u>
Steam Flow (lb/hr)	<u>658,100</u>	<u>658,000</u>	<u>658,000</u>	<u>658,000</u>
Feed Water Flow (lb/hr)	<u>658,000</u>	<u>658,000</u>	<u>657,000</u>	<u>658,000</u>
Air Flow	<u>555,000</u>	<u>555,000</u>	<u>555,000</u>	<u>555,000</u>
Excess Air (%)				
Excess O ₂ (%)	<u>1.4%</u>	<u>1.35%</u>	<u>1.35%</u>	
Soot Blowing				
Boiler Inlet Feed Water Temp (OF)	<u>450°</u>	<u>450°</u>	<u>450</u>	<u>450</u>
Boiler Exit Steam Press. (psig)				
Boiler Exit Steam Temp (OF)				
Reheat Inlet Steam Press. (psig)				
Reheat Inlet Steam Temp (OF)				
Reheat Exit Steam Press. (psig)				
Reheat Exit Steam Temp (OF)				
Condenser Pressure (in Hg)				

Parameters	145	245	400	485
Cooling Water Temp (OF)				
Boiler Air Inlet Temp (OF)	92	92	94	94
Boiler Flue Gas Exit Temp (OF)	525	525	526	526
F.D. Fan Pressure Rise (in H2O)	650	642	643	644
F.D. Fan Current (amps)	266	270	270	270
F.D. Fan Voltage (V)				
ID Fan Pressure Rise (in H2O)				
ID Fan Current (amps)				
ID Fan Voltage (V)				
Forced Draft Inlet Air Temp (OF)				
Ambient Air Relative Humidity				
Barometric Pressure (in Hg)				
Ambient Air Temp (OF)				
Boiler Heat Rate (BTU/KW-hr)				
Burner Tilt				
Inlet Temp (OF)				
Outlet Temp (OF)				
Inlet Pressure (in H2O)				
Fapping Cycle Period (min)				
Spark Rate (sparks/min)				
Operating Voltage (KV)				
Operating Amps				

TEST 2

BOILER OPERATING CONDITIONS

Date 4-13-73

Stack Identification Number

Boiler Number

Plant Location

UNIT 1

HARBOR STATION

Parameters	1.00	2.00	4.00
Gross Load (MW)	88.5	88.6	88.5
Net Load (MW)	1.00	2.00	4.00
Fuel Flow (gal/hr)	496,315	502,574	515,085
Steam Flow (lb/hr)	652,000	652,000	652,000
Feed Water Flow (lb/hr)	652,000	652,000	652,000
Air Flow	550,000	550,000	550,000
Excess Air (%)	1.55	1.60	1.65
Excess O2 (%)			
Scot Blowing			
Boiler Inlet Feed Water Temp (°F)	450	450	450
Boiler Exit Steam Press. (psig)			
Boiler Inlet Steam Temp (°F)			
Reheat Inlet Steam Press. (psig)			
Reheat Inlet Steam Temp (°F)			
Reheat Exit Steam Press. (psig)			
Reheat Exit Steam Temp (°F)			

X X X X X X X

Parameters	1.04	2.02	4.00
Cooling Water Temp (°F)			
Boiler Air Inlet Temp (°F)	90	90	95
Boiler Flue Gas Exit Temp (°F)	502	505	505
F.D. Fan Pressure Rise (in H2O)	615	615	620
F.D. Fan Current (amps)	260	250	265
F.D. Fan Voltage (V)			
ID Fan Pressure Rise (in H2O)			
ID Fan Current (amps)			
ID Fan Voltage (V)			
Forced Draft Inlet Air Temp (°F)			
Ambient Air Relative Humidity			
Barometric Pressure (in Hg)			
Ambient Air Temp (°F)			
Boiler Heat Rate (BTU/KW-hr)			
Burner Tilt			
Inlet Temp (°F)			
Outlet Temp (°F)			
Inlet Pressure (in H2O)			
Fapping Cycle Period (min)			
Spark Rate (sparks/min)			
Operating Voltage (KV)			
Operating Amps			

BOILER OPERATING CONDITIONS

Date 4-16-73

Stack Identification Number HARBOR - UNIT 1

Boiler Number _____

Plant Location _____

<u>Parameters</u>	<u>245</u>	<u>345</u>	<u>445</u>
Gross Load (MW)	<u>895</u>	<u>875</u>	<u>897</u>
Net Load (MW)	<u>246</u>	<u>316</u>	
Fuel Flow (gal/hr)	<u>800,781</u>	<u>806,944</u>	<u>813,243</u>
Steam Flow (lb/hr)	<u>656,000</u>	<u>656,000</u>	<u>652,000</u>
Feed Water Flow (lb/hr)	<u>552,000</u>	<u>644,000</u>	<u>645,000</u>
Air Flow	<u>550,000</u>	<u>548,000</u>	<u>548,000</u>
Excess Air (%)			
Excess O2 (%)	<u>2.0</u>	<u>1.9</u>	
Soot Blowing			
Boiler Inlet Feed Water Temp (°F)	<u>450</u>	<u>450</u>	<u>450</u>
Boiler Exit Steam Press. (psig)			
Boiler Exit Steam Temp (°F)			
Reheat Inlet Steam Press. (psig)			
Reheat Inlet Steam Temp (°F)			
Reheat Exit Steam Press. (psig)			
Reheat Exit Steam Temp (°F)			

_____ (in Hg)

Parameters

	315	325	405						
Cooling Water Temp (OF)	110	110	111						
Boiler Air Inlet Temp (OF)	520	525	522						
Boiler Flue Gas Exit Temp (OF)	634	634	634						
F.D. Fan Pressure Rise (in H2O)	275	274	274						
F.D. Fan Current (amps)									
F.D. Fan Voltage (V)									
ID Fan Pressure Rise (In H2O)									
ID Fan Current (amps)									
ID Fan Voltage (V)									
Forced Draft Inlet Air Temp (OF)									
Ambient Air Relative Humidity									
Darometric Pressure (in Hg)									
Ambient Air Temp (OF)									
Boiler Heat Rate (BTU/KW-hr)									
Burner Tilt									
Inlet Temp (OF)									
Outlet Temp (OF)									
Inlet Pressure (in H2O)									
Extinguish Cycle Period (min)									
Spark Rate (sparks/min)									
Operating Voltage (KV)									
Operating Amps									

Plant 2

0AQPS - 78-1
II - I - 263

0.004 94
6070

FUEL
OIL COMBUSTION
AP-42 Section 1.3
Reference Number
24

4193 Ref 2

Emission Test Report
Bridgeport Harbor Station Stack No. 2
Steam Generator No. 2

Nov. 1961

The United Illuminating Company
Bridgeport Harbor Station
10 Henry Street
Bridgeport, Connecticut
06604

Approved by:

E. W. Somerville *E. W. Somerville*
Vice President, Engineering and Planning

Submitted by:

M. R. McCraven *M. R. McCraven*
Director of Environmental Engineering

Emission Test Report

Bridgeport Harbor Station Stack No. 2
Steam Generator No. 2
(Ref. "Intent to Test" Form Number 720050)

Test Conducted By
The United Illuminating Company
Development and Test Laboratory
80 Temple Street
New Haven, Connecticut
06506

United Illuminating Company Personnel Present

J. Sombati
J. Hotchkiss
J. Macknis

and by
York Research Corporation
One Research Drive
Stamford, Connecticut
06906

York Research Corporation Personnel Present

R. Larkin
J. Kittrell

Prepared by:

J. S. Sombati *J. Sombati*
Development & Test Laboratory Supervisor

J. W. Hotchkiss *J. W. Hotchkiss*
Assistant Mechanical Engineer

Checked by:

J. F. Crowe *J. F. Crowe*
Chief Mechanical Engineer

Test Results

Bridgeport Harbor Station
Steam Generator No. 2

Test Conducted on
December 11, 1973

Introduction

Emission tests for particulates and nitrogen oxides were conducted as required by Connecticut State Law on The United Illuminating Company Bridgeport Harbor Station Steam Generator No. 2, stack No. 2, located in Bridgeport, Connecticut. Testing was conducted on December 11, 1973.

Particulate testing was performed in accordance with test methods and procedures as prescribed in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. Testing was performed by York Research Corporation of Stamford, Connecticut, using a sampling train as described in Appendix A.

Nitrogen oxide emission testing was performed by the United Illuminating Company Development and Test Laboratory using a Dynascience Model P-101 NO_x Analyzer. Field data is included in Appendix B.

Tests were also conducted to determine stack gas velocity, moisture content, and flue-gas analysis. The procedures used in determining these various parameters, except for flue gas analysis, are those found in the above mentioned Federal Register. The stack flue gas was analyzed by using an Analytical Instrument Development Model 512 Portable Gas Chromatograph.

York Research Corporation was retained to perform particulate tests, together with a preliminary velocity traverse, moisture determination, and fuel oil analysis. The United Illuminating Company was responsible for the flue gas analysis, nitrogen oxide analysis, and for accumulating boiler operating data.

This test report includes the information required for Item Nos. III, IV, V, VI, VII, VIII, IX, X, XI, XII and XIII from the Department of Environmental Protection's Intent to Test form in compliance with the Department of Environmental Protection's new Source Test Guidelines and Procedures, (received April 3, 1973).

TABLE I

SUMMARY OF TEST RESULTS

STEAM GENERATOR NO. 2

STACK NO. 2

<u>Component</u>	<u>Sampling Duration</u>		<u>Number of Tests</u>	<u>Measured Concentrations</u>	<u>Method Employed to Determine Concentration</u>
	<u>Minutes per point</u>	<u>Total Test Time</u>			
1) NO _x		15 min	3	0.42 lb/10 ⁶ BTU	Dynascience Model P-101 NO _x Analyzer
2) Particu- late	5	60 min	3	0.05 lb/10 ⁶ BTU	Method 5*
3) Moisture	5	60 min	3	7.4%	Method 4*
4) Gas Analysis		15 min	3	33% Excess Air	A. I. D. Model 512 Portable Gas Chromatograph
5) Velocity	1/2	15 min	3	0.45" H ₂ O to 1.5" H ₂ O**	Method 2*

* Federal Register, Volume 36, No. 247, December 23, 1971

** Range of S-type pitot Tube Differential

TABLE II

SUMMARY OF RESULTS

STEAM GENERATOR NO. 2

STACK NO. 2

Test	<u>1</u>	<u>2</u>	<u>3</u>	<u>Average</u>
Date	12/11/73	12/11/73	12/11/73	
Stack Flow, ACFM	584,901	628,201	617,552	610,218
Stack Flow, SCFM	406,382	427,969	426,971	420,441
Stack Flow, lb/hr	1,905,784	2,005,689	2,000,348	1,970,607
% Excess O ₂ at Test Point	6.57	6.66	6.69	6.64
Particulate Emissions				
gr/SCF	0.030	0.020	0.022	0.024
lb/hr	104.85	71.90	81.98	86.24
lb/MBTU	0.06	0.04	0.05	0.05
Nitrogen Oxide Emission				
ppm	255	252	246	251
lb/hr	741.0	771.1	751.0	754.4
lb/MBTU	0.41	0.43	0.42	0.42

particulate: $86.24 \frac{\text{lb}}{\text{hr}} \times \frac{1 \text{ lb}}{12.37 \times 10^3 \text{ gal}} = 7 \frac{\text{lb}}{10^3 \text{ gal}} = 7 \frac{\text{lb}}{10^3 \text{ gal}} = 35 \frac{\text{lb}}{10^3 \text{ gal}}$

NOx: $754 \frac{\text{lb}}{\text{hr}} \times \frac{1 \text{ lb}}{12.37 \times 10^3 \text{ gal}} = 61 \frac{\text{lb}}{10^3 \text{ gal}}$

checked
checked
checked
(60% efficiency)

TABLE III

AVERAGE BOILER OPERATING DATA FOR TEST PERIODS

STEAM GENERATOR NO. 2

STACK NO. 2

	<u>1</u>	<u>2</u>	<u>3</u>
Test			
Date	12/11/73	12/11/73	12/11/73
Steam Flow lb/hr	1,325,000 ^{140 MW}	1,325,000	1,325,000
Oil Flow gal/hr	12,257	12,280	12,263
Heat Input, MBTU/hr	1805.3	1808.7	1806.2
Stack Gas Temperature °F	250	250	250
Gas Density, lb/ft ³	0.058	0.058	0.058

TABLE IV

FUEL OIL ANALYSIS

STEAM GENERATOR NO. 2

STACK NO. 2

<u>Test</u>	<u>1</u>	<u>2</u>	<u>3</u>
Date	12/11/73	12/11/73	12/11/73
	<u>Composition (% by Weight)</u>		
Carbon	86.10	86.10	86.10
Hydrogen	12.61	12.61	12.61
Nitrogen	0.1	0.1	0.1
Ash	0.019	0.019	0.019
Sulfur	0.348	0.348	0.348
Specific Gravity	0.909	0.909	0.909
BTU/lb	19,452	19,452	19,452
BTU/gal	147,290	147,290	147,290

1. Sampling Train Information
(Ref. Item VIII, "Intent To Test" Form)

a. Schematic Diagram and description of sampling train:

See Appendix A.

b. Media type used to determine gas stream components:

1. NO_x: Dynascience Model P-101 NO_x Analyzer
2. Particulates: Tared glass fiber filter.
3. Flue Gas Analysis: Analytical Instrument Development Model 512 Portable Gas Chromatograph

c. Sampling Probes:

1. Nitrogen Oxides: Stainless steel tube
2. Particulates: See Appendix A
3. Flue Gas Analysis: Stainless steel tube

d. Probe Cleaning Method:

See Appendix A

2. Field Data Sheets
(Ref. Item IX, "Intent To Test" Form)

See Appendices A, B, C, D.

3. Description of Operation
(Ref. Item X, "Intent To Test" Form)

The operation tested was Bridgeport Harbor Station steam generator No. 2, stack No. 2, Registration Number BHS2, stack 2, having a total BTU/hr rating of 1806.7 MBTU/hr (averaged over the test period), burning No. 6 residual fuel oil at an average rate of 12,267 gal/hr, and having a gas flow of 610,218 ACFM, average for the test period. See Table IV for fuel oil analysis.

4. Sampling Area Description
(Ref. Item XI, "Intent To Test" Form)

Emission sampling was performed in the stack 170 feet above the stack foundation (8 stack diameters above the breeching inlet and 6 stack diameters down from the top). Emission sampling was performed using four - 4" diameter sampling ports, spaced 90° apart on the stack circumference. A total of twelve sampling points (3 per sampling port) were used in the test for particulates. The inside diameter of the stack at the sampling location was found to be 12'-10-3/4" I.D.

a. Stack Configuration:

See Appendix A.

b. Sampling Port Location:

See Appendix A.

c. Sampling Point Position:

See Appendix A.

5. Stack and Vent Description
(Ref. Item XII, "Intent To Test" Form)

One Babcock and Wilcox Cyclone fired Radiant Reheat Boiler discharges flue gas through two breechings into the stack. Attached to the outlet of the boiler is a Research-Cottrell electrostatic precipitator, having an estimated collection efficiency of 60% when burning No. 6 residual fuel oil.

6. Operational Parameters
(Ref. Item XIII, "Intent To Test" Form)

Electric utility steam generators burning No. 6 residual fuel oil having rated capacities as registered.

APPENDIX A

PARTICULATE TEST

V. SAMPLING METHODS

1. Port Location

The test port locations and the number of points sampled were calculated from guidelines in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. Enough points were used to assure accurate measurement of particulate emissions, temperature, and velocity over the cross-sectional area of each stack (See Figures 1-4).

2. Velocity and Temperature

Velocity was determined in accordance with Guidelines in Method 2 of the Federal Register. A preliminary velocity traverse was made to establish isokinetic sampling rates using EPA Method 5 sampling techniques (See Figure #6).

3. Flue Gas Analysis

Gas analysis for CO₂ and O₂ was conducted by UI using an Orsat apparatus. Readings for each test are reported in the Summary of Results.

4. Particulate Sampling Methods - EPA Method 5

The sampling apparatus consisted of a nine (9) foot probe on Unit 2 and a fifteen (15) foot probe on Unit 3, heated filter, four impingers, dry gas meter, vacuum pump, and calibrated orifice as shown in Figure 5. The stainless steel, button-hook type sampling nozzle (1), Type "S" pitot tube (2), and thermocouple (3), extended from the sampling end of the probe, which consisted of 1/2 inch inside diameter medium-wall stainless steel tube with a ground steel joint on one end. The probe was logarithmically wound from the entrance end with 26-gauge nickel-chromium wire. During sampling, the wire was connected to a variable transformer to maintain a gas temperature of 250°F in the probe. The wire wound tube was wrapped with fiber glass tape and encased in a 1-inch-OD stainless steel tube for protection. The end of the steel tube that does not have the ball-joint protruding has a nut welded to it for connection to the stainless steel coupling used to attach the nozzle. The probe connects to a very coarse fritted glass filter holder (5) which holds a tared glass fiber filter. The filter holder was con-

tained in an electrically heated enclosed box (4) which is thermostatically maintained at a minimum temperature of 250°F to prevent water condensation. Attached to the heated box with tygon tubing was an ice bath (7) containing four impingers connected in series with vacuum hose. The first impinger (8) receives the gas stream from the filter. This impinger is of the Greenburg-Smith design modified by replacing the tip with a $\frac{1}{2}$ inch ID glass tube extending to 0.5 inch from the bottom of the flask. This impinger was initially filled with 100 milliliters of distilled water. The second impinger (9) is a Greenburg-Smith impinger with tip, and also filled with 100 milliliters of distilled water. The third impinger (10) modified like the first, with no water. The fourth impinger (11) is also a Greenburg-Smith type modified like the first and contained 300 grams of dry indicating silica gel.

From the fourth impinger the effluent stream flows through a dial thermometer (12), a check valve (13); flexible rubber vacuum tubing (14); vacuum gauge (15); a valve (16); a leakless vacuum pump (17), rated at 4 cubic feet per minute at 0 inches of mercury gauge pressure and 0 cubic feet per minute at 26 inches of mercury gauge pressure, and connected in parallel with a bypass needle valve (18); and a dry gas meter rated at .1 cubic foot per revolution (19). A calibrated orifice (20) completes the train and was used to measure instantaneous meter flow rates. The three thermometers (12) are dial type with a range of 25° to 125°F. A fourth thermometer in the heated portion of the box has a range up to 500°F. The dual manometer (21) across the calibrated orifice is an inclined-vertical type graduated in hundredths of an inch of water from 0 to 1.0 inch and in tenths from 1 to 10 inches.

5. Test Procedure

Prior to the start of a test series for each stack, the pressure, temperature, and range of velocity pressures were determined during preliminary pitot tube and temperature traverse.

During each test the following readings were taken at each point:

1. Point Designation
2. Clock Time
3. Dry gas meter reading (CF)
4. Velocity head (ΔP in inches water)
5. Desired pressure drop across orifice (ΔH inches water)
6. Actual pressure drop across orifice (ΔH in inches water)
7. Dry gas temperature (°F) gas meter inlet
8. Dry gas temperature (°F) gas meter outlet.
9. Vacuum pump gauge reading (in. Hg).

10. Filter box temperature ($^{\circ}$ F)
11. Dry gas temperature ($^{\circ}$ F) at the discharge of last impinger
12. Stack temperature ($^{\circ}$ F)

The relationship of ΔP reading with the ΔH reading is a function of the following variables:

1. Orifice calibration factor
2. Gas meter temperature
3. % moisture in the flue gas
4. Ratio of flue gas pressure to barometric pressure
5. Stack temperature
6. Sampling nozzle diameter

A nomograph was used to correlate all the above variables such that a direct relationship between ΔP and ΔH could be determined by the sampler within fifteen seconds and isokinetic conditions maintained throughout the test.

6. BASIC LABORATORY PROCEDURE

The following paragraph briefly describes the methods used in the laboratory to obtain the raw data used in the calculations of our results as reported in Section III and VI of this report.

The clean up is done in the field according to EPA test procedure. The filters were previously tare weighed and recorded at the laboratory. Upon return they are dried, cooled in a dessicator, then weighed on an analytical balance and the amount of particulate collected is the difference in the two weights. The particulate wash solution (taken from the train in front of the filter) is placed in a tared beaker, the wash solution is evaporated with an Infra-Red Heat Lamp and the beaker weighed again. The difference in weight is the weight of the particulate in the wash. This is combined with the filter catch as the weight of the sample.

The impinger condensate is measured for moisture determination.


CALIBRATION

The equipment used on this assignment was calibrated one week prior to field testing and re-calibrated upon equipment return after testing. York Research calibration is traceable to the National Bureau of Standards.


TEST TEAM

Robert J. Larkin
James R. Kittrell

Prepared By:


Robert J. Larkin
Test Engineer

Reviewed By:


Robert S. Epstein
Project Director

Approved By:


Roy S. Egdall
Manager Engineering Services

11/5/73
 OK
 il OK
 Quick Connects OK Valves OK
 Meters OK
 Test Meter _____
 Meters OK
 _____ OK
 Electrical Check - Amphenol OK
 _____ OK
 _____ OK
 Check at 27" hg. - OK

Check each item when checked and write in any remarks.

Calibration - Orifice and Meter

11/5/73 Box No. S 1563 P_b 29.9

Orifice	CF _w	CF _d	T _w	IT _d	OT _d	T _d Avg.	Time t
1.5	5	5.15	67	85	75	80	12.73
2.0	5	5.06	67	85.5	77.6	87.15	9.012
2.0	10	10.16	68	88.8	79.5	84.1	13.2
4.0	10	10.03	68	89.0	79.6	84.3	9.306
6.0	10	10.05	68	92.8	80.3	86.5	7.67
8.0	10						

Calculate Y & H_a at man. 2.0

$$Y = \frac{CF_w P_b (T_d \text{ avg.} + 460)}{CF_d (P_b + 0.147(T_w + 460))}$$

$$\Delta H_a = \frac{0.0634 P_b (OT_d + 460) \left(\frac{CF_w}{(T_w + 460)} \right)^2}{(P_b + 460) \left((P_b + 460) t \right)^2}$$

Tolerances

$$Y = 0.99 - \frac{1.00}{1.84} - 1.0$$

$$\Delta H_a = 1.6 - \frac{1.84}{1.84} - 2.1$$

0.317 (Man. Orifice)

$$(T_w + 460)^2$$

Pb (OTd + 460)

CFw

0.01585

$$(67 + 460)^2$$

29.9 (75 + 460)

0.0317

$$(67 + 460)^2$$

29.9 (77.6 + 460)

0.0634

$$(68 + 460)^2$$

29.9 (79.5 + 460)

0.1268

$$(68 + 460)^2$$

29.9 (79.6 + 460)

0.1902

$$(68 + 460)^2$$

29.9 (80.3 + 460)

0.2536

$$(\quad + 460)^2$$

Man. II

CFw Pb (Td avg. + 460)

Y =

$$CFd Pb + \frac{\text{Man. Orifice}}{13.6} (T_w + 460)$$

$$Y = \frac{5 \times 29.9}{5.15} (80 + 460)$$

$$Y = \frac{5.15}{5} (29.9 + 0.0368) (67 + 460)$$

$$Y = \frac{5 \times 29.9 (81.5 + 460)}{5.06} (29.9 + 0.0737) (67 + 460)$$

$$Y = \frac{10 \times 29.9 (84.1 + 460)}{10.16 (29.9 + 0.147) (68 + 460)}$$

$$Y = \frac{10 \times 29.9 (84.3 + 460)}{10.03 (29.9 + 0.291) (68 + 460)}$$

$$Y = \frac{10 \times 29.9 (86.5 + 460)}{10.05 (29.9 + 0.431) (68 + 460)}$$

$$Y = \quad \times \quad (\quad + 460)$$

$$Y = \quad (\quad + 0.588) (\quad + 460)$$

Man. II

Man.	Y.
.5	.993
1.0	1.01
2.0	1.00
4.0	1.0
6.0	1.0
8.0	


REPORT NO. Y-8278-3

FIELD DATA

PROBE LENGTH AND TYPE 3/16
 NOZZLE I.D. 10
 ASSUMED MOISTURE % 10
 SAMPLE BOX NUMBER S-1003
 METER BOX NUMBER 120
 METER AM, 26
 C FACTOR 1.16
 PROBE HEATER SETTING 4.2
 HEATER BOX SETTING 4.2
 REFERENCE SP

50 ml H₂O net

PLANT WT Harbor Station
 DATE 12/17/73
 SAMPLING LOCATION Stack Units
 SAMPLE TYPE Particulates
 RUN NUMBER 1
 OPERATOR RJK
 AMBIENT TEMPERATURE 35
 BAROMETRIC PRESSURE 30.23
 STATIC PRESSURE (IP) 6.34
 FILTER NUMBER (S) 345



SCHEMATIC OF TRAVERSE POINT LAYOUT
 READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (V _m , ft ³)	VELOCITY HEAD (SP), in. H ₂ O	ORIFICE PRESSURE DIFFERENTIAL (SP), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE (T _m in, °F)		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
				DESIRED	ACTUAL		INLET	OUTLET (T _m out), °F			
W 1	1010	95.845	1.4	1.38	1.38	350	55	55	7		
3	1015	102.30	1.3	1.37	1.37	350	54	56	6		
3	1020	104.92	1.5	1.46	1.46	350	53	56	3		
END	1025	106.983	1.5	1.48	1.48	350	54	53	8		
S 1	1032	110.40	1.3	1.34	1.34	350	53	53	8		
3	1037	113.84	1.4	1.38	1.38	350	50	48	8		
3	1042	116.858	1.4	1.38	1.38	350	48	51	7		
END	1047	116.858	1.4	1.38	1.38	350	48	50	7		
F 1	1053	120.00	1.3	1.34	1.34	350	46	48	7		
3	1057	122.46	1.4	1.38	1.38	350	46	48	7		
3	1102	136.336	1.4	1.35	1.35	350	47	47	6		
END	1104	139.48	1.3	1.16	1.16	350					
N 1	1109	132.91									
3	1114	136.500									
END	1119										

ES-041

COMMENTS


REPORT NO. Y-0278-3

FIELD DATA

PROBE LENGTH AND TYPE 3/16
 NOZZLE I.D. 10
 ASSURED COISTURE % 5-1563
 SAMPLE COX NUMBER 190
 METER BOX NUMBER 190
 METER SH 100.20
 C FACTOR 1.16
 PROBE HEATER SETTING 100.20
 HEATER BOX SETTING 1.16
 REFERENCE AP

PLANT MT Hubbar station
 DATE 12/11/53
 SAMPLING LOCATION Stack Chimney
 SAMPLE TYPE 2% chloride
 RUN NUMBER 2
 OPERATOR ATL
 AMBIENT TEMPERATURE 35
 BAROMETRIC PRESSURE 29.85
 STATIC PRESSURE (P) 6
 FILTER NUMBER (S) EL-405

65 ml H₂O net



SCHEMATIC OF TRAVERSE POINT LAYOUT
 READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24 Hr CLOCK)	GAS METER READING (V _m , ft ³)	VELOCITY HEAD (59.2 in. H ₂ O)	ORIFICE PRESSURE DIFFERENTIAL (in. H ₂ O)		STACK TEMPERATURE (T _s , °F)	DRY GAS METER TEMPERATURE (T _m in., °F)		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
				DESIRED	ACTUAL		INLET	OUTLET			
N 1	1208	36.517	1.5	1.45	1.48	250	43	46	5		
2	1213	37.64	1.5	1.45	1.48	250	44	46	5		
3	1218	43.00	1.4	1.38	1.38	250	47	47	5		
END	1233	45.963	1.4	1.38	1.38	250	45	45	5		
EL	1236	45.963	1.4	1.38	1.38	250	46	46	5		
2	1237	52.15	1.3	1.35	1.35	250	46	46	5		
3	1236	53.40	1.5	1.48	1.48	250	46	46	5		
END	1241	55.328	1.5	1.48	1.48	250	46	46	5		
S 1	1242	55.328	1.5	1.48	1.48	250	46	46	5		
2	1252	58.74	1.5	1.48	1.48	250	47	45	5		
3	1257	62.15	1.5	1.48	1.48	250	47	46	5		
END	1302	65.340	1.5	1.48	1.48	250	47	46	5		
N 1	1305	65.340	1.5	1.48	1.48	250	47	46	5		
2	1310	68.20	1.5	1.48	1.48	250	47	46	5		
3	1315	71.48	1.5	1.48	1.48	250	47	46	5		
END	1320	75.341									

ES-041

COMMENTS

FIELD DATA

PROBE LENGTH AND TYPE _____
 NOZZLE I.D. 3/16
 ASSUMED MOISTURE, % 10
 SAMPLE BOX NUMBER _____
 METER BOX NUMBER 5-1563
 METER A.H. 1 20
 C FACTOR 26
 PROBE HEATER SETTING 110.0
 HEATER BOX SETTING 100.0
 REFERENCE AQ _____

PLANT WT Harbor Station
 DATE 12/11/73
 SAMPLING LOCATION Stack Unit 2
 SAMPLE TYPE Particulate
 RUN NUMBER 3
 OPERATOR P.J.
 AMBIENT TEMPERATURE 35
 BAROMETRIC PRESSURE 30.47
 STATIC PRESSURE, (P_s) _____
 FILTER NUMBER (S) _____





SCHEMATIC OF TRAVERSE POINT LAYOUT
 READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (Vol. ft ³)	VELOCITY HEAD (V ₉₀), in. H ₂ O	ORIFICE DIFFERENTIAL (A.H.I. in. H ₂ O)		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
				DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F			
W 1	1343	75.351	1.5	1.48	1.48	250	44	44	6		
2	1345	75.28	1.5	1.48	1.48	250	44	44	6		
3	1353	83.22	1.4	1.38	1.38	250	44	45	7		
END	1354	85.330									
S 1	1400	85.370	1.5	1.48	1.48	250	44	45	6		
2	1405	85.81	1.5	1.48	1.48	250	44	45	6		
3	1410	91.54	1.5	1.48	1.48	250	44	44	6		
END	1415	91.991									
E 1	1416	95.451	1.5	1.48	1.48	250	46	45	6		
2	1421	98.50	1.5	1.38	1.38	250	48	46	6		
3	1426	101.93	1.5	1.38	1.38	250	48	46	6		
END	1431	104.918									
N 1	1433	104.919	1.5	1.48	1.48	250	47	45	7		
2	1437	105.10	1.4	1.38	1.38	250	47	46	6		
3	1443	111.35	1.3	1.38	1.38	250	47	46	6		
END	1447	114.360									

COMMENTS

ES-041



TRAVERSE POINT No.	DISTANCE FROM WALL
3	6.8'
2	22.7'
1	45.7'

REVISED	
THE UNITED ILLUMINATING CO. NEW HAVEN, CONN. STACK CONFIGURATION AND SAMPLING POINT LOCATION STACK #2 BRIDGEPORT HARBOR STATION	
DRAWN BY P.L.S.	DATE 4-2-74
TRACED BY	DATE
APPROVED BY J.W.L.H.	DATE 4-2-74
SCALE 1/8"=1'-0"	DRAWING NO. 41272-7

APPENDIX B

NITROGEN OXIDE TEST

FLUE GAS ANALYSIS

THE UNITED ILLUMINATING COMPANY

ORSAT DATA & CALCULATION SHEET

Stack Identification Number 2

Date DEC. 11, 1973

Boiler Number 2

Time 11:15

Plant Location Bpt Harbor Sta

Sampling Point Location Stack

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt/mole (dry)
CO ₂ , % Vol (dry)	11.95	11.84	11.95		11.91	44/100	52.4
CO, % Vol (dry)	0	0	0		0.00	28/100	+ 0.00
O ₂ , % Vol (dry)	6.55	1.63	6.55		6.57	32/100	+ 2.10
N ₂ , % Vol (dry)	81.50	81.54	81.50		81.51	28/100	+ 22.83
Avg. molecular wt. of dry stack gas =							30.17

1051

THE UNITED ILLUMINATING COMPANY

ORSAT DATA & CALCULATION SHEET

Date DEC. 11, 1973
 Time 1:20 PM

Stack Identification Number 2
 Boiler Number 2
 Plant Location Bgt Harrier
 Sampling Point Location STACK

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt/mole. (dry)
CO ₂ , % Vol (dry)	11.70	11.90	11.80		11.77	44/100	5.18
CO, % Vol (dry)	0	0	0		0.00	28/100	+ 0.00
O ₂ , % Vol (dry)	1.67	6.67	6.67		6.66	32/100	+ 2.13
N ₂ , % Vol (dry)	81.53	81.51	81.56		81.57	28/100	+ 22.84
Avg. molecular wt. of dry stack gas =							30.15

THE UNITED ILLUMINATING COMPANY

ORSAT DATA & CALCULATION SHEET

Stack Identification Number 2

Date DEC 11, 1973

Boiler Number 2


Time 2:45 PM

Plant Location Bot Harbor

Sampling Point Location Stack

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt/mole (dry)
CO ₂ , % vol (dry)	11.60	11.75	11.75		11.71	44/100	5.15
CO, % vol (dry)	0	0	0		0.00	28/100	+ 0.00
O ₂ , % vol (dry)	0	0	0		6.69	32/100	+ 2.14
N ₂ , % vol (dry)	81.60	81.60	81.60		81.60	28/100	+ 22.85
Avg. molecular wt. of dry stack gas =							30.14

TEST NO. 1



N2X512

02X256

COX512

calibrate test #1 11:30 AM

N2X512

02X256

COX512


Sample-3

N2X512

02X256

COX512


Sample
Test #1



0.2256

0.2252

Sample 1-1
Test #1
11:20 AM




0.2128

0.2252

0.2256

0.2252

Calibrate
11:15 AM
12/11/99



11:00 AM

10:55 AM
SAMPLE

Recalibrate

10:45 AM
Sample
10:45 AM
check
12/11/73


Bot. Harbor Station
Stack No 2

Test No 1
12/11/73

2770

Nov
Test #1

TEST NO. 2



COX128

Calibrate
1:25 PM
7/2/02

Sample 12-3
7/2/02

N2056

02X256

COX128

02X256

COX128

Top

Sample #2
10:55 AM

Calibrate

Sample

Calibrate

Nov Test #2
Cont #2
12/11/73 10:55 AM

Bot. Harbor Station
Stack No 2
Test No 2
12/11/73

NOX CH EQUIPMENT

NOX ANALYZER


NOX CH EQUIPMENT

NOX ANALYZER

NOX

TEST NO. 3

Vertical text on the right edge of the grid, possibly a scale or axis label.



821128

02X256

02X200

Calibrate
2:50 PM

02Y256

02X512

Sample 13-3
Trial 13

25256

021512

Sample #3-2
Tot #3

26121

25252

021512

Sample #3-1
Tot #3
2140

02120

Count 1000-2000

11/20

0.255

0.2510

Calibrate
Test #3

2:30 PM

zero
check

NOY
Calibrate

NOY
Sample #3
2:10 PM

Test #3

zero
check

DATE TIME

OPERATOR

calibrate

Test #3

Unit #2

12/11/73

2:30 PM

Nix

Bridgport Harbor Sta.

Stack No 2

Test No 3

12/11/73

Chart No. 1000

APPENDIX C

BOILER OPERATING DATA

Date DEC 11, 1973

Stack Identification Number BHS 2

Boiler Number 2

Plant Location BRT H/C S...

Parameters	0907	1038	1125
Gross Load (Msi)	182	182	182
Net Load (Msi)			
Fuel Flow (gal/hr) <u>Water Return</u>	8,742.51	8,746.25	7,775.84
Steam Flow (lb/hr)	1,325,000	1,325,000	1,325,000
Feed Water Flow (lb/hr)	1,260,000	1,250,000	1,250,000
Air Flow (lb/hr)	1,150,000	1,175,000	1,175,000
Excess Air (%)	—	—	—
Excess O ₂ (%) <u>Exhaust Outlet</u>	1.9	2.9	2.0
Soot Blowing	—	—	—
Boiler Inlet Feed Water Temp (°F) <u>(Average)</u>	570	572	574
Boiler Exit Steam Press. (psig)	2050	2050	2050
Boiler Exit Steam Temp (°F)	970/970	970/970	970/970
Reheat Inlet Steam Press. (psig)	440	440	435
Reheat Inlet Steam Temp (°F)	—	—	—
Reheat Exit Steam Press. (psig)	140	140	140
Reheat Exit Steam Temp (°F)	980	980	970
Condenser Pressure (in-Hg) Abs	1.4	1.4	1.4

Parameters	0901	1036	1125
Boiling-Water Temp (Op)	51	51	51
Boiler Air Inlet Temp (OF)	505	504	563
Boiler Air Inlet Temp (OF)	275/245	275/250	275/250
D. Fan Pressure Rise (in H2O)	40	36	36
D. Fan Current (amps)	305/300	305/300	305/305
D. Fan Voltage (V)	—	—	—
Fan Pressure Rise (in H2O)	—	—	—
Fan Current (amps)	—	—	—
Fan Voltage (V)	—	—	—
Excess Draft Inlet Temp (OF)	37	39	41
Ambient Air Relative Humidity	—	—	—
Barometric Pressure (in Hg)	29.91	29.83	29.82
Ambient Air Temp (OF)	37	39	41
Boiler Heat Rate (TU/KW-hr)	—	—	—
Boiler Tilt	—	—	—
Boiler Inlet Temp (OF)	275/245	275/250	275/250
Boiler Outlet Temp (OF)	—	—	—
Boiler Inlet Pressure (in H2O)	2.5	2.3	2.2
Boiler Operating Cycle Period (min)	—	—	—
Boiler Spark Rate (sparks/min)	—	—	—
Boiler Operating Voltage (KV)	—	—	—
Boiler Operating Amps	—	—	—

BOILER OPERATING CONDITIONS

Date DEC 11 1973

Stack Identification Number 2

Boiler Number 2

Plant Location EST 2

Parameters	1203	1305						
Gross Load (MW)	182	182						
Net Load (MW)								
Fuel Flow (lb/hr)	8785	8500						
Steam Flow (lb/hr)	1200	1200						
Feed Water Flow (lb/hr)	1250	1250						
Air Flow								
Excess Air (%)	1.9	1.9						
Excess O2 (%)								
Scot Blowing								
Boiler Inlet Feed Water Temp (°F)	512	512						
Boiler Exit Steam Press. (psig)		205						
Boiler Exit Steam Temp (°F)	969	969						
Reheat Inlet Steam Press. (psig)	505	505						
Reheat-Inlet Steam Temp (°F)								
Reheat-Exit Steam Press. (psig)		470						
Reheat-Exit Steam Temp (°F)	970	970						

Parameter	1223	1325																		
Cooling-Water Temp (OF)	51	51																		
Boiler Air Inlet Temp (OF)	56	56																		
Boiler Flue Gas Exit Temp (OF)	274/253	274/253																		
F.D. Fan Pressure Rise (in H2O)	26	26																		
F.D. Fan Current (amps)	310/297	310/297																		
F.D. Fan Voltage (V)	—	—																		
ID Fan Pressure Rise (in H2O)	—	—																		
ID Fan Current (amps)	—	—																		
ID Fan Voltage (V)	—	—																		
Forced Draft Inlet Air Temp (OF)	45	45																		
Ambient Air Relative Humidity	—	—																		
Barometric Pressure (in Hg)	29.85	29.85																		
Ambient Air Temp (OF)	—	—																		
Boiler Heat Rate (BTU/KW-hr)	—	—																		
Burner Tilt	—	—																		
Inlet Temp (OF)	257.52	257.52																		
Outlet Temp (OF)	—	—																		
Inlet Pressure (in H2O)	2.2	2.2																		
Rapping Cycle Period (min)	—	—																		
Spark Rate (sparks/min)	0	0																		
Operating Voltage (KV)	—	—																		
Operating Amps	—	—																		

PRECIP
A B
100 0
320 0
255 0
13 0
43 0
120 0

IN? C-EM? OUT? IN? IN?

Parameters	1346	1455							
Boiling-Water Temp (OF)	51	51							
Boiler Air Inlet Temp (OF)	567	565							
Boiler Flue Gas Exit Temp (OF)	217/210	217/210							
D. Fan Pressure Rise (in H2O)	35	36							
D. Fan Current (amps)	315/300	308/300							
D. Fan Voltage (V)									
D Fan Pressure Rise (in H2O)									
D Fan Current (amps)									
D Fan Voltage (V)									
Forced Draft Inlet Air Temp (OF)									
Ambient Air Relative Humidity									
Barometric Pressure (in Hg)	29.87								
Ambient Air Temp (OF)	42								
Boiler Heat Rate (BTU/KW-hr)									
Burner Tilt									
Inlet Temp (OF)	200/155	217/350							
Outlet Temp (OF)									
Inlet Pressure (in H2O)	9.2	7.3							
Trapping Cycle Period (min)									
Spark Rate (sparks/min)	10								
Operating Voltage (KV)									
Operating Amps									

7 REC II

IN VOLT
ERRATIC
OUT

IN DC
ERRATIC
OUT

100
340
255

erratic
0

erratic
0

erratic
0

erratic
0

erratic
0

APPENDIX D

SAMPLE CALCULATIONS

SAMPLE CALCULATIONS

NOTE: All equations used in these calculations are found in the Federal Register, Vol. 36, No. 247, dated December 23, 1971.

Calculations representative of Test #1.

1. Dry Gas Volume

$$\begin{aligned} V_{mstd} &= \left(17.71 \frac{^{\circ}R}{\text{in.Hg.}} \right) V_m \left(\frac{P_{\text{bar}} + \frac{\Delta H}{13.6}}{T_m} \right) && \text{eq. 5-1} \\ &= \left(17.71 \frac{^{\circ}R}{\text{in.Hg.}} \right) 37.605 \text{ ft}^3 \left(\frac{29.92 \text{ in.Hg.} + \frac{1.279 \text{ In. H}_2\text{O}}{13.6}}{511.4 \text{ } ^{\circ}R} \right) \\ &= 39.087 \text{ ft}^3 \end{aligned}$$

2. Volume of Water Vapor

$$\begin{aligned} V_{wstd} &= \left(0.0474 \frac{\text{ft}^3}{M} \right) V_{lc} && \text{eq. 5-2} \\ &= \left(0.0474 \frac{\text{ft}^3}{M} \right) 60.2 \text{ ml} \\ &= 2.853 \text{ ft}^3 \end{aligned}$$

3. Moisture Content

$$\begin{aligned} B_{ws} &= \frac{V_{wstd}}{V_{wstd} + V_{mstd}} \\ &= \frac{2.853 \text{ ft}^3}{2.853 \text{ ft}^3 + 39.087 \text{ ft}^3} \\ &= 0.068 \times 100\% = 6.8\% \end{aligned}$$

4. Molecular Weight (dry)

$$\begin{aligned} M_d &= 0.44 (\% \text{CO}_2) + 0.32 (\% \text{O}_2) \\ &\quad + 0.28 (\% \text{N}_2) + 0.28 (\% \text{CO}) \quad \text{eq. 3-2} \\ &= 0.44 (11.91) + 0.32 (6.57) + 0.28 (81.52) \\ &\quad + 0.28 (0.00) \\ &= 30.17 \text{ lb/lb-mole} \end{aligned}$$

5. Molecular Weight (wet)

$$\begin{aligned} M_s &= M_d (1 - B_{ws}) + 18 B_{ws} \\ &= 30.17 (1 - .068) + 18 (.068) \\ &= 29.34 \text{ lb/lb-mole} \end{aligned}$$

6. Stack Gas Velocity

$$\begin{aligned} V_s &= K_p C_p \sqrt{\Delta P} \left(\frac{T_s}{P_s \times M_s} \right)^{1/2} \quad \text{eq. 2-2} \\ &= (85.48) (.86) (1.129) \left(\frac{710}{29.88 \times 29.34} \right)^{1/2} \\ &= 74.70 \text{ F.P.S.} \end{aligned}$$

7. Gas Volumetric Flow Rate, ACFM

$$\begin{aligned} \text{ACFM} &= V_s \times A_s \times 60 \text{ sec/min} \\ &= 74.70 \times 130.5 \text{ ft}^2 \times 60 \text{ sec/min} \\ &= 584,901 \text{ ACFM} \end{aligned}$$

8. Gas Volumetric Flow Rate, SCFM

$$\begin{aligned} Q_s &= 60 (1 - B_{ws}) V_s A_s \left(\frac{T_{std}}{T_s} \right) \left(\frac{P_s}{P_{std}} \right) \quad \text{ea. 2-3} \\ &= 60 (1 - .068) (74.70) (130.5) \left(\frac{530}{710} \right) \left(\frac{29.88}{29.92} \right) \\ &= 406,382 \text{ SCFM} \end{aligned}$$

9. Gas Volumetric Flow Rate, lb/hr

$$\begin{aligned} W_s &= Q_s \times \frac{60 \text{ min}}{\text{hr}} \times \frac{M_d}{386 \text{ ft}^3} \\ &= 406,382 \text{ SCFM} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{30.17 \text{ lb/lb-mole}}{386 \text{ ft}^3} \\ &= 1,905,784 \text{ lb/hr} \end{aligned}$$

10. Particulate Concentrations, gr/SCF

$$\begin{aligned} C's &= \left(0.0154 \frac{\text{gr}}{\text{mg}} \right) \frac{M_n}{V_{mstd}} && \text{eq. 5-4} \\ &= \left(0.0154 \frac{\text{gr}}{\text{mg}} \right) \frac{76.4 \text{ mg}}{39.087 \text{ ft}^3} \\ &= 0.030 \text{ gr/SCF} \end{aligned}$$

11. Particulate Concentrations, lb/ft³

$$\begin{aligned} C_s &= \frac{\left(\frac{1}{453600} \frac{\text{lb}}{\text{mg}} \right) M_n}{V_{mstd}} && \text{eq. 5-5} \\ &= \frac{\left(\frac{1}{453600} \frac{\text{lb}}{\text{mg}} \right) 76.4 \text{ mg}}{39.087 \text{ ft}^3} \\ &= 4.30 \times 10^{-6} \text{ lb/SCF} \end{aligned}$$

12. Particulate Concentrations, lb/hr

$$\begin{aligned} C_w &= C_s Q_s \times \frac{60 \text{ min}}{\text{hr}} \\ &= (4.30 \times 10^{-6} \text{ lb/SCF}) (406,382 \text{ SCFM}) \frac{60 \text{ min}}{\text{hr}} \\ &= 104.85 \text{ lb/hr} \end{aligned}$$

13. Particulate Concentrations, lb/MBTU

$$\begin{aligned}
 E_r &= \frac{C_w}{\text{Heat Input}} \\
 &= \frac{104.85 \text{ lb/hr}}{1805.3 \times 10^6 \text{ BTU/hr}} \\
 &= 0.058 \text{ lb/MBTU}
 \end{aligned}$$

14. % Isokinetic Sampling

$$I = \frac{\overline{Ts} \left(\frac{1.667 \text{ min}}{\text{sec}} \right) \left(\frac{V_{lc}}{V_s} + \frac{V_m}{T_m} \left(P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6} \right) \right)}{\ominus \quad V_s \quad P_s \quad A_n} \quad \text{eq. 5-6}$$

$$\begin{aligned}
 I &= \frac{710 (1.667) \left(\frac{(0.00267) (60.2)}{(60) (74.70) (29.88)} + \frac{37.605}{511.4} \left(29.92 + \frac{1.279}{13.6} \right) \right)}{(0.0001916)} \\
 &= 109.2\%
 \end{aligned}$$

15. NO_x Concentrations, lb/hr

$$\begin{aligned}
 \text{lb/hr} &= \text{PPM} \times \frac{M_w (\text{NO}_2)}{M_d} \times W_s \\
 &= \frac{255}{10^6} \times \frac{46 \text{ lb/lb-mole}}{30.17 \text{ lb/lb-mole}} \times 1,905,784 \frac{\text{lb}}{\text{hr}} \\
 &= 741.0 \text{ lb/hr}
 \end{aligned}$$

16. NO_x Concentrations, lb/MBTU

$$\begin{aligned}
 \text{lb/MBTU} &= \frac{\text{lb/hr}}{\text{Heat Input}} \\
 &= \frac{741.0 \text{ lb/hr}}{1805.3 \times 10^6 \text{ BTU/hr}} \\
 \text{lb/MBTU} &= \frac{0.410 \text{ lb}}{10^6 \text{ BTU}}
 \end{aligned}$$

17. Stack Pressure (Absolute) in.Hg.

$$P_s = P_b + \frac{P_d}{13.6} = 29.92 + \frac{(-0.6)}{13.6} = 29.88 \text{ in.Hg.}$$

18. Nozzle Area (ft²)

$$A_n = \pi D^2/4 = 0.785 (0.1875/12)^2 = 1.916 \times 10^{-4} \text{ ft}^2$$

19. Stack Area (ft²)

$$A_s = \pi D^2/4 = 0.785 (154.75/12)^2 = 130.5 \text{ ft}^2$$

20. Heat Input, MBTU

$$\begin{aligned} & \text{Sp. Gr.} \times 8.33 \text{ lb/gal} \times \text{BTU/lb} \times \text{gal/hr} \\ & 0.909 \times 8.33 \times 19.452 \times 12.257 = 1805.3 \text{ MBTU/hr} \end{aligned}$$

21. Gas Density, lb/ft³

$$\begin{aligned} \text{Gas Density} &= \frac{\text{Mol wt gas (md)}}{386 \text{ ft}^3} \times \frac{T_{\text{std}}}{T_s} \times \frac{P_{\text{bar}}}{P_{\text{std}}} \\ &= \frac{30.17}{386} \times \frac{530 \text{ }^\circ\text{R}}{710} \times \frac{29.92}{29.92} = 0.058 \text{ lb/ft}^3 \end{aligned}$$

THE UNITED ILLUMINATING COMPANY

SOURCE TESTING CALCULATION FORMS

Test No. Bridgeport Harbor Stack #2 No. Runs 3

Name of Firm The United Illuminating Company

Location of Plant 10 Henry Street, Bridgeport, Connecticut

Type of Plant Steam Generating Station

Control Equipment Electrostatic Precipitator

Sampling Point Locations Stack

Pollutants Sampled Particulates, Nitrogen Oxides

Time of Particulate Test:

Run No. <u>1</u>	Date <u>12/11/73</u>	Begin <u>10:10</u>	End <u>11:19</u>
Run No. <u>2</u>	Date <u>12/11/73</u>	Begin <u>12:08</u>	End <u>13:20</u>
Run No. <u>3</u>	Date <u>12/11/73</u>	Begin <u>13:43</u>	End <u>14:47</u>

PARTICULATE EMISSION DATA

Run No.	1	2	3
$K_p = 35.48 \frac{ft}{sec} \left(\frac{lb.}{lb\ mole \cdot ^\circ R} \right)^{1/2}$	85.48	85.48	85.48
$C_o =$ Pitot tube coefficient (calib.)	0.86	0.86	0.86
$\bar{V}_{AP} =$ Average velocity head of stack gas, inches H ₂ O	1.129	1.207	1.190
$\bar{T}_s =$ Average stack temp., °R	710	710	710
$P_b =$ Barometric pressure, "Hg Abs.	29.92	29.85	29.87
$P_d =$ Gas duct pressure, "H ₂ O	-0.6	-0.6	-0.6
$P_s =$ Absolute stack gas pressure, inches Hg	29.88	29.81	29.83
$w_{s,w} =$ % moisture in stack gas, by volume	6.8	8.4	7.1
$M_d =$ Molecular weight of stack gas, dry	30.17	30.15	30.14
$M_s =$ Molecular weight of stack gas	29.34	29.13	29.28

Run No.	1	2	3	Average
V_s = Stack gas velocity, F.P.S.	74.70	80.23	78.87	
% CO ₂	11.91	11.77	11.71	
% O ₂	6.57	6.66	6.69	
% CO	0.00	0.00	0.00	
% N ₂	81.52	81.57	81.60	
V_{lc} = Total volume of liquid collected in impingers and silica gel, ml.	60.2	78.9	66.5	
V_m = Volume of dry gas sampled at meter conditions, FT ³	37.605	38.724	39.009	
V_{std} = Volume of dry gas sampled at STP, FT ³	39.087	40.616	40.946	
T_m = Average dry gas meter temp., °R	511.4	505.8	505.7	
ΔH = Average pressure drop across orifice, inches H ₂ O	1.279	1.438	1.397	
θ = Total Sampling Time, min.	60	60	60	
D_n = Nozzle dia., inches	0.1875	0.1875	0.1875	
A_n = Nozzle area, FT ² x 10 ⁻⁴	1.916	1.916	1.916	
I = % of isokinetic sampling	109.2	107.8	108.9	
Q_s = Stack gas volume at STP (SCFM)	406,382	427,969	426,971	420,441
Q_a = Stack gas volume at stack conditions (ACFM)	584,901	628,201	617,552	610,218
W_s = Stack gas mass flow lbs/hr	1905784	2005689	2000348	1970607
M_p = Particulate-probe, washings, mg	-	-	-	
M_f = Particulate-filter (mg)	-	-	-	
M_n = Particulate-total (mg)	76.4	51.6	59.5	
C 's = Particulate Concentrations gr/scf	0.030	0.020	0.022	0.024
C_w = Particulate total emission lb/hr	104.85	71.90	81.98	86.24
E_r = Particulate emission rate, lb/10 ⁶ BTU	0.058	0.040	0.045	0.05
C = NO _x concentrations, PPM	255	252	246	251
C_n = NO _x lb/10 ⁶ BTU	0.410	0.426	0.416	0.42

#46

OARPS-78-1
7615-II-I 264

FUEL
OIL COMBUSTION
AP-42 Section 1.3
Reference Number
24

4/93 Ref 21

Emission Test Report
English Station Stack No. 3
Steam Generator Nos. 7, 9, 11

~~1953~~ - 1937 1941 1941

The United Illuminating Company
English Station
510 Grand Avenue
New Haven, Connecticut
06505

Approved by:

E. W. Somerville *E. W. Somerville*
Vice President, Engineering and Planning

Submitted by:

M. R. McCraven *M. R. McCraven*
Director of Environmental Engineering

Emission Test Report

English Station Stack No. 3
Steam Generator Nos. 7, 9, 11
(Ref. "Intent to Test" Form Number 720052)

Test Conducted By
The United Illuminating Company
Development and Test Laboratory
80 Temple Street
New Haven, Connecticut
06506

United Illuminating Company Personnel Present

J. Sombati
J. Hotchkiss
J. Macknis
M. Collins

and by
York Research Corporation
One Research Drive
Stamford, Connecticut
06906

York Research Corporation Personnel Present

R. Larkin
J. Kittrell

Prepared by:

J. S. Sombati *J. S. Sombati*
Development & Test Laboratory Supervisor

J. W. Hotchkiss *John W. Hotchkiss*
Assistant Mechanical Engineer

Checked by:

J. F. Crowe *J. F. Crowe*
Chief Mechanical Engineer

Test Results

English Station Steam Generator
Nos. 7, 9, 11

Test Conducted on
December 26, 27, 1973.

Introduction

Emission tests for particulates and nitrogen oxides were conducted as required by Connecticut State Law on The United Illuminating Company English Station Steam Generator Nos. 7, 9 and 11, stack No. 3 located in New Haven, Connecticut. Testing was conducted on December 26 and 27, 1973.

Particulate testing was performed in accordance with test methods and procedures as prescribed in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. Testing was performed by York Research Corporation of Stamford, Connecticut, using a sampling train as described in Appendix A.

Nitrogen oxide emission testing was performed by the United Illuminating Company Development and Test Laboratory using a Dynascience Model P-101 NO_x Analyzer. Field data is included in Appendix B.

Tests were also conducted to determine stack gas velocity, moisture content, and flue-gas analysis. The procedures used in determining these various parameters, except for flue gas analysis, are those found in the above mentioned Federal Register. The stack flue gas was analyzed by using an Analytical Instrument Development Model 512 Portable Gas Chromatograph.

York Research Corporation was retained to perform particulate tests, together with a preliminary velocity traverse, moisture determination, and fuel oil analysis. The United Illuminating Company was responsible for the flue gas analysis, nitrogen oxide analysis, and for accumulating boiler operating data.

This test report includes the information required for Item Nos. III, IV, V, VI, VII, VIII, IX, X, XI, XII, and XIII from the Department of Environmental Protection's Intent to Test form in compliance with the Department of Environmental Protection's new Source Test Guidelines and Procedures, (received April 3, 1973).

1. Sampling Train Information

(Ref. Item VIII, "Intent To Test" Form)

- a. Schematic Diagram and description of sampling train:

See Appendix A.

- b. Media type used to determine gas stream components:

1. NO_x: Dynascience Model P-101 NO_x Analyzer
2. Particulates: Tared glass fiber filter.
3. Flue Gas Analysis: Analytical Instrument Development Model 512 Portable Gas Chromatograph

- c. Sampling Probes:

1. NO_x: Stainless steel tube
2. Particulates: See Appendix A.
3. Flue Gas Analysis: Stainless steel tube.

- d. Probe Cleaning Method

See Appendix A

2. Field Data Sheets

(Ref. Item IX, "Intent To Test" Form)

See Appendices A, B, C, D.

3. Description of Operation

(Ref. Item X, "Intent To Test" Form)

The operation tested was English Station steam generator numbers 7, 9, and 11, stack 3, Registration Number E.S. 7, 9, and 11, stack 3, having a total BTU/hr rating of 381.8 MBTU (averaged over test period), burning No. 6 residual fuel oil at an average rate of 2585 gal/hr and having a gas flow of 159,264 ACFM average for the test period. See Table IV for fuel oil analysis.

4. Sampling Area Description
(Ref. Item XI, "Intent To Test" Form)

Emission Sampling was performed in the stack 135 feet above the stack foundation (7 stack diameters above the breeching inlet and 2 stack diameters down from the top). Emission sampling was performed using four 4" diameter sampling ports spaced 90° apart on the stack circumference. A total of twenty sampling points (5 per sampling port) were used in the test for particulates. The inside diameter of the stack at the sampling location was found to be 14'-7-1/4" I.D.

a. Stack Configuration:

See Appendix A

b. Sampling Port Location:

See Appendix A

c. Sampling Point Position:

See Appendix A

5. Stack and Vent Description
(Ref. Item XII, "Intent To Test" Form)

Three Babcock and Wilcox cross drum inclined tube boilers discharge flue gas into two ducts which enter the base of the stack 180° apart on the stack circumference. These boilers do not have any precipitators or other stack cleaning apparatus connected to the flue gas ducts.

6. Operational Parameters
(Ref. Item XIII, "Intent To Test" Form)

Electric utility steam generator burning No. 6 residual fuel oil having rated capacities as registered.

TABLE I

SUMMARY OF TEST RESULTS

STEAM GENERATORS 7, 9, 11

STACK NO. 3

<u>Point</u>	<u>Sampling Duration</u>		<u>Number of Tests</u>	<u>Measured Concentrations</u>	<u>Method Employed to Determine Concentration</u>
	<u>Minutes per point</u>	<u>Total Test Time</u>			
		15 min.	3	0.23 lb/10 ⁶ BTU	Dynascience Model P-101
<u>Temperature</u>	5	100 min.	3	0.03 lb/10 ⁶ BTU	Method 5*
<u>Moisture</u>	5	100 min.	3	8.7%	Method 4*
<u>Analysis</u>		15 min.	3	39% Excess Air	A.I.D. Model 512 Portable Gas Chromatograph
<u>Velocity</u>	1/2	15 min.	3	0.03" to 0.07" H ₂ O**	Method 2*

*Federal Register, Volume 36, No. 247, December 23, 1971

** Range of S-Type Pitot-Tube Differential

TABLE II

SUMMARY OF RESULTS

STEAM GENERATORS 7, 9, 11

STACK NO. 3

Test	<u>1</u>	<u>2</u>	<u>3</u>	<u>Average</u>
Date	12/26/73	12/27/73	12/27/73	
Stack Flow, ACFM	154,878	164,621	158,293	159,264
Stack Flow, SCFM	82,588	87,963	84,277	84,943
Stack Flow, lb/hr	385,284	409,780	391,823	395,629
% Excess O ₂ at Test Point	7.51	7.78	8.09	7.79
Particulate Emissions				
gr/SCF	0.014	0.013	0.015	0.014
lb/hr	9.81	9.87	10.57	10.08
lb/MBTU	0.02	0.03	0.03	0.03
Nitrogen Oxide Emission				
ppm	138	138	150	142
lb/hr	81.5	86.8	90.4	86.2
lb/MBTU	0.20	0.23	0.25	0.23

Handwritten notes:
 150 ppm x 1 lb / 2600 ft³ = 0.014 gr/SCF
 138 ppm x 1 lb / 2600 ft³ = 0.013 gr/SCF
 150 ppm x 1 lb / 2600 ft³ = 0.015 gr/SCF
 Average = 137 ppm

TABLE III

AVERAGE BOILER OPERATING DATA FOR TEST PERIODS

STEAM GENERATORS 7, 9, 11

STACK 3

	<u>1</u>	<u>2</u>	<u>3</u>
Test			
Date	12/26/73	12/27/73	12/27/73
Steam Flow (avg. total) lb/hr	291,660	273,300	258,300
Oil Flow (avg. total) gal/hr	2754	2562	2440
Heat Input (avg. total) MBTU/hr	406.0	378.6	360.7
Stack Gas Temperature °F	450	450	450
Gas Density, lb/ft ³	0.046	0.045	0.045

FUEL OIL ANALYSIS

STEAM GENERATORS 7, 9, 11

STACK NO. 3

Test	<u>1</u>	<u>2</u>	<u>3</u>
Date	12/26/73	12/27/73	12/27/73
	<u>Composition (% by Weight)</u>		
Carbon	86.40	86.37	86.37
Hydrogen	12.30	12.35	12.35
Nitrogen	<0.1	<0.1	<0.1
Ash	0.022	0.017	0.017
Sulfur	0.378	0.366	0.366
Specific Gravity	0.910	0.912	0.912
BTU/lb	19,447	19,451	19,451
BTU/gal	147,414	147,768	147,768

APPENDIX A

PARTICULATE TEST

V. SAMPLING METHODS

1. Port Location

All test ports are located in the stack and the number of points sampled were calculated on the guidelines in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. Enough points were used to assure accurate measurement of particulate emissions, temperature, and velocity over the cross-sectional area of each stack. (See Figures 2,4,6 and 8.)

2. Velocity and Temperature

Velocity was determined by pitot tube in accordance with Western Precipitation Company Bulletin "WP-50". An S-type Pitot Tube (2) and thermocouple (3) are rigidly attached to the sampling probe (See Figure 9). A preliminary velocity traverse was made to establish isokinetic sampling rates using EPA Method 5 sampling techniques.

3. Flue Gas Analysis

Gas analysis for CO₂ and O₂ was conducted by the UI using an Orsat apparatus. Readings for each test are reported in the Summary of Results.



4. Particulate Sampling Methods - EPA Method 5

The sampling apparatus consisted of a nine (9) foot probe heated filter, four impingers, dry gas meter, vacuum pump, and calibrated orifice as shown in Figure 9. The stainless steel, button-hook type probe tip (1) was equipped with a 5/8 inch diameter fitting connected by a stainless steel coupling with asbestos packing to the probe. The probe consisted of 1/2 inch inside diameter medium-wall stainless steel tube with a ground steel joint on one end. The probe was logarithmically wound from the entrance end with 26-gauge nickel-chromium wire. During sampling, the wire was connected to a variable transformer to maintain a gas temperature of 300°F in the probe. The wire wound tube was wrapped with fiber glass tape and encased in a 1-inch-OD stainless steel tube for protection. The end of the steel tube that does not have the ball-joint protruding has a nut welded to it for connection to the stainless steel coupling used to attach the nozzle. The probe connects to a very coarse fritted glass filter holder (4) which holds a tared glass fiber filter. The filter holder was contained in an electrically heated enclosed box (5) which is thermostatically maintained at a minimum temperature of 250-300°F to prevent water condensation. Attached to the heated box was an ice bath (7) containing four impingers connected in series with vacuum hose. The first impinger (8) receives the gas stream from the filter. This impinger is of the Greenburg-Smith design modified by replacing the tip with a 1/2 inch ID glass tube extending to 0.5 inch from the bottom of the flask. This impinger was initially filled with 100 milliliters of distilled water. The second impinger (9) is a Greenburg-Smith impinger with tip, and also filled with 100 milliliters of distilled water. The third impinger (10) modified like the first, with no water. The fourth impinger (11) is also a Greenburg-Smith type modified like the first and contained 300 grams of dry indicating silica gel.

From the fourth impinger the effluent stream flows through a dial thermometer (12), a check valve (13); flexible rubber vacuum tubing (14); vacuum gauge (15); a valve (16); a leakless vacuum pump (17), rated at 4 cubic feet per minute at 0 inches of mercury gauge pressure and 0 cubic feet per minute at 26 inches of mercury gauge pressure, and connected in parallel with a bypass needle valve (18); and a dry gas meter rated at .1 cubic foot per revolution (19). A calibrated orifice (20) completes the train and was used to measure instantaneous meter flow rates. The three thermometers (12) are dial type with a range of 25° to 125°F. A fourth thermometer in the heated portion of the box has a range up to 500°F. The dual manometer (21) across the calibrated orifice is an inclined-vertical type graduated in hundredths of an inch of water from 0 to 1.0 inch and in tenths from 1 to 10 inches.



5. Test Procedure

Prior to the start of a test series for each stack, the pressure, temperature, and range of velocity pressures were determined during preliminary pitot tube and temperature traverse.

During each test the following readings were taken at each point:

1. Point Designation
2. Clock Time
3. Dry gas meter reading (CF)
4. Velocity head (ΔP in inches water)
5. Desired pressure drop across orifice (ΔH in inches water)
6. Actual pressure drop across orifice (ΔH in inches water)
7. Dry gas temperature ($^{\circ}F$) gas meter inlet.
8. Dry gas temperature ($^{\circ}F$) gas meter outlet.
9. Vacuum pump gauge reading (in. Hg).
10. Filter box temperature ($^{\circ}F$)
11. Dry gas temperature ($^{\circ}F$) at the discharge of last impinger.
12. Stack temperature ($^{\circ}F$)

The relationship of ΔP reading with the ΔH reading is a function of the following variables:

1. Orifice calibration factor
2. Gas meter temperature
3. % moisture in the flue gas
4. Ratio of flue gas pressure to barometric pressure
5. Stack temperature
6. Sampling nozzle diameter

A nomograph was used to correlate all the above variables such that a direct relationship between ΔP and ΔH could be determined by the sampler within fifteen seconds and isokinetic conditions maintained throughout the test.

6. Basic Laboratory Procedure

The following paragraph briefly describes the methods used in the laboratory to obtain the raw data used in the calculations of our results as reported in Section III of this report.

The clean up is done in the field according to EPA test procedure. The filters were previously tare weighed and recorded at the laboratory. Upon return they are dried, cooled in a dessicator, then weighed on an analytical balance and the amount of particulate collected is the difference in the two weights. The particulate wash solution (taken from the train in front of the filter) is placed in a tared beaker, the wash solution is evaporated with and Infra-Red Heat Lamp and the beaker weighed



again. The difference in weight is the weight of the particulate in the wash. This is combined with the filter catch as the weight of the sample.

The impinger condensate is measured for moisture determination.

7. Calibration


The equipment used on this assignment was calibrated one week prior to field testing and re-calibrated upon equipment return after testing. York Research calibration is traceable to the National Bureau of Standards.



TEST TEAM

Robert J. Larkin
James R. Kittrell

Prepared By:



Robert J. Larkin
Test Engineer

Reviewed By:



Robert S. Epstein
Project Director

Approved By:




Roy S. Uggall
Manager-Engineering Services



SAMPLING TRAIN

Figure No. 9



Pitot Tube Calibration

ΔP_{std}	ΔP_s	$\frac{\Delta P_{std}}{\Delta P_s}$	F_s
.06	.08	.750	.866
.20	.28	.714	.845
.38	.53	.717	.847
.62	.91	.681	.825
.72	1.03	.699	.836

$$F_s = \sqrt{\frac{\Delta P_{std}}{\Delta P_s}}$$

Pitot Tube # 14

$F_s =$.84

$F_{std} = 1.00$

Calibrated by *R. L. [Signature]*
 Date 12/12/73

Oil ok
 Quick Connects ok Valves ok
 Meters ok
 Test Meter _____
 Meters ok
 _____ ok
 Physical Check - Amphenol ok
 _____ ok
 Gauge ok
 Check at 27" hg. - OK CF

Initial each item when checked and write in any remarks.
 Calibration - Orifice and Meter

11/5/73 Box No. 51563 P_b 29.9

CF _w	CF _d	T _w	IT _d	OT _d	T _d Avg.	Time t
5	5.15	67	85	75	80	12.23
5	5.06	67	85.5	77.6	87.5	9.012
10	10.16	68	88.8	79.5	84.1	13.2
10	10.63	68	89.0	79.6	84.3	93.06
10	10.05	68	92.8	80.3	86.5	7.67
10						

Calculate Y & H_g at man. 2:0

$$Y = \frac{CF_w P_b (T_d \text{ avg.} + 460)}{CF_d (P_b + 0.147 (T_w + 460))}$$

$$Y = \frac{(C + 0.147) (C + 460)}{0.0634 P_b (OT_d + 460) \left(\frac{(T_w + 460)}{CF_w} \right)^2}$$

$$\Delta H_g = \frac{0.0634}{(C + 460) \left(\frac{(C + 460)t}{CF_w} \right)^2}$$


Tolerances

$$Y = 0.99 - 1.00 - 1.01$$

$$\Delta H_g = 1.6 - 1.84 - 2.1$$

ΔH_0	P_b	$(T_w + 460) t^2$	CF_w	Man. II@
0.317 (Man. Orifice)	$P_b (OT_d + 460)$	$(T_w + 460) t^2$	CF_w	
$\Delta H_0 =$	0.01585	$(67 + 460) \frac{12.2}{.5}$	$(67 + 460) \frac{12.2}{.5}$	1.78
$\Delta H_0 =$	$29.9 (75 + 460)$	$(67 + 460) \frac{90.12}{1.0}$	5	1.77
$\Delta H_0 =$	0.0317	$(68 + 460) \frac{13.2}{2.0}$	10	1.90
$\Delta H_0 =$	$29.9 (79.5 + 460)$	$(68 + 460) \frac{93.06}{4.0}$	10	1.89
$\Delta H_0 =$	0.1268	$(68 + 460) \frac{7.67}{6.0}$	10	1.93
$\Delta H_0 =$	$29.9 (29.6 + 460)$	$(68 + 460) \frac{7.67}{6.0}$	10	1.93
$\Delta H_0 =$	0.1902	$(68 + 460) \frac{7.67}{6.0}$	10	1.93
$\Delta H_0 =$	$29.9 (80.3 + 460)$	$(68 + 460) \frac{7.67}{6.0}$	10	1.93
$\Delta H_0 =$	0.2536	$(68 + 460) \frac{7.67}{6.0}$	10	1.93

$Y =$	$CF_d P_b + \frac{Man. Orifice}{13.6} (T_w + 460)$	Man.
$CF_w P_b (T_d \text{ avg.} + 460)$		
$Y =$	$5 \times 29.9 (80 + 460)$.5
$Y =$	$5.15 (29.9 + 0.0368) (67 + 460)$	
$Y =$	$5 \times 29.9 (81.5 + 460)$	1.0
$Y =$	$5.06 (29.9 + 0.0737) (67 + 460)$	
$Y =$	$10 \times 29.9 (84.1 + 460)$	2.0
$Y =$	$10.16 (29.9 + 0.147) (68 + 460)$	
$Y =$	$10 \times 29.9 (84.3 + 460)$	4.0
$Y =$	$10.03 (29.9 + 0.294) (68 + 460)$	
$Y =$	$10 \times 29.9 (86.5 + 460)$	6.0
$Y =$	$10.05 (29.9 + 0.431) (68 + 460)$	
$Y =$	$\frac{10}{10} \times (\quad + 460)$	8.0



FIELD DATA

PLANT U.T. English Sta.
 DATE 12/24/73
 SAMPLING LOCATION Stack B3
 SAMPLE TYPE PET.
 RUN NUMBER 1
 OPERATOR DWL + JAL
 AMBIENT TEMPERATURE 50
 BAROMETRIC PRESSURE 30.08
 STATIC PRESSURE (P₁) 12.0
 FILTER NUMBER (S) FL-183

50 ml H₂O net

SCHEMATIC OF TRAVERSE POINT LAYOUT

READ AND RECORD ALL DATA EVERY 5 MINUTES


PROBE LENGTH AND TYPE 9' SS
 NOZZLE I.D. 3/8" .375
 ASSUMED MOISTURE % 10
 SAMPLE BOX NUMBER 5-1563
 METER BOX NUMBER 1-90
 METER A/F 1.90
 C FACTOR 1.0
 PRONE HEATER SETTING 100%
 HEATER BOX SETTING 100%
 REFERENCE AP 15

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (V _m , ft ³)	VELOCITY HEAD (ΔP), in. H ₂ O	ORIFICE PRESSURE DIFFERENTIAL (ΔH), in. H ₂ O		STACK TEMPERATURE (T _g), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	HEATER TEMPERATURE, °F
				DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F			
E 1	1355	55.930	.06	.72	.72	450	62	62	5.0	280-320	< 70
A 2	1400	58.30	.06	.72	.72	450	63	71	5.0		
S 3	1405	60.51	.05	.60	.60	450	64	73	4.5		
T 4	1410	62.66	.03	.37	.37	450	66	74	3.5		
S 5	1415	64.40	.03	.37	.37	450	68	76	3.5		
Ewd 1	1420	66.14				450	66	72	5.0		
W 1	1423	66.14	.06	.72	.72	450	66	72	5.0		
e 2	1428	68.50	.06	.72	.72	450	68	76	5.0		
S 3	1433	70.72	.04	.48	.48	450	64	78	4.5		
T 4	1438	72.66	.03	.37	.37	450	70	78	4.5		
S 5	1443	74.32	.03	.37	.37	450	72	75	3.5		
Ewd 1	1448	75.92	.05	.60	.60	450	69	70	4.5		
W 1	1451	75.92	.05	.60	.60	450	70	72	4.5		
o 2	1456	78.08	.05	.60	.60	450	70	73	4.5		
c 3	1501	80.14	.05	.60	.60	450	72	75	4.0		
T 4	1506	82.30	.04	.48	.48	450	72	75	4.0		
S 5	1511	84.18	.04	.48	.48	450	71	77	4.0		
Ewd 1	1516	86.15	.06	.72	.72	450	70	71	5.0		
S 1	1520	86.15	.06	.72	.72	450	70	72	4.5		
a 2	1525	88.55	.05	.60	.60	450	71	72	4.5		
u 3	1530	90.61	.05	.60	.60	450	71	74	4.5		
T 4	1535	92.70	.03	.37	.37	450	73	75	3.5		
H 5	1540	94.28	.03	.37	.37	450	73	77	3.5		
H 5	1545	95.94									

COMMENTS:

ES-041

FIELD DATA



PLANT U.T. (English Stn)
 DATE 12/27/73
 SAMPLING LOCATION Stack #3
 SAMPLE TYPE Part
 RUN NUMBER 2
 OPERATOR TRR + RWL
 AMBIENT TEMPERATURE 55
 BAROMETRIC PRESSURE 30.01
 STATIC PRESSURE (PS) -2.20
 FILTER NUMBER(S) FL-501


H_2O collected = 80 mL

PROBE LENGTH AND TYPE 8' SS
 NOZZLE I.D. 3/8" .375
 ASSUMED MOISTURE % 10
 SAMPLE BOX NUMBER S-1563
 METER BOX NUMBER 5-1563
 METER AH 190
 C FACTOR 100%
 PROBE HEATER SETTING 100%
 HEATER BOX SETTING 100%
 REFERENCE AD 15

SCHEMATIC OF TRAVERSE POINT LAYOUT

READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (V.M.) H ³	VELOCITY HEAD (adj.) in. H ₂ O	ORIFICE PRESSURE DIFFERENTIAL (AH) in. H ₂ O		STACK TEMPERATURE (T _s) °F	DRY GAS METER TEMPERATURE (T _m in. °F)		PUMP VACUUM in. Hg	SAMPLE BOX TEMPERATURE °F	IMPINGER TEMPERATURE °F
				DESIRED	ACTUAL		INLET	OUTLET			
E 1	1018	2.794	.07	.85	.85	450	63	63	4	250-300	<70
A 2	1023	5.74	.06	.72	.72	↓	64	68			
S 3	1028	9.06	.05	.60	.60	↓	64	69			
T 4	1033	10.10	.04	.48	.48		66	70			
S 5	1038	12.80	.03	.37	.37		66	69			
END	1043	13.735									
M 1	1047	13.235	.06	.72	.72	450	66	66			
E 2	1052	16.10	.07	.82	.82	↓	67	66			
S 3	1057	18.58	.05	.60	.60	↓	70	68			
T 4	1103	20.49	.04	.48	.48		70	67			
S 5	1107	22.62	.03	.37	.37		69	67			
END	1112	24.350									
N 1	1118	24.350	.05	.60	.60	450	64	64			
O 2	1123	26.40	.07	.85	.85	↓	69	65			
R 3	1128	28.88	.06	.72	.72	↓	71	69			
T 4	1133	31.16	.04	.48	.48		73	70			
M 5	1138	33.10	.03	.37	.37		73	70			
END	1143	34.725									
S 1	1144	34.725	.06	.72	.72	450	70	68			
O 2	1147	37.55	.07	.85	.85	↓	73	70			
S 3	1154	39.03	.06	.72	.72		74	70			
T 4	1159	41.85	.05	.60	.60		73	70			
M 5	1204	44.44	.03	.37	.37		73	70			
COMMENTS:	1209	46.210									



PLANT U.I. (English Stn)
 DATE 12/27/73
 SAMPLING LOCATION Stack #3
 SAMPLE TYPE part
 RUN NUMBER 3
 OPERATOR RWL + TRR
 AMBIENT TEMPERATURE 55
 BAROMETRIC PRESSURE 30.60
 STATIC PRESSURE (PSI) 1.20
 FILTER NUMBER(S) EL-578



H₂O Collected
= 70 mL NET

PROBE LENGTH AND TYPE 9' SS
 NOZZLE I.D. 3/8" .675"
 ASSUMED MOISTURE % 10
 SAMPLE BOX NUMBER 5-1563
 METER BOX NUMBER 1-90
 METER A.H. 1.60
 C FACTOR 100%
 PROBE HEATER SETTING 100%
 HEATER BOX SETTING 100%
 REFERENCE DP 1.5

SCHEMATIC OF TRAVERSE POINT LAYOUT
 READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (m ³)	VELOCITY HEAD (app. in. H ₂ O)	ORIFICE PRESSURE DIFFERENTIAL (AH), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
				DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F			
W 1	12:35	46.210	.06	.72	.72	450	67	67	5.0	250-300	<70
e 2	12:40	48.50	.06	.72	.72	↓	70	68	↓		
S 3	12:45	50.70	.05	.60	.60	↓	72	69	↓		
T 4	12:50	52.73	.04	.48	.48		73	70			
S 5	12:55	54.57	.03	.37	.37						
END	13:00	56.455									
H 1	13:02	56.455	.06	.72	.72	450	73	70			
O 2	13:03	59.06	.06	.72	.72	↓	74	71			
R 3	13:12	61.06	.04	.48	.48		74	71			
T 4	13:17	63.10	.04	.48	.48		74	70			
H 5	13:22	65.08	.03	.37	.37						
END	13:27	66.688									
E 1	13:31	66.658	.06	.72	.72	450	74	76			
A 2	13:36	69.20	.06	.72	.72	↓	74	77			
S 3	13:41	71.34	.04	.48	.48		83	78			
T 4	13:46	73.70	.03	.37	.37		85	78			
S 5	13:51	75.64	.03	.37	.37		84	76			
END	13:56	77.101									
S 1	14:01	77.101	.06	.72	.72	450	76	76			
O 2	14:06	79.58	.06	.72	.72	↓	76	76			
T 3	14:11	81.74	.04	.48	.48		76	75			
T 4	14:16	83.90	.04	.48	.48		74	74			
W 5	14:21	85.94	.04	.48	.48		74	73			
W 5	14:26	88.080									

COMMENTS:



TRAVERSE POINT No.	DISTANCE FROM WALL
5	4.4'
4	14.4'
3	25.6'
2	39.7'
1	60.0'

DRAWN BY P.L.S. DATE 3-21-74
 CHECKED BY T.M.H. DATE 4-1-74
 APPROVED BY T.M.H. DATE 7-21-73
 SCALE NONE DRAWING NO.

REVERSED
 THE UNITED ILLUMINATING CO.
 NEW HAVEN, CONN.
 STACK CO. SPECIFICATION AND
 SAMPLING POINT LOCATION
 STACK No. 3
 ENGLISH STATION

APPENDIX B

NITROGEN OXIDE TEST

FLUE GAS ANALYSIS

THE UNITED ILLUMINATING COMPANY
ORSAT DATA & CALCULATION SHEET

Identification Number SPICK 3

Date DEC 26, 1973

Order Number 7-9-11

Time 1500

Location English

Sampling Point Location STACK

TEST 1

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt/mole (dry)
O ₂ , % Vol (dry)	10.60	10.70	10.50		10.70	44/100	4.708
CO, % Vol (dry)	0	0	0		0.00	28/100	+0.000
CO ₂ , % Vol (dry)	7.54	7.48	7.50		7.51	32/100	+2.403
H ₂ , % Vol (dry)	81.86	81.82	81.68		81.79	28/100	+23.901
Avg. molecular wt. of dry stack gas =							30.01

THE UNITED ILLUMINATING COMPANY
ORSAT DATA & CALCULATION SHEET

Identification Number STACK 3 Date Dec. 27, 1973

Order Number 7-9-11 Time 1150

Plant Location English

Sampling Point Location STACK

TEST 2

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt/mole (dry)
CO ₂ , % Vol (dry)	10.34	10.28	10.40		10.34	44/100	4.55
O ₂ , % Vol (dry)	0	0	0			28/100	+
N ₂ , % Vol (dry)	7.88	7.72	7.75		7.78	32/100	+ 2.19
Ar, % Vol (dry)	81.78	82.00	81.85		81.88	28/100	+ 22.93
Avg. molecular wt. of dry stack gas =							29.97


TEST NO. 1

calibrate
480 ppm
70% 2:20 PM
Dec. 26/1973
Stack # 3

English Station
Stack No 3
Test 1
12/26/73

calibrate
400 ppm
70% 2:20 PM
Dec. 26/1973
Stack # 3

English Station
Stack No 3
Test 1
12/26/73



RECALIB.

1440

1435


1428

TEST 1
NOX
STACK 3

02X512
02X256

02X512

Test #1
Stack #3
3 Eff. 1973
Dec 26, 1973




02X512

02X256

02X512

Calibrat

English Station
Stack No 3
Test 1
12/26/73



COH23

A2X512

O2X256

CO2X512

Calibrate

A2X512

O2X256

CO2X256

Sample 1-3
Test II
5 peak #9

A2X512

O2X256

CO2X256

Test II
Sample 1-2
5 peak #9


TEST NO. 2

Calibration check

Zero check

Nox
calibrate
70% 400 ppm
11:25 AM '73
Test 2 Stack 3
12/27/73

English Station
Stack No 3
Test 2
12/27/73



N2 512

O2 X 256


CO X 512


Orsat Calibrate
11:50 AM
Test 2
12/27/79

NOX
Sample 11:45 AM
Test 2

Re Calibrate

int





TEST NO. 3

Nox Sample
1:30-1:45 PM


Calibrate

Nox SAMPLE III @ 1:35 Test 3 stack 3 1:30 PM

Nox
cal. 5%
70% 400 ppm

ECPO
check

English station
Stack No 3
Test 3
12/27/73



Sample 3-1
Steel 3

COX 288

COX 512


COX 256

COX 512

COX 256

COX 512

Calibrate
Test 3
2.66 ppm
Steel 3



APPENDIX C

BOILER OPERATING DATA

BOILER CONDITIONS

STACK ID NUMBER

STACK 3

DATE DEC 26, 1973

BOILER NO. 7-9-11

TEST NO. 1

PLANT English Sta

PARAMETERS	1415	1523	1608				
METER (GAL) TONLS	9590157	9590633	95910045				
STEAM HEADR PRESS.	1	3.4	3.2				
FUEL OIL HEADR PRESS.	192	184	187				
BOILER # 7 WINDBOX Press %	17	2.0	2.0				
OIL FLOW %	68	68	72				
AIR FLOW %	10	71	71				
STEAM FLOW %/hr	95,500	96,050	100,000				
Barometer	30.08	30.08	30.08				
BOILER # 9 WINDBOX Press %	2.9	2.7	3.0				
OIL FLOW %	75	70	78				
AIR FLOW %	77	78	78				
STEAM FLOW %/hr	103,000	100,000	105,000				
MS RECIRC OIL PRESS	5653839	6105433	66651101				
BOILER # 11 WINDBOX Press %	3.4	3.4	3.4				
OIL FLOW %	75	72	80				
AIR FLOW %	76	76	76				

STACK ID NUMBER

SYNOPSIS 3

DATE DEC 22, 19

BOILER NO.

10-11

TEST NO. 2

PLANT

English

PARAMETERS	1009	1126	1223				
OIL METER (CAL)	75961906	75767568	9577170				
LP STEAM HEADER PRESS.	364	349	364				
LP FUEL OIL HEADER PRESS.	185	187	186				
LP BOILER # 7 WINDBOX PRESS. "H ₂ O"	1.9	1.7	1.9				
OIL FLOW %	68	65	65				
AIR FLOW %	70	70	70				
STEAM FLOW ^{lb/hr}	87,000	90,500	87,000				
Recirc Header	8692040	8094331	81091032				
LP BOILER # 9 WINDBOX PRESS. "H ₂ O"	2.9	2.9	3.0				
OIL FLOW %	75	72	71				
AIR FLOW %	76	79	79				
STEAM FLOW ^{lb/hr}	104,000	102,000	98,000				
BYPASS METER	30.01	30.00	29.96				
LP BOILER # 11 WINDBOX PRESS. "H ₂ O"	3.1	3.1	3.2				
OIL FLOW %	72	69	72				
AIR FLOW %	74	75	75				

BOILER CONDITIONS

STACK ID NUMBER _____

STACK 3

DATE DEC 27, 1973

BOILER NO. _____

7-9-11

TEST NO. 3

PLANT _____

English

PARAMETERS	1223	1334	1433				
METER (GAL)	75971640	95971720	75800536				
STEAM HEADER PRESS.	364	370	358				
FUEL OIL HEADER PRESS.	186	187	187				
BOILER # 7 WINDBOX PRESS. "	1.9	1.9	2.6				
OIL FLOW %	65	64	48				
AIR FLOW %	70	70	60				
STEAM FLOW ^{lb/hr}	87,000	93,000	68,000				
Recirc Motor	8091032	8097971	8609742				
BOILER # 9 WINDBOX PRESS. "	5.0	29	34				
OIL FLOW %	71	70	58				
AIR FLOW %	79	78	64				
STEAM FLOW ^{lb/hr}	98,000	105,000	75,000				
Barometer	29.96	30.00	30.00				
P BOILER # 11 WINDBOX PRESS. "	3.2	3.0	3.0				
OIL FLOW %	72	70	65				
	75	75	70				

APPENDIX D

SAMPLE CALCULATIONS

NOTE: All equations used in these calculations are found in the Federal Register, Vol. 36, No. 247, dated December 23, 1971.

Calculations representative of Test #1.

1. Dry Gas Volume

$$\begin{aligned}
 V_{mstd} &= \left(17.71 \frac{^{\circ}R}{\text{in. Hg}} \right) V_m \left(\frac{P_{\text{bar}} + \frac{\Delta H}{13.6}}{T_m} \right) && \text{eq. 5-1} \\
 &= \left(17.71 \frac{^{\circ}R}{\text{in. Hg}} \right) 40.01 \text{ ft}^3 \left(\frac{30.08 \text{ in. Hg} + \frac{0.540 \text{ in. H}_2\text{O}}{13.6}}{531.3 \text{ }^{\circ}R} \right) \\
 &= 40.170 \text{ ft}^3
 \end{aligned}$$

2. Volume of Water Vapor

$$\begin{aligned}
 V_{wstd} &= \left(0.0474 \frac{\text{ft}^3}{\text{ml.}} \right) V_{lc} && \text{eq. 5-2} \\
 &= \left(0.0474 \frac{\text{ft}^3}{\text{ml.}} \right) 83.2 \text{ ml.} \\
 &= 3.944 \text{ ft}^3
 \end{aligned}$$

3. Moisture Content

$$\begin{aligned}
 B_{ws} &= \frac{V_{wstd}}{V_{wstd} + V_{mstd}} && \text{eq. 5-3} \\
 &= \frac{3.944 \text{ ft}^3}{3.944 \text{ ft}^3 + 40.170 \text{ ft}^3} \\
 &= 0.089 \times 100\% = 8.9\%
 \end{aligned}$$

$$M_d = 0.44 (\% \text{ CO}_2) + 0.32 (\% \text{ O}_2) + 0.28 (\% \text{ N}_2) + 0.28 (\% \text{ CO}) \quad \text{eq. 3-2}$$

$$= 0.44 (10.70) + 0.32 (7.51) + 0.28 (81.79) + 0.28 (0.00)$$

$$= 30.01 \text{ lb/lb-mole}$$

5. Molecular Weight (wet)

$$M_s = M_d (1 - B_{ws}) + 18 B_{ws}$$

$$= 30.01 (1 - 0.089) + 18 (0.089)$$

$$= 28.94 \text{ lb/lb-mole}$$

6. Stack Gas Velocity

$$V_s = K_p C_p \sqrt{\Delta P} \left(\frac{T_s}{P_s M_s} \right)^{1/2} \quad \text{eq. 2-2}$$

$$= (85.48) (.84) (.210) \left(\frac{910}{30.07 \times 28.94} \right)^{1/2}$$

$$= 15.42 \text{ F.P.S.}$$

7. Gas Volumetric Flow Rate, ACFM

$$\text{ACFM} = V_s \times A_s \times 60 \text{ sec/min}$$

$$= 15.42 \times 167.4 \text{ ft}^2 \times 60 \text{ sec/min}$$

$$= 154,878 \text{ ACFM}$$

8. Gas Volumetric Flow Rate, SCFM

$$Q_s = 60 (1 - B_{ws}) V_s A_s \left(\frac{T_{std}}{T_s} \right) \left(\frac{P_s}{P_{std}} \right) \quad \text{eq. 2-3}$$

$$= 60 (1 - 0.089) (15.42) (167.4) \left(\frac{530}{910} \right) \left(\frac{30.07}{29.92} \right)$$

$$= 82,588 \text{ SCFM}$$

$$W_s = \frac{Q_s \times 60 \text{ min}}{\text{hr}} \times \frac{\text{Mn}}{386 \text{ ft}^3}$$

$$= 82,588 \text{ SCFM} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{30.01 \text{ lb/lb-mole}}{386 \text{ ft}^3}$$

$$= 385,284 \text{ lb/hr}$$

10. Particulate Concentrations, gr/SCF

$$C's = \left(0.0154 \frac{\text{gr.}}{\text{mg.}} \right) \left(\frac{\text{Mn}}{V_{\text{mstd}}} \right) \quad \text{eq. 5-4}$$

$$= \left(0.0154 \frac{\text{gr.}}{\text{mg.}} \right) \frac{36.1 \text{ mg.}}{40.17 \text{ ft}^3}$$

$$= 0.0138 \text{ gr/SCF}$$

11. Particulate Concentrations, lb/ft³

$$C_s = \frac{\left(\frac{1}{453600} \frac{\text{lb.}}{\text{mg.}} \right) \text{ Mn}}{V_{\text{mstd}}} \quad \text{eq. 5-5}$$

$$= \frac{\left(\frac{1}{453600} \frac{\text{lb.}}{\text{mg.}} \right) 36.1 \text{ mg.}}{40.17 \text{ ft}^3}$$

$$= 1.98 \times 10^{-6} \text{ lb/SCF}$$

12. Particulate Concentrations, lb/hr

$$C_w = C_s Q_s \times \frac{60 \text{ min}}{\text{hr}}$$

$$= (1.98 \times 10^{-6} \text{ lb/SCF}) (82,588 \text{ SCFM}) \frac{60 \text{ min}}{\text{hr}}$$

$$= 9.81 \text{ lb/hr}$$

13. Particulate Concentrations, lb/MBTU

$$E_r = \frac{C_w}{\text{Heat Input}}$$

$$= \frac{9.81 \text{ lb/hr}}{406.0 \times 10^6 \text{ BTU/hr}}$$

$$= 0.024 \text{ lb/MBTU}$$

14. % Isokinetic Sampling

$$I = \frac{\bar{T}_s (1.667 \frac{\text{min}}{\text{sec}}) \left((0.00267) V_{lc} + \frac{V_m}{T_m} \left(P_{\text{bar}} + \frac{\Delta H}{13.6} \right) \right)}{\ominus V_s P_s A_n}$$

eq. 5-6

$$I = \frac{910 (1.667) \left((0.00267) (83.2) + \frac{40.01}{531.3} \left(30.08 + \frac{0.540}{13.6} \right) \right)}{(100) (15.42) (30.07) (7.666 \times 10^{-4})}$$

$$= 106.3\%$$

15. NO_x Concentrations, lb/hr

$$\text{lb/hr} = \frac{\text{PPM} \times M_w (\text{NO}_2) \times W_s}{M_d}$$

$$= \frac{138}{10^6} \times \frac{46 \text{ lb/lb-mole}}{30.01 \text{ lb/lb-mole}} \times 385,284 \frac{\text{lb}}{\text{hr}}$$

$$= 81.5 \text{ lb/hr}$$

16. NO_x Concentrations, lb/MBTU

$$\text{lb/MBTU} = \frac{\text{lb/hr}}{\text{Heat Input}}$$

$$= \frac{81.5 \text{ lb/hr}}{406.0 \times 10^6 \text{ BTU/hr}}$$

$$= \frac{0.201 \text{ lb}}{10^6 \text{ BTU}}$$

17. Stack Pressure (Absolute), in. Hg

$$P_s = P_b + \frac{P_d}{13.6} = 30.08 + \frac{(-0.20)}{13.6} = 30.07 \text{ in. Hg.}$$

18. Nozzle Area (Ft²)

$$A_n = \frac{\pi D^2}{4} = 0.785 \times (0.375/12)^2 = 7.666 \times 10^{-4} \text{ Ft.}^2$$

19. Stack Area (ft²)

$$A_s = \pi D^2/4 = 0.785 (175.25/12)^2 = 167.43 \text{ ft}^2$$

20. Heat Input MBTU

$$\text{Sp. Gr.} \times 8.33 \text{ lb/gal} \times \text{BTU/lb} \times \text{gal/hr}$$

$$0.910 \times 8.33 \times 19447 \times 2754 = 406.0 \times 10^6 \text{ BTU/hr.}$$

21. Gas Density lb/ft³

$$\text{Gas Density} = \frac{\text{Mol wt gas (md)}}{386 \text{ ft}^3} \times \frac{T_{\text{std}}}{T_s} \times \frac{P_{\text{bar}}}{P_{\text{std}}}$$

$$= \frac{30.01}{386} \times \frac{530^\circ\text{R}}{910} \times \frac{30.08}{29.92} = 0.046 \text{ lb/ft}^3$$

THE UNITED ILLUMINATING COMPANY
SOURCE TESTING CALCULATION FORMS

Test No. English Station #3

No. Runs 3

Name of Firm United Illuminating Company

Location of Plant 510 Grand Avenue, New Haven, Connecticut

Type of Plant Steam Generating Station

Control Equipment None

Sampling Point Locations Stack

Pollutants Sampled Particulates, Nitrogen Oxides

Time of Particulate Test:

Run No. <u>1</u>	Date <u>12/26/73</u>	Begin <u>1355</u>	End <u>1545</u>
Run No. <u>2</u>	Date <u>12/27/73</u>	Begin <u>1018</u>	End <u>1209</u>
Run No. <u>3</u>	Date <u>12/27/73</u>	Begin <u>1235</u>	End <u>1426</u>

PARTICULATE EMISSION DATA

Run No.	1	2	3
$K_p = 85.48 \frac{ft}{sec} \left(\frac{lb.}{lb\ mole \cdot ^\circ R} \right)^{\frac{1}{2}}$	85.48	85.48	85.48
$C_p =$ Pitot tube coefficient (calib.)	0.84	0.84	0.84
$\sqrt{VAP} =$ Average velocity head of stack gas, inches H ₂ O	0.210	0.223	0.214
$\bar{T}_s =$ Average stack temp., °R	910	910	910
$P_b =$ Barometric pressure, "Hg Abs.	30.08	30.01	30.00
$P_d =$ Gas duct pressure, "H ₂ O	-0.20	-0.20	-0.20
$P_s =$ Absolute stack gas pressure, inches Hg	30.07	30.00	29.99
$B_{ws} =$ % moisture in stack gas, by volume	8.9	8.5	8.8
$M_d =$ Molecular weight of stack gas, dry	30.01	29.97	29.91
$M_s =$ Molecular weight of stack gas	28.94	28.96	28.86

0A QPS-78-1
76/5-II-I 305

FUEL
OIL COMBUSTION
AP-42 Section 1.3
Reference Number
24

4/93 Ret 21

Emission Test Report

English Station Stack No. 1

Steam Generator Nos. 1, 3, 5

10
1984 1989

The United Illuminating Company
English Station
510 Grand Avenue
New Haven, Connecticut
06505

Approved by:

E. W. Somerville *E. W. Somerville*
Vice President, Engineering and Planning

Submitted by:

M. R. McCraven, *M. R. McCraven*
Director of Environmental Engineering

Emission Test Report

English Station Stack No. 1
Steam Generator Nos. 1, 3, 5
(Ref. "Intent to Test" Form Number 730060)

Test Conducted by
The United Illuminating Company
Development and Test Laboratory
80 Temple Street
New Haven, Connecticut
06506

United Illuminating Company Personnel Present

J. Sombati
J. Hotchkiss
J. Macknis
M. Collins

and by
York Research Corporation
One Research Drive
Stamford, Connecticut
06906

York Research Corporation Personnel Present

R. Larkin
J. Kittrell

Prepared by:

J. S. Sombati *J. S. Sombati*
Development & Test Laboratory Supervisor

J. W. Hotchkiss *J. W. Hotchkiss*
Assistant Mechanical Engineer

Checked by:

J. F. Crowe *J. F. Crowe*
Chief Mechanical Engineer

Test Results

English Station Steam Generator
Nos. 1, 3, 5

Test Conducted on
December 13, 14, 1973.

Introduction

Emission tests for particulates and nitrogen oxides were conducted as required by Connecticut State Law on The United Illuminating Company English Station Steam Generator Nos. 1, 3, and 5, stack No. 1 located in New Haven, Connecticut. Testing was conducted on December 13 and 14, 1973.

Particulate testing was performed in accordance with test methods and procedures as prescribed in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. Testing was performed by York Research Corporation of Stamford, Connecticut, using a sampling train as described in Appendix A.

Nitrogen oxide emission testing was performed by the United Illuminating Company Development and Test Laboratory using a Dynascience Model P-101 NO_x Analyzer. Field data is included in Appendix B.

Tests were also conducted to determine stack gas velocity, moisture content, and flue-gas analysis. The procedures used in determining these various parameters, except for flue gas analysis, are those found in the above mentioned Federal Register. The stack flue gas was analyzed by using an Analytical Instrument Development Model 512 Portable Gas Chromatograph.

York Research Corporation was retained to perform particulate tests, together with a preliminary velocity traverse, moisture determination, and fuel oil analysis. The United Illuminating Company was responsible for the flue gas analysis, nitrogen oxide analysis, and for accumulating boiler operating data.

This test report includes the information required for Item Nos. III, IV, V, VI, VII, VIII, IX, X, XI, XII, and XIII from the Department of Environmental Protection's Intent to Test form in compliance with the Department of Environmental Protection's new Source Test Guidelines and Procedures, (received April 3, 1973).

TABLE I

SUMMARY OF TEST RESULTS

STEAM GENERATORS 1, 3, 5

STACK NO. 1

<u>Component</u>	<u>Sampling Duration</u>		<u>Number of Tests</u>	<u>Measured Concentrations</u>	<u>Method Employed to Determine Concentration</u>
	<u>Minutes per point</u>	<u>Total Test Time</u>			
1) NO _x		15 min.	3	0.30 lb/10 ⁶ BTU	Dynascience Model P-101
2) Particu- late	5	100 min.	3	0.03 lb/10 ⁶ BTU	Method 5*
3) Moisture	5	100 min.	3	8.3%	Method 4*
4) Gas Analysis		15 min.	3	36% Excess Air	A.I.D. Model 512 Portable Gas Chromatograph
5) Velocity	1 1/2	15 min.	3	0.03" to 0.12" H ₂ O **	Method 2*

*Federal Register, Volume 36, No. 247, December 23, 1971

** Range of S-Type Pitot-Tube Differential

TABLE II

SUMMARY OF RESULTS

STEAM GENERATORS 1, 3, 5

STACK NO. 1

	<u>1</u>	<u>2</u>	<u>3</u>	<u>Average</u>
Test Date	12/13/73	12/13/73	12/14/73	
Stack Flow, ACFM	196,242	217,800	200,976	205,006
Stack Flow, SCFM	105,819	116,594	106,997	109,803
Stack Flow, lb/hr	494,608	545,334	499,948	513,297
% Excess O ₂ at Test Point	7.22	7.22	7.25	7.23
Particulate Emissions				
gr/SCF	0.013	0.013	0.015	0.014
lb/hr.	11.49	13.02	13.55	12.69
lb/MBTU	0.03	0.03	0.03	0.03
Nitrogen Oxide Emission				
ppm	165	165	171	167
lb/hr	125.1	137.6	130.8	131.2
lb/MBTU	0.30	0.30	0.30	0.30

Part: 12.7 lb/hr
 295702.2 lb
 103 gal

NO_x: 131.6 lb/hr
 45.4 lb
 103 gal

No controls

TABLE III

AVERAGE BOILER OPERATING DATA FOR TEST PERIODSSTEAM GENERATORS 1, 3, 5.STACK 1

	<u>1</u>	<u>2</u>	<u>3</u>
Test Date	12/13/73	12/13/73	12/14/73
Steam Flow (avg. total) lb/hr	331,650	337,660	331,330
Oil Flow (avg. total) gal/hr	2947	2957	2959
Heat Input (avg. total) MBTU/hr	440.0	441.5	441.5
Stack Gas temperature °F	443.8	446.5	443.5
Gas Density, lb/ft ³	0.0457	0.0456	0.0451

TABLE IV

FUEL OIL ANALYSIS

STEAM GENERATORS 1, 3, 5

STACK 1

Test	<u>1</u>	<u>2</u>	<u>3</u>
Date	12/13/73	12/13/73	12/14/73
	<u>Composition (% by Weight)</u>		
Carbon	86.73	86.73	86.65
Hydrogen	12.31	12.31	12.48
Nitrogen	<0.1	<0.1	<0.1
Ash	0.015	0.015	0.014
Sulfur	0.45	0.45	0.46
Specific Gravity	0.903	0.903	0.903
BTU/lb	19,847	19,847	19,835
BTU/gal.	149,289	149,289	149,199

1. Sampling Train Information
(Ref. Item VIII, "Intent To Test" Form)

a. Schematic Diagram and description of sampling train:

See Appendix A.

b. Media type used to determine gas stream components:

1. NO_x: Dynascience Model P-101 NO_x Analyzer

2. Particulates: Tared glass fiber filter.

3. Flue Gas Analysis: Analytical Instrument Development Model 512 Portable Gas Chromatograph

c. Sampling Probes :

1. NO_x: Stainless steel tube.

2. Particulates: See Appendix A

3. Flue Gas Analysis: Stainless steel tube.

d. Probe Cleaning Method:

See Appendix A

2. Field Data Sheets
(Ref. Item IX, "Intent to Test" Form)

See Appendices A, B, C, D.

3. Description of Operation
(Ref. Item X, "Intent to Test" Form)

The operation tested was English Station steam generator numbers 1, 3, and 5, stack 1, Registration Number E.S. 1, 3 and 5, stack 1, having a total BTU/hr. rating of 441.0 MBTU (averaged over test period), burning No. 6 residual fuel oil at an average rate of 2954 gal/hr. for all three boilers, and having a gas flow of 205,006 ACFM average for the test period. See Table IV for fuel oil analysis.

4. Sampling Area Description
(Ref. Item XI, "Intent to Test" Form)

Emission sampling was performed in the stack 135 feet above the stack foundation (7 stack diameters above the breeching inlet and 2 stack diameters down from the top). Emission sampling was performed using four 4" diameter sampling ports spaced 90° apart on the stack circumference. A total of twenty sampling points (5 per sampling port) were used in the test for particulates. The inside diameter of the stack at the sampling location was found to be 14'-7-1/2" I.D.

a. Stack Configuration

See Appendix A

b. Sampling Port Location

See Appendix A.

c. Sampling Point Position

See Appendix A.

5. Stack and Vent Descriptions
(Ref. Item XII, "Intent to Test" Form)

Three Babcock and Wilcox cross drum inclined tube boilers discharge flue gas into two ducts which enter the base of the stack 180° apart on the stack circumference. These boilers do not have any precipitators or other stack cleaning apparatus connected to the flue gas ducts.

6. Operational Parameters
(Ref. Item XIII, "Intent to Test" Form)

Electric utility steam generator burning No. 6 residual fuel oil having rated capacities as registered.


APPENDIX A

PARTICULATE TEST

TEST TEAM


Robert J. Larkin
James R. Kittrell

Prepared By:



Robert J. Larkin
Test Engineer

Reviewed By:



Robert S. Epstein
Project Director

Approved By:



Roy S. Egge
Manager-Engineering Services



V. SAMPLING METHODS

1. Port Location

All test ports are located in the stack and the number of points sampled were calculated on the guidelines in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. Enough points were used to assure accurate measurement of particulate emissions, temperature, and velocity over the cross-sectional area of each stack. (See Figures 2,4,5 and 8.)

2. Velocity and Temperature

Velocity was determined by pitot tube in accordance with Western Precipitation Company Bulletin "WP-50". An S-type Pitot Tube (2) and thermocouple (3) are rigidly attached to the sampling probe (See Figure 9). A preliminary velocity traverse was made to establish isokinetic sampling rates using EPA Method 5 sampling techniques.

3. Flue Gas Analysis

Gas analysis for CO₂ and O₂ was conducted by the UI using an Orsat apparatus. Readings for each test are reported in the Summary of Results.

4. Particulate Sampling Methods - EPA Method 5

The sampling apparatus consisted of a nine (9) foot probe heated filter, four impingers, dry gas meter, vacuum pump, and calibrated orifice as shown in Figure 9. The stainless steel, button-hook type probe tip (1) was equipped with a 5/8 inch diameter fitting connected by a stainless steel coupling with asbestos packing to the probe. The probe consisted of 1/2 inch inside diameter medium-wall stainless steel tube with a ground steel joint on one end. The probe was logarithmically wound from the entrance end with 26-gauge nickel-chromium wire. During sampling, the wire was connected to a variable transformer to maintain a gas temperature of 300°F in the probe. The wire wound tube was wrapped with fiber glass tape and encased in a 1-inch-OD stainless steel tube for protection. The end of the steel tube that does not have the ball-joint protruding has a nut welded to it for connection to the stainless steel coupling used to attach the nozzle. The probe connects to a very coarse fritted glass filter holder (4) which holds a tared glass fiber filter. The filter holder was contained in an electrically heated enclosed box (5) which is thermostatically maintained at a minimum temperature of 250-300°F to prevent water condensation. Attached to the heated box was an ice bath (7) containing four impingers connected in series with vacuum hose. The first impinger (8) receives the gas stream from the filter. This impinger is of the Greenburg-Smith design modified by replacing the tip with a 1/2 inch ID glass tube extending to 0.5 inch from the bottom of the flask. This impinger was initially filled with 100 milliliters of distilled water. The second impinger (9) is a Greenburg-Smith impinger with tip, and also filled with 100 milliliters of distilled water. The third impinger (10) modified like the first, with no water. The fourth impinger (11) is also a Greenburg-Smith type modified like the first and contained 300 grams of dry indicating silica gel.

From the fourth impinger the effluent stream flows through a dial thermometer (12), a check valve (13); flexible rubber vacuum tubing (14); vacuum gauge (15); a valve (16); a leakless vacuum pump (17), rated at 4 cubic feet per minute at 0 inches of mercury gauge pressure and 0 cubic feet per minute at 26 inches of mercury gauge pressure, and connected in parallel with a bypass needle valve (18); and a dry gas meter rated at .1 cubic foot per revolution (19). A calibrated orifice (20) completes the train and was used to measure instantaneous meter flow rates. The three thermometers (12) are dial type with a range of 25° to 125°F. A fourth thermometer in the heated portion of the box has a range up to 500°F. The dual manometer (21) across the calibrated orifice is an inclined-vertical type graduated in hundredths of an inch of water from 0 to 1.0 inch and in tenths from 1 to 10 inches.

5. Test Procedure

Prior to the start of a test series for each stack, the pressure, temperature, and range of velocity pressures were determined during preliminary pitot tube and temperature traverse.

During each test the following readings were taken at each point:

1. Point Designation
2. Clock Time
3. Dry gas meter reading (CF)
4. Velocity head (ΔP in inches water)
5. Desired pressure drop across orifice (ΔH in inches water)
6. Actual pressure drop across orifice (ΔH in inches water)
7. Dry gas temperature ($^{\circ}F$) gas meter inlet.
8. Dry gas temperature ($^{\circ}F$) gas meter outlet.
9. Vacuum pump gauge reading (in. Hg).
10. Filter box temperature ($^{\circ}F$)
11. Dry gas temperature ($^{\circ}F$) at the discharge of last impinger.
12. Stack temperature ($^{\circ}F$)

The relationship of ΔP reading with the ΔH reading is a function of the following variables:

1. Orifice calibration factor
2. Gas meter temperature
3. % moisture in the flue gas
4. Ratio of flue gas pressure to barometric pressure
5. Stack temperature
6. Sampling nozzle diameter

A nomograph was used to correlate all the above variables such that a direct relationship between ΔP and ΔH could be determined by the sampler within fifteen seconds and isokinetic conditions maintained throughout the test.

6. Basic Laboratory Procedure

The following paragraph briefly describes the methods used in the laboratory to obtain the raw data used in the calculations of our results as reported in Section III of this report.

The clean up is done in the field according to EPA test procedure. The filters were previously tare weighed and recorded at the laboratory. Upon return they are dried, cooled in a dessicator, then weighed on an analytical balance and the amount of particulate collected is the difference in the two weights. The particulate wash solution (taken from the train in front of the filter) is placed in a tared beaker, the wash solution is evaporated with and Infra-Red Heat Lamp and the beaker weighed

again. The difference in weight is the weight of the particulate in the wash. This is combined with the filter catch as the weight of the sample.


The impinger condensate is measured for moisture determination.

7. Calibration

The equipment used on this assignment was calibrated one week prior to field testing and re-calibrated upon equipment return after testing. York Research calibration is traceable to the National Bureau of Standards.

SAMPLING TRAIN

Figure No. 9



York Research Corporation

Pitot Tube Calibration

ΔP_{std}	ΔP_s	$\frac{\Delta P_{std}}{\Delta P_s}$	F_s
.06	.08	.750	.866
.20	.28	.714	.845
.38	.53	.717	.847
.62	.91	.681	.825
.72	1.03	.699	.836

$$F_s = \sqrt{\frac{\Delta P_{std}}{\Delta P_s}}$$

Pitot Tube # 14

$F_s =$.84

$F_{std} = 1.00$

Calibrated by 

Date 12/12/73

Oil OK
 Quick Connects OK Valves OK
 Meters OK
 Test Meter _____
 Thermometers OK
 S _____ OK
 Electrical Check - Amphenol OK
 Ice _____ OK
 Vacuum Gauge _____ OK
 Check at 27" hg. - OK CF
 Checks _____

Label each item when checked and write in any remarks.

Calibration - Orifice and Meter

11/5/73 Box No. 51563 P_b 29.9

Orifice	CF _w	CF _d	T _w	IT _d	OT _d	T _d Avg.	Time t
.5	5	5.15	67	85	75	80	12.73
.0	5	5.06	67	85.5	77.6	87.15	9.012
.0	10	10.16	68	88.8	79.5	84.1	13.2
.0	10	10.03	68	89.0	79.6	84.3	93.06
.0	10	17.05	68	92.8	80.3	86.5	7.67
.0	10						

Calculate Y & H_g at man. 2:0

$$Y = \frac{CF_w P_b (T_d \text{ avg.} + 460)}{CF_d (P_b + 0.147 (T_w + 460))}$$

$$\Delta H_g = \frac{0.0634}{P_b (OT_d + 460)} \left(\frac{(T_w + 460)}{CF_w} \right)^2$$

$$\Delta H_g = \frac{0.0634}{(T_w + 460)} \left(\frac{(T_w + 460)t}{CF_w} \right)^2$$

Tolerances

$$Y = 0.99 - \frac{1.00}{1.00} - 1.00$$

$$\Delta H_g = 1.6 - \frac{1.84}{1.84} - 2.1$$

0.317 (Man. Orifice)

$$\left(\frac{(T_w + 460)t}{CF_w} \right)^2$$

Man. H@

P_b (OT_d + 460)

CF_w

0.01585

$$\left(\frac{(67 + 460)}{12.2} \right)^2$$

.5

1.78

29.9 (75 + 460)

5

0.0317

$$\left(\frac{(67 + 460)}{90.12} \right)^2$$

1.0

1.77

29.9 (77.6 + 460)

5

0.0634

$$\left(\frac{(68 + 460)}{13.2} \right)^2$$

2.0

1.90

29.9 (79.5 + 460)

10

0.1268

$$\left(\frac{(68 + 460)}{93.06} \right)^2$$

4.0

1.89

29.9 (72.6 + 460)

10

0.1902

$$\left(\frac{(68 + 460)}{7.67} \right)^2$$

6.0

1.93

29.9 (80.3 + 460)

10

0.2536

$$\left(\frac{\quad + 460}{\quad} \right)^2$$

Calibration Calculations Meter and Pump Box

Date 11/5/73 Box No. 5156

CF_w P_b (T_d avg. + 460)

Man.

Y =

CF_d P_b + $\frac{\text{Man. Orifice}}{13.6}$ (T_w + 460)

$$Y = \frac{5 \times 29.9}{5.15} \left(\frac{80}{29.9} + 0.0368 \right) (67 + 460)$$

.5

$$Y = \frac{5 \times 29.9 (81.5 + 460)}{5.06} \left(\frac{29.9}{29.9} + 0.0737 \right) (67 + 460)$$

1.0

$$Y = \frac{10 \times 29.9 (84.1 + 460)}{10.16} \left(\frac{29.9}{29.9} + 0.147 \right) (68 + 460)$$

2.0

$$Y = \frac{10 \times 29.9 (84.3 + 460)}{10.03} \left(\frac{29.9}{29.9} + 0.294 \right) (68 + 460)$$

4.0

$$Y = \frac{10 \times 29.9 (86.5 + 460)}{10.05} \left(\frac{29.9}{29.9} + 0.431 \right) (68 + 460)$$

6.0

$$Y = \frac{\quad \times \quad}{\quad} \left(\frac{\quad}{\quad} + 460 \right)$$

8.0

PLANT 4E English st.
 DATE 12/11/73
 SAMPLING LOCATION Stack
 SAMPLE TYPE Particulate
 RUN NUMBER 1
 OPERATOR J.K.S.
 AMBIENT TEMPERATURE 40
 BAROMETRIC PRESSURE 29.99
 STATIC PRESSURE (PS) 2.22
 FILTER NUMBER(S) EL-3015




PROBE LENGTH AND TYPE 9' SS
 NOZZLE I.D. 3/8" = .375
 ASSUMED MOISTURE 10
 SAMPLE BOX NUMBER S-1163
 METER AMPL. 1.10
 CF FACTOR 2.4
 PROBE HEATER SETTING 1000 W
 HEATER BOX SETTING 1000 W
 REFERENCE SP 15

86ml H₂O net

SCHEMATIC OF TRAVERSE POINT LAYOUT
 READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (V _m), ft ³	VELOCITY HEAD (ΔP ₁), in. H ₂ O	ORIFICE PRESSURE DIFFERENTIAL (ΔH), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPIRGER TEMPERATURE, °F
				DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F			
S 1	1109	85.258	10	1.20	1.20	450	43	43	5	250-300	~70
2	1104	87.48	10	1.20	1.20	450	43	50	5	"	"
3	1119	89.82	10	1.20	1.20	450	43	53	5	"	"
4	1124	94.95	09	1.65	1.65	450	43	53	4.5	"	"
5	1129	97.20	06	2.2	2.2	440	43	49	4	"	"
END											
N 1	1137	94.56	11	1.30	1.30	445	44	42	5	"	"
2	1142	102.82	10	1.30	1.30	445	47	42	5	"	"
3	1147	105.59	09	1.65	1.65	445	47	43	4.5	"	"
4	1152	108.23	06	2.2	2.2	445	47	43	4	"	"
5	1157	110.49	05	3.6	3.6	445	47	43	3.5	"	"
END											
N 1	1202	112.15	05	3.6	3.6	445	42	42	4	"	"
2	1210	113.15	07	3.4	3.4	445	42	42	4	"	"
3	1215	114.62	05	3.2	3.2	445	45	43	3.5	"	"
4	1220	117.02	04	4.2	4.2	420	42	43	3.5	"	"
5	1225	119.05	03	3.6	3.6	430	42	43	3.5	"	"
END											
E 1	1235	122.50	10	1.30	1.30	445	43	43	5	"	"
2	1243	125.55	09	1.65	1.65	445	43	43	4.5	"	"
3	1246	125.10	07	3.4	3.4	445	43	43	4	"	"
4	1253	130.50	05	2.2	2.2	445	49	43	4	"	"
5	1258	132.71	04	4.2	4.2	435	49	43	3	"	"

COMMENTS/NOTES 134, 528



PLANT 42 English St.
 DATE 12/14/73
 SAMPLING LOCATION Stack
 SAMPLE TYPE Particulate
 RUN NUMBER 5
 OPERATOR JRK
 AMBIENT TEMPERATURE 45
 BAROMETRIC PRESSURE 30.60
 STATIC PRESSURE (P_s) 36
 FILTER NUMBER(S) E1-609

PROBE LENGTH AND TYPE 9'-55
 NOZZLE I.D. 3/8" = .375
 ASSURED MOISTURE, % 10
 SAMPLE BOX NUMBER 5-1562
 METER BOX NUMBER 150
 METER DIA. 2.4
 C FACTOR 1.24
 PROBE HEATER SETTING 1220 Zc
 HEATER BOX SETTING 1220 Zc
 REFERENCE DP -.15

SCHMATIC OF TRAVERSE POINT LAYOUT

READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (m ³ , ft ³)	VELOCITY HEAD (60%), in. H ₂ O	ORIFICE DIFFERENTIAL (ΔH), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
				DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F			
51	0942	89.330	1.2	1.45	1.45	445	55	60	55	250-300	< 70
2	0947	93.53	1.0	1.20	1.20	445	5	65	5	"	"
3	0952	95.50	1.08	.96	.96	445	4	72	4	"	"
4	0957	98.11	1.07	.84	.84	445	4	73	4	"	"
5	1002	100.55	1.04	.47	.47	435	3	73	3	"	"
END	1007	103.44	-	-	-	-	-	-	-	-	-
N 1	1010	102.44	1.1	1.30	1.30	450	5	65	5	"	"
2	1015	105.42	1.0	1.30	1.20	445	5	75	5	"	"
3	1020	108.53	0.9	1.05	1.05	445	4	76	4	"	"
4	1025	110.13	1.02	.84	.84	445	4	78	4	"	"
5	1030	113.63	1.05	.54	.54	445	3.5	79	3.5	"	"
END	1035	115.737	-	-	-	-	-	-	-	-	-
N 1	1037	115.737	0.9	1.05	1.05	450	4.5	64	4.5	"	"
2	1042	118.51	1.07	.84	.84	445	4.5	67	4.5	"	"
3	1047	120.26	1.05	.54	.54	445	4.0	67	4.0	"	"
4	1052	123.09	1.05	.54	.54	445	4.0	67	4.0	"	"
5	1057	125.19	1.04	.47	.47	435	3.5	65	3.5	"	"
END	1102	127.13	-	-	-	-	-	-	-	-	-
E 1	1105	132.13	1.0	1.20	1.20	445	5	62	5	"	"
2	1110	130.08	0.9	1.05	1.05	445	5	62	5	"	"
3	1115	132.28	0.8	.86	.86	445	5	65	5	"	"
4	1120	135.41	1.0	.22	.22	445	4.5	67	4.5	"	"
5	1125	137.68	1.05	.54	.54	445	4	67	4	"	"

COMMENTS: 1130 139.50

APPENDIX B

NITROGEN OXIDE TEST

FLUE GAS ANALYSIS

THE UNITED ILLUMINATING COMPANY

ORSAT DATA & CALCULATION SHEET

Stack Identification Number STXK 1 Date DEC 13, 1973

Boiler Number 1-3-5 Time _____

Plant Location English Sta

Sampling Point Location Stack

TEST 1

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt/mole. (dry)	
CO ₂ , % vol (dry)	11.15	11.15	11.05		11.116	44/100	4.89	
CO, % vol (dry)	0	0	0			28/100	+	
O ₂ , % vol (dry)	7.17	7.17	7.32		7.220	32/100	+ 2.31	
N ₂ , % vol (dry)	81.68	81.68	81.63		81.663	28/100	+ 22.87	
Avg. molecular wt. of dry stack gas =								30.07

ORSAT DATA & CALCULATION SHEET

Stack Identification Number STICK 1Boiler Number 1-3-5Plant Location English StaSampling Point Location STICKDate DEC 13, 1973Time 1445TEST 2

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt/mole. (dry)	
CO ₂ , % Vol (dry)	11.29	11.29	11.18		11.253	44/100	4.95	
CO, % Vol (dry)	0	0	0			28/100	+	
O ₂ , % Vol (dry)	7.23	7.23	7.21		7.223	32/100	+ 2.31	
N ₂ , % Vol (dry)	81.48	81.48	81.61		81.523	28/100	+ 22.83	
Avg. molecular wt. of dry stack gas =							30.09	

TEST NO. 1

zero
check


sample
12:50 PM

calibrate

sample
1:50 PM
10/10/73

zero
check

calibrate
English STA
5 parts
Test 10/10/73



Sample 1-1
Stack I
Eng. Sta

02728

027512

02756


02752

02756


02751

Calibrate English Station
12:30 PM Stack I
Best 1


Sample 1-3
Test 1



Sample 1-2
Stack 1
Test 1



Sample 1-1
Stack I
E99
512



TEST NO. 2

Sample
1415 PM

calibrate

zero
check

1355 NOx Sample
TEST 2

English Sta
SMK 1 Test 2
12-13-73

Calibrat
14:55

Hy 1024

02X512

02X512

Sample # 203
Test 10

Hy 1024

02X512

02X512

Sample # 202
Test 10

02X512

02X512

02X512

02X512

02X512

02X512

02X512

CO # 28

Chart 105-0

Chart 105-0

Chart 105-0

12:52

CO # 256

CO # 512

Calibrate
14:55

12:00

Chart 105-0

TEST NO. 3

Calibrate
70% = 420 PPM

1130

1125

ReCalibrate
11:20

Sample
11:15

20%
check

70% = 420 PPM

6.9-
Calibrate
11:05 12/11/79
Test 3
Stack 4

1000000

1000000

1000000

13x5

02x256

02x512

Sample 3-1
2nd-1


02x28

02x512

02x256

02x512

Calibrate
11:40
Test 3
E.S.



Calibrate
11:55 AM

Sample 3-3
Stack 1
E.S.

Sample 3-2
Stack 1
E.S.

02x256

02x512

02x512

02x256

02x512

02x256

02x512

ES&S ELECTRONIC SYSTEMS INC. USA

ES&S USA

APPENDIX C

BOILER OPERATING DATA

DATE: DEC 13, 1973

TEST NO. 1

STACK ID NUMBER STACK 1

BOILER NO. 1-3-5

PLANT ENGLISH STA

PARAMETERS	1116	1223	1300			
OIL METER (GAL)	8000	11300	13108			
LP STEAM HEADER PRESS.	367	364	364			
LP FUEL OIL HEADER PRESS.	188	185	185			
LP BOILER # 1 WINDBOX PRESS "	3.6	3.5	3.6			
OIL FLOW %	85	82	82			
AIR FLOW %	72	72	72			
STEAM FLOW ¹⁵ / _{hr}	105,000	105,000	105,000			
BAROMETER "Hg	30.01	29.99	29.98			
LP BOILER # 3 WINDBOX PRESS "Hg	3.8	3.8	3.8			
OIL FLOW %	90	89	88			
AIR FLOW %	82	82	82			
STEAM FLOW ¹⁶ / _{hr}	115,000	110,000	110,000			
LP BOILER # 5 WINDBOX PRESS "H ₂ O	3.2	3.1	3.4			
OIL FLOW %	87	86	85			
AIR FLOW %	91	94	94			
STEAM FLOW ¹⁶ / _{hr}	115,000	115,000	115,000			

DATE DEC. 13, 1973

TEST NO. 2

STACK ID NUMBER STACK #1

BOILER NO. 1-3-5

PLANT English Sta

PARAMETERS	1300	1417	1529
CIL METER (GAL)	13108	16870	20450
LP STEAM HEADER PRESS.	364	358	362
LP FUEL OIL HEADER PRESS.	185	185	186
LP BOILER #1 WATER PRESS.	3.6	3.6	3.0
OIL FLOW %	82	80	80
AIR FLOW %	72	72	70
STEAM FLOW ^{lb/hr}	105,000	102,000	103,000
BAROMETER	29.98	29.95	29.96
LP BOILER #3 WATER PRESS. ^{lb}	3.8	3.7	3.8
OIL FLOW %	88	88	90
AIR FLOW %	82	82	82
STEAM FLOW ^{lb/hr}	110,000	115,000	115,000
LP BOILER #5 WATER PRESS. ^{lb}	3.4	3.6	3.4
OIL FLOW %	85	87	90
AIR FLOW %	94	95	95
	115,000	123,000	125,000

DATE DEC 14, 1977

TEST NO. 3

STACK ID NUMBER STACK 1

BOILER NO. 1-3-5

PLANT English Sto

PARAMETERS	0956	1103	1206
OIL METER (GAL)	03294	06645	09704
LP STEAM HEADER PRESS.	362	368	358
LP FUEL OIL HEADER PRESS.	190	190	188
LP BOILER # 1 WINDBOX PRESS "H ₂ O"	3.4	3.2	3.4
OIL FLOW %	81	79	81
AIR FLOW %	69	69	70
STEAM FLOW lb/hr	100,000	98,000	103,000
Barometer	29.62	29.59	29.58
LP BOILER # 3 WINDBOX PRESS "H ₂ O"	3.7	3.7	3.7
OIL FLOW %	89	88	88
AIR FLOW %	80	80	80
STEAM FLOW lb/hr	112,000	108,000	113,000
LP BOILER # 5 WINDBOX PRESS "H ₂ O"	3.7	3.6	3.5
OIL FLOW %	91	90	91
AIR FLOW %	92	92	92
STEAM FLOW lb/hr	110,000	118,000	123,000

APPENDIX D

SAMPLE CALCULATIONS

SAMPLE CALCULATIONS

NOTE: All equations used in these calculations are found in the Federal Register, Vol. 36, No. 247, dated December 23, 1971.

Calculations representative of Test #1:

1. Dry Gas Volume

$$\begin{aligned}
 V_{mstd} &= \left(17.71 \frac{^{\circ}R}{\text{in. Hg}} \right) V_m \left(\frac{P_{\text{bar}} + \frac{\Delta H}{13.6}}{T_m} \right) && \text{eq. 5-1} \\
 &= \left(17.71 \frac{^{\circ}R}{\text{in. Hg}} \right) \left(49.27 \text{ ft}^3 \right) \left(\frac{29.99 \text{ in. Hg} + \frac{0.875 \text{ in H}_2\text{O}}{13.6}}{504.9 \text{ }^{\circ}R} \right) \\
 &= 51.94 \text{ ft}^3
 \end{aligned}$$

2. Volume of Water Vapor

$$\begin{aligned}
 V_{wstd} &= \left(\frac{0.0474 \text{ ft}^3}{\text{ml.}} \right) (V_{lc}) && \text{eq. 5-2} \\
 &= \left(\frac{0.0474 \text{ ft}^3}{\text{ml.}} \right) (97.7 \text{ ml.}) \\
 &= 4.63 \text{ ft}^3
 \end{aligned}$$

3. Moisture Content

$$\begin{aligned}
 B_{ws} &= \frac{V_{wstd}}{V_{wstd} + V_{mstd}} && \text{eq. 5-3} \\
 &= \frac{4.63 \text{ ft}^3}{4.63 \text{ ft}^3 + 51.94 \text{ ft}^3} \\
 &= 0.0818 \times 100\% = 8.2\%
 \end{aligned}$$

4. Molecular Weight (dry)

$$\begin{aligned}
 M_d &= 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2) + 0.28 (\%CO) && \text{eq. 3-2} \\
 &= 0.44 (11.12) + 0.32 (7.22) + 0.28 (81.66) \\
 &\quad + 0.28 (0.00) \\
 &= 30.07 \text{ lb/lb-mole}
 \end{aligned}$$

5. Molecular Weight (wet)

$$\begin{aligned}
 M_s &= M_d (1-Bws) + 18 Bws \\
 &= 30.07 (1-.082) + 18 (.082) \\
 &= 29.08 \text{ lb/lb-mole}
 \end{aligned}$$

6. Stack Gas Velocity

$$\begin{aligned}
 V_s &= K_p C_p \sqrt{\Delta P} \left(\frac{T_s}{P_s M_s} \right)^{1/2} && \text{eq. 2-2} \\
 &= (85.48) (.84) (.266) \left(\frac{903.8}{29.97 \times 29.08} \right)^{1/2} \\
 &= 19.48 \text{ F.P.S.}
 \end{aligned}$$

7. Gas Volumetric Flow Rate, ACFM

$$\begin{aligned}
 \text{ACFM} &= V_s \times A_s \times 60 \text{ sec/min} \\
 &= 19.48 \times 167.9 \text{ ft}^2 \times 60 \text{ sec/min} \\
 &= 196,242 \text{ ACFM}
 \end{aligned}$$

8. Gas Volumetric Flow Rate, SCFM

$$\begin{aligned}
 Q_s &= 60 (1-Bws) (V_s) (A_s) \left(\frac{T_{std}}{T_s} \right) \left(\frac{P_s}{P_{std}} \right) && \text{eq. 2-3} \\
 &= 60 (1-.082) (19.48) (167.9) \left(\frac{530}{903.8} \right) \left(\frac{29.97}{29.92} \right) \\
 &= 105,819 \text{ SCFM}
 \end{aligned}$$

9. Gas Volumetric Flow Rate, lb/hr

$$\begin{aligned}
 W_s &= Q_s \times \frac{60 \text{ min}}{\text{hr}} \times \frac{M_d}{386 \text{ ft}^3} \\
 &= 105,819 \text{ SCFM} \times \frac{60 \text{ min}}{\text{hr.}} \times \frac{30.07 \text{ lb/lb-mole}}{386 \text{ ft}^3} \\
 &= 494,608 \text{ lb/hr.}
 \end{aligned}$$

10. Particulate Concentrations, gr/SCF

$$\begin{aligned}
 C's &= \left(\frac{0.0154 \text{ gr.}}{\text{mg.}} \right) \frac{M_n}{V_{mstd}} && \text{eq. 5-4} \\
 &= \left(\frac{0.0154 \text{ gr.}}{\text{mg.}} \right) \frac{42.8 \text{ mg}}{51.94 \text{ ft}^3} \\
 &= 0.013 \text{ gr/SCF}
 \end{aligned}$$

11. Particulate Concentrations, lb/ft³

$$\begin{aligned}
 C_s &= \frac{\left(\frac{1}{453600} \frac{\text{lb.}}{\text{mg.}} \right) M_n}{V_{mstd}} && \text{eq. 5-5} \\
 &= \frac{\left(\frac{1}{453600} \frac{\text{lb}}{\text{mg.}} \right) 42.8 \text{ mg.}}{51.94 \text{ ft}^3} \\
 &= 1.81 \times 10^{-6} \text{ lb/SCF}
 \end{aligned}$$

12. Particulate Concentrations, lb/hr

$$\begin{aligned}
 C_w &= C_s Q_s \times \frac{60 \text{ min}}{\text{hr}} \\
 &= (1.81 \times 10^{-6} \text{ lb/SCF}) (105,819 \text{ SCFM}) \times \frac{60 \text{ Min}}{\text{hr}} \\
 &= 11.49 \text{ lb/hr}
 \end{aligned}$$

13. Particulate Concentrations, lb/MBTU

$$\begin{aligned}
 E_r &= \frac{C_w}{\text{Heat Input}} \\
 &= \frac{11.49 \text{ lb/hr}}{440.0 \times 10^6 \text{ BTU/hr}} \\
 &= 0.026 \text{ lb/MBTU}
 \end{aligned}$$

14. % Isokinetic Sampling

$$I = \frac{\bar{T}_s (1.667 \frac{\text{min}}{\text{sec}}) \left((0.00267) v_{lc} + \frac{V_m}{T_m} \left(P_{\text{bar}} + \frac{\Delta H}{13.6} \right) \right)}{\ominus V_s P_s A_n}$$

$$I = \frac{903.8 (1.667) \left((0.00267) (97.7) + \frac{49.27}{504.9} \left(29.99 + \frac{.875}{13.6} \right) \right)}{(100) (1948) (29.97) (7.67 \times 10^{-4})} \quad \text{eq. 5-6}$$

$$= 107.5\%$$

15. NO_x Concentrations, lb/hr

$$\text{lb/hr} = \text{PPM} \times \frac{M_w (\text{NO}_2)}{M_d} \times W_s$$

$$= \frac{165}{10^6} \times \frac{46 \text{ lb/lb-mole}}{30.07 \text{ lb/lb-mole}} \times 494,608 \frac{\text{lb}}{\text{hr}}$$

$$= 124.8 \text{ lb/hr}$$

16. NO_x Concentrations, lb/MBTU

$$\text{lb/MBTU} = \frac{\text{lb/hr}}{\text{Heat Input}}$$

$$= \frac{124.8 \text{ lb/hr}}{440.0 \times 10^6 \text{ BTU/hr}}$$

$$\text{lb/MBTU} = \frac{0.284 \text{ lb}}{10^6 \text{ BTU}}$$

17. Stack Pressure (Absolute), in. Hg

$$P_s = P_b + \frac{P_d}{13.6} = 29.99 + \frac{(-0.27)}{13.6} = 29.97 \text{ in. Hg.}$$

18. Nozzle Area (Ft²)

$$A_n = \frac{\pi D^2}{4} = 0.785 \times \left(\frac{0.375}{12} \right)^2 = 7.67 \times 10^{-4} \text{ ft.}^2$$

19. Stack Area (ft²)

$$A_s = \frac{\pi D^2}{4} = 0.785 \times \left(\frac{175.5}{12}\right)^2 = 167.9 \text{ ft}^2$$

20. Heat Input, 10⁶ BTU

Sp. Gr. x 8.33 #/gal. x BTU/lb. x gal/hr

$$0.903 \times 8.33 \text{ #/gal} \times 19,847 \text{ BTU/lb} \times 2947 \text{ gal/hr} = \\ 440.0 \times 10^6 \text{ BTU hr.}$$

21. Gas Density (lb/ft³)

$$\text{Gas Density} = \frac{\text{Mol wt gas}}{386 \text{ ft}^3} \times \frac{T_{\text{std}}}{T_s} \times \frac{P_{\text{bar}}}{P_{\text{std}}} \\ = \frac{30.07}{386} \times \frac{530}{903.8} \times \frac{29.99}{29.92} = \\ = 0.0457 \text{ lb/ft}^3$$

THE UNITED ILLUMINATING COMPANY
SOURCE TESTING CALCULATION FORMS

Test No. English Station Stack 1 No. Runs 3
 Name of Firm The United Illuminating Company
 Location of Plant 510 Grand Avenue, New Haven, Connecticut
 Type of Plant Steam Generating Station
 Control Equipment None
 Sampling Point Locations Stack
 Pollutants Sampled Particulates, Nitrogen Oxides

Time of Particulate Test:

Run No. <u>1</u>	Date <u>12/13/73</u>	Begin <u>11:09</u>	End <u>13:03</u>
Run No. <u>2</u>	Date <u>12/13/73</u>	Begin <u>13:47</u>	End <u>15:40</u>
Run No. <u>3</u>	Date <u>12/14/73</u>	Begin <u>9:42</u>	End <u>11:30</u>

PARTICULATE EMISSION DATA

Run No.	1	2	3	
$K_p = 35.48 \frac{ft}{sec} \left(\frac{lb.}{lb \text{ mole-}^{\circ}R} \right)^{1/2}$	85.48	85.48	85.48	
$C_p =$ Pitot tube coefficient (calib.)	0.84	0.84	0.84	
$\sqrt{VAP} =$ Average velocity head of stack gas, inches H ₂ O	0.266	0.295	0.271	
$\bar{T}_s =$ Average stack temp., °R	903.8	906.5	903.5	
$P_b =$ Barometric pressure, "Hg Abs.	29.99	29.96	29.60	
$P_d =$ Gas duct pressure, "H ₂ O	-0.27	-0.27	-0.26	
$P_s =$ Absolute stack gas pressure, inches Hg	29.97	29.94	29.58	
$B_{ws} =$ % moisture in stack gas, by volume	8.2	8.5	8.2	
$M_d =$ Molecular weight of stack gas, dry	30.07	30.09	30.06	
$M_s =$ Molecular weight of stack gas	29.08	29.06	29.07	

V_s = Stack gas velocity, F.P.S.	19.48	21.62	19.95	
% CO ₂	11.12	11.25	11.06	
% O ₂	7.22	7.22	7.25	
% CO	0.00	0.00	0.00	
% N ₂	81.66	81.53	81.69	
Vlc = Total volume of liquid collected in impingers and silica gel, ml.	97.7	111.14	95.0	
Vm = Volume of dry gas sampled at meter conditions, FT ³	49.27	53.817	50.490	
std = Volume of dry gas sampled at STP, FT ³	51.94	56.37	50.46	
Tm = Average dry gas meter temp., °R	504.9	507.9	525.7	
ΔH = Average pressure drop across orifice, inches H ₂ O	0.875	1.059	0.898	
θ = Total Sampling Time, min.	100	100	100	
Dn = Nozzle dia., inches	0.375	0.375	0.375	
An = Nozzle area, FT ²	7.67×10^{-4}	7.67×10^{-4}	7.67×10^{-4}	
I = % of isokinetic sampling	105.2	105.9	103.2	
Qs = Stack gas volume at STP (SCFM)	105,819	116,594	106,997	109,303
Qa = Stack gas volume at stack conditions (ACFM)	196,242	217,800	200,976	205,006
Ws = Stack gas mass flow lbs/hr	494,608	545,334	499,948	513,297
Mp = Particulate-probe, washings, mg	-	-	-	
Mf = Particulate-filter (mg)	-	-	-	
Mn = Particulate-total (mg)	42.8	47.7	48.4	
C's = Particulate Concentrations gr/scf	0.013	0.013	0.015	0.014
Cv = Particulate total emission lb/hr	11.49	13.02	13.55	12.69
Er = Particulate emission rate, lb/10 ⁶ BTU	0.026	0.029	0.031	0.03
C = NO _x concentrations, PPM	165	165	171	
Cn = NO _x lb/10 ⁶ BTU	0.284	0.312	0.296	0.30

EMISSION TEST REPORT
(Ref. Intent to Test Form
Numbers 720045 and 720047)

0AQPS-78-1
II-I-257

The United Illuminating Company
Steel Point Station
43 East Main Street
Bridgeport, Connecticut
06608

FUEL OIL
COMBUSTION
AP-42 Section 1.3
Reference Number
24

Stack No. S.P. 7
Steam Generator Nos. 25, 26, 27

#12493 Ref 2

1950

Test Conducted By
The United Illuminating Company
Test and Development Laboratory
80 Temple Street
New Haven, Connecticut
06506

Prepared by:

J.S. Sombati John A. Sombati
Development & Testing Laboratory Supervisor

J.W. Hotchkiss John W. Hotchkiss
Assistant Mechanical Engineer

Approved by:

D.W. Hoskinson Dwain W. Hoskinson
Chief Mechanical Engineer

Submitted by:

M.R. McCraven M.R. McCraven
Director of Environmental Engineering

General
Introduction

Emission tests were conducted on The United Illuminating Company Steel Point Station Steam Generators 25, 26 and 27. All three steam generators discharge emissions into a common stack, Stack #7. Steam Generators 25 and 27 are connected to a common flue gas duct which discharges into the base of Stack #7. The flue gas duct of Steam Generator 26 is connected to Stack 7 approximately 20 feet from the top of the stack. Due to this unique stack configuration, it became necessary to sample each flue gas duct for emissions.

Emission tests for Particulates and Nitrogen Oxides were conducted on each flue gas duct. The weighted averages of Particulates and Nitrogen Oxide emissions are summarized on the following page.

Summary of Test Results*

Stack Number S.P. 7

Steam Generator Nos. 25, 26, 27

<u>Component</u>	<u>Sampling Duration</u>		<u>Number of tests (Minimum of 3)</u>	<u>Measured Concentrations Weighted Average</u>	Techna Employee to Determine Concentration
	<u>minutes per point</u>	<u>total test time</u>			
NO _x	-	-	6	0.15 lb/MBTU	Dynascience Model NX-130
Particulates	-	-	5	0.05 lb/MBTU	Method 5**

*Weighted average of individual boiler tests
 (Ref: Intent to Test Form Nos. 720045 and 720047.)
 **Federal Register, Vol. 36, No. 247, December 23, 1971.

TEST RESULTS

Steam Generator No. 26
(Ref. Intent to Test Form No. 720047)

Test Conducted On
December 18, 19, 20, 21, 28, 1972

Introduction

Emission tests for Particulates and Nitrogen Oxides were conducted as required by Connecticut State Law on United Illuminating Company Steel Point Station Steam Generator 26, located in Bridgeport, Connecticut. Testing was conducted on December 18-21 and on December 28, 1972.

Source Sampling was performed in accordance with test methods and procedures as prescribed in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. These tests were conducted on the flue gas duct downstream of the precipitator outlet and upstream of the stack inlet. This site location was chosen due to the impracticality of source sampling in the stack due to stack configuration. It should be noted at this time that this stack #7 also handles the emissions produced by Steam Generators 25 and 27, which have been previously tested on December 5, 6, and 7, 1972 (Report No. 720045). A copy of that test report was forwarded to the State Department of Environmental Protection on December 26, 1972.

The primary contaminants tested for were Particulates and Nitrogen Oxides. Tests were also conducted to determine stack gas velocity and volumetric flow rates, flue gas analysis and molecular weight and moisture content of the flue gas. The procedures used in determining these various parameters, except for nitrogen oxides, are those found in the above mentioned Federal Register. Nitrogen Oxide emissions were found by using a Dynascience Model NX-130 NO_x Analyzer instead of using the phenoldisulfonic acid procedure as stated in Method 7 of the above mentioned Federal Register.

Two tests for determination of particulate emissions are reported. Results of these tests comply with the State Law on emission rates. Due to an operational malfunction of the electrostatic precipitator, the results from one test were disregarded as not being representative of normal emissions from the source. After mechanical and electrical maintenance was performed, the unit was tested with the results shown as Test 3B.

This test report includes the information required for Items III, IV, V, VI, VII, IX, X, XI and XII from the Department of Environmental Protection's "Intent to Test" form in compliance with the DEP's Source Test Guidelines and Procedures.

Source Test Form #2 was not available at the time of the writing of this report.

1. Sampling Train Information
(Ref. Item VII "Intent to Test" Form)

- a.) Schematic diagram of sampling train: See Fig. 1. Sampling Train used: RAC Stack-sampler Model 2343, purchased April 4, 1972.
- b.) Media type used to determine gas stream components. NO_x: DynaScience Model NX-130 NO_x Analyzer. Particulates: Reeve Angel 900 AF, 11 cm diameter glass fiber filter.
- c.) Sampling tube: Stainless steel for particulates, glass probe for NO_x, moisture, and orsat analysis.
- d.) Probe cleaning method: Wash probe with acetone and store in sealed container.

2. Description of Operations
(Ref. Item IX "Intent to Test" Form)

The operation tested was Steel Point Station Steam Generator #26, Registration Number S.P. 26, Stack 7, having a capacity of 420.4×10^6 BTU/hr, burning #6 fuel oil at a rate of 2888 gal/hr., and having a gas flow of 158328 ACFM. See Table IV for fuel oil analysis.

3. Sampling Area Description
(Ref. Item X "Intent to Test" Form)

This flue gas discharges into Stack 7. Also discharging into this stack are Steam Generators 25 and 27. Due to stack configuration, it is necessary to sample Boiler 26 in this proposed location. (Intent to Test Forms for Steel Point Station Steam Generators 25 and 27 were mailed on October 30, 1972. Included were prints showing Boilers 25 and 27 flue gas duct configuration at Stack 7).

a.) Stack Configuration

(See Westcott and Mapes drawing
Number 2022A Project Number 47001.)

b.) Sampling Port Locations

(See drawing referenced above.)

c.) Sampling Point Positions for Each Port

(See drawing referenced above.)

4. Stack and Vent Descriptions
(Ref. Item XI "Intent to Test" Form)

Connected to this boiler is a Research-Cottrell electro-static precipitator having an estimated collection efficiency of approximately 60% when burning residual fuel oil. The outlet of the precipitator discharges through a flue gas duct into Stack #7. Emission sampling was conducted in sampling ports installed in the flue gas duct located between the precipitator outlet and the stack. (See Westcott and Mapes drawing Number 2022A referenced above.)

5. Operational Parameters
(Ref. Item XII "Intent to Test" Form)

Electric utility steam generator burning No. 6 residual fuel oil, having rated capacity as registered.

Table I

Summary of Test Results
 Steam Generator No. 26

Component	Sampling Duration minutes per point	total test time	Number of Tests (Minimum of 3)	Measured Concentrations	Method Employee to Determine Concentration i.e., material balance, emission factor, reference, (specify) etc.
NO _x		15 min.	3	0.13 lb/10 ⁶ BTU	DYNASCIENCE MODEL NX-130
Particulates	5	220 min.	3	0.05 lb/10 ⁶ BTU**	METHOD 5*
Moisture		220 min.	3	10.3%	CONDENSER METHOD
Gas Analysis		30 min.	3	37% Excess Air	METHOD 3 (ORSAT)*
Velocity	1/2	25 min.	3	0.02" to 1.1" H ₂ O	METHOD 2*

*Federal Register, Vol. 36, No. 247, December 23, 1971

**Average of two tests

NO_x 25, 27 10.8% O₂ - 7.5% CO₂

1126

TABLE II

Summary of Results
Steam Generator No. 26

	<u>Test 1</u>	<u>Test 2</u>	<u>Test 3A</u>	<u>Test 3B</u>	<u>Average</u>
Date	12/19/72	12/20/72	12/21/72	12/28/72	
Stack Flow, ACFM	159192	153174	158378	162568	158328
Stack Flow, SCFM	95623	92188	97986	100293	96523
Stack Flow, lb/hr	443978	429032	456471	466597	449020
% Excess O ₂ @ Test Point	7.15	7.72	7.4	N.A.	7.42
Particulate Emissions					
gr/SCF	0.026	*	-	0.019	0.023**
lb/hr	21.17	*	-	16.13	18.65**
lb/MBTU	0.05	*	-	0.04	0.05
Nitrogen Oxide Emissions					
ppm	118.65	107.79	114.65	-	113.7
lb/MBTU	0.13	0.11	0.13	-	0.13

Control:
electrostatic
precipitator

*Not calculated (estimate efficiency)
**Average of Test 1 and Test 3 (60%)

6.5 lb
10³ gal

1460000 19 lb
10³ gal

TABLE III

Average Boiler Operating Data for Test Periods

	<u>Test 1</u>	<u>Test 2</u>	<u>Test 3A</u>	<u>Test 3B</u>
Date	12/19/72	12/20/72	12/21/72	12/28/72
Gross Load, MW	33.5	N.A.	N.A.	33.8
Steam Flow, lb/hr	316,000	314,000	320,000	320,000
Oil Flow, gal/hr	2,846	2,800	2,848	2,888
Air Flow, lb/hr	345,000	344,000	360,000	360,000
Excess O ₂ (%)	3.8	3.5	4.0	4.0
Soot Blowing	None	None	None	None
Additive Rate ("CHESCO")	2000:1	2000:1	2000:1	2000:1
Stack Gas Temperature OF	326.6	326.3	325.9	311.7
Gas Density lb/ft. ³	0.052	0.052	0.052	0.053

TABLE IV

Ultimate Analysis Of
Representative Fuel Oil Sample

January 12, 1973

DATE

FUEL ENGINEERING COMPANY

254139

REPORT NUMBER

FUEL TESTING DEPARTMENT

TEST REPORT

Ultimate Analysis

Carbon = 85.37%
Hydrogen = 12.24%
Sulfur = 0.41%
Nitrogen = 0.27%
Oxygen = 1.71%
API @60°F = 23.6
Specific Gravity = 0.9123

BTU per pound = 19,159
BTU per gallon = 145,551

Your P.O. No


On Sample Marked Steel Point #26 Special Test


Sample Taken by You
Us

Received from United Illuminating Co.
80 Temple Street
New Haven, Conn 06506
Attn: Mr. J. Sombati

Fuel Engineering Company of New York

by:





THE UNITED ILLUMINATING COMPANY
TYPICAL SAMPLING TRAIN
FIGURE 1

- 1) Probe
- 2) Box Thermometer
- 3) Gas Thermometer
- 4) Particulate Filter
- 5) Impingers (Greenburg-Smith)
- 6) Thermometer
- 7) Check Valve
- 8) Dribble Cord
- 9) Vacuum Gauge
- 10) Coarse Flow Adjust Valve
- 11) Fine Flow Adjust Valve
- 12) Goler
- 13) Vacuum Pump
- 14) Filter
- 15) Dry Gas Meter
- 16) Coke Tube
- 17) Inlet Manometer
- 18) Solenoid Valves
- 19) Filter
- 20) Thermocouple
- 21) Johns & Northrup 6695-2, I.C. Temperature Potentiometer

Moisture Determination

Moisture determination in stack gas is used in the calculation of isokinetic conditions. The amount of moisture in the stack gas was found by using the following procedure.

The gas sample is aspirated through a pyrex glass probe which is electrically heated and encased in a stainless steel tube. The probe is inserted into the flue gas duct and heated electrically using a variable transformer. The gas sample is drawn through the probe, and through a glass pre-weighed tube filled with silica gel. From the silica gel tube the gas passes through a rotometer, through the aspirating pump, and through a dry gas meter, and passes into the atmosphere. The rotometer is used to control the flow rate of the gas. By averaging the temperature of the gas through the dry gas meter, and recording the volume of gas passed through the meter, the amount of moisture can be determined.

The volume of water absorbed by the silica gel tube is converted to the vapor state by using the ideal gas law equation:

$$V_{wt} = \frac{MaRT_m}{P_m M_w}$$

where M_a = mass or weight of water absorbed, grams

R = gas law constant, $21.83 \frac{\text{in Hg} \cdot \text{FT}^3}{\text{lb mol} \cdot \text{OR}}$

T_m = average outlet temperature of the dry gas meter, OR

P_m = barometric pressure, in Hg

M_w = 18 lb/lb mol

The proportion by volume of the stack gas that is water vapor (B_{ws}) is found by using the equation:

$$B_{ws} = \frac{\text{Amount of water absorbed in the silica gel tube}}{\text{Amount of water absorbed} + \text{Amount of metered gas}}$$

Orsat Analysis

A Burrell Gas Analyzer was used to determine O_2 , CO_2 , CO , and N_2 concentrations of the flue gas. The gas sample was aspirated through a stainless steel probe, packed with glass wool at the inlet of the probe. Teflon tubing connected the stainless steel probe to the orsat analyzer. After a sufficient sample was drawn through the probe, tubing, and orsat manifold, a sample of gas was analyzed.

Velocity Traverse

A preliminary velocity traverse was made of the flue gas duct in order to determine a correct nozzle size used in determining particulate concentrations with the RAC Staksampler. It was noted that four traverse points had a negative delta "P". These four areas, located at port 1, points 7 and 8 and at port 6, points 7 and 8 were not used in the test for particulates. Instead of using 48 traverse and sampling points, only 44 sampling points were used.

Since these traverse points indicated negative delta "P," the total cross-sectional area of the flue gas duct was also reduced by the amount of the area occupied by these four sampling areas. The cross-sectional area of the duct was, therefore, reduced from 49.9Ft² to 45.8Ft².

Particulate Determination

The apparatus used in determining particulate emissions was a RAC Staksampler Model 2343-5, Serial No. 1399. The procedure followed in this test is Method 5 of the Federal Register, Vol. 36, No. 247, December 23, 1971.

Used in this test was a 10 foot stainless steel probe and pitot tube, recalibrated by the Research Corporation of New England. The pitot tube coefficient obtained from the calibration of this pitot tube was 0.817.

Two modifications were made to the RAC Staksampler by the UI Co. The heated box housing the four-inch fiber filter was fitted with a 0°-300° F indicating thermometer. This enabled the equipment operator to be aware of the exact box temperature during the sampling period.

Also modified was the glass elbow from the filter to the first impinger. This was fitted with a tee connection into which a thermometer with a glass ground joint was inserted. This enabled the operator to check the gas temperature leaving the filter and make any corrections if need be in the probe heating transformer.

After running one test for particulate concentrations, it was found that the amount of silica gel in the fourth impinger had nearly been spent. To insure in future runs of this test that the effectiveness of the silica gel would not be depleted, 300 grams instead of 200 grams was used. This was found to give a greater margin of safety in making sure that there was no moisture carry-over into the dry gas meter.

NO_x Determination

Nitrogen oxides were determined by using a Dynascience NO_x Analyzer, Model NX-130, Serial No. 418. A stainless steel probe, packed with glass wool at the inlet, was inserted approximately 3 feet into the center of the flue gas duct. After calibrating the instrument with a known concentration of NO gas, the flue gas sample was drawn through the instrument which gave a direct read-out on the meter scale. The instrument was operated for fifteen minutes for each test, with readings taken every minute. At the conclusion of the test, the NO_x concentrations in PPM were averaged, and used in the final NO_x calculations.

SAMPLE CALCULATIONS

NOTE: All equations used in these calculations are found in the Federal Register, Vol. 36, No. 247, dated December 23, 1971.

Calculations representative of Test #1.

1) Dry Gas Volume

$$\begin{aligned} V_{mstd} &= \left(17.71 \frac{O_R}{\text{inHg}} \right) V_m \left(\frac{P_{\text{bar}} + \frac{\bar{\Delta}H}{13.6}}{T_m} \right) && \text{eq. 5-1} \\ &= \left(17.71 \frac{O_R}{\text{inHg}} \right) 162.055 \text{ ft}^3 \left(\frac{29.93 \text{ in Hg} + \frac{2.066 \text{ in H}_2\text{O}}{13.6}}{553.6 \text{ OR}} \right) \\ &= 155.84 \text{ ft}^3 \end{aligned}$$

2) Volume of Water Vapor

$$\begin{aligned} V_{wstd} &= \left(0.0474 \frac{\text{FT}^3}{M} \right) V_{lc} && \text{eq. 5-2} \\ &= \left(0.0474 \frac{\text{FT}^3}{M} \right) 389.4 \text{ ml} \\ &= 18.46 \text{ FT}^3 \end{aligned}$$

3) Moisture Content

$$\begin{aligned} B_{ws} &= \frac{V_{wstd}}{V_{wstd} + V_{mstd}} \\ &= \frac{18.46 \text{ FT}^3}{18.46 \text{ FT}^3 + 155.84 \text{ FT}^3} \\ &= 0.106 \times 100\% = 10.6\% \end{aligned}$$

4) Molecular Weight (dry)

$$\begin{aligned}
 M_d &= 0.44 (\% \text{ CO}_2) + 0.32 (\% \text{ O}_2) + 0.28 (\% \text{ N}_2) + 0.28 (\% \text{ CO}) && \text{eq. 3-2} \\
 &= 0.44 (10.0) + 0.32 (7.15) + 0.28 (82.85) \\
 &\quad + 0.28 (0) \\
 &= 29.87 \text{ lb/lb-mole}
 \end{aligned}$$

5) Molecular Weight (wet)

$$\begin{aligned}
 M_S &= M_d (1 - B_{ws}) + 18 B_{ws} \\
 &= 29.87 (1 - .106) + 18 (.106) \\
 &= 28.61 \text{ lb/lb-mole}
 \end{aligned}$$

6) Stack Gas Velocity

$$\begin{aligned}
 V_s &= K_p C_p \sqrt{\Delta P} \left(\frac{T_s}{P_s M_s} \right)^{\frac{1}{2}} && \text{eq. 2-2} \\
 &= (85.48) (.817) (.864) \left(\frac{786.56}{29.835 \times 28.61} \right)^{\frac{1}{2}} \\
 &= 57.93 \text{ F.P.S.}
 \end{aligned}$$

7) Gas Volumetric Flow Rate, ACFM

$$\begin{aligned}
 \text{ACFM} &= V_s \times A \times 60 \text{ sec/min} \\
 &= 57.93 \times 45.8 \text{ FT}^2 \times 60 \text{ sec/min} \\
 &= 159,192 \text{ ACFM}
 \end{aligned}$$

8) Gas Volumetric Flow Rate, SCFM

$$\begin{aligned}
 Q_s &= 60 (1 - B_{ws}) V_s A \left(\frac{T_{std}}{T_s} \right) \left(\frac{P_s}{P_{std}} \right) && \text{eq. 2-3} \\
 &= 60 (1 - .106) (57.93) (45.8) \left(\frac{530}{786.56} \right) \left(\frac{29.835}{29.92} \right) \\
 &= 95,623 \text{ SCFM}
 \end{aligned}$$

9) Gas Volumetric Flow Rate, lb/hr

$$\begin{aligned}
 W_s &= Q_s \times \frac{60 \text{ min}}{\text{hr}} \times \frac{M_d}{386 \text{ FT}^3} \\
 &= 95,623 \text{ SCFM} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{29.87 \text{ lb/lb-mole}}{386 \text{ FT}^3} \\
 &= 443,978 \text{ lb/hr}
 \end{aligned}$$

10) Particulate Concentrations, gr/SCF

$$\begin{aligned}
 C's &= \left(0.0154 \frac{\text{gr}}{\text{mg}} \right) \frac{M_n}{V_{mstd}} && \text{eq. 5-4} \\
 &= \left(0.0154 \frac{\text{gr}}{\text{mg}} \right) \frac{261.2 \text{ mg}}{155.84 \text{ FT}^3} \\
 &= 0.026 \text{ gr/SCF}
 \end{aligned}$$

11) Particulate Concentrations, lb/FT³

$$\begin{aligned}
 C_s &= \frac{\left(\frac{1}{453600} \frac{\text{lb}}{\text{mg}} \right) m_n}{V_{mstd}} && \text{eq. 5-5} \\
 &= \frac{\left(\frac{1}{453600} \frac{\text{lb}}{\text{mg}} \right) 261.2 \text{ mg}}{155.84 \text{ FT}^3} \\
 &= 3.69 \times 10^{-6} \text{ lb/SCF}
 \end{aligned}$$

12) Particulate Concentrations, lb/hr

$$\begin{aligned}
 C_w &= C_s Q_s \times \frac{60 \text{ min}}{\text{hr}} \\
 &= (3.69 \times 10^{-6} \text{ lb/SCF}) (95,623 \text{ SCFM}) \frac{60 \text{ min}}{\text{hr}} \\
 &= 21.17 \text{ lb/hr}
 \end{aligned}$$

13) Particulate Concentrations, lb/MBTU

$$\begin{aligned}
 E_r &= \frac{C_w}{\text{Heat Input}} \\
 &= \frac{21.17 \text{ lb/hr}}{414.2 \times 10^6 \text{ BTU/hr}} \\
 &= 0.051 \text{ lb/MBTU}
 \end{aligned}$$

14) % Isokinetic Sampling

$$I = T_s \left(\frac{1.667 \text{ min}}{\text{sec}} \right) \frac{\left((0.00267) \frac{V_{lc}}{\theta V_s} + \frac{V_m}{T_m} \left(p_{\text{bar}} + \frac{\bar{\Delta H}}{13.6} \right) \right)}{P_s A_n}$$

eq. 5-6

$$I = 786.56 (1.667) \frac{\left((0.00267) (389.4) + \frac{162,055}{553.6} \left(29.93 + \frac{2.066}{13.6} \right) \right)}{(220) (57.93) (29.835) (0.00034)}$$

$$= 99.84\%$$

15) NO_x Concentrations, lb/hr

$$\text{lb/hr} = \text{PPM} \times \frac{M_w (\text{NO})}{M_d} \times W_s$$

$$= \frac{118.65}{10^6} \times \frac{30 \text{ lb/lb-mole}}{29.87 \text{ lb/lb-mole}} \times 443,978 \frac{\text{lb}}{\text{hr}}$$

$$= 52.9 \text{ lb/hr}$$

16) NO_x Concentrations, lb/MBTU

$$\text{lb/MBTU} = \frac{\text{lb/hr}}{\text{Heat Input}}$$

$$= \frac{52.9 \text{ lb/hr}}{414.2 \times 10^6 \text{ BTU/hr}}$$

$$\text{lb/MBTU} = \frac{0.128 \text{ lb}}{10^6 \text{ BTU}}$$

THE UNITED ILLUMINATING COMPANY

SOURCE TESTING CALCULATION FORMS

Test No. St. Pt. 26, Stack 7 No. Runs 3
 Name of Firm The United Illuminating Company
 Location of Plant Steel Point Station
 Type of Plant Steam Generation
 Control Equipment Electrostatic Precipitator
 Sampling Point Locations Stack Entry Duct
 Pollutants Sampled Particulates, Nitrogen Oxides

Time of Particulate Test:

Run No. <u>1</u>	Date <u>12-19-72</u>	Begin <u>1425</u>	End <u>1930</u>
Run No. <u>2</u>	Date <u>12-20-72</u>	Begin <u>1457</u>	End <u>1920</u>
Run No. <u>3A</u>	Date <u>12-21-72</u>	Begin <u></u>	End <u></u>
Run No. <u>3B</u>	Date <u>12-28-72</u>	Begin <u>1403</u>	End <u>1756</u>

PARTICULATE EMISSION DATA

Run No.	1	2	3A	3B
$K_p = 85.49 \frac{\text{ft}}{\text{sec}} \left(\frac{\text{lb.}}{\text{lb mole-}^\circ\text{R}} \right)^{\frac{1}{2}}$	85.48	85.48	85.48	85.48
$C_p = \text{Pitot tube coefficient (calib.)}$.817	.817	.817	.817
$\sqrt{\Delta P} = \text{Average velocity head of stack gas, inches H}_2\text{O}$.864	.834	.830	.894
$T_s = \text{Average stack temp., } ^\circ\text{R}$	786.56	786.27	785.91	771.70
$P_b = \text{Barometric pressure, "Hg Abs.}$	29.93	29.97	30.06	29.94
$P_d = \text{Gas duct pressure, "H}_2\text{O}$	-1.3"	-1.2"	-1.3"	-1.25"
$P_s = \text{Absolute stack gas pressure, inches Hg}$	29.835	29.882	29.965	29.849
$B_{ws} = \% \text{ moisture in stack gas, by volume}$	10.6	10.6	8.4*	9.9
$M_d = \text{Molecular weight of stack gas, dry}$	29.87	29.94	29.97	29.83
$M_s = \text{Molecular weight of stack gas}$	28.61	28.67	28.96	(avg.) 28.75

*Silica gel tube method

(avg.)

V_s = Stack gas velocity, F.P.S.	57.93	55.74	55.12	59.12
% CO ₂	10.10	10.3	10.45	10.25*
% O ₂	7.15	7.72	7.4	7.42*
% CO	0.00	0.12	0.03	0.05*
% N ₂	82.85	81.85	82.13	82.28*
Vlc = Total volume of liquid collected in impingers and silica gel, ml.	389.4	373.2	-	373.8
Vm = Volume of dry gas sampled at meter conditions, FT ³	162.055	151.941	-	161.903
Vstd = Volume of dry gas sampled at STP, FT ³	155.84	149.61	-	161.43
Tm = Average dry gas meter temp., °R	553.6	541.1	-	533.7
ΔH = Average pressure drop across orifice, inches H ₂ O	2.066	1.31	-	2.102
θ = Total Sampling Time, min.	220	220	-	220
Dn = Nozzle dia., inches	.25	.25	-	.25
An = Nozzle area, FT ²	.00034	.00034	-	.00034
I = % of isokinetic sampling	99.84	99.40	-	98.70
Qs = Stack gas volume at STP (SCFM)	95,623	92,188	97,986	100,293
Qa = Stack gas volume at stack conditions (ACFM)	159,192	153,174	158,378	162,568
Ws = Stack gas mass flow lbs/hr	443,978	429,032	456,471	466,597
Mp = Particulate-probe, washings, mg	100.9		-	70.7
Mf = Particulate-filter (mg)	160.3		-	126.0
Mn = Particulate-total (mg)	261.2		-	196.7
C's = Particulate Concentrations gr/scf	0.026		-	0.019
Cw = Particulate total emission lb/hr	21.17		-	16.13
Er = Particulate emission rate, lb/10 ⁶ BTU	0.05		-	0.04
C = NO _x concentrations, PPM	118.65	107.79	114.65	
Cn = NO _x , lb/10 ⁶ BTU	0.13	0.11	0.13	0.12

TEST RESULTS

Steam Generator Nos. 25 and 27
(Ref. Intent to Test Form No. 720045)

Test Conducted On
December 4, 5, 6, 7, 1972

Introduction

Emission tests for Particulates and Nitrogen Oxides were conducted as required by Connecticut State Law on United Illuminating Company Steel Point Station Steam Generators 25 and 27, located in Bridgeport, Connecticut. Testing was conducted on December 4-7, 1972.

Source Sampling was performed in accordance with test methods and procedures as prescribed in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. These tests were conducted on the flue gas duct downstream of the precipitator outlet and upstream of the stack inlet. This site location was chosen due to the impracticality of source sampling in the stack due to stack configuration. This Stack #7 also handles the emissions produced by Steam Generator 26, which was tested on December 18-21 and on December 28, 1972. A copy of that report is enclosed.

The primary contaminants tested for were Particulates and Nitrogen Oxides. Tests were also conducted to determine stack gas velocity and volumetric flow rates, flue gas analysis and molecular weight and moisture content of the flue gas. The procedures used in determining these various parameters, except for nitrogen oxides, are those found in the above mentioned Federal Register. Nitrogen Oxide emissions were found by using a Dynascience Model NX-130 NO_x Analyzer instead of using the phenoldisulfonic acid procedure as stated in Method 7 of the above mentioned Federal Register.

This test report includes the information required for Items III, IV, V, VI, VII, IX, X, XI and XII from the Department of Environmental Protection's "Intent to Test" form in compliance with the DEP's Source Test Guidelines and Procedures.

Source Test Form #2 was not available at the time of the writing of this report.

1. Sampling Train Information
(Ref. Item VII "Intent to Test" Form)

- a.) Schematic diagram of sampling train: See Fig. 1. Sampling Train used: RAC Stack-sampler Model 2343, purchased April 4, 1972.
- b.) Media type used to determine gas stream components. NO_x: DynaScience Model NX-130 NO_x Analyzer. Particulates: Reeve Angel 900 AF, 11 cm diameter glass fiber filter.
- c.) Sampling tube: Stainless steel for particulates, glass probe for NO_x, moisture, and orsat analysis.
- d.) Probe cleaning method: Wash probe with acetone and store in sealed container.

2. Description of Operations
(Ref. Item IX "Intent to Test" Form)

The operation tested was Steel Point Station Steam Generators 25, 27, Registration Number S.P. 25, 27, Stack 7, having a total capacity of 392.7×10^6 BTU/hr, burning #6 fuel oil at a rate of 2725 gal/hr for both boilers, and having a total gas flow of 217,350 ACFM. See Table IV for fuel oil analysis.

3. Sampling Area Description
(Ref. Item X "Intent to Test" Form)

This flue gas discharges into Stack 7. Also discharging into this stack is Steam Generator 26. Due to stack configuration, it is necessary to sample these boilers in the flue gas duct upstream of the stack inlet.

a.) Stack Configuration

(See Westcott and Mapes drawing
Number 200-A, Project Number 41013.)

b.) Sampling Port Locations

(See drawing referenced above.)

c.) Sampling Point Positions for Each Port

(See drawing referenced above.)

4. Stack and Vent Descriptions
(Ref. Item XI "Intent to Test" Form)

Connected to each boiler is a Research Cottrell electrostatic precipitator having an estimated collection efficiency of approximately 60% when burning residual fuel oil. The precipitator outlet ducts merge together into a common duct, which is connected to the base of No. 7 stack. Emission sampling was conducted in sampling ports installed in the common flue gas duct joining the precipitator outlets to the stack. (See Westcott and Mapes drawing Number 200-A referenced above.)

5. Operational Parameters
(Ref. Item XII "Intent to Test" Form)

Electric utility steam generators burning No. 6 residual fuel oil and having rated capacities as registered.

Table I

Summary of Test Results
Steam Generator Nos. 25, 27

Component	Sampling Duration		Number of Tests (Minimum of 3)	Measured Concentrations	Agency employed to Determine Concentration
	minutes per point	total test time			
NO _x		15 min.	3	0.18 lb/10 ⁶ BTU	1.9., material balance, emiss factor, reference, (specify) at
Particulates	5	235 min.	3	0.06 lb/10 ⁶ BTU	Dynascience Model NX-130
Moisture		235 min.	3	7.8%	Method 5* Condenser Method
Gas Analysis		30 min.	3	53% Excess Air	Method 3 (ORSAT)*
velocity	$\frac{1}{2}$	25 min.	3	0.05" to 1.3" H ₂ O	Method 2*

TABLE II

Summary of Results
Steam Generator Nos. 25, 27

	<u>Test 1</u>	<u>Test 2</u>	<u>Test 3</u>	<u>Average</u>
Date	12/5/72	12/7/72	12/7/72	
Stack Flow, ACFM	227,482	211,751	212,818	217,350
Stack Flow, SCFM	134,816	125,426	126,902	129,048
Stack Flow, lb/hr	620,084	577,477	584,867	594,143
% Excess O ₂ @ Test Point	10.92	10.50	10.50	10.64
Particulate Emissions				
gr/SCF	0.024	0.020	0.025	0.023
lb/hr	27.4	22.0	27.0	25.5
lb/MBTU	0.07	0.05	0.07	0.06
Nitrogen Oxide Emissions				
ppm	*60	119	123.8	
lb/MBTU	*0.10	0.17	0.19	0.18

*Invalid Data

TABLE III

Average Boiler Operating Data for Test Periods
Steam Generator Nos. 25, 27

	<u>Test 1</u>	<u>Test 2</u>	<u>Test 3</u>
Date	12/5/72	12/7/72	12/7/72
Gross Load, MW	7.0	7.7	7.2
Steam Flow, lb/hr, 25 blr. 27 blr.	129,000 132,800	126,800 142,300	125,200 140,000
Oil Flow, gal/hr, 25 blr. 27 blr.	1336 1337	1353 1462	1296 1390
Excess O ₂ (%)	10.9	10.5	10.5
Soot Blowing	None	None	None
Additive Rate ("CHESCO")	2000:1	2000:1	2000:1
Stack Gas Temperature OF	371.6	376.3	375.7
Gas Density lb/ft. ³	0.049	0.049	0.049

TABLE IV (a)

Ultimate Analysis Of
Representative Fuel Oil Samples

January 3, 1973

FUEL ENGINEERING COMPANY

254021

DATE

FUEL TESTING DEPARTMENT

REPORT NUMBER

FUEL OIL TEST REPORT

Your P.C. No.

Degrees A.P.I., 60°F	25.4
Specific Gravity, 60°F	0.9018
Flash Point °F	OVER 230
Bottom Sediment (incl. water)	0.60
Sulphur % D-1552	0.46
B.T.U. Per Pound D-240	19062
B.T.U. Per Gallon	143156
Viscosity @ 122°F SSF	56.3
Ash	.029

On Sample Marked Oil - Steel Point Special Test

Sampling Date 12-5-72

Supplier's Name

Sample Taken by You
Us

Received from United Illuminating Company
80 Temple Street
New Haven, Connecticut 06506
Attn: Mr. A. Henriksen

Ultimate: Carbon = 85.81%
Hydrogen = 12.83%
Nitrogen = 0.24%
Oxygen = 0.66%
Vanadium = 4 PPM
Sodium = 47 PPM

Fuel Engineering Company of New York

by: *H. Gould*

TABLE IV (b)

Analysis Of
Representative Fuel Oil Samples

Dec 22, 1972

DATE

CORRECTED REPORT

FUEL ENGINEERING COMPANY

FUEL TESTING DEPARTMENT

FUEL OIL TEST REPORT

254022

REPORT NUMBER

Your P.O. No.

Degree A.P.I., 60°F	
Specific Gravity, 60°F	
Flash Point °F	
Bottom Sediment (incl. water)	
Sulphur %	0.35
B.T.U. Per Pound	19220
B.T.U. Per Gallon	
Viscosity @	

On Sample Marked Oil - Steel Point Special Test

Sampling Date 12-6-72

Supplier's Name

Sample Taken by You
Us

#25-#27

Received from United Illuminating Company
80 Temple Street
New Haven, Connecticut 06506
Attn: Mr. A. Henrikson

Fuel Engineering Company of New York

by: *A. J. Van Slyke*

TABLE IV (c)

Analysis Of
Representative Fuel Oil Samples

FUEL ENGINEERING COMPANY

254023

Dec 22 1972
DATE

FUEL TESTING DEPARTMENT

REPORT NUMBER

FUEL OIL TEST REPORT

Your P.O. No.

Degree API, 60 F	
Specific Gravity, 60 F	
Flash Point F	
Bottom Sediment (incl. water)	
Sulphur %	D-1.550 0.50
B.T.U. Per Pound	19280
B.T.U. Per Gallon	
Viscosity @	

On Sample Marked Oil - Steel Point Special Test

Sampling Date 12-7-72

Sample Taken by You Us


Supplier's Name


25 - # 27

Received from United Illuminating Company
80 Temple Street
New Haven, Connecticut 06506
Attn: Mr. A. Henricksen

Fuel Engineering Company of New York

by





THE UNITED ILLUMINATING COMPANY
 TYPICAL SAMPLING TRAIN
 FIGURE 1

- 1) Filter
- 2) Box Thermometer
- 3) Gas Thermometer
- 4) Particulate Filter
- 5) Tapress (Greenberg Smith)
- 6) Thermocouple
- 7) Check Valve
- 8) Dry Foot Cord
- 9) Vacuum Gauge
- 10) Coarse Flow Adjust Valve
- 11) Fine Flow Adjust Valve
- 12) Gas Meter
- 13) Vacuum Pump
- 14) Filter
- 15) Dry Gas Meter
- 16) Gas Inlet
- 17) Pressure Transmitter
- 18) Selector Valve
- 19) Filter
- 20) Potentiometer
- 21) Thermocouple

Leeds & Northrup 8695-2, I.C. Temperature-Potentiometer

Moisture Determination

Moisture determination in stack gas is used in the calculation of isokinetic conditions. The amount of moisture in the stack gas was found by using the following procedure.

The gas sample is aspirated through a pyrex glass probe which is electrically heated and encased in a stainless steel tube. The probe is inserted into the flue gas duct and heated electrically using a variable transformer. The gas sample is drawn through the probe, and through a glass pre-weighed tube filled with silica gel. From the silica gel tube the gas passes through a rotometer, through the aspirating pump, and through a dry gas meter, and passes into the atmosphere. The rotometer is used to control the flow rate of the gas. By averaging the temperature of the gas through the dry gas meter, and recording the volume of gas passed through the meter, the amount of moisture can be determined.

The volume of water absorbed by the silica gel tube is converted to the vapor state by using the ideal gas law equation:

$$V_{wt} = \frac{MaRT_m}{P_m M_w}$$

where M_a = mass or weight of water absorbed, grams
 R = gas law constant, $21.83 \frac{\text{in Hg} - \text{FT}^3}{\text{lb mol} - ^\circ\text{R}}$

T_m = average outlet temperature of the dry gas meter, $^\circ\text{R}$

P_m = barometric pressure, in Hg

M_w = 18 lb/lb mol

The proportion by volume of the stack gas that is water vapor (B_{ws}) is found by using the equation:

$$B_{ws} = \frac{\text{Amount of water absorbed in the silica gel tube}}{\text{Amount of water absorbed} + \text{Amount of metered gas}}$$

Orsat Analysis

A Burrell Gas Analyzer was used to determine O_2 , CO_2 , CO , and N_2 concentrations of the flue gas. The gas sample was aspirated through a stainless steel probe, packed with glass wool at the inlet of the probe. Teflon tubing connected the stainless steel probe to the orsat analyzer. After a sufficient sample was drawn through the probe, tubing, and orsat manifold, a sample of gas was analyzed.

Velocity Traverse

A preliminary velocity traverse was made of the flue gas duct in order to determine a correct nozzle size used in determining particulate concentrations with the RAC Staksamplr. It was noted that three traverse points had a negative delta "P". These three areas, located at port 1, point 1, and at port 5, points 1 and 2, were not used in the test for particulates. Instead of using 50 traverse and sampling points, only 47 sampling points were used.

Since three traverse points indicated negative delta "P", the total cross-sectional area of the flue gas duct was also reduced by the amount of the area occupied by these three sampling areas. The cross-sectional area of the duct was therefore reduced from 64.9Ft² to 61.0Ft².

Particulate Determination

The apparatus used in determining particulate emissions was a RAC Staksamplr Model 2343-5, Serial No. 1399. The procedure followed in this test is Method 5 of the Federal Register, Vol. 36, No. 247, December 23, 1971.

Used in this test was a 10 foot stainless steel probe and pitot tube, calibrated by The Research Corporation of New England. The pitot tube coefficient obtained from the calibration of this pitot tube was 0.819.

Two modifications were made to the RAC Staksamplr by the United Illuminating Company. The heated box housing the four-inch fiber filter was fitted with a 0°-300° F indicating thermometer. This enabled the equipment operator to be aware of the exact box temperature during the sampling period.

Also modified was the glass elbow from the filter to the first impinger. This was fitted with a tee connection into which a thermometer with a glass ground joint was inserted. This enabled the operator to check the gas temperature leaving the filter and make any corrections if need be in the probe heating transformer.

After running one test for particulate concentrations, it was found that the amount of silica gel in the fourth impinger had nearly been spent. To insure in future runs of this test that the effectiveness of the silica gel would not be depleted, 300 grams instead of 200 grams was used. This was found to give a greater margin of safety in making sure that there was no moisture carry-over into the dry gas meter.

NO_x Determination

Nitrogen oxides were determined by using a Dynascience NO_x Analyzer, Model NX-130, Serial No. 418. A stainless steel probe,

packed with glass wool at the inlet, was inserted approximately three feet into the center of the flue gas duct. After calibrating the instrument with a known concentration of NO gas, the flue gas sample was drawn through the instrument which gave a direct readout on the meter scale. The instrument was operated for fifteen minutes for each test, with readings taken every minute. At the conclusion of the test, the NO_x concentrations in PPM were averaged, and used in the final NO_x calculations.

THE UNITED ILLUMINATING COMPANY

SOURCE TESTING CALCULATION FORMS

Test No. S.P. 25, 27 No. Runs 3

Name of Firm The United Illuminating Company

Location of Plant Steel Point Station, Bridgeport

Type of Plant Steam Generating Station

Control Equipment Electrostatic Precipitators

Sampling Point Locations Flue Gas Duct After Precipitators

Pollutants Sampled Particulates, Nitrogen Oxides

Time of Particulate Test:

Run No. 1 Date 12/5/72 Begin 1517 End 1939

Run No. 2 Date 12/7/72 Begin 1051 End 1522

Run No. 3 Date 12/7/72 Begin 1656 End 2113

PARTICULATE EMISSION DATA

Run No.	1	2	3	
$K_p = 85.48 \frac{ft}{sec} \left(\frac{lb.}{lb \text{ mole} \cdot ^\circ R} \right)^{\frac{1}{2}}$	85.48	85.48	85.48	
$C_p =$ Pitot tube coefficient (calib.)	0.319	0.819	0.819	
$\sqrt{\Delta P} =$ Average velocity head of stack gas, inches H ₂ O	0.905	0.845	0.851	
$\bar{T}_s =$ Average stack temp., °R	831.6	836.3	835.7	
$P_b =$ Barometric pressure, "Hg Abs.	30.13	30.54	30.58	
$P_d =$ Gas duct pressure, "H ₂ O	-1.4	-1.04	-0.97	
$P_s =$ Absolute stack gas pressure, inches Hg	30.08	30.46	30.51	
$B_{ws} =$ % moisture in stack gas, by volume	7.5	8.2	7.8	
$M_d =$ Molecular weight of stack gas, dry	29.59	29.62	29.65	
$M_s =$ Molecular weight of stack gas	28.72	28.57	28.74	

V_s = Stack gas velocity, F.P.S.	62.15	57.86	59.15
% CO ₂	7.23	7.50	7.79
% O ₂	10.92	10.50	10.50
% CO	0.00	0.02	0.07
% N ₂	81.85	31.97	81.72
V_{lc} = Total volume of liquid collected in impingers and silica gel, ml.	303	308.6	293.7
V_m = Volume of dry gas sampled at meter conditions, FT ³	174.79	169.14	159.96
V_{std} = Volume of dry gas sampled at STP, FT ³	176.73	164.24	164.65
T_m = Average dry gas meter temp., °R	531.4	559.7	559.1
ΔH = Average pressure drop across orifice, inches H ₂ O	2.15	2.01	2.00
θ = Total Sampling Time, min.	235	235	235
D_n = Nozzle dia., inches	0.250	0.250	0.250
A_n = Nozzle area, FT ²	0.00034	0.00034	0.00034
I = % of isokinetic sampling	100.16	99.97	99.10
Q_s = Stack gas volume at STP (SCFM)	134,816	125,426	126,902
Q_a = Stack gas volume at stack conditions (ACFM)	227,482	211,751	212,613
W_s = Stack gas mass flow lbs/hr	620,084	577,477	534,367
M_p = Particulate-probe, washings, mg	210.8	162.9	211.2
M_f = Particulate-filter (mg)	61.3	55.6	53.5
M_n = Particulate-total (mg)	272.1	218.5	264.7
$C's$ = Particulate Concentrations gr/scf	0.024	0.020	0.025
C_w = Particulate total emission lb/hr	27.4	22.0	27.0
E_r = Particulate emission rate, lb/10 ⁶ BTU	0.07	0.05	0.07
C = NO _x concentrations, PPM	*50	119.0	123.9
C_n = NO _x , lb/10 ⁶ BTU	*0.10	0.17	0.19

Stack Identification Number _____ Date Dec. 5, 1972


Boiler Number 25-27 Time 11:00

Plant Location Steel Point

Sampling Point Location _____

Chemical Analysis

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt/mole (dry)
CO ₂ , % Vol (dry)	6.8	7.5	7.2	7.4	7.225	44/100	3.179
CO, % Vol (dry)	18.0	18.4	18.0	18.2	0	28/100	+ 0
O ₂ , % Vol (dry)	18.6	18.4	18.0	18.2	10.925	32/100	+ 3.494
H ₂ , % Vol (dry)	82.0	81.6	82.0	81.8	81.85	28/100	+ 22.918
O ₂	11.2	10.9	10.8	10.8	10.9		
Avg. molecular wt. of dry stack gas =							29.593



THE UNITED ILLUMINATING COMPANY
ORSAT DATA & CALCULATION SHEET

Stack Identification Number _____

Date Dec. 6, 1972

Boiler Number 25-27

Time 11:00 AM

Plant Location Steel Point

Sampling Point Location Port 3 - 3 feet in

Continued from page 1

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt/mole (dry)
CO ₂ , % Vol (dry)	7.5	7.4	7.6	7.5	7.50	44/100	3.30
CO, % Vol (dry)	17.8	18.1	18.0	18.2	18.02	28/100	0
O ₂ , % Vol (dry)	17.8	18.0	18.0	18.2	18.05	32/100	3.36
N ₂ , % Vol (dry)	82.2	81.9	82.0	81.8	81.97	28/100	22.95
	10.30	10.60	10.40	10.70	10.5		
							29.613

Avg. molecular wt. of dry stack gas =

BIRS 25/27
NOx RUN #1
12-5-72

determination by Portable DynaScience
NOx Monitor

10:55 AM MAX NOx Reading = 12%
scale calibration = 100% = 500 PPM

$$\therefore \frac{12}{100} = \frac{x}{500} \quad \frac{60}{100/6000}$$

x = 60 PPM

Sample out temp to inst = 77°F.

11:00 AM NOx Reading = 11%
 $\therefore x = 55 \text{ PPM}$

60 PPM NOx = Max observed.

Note: Probe inserted into Port #3
Distance in 2 1/2 feet.

Disregard due to air leak
in manifold line

NOx 2

BLRS 25, 27.
DEC 6, 1972.

NOx, Run 2

INSERTION POINT: PORT 3, 3 FT IN.

RECALIBRATED DYNASCIENCE (C) FIELD
CONDITIONS

ZERO = 4.87 SPAN = 4.7
SCALE: 0-100% = 0-500 PPM.

TIME	READINGS		
11:45	24%	=	120 PPM
11:46	24%	=	120 PPM
11:47	23.75%	=	118 PPM
11:48	24%	=	120 PPM
11:49	24%	=	120 PPM
11:50	24%	=	120 PPM
11:51	24%	=	120 PPM
11:52	23.75%	=	118 PPM
11:53	23.75%	=	118 PPM
11:54	23.5%	=	117.5 PPM
11:55	23.75%	=	118 PPM
11:56	23.75%	=	118 PPM
11:57	23.75%	=	118 PPM
11:58	24%	=	120 PPM
11:59	24%	=	120 PPM

Avg = 119 PPM

NOX RUN # 3
DEC 6, 1972

3:25 PM

Point # 3 - 3 ft insertion

0-100% = 0-500 PPM

3:25 24% = 120 PPM

3:26 24% = 120 PPM

3:27 24% = 120 PPM

3:28 24.2% = 121 PPM

3:29 24% = 120 PPM

3:30 24.5% = 122 PPM

3:31 25% = 125 PPM

3:32 25% = 125 PPM

3:33 25% = 125 PPM

3:34 25% = 125 PPM

3:35 25% = 125 PPM

3:36 25% = 125 PPM

3:37 25.5% = 127 PPM

3:38 25.3% = 126 PPM

3:39 25.5% = 127 PPM

3:40 25.7% = 128 PPM

Avg = 123.81 PPM

Birs. 25/27

12-5-72

12:30 - 1:00 PM

INITIAL VELOCITY TRAVERSE

TRAVERSE

POINT	DISTANCE	POINT.	AP.	$\sqrt{\Delta P}$
1	14"	1.	NEG	
	25"	2	.25	
	36"	3	.43	
	47"	4	.48	
	58"	5	.54	
	69"	6	.66	
	80"	7	.62	
	91"	8	.50	
	102'	9	.37	
	113"	10	.32	

	14"	1	.62	
	25"	2	.70	
	36"	3	.59	
	47"	4	.63	
	58"	5	.89	
	69"	6	.87	
	80"	7	.93	
	91"	8	.56	
	102'	9	.45	
	113"	10	.52	

TRANSVERSE

PORT	DISTANCE	POINT	AP	VAP.	TEMP
3	14	1	.55		
	25	2	.75		
	36	3	.82		
	47	4	1.1		
	58	5	1.2		379° F
	69	6	1.1		
	80	7	1.2		
	91	8	1.1		
	102	9	.92		
	113	10	.56		

14	1	.14
25	2	.25
36	3	.94
47	4	1.2
58	5	1.2
69	6	1.1
80	7	1.3
91	8	1.2
102	9	1.1
113	10	.5

DATE	DISTANCE	TRAVERSE POINT	AP	VOP
5	14	1	NEG	
	25	2	NEG	
	36	3	.05	
	47	4	.78	
	58	5	.65	
	69	6	.70	
	80	7	.85	
	91	8	1.1	
	102	9	.93	
	113	10	.05	

duct pressure - 1.4" H₂O
 barometer 30.20

Stack Identification Number 25/27

Boiler Number 25-27

Plant Steel / Mill

Run No. 1

Location Steel Paint Stack Duct

Date 12-5-72

Operator JSS

Meter ΔH_2 1.89

C Factor (.91)(.91)(.98)

1.89 ΔH_2 100

Ambient Temp of 46 ^{5:30}

Bar. Press. "Hg 30.18 - 30.73

Assumed Moisture % 6.5

Heater Box Setting, of 275

Probe Tip Dia., in. .25

Probe Length 10'

Probe Heater Setting 50%

Avg $\sqrt{\Delta P}$ 0.905 Avg. ΔH 2.15

Stack Air Pressure: -1.4 in H₂O

I = 100.21

Point	Clock Time	Dry Gas Meter, CF	Pitot in H ₂ O ΔP	Orifice ΔH in H ₂ O Desired	Orifice ΔH Actual	Dry Gas Temp. Inlet	Dry Gas Temp. Outlet	Pump Vacuum In. Hg Gauge	Box Temp. Of	Impinger Temp Of	$\sqrt{\Delta P}$ Stack Press. Hg	Stack Temp Of
1	3:17	235.995	.572	1.3	1.8	90	60	4	248	55	1.226	300
2	3:17	235.995	.572	1.1	2.1	90	60	7	240	55	1.226	300
3	3:17	242.195	1.1	2.8	2.6	90	60	7	240	55	1.226	300
4	3:17	247.2	1.2	3.0	3.1	90	60	7	240	55	1.226	300
5	3:17	251.75	1.3	3.5	3.5	90	60	7	240	55	1.226	300
6	3:17	251.35	1.15	3.0	3.0	90	60	7	240	55	1.226	300
7	3:17	249.0	1.25	3.7	3.7	90	60	7	240	55	1.226	300
8	3:17	248.6	1.1	4.5	4.65	90	60	7	240	55	1.226	300
9	3:17	248.9	1.05	3.6	3.6	90	60	7	240	55	1.226	300
10	3:17	248.12	.69	1.75	1.75	90	60	7	240	55	1.226	300
11	4:16	277.5	.30	.50	.60	91	60	2	270	50	1.226	300
12	4:21	277.1	.32	.50	.51	91	60	2	270	50	1.226	300
13	4:31	281.1	.30	.50	.51	91	60	2	270	50	1.226	300
14	4:31	285.7	.30	.50	.51	91	60	2	270	50	1.226	300
15	4:36	290.34	1.5	3.6	3.6	91	60	5.5	270	55	1.226	300

TEST 1

WEIGHT OF PARTICULATE COLLECTED

mg
 FILTER Paper: Reeve Angel 900HF, 11cm., Glass fiber

CONTAINER NUMBER	FINAL WEIGHT	TARE. WEIGHT	WEIGHT GAIN
Filter	.6592 grams	.5979 grams	.0613 grams
Washings	65.5000 grams	65.2892 grams	.2108
TOTAL	66.1592 grams	65.8871 grams	<u>.2721 grams</u>

VOLUME OF LIQUID WATER COLLECTED, ml

	1	2	3	4
IMPIGNER				
FINAL VOL.	277 ml	182 ml	14 ml	230
INITIAL VOL.	100 ml	100 ml	0	200 g
LIQUID COLLECTED	177 ml	82 ml	14 ml	309 23 ml

Stack Identification Number _____

Boiler Number _____

Plant Steel Point

Run No. 2

Location R115 25/27

Date 12-7-72

Operator JSS

Meter Δ H 1.96

C Factor 92, 94, 1.0, 1.03

Ambient Temp of 50

Bar. Press. "Hg 30.57

Assumed Moisture % 7.5

Heater Box Setting, OF 275

Probe Tip Dia., In. .25

Probe Length 10' S.S.

Probe Heater Setting 550

Avg $\sqrt{\Delta P}$ 0.845 Avg. ΔH 2.01

Stat press -1.04" H₂O

IT = 99.98 %

Point	Clock Time	Dry Gas Meter, CF	Pitot in H ₂ O ΔP	Desired Orifice ΔH in H ₂ O	Actual ΔH	Dry Gas Inlet OF	Dry Gas Outlet Temp.	Pump Vacuum In. Hg Gauge	Box Temp. OF	Impinger Temp OF	$\sqrt{\Delta P}$ in Hg	Stack Temp OF
1	10:51	412.475	.57	.83	.83	55	55	7.2	210	50	.818	357
2	10:57	413.22	.50	1.05	1.05	68	55	7.5	212	50	.787	310
3	11:01	416.72	.50	1.15	1.15	76	56	7.5	255	50	.787	310
4	11:06	419.80	.52	1.50	1.50	81	60	7.5	283	50	.730	362
5	11:11	422.95	.55	1.58	1.58	93	64	2.9	262	50	.742	310
6	11:12	424.20	.57	1.61	1.61	98	68	2.9	260	50	.755	310
7	11:21	429.55	.50	1.95	1.95	100	70	2.8	268	50	.767	305
8	11:26	423.72	.37	1.08	1.08	102	72	2.0	278	50	.668	310
9	11:31	428.50	.35	1.0	1.0	98	75	2.1	266	50	.691	348
10	11:36	429.10	.59	1.7	1.7	97	76	3.1	260	50	.768	310
11	11:41	434.48	.76	2.18	2.18	104	77	3.5	297	50	.812	208
12	11:46	430.76	.54	1.68	1.68	110	81	3.0	272	50	.791	305
13	11:51	438.67	.44	1.6	1.6	110	53	2.6	250	50	.570	260
14	12:02	452.19	.92	2.3	2.3	112	86	3.5	260	50	.900	310

Point	Clock Time	Dry Gas Meter, CF	Pitot in H2O Δ P	Orifice Δ H in H2O		Dry Gas Temp.		Pump Vacuum In. Hg Gauge	Box Temp. OF	Impinger Temp CF	Stack Press in. Hg	Stack Temp CF
				Desired	Actual	Inlet	Outlet					
1	1207	1156.11	1.03	2.52	2.58	114	86	3.6	260	50	1.01	385
2	1212	442.25	1.00	2.50	2.50	118	88	3.8	258	50	1.02	395
3	1217	464.39	1.02	1.57	1.57	118	90	2.8	258	50	1.01	397
4	1222	487.15	1.01	1.22	1.22	114	90	2.1	252	50	1.02	395
5	1227	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
6	1232	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
7	1237	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
8	1242	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
9	1247	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
10	1252	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
11	1257	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
12	1302	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
13	1307	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
14	1312	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
15	1317	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
16	1322	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
17	1327	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
18	1332	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
19	1337	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
20	1342	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
21	1347	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
22	1352	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
23	1357	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
24	1362	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
25	1367	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
26	1372	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
27	1377	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
28	1382	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
29	1387	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
30	1392	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
31	1397	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
32	1402	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
33	1407	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
34	1412	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
35	1417	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
36	1422	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
37	1427	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
38	1432	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
39	1437	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
40	1442	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
41	1447	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
42	1452	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
43	1457	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
44	1462	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
45	1467	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
46	1472	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
47	1477	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
48	1482	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
49	1487	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397
50	1492	470.61	1.01	1.18	1.08	112	91	2.1	278	50	1.02	397

TEST 2

WEIGHT OF PARTICULATE COLLECTED

mg.

Water Purifier: Reverse Annual 900 A.F. 11 CM Glass Filter

CONTAINER NUMBER	FINAL WEIGHT	TARE WEIGHT	WEIGHT GAIN
Filter	.6705 grams	.6149 grams	.0556 grams
Washings	65.2710 grams	65.1081 grams	.1629 grams
TOTAL	65.9415 grams	65.7230 grams	.2185 grams

VOLUME OF LIQUID WATER COLLECTED, ml

INDICATOR	1	2	3	4
FINAL VOL.	273	180 ml	13 ml	342.6
INITIAL VOL.	100 ml	100 ml	0 ml	300.0 g
LIQUID COLLECTED	173	80 ml	13 ml	42.6 g 342.6 ml

Stack Identification Number

Boiler Number 25-27

Plant Steel Point

Run No. 3

Location Stack Inlet duct

Date 12-7-72

Operator Sculati

Meter Δ H 1.92

C Factor 96

Ambient Temp of 60

Bar. Press. "Hg 30.58

Assumed Moisture % 8

Heater Box Setting, OF 275°

Probe Tip Dia., In. .25"

Probe Length 10'

Probe Heater Setting 55%

Avg Δ P .851 Avg. Δ H 2.00

duct press = -.97" H2O
I = 98.888%

Point	Clock Time	Dry Gas Meter, CF	Pitot in H2O Δ P	Orifice Δ H in H2O Desired	Orifice Δ H Actual	Dry Gas Inlet	Dry Gas Temp. Outlet	Pump Vacuum In. Hg Gauge	Box Temp. OF	Impinger Temp OF	Stack Press. In. Hg	Stack Temp OF
1	---	580.824	None	---	---	---	---	---	---	---	---	---
2	11:56	580.814	.05	1.8	1.8	74	74	2.2	282	55	1.87	285
3	12:01	581.53	.72	1.82	1.82	78	74	3	290	50	1.98	353
4	12:06	580.26	.16	1.2	1.2	94	76	2.5	250	50	1.77	283
5	12:11	580.28	.70	1.5	1.5	101	78	3.1	270	50	1.88	284
6	12:16	591.23	.48	1.2	1.2	108	81	2.5	287	50	1.78	285
7	12:21	574.89	1.15	2.9	2.9	110	84	4.5	260	50	1.67	285
8	12:26	584.24	1.2	3.05	3.05	116	86	4.8	250	50	1.69	283
9	12:31	588.35	1.12	2.15	2.15	117	88	1.5	265	50	1.34	285
10	12:35	581.542	---	---	---	---	---	---	---	---	---	---
11	12:40	580.504	.17	1.5	1.5	106	88	1.5	280	50	1.71	285
12	12:45	580.29	.23	1.72	1.72	101	88	2.0	281	50	1.57	285
13	12:50	580.76	1.05	2.6	2.6	108	89	4.0	281	50	1.63	285
14	12:55	613.281	1.5	3.8	3.8	121	90	5.3	280	50	1.27	286
15	1:00	618.83	1.6	4.0	4.0	127	94	5.8	282	50	1.26	285

Point	Clock Time	Dry Gas Meter, CF	Pitot in H ₂ O Δ P	Orifice Δ H in H ₂ O Desired	Orifice Δ H Actual	Dry Gas Inlet	Dry Gas Temp. Outlet	Pump Vacuum In. Hg Gauge	Box Temp. OF	Impinger Temp OF	W/P Stack Inlet	Stack Temp OF
1	1832	646.007	1.82	4.83	4.63	126	92	2.1	262	50	1.14	302
2	1832	659.471	1.82	2.75	2.75	126	90	2.4	252	50	1.17	358
3	1847	658.561	1.79	3.18	3.18	119	90	1.5	267	50	1.62	352
4	1850	658.561	1.6	3.5	3.5	119	90	5.2	246	50	1.12	320
5	1850	658.561	1.2	3.0	3.0	121	91	4.8	245	50	1.01	311
6	1902	659.96	1.85	3.0	3.0	121	92	4.9	220	50	1.12	325
7	1901	672.681	1.2	3.0	3.0	121	92	4.9	155	50	1.04	321
8	1912	658.561	1.82	2.1	2.1	116	92	3.7	250	50	1.07	322
9	1919	658.561	1.70	1.78	1.98	116	92	3.5	255	50	1.10	325
10	1935	659.881	1.6	1.8	1.8	92	85	3.2	285	50	1.13	357
11	1935	693.26	1.6	2.1	2.1	102	86	3.5	292	50	1.15	360
12	1935	693.26	1.6	2.1	2.1	102	85	3.0	265	50	1.00	332
13	1935	693.26	1.6	1.64	1.64	110	86	3.1	252	50	1.08	341
14	1935	693.26	1.6	2.45	2.45	112	86	4.0	266	50	1.02	342
15	1935	693.26	1.6	2.15	2.15	115	86	4.0	283	50	1.02	345
16	2000	708.581	1.62	2.1	2.1	118	88	4.2	288	50	1.08	346
17	2010	711.59	1.65	1.67	1.67	115	88	4.1	268	50	1.08	344
18	2015	720.11	1.63	1.7	1.7	115	88	2.5	290	50	1.27	344
19	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
20	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
21	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
22	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
23	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
24	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
25	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
26	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
27	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
28	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
29	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
30	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
31	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
32	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
33	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
34	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
35	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
36	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
37	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
38	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
39	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
40	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
41	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
42	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
43	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
44	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
45	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
46	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
47	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
48	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
49	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
50	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
51	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
52	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
53	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
54	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
55	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
56	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
57	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
58	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
59	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
60	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
61	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
62	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
63	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
64	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
65	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
66	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
67	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
68	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
69	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
70	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
71	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
72	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
73	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
74	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
75	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
76	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
77	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
78	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
79	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
80	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
81	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
82	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
83	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
84	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
85	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
86	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
87	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
88	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
89	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
90	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
91	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
92	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
93	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
94	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
95	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
96	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
97	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
98	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
99	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348
100	2020	722.24	1.47	1.2	1.2	108	88	2.5	285	50	1.35	348

TEST 3

WEIGHT OF PARTICULATE COLLECTED

mg

Filter Paper: Rose Brand 900AF, 11cm Glass Fiber

CONTAINER NUMBER	FINAL WEIGHT	TARE WEIGHT	WEIGHT GAIN
1 Filter	.6512 grams	.5977 grams	.0535 grams
2 Washings	63.3098 grams	63.0976 grams	.2122 grams
TOTAL	63.9610	63.6953 grams	.2647 grams

VOLUME OF LIQUID WATER COLLECTED, ml

INSTRUMENT	1	2	3	4
FINAL VOL.	266 ml	172 ml	13 ml	342.7
INITIAL VOL	100 ml	100 ml	0 ml	300.0 g
LIQUID COLLECTED	166 ml	72 ml	13 ml	42.7 g 293.7 ml

OIL FLOW CALCULATIONS

EST 1

#25	:	1336 gal/hr	
#27	:	1337.5 gal/hr	
		2673.5 gal/hr	$\times 143,156 \text{ BTU/gal}$
			$= 385.7 \times 10^6 \text{ BTU/hr}$

EST 2

#25	:	1353.25 gal/hr	
#27	:	141.25 gal/hr	
		2815.5 gal/hr	$\times 144,342 \text{ BTU/gal}$
			$= 406.4 \times 10^6 \text{ BTU/hr}$

EST 3

#25	:	1296 gal/hr	
#27	:	1390 gal/hr	
		2686 gal/hr	$\times 144,793 \text{ BTU/gal}$
			$= 388.9 \times 10^6 \text{ BTU/hr}$

N

Stack Identification Number BLR 35, 27 STACK 7 Date 12-5-72

Boiler Number _____

Plant Location STEEL FRONT 3:00 TO 8:00

Parameters	# 25	# 27	# 25	# 27	25	27	25	27
Gross Load (MW)	10:00 MW		7.5		7.5		7.4	
Net Load (MW)	10:12	10:10			12:12	12:10	1:12	1:10
Fuel Flow (gal/hr)	7554596	9806320			7552265	9809180	7558630	78105
Steam Flow (lb/hr)	128,000	139,000	129,000	139,000	129,000	138,000	129,000	138,000
Feed Water Flow (lb/hr)								
Air Flow	168,000	151,000	170,000	151,000	170,000	151,000	170,000	151,000
Excess Air (%)	43	38.5	43	38.5	43.25	38.5	43.0	43.0
Excess O2 (%)	8.6%	7.7%	8.6	7.7	8.65	7.7	8.60	7.8
Soot Blowing								
Boiler Inlet Feed Water Temp (°F)	975	975	975	950	975	980	975	970
Boiler Inlet Steam Press. (psig)	640		640		638		632	
Boiler Inlet Steam Temp (°F)								
Boiler Inlet Steam Press. (psig)								
Boiler Inlet Steam Temp (°F)								
Boiler Inlet Steam Press. (psig)								
Boiler Inlet Steam Temp (°F)								

10:10 11:00 12:00 1:00

	20	21	22	23	24	25	26	27
Barometers								
Cooling Water Temp (OF)								
Boiler Air Inlet Temp (OF)								
Boiler Flue Gas Exit Temp (OF)								
F.D. Fan Pressure-3150- (in H2O)	9.0	6.3	9.0	6.8	9.0	6.8	9.0	6.8
F.D. Fan Current (amps)								
F.D. Fan Voltage (V)								
ID Fan Pressure Rise (in H2O)								
ID Fan Current (amps)								
ID Fan Voltage (V)								
Forced Draft Inlet Air Temp (OF)								
Ambient Air Relative Humidity								
Barometric Pressure (in Hg)	30.22	—	30.11	30.12	30.11	30.12	30.19	30.19
Ambient Air Temp (OF)								
Boiler Heat Rate (BTU/KW-hr)								
Burner Tilt								
Inlet Temp (OF)								
Outlet Temp (OF)								
Inlet Pressure (in H2O)								
Heating Cycle Period (min)								
Spark Rate (sparks/min)								
Operating Voltage (KV)								
Operating Amps	2.9	2.4	5%	2%	5%	2.5%	5%	2.9

Track Identification Number 13105 21500 5000 Date 12-5-72

Boiler Number _____ Plant Location 57504 01 200 300 400 500

Parameters	25	27	35	27	25	27	25	27
Gross Load (MW)	7.2	7.1	7.1	7.1	7.1	7.1	7.1	7.1
Net Load (MW)	2:12	2:10	3:12	3:10	4:12	4:10	5:12	5:10
Fuel Flow (gal/hr)	7559954	9811778	7561337	9813351	7562681	9814711	7564017	9816053
Steam Flow (lb/hr)	128000	137000	128000	135000	129000	135000	129000	134000
Feed-water-Flow (330/hr)								
Air Flow	170000	157000	170000	151000	170000	157000	170000	157000
Excess Air (%)	43.5	40.0	43.5	40.5	44.0	41.0	44.5	41.5
Excess O2 (%)	8.7	8.0	8.7	8.1	8.8	8.2	8.9	8.3
Soot Blowing								
Boiler Inlet Feed Water Temp (°F)	975	975	950	975	990	1000	1000	1000
Boiler Exit Steam Press. (psig)	622		620		620		610	
Boiler Inlet Steam Temp (°F)								
Boiler Inlet Steam Press. (psig)								
Boiler Exit Steam Temp (°F)								
Boiler Exit Steam Press. (psig)								
Boiler Inlet Steam Temp (°F)								
Boiler Inlet Steam Press. (psig)								
Boiler Exit Steam Temp (°F)								
Boiler Exit Steam Press. (psig)								
Boiler Inlet Steam Temp (°F)								
Boiler Inlet Steam Press. (psig)								
Boiler Exit Steam Temp (°F)								
Boiler Exit Steam Press. (psig)								
Condenser Pressure (in Hg)								

Boiling-Water Temp (OF)									
Boiler Air Inlet Temp (OF)									
Boiler Flue Gas Exit Temp (OF)									
I.D. Fan Pressure Rise (in H2O)	9.0	6.8	9.0	6.8	9.0	6.8	9.1		
S.D. Fan Current (amps)									
S.D. Fan Voltage (V)									
I.D. Fan Pressure Rise (in H2O)									
I.D. Fan Current (amps)									
I.D. Fan Voltage (V)									
Forced Draft Inlet Air Temp (OF)									
Ambient Air Relative Humidity									
Barometric Pressure (in Hg)	30.19	30.19	30.19	30.19	30.20	30.20	30.21		
Ambient Air Temp (OF)									
Boiler Heat Rate (Btu/hr-hr)									
Burner Tilt									
Inlet Temp (OF)									
Outlet Temp (OF)									
Inlet Pressure (in H2O)									
Trapping Cycle Period (min)									
Spark Rate (sparks/min)									
Operating Voltage (KV)									
Operating Amps									

68

Stack Identification Number BLRS 250111 Stack # 47 Date 12-5-72

Boiler Number _____

Plant Location 5785C PT 630 700 800

Parameters	700	800
Gross Load (MW)	2.0	2.7
Net Load (MW)	6.72	6.48
Fuel Flow (gal/hr)	7565353	9872390
Steam Flow (lb/hr)	139000	112000
Feedwater Flow (lb/hr)		
Air Flow	172000	151000
Excess Air (%)	44.0	40.5
Excess O2 (%)	5.8	8.5
Soot Blowing		
Boiler Inlet Feed Water Temp (°F)	1000	1000
Boiler Inlet Feed Water Press. (psig)	610	600
Boiler Exit Steam Temp (°F)		
Boiler Exit Steam Press. (psig)		
Reheat Inlet Steam Temp (°F)		
Reheat Inlet Steam Press. (psig)		
Reheat Inlet Steam Temp (°F)		
Reheat Inlet Steam Press. (psig)		
Reheat Exit Steam Temp (°F)		
Reheat Exit Steam Press. (psig)		
Condenser Pressure (in Hg)		

cooling-water Temp (°F)									
Boiler Air Inlet Temp (°F)									
Boiler Flue Gas Exit Temp (°F)									
F.D. Fan Pressure Rise (in H2O)	9.1	6.8	9.0	6.8	9.0	6.8			
F.D. Fan Current (amps)									
F.D. Fan Voltage (V)									
ID Fan Pressure Rise (in H2O)									
ID Fan Current (amps)									
ID Fan Voltage (V)									
Forced Draft Inlet Air Temp (°F)									
Ambient Air Relative Humidity									
Barometric Pressure (in Hg)	30.24		30.26						
Ambient Air Temp (°F)									
Boiler Heat Rate (BTU/MM-HR)									
Burner Tilt									
Inlet Temp (°F)									
Outlet Temp (°F)									
Inlet Pressure (in H2O)									
Rapping Cycle Period (min)									
Spark Rate (sparks/min)									
Operating Voltage (KV)									
Operating Amps	22	52	21	57					

Task Identification Number

47

Date 12-6-72

Boiler Number 25427

Plant Location STEEL Bldg

1000

1300

1000

200

Parameter	25	27	25	27	25	27	25	27	25	27
Gross Load (MW)	2.6	2.6	2.3	2.3	2.8	2.8	2.8	2.8	2.8	2.8
Net Load (MW)	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2	1.2
Fuel Flow (gal/hr)	1578134	1307449	7522477	832178	7580860	7833665	1550000	1550000	1550000	1550000
Steam Flow (lb/hr)	120000	147000	125000	138000	128000	141000	149000	149000	149000	149000
Food Water Flow (lb/hr)										
Air Flow	158000	149000	168000	145000	161000	149000	149000	167000	167000	167000
Excess Air (%)	42.0	28.0	41.5	38.25	46.75	35.5	40.0	40.0	40.0	40.0
Excess O2 (%)	8.4	7.6	8.3	7.75	8.15	7.1	8.0	8.0	8.0	8.0
-SO2 Blowing										
Boiler Inlet Food Water Temp (°F)	975	1000	950	980	950	980	950	975	975	1000
Boiler Exit Steam Press. (psig)	648		630		650		650		648	
Boiler Exit Steam Temp (°F)										
Condensate Inlet Steam Press. (psig)										
Condensate Inlet Steam Temp (°F)										
Condensate Exit Steam Press. (psig)										
Condensate Exit Steam Temp (°F)										
Condensate Pressure (in Hg)										

Parameters	25	27	25	27	25	27	25	27
Cooling-Water Temp (°F)								
Boiler Air Inlet Temp (°F)								
Boiler Flue Gas Exit Temp (°F)								
D. Fan Pressure Rise (in H2O)	8.9	6.8	8.8	6.8	8.8	6.8	8.8	6.8
D. Fan Current (amps)								
D. Fan Voltage (V)								
ID Fan Pressure Rise (in H2O)								
ID Fan Current (amps)								
ID Fan Voltage (V)								
Forced Draft Inlet Air Temp (°F)								
Ambient Air Relative Humidity								
Barometric Pressure (in Hg)	30.00	—	29.96	—	29.96	—	29.96	—
Ambient Air Temp (°F)								
Boiler Heat Rate (Btu/hr-hr)								
Burner tilt								
Inlet Temp (°F)								
Outlet Temp (°F)								
Inlet Pressure (in H2O)								
Reaping Cycle Period (min)								
Spark Rate (sparks/min)								
Operating Voltage (KV)								
Operating amps								

Stack Identification Number

27

Date 10-6-72

Boiler Number

25 4 27

Plant Location

57246 P-E

300

400

500

Parameters	25	27	25	27	25	27
Gross Load (MW)	2.7	2.7	2.7	2.7	2.7	2.7
Net Load (MW)	3.2	3.2	4.1	4.1	5.2	5.10
Fuel Flow (gal/hr)	758217	9826560	7384926	7837972	7586281	5394137
Steam Flow (lb/hr)	1700000	1440000	1280000	1410000	1090000	1410000
Food-Water-Flow (lb/hr)						
Air Flow	157000	148000	169000	148000	157000	148000
Excess Air (%)	4.0	5.675	39.5	36.0	40.0	36.0
Excess O2 (%)	8.0	7.35	7.9	7.2	18.0	7.2
Soot-Blowing						
Boiler Inlet Feed Water Temp-(°F)	170	1000	975	990	975	1000
Boiler Exit Steam Press. (psig)		648		645		645
Boiler Exit Steam Temp (°F)						
Reheat Inlet Steam Press. (psig)						
Reheat Inlet Steam Temp (°F)						
Reheat Exit Steam Press. (psig)						
Reheat Exit Steam Temp (°F)						
Condenser Pressure (in Hg)						

Boiling-Water Temp (°F)									
Boiler Air Inlet Temp (°F)									
Boiler Flue Gas Exit Temp (°F)									
D. Fan Pressure Rise in H2O	88	6.8	81	6.8	87	6.8			
D. Fan Current (amps)									
D. Fan Voltage (V)									
D Fan Pressure Rise (in H2O)									
D Fan Current (amps)									
D Fan Voltage (V)									
Correct Draft Inlet Air Temp (°F)									
Ambient Air Relative Humidity									
Barometric Pressure (in Hg)	29.88		29.86		29.83				
Ambient Air Temp (°F)									
Boiler Heat Rate BTU/Hr-hr)									
Boiler Flue									
Inlet Temp (°F)									
Outlet Temp (°F)									
Inlet Pressure (in H2O)									
Operating Cycle Period (min)									
Spark Rate (sparks/min)									
Increasing Voltage (W)									
Decreasing Amps	54	53	51	47	57	47			

Back Identification Number

25-1-27

Date 12-7-72

Plant Location

57866

12.00

2.00

PARAMETERS	25	27	25	27	25	27	25	27
Gross Load (MW)	3.7	7.8	7.8	7.8	7.8	7.8	7.8	7.8
Net Load (MW)	11.12	12.12	12.10	11.12	11.12	11.12	11.12	11.12
Fuel Flow (gal/hr)	1598466	9852513	7547711	1853960	2211472	9255396	7602537	5856906
Steam Flow (lb/hr)	128000	110000	128000	119000	127000	144000	126000	142000
Feed Water Flow (lb/hr)	165000	120000	148000	153000	148000	152000	167000	152000
Air Flow	43.0	39.0	42.75	39.0	43.5	38.5	41.0	39.0
Excess Air (%)	8.6	7.8	8.55	7.8	8.7	7.7	8.8	7.8
Excess O2 (%)								
SOOT BLOWING								
Boiler Inlet Feed Water Temp. (OP)	925	1025	975	1025	975	1000	990	1025
Boiler Exit Steam Press. (PSIG)	650		614		650		640	
Boiler Exit Steam Temp (OF)								
HEAT EXCHANGER INLET STEAM PRESS. (PSIG)								
HEAT EXCHANGER INLET STEAM TEMP (OF)								
HEAT EXCHANGER EXIT STEAM PRESS. (PSIG)								
HEAT EXCHANGER EXIT STEAM TEMP (OF)								
CONDENSER PRESSURE (in Hg)								

Poling-Water-Temp (OF)									
High Air Inlet									
High Air Inlet									
High Air Inlet									
D. Fan Pressure Rise (in H2O)	9.2	6.8	9.2	6.8	9.2	6.8	9.2	6.8	9.2
D. Fan Current (amps)									
D. Fan Voltage (V)									
Fan Pressure Rise (in H2O)									
Fan Current (amps)									
Fan Voltage (V)									
Exhaust Inlet									
Fan Temp (OF)									
Exhaust Air Relative									
Humidity									
Exhaust Pressure (in Hg)	30.55		30.54						30.56
Exhaust Air Temp (OF)									
Exhaust Heat Rate									
Exhaust Rate (kW/hr)									
Exhaust Flow									
Exhaust Temp (OF)									
Exhaust Temp (OF)									
Exhaust Pressure (in H2O)									
Exhaust Cycle Period (min)									
Exhaust Rate (sparks/min)									
Exhaust Voltage (KV)									
Exhaust Amperes									

Track Identification Number 2

Date 12/7/72

Boiler Number 25 5 77

Plant Location STEEL POT

300

400

500

600

Parameters	25	27	25	27	25	27	25	27
Gross Load (MM)	7.5	7.7	9.4	7.7	7.4	7.7	7.3	7.7
Net Load (MM)	3.4	3.4	4.4	4.1	5.4	5.4	5.4	6.4
Fuel Flow (gal/hr)	36,387	98,583.62	76,052.15	98,598.1	76,065.45	98,612.76	76,072.34	75,626.12
Steam Flow (lb/hr)	126,000	141,000	126,000	141,000	126,000	141,000	126,000	140,000
Feed Water Flow (lb/hr)								
Air Flow	168,000	152,000	168,000	153,000	168,000	153,000	168,000	152,000
Excess Air (%)	44.0	59.0	41.5	39.0	45.0	39.5	45.0	40.0
Excess O2 (%)	8.8	7.8	8.9	7.8	9.0	7.9	9.0	8.0
<u>Section</u>								
Boiler Inlet Feed Water Temp. (°F)	970	1025	950	1025	980	1025	985	
Boiler Exit Steam Temp. (°F)	640		636		632		630	
Boiler Inlet Steam Temp. (°F)								
Boiler Exit Steam Temp. (°F)								
Condenser Inlet Steam Temp. (°F)								
Condenser Exit Steam Temp. (°F)								
Condenser Pressure (in Hg)								

Cooling Water Temp (OF)								
Oil Inlet Temp (OF)								
Oil Inlet Temp (OF)								
Oil Inlet Temp (OF)								
D. Fan Pressure Rise in H2O	9.2	6.8	9.2	6.8	9.2	6.8	9.2	
D. Fan Current (amps)								
D. Fan Voltage (V)								
D Fan Pressure Rise (in H2O)								
D Fan Current (amps)								
D Fan Voltage (V)								
Record Draft Inlet Air Temp (OF)								
Ambient Air Relative Humidity								
Barometric Pressure (in Hg)			30.58		30.62			
Ambient Air Temp (OF)								
Oil Heat Rate BTU/KW-HR								
Wigner Tilt								
Inlet Temp (OF)								
Outlet Temp (OF)								
Inlet Pressure (in H2O)								
Tripping Cycle Period (min)								
Spark Rate (sparks/min)								
Operating Voltage (KV)								
Operating Amps								

5 2 5 2 6

6.9

Back Identification Number

47

Date 12-7-72

Boiler Number 25-027

Boiler Location STEEL #1

7:20

8:00

9:47 9:48

9:45

Parameters	25	27	25	27	25	27		
Gross Load (MW)	7.3		7.2		7.0			
Net Load (MW)	7.2		8.15		9.47			
Fuel Flow (gal/hr)	2609222	2884150	2610510	2855600	2612485			
Steam Flow (lb/hr)	126,000	140,000	124,000	140,000	131,000			139,000
Feedwater Flow (lb/hr)	168,000	153,000	162,000	153,000	170,000			153,000
Air Flow	45.0	40.0	45.5	41.0	46.5			41.5
Excess Air (%)	9.0	8.0	9.1	8.2	9.3			8.3
Excess O2 (%)								
Boiler Blowdown								
Boiler Inlet Feed Water Temp (°F)	975	1025	1000	1000	1000			1030
Boiler Exit Steam Press. (psig)	630		625		620			
Boiler Exit Steam Temp (°F)								
Boiler Inlet Steam Temp (°F)								
Boiler Inlet Steam Press. (psig)								
Boiler Inlet Steam Temp (°F)								
Boiler Exit Steam Temp (°F)								
Boiler Exit Steam Press. (psig)								
Boiler Exit Steam Temp (°F)								
Boiler Pressure (in. Hg)								

Exhaust Air Inlet (OF)									
Exhaust Air Inlet (OF)									
Exhaust Air Inlet (OF)									
D. Fan Pressure Rise (in H2O)		6.8	9.2	6.9	9.2	6.9			
D. Fan Current (amps)									
D. Fan Voltage (V)									
Fan Pressure Rise (in H2O)									
Fan Current (amps)									
Fan Voltage (V)									
Exhaust Inlet Temp (OF)									
Ambient Air Relative Humidity									
Barometric Pressure (in Hg)			30.70						
Ambient Air Temp (OF)									
Cylinder Heat Rate (BTU/HV-Hr)									
Engine Tilt									
Inlet Temp (OF)									
Outlet Temp (OF)									
Inlet Pressure (in H2O)									
Operating Cycle Period (min)									
Spark Rate (sparks/min)									
Operating Voltage (V)									
Operating Amps	5	2	6	2	6	2			

The United Illuminating Company

Steel Point Station

Boiler No. 26

IT No. 720047

April 9, 1993

PRELIMINARY

THE UNITED ILLUMINATING COMPANY
MOISTURE DETERMINATION
SILICA GEL METHOD

APPENDIX B

Stack Identification Number 7

Date 12-18-72

Boiler Number 26

Operator JTM

Plant Steel Point Station

Amb. Temp. (OF) 45

Location Stack Entry Point

Bar. Press. "Hg In. 1 30.18 → 30.16
Test 2 30.16 → 30.16

	Analysis 1	Analysis 2	Analysis 3
Time	Start	4:120	
Tube	A	B	
Final Wt. Tube, grams	315.0	315.5	
Initial Wt. Tube, grams	308.1	309.1	
Wt. Collected Moisture, (Ma), grams	6.9	6.4	
D GM Final, Ft. 3	1257	12817	
D GM Initial, Ft. 3	1227	1257	
Volume of Gas (Vm), Ft. 3	3.0	3.0	
Avg. Meter Temp. °R	505.5	509	
Vol. of H ₂ O Absorbed (Vwt)	.310	.366	
Water Vapor (%) of Gas (Bws)	9.3%	8.7%	9.0%

MOISTURE DETERMINATION

$$wt = \left[\frac{(6.9 \text{ gr}) \frac{1 \text{ lb}}{454 \text{ gr}}}{(30.17 \text{ in Hg})} \right] \left[\frac{21.83 \text{ in Hg} \cdot \text{ft}^3}{16 \text{ mol} \cdot \text{oz}} \right] (568.5 \cdot R) = 0.310$$

$$\left[\frac{18 \cdot 16}{16 \cdot \text{mol}} \right]$$

$$Bws = \frac{V_{wt}}{V_{wt} + V_m} = \frac{0.093}{0.093 + 0.000} = 9.3\%$$

TIME	INLET TEMP.	OUTLET TEMP.
4:44	48	50
4:54	47	50
4:12	47	50
4:18	47	50
	47	50

= 48.5 + 460 = 508.5°

11#2

4:20	47	50	
4:28	47	49	07
4:36	48	49	43/3.00
4:45	48	50	<u>301</u>
4:54	48	50	
5:02	48	50	
	48	50	∴ 49 + 460 = 509°

MOISTURE DETERMINATION

$$wt = \frac{[(6.4 \text{ gr}) \frac{1 \text{ lb}}{454 \text{ gr}}] \left[\frac{21.83 \text{ in Hg} \cdot \text{ft}^3}{16 \text{ mol} \cdot ^\circ\text{R}} \right] (509 \cdot \text{R})}{(30.15 \text{ in Hg}) \left[\frac{18 \text{ lb}}{16 \text{ mol}} \right]} = .288$$

$$BWS = \frac{V_{wt}}{V_{wt} + V_m} = .087 = 8.7\%$$

INLET TEMP OUTLET TEMP

See other sheet

THE UNITED ILLUMINATING COMPANY

ORSAT DATA & CALCULATION SHEET

Stack Identification Number 7

Date 12-19-72

Boiler Number 26

Time 12:30

Plant Location Steel Plant

Sampling Point Location Stack Entry Duct

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt/mole (dry)
CO ₂ , % Vol (dry)	9.8	9.2	10.3	10.2	10.0	44/100	4.40
CO, % Vol (dry)	17.0	16.2	17.2	17.6	0	28/100	0
O ₂ , % Vol (dry)	17.0	16.8	17.2	17.5	7.15	32/100	2.28
N ₂ , % Vol (dry)	53.0	53.2	53.8	53.4	53.35	28/100	123.19
<u>Humid O₂</u>	7.20	7.00	7.00	7.40			
Avg. molecular wt. of dry stack gas =							29.87

THE UNITED ILLUMINATING COMPANY
ORSAT DATA & CALCULATION SHEET

1557 3

Stack Identification Number _____

Date Dec 21, 1972

Boiler Number 25-227 26

Time 3:15 PM

Plant Location Steel Point

Sampling Point Location Stack Exit Duct

Chemistry Dept

	Analysis 1	Analysis 2	Analysis 3	Analysis 4	Average	X mole wt	wt./mole. (dry)
CO ₂ , % Vol (dry)	10.6	10.7	9.6	10.9	10.45	44/100	4.598
CO, % Vol (dry)	18.2	18.9	19.0	18.0	0.025	28/100	+0.002
O ₂ , % Vol (dry)	18.2	18.0	17.0	18.1	7.4	32/100	+2.342
N ₂ , % Vol (dry)	31.8	31.8	33.0	31.9	52.125	28/100	+22.985
	7.6	7.5	7.4	7.1			
Avg. molecular wt. of dry stack gas =							29.968

TEST 1

IR #26

NOx RUN #1

12-19-72

instrument calibrated at field conditions
with standard NO gas of 420 ppm = 84%
0-500 ppm = 0-100% scale.

4.5 hrs sample out temp 76°

4.15 hrs

	Time	% scale	ppm NOx	sample no.
07	10:26	21.75%	109	78
	10:27	22%	110	78
	10:28	23%	115	79
	10:29	23%	115	80
	10:30	23%	115	80
	10:31	23.8%	119	82
	10:32	23.9%	119.5	82
	10:33	24%	120	83
	10:34	24%	120	84
	10:35	24%	120	84
	10:36	24%	120	85
	10:37	24%	120	86
	10:38	24%	120	87
	10:39	23.9%	119.5	87
	10:40	23.9%	119.5	87

AVG = 118.653

26

NOx

TEST # 2

12-20-72

J. Sornbati

Science Calib - 0-100% scale = 0-500 ppm NOx

STD Calib gas = 120 ppm = 84% full scale

Zero = 1.85 Span = 1.16

TIME	% scale	ppm NOx	sample Temp
1152	20	100	76
1154	20.5	103.5	75
1151	21	105	75
1152	20.75	103.8	75
1153	21	105	75
1154	21.5	107.5	75
1155	21	105	75
1156	21.5	107.5	76
1157	22	110	76
1158	21.8	109	76
1159	21.8	109	77
1200	21.8	109	77
1201	21.9	109.5	78
1202	21.8	109	78
1203	21.8	109	78
1204	21.8	109	79
1205	21.9	109.5	79

AVG = 107.79

PLR #26

NOX Test

12-21-72

Dyna Science NOx Analyzer

0-100% scale = 0-300 ppm NOx

Calibrated Unit @ Field Conditions

420 ppm NO = 84% scale

10 = 4.95

20 = 4.20

	% Scale	PPM	Sample
1351	21%	105	70
1352	21.5	107.5	70
1353	22%	110	70
1354	22.8	114	70
1355	23.2	116	70
1356 1356	23.5	117.5	70
1357 1357	23.7	118.5	70
1358 1358	23.8	119	70
1359 1359	23.8	119	70
1400	23.7	118.5	70
1401	23.0	115	71
1402	23.0	115	71
1403	23.0	115	71
1404	23.0	115	72
1405	23.0	115	72
1406	23.0	115	72
1407	23.0	115	72
1408	23.0	115	72
1409	22.8	114	72
1410	22.8	114	72

AVG = 118.65

Stack Identification Number 7

Boiler Number 26

Plant STEEL POINT STATION

Run No. Preliminary Velocity Traverse

Location Stack Entry Point

Date 12-18-72

Operator SSS

Meter Δ H

C Factor

Ambient Temp of

Bar. Press. "Hg

Assumed Moisture %

Heater Box Setting, of

Probe Tip Dia., In.

Probe Length 10'

Probe Heater Setting

Avg. Δ P Avg. Δ H

Stack Pressure

% S oxidinetic

Point	Clock Time	Dry Gas Meter, CF	Pitot in H ₂ O Δ P	Orifice in H ₂ O Desired	Actual Δ H	Dry Gas Inlet	Temp. Outlet	Pump Vacuum In. Hg Gauge	Box Temp. of	Impinger Temp of	$\sqrt{\Delta P}$	St Te of
1			1.1	1.10	1.25	1.15	65	12				
2			.92	.92	1.05	1.05	65	12				
3			.83	.90	1.05	1.05	65	12				
4			1.0	1.1	1.10	1.05	65	12				
5			.85	1.1	1.10	1.15	65	12				
6			.15	1.1	1.10	1.15	65	12				
7			.97	.97	.89	.84	65	12				
8			.31	.15	.25	.52	65	12				

90% 90% 90% 90% 90% 90% 90% 90% 90% 90% 90% 90%

MEY

Stack Identification Number _____

Boiler Number 26

Plant Steel Point Station

Run No. 1

Location Stack Entry Duct

Date 12-19-72

Operator Sandwell

Meter ΔH 1.89

C Factor .90

Ambient Temp of 64 (12.5)

Bar. Press. "Hg 29.94, 29.92, 29.92

Assumed Moisture % 9

Heater Box Setting, of 275

Probe Tip Dia., In. .25

Probe Length 10'

Probe Heater Setting 50%

Avg. ΔP .864 Avg. ΔH 2.066

Stack Pressure -1.3" H₂O

% Isokinetic .9984

Point	Clock Time	Dry Gas Meter, CF	Pitot in H ₂ O ΔP	Orifice ΔH in H ₂ O Desired	Actual ΔH	Dry Gas Temp. Inlet	Dry Gas Temp. Outlet	Pump Vacuum In. Hg Gauge	Box Temp. of	Impinger Temp of	$\sqrt{\Delta P}$	Stack Temp of
6-1	1425	749.10	.26	2.1	2.1	72	74	3.6	255	62	1.47	62
6-2	1430	753.53	.28	2.03	2.03	81	74	3.3	255	62	1.47	62
6-3	1435	757.96	.30	1.88	1.88	86	75	3.1	255	62	1.47	62
6-4	1440	762.39	.59	1.82	1.82	100	76	3.0	263	62	1.47	62
6-5	1445	766.82	.71	1.78	1.78	102	78	3.1	262	62	1.47	62
6-6	1450	771.25	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-7	1455	775.68	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-8	1460	780.11	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-9	1465	784.54	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-10	1470	788.97	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-11	1475	793.40	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-12	1480	797.83	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-13	1485	802.26	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-14	1490	806.69	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-15	1495	811.12	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-16	1500	815.55	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-17	1505	820.00	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-18	1510	824.43	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-19	1515	828.86	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-20	1520	833.29	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-21	1525	837.72	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-22	1530	842.15	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-23	1535	846.58	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-24	1540	851.01	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-25	1545	855.44	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-26	1550	859.87	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-27	1555	864.30	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-28	1560	868.73	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-29	1565	873.16	.71	1.78	1.78	97	79	2.8	265	62	1.47	62
6-30	1570	877.59	.71	1.78	1.78	97	79	2.8	265	62	1.47	62

Point	Clock Time	Dry Gas Meter, CF	Pilot in H2O Δ p	Orifice ΔH in H2O Desired	Orifice ΔH Actual	Dry Gas Temp. Inlet	Dry Gas Temp. Outlet	Pump Vacuum In. Hg Gauge	Box Temp. OF	Impinger Temp OF	VAP	Sta
2-1	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	1
2-2	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	2
2-3	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	3
2-4	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	4
2-5	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	5
2-6	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	6
2-7	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	7
2-8	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	8
2-9	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	9
2-10	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	10
2-11	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	11
2-12	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	12
2-13	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	13
2-14	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	14
2-15	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	15
2-16	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	16
2-17	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	17
2-18	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	18
2-19	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	19
2-20	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	20
2-21	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	21
2-22	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	22
2-23	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	23
2-24	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	24
2-25	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	25
2-26	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	26
2-27	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	27
2-28	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	28
2-29	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	29
2-30	1500	800.00	1.05	2.00	2.00	98	87	4.9	250	50	1.01	30

1251

D11

26

12-19-72

WEIGHT OF PARTICULATE COLLECTED

mg

FILTER USED: DREIF ANGEL 900AF 11.122

CONTAINER NUMBER	FINAL WEIGHT	TARE WEIGHT	WEIGHT GAIN
Filter	17610g	16007g	160.3mg
Washings	100.9 mg		100.9 mg
TOTAL			261.2 mg

VOLUME OF LIQUID WATER COLLECTED, ml

CONTAINER	1	2	3	4
FINAL VOL.	334	196	13	343.4
INITIAL VOL	100	100	0	300
LIQUID COLLECTED	234	96	13	46.4 g
Total	387.4 ml			46.4 g

Stack Identification Number 26

Boiler Number 26

Plant Steel Plant

Run No. 2

Location Stack Entry Duct

Date 12-26-72

Operator Sundaram

Meter Δ H 1.889

C Factor 0.87, 0.80

Ambient Temp OF 39.9

Bar. Press. "Hg 30.02

Assumed Moisture % 8.8

Heater Box Setting, OF 250

Probe Tip Dia., In. .25

Probe Length 10'

Probe Heater Setting 250

Avg Δ P .834 Avg. Δ H 1.81

Stack Pressure -1.2" H₂O

% Isokinetic 99.74

Point	Clock Time	Dry Gas Meter, CF	Pitot in H ₂ O Δ P	Orifice Δ H in H ₂ O Desired	Orifice Δ H Actual	Dry Gas Inlet OF	Dry Gas Temp. Outlet	Pump Vacuum In. Hg Gauge	Box Temp. OF	Impinger Temp OF	$\sqrt{\Delta$ P	Sta Temp OF
6-1	1:07	411.08	.75	1.0	1.0	10	58	30.0	235	53	.87	37
6-2	1:10	418.44	.7	1.05	1.05	8	55	30.0	232	50	.87	37
6-3	1:17	418.88	.61	1.05	1.05	7	48	2.5	272	50	.87	37
6-4	1:22	418.88	.61	1.0	1.0	7	50	2.5	272	50	.87	37
6-5	1:27	418.88	.61	1.32	1.32	7	50	2.2	220	55	.87	37
6-6	1:32	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-7	1:37	418.88	.61	1.05	1.05	7	50	2.2	220	55	.87	37
6-8	1:42	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-9	1:47	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-10	1:52	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-11	1:57	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-12	2:02	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-13	2:07	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-14	2:12	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-15	2:17	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-16	2:22	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-17	2:27	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-18	2:32	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-19	2:37	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-20	2:42	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-21	2:47	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-22	2:52	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-23	2:57	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-24	3:02	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-25	3:07	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-26	3:12	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-27	3:17	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-28	3:22	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-29	3:27	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37
6-30	3:32	418.88	.61	1.0	1.0	7	50	2.2	220	55	.87	37

956105

Point	Clock Time	Dry Gas Meter, CF	Pitot in H ₂ O Δ p	Orifice ΔH in H ₂ O Desired	Actual ΔH	Dry Gas Inlet OF	Outlet Temp.	Pump Vacuum In. Hg Gauge	Box Temp. OF	Impinger Temp OF	W/P	Stack Pump OF
1-1	17:22	946.35	1.00	2.0	2.3	78	66	5.7	212	50	1.00	305
1-2	17:27	940.27	1.00	2.0	2.0	79	67	5.0	212	50	1.017	305
1-3	17:32	941.42	1.00	2.14	2.07	78	68	5.2	212	50	1.007	305
1-4	17:37	942.26	1.00	2.28	2.08	78	68	5.2	212	50	1.005	305
1-5	17:42	941.15	1.00	2.1	2.07	78	67	5.3	212	50	1.003	305
1-6	17:47	942.83	1.00	2.25	2.0	79	67	4.8	215	50	1.001	305
1-7	17:52	942.83	1.00	2.2	2.2	79	69	5.2	214	50	1.001	305
1-8	17:57	942.87	1.00	2.2	2.2	79	71	4.0	210	50	1.001	305
1-9	18:02	943.11	1.00	2.3	2.3	79	71	4.0	210	50	1.001	305
1-10	18:07	943.51	1.00	2.4	2.4	79	72	3.8	210	50	1.001	305
1-11	18:12	943.97	1.00	2.48	2.48	80	73	2.9	208	50	1.001	305
1-12	18:17	944.31	1.00	2.74	2.74	80	73	2.5	207	50	1.001	305
1-13	18:22	944.77	1.00	2.9	2.9	80	74	2.2	207	50	1.001	305
1-14	18:27	945.11	1.00	3.0	3.0	80	74	2.2	207	50	1.001	305
1-15	18:32	945.41	1.00	3.05	3.05	80	74	2.2	207	50	1.001	305
1-16	18:37	945.72	1.00	3.2	3.2	80	74	2.2	207	50	1.001	305
1-17	18:42	946.02	1.00	3.3	3.3	80	74	2.2	207	50	1.001	305
1-18	18:47	946.32	1.00	3.4	3.4	80	74	2.2	207	50	1.001	305
1-19	18:52	946.62	1.00	3.5	3.5	80	74	2.2	207	50	1.001	305
1-20	18:57	946.92	1.00	3.6	3.6	80	74	2.2	207	50	1.001	305
1-21	19:02	947.22	1.00	3.7	3.7	80	74	2.2	207	50	1.001	305
1-22	19:07	947.52	1.00	3.8	3.8	80	74	2.2	207	50	1.001	305
1-23	19:12	947.82	1.00	3.9	3.9	80	74	2.2	207	50	1.001	305
1-24	19:17	948.12	1.00	4.0	4.0	80	74	2.2	207	50	1.001	305
1-25	19:22	948.42	1.00	4.1	4.1	80	74	2.2	207	50	1.001	305
1-26	19:27	948.72	1.00	4.2	4.2	80	74	2.2	207	50	1.001	305
1-27	19:32	949.02	1.00	4.3	4.3	80	74	2.2	207	50	1.001	305
1-28	19:37	949.32	1.00	4.4	4.4	80	74	2.2	207	50	1.001	305
1-29	19:42	949.62	1.00	4.5	4.5	80	74	2.2	207	50	1.001	305
1-30	19:47	949.92	1.00	4.6	4.6	80	74	2.2	207	50	1.001	305
1-31	19:52	950.22	1.00	4.7	4.7	80	74	2.2	207	50	1.001	305
1-32	19:57	950.52	1.00	4.8	4.8	80	74	2.2	207	50	1.001	305
1-33	20:02	950.82	1.00	4.9	4.9	80	74	2.2	207	50	1.001	305
1-34	20:07	951.12	1.00	5.0	5.0	80	74	2.2	207	50	1.001	305
1-35	20:12	951.42	1.00	5.1	5.1	80	74	2.2	207	50	1.001	305
1-36	20:17	951.72	1.00	5.2	5.2	80	74	2.2	207	50	1.001	305
1-37	20:22	952.02	1.00	5.3	5.3	80	74	2.2	207	50	1.001	305
1-38	20:27	952.32	1.00	5.4	5.4	80	74	2.2	207	50	1.001	305
1-39	20:32	952.62	1.00	5.5	5.5	80	74	2.2	207	50	1.001	305
1-40	20:37	952.92	1.00	5.6	5.6	80	74	2.2	207	50	1.001	305
1-41	20:42	953.22	1.00	5.7	5.7	80	74	2.2	207	50	1.001	305
1-42	20:47	953.52	1.00	5.8	5.8	80	74	2.2	207	50	1.001	305
1-43	20:52	953.82	1.00	5.9	5.9	80	74	2.2	207	50	1.001	305
1-44	20:57	954.12	1.00	6.0	6.0	80	74	2.2	207	50	1.001	305
1-45	21:02	954.42	1.00	6.1	6.1	80	74	2.2	207	50	1.001	305
1-46	21:07	954.72	1.00	6.2	6.2	80	74	2.2	207	50	1.001	305
1-47	21:12	955.02	1.00	6.3	6.3	80	74	2.2	207	50	1.001	305
1-48	21:17	955.32	1.00	6.4	6.4	80	74	2.2	207	50	1.001	305
1-49	21:22	955.62	1.00	6.5	6.5	80	74	2.2	207	50	1.001	305
1-50	21:27	955.92	1.00	6.6	6.6	80	74	2.2	207	50	1.001	305
1-51	21:32	956.22	1.00	6.7	6.7	80	74	2.2	207	50	1.001	305
1-52	21:37	956.52	1.00	6.8	6.8	80	74	2.2	207	50	1.001	305
1-53	21:42	956.82	1.00	6.9	6.9	80	74	2.2	207	50	1.001	305
1-54	21:47	957.12	1.00	7.0	7.0	80	74	2.2	207	50	1.001	305
1-55	21:52	957.42	1.00	7.1	7.1	80	74	2.2	207	50	1.001	305
1-56	21:57	957.72	1.00	7.2	7.2	80	74	2.2	207	50	1.001	305
1-57	22:02	958.02	1.00	7.3	7.3	80	74	2.2	207	50	1.001	305
1-58	22:07	958.32	1.00	7.4	7.4	80	74	2.2	207	50	1.001	305
1-59	22:12	958.62	1.00	7.5	7.5	80	74	2.2	207	50	1.001	305
1-60	22:17	958.92	1.00	7.6	7.6	80	74	2.2	207	50	1.001	305
1-61	22:22	959.22	1.00	7.7	7.7	80	74	2.2	207	50	1.001	305
1-62	22:27	959.52	1.00	7.8	7.8	80	74	2.2	207	50	1.001	305
1-63	22:32	959.82	1.00	7.9	7.9	80	74	2.2	207	50	1.001	305
1-64	22:37	960.12	1.00	8.0	8.0	80	74	2.2	207	50	1.001	305
1-65	22:42	960.42	1.00	8.1	8.1	80	74	2.2	207	50	1.001	305
1-66	22:47	960.72	1.00	8.2	8.2	80	74	2.2	207	50	1.001	305
1-67	22:52	961.02	1.00	8.3	8.3	80	74	2.2	207	50	1.001	305
1-68	22:57	961.32	1.00	8.4	8.4	80	74	2.2	207	50	1.001	305
1-69	23:02	961.62	1.00	8.5	8.5	80	74	2.2	207	50	1.001	305
1-70	23:07	961.92	1.00	8.6	8.6	80	74	2.2	207	50	1.001	305
1-71	23:12	962.22	1.00	8.7	8.7	80	74	2.2	207	50	1.001	305
1-72	23:17	962.52	1.00	8.8	8.8	80	74	2.2	207	50	1.001	305
1-73	23:22	962.82	1.00	8.9	8.9	80	74	2.2	207	50	1.001	305
1-74	23:27	963.12	1.00	9.0	9.0	80	74	2.2	207	50	1.001	305
1-75	23:32	963.42	1.00	9.1	9.1	80	74	2.2	207	50	1.001	305
1-76	23:37	963.72	1.00	9.2	9.2	80	74	2.2	207	50	1.001	305
1-77	23:42	964.02	1.00	9.3	9.3	80	74	2.2	207	50	1.001	305
1-78	23:47	964.32	1.00	9.4	9.4	80	74	2.2	207	50	1.001	305
1-79	23:52	964.62	1.00	9.5	9.5	80	74	2.2	207	50	1.001	305
1-80	23:57	964.92	1.00	9.6	9.6	80	74	2.2	207	50	1.001	305
1-81	24:02	965.22	1.00	9.7	9.7	80	74	2.2	207	50	1.001	305
1-82	24:07	965.52	1.00	9.8	9.8	80	74	2.2	207	50	1.001	305
1-83	24:12	965.82	1.00	9.9	9.9	80	74	2.2	207	50	1.001	305
1-84	24:17	966.12	1.00	10.0	10.0	80	74	2.2	207	50	1.001	305
1-85	24:22	966.42	1.00	10.1	10.1	80	74	2.2	207	50	1.001	305
1-86	24:27	966.72	1.00	10.2	10.2	80	74	2.2	207	50	1.001	305
1-87	24:32	967.02	1.00	10.3	10.3	80	74	2.2	207	50	1.001	305
1-88	24:37	967.32	1.00	10.4	10.4	80	74	2.2	207	50	1.001	305
1-89	24:42	967.62	1.00	10.5	10.5	80	74	2.2	207	50	1.001	305
1-90	24:47	967.92	1.00	10.6	10.6	80	74	2.2	207	50	1.001	305
1-91	24:52	968.22	1.00	10.7	10.7	80	74	2.2	207	50	1.001	305
1-92	24:57	968.52	1.00	10.8	10.8	80	74	2.2	207	50	1.001	305
1-93	25:02	968.82	1.00	10.9	10.9	80	74	2.2	207	50	1.001	305
1-94	25:07	969.12	1.00	11.0	11.0	80	7					

date 12-20-72

WEIGHT OF PARTICULATE COLLECTED

mg			
FILTER USED: REEVE ANGL 9001F 11CM			
CONTAINER NUMBER	FINAL WEIGHT	TARE WEIGHT	WEIGHT SPIN
Filter	1.9216g	.6151g	1306.5 mg
Washings	57.5mg		57.5 mg
TOTAL			1364.0 mg

VOLUME OF LIQUID WATER COLLECTED, ml

CONTAINER	1	2	3	4
FINAL VOL	348	167.5	1	356.7
INITIAL VOL	100	100	0	300 g
LIQUID COLLECTED	248	67.5	1	56.7 g 56.7 ml
TOTAL				373.7 ml

248
67.5

373.7 ml

56.7

Stack Identification Number _____
 Boiler Number 76
 Plant _____
 Run No. _____
 Location _____
 Date 12-20-72
 Operator _____
 Meter ΔH _____
 C Factor _____

Ambient Temp OF _____
 Bar. Press. "Hg 30.06
 Assumed Moisture % _____
 Heater Box Setting, OF _____
 Probe Tip Dia., In. _____
 Probe Length _____
 Probe Heater Setting _____
 Avg. ΔP _____ Avg. ΔH _____
 Stack Pressure -1.3" H₂O
 % Isokinetic _____

Point	Clock Time	Dry Gas Meter, CF	Pitot in H ₂ O ΔP	Orifice ΔH in H ₂ O	Actual ΔH	Dry Gas Temp. OF	Inlet	Outlet	Pump Vacuum In. Hg Gauge	Box Temp. OF	Impinger Temp OF	$\sqrt{\Delta P}$	Stack Temp OF
1-1			1.15									1.076	277
1-2			.91									.954	277
1-3			.89									.760	284
1-4			.81									.711	282
1-5			.83									.822	282
1-6			.81									.878	282
1-7			.81									.832	281
1-8			.85									.881	281
1-9			1.15									1.072	282
1-10			.82									.875	282
1-11			.82									.875	282
1-12			.82									.875	282
1-13			.82									.875	282
1-14			.82									.875	282
1-15			.82									.875	282
1-16			.82									.875	282
1-17			.82									.875	282
1-18			.82									.875	282
1-19			.82									.875	282
1-20			.82									.875	282

Run	Clock Time	Dry Gas Meter, CF	Pitot in H ₂ O ΔP	Orifice ΔH in H ₂ O Desired	Actual	Dry Gas Inlet Temp. OF	Outlet Temp. OF	Vacuum In. Hg Gauge	Box Temp. OF	Impinger Temp. OF	VAP	Barometer Temp. OF
1			1.28	3.00							1.140	
2			1.25	3.00							1.070	
3			1.15	3.00							1.000	
4			1.10	3.00							1.000	
5			1.10	3.00							1.000	
6			1.08	3.00							1.000	
7			1.08	3.00							1.000	
8			1.08	3.00							1.000	
9			1.08	3.00							1.000	
10			1.08	3.00							1.000	
11			1.08	3.00							1.000	
12			1.08	3.00							1.000	
13			1.08	3.00							1.000	
14			1.08	3.00							1.000	
15			1.08	3.00							1.000	
16			1.08	3.00							1.000	
17			1.08	3.00							1.000	
18			1.08	3.00							1.000	
19			1.08	3.00							1.000	
20			1.08	3.00							1.000	
21			1.08	3.00							1.000	
22			1.08	3.00							1.000	
23			1.08	3.00							1.000	
24			1.08	3.00							1.000	
25			1.08	3.00							1.000	
26			1.08	3.00							1.000	
27			1.08	3.00							1.000	
28			1.08	3.00							1.000	
29			1.08	3.00							1.000	
30			1.08	3.00							1.000	
31			1.08	3.00							1.000	
32			1.08	3.00							1.000	
33			1.08	3.00							1.000	
34			1.08	3.00							1.000	
35			1.08	3.00							1.000	
36			1.08	3.00							1.000	
37			1.08	3.00							1.000	
38			1.08	3.00							1.000	
39			1.08	3.00							1.000	
40			1.08	3.00							1.000	
41			1.08	3.00							1.000	
42			1.08	3.00							1.000	
43			1.08	3.00							1.000	
44			1.08	3.00							1.000	
45			1.08	3.00							1.000	
46			1.08	3.00							1.000	
47			1.08	3.00							1.000	
48			1.08	3.00							1.000	
49			1.08	3.00							1.000	
50			1.08	3.00							1.000	

Run	Clock Time	Dry Gas Motor, CF	Pilot In H ₂ O Δ P	Office ΔH Desired	Office ΔH Actual	Dry Gas Inlet	Dry Gas Outlet	Pump Vacuum In. Hg	Box Temp. OF	Impinger Temp. OF	W.P.	Stack Temp. OF
1	1517	109.45	1.02	2.9	2.9	70	68	4.5	202	70	1.09	206
2	1522	113.95	1.01	2.85	2.85	69	67	4.5	202	70	1.02	212
3	1527	117.44	1.1	2.68	2.68	66	64	4.5	201	70	1.05	212
4	1532	122.13	1.05	2.72	2.72	64	61	4.5	201	70	1.02	212
5	1537	127.08	1.02	2.78	2.78	64	62	4.5	201	70	1.07	212
6	1542	132.19	1.1	2.65	2.65	65	64	4.5	200	70	1.05	212
7	1547	138.19	1.1	2.65	2.65	65	64	4.5	200	70	1.05	212
8	1552	144.91	1.05	2.7	2.7	65	62	4.5	200	70	1.06	212
9	1557	152.40	1.02	2.9	2.9	68	62	4.5	200	70	1.02	212
10	1602	158.0	1.05	2.85	2.85	61	61	4.5	200	70	1.07	212
11	1607	156.39	1.15	2.65	2.65	61	60	4.5	200	70	1.07	212
12	1612	152.89	1.02	3.05	3.05	68	72	4.5	200	70	1.05	215
13	1617	158.39	1.02	3.05	3.05	68	72	4.5	200	70	1.05	215
14	1622	163.89	1.02	3.05	3.05	68	72	4.5	200	70	1.05	215
15	1627	169.39	1.02	3.05	3.05	68	72	4.5	200	70	1.05	215
16	1632	174.89	1.05	3.0	3.0	69	70	4.5	200	70	1.02	210
17	1637	180.39	1.05	3.0	3.0	69	70	4.5	200	70	1.02	210
18	1642	185.89	1.05	3.0	3.0	69	70	4.5	200	70	1.02	210
19	1647	191.39	1.05	3.0	3.0	69	70	4.5	200	70	1.02	210
20	1652	196.89	1.05	3.0	3.0	69	70	4.5	200	70	1.02	210
21	1657	202.39	1.02	3.0	3.0	68	68	4.5	200	70	1.02	212
22	1662	207.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	212
23	1667	213.39	1.05	2.85	2.85	68	68	4.5	200	70	1.05	215
24	1672	218.89	1.05	2.85	2.85	68	68	4.5	200	70	1.05	215
25	1677	224.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
26	1682	229.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
27	1687	235.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
28	1692	240.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
29	1697	246.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
30	1702	251.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
31	1707	257.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
32	1712	262.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
33	1717	268.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
34	1722	273.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
35	1727	279.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
36	1732	284.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
37	1737	290.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
38	1742	295.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
39	1747	301.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
40	1752	306.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
41	1757	312.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
42	1762	317.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
43	1767	323.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
44	1772	328.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
45	1777	334.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
46	1782	339.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
47	1787	345.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
48	1792	350.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
49	1797	356.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
50	1802	361.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
51	1807	367.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
52	1812	372.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
53	1817	378.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
54	1822	383.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
55	1827	389.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
56	1832	394.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
57	1837	400.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
58	1842	405.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
59	1847	411.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
60	1852	416.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
61	1857	422.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
62	1862	427.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
63	1867	433.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
64	1872	438.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
65	1877	444.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
66	1882	449.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
67	1887	455.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
68	1892	460.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
69	1897	466.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
70	1902	471.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
71	1907	477.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
72	1912	482.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
73	1917	488.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
74	1922	493.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
75	1927	499.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
76	1932	504.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
77	1937	510.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
78	1942	515.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
79	1947	521.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
80	1952	526.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
81	1957	532.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
82	1962	537.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
83	1967	543.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
84	1972	548.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
85	1977	554.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
86	1982	559.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
87	1987	565.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
88	1992	570.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
89	1997	576.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
90	2002	581.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
91	2007	587.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
92	2012	592.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
93	2017	598.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
94	2022	603.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
95	2027	609.39	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
96	2032	614.89	1.0	2.85	2.85	68	68	4.5	200	70	1.0	215
97	2037	620.39	1.0	2.85	2.85	68	68	4.5				

0AQPS - 78-1

II-I-258

FUEL
OIL COMBUSTION
AP-42 Section 1.3
Reference Number
24


4/93 Ref 21

Emission Test Report
English Station Stack No. 5
Steam Generator No. 13

11
1948

The United Illuminating Company
English Station
510 Grand Avenue
New Haven, Connecticut
06505

Approved by:

E. W. Somerville 
Vice President, Engineering and Planning

Submitted by:

M. R. McCraven 
Director of Environmental Engineering

Emission Test Report

English Station Stack No. 5
Steam Generator No. 13
(Ref. "Intent to Test" Form Number 720051)

Test Conducted By
The United Illuminating Company
Development and Test Laboratory
80 Temple Street
New Haven, Connecticut
06506

United Illuminating Company Personnel Present

J. Sombati
J. Hotchkiss
J. Macknis
M. Collins

and by
York Research Corporation
One Research Drive
Stamford, Connecticut
06906

York Research Corporation Personnel Present

R. Larkin
J. Kittrell

Prepared by:

J. S. Sombati *J. Sombati*
Development & Test Laboratory Supervisor

J. W. Hotchkiss *J. W. Hotchkiss*
Assistant Mechanical Engineer

Checked by:

J. F. Crowe *James F. Crowe*
Chief Mechanical Engineer

Test Results

English Station Steam Generator
No. 13

Test Conducted on
December 28, 1973

Introduction

Emission tests for particulates and nitrogen oxides were conducted as required by Connecticut State Law on The United Illuminating Company English Station Steam Generator No. 13, stack No. 5, located in New Haven, Connecticut. Testing was conducted on December 28, 1973.

Particulate testing was performed in accordance with test methods and procedures as prescribed in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. Testing was performed by York Research Corporation of Stamford, Connecticut, using a sampling train as described in Appendix A.

Nitrogen oxide emission testing was performed by the United Illuminating Company Development and Test Laboratory using a Dynascience Model P-101 NO_x Analyzer. Field data is included in Appendix B.

Tests were also conducted to determine stack gas velocity, moisture content, and flue-gas analysis. The procedures used in determining these various parameters, except for flue gas analysis, are those found in the above mentioned Federal Register. The stack flue gas was analyzed by using an Analytical Instrument Development Model 512 Portable Gas Chromatograph.

York Research Corporation was retained to perform particulate tests, together with a preliminary velocity traverse, moisture determination, and fuel oil analysis. The United Illuminating Company was responsible for the flue gas analysis, nitrogen oxide analysis, and for accumulating boiler operating data.

This test report includes the information required for Item Nos. III, IV, V, VI, VII, VIII, IX, X, XI, XII, and XIII from the Department of Environmental Protection's Intent to Test form in compliance with the Department of Environmental Protection's new Source Test Guidelines and Procedures, (received April 3, 1973).

TABLE I

SUMMARY OF TEST RESULTS

STEAM GENERATOR NO. 13

STACK NO. 5

<u>Component</u>	<u>Sampling Duration</u>		<u>Number of Tests</u>	<u>Measured Concentrations</u>	<u>Method Employed to Determine Concentration</u>
	<u>Minutes per point</u>	<u>Total Test Time</u>			
1) NO _x		15 min.	3	0.20 lb/10 ⁶ BTU	Dynascience Model P-101 NO _x Analyzer
2) Particulate	5	60 min.	3	0.03 lb/10 ⁶ BTU	Method 5*
3) Moisture	5	60 min.	3	9.6%	Method 4*
4) Gas Analysis		15 min.	3	35% Excess Air	A.I.D. Model 512 Portable Gas Chromatograph
5) Velocity	1/2	15 min.	3	0.21" H ₂ O to 0.48" H ₂ O **	Method 2*

*Federal Register, Volume 36, No. 247, December 23, 1971

** Range of S-Type Pitot-Tube Differential

TABLE II

SUMMARY OF RESULTS

STEAM GENERATOR NO. 13

STACK NO. 5

	<u>1</u>	<u>2</u>	<u>3</u>	<u>Average</u>
Test Date	12/28/73	12/28/73	12/28/73	
Stack Flow, ACFM	162,430	165,179	173,179	166,929
Stack Flow, SCFM	104,260	103,566	104,008	103,945
Stack Flow, lb/hr	488,131	484,882	486,628	486,547
% Excess O ₂ at Test Point	7.0	7.0	7.1	7.0
Particulate Emissions				
gr/SCF	0.020	0.008	0.017	0.015
lb/hr	18.02	6.90	14.85	13.26
lb/MBTU	0.05	0.02	0.04	0.03
Nitrogen Oxide Emission				
ppm	109	108	108	108
lb/hr	80.0	81.3	80.3	80.5
lb/MBTU	0.20	0.20	0.20	0.20

13 5 10
 27/28/73
 4.9 lb
 29.0 lb
 21.0 lb
 21.0 lb

TABLE III

AVERAGE BOILER OPERATING DATA FOR TEST PERIODS

STEAM GENERATOR NO. 13

STACK NO. 5

	<u>1</u>	<u>2</u>	<u>3</u>
Test			
Date	12/28/73	12/28/73	12/28/73
Gross Load, mw	34	33.5	33
Steam Flow, lb/hr	310,000	305,000	305,000
Feed Water Flow, lb/hr	340,000	335,000	345,000
Oil Flow, gal/hr	2725	2725	2725
Heat Input, MBTU/hr	401.1	401.1	401.1
Stack Gas Temperature, °F	306	307	310
Gas Density, lb/ft ³	0.054	0.054	0.054

TABLE IV
FUEL OIL ANALYSIS
STEAM GENERATOR NO. 13
STACK NO. 5

Test	<u>1</u>	<u>2</u>	<u>3</u>
Date	12/28/73	12/28/73	12/28/73
	<u>(Composition (% by Weight))</u>		
Carbon	86.46	86.46	86.46
Hydrogen	12.20	12.20	12.20
Nitrogen	<0.1	<0.1	<0.1
Ash	0.022	0.022	0.022
Sulfur	0.335	0.335	0.335
Specific Gravity	0.909	0.909	0.909
BTU/lb	19,438	19,438	19,438
BTU/gal	147,184	147,184	147,184

1. Sampling Train Information

(Ref. Item VIII, "Intent To Test" Form)

- a. Schematic Diagram and description of sampling train:

See Appendix A.

- b. Media type used to determine gas stream components:

1. NO_x: Dynascience Model P-101 NO_x Analyzer
2. Particulates: Tared glass fiber filter.
3. Flue Gas Analysis: Analytical Instrument Development Model 512 Portable Gas Chromatograph

- c. Sampling Probes:

1. NO_x: Stainless steel tube
2. Particulates: See Appendix A
3. Flue Gas Analysis: Stainless steel tube.

- d. Probe Cleaning Method:

See Appendix A

2. Field Data Sheets

(Ref. Item IX, "Intent To Test" Form)

See Appendices A, B, C, D.

3. Description of Operation

(Ref. Item X, "Intent To Test" Form)

The operation tested was English Station steam generator number 13, stack 5, Registration Number E.S. 13, stack 5, having a total BTU/hr rating of 401.1 MBTU (averaged over test period) burning No. 6 residual fuel oil at an average rate of 2725 gal/hr; and having a gas flow of 166,929 ACFM average for the test period. See Table IV for fuel oil analysis.

4. Sampling Area Description
(Ref. Item XI, "Intent To Test" Form)

Emission sampling was performed in the stack 106 feet above the stack foundation (8 stack diameters above the breeching inlet and 3 stack diameters down from the top). Emission sampling was performed using four - 4" diameter sampling ports spaced 90° apart on the stack circumference. A total of twelve sampling points (3 per sampling port) were used in the test for particulates. The inside diameter of the stack at the sampling location is 9'-4" I.D.

a. Stack Configuration:

See Appendix A

b. Sampling Port Location:

See Appendix A

c. Sampling Point Position:

See Appendix A

5. Stack and Vent Description
(Ref. Item XII, "Intent To Test" Form)

One Babcock and Wilcox Radiant Type Top-Fired Balanced Draft boiler discharges flue gas through a Research-Cottrell Electrostatic Precipitator to the stack breeching. The stack height is 135' with the breeching inlet located 103 feet down from the top of the stack.

6. Operational Parameters
(Ref. Item XIII, "Intent To Test" Form)

Electric utility steam generator burning No. 6 residual fuel oil having rated capacities as registered.

APPENDIX A

PARTICULATE TEST

V. SAMPLING METHODS

1. Port Location

All test ports are located in the stack and the number of points sampled were calculated on the guidelines in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. Enough points were used to assure accurate measurement of particulate emissions, temperature, and velocity over the cross-sectional area of each stack. (See Figures 2, 4, 6 and 8.)

2. Velocity and Temperature

Velocity was determined by pitot tube in accordance with Western Precipitation Company Bulletin "WP-50". An S-type Pitot Tube (2) and thermocouple (3) are rigidly attached to the sampling probe (See Figure 9). A preliminary velocity traverse was made to establish isokinetic sampling rates using EPA Method 5 sampling techniques.

3. Flue Gas Analysis

Gas analysis for CO_2 and O_2 was conducted by the UI using an Orsat apparatus. Readings for each test are reported in the Summary of Results.

4. Particulate Sampling Methods - EPA Method 5

The sampling apparatus consisted of a nine (9) foot probe heated filter, four impingers, dry gas meter, vacuum pump, and calibrated orifice as shown in Figure 9. The stainless steel, button-hook type probe tip (1) was equipped with a 5/8 inch diameter fitting connected by a stainless steel coupling with asbestos packing to the probe. The probe consisted of 1/2 inch inside diameter medium-wall stainless steel tube with a ground steel joint on one end. The probe was logarithmically wound from the entrance end with 26-gauge nickel-chromium wire. During sampling, the wire was connected to a variable transformer to maintain a gas temperature of 300°F in the probe. The wire wound tube was wrapped with fiber glass tape and encased in a 1-inch-OD stainless steel tube for protection. The end of the steel tube that does not have the ball-joint protruding has a nut welded to it for connection to the stainless steel coupling used to attach the nozzle. The probe connects to a very coarse fritted glass filter holder (4) which holds a tared glass fiber filter. The filter holder was contained in an electrically heated enclosed box (5) which is thermostatically maintained at a minimum temperature of 250-300°F to prevent water condensation. Attached to the heated box was an ice bath (7) containing four impingers connected in series with vacuum hose. The first impinger (8) receives the gas stream from the filter. This impinger is of the Greenburg-Smith design modified by replacing the tip with a 1/2 inch ID glass tube extending to 0.5 inch from the bottom of the flask. This impinger was initially filled with 100 milliliters of distilled water. The second impinger (9) is a Greenburg-Smith impinger with tip, and also filled with 100 milliliters of distilled water. The third impinger (10) modified like the first, with no water. The fourth impinger (11) is also a Greenburg-Smith type modified like the first and contained 300 grams of dry indicating silica gel.

From the fourth impinger the effluent stream flows through a dial thermometer (12), a check valve (13); flexible rubber vacuum tubing (14); vacuum gauge (15); a valve (16); a leakless vacuum pump (17), rated at 4 cubic feet per minute at 0 inches of mercury gauge pressure and 0 cubic feet per minute at 26 inches of mercury gauge pressure, and connected in parallel with a bypass needle valve (18); and a dry gas meter rated at .1 cubic foot per revolution (19). A calibrated orifice (20) completes the train and was used to measure instantaneous meter flow rates. The three thermometers (12) are dial type with a range of 25° to 125°F. A fourth thermometer in the heated portion of the box has a range up to 500°F. The dual manometer (21) across the calibrated orifice is an inclined-vertical type graduated in hundredths of an inch of water from 0 to 1.0 inch and in tenths from 1 to 10 inches.

5. Test Procedure

Prior to the start of a test series for each stack, the pressure, temperature, and range of velocity pressures were determined during preliminary pitot tube and temperature traverse.

During each test the following readings were taken at each point:

1. Point Designation
2. Clock Time
3. Dry gas meter reading (CF)
4. Velocity head (ΔP in inches water)
5. Desired pressure drop across orifice (ΔH in inches water)
6. Actual pressure drop across orifice (ΔH in inches water)
7. Dry gas temperature ($^{\circ}F$) gas meter inlet.
8. Dry gas temperature ($^{\circ}F$) gas meter outlet.
9. Vacuum pump gauge reading (in. Hg).
10. Filter box temperature ($^{\circ}F$)
11. Dry gas temperature ($^{\circ}F$) at the discharge of last impinger.
12. Stack temperature ($^{\circ}F$)

The relationship of ΔP reading with the ΔH reading is a function of the following variables:

1. Orifice calibration factor
2. Gas meter temperature
3. % moisture in the flue gas
4. Ratio of flue gas pressure to barometric pressure
5. Stack temperature
6. Sampling nozzle diameter

A nomograph was used to correlate all the above variables such that a direct relationship between ΔP and ΔH could be determined by the sampler within fifteen seconds and isokinetic conditions maintained throughout the test.

6. Basic Laboratory Procedure

The following paragraph briefly describes the methods used in the laboratory to obtain the raw data used in the calculations of our results as reported in Section III of this report.

The clean up is done in the field according to EPA test procedure. The filters were previously tare weighed and recorded at the laboratory. Upon return they are dried, cooled in a dessicator, then weighed on an analytical balance and the amount of particulate collected is the difference in the two weights. The particulate wash solution (taken from the train in front of the filter) is placed in a tared beaker, the wash solution is evaporated with and Infra-Red Heat Lamp and the beaker weighed

again. The difference in weight is the weight of the particulate in the wash. This is combined with the filter catch as the weight of the sample.

The impinger condensate is measured for moisture determination.


7. Calibration

The equipment used on this assignment was calibrated one week prior to field testing and re-calibrated upon equipment return after testing. York Research calibration is traceable to the National Bureau of Standards.

TEST TEAM


Robert J. Larkin
James R. Kittrell

Prepared By:



Robert J. Larkin
Test Engineer

Reviewed By:



Robert S. Epstein
Project Director

Approved By:




Roy S. Egdall
Manager-Engineering Services



SAMPLING TRAIN

Figure No. 9



York Research Corporation

Pitot Tube Calibration


ΔP_{std}	ΔP_s	$\frac{\Delta P_{std}}{\Delta P_s}$	F_s
.06	.08	.750	.866
.20	.28	.714	.845
.38	.53	.717	.847
.62	.91	.681	.825
.72	1.03	.699	.836

$$F_s = \sqrt{\frac{\Delta P_{std}}{\Delta P_s}}$$

Pitot Tube # 1A

$F_s =$.84

$F_{std} = 1.00$

Calibrated by 
Date 12/12/73

il OK
 Quick Connects OK Valves OK
 ters OK
 st Meter _____
 meters OK
 _____ OK
 ical Check - Amphenol OK
 _____ OK
 i Gauge OK
 check at 27" hg. - OK CF

al each item when checked and write in any remarks.

Calibration - Orifice and Meter

11/5/73 Box No. 51563 P_b 29.9

CF _w	CF _d	T _w	IT _d	OT _d	T _d Avg.	Time t
5	5.15	67	85	75	80	12.73
5	5.06	67	85.5	77.6	87.5	9.012
10	10.16	68	88.8	79.5	84.1	13.2
10	10.03	68	89.0	79.6	84.3	93.06
10	10.05	68	92.8	80.3	86.5	7.67
10						

late Y & H_g at man. 2.0

$$Y = \frac{CF_w P_b (T_d \text{ avg.} + 460)}{CF_d (P_b + 0.147(T_w + 460))}$$

$$\Delta H_g = \frac{0.0634}{P_b (OT_d + 460)} \left(\frac{(T_w + 460)^2}{CF_w} \right)$$

$$\Delta H_g = \frac{0.0634}{(T_w + 460)} \left((T_w + 460)t \right)^2$$

Tolerances

$$Y = 0.99 - 1.00 - 1.01$$

$$\Delta H_g = 1.6 - 1.84 - 2.1$$

ΔH_a	P_b (Orifice)	$(T_w + 460)^2$	Man. H@
0.317	$(T_w + 460)^2$		
P_b (Orifice)	CF_w		
0.01585	$(67 + 460)^2$	1178	.5
$29.9 (75 + 460)$	5		
0.0317	$(67 + 460)^2$	90.12	1.0
$29.9 (77.6 + 460)$	5	1.77	
0.0634	$(68 + 460)^2$	13.2	2.0
$29.9 (79.5 + 460)$	10	1.90	
0.1268	$(68 + 460)^2$	93.06	4.0
$29.9 (29.6 + 460)$	10	1.89	
0.1902	$(68 + 460)^2$	7.67	6.0
$29.9 (80.3 + 460)$	10	1.93	
0.2536	$(\quad + 460)^2$		

$CF_w P_b$ (T_d avg. + 460)	Man.	Y
$CF_d P_b + \frac{\text{Man. Orifice}}{13.6} (T_w + 460)$		
$5 \times 29.9 (80 + 460)$.5	.9
$5.15 (29.9 + 0.0368) (67 + 460)$		
$5 \times 29.9 (81.5 + 460)$	1.0	1.0
$5.06 (29.9 + 0.0737) (67 + 460)$		
$10 \times 29.9 (84.1 + 460)$	2.0	1.0
$10.16 (29.9 + 0.147) (68 + 460)$		
$10 \times 29.9 (84.5 + 460)$	4.0	1.0
$10.03 (29.9 + 0.294) (68 + 460)$		
$10 \times 29.9 (86.5 + 460)$	6.0	1.0
$10.05 (29.9 + 0.431) (68 + 460)$		
$\quad \times (\quad + 460)$		
$\quad (\quad + 0.588) (\quad + 460)$	8.0	

PLANT U.I. (English)
 DATE 12/24/53
 SAMPLING LOCATION Stack #5
 SAMPLE TYPE Part.
 RUN NUMBER _____
 OPERATOR J.R.K.
 AMBIENT TEMPERATURE 40
 BAROMETRIC PRESSURE 29.89
 STATIC PRESSURE (P_s) 31
 FILTER NUMBER (s) FL-702

PROBE LENGTH AND TYPE 9' S.S.
 NOZZLE I.D. 3/16" = .1875"
 ASSUMED MOISTURE, % 10
 SAMPLE BOX NUMBER S-1563
 METER BOX NUMBER 1-90
 METER ΔH_v 67
 C FACTOR 100%
 PROBE HEATER SETTING 100%
 HEATER BOX SETTING 100%
 REFERENCE ΔP 2.00



SCHEMATIC OF TRAVERSE POINT LAYOUT

READ AND RECORD ALL DATA EVERY 5 MINUTES


TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (V _m), ft ³	VELOCITY HEAD (ΔP _v), in. H ₂ O	ORIFICE DIFFERENTIAL (ΔH), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
				DESIRED	ACTUAL		INLET (T _{m in.}), °F	OUTLET (T _{m out.}), °F			
W 1	1350	93.537	.36	.33	.33	305	64	62	2.0	250-300	~70
W 2	1355	95.19	.32	.24	.24	305	70	63	2.0		
W 3	1400	96.71	.21	.19	.19	305	72	64	1.5		
END											
W 1	1405	97.98	.40	.37	.37	305	67	65	2.0		
W 2	1410	97.98	.39	.36	.36	305	67	65	2.0		
W 3	1415	99.64	.26	.24	.24	305	65	64	1.5		
END											
W 1	1420	101.09	.45	.42	.42	310	65	64	2.0		
W 2	1425	102.69	.42	.39	.39	310	67	63	2.0		
W 3	1430	104.54	.24	.22	.22	300	67	63	1.5		
END											
W 1	1440	106.29	.44	.41	.41	310	68	65	2.0		
W 2	1445	107.615	.41	.37	.37	305	71	66	1.5		
W 3	1450	109.39	.32	.30	.30	305	68	66	1.0		
END											
W 1	1455	111.17									
W 2	1504	112.709									
W 3											
END											

FIELD DATA

PROBE LENGTH AND TYPE 9' S.S.
 NOZZLE I.D. 1/4" .250"
 ASSUMED MOISTURE, % 1.0
 SAMPLE BOX NUMBER S-1563
 METER BOX NUMBER 1.90
 METER ΔH, 9.1
 C FACTOR 1.30 %
 PROBE HEATER SETTING 130 %
 HEATER BOX SETTING 130 %
 REFERENCE ΔP 6.5

H₂O Collected = 53 mL NET

PLANT U.I. (English)
 DATE 12/28/23
 SAMPLING LOCATION Stack #5
 SAMPLE TYPE Part
 RUN NUMBER R
 OPERATOR TAL
 AMBIENT TEMPERATURE 40
 BAROMETRIC PRESSURE 29.89
 STATIC PRESSURE, (P_s) 30
 FILTER NUMBER (S) FL-660




SCHMATIC OF TRAVERSE POINT LAYOUT
 READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24-hr CLOCK)	GAS METER READING (V _m), ft ³	VELOCITY HEAD (ΔP _s), in. H ₂ O	ORIFICE DIFFERENTIAL (ΔH), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
				DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F			
(W) 1	1535	12.820	.42	1.20	1.20	310	64	62	5.0	280-300	<70
2	1540	16.32	.40	1.15	1.15	310	70	63	4.5		
3	1545	18.58	.26	.73	.73	305	72	64	3.5		
End	1550	20.92	.43	1.25	1.25	310	70	64	5.0		
(S) 1	1553	20.92	.39	1.10	1.10	310	74	65	4.5		
2	1558	23.28	.24	.68	.68	300	76	67	3.5		
3	1603	26.04	.40	1.15	1.15	305	72	66	5.0		
End	1608	28.29	.38	1.05	1.05	310	76	68	4.5		
(E) 1	1610	31.23	.27	.75	.75	305	77	69	4.0		
2	1615	33.93	.44	1.25	1.25	310	79	69	5.0		
3	1620	36.30	.41	1.15	1.15	305	80	70	5.0		
End	1625	36.30	.27	.75	.75	305	80	70	4.0		
(N) 1	1630	39.21	.44	1.25	1.25	305	80	70	5.0		
2	1635	42.09	.44	1.25	1.25	305	80	70	4.0		
3	1640	44.45									
End	1645										

COMMENTS:


PLANT U.I. (English)
 DATE 12/23/73
 SAMPLING LOCATION 5, 10, 12, 15
 SAMPLE TYPE 1, 2, 3
 RUN NUMBER 1, 2, 3
 OPERATOR TAK
 AMBIENT TEMPERATURE 50
 BAROMETRIC PRESSURE 30.0
 STATIC PRESSURE, (P) 1.5
 FILTER NUMBER (S) F6-202

PROBE LENGTH AND TYPE 9' S.S.
 NOZZLE I.D. 1/4" = 0.250
 NET ASSUMED MOISTURE, % 10
 SAMPLE BOX NUMBER 5-1563
 METER BOX NUMBER 1-56
 METER A.M.C. 49
 C FACTOR 49
 PROBE HEATER SETTING 90.20
 HEATER BOX SETTING 90.20
 REFERENCE AP 4.5




SCHMATIC OF TRAVERSE POINT LAYOUT
 READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK) SAMPLING TIME, min	GAS METER READING (V _m , ft ³)	VELOCITY HEAD (avg), in. H ₂ O	ORIFICE PRESSURE DIFFERENTIAL (avg), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPIRGER TEMPERATURE, °F
				DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F			
(N) 1	1714	44.50	4.8	1.33	1.35	310	6.5	6.4	5.5		
2	1719	47.73	4.0	1.15	1.15	310	7.3	6.5	5.0		
3	1724	50.94	2.5	2.9	2.9	310	7.0	6.7	4.0		
END	1729	52.55									
(E) 1	1733	52.55	4.6	1.30	1.30	310	6.8	6.8	5.0		
2	1738	55.92	4.2	1.20	1.20	310	7.0	6.7	5.0		
3	1743	58.97	3.0	1.55	1.55	310	6.8	6.4	4.5		
END	1748	61.43									
(S) 1	1750	61.43	4.7	1.35	1.35	310	6.7	6.3	5.5		
2	1755	64.48	4.3	1.20	1.20	310	6.9	6.3	5.0		
3	1800	67.41	2.5	1.71	1.71	310	6.5	6.2	4.0		
END	1805	69.71									
(W) 1	1808	69.71	4.6	1.30	1.30	310	6.5	5.5	5.5		
2	1813	72.91	4.6	1.15	1.15	310	6.3	5.4	5.0		
3	1818	75.64	3.9	1.52	1.52	310	6.4	6.0	4.5		
END	1823	78.137									



TRAVERSE POINT No.	DISTANCE FROM WALL
3	4.9"
2	16.5"
1	33.0"



REVISED					
THE UNITED ILLUMINATING CO. NEW HAVEN, CONN. STACK CONFIGURATION AND SAMPLING POINT LOCATION STACK No. 5 ENGLISH STATION					
DRAWN BY	P.L.O.	DATE	3-23-74		
TRACED BY		DATE			
APPROVED BY	J.M.H.	DATE	4-1-77		
SCALE	AS SHOWN	DRAWING NO.	11-2-1-1		

APPENDIX B

NITROGEN OXIDE TEST

FLUE GAS ANALYSIS

TEST NO. 1

CO2X512

Calibrate
#13
Test I
12/28/73
2:55 PM

Zero
check


Max
Sample
2:40 PM
#13
Test I

calibrate

Sample
2:55 PM
#13
Test I

Not
calibrate
2:40 PM
#13
12/28/73

English station
Stack No 5
Test No 1
12/28/73



CO₂ 512

Sample #3 Boiler

N₂ 1024

CO₂ 512

CO₂ 512

Sample #2 #13

N₂ 1024


CO₂ 512

CO₂ 512

Sample #1 #13
3:05 PM
14/08/73

CO₂ 128

N₂ 512



COX 28

calibrate
345 PM

02X 1024

02X 256

COX 512

02X 512

02X 512


TEST NO. 2

NOx
Sample
4:05 PM

ENG
Stack

NOx
Calibration
70% = 920 PPM
4:00 PM

English Station
Stack No 5
Test No 2
12/28/73



594/e
2-1 #13

CO2X512

02X256

02X512

02X256

CO2X512

calibrate
Test 2
11:10 PM

TEST 3, BCR 26, 10-28-72

WEIGHT OF PARTICULATE COLLECTED

mg

DATA SHEET NUMBER	FINAL WEIGHT	THREE WEIGHT	WEIGHT
Filter	74089	.61689	126.0 mg
Washings	70.7 mg		70.7 mg
TOTAL			196.7 mg

VOLUME OF LIQUID WASTE COLLECTED, ml

NUMBER	FINAL VOL	INITIAL VOL	FLUID COLLECTED	TOTAL
1	325	100	225	
2	190	90	100	
3	2	0	2	
4				325 ml

Weight of particulates in washings

Test #3: 12/23/72

W.C. B. Lsn, Stack 7
(Stack empty)

DRM #1 (before)

65.3316 (before)

65.2900 (before)

DRM #3 (after)

63.1297 (before)

63.0998

DRM (X's SR) (before)

60.9756 (before)

60.9738

F. ltr paper + mat (wash)

0.7941

0.0054

Wt. of residues (blank) 0.0400

0.0527

Wt. of particulates on filter: 0.1260g

0.0707

Total weight of ash: 0.0707g

Total particulate wgt: 0.1967g

OIL FIELD

TEST 1:

9:00 PM 0474876
12:00 N 0449264

$$\frac{05612 \text{ gal}}{9 \text{ hr}} = 2846 \text{ gal/hr}$$

DURING TEST

7:00 PM 0469158
9:00 PM 0454054

$$\frac{14121 \text{ gal}}{5 \text{ hr}} = 2824 \text{ gal/hr}$$

TEST 2

7:00 PM 0518856
10:00 AM 0493451

$$\frac{051005 \text{ gal}}{9 \text{ hr}} = 2800 \text{ gal/hr}$$

DURING TEST

7:00 PM 0518851
3:00 PM 0507800

$$\frac{11056}{4 \text{ hr}} = 2764 \text{ gal/hr}$$

TEST 3 B

6:20 PM 0823000
1:20 0808538

$$\frac{14142 \text{ gal}}{5 \text{ hr}} = 2828 \text{ gal/hr}$$

TEST 3 N

0566630
0556661

$$\frac{0769 \text{ gal}}{3.5 \text{ hr}} = 2197 \text{ gal/hr}$$

Avg Fuel Consumed During TEST = 2831 gal/hr

Fuel Calculations

BTU/lb. from Saylor's: 1/5/73

19159 BTU/lb

145,551 BTU/gal

OMIT

From 25, 27 analysis

Specific gravity = 0.9018

8.33 lb/gal (for H₂O) x 0.9018 = 7.52 lb/gal

BTU/gal = 19636 BTU/lb x 7.52 lb/gal

= 147,503 BTU/gal

TEST 1 2846 gal/hr x 145,551 BTU/gal

= 414.2 x 10⁶ BTU/hr

TEST 2 = 2800 gal x 145,551 BTU/gal

= 407.6 x 10⁶ BTU/hr

TEST 30: 2888 gal/hr x 145,551 BTU/gal

= 420.4 x 10⁶ BTU/hr

TEST 31 2848 gal/hr x 145,551 BTU/gal

= 414.5 x 10⁶ BTU/hr

Avg. 414.2

Stack Identification Number 7 TEST 1 Date 12-19-72

Boiler Number S.P. 26

Plant Location STEEL PLANT STATION

Parameters	10:00	11:05	12:00	1:02	2:00	3:00	4:01
Gross Load (MW)	34	34	33	33	33.5	33.5	33.5
Net Load (MW)							
Evap Flow (gal/hr)		204458	219264	245268	255952	24925	246581
Steam Flow (lb/hr)	315,000	315,000	315,000	318,000	315,000	315,000	315,000
Feed Water Flow (lb/hr)	320,000	320,000	320,000	320,000	320,000	320,000	320,000
Air Flow	345,000	345,000	346,000	345,000	345,000	346,000	345,000
Excess Air (%)	19.5	19.5	19.5	19.0	18.75	18.5	18.5
Excess O2 (%)	3.9	3.9	3.9	3.8	3.75	3.7	3.7
SOOT BLOWING	NO	NO	NO	NO	NO	NO	NO
Boiler Inlet Feed Water Temp (°F)	114.5	114.5	110.0	114.5	115.0	115.0	116.0
Boiler Inlet Steam Press. (psig)	920	900	930	900	900	900	900
Boiler Inlet Steam Temp (°F)							
Boiler Outlet Steam Press. (psig)							
Boiler Outlet Steam Temp (°F)							
Condenser Pressure (in Hg)							

Stack Identification Number 7

Date 12-19-77

Boiler Number STEEL POINT 226

ALL REACTIVE OIL

Plant Location STEEL POINT STATION BPT

PRECIPITATOR OIL

NO. TESTS: 1050

Parameters	5:00	6:00	7:00	9:00			
Gross Load (MW)	23.5	23.5	23.5	23.5			ADD.
Net Load (MW)							
Fuel Flow (gal/hr)	0463108	0466323	0469115	0474876			
Steam Flow (lb/hr)	315000	315000	315000	318000			316
Feed Water Flow (lb/hr)	320000	320000	320000	320000			320000
Air Flow (lb/hr)	345000	345000	345000	345000			345000
Excess Air (%)	19.0	18.75	18.0	18.0			
Excess O2 (%)	3.8	3.7	3.6	3.6			
SOot Blowing	NO	NO	NO	NO			
Boiler Inlet Feed Water Temp. (°F)	1160	1165	1160	1160			
Boiler Exit Steam Press. (psig)	200	200	200	200			
Boiler Exit Steam Temp (°F)							
Reheat Inlet Steam Temp (°F)							
Reheat Exit Steam Temp (°F)							
Process Inlet Steam Press. (psig)							
Process Inlet Steam Temp (°F)							
Condenser Pressure (in Hg)							

PARAMETERS

	5:00	6:00	7:00	8:00					
Cooling Water Temp (°F)									
Boiler Air Inlet To M.H. Temp (°F)	115	110	110	110					
Boiler Flue-Gas Exit From M.H. Temp (°F)	618	618	620	623					
Boiler Inlet Pressure Rise (in H2O)	715	715	718	722					
F.D. Fan Current-(amps)	348	380	350	355					
F.D. Fan Voltage (V)									
ID Fan Pressure Rise (in H2O)	6.2	6.2	6.2	6.2					
ID Fan Current (amps)	0.5	0.5	0.5	0.5					
ID Fan Voltage (V)									
Forced Draft Inlet Air Temp (°F)									
Ambient Air Relative Humidity									
Barometric Pressure (in Hg)									
Ambient Air Temp (°F)									
Boiler Heat Rate (BTU/KW-Hr)									
Boiler Tilt									
Inlet Temp (°F)									
Outlet Temp (°F)									
Inlet Pressure (in H2O)									
Rapping Cycle Period (min)									
Spark Rate (sparks/min)									
Operating Voltage (KV)									
Operating Amps									

Stack Identification Number 7 Date 12-22-72

Boiler Number 26

Plant Location STPA 2000 FT 550000000 73PT

Parameters	10:00	12:00	1:10	2:10	3:00	4:00	5:00
Gross Load (MW)							
Net Load (MW)							
Fuel Flow (gal/hr)	2403651	2402250	0502668	0505462	0507800	0510585	0513311
Steam Flow (lb/hr)	325,000	310,000	310,000	310,000	310,000	320,000	320,000
Feed Water Flow (lb/hr)	300,000	318,000	301,000	301,000	301,000	310,000	310,000
Air Flow	340,000	360,000	350,000	345,000	340,000	340,000	340,000
Excess Air (%)	20.0	22.5	18.5	17.5	16.0	17.30	16.0
Excess O2 (%)	4.0	4.5	3.7	3.5	3.2	3.16	3.2
Soot Blowing	NO						
Boiler Inlet Feed Water Temp (°F)	1150	1160	1150	1160	1160	1160	1170
Boiler Inlet Steam Press. (psig)	900	960	900	900	900	900	900
Boiler Inlet Steam Temp (°F)							
Boiler Inlet Steam Press. (psig)							
Boiler Inlet Steam Temp (°F)							
Boiler Inlet Steam Press. (psig)							
Boiler Inlet Steam Temp (°F)							
Condenser Pressure (in Hg)							

	10:00	10:15	10:30	10:45	11:00	11:15	11:30	11:45	12:00
Cooling Water Temp (°F)									
Boiler Air Inlet Temp (°F)	115	112	110	110	110	110	111	111	112
Boiler Flue Gas Exit Temp (°F)	870	605	600	590	590	600	605	605	605
F.D. Fan Pressure Rise (in H2O)	1.90	705	700	695	700	700	710	710	710
F.D. Fan Current (amps)	340	345	340	340	340	345	350	350	345
F.D. Fan Voltage (V)									
ID Fan Pressure Rise (in H2O)	6.7	6.6	6.9	6.2	6.1	6.2	6.2	6.2	6.2
ID Fan Current (amps)	0.5	-0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
ID Fan Voltage (V)									
Forced Draft Inlet Air Temp (°F)									
Ambient Air Relative Humidity									
Barometric Pressure (in Hg)									
Ambient Air Temp (°F)									
Boiler Heat Rate (BTU/KW-Hr)									
Burner Title									
Inlet Temp (°F)									
Outlet Temp (°F)									
Inlet Pressure (in H2O)									
Sampling Cycle Period (min)									
Spark Rate (sparks/min)									
Operating Voltage (KV)									
Operating Amps									
Operator									

Stack Identification Number 47 Date 12/21/72

Boiler Number 501

Plant Location STILL RT

11/11/72

Parameters							
Gross Load (MW)							
Net Load (MW)	<u>1200</u>	<u>(3450)</u>	<u>(350)</u>	<u>450</u>			
Fuel Flow (GAL/hr)	<u>355666</u>	<u>450000</u>	<u>550386</u>	<u>651163</u>			
Steam Flow (lb/hr)	<u>321000</u>	<u>315000</u>	<u>321100</u>	<u>329000</u>			
Feed Water Flow (lb/hr)	<u>321000</u>	<u>329000</u>	<u>318000</u>	<u>329000</u>			
Air Flow	<u>115000</u>	<u>180000</u>	<u>160000</u>	<u>360000</u>			
Excess Air (%)	<u>21.5</u>	<u>19.5</u>	<u>14.5</u>	<u>14.5</u>			
Excess O ₂ (%)	<u>4.3</u>	<u>3.9</u>	<u>3.4</u>	<u>3.9</u>			
SOOT DRAWING							
BOILER INLET FEED WATER							
TEMP. (°C)	<u>145.0</u>	<u>145.0</u>	<u>116.0</u>	<u>145.0</u>			
BOILER INLET STEAM							
TEMP. (°C)	<u>300</u>	<u>300</u>	<u>300</u>	<u>300</u>			
BOILER INLET STEAM							
TEMP. (°C)							
CONDENSER INLET STEAM							
TEMP. (°C)							
CONDENSER INLET STEAM							
TEMP. (°C)							
CONDENSER EXHAUST STEAM							
TEMP. (°C)							
CONDENSER EXHAUST STEAM							
TEMP. (°C)							
CONDENSER PRESSURE (in Hg)							


Stack Identification Number 44-7 Date 12-28-72

Boiler Number 26

Plant Location ST. Pt.

Parameters	1 st	2 nd	3 rd	4 th	5 th	6 th
Gross Load (MW)	33.6	33.8	33.8	34.0	34.0	34.0
Net Load (MW)	1.25	9.2	2.12	4.15	5.15	6.12
Fuel Flow (gal/hr)	050855	081140	081425	081715	081962	082200
Storm Flow (lb/hr)	320,000	320,000	320,000	320,000	314,000	321,000
Feed Water Flow (lb/hr)	325,000	325,000	325,000	325,000	325,000	325,000
Air Flow	360,000	460,000	360,000	360,000	360,000	360,000
Excess Air (%)	20.05	24.05	26.05	28.0	30.0	32.0
Excess O ₂ (%)	4.05	4.05	4.05	4.0	4.0	4.0
-SOOT-BLISTER-						
COILER INLET Feed Water Temp (°F)	1140	1140	1140	1140	1140	1140
BOILER INLET Steam Temp (°F)	900	900	900	905	905	900
COILER INLET Steam Temp (°F)						
BOILER INLET Steam Temp (°F)						
CONDENSER INLET Steam Temp (°F)						
CONDENSER EXIT Steam Temp (°F)						
CONDENSER PRESSURE (in Hg)						

INLET AIR TEMP (OF)	100	95	97	100	100	105	105
EXHAUST AIR TEMP (OF)	600	600	600	600	600	610	600
INLET FAN PRESSURE RISE (IN H2O)	675	700	700	700	700	708	710
F.D. Fan Current (amps)	330	325	328	332	336	342	
F.D. Fan Voltage (V)							
ID Fan Pressure Rise (IN H2O)	6.5	6.4	6.4	6.4	6.5	6.5	6.5
ID Fan Current (amps)	160	160	160	158	160	160	160
ID Fan Voltage (V)							
FORCED DRAFT INLET AIR TEMP (OF)							
AMBIENT AIR RELATIVE HUMIDITY							
BAROMETRIC PRESSURE (IN HG)			29.94			30.02	
AMBIENT AIR TEMP (OF)							
BOILER HEAT RATE (BTU/HR-HR)							
BURNER FLAME							
INLET TEMP (OF)							
CURTAIN TEMP (OF)							
INLET PRESSURE (IN H2O)							
RAPPING CYCLE PERIOD (MIN)							
SPARK RATE (SPARKS/MIN)							
OPERATING VOLTAGE (KV)							
OPERATING AMPS							



2-1-57

TEST NO. 3

Calibrate
Test 3
5:57 PM

zero check


Sample
5:40 PM
Test 3
Boiler 13

No
calibrate
20%
4:20 PM

Sample
5:30 PM
Test 3
Boiler 13

English station
Stack No 5
Test No 3

12/28/73



02x256

CO2x512

Sample
3-2
Boiler
#13

N2x512

02x256

CO2x512


Sample 3-1
Test 3

CO2x28

N2x512

02x256

CO2x512



CO2 128

N2 504

O2 256

CO2 512

Calibrate

N2 824

CO2 512

O2 256

sample 3-3 Test 3 polar B

N2 1024

APPENDIX C

BOILER OPERATING DATA

Date Dec 28, 1973

Stack Identification Number 5
 Boiler Number 13
 Plant Location English Sta

<u>Parameters</u>	<u>1340</u>	<u>1450</u>	<u>1607</u>	<u>1803</u>
Gross Load (MW)	34	33.5	33.5	33
Net Load (MW)	—	—	—	—
Fuel Flow (gal/hr) <u>Meter</u>	<u>593281</u>	<u>516912</u>	<u>600403</u>	<u>125624</u>
Steam Flow (lb/hr)	310,000	305,000	305,000	305,000
Feed Water Flow (lb/hr)	310,000	330,000	330,000	315,000
Air Flow	275,000	330,000	310,000	310,000
Excess Air (%)	—	—	—	—
Excess O ₂ (%)	3.8	3.9	3.8	3.8
Soot Blowing	—	—	—	—
Boiler Inlet Feed Water Temp (°F)	380	380	370	350
Boiler Exit Steam Press. (psig)	860	870	870	870
Boiler Exit Steam Temp (°F)	870	870	870	870
Reheat Inlet Steam Press. (psig)	—	—	—	—
Reheat Inlet Steam Temp (°F)	—	—	—	—
Reheat Exit Steam Press. (psig)	—	—	—	—
Reheat Exit Steam Temp (°F)	—	—	—	—
Condenser Pressure (in Hg)	29.30	29.35	29.35	29.35

Parameters	1803	1607	1803
Cooling Water Temp (°F)	1450	1607	1803
Boiler Air Inlet Temp (°F)	43/43	115	44/44
Air Heater Inlet	105	115	110
Boiler Flue Gas Exit Temp (°F)	320	315	320
Air Filter Outlet	6.9	6.5	6.5
F.D. Fan Pressure Rise (in H2O)	230	230	232
F.D. Fan Current (amps)	—	—	—
F.D. Fan Voltage (V)	—	—	—
DISC PRESS.	—	—	—
ID Fan Pressure Rise (in H2O)	—	—	—
ID Fan Current (amps)	—	—	—
ID Fan Voltage (V)	—	—	—
Forced Draft Inlet Air Temp (°F)	—	—	—
Ambient Air Relative Humidity	—	—	—
Barometric Pressure (in Hg)	29.89	29.89	29.90
Ambient Air Temp (°F)	50	50	—
Boiler Heat Rate (BTU/KW-hr)	—	—	—
Burner Tilt	—	—	—
Inlet Temp (°F)	320	315	320
Outlet Temp (°F)	—	—	—
Inlet Pressure (in H2O)	—	—	—
Rapping Cycle Period (min)	—	—	—
Spark Rate (sparks/min)	—	—	—
Operating Voltage (V) Primary	—	—	—
Operating Amps Primary	—	—	—

2-1-67

APPENDIX D

SAMPLE CALCULATIONS

SAMPLE CALCULATIONS

NOTE: All equations used in these calculations are found in the Federal Register, Vol. 36, No. 247, dated December 23, 1971.

Calculations representative of Test #1.

1. Dry Gas Volume

$$\begin{aligned} V_{mstd} &= \left(17.71 \frac{^{\circ}R}{\text{in. Hg.}} \right) V_m \left(\frac{P_{\text{bar}} + \frac{\Delta H}{13.6}}{T_m} \right) && \text{eq. 5-1} \\ &= \left(17.71 \frac{^{\circ}R}{\text{in. Hg.}} \right) 19.172 \text{ ft}^3 \left(\frac{29.89 \text{ in.hg} + \frac{0.324 \text{ in H}_2\text{O}}{13.6}}{525.9 \text{ } ^{\circ}R} \right) \\ &= 19.313 \text{ ft}^3 \end{aligned}$$

2. Volume of Water Vapor

$$\begin{aligned} V_{wstd} &= \left(0.0474 \frac{\text{Ft}^3}{\text{ml.}} \right) V_{lc} && \text{eq. 5-2} \\ &= \left(0.0474 \frac{\text{Ft}^3}{\text{ml.}} \right) 31.1 \text{ ml.} \\ &= 1.474 \text{ Ft}^3 \end{aligned}$$

3. Moisture Content

$$\begin{aligned} Bws &= \frac{V_{wstd}}{V_{wstd} + V_{mstd}} && \text{eq. 5-3} \\ &= \frac{1.474 \text{ Ft}^3}{1.474 \text{ Ft}^3 + 19.313 \text{ Ft}^3} \\ &= 0.0709 \times 100\% = 7.1\% \end{aligned}$$

4. Molecular Weight (dry)

$$\begin{aligned} M_d &= 0.44 (\% \text{ CO}_2) + 0.32 (\% \text{ O}_2) \\ &\quad + 0.28 (\% \text{ N}_2) + 0.28 (\% \text{ CO}) \qquad \text{eq. 3-2} \\ &= 0.44 (11.53) + 0.32 (6.98) + 0.28 (81.49) \\ &\quad + 0.28 (0.00) \\ &= 30.12 \text{ lb/lb-mole} \end{aligned}$$

5. Molecular Weight (wet)

$$\begin{aligned} M_s &= M_d (1 - B_{ws}) + 18 B_{ws} \\ &= 30.12 (1 - 0.071) + 18 (.071) \\ &= 29.26 \text{ lb/lb-mole} \end{aligned}$$

6. Stack Gas Velocity

$$\begin{aligned} V_s &= K_p C_p \sqrt{\Delta P} \left(\frac{\bar{T}_s}{P_s \times M_s} \right)^{1/2} \qquad \text{eq. 2-2} \\ &= (85.48) (.84) (.589) \left(\frac{765.8}{29.87 \times 29.26} \right)^{1/2} \\ &= 39.59 \text{ F.P.S.} \end{aligned}$$

7. Gas Volumetric Flow Rate, ACFM

$$\begin{aligned} \text{ACFM} &= V_s \times A_s \times 60 \text{ sec/min} \\ &= 39.59 \times 68.38 \text{ Ft}^2 \times 60 \text{ sec/min} \\ &= 162,430 \text{ ACFM} \end{aligned}$$

8. Gas Volumetric Flow Rate, SCFM

$$\begin{aligned} Q_s &= 60 (1 - B_{ws}) V_s A_s \left(\frac{T_{std}}{T_s} \right) \left(\frac{P_s}{P_{std}} \right) \qquad \text{eq. 2-3} \\ &= 60 (1 - 0.071) (39.59) (68.38) \left(\frac{530}{765.8} \right) \left(\frac{29.87}{29.92} \right) \\ &= 104,260 \text{ SCFM} \end{aligned}$$

9. Gas Volumetric Flow Rate, lb/hr

$$\begin{aligned}
 W_s &= Q_s \times \frac{60 \text{ min}}{\text{hr}} \times \frac{M_d}{386 \text{ Ft}^3} \\
 &= 104,260 \text{ SCFM} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{30.12 \text{ lb/lb-mole}}{386 \text{ Ft}^3} \\
 &= 488,131 \text{ lb/hr}
 \end{aligned}$$

10. Particulate Concentrations, gr/SCF

$$\begin{aligned}
 C's &= \left(0.0154 \frac{\text{gr.}}{\text{mg.}} \right) \frac{M_n}{V_{mstd}} && \text{eq. 5-4} \\
 &= \left(0.0154 \frac{\text{gr.}}{\text{mg.}} \right) \frac{25.3 \text{ mg.}}{19.313 \text{ Ft}^3} \\
 &= 0.0201 \text{ gr/SCF}
 \end{aligned}$$

11. Particulate Concentrations, lb/Ft³

$$\begin{aligned}
 C_s &= \frac{\left(\frac{1}{453600} \frac{\text{lb}}{\text{mg}} \right) M_n}{V_{mstd}} && \text{eq. 5-5} \\
 &= \frac{\left(\frac{1}{453600} \frac{\text{lb}}{\text{mg}} \right) 25.3 \text{ mg.}}{19.313 \text{ Ft}^3} \\
 &= 2.88 \times 10^{-6} \text{ lb/SCF}
 \end{aligned}$$

12. Particulate Concentrations, lb/hr

$$\begin{aligned}
 C_w &= C_s Q_s \times \frac{60 \text{ min}}{\text{hr}} \\
 &= (2.88 \times 10^{-6} \text{ lb/SCF}) (104,260 \text{ SCFM}) \frac{60 \text{ min}}{\text{hr}} \\
 &= 18.02 \text{ lb/hr}
 \end{aligned}$$

13. Particulate Concentrations, lb/MBTU

$$\begin{aligned}
 E_r &= \frac{C_w}{\text{Heat Input}} \\
 &= \frac{18.02 \text{ lb/hr}}{401.1 \times 10^6 \text{ BTU/hr}} \\
 &= 0.045 \text{ lb/MBTU}
 \end{aligned}$$

14. % Isokinetic Sampling

$$I = \frac{\bar{Ts} (1.667 \frac{\text{min}}{\text{sec}})}{\ominus \frac{Vs Ps An}{\left((0.00267) Vlc + \frac{VM}{Tm} \left(Pbar + \frac{\Delta H}{13.6} \right) \right)}}$$

eq. 5-6

$$I = \frac{765.8 (1.667)}{(60) (39.59) (29.87) (1.916 \times 10^{-4})} \left((0.00267) (31.1) + \frac{19.172}{525.9} 29.89 + \left(\frac{0.324}{13.6} \right) \right)$$

$$= 110.2\%$$

15. NO_x Concentrations, lb/hr

$$\text{lb/hr} = \text{PPM} \times \frac{Mw (\text{NO}_2)}{Md} \times Ws$$

$$= \frac{109}{10^6} \times \frac{46 \text{ lb/lb-mole}}{30.12 \text{ lb/lb-mole}} \times 488,131 \frac{\text{lb}}{\text{hr}}$$

$$= 81.3 \text{ lb/hr}$$

16. NO_x Concentrations, lb/MBTU

$$\text{lb/MBTU} = \frac{\text{lb/hr}}{\text{Heat Input}}$$

$$= \frac{81.3 \text{ lb/hr}}{401.1 \times 10^6 \text{ BTU/hr}}$$

$$= \frac{0.203 \text{ lb}}{10^6 \text{ BTU}}$$

17. Stack Pressure (Absolute) in. Hg.

$$Ps = Pb + \frac{Pd}{13.6} = 29.89 + \frac{(-0.31)}{13.6} = 29.87 \text{ in. Hg.}$$

18. Nozzle Area (Ft²)

$$An = \pi D^2 / 4 = 0.785 (0.1875/12)^2 = 1.916 \times 10^{-4} \text{ Ft}^2$$

19. Stack Area (Ft²)

$$A_s = \pi D^2 / 4 = 0.785 (112/12)^2 = 68.38 \text{ Ft}^2$$

20. Heat Input, MBTU

$$\text{Sp. Gr.} \times 8.33 \text{ lb/gal} \times \text{BTU/lb} \times \text{gal/hr}$$

$$0.909 \times 8.33 \times 19,438 \times 2725 = 401.1 \times 10^6 \text{ BTU}$$

21. Gas Density, lb/Ft³

$$\text{Gas Density} = \frac{\text{mol wt gas (md)}}{386 \text{ Ft}^3} \times \frac{T_{\text{std}}}{T_s} \times \frac{P_{\text{bar}}}{P_{\text{std}}}$$

$$= \frac{30.12}{386} \times \frac{530 \text{ } ^\circ\text{R}}{765.8} \times \frac{29.89}{29.92} = 0.054 \text{ lb/Ft}^3$$

THE UNITED ILLUMINATING COMPANY
SOURCE TESTING CALCULATION FORMS

Test No. English Station #5 No. Runs 3
 Name of Firm United Illuminating Company
 Location of Plant 510 Grand Avenue, New Haven, Connecticut
 Type of Plant Steam Generating Station
 Control Equipment Electrostatic Precipitator
 Sampling Point Locations Stack
 Pollutants Sampled Particulates, Nitrogen Oxides

Time of Particulate Test:

Run No. <u>1</u>	Date <u>12/28/73</u>	Begin <u>1350</u>	End <u>1504</u>
Run No. <u>2</u>	Date <u>12/28/73</u>	Begin <u>1535</u>	End <u>1645</u>
Run No. <u>3</u>	Date <u>12/28/73</u>	Begin <u>1714</u>	End <u>1823</u>

PARTICULATE EMISSION DATA

Run No.	1	2	3	
$K_p = 95.48 \frac{ft}{sec} \left(\frac{lb.}{lb. mole \cdot OR} \right)^{\frac{1}{2}}$	85.48	85.48	85.48	
$C_p =$ Pitot tube coefficient (calib.)	0.84	0.84	0.84	
$\sqrt{VAP} =$ Average velocity head of stack gas, inches H ₂ O	0.589	0.596	0.619	
$\bar{T}_s =$ Average stack temp., °R	765.8	767.1	770.0	
$P_b =$ Barometric pressure, "Hg Abs.	29.89	29.89	29.90	
$P_d =$ Gas duct pressure, "H ₂ O	-0.31	-0.30	-0.35	
$P_s =$ Absolute stack gas pressure, inches Hg	29.87	29.87	29.87	
$B_{ws} =$ % moisture in stack gas, by volume	7.1	9.1	12.6	
$M_d =$ Molecular weight of stack gas, dry	30.12	30.12	30.10	
$M_s =$ Molecular weight of stack gas	29.26	29.02	28.58	

V_s = Stack gas velocity, F.P.S.	39.59	40.26	42.21	
% CO ₂	11.53	11.51	11.35	
% O ₂	6.98	6.98	7.11	
% CO	0.00	0.00	0.00	
% N ₂	81.49	81.51	81.54	
V_{lc} = Total volume of liquid collected in impingers and silica gel, ml.	31.1	67.1	103.3	
V_m = Volume of dry gas sampled at meter conditions, FT ³	19.172	31.675	33.637	
V_{std} = Volume of dry gas sampled at STP, FT ³	19.313	31.710	34.051	
T_m = Average dry gas meter temp., °R	525.9	530.2	524.5	
ΔH = Average pressure drop across orifice, inches H ₂ O	0.324	1.018	1.098	
θ = Total Sampling Time, min.	60	60	60	
D_n = Nozzle dia., inches	0.1875	0.250	0.250	
A_n = Nozzle area, FT ² ($\times 10^{-4}$)	1.916	3.407	3.407	
I = % of isokinetic sampling	110.2	102.4	109.5	
Q_s = Stack gas volume at STP (SCFM)	104,260	103,566	104,008	103,945
Q_a = Stack gas volume at stack conditions (ACFM)	162,430	165,179	173,179	166,929
W_s = Stack gas mass flow lbs/hr	488,131	484,882	486,628	486,547
M_p = Particulate-probe, washings, mg	-	-	-	
M_f = Particulate-filter (mg)	-	-	-	
M_n = Particulate-total (mg)	25.3	16.1	36.9	
$C's$ = Particulate Concentrations gr/scf	0.020	0.008	0.017	0.015
Q_v = Particulate total emission lb/hr	18.02	6.90	14.85	13.26
E_r = Particulate emission rate, lb/10 ⁶ BTU	0.045	0.017	0.037	0.03
C = NO _x concentrations, PPM	109	108	108	
C_n = NO _x , lb/10 ⁶ BTU	0.203	0.200	0.200	0.20

OAQPS - 78-1

II - I - 259

FUEL
OIL COMBUSTION
AP-42 Section 1.3
Reference Number
24

4/93 Ref 21

Emission Test Report


Bridgeport Harbor Station Stack No. 3

Steam Generator No. 3


1968

The United Illuminating Company
Bridgeport Harbor Station
10 Henry Street
Bridgeport, Connecticut
06604

Approved by:

R.J. Grose 
Vice President, Engineering and Planning

Submitted by:

M.R. McCraven 
Director of Environmental Engineering

Emission Test Report

Bridgeport Harbor Station Stack No. 3
Steam Generator No. 3
(Ref. "Intent to Test" Form Number 720055)

Test Conducted by
The United Illuminating Company
Development and Test Laboratory
80 Temple Street
New Haven, Connecticut
06506

United Illuminating Company Personnel Present
J. Hotchkiss
J. Macknis
M. Collins

and by
York Research Corporation
One Research Drive
Stamford, Connecticut
06906

York Research Corporation Personnel Present
R. Larkin
J. Kittrell

Prepared by:

J.S. Sombati *J.S. Sombati*
Development & Test Laboratory Supervisor

J.W. Hotchkiss *J.W. Hotchkiss*
Assistant Mechanical Engineer

Checked by:

J.F. Crowe *J.F. Crowe*
Chief Mechanical Engineer

Test Results

Bridgeport Harbor Station
Steam Generator No. 3

Test Conducted on
February 21, 22, 1974

Introduction

Emission tests for particulates and nitrogen oxides were conducted as required by Connecticut State Law on The United Illuminating Company Bridgeport Harbor Station Steam Generator No. 3, Stack No. 3, located in Bridgeport, Connecticut. Testing was conducted on February 21 and 22, 1974.

Particulate testing was performed in accordance with test methods and procedures as prescribed in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. Testing was performed by York Research Corporation of Stamford, Connecticut, using a sampling train as described in Appendix A.

Nitrogen oxide emission testing was performed by the United Illuminating Company Development and Test Laboratory using a Dynascience Model P-101 NO_x Analyzer. It is to be noted that the Nitrogen Oxide Test Results for test No. 1 indicate the unit to be in violation. However, averaging all three test results show the unit to comply with the allowable emission rate of 0.30 lb./MBTU. Field data is included in Appendix B.

Tests were also conducted to determine stack gas velocity, moisture content and flue-gas analysis. The procedures used in determining these various parameters, except for flue gas analysis, are those found in the abovementioned Federal Register. The stack flue gas was analyzed by using an Analytical Instrument Development Model 512 Portable Gas Chromatograph.

York Research Corporation was retained to perform particulate tests, together with a preliminary velocity traverse, moisture determination, and fuel oil analysis. The United Illuminating Company was responsible for the flue gas analysis, nitrogen oxide analysis, and for accumulating boiler operating data.

This test report includes the information required for Item Nos. III, IV, V, VI, VII, VIII, IX, X, XI, XII and XIII from the Department of Environmental Protection's Intent to Test form in compliance with the Department of Environmental Protection's new Source Test Guidelines and Procedures, (Received April 3, 1973).

TABLE I

SUMMARY OF TEST RESULTS

STEAM GENERATOR NO. 3

STACK NO. 3

<u>Component</u>	<u>Sampling Minutes per point</u>	<u>Duration Total Test Time</u>	<u>Number Of Tests</u>	<u>Measured Concentrations</u>	<u>Method Employed to Determine Concentration</u>
1) NO _x		15 min.	3	0.30 lb/10 ⁶ BTU	Dynascience Model P-101 NO _x Analyzer
2) Particulate	5	60 min.	3	0.02 lb/10 ⁶ BTU	Method 5*
3) Moisture	5	60 min.	3	8.6%	Method 4*
4) Gas Analysis		15 min.	3	33% Excess Air	A.I.D. Model 512 Portable Gas Chromatograph
5) Velocity	½	15 min.	3	1.1" H ₂ O to 1.5" H ₂ O**	Method 2*

* Federal Register, Volume 36, No. 247, December 23, 1971

** Range of S-Type Pitot Tube Differential

TABLE III

AVERAGE BOILER OPERATING DATA FOR TEST PERIODS

STEAM GENERATOR NO. 3

STACK NO. 3

	<u>1</u>	<u>2</u>	<u>3</u>
Test			
Date	2/21/74	2/21/74	2/22/74
Steam Flow lb/hr	2,512,743 ¹⁶⁴	2,449,000	2,449,800
Oil Flow gal/hr	27,942	27,000	27,140
Heat Input, MBTU/hr	4011.4	3889.5	3910.0
Stack Gas Temp. °F	290	290	290
Gas Density, lb/ft ³	.055	.056	.054

TABLE IV
SUMMARY OF RESULTS
STEAM GENERATOR NO. 3

	<u>STACK NO. 3</u>		
	<u>1</u>	<u>2</u>	<u>3</u>
Date	2/21/74	2/21/74	2/22/74
<u>Composition (% by weight)</u>			
Carbon	85.70	85.59	86.74
Hydrogen	13.07	12.68	12.99
Nitrogen	0.1	0.1	0.1
Ash	0.018	0.019	0.018
Sulfur	0.34	0.37	0.34
Specific Gravity	0.90	0.90	0.90
BTU/lb	19,149	19,215	19,217

1. Sampling Train Information

(Rev. Item VIII, "Intent To Test" Form)

- a. Schematic Diagram and description of sampling train:

See Appendix A.

- b. Media type used to determine gas stream components:

1. NO_x: Dynascience Model P-101 NO_x Analyzer
2. Particulates: Tared glass fiber filter.
3. Flue Gas Analysis: Analytical Instrument Development Model 512 Portable Gas Chromatograph

- c. Sampling Probes:

1. Nitrogen Oxides: Stainless steel tube
2. Particulates: See Appendix A
3. Flue Gas Analysis: Stainless steel tube.

- d. Probe Cleaning Method:

See Appendix A

2. Field Data Sheets

Ref. Item IX, "Intent To Test" Form)

See Appendices A, B, C, D.

3. Description of Operation

Ref. Item X, "Intent To Test" Form)

The operation tested was Bridgeport Harbor Station steam generator No. 3, stack No. 3, Registration Number BHS 3, stack 3, having a total BTU/hr rating of 3937 MBTU/hr (averaged over the test period), burning No. 6 residual fuel oil at an average rate of 27,360 gal/hr, and having a gas flow of 1,287,034 ACFM, average for the test period. See Table IV for fuel oil analysis.

4. Sampling Area Description
(Ref. Item XI, "Intent To Test" Form)

Emission sampling was performed in the stack 243 feet above the stack foundation (approximately 10 stack diameters above the breeching inlets and approximately 15 stack diameters down from the top). Emission sampling was performed using four 4" diameter sampling ports, spaced 90° apart on the stack circumference. A total of twelve sampling points (3 per sampling port) were used in the test for particulates. The inside diameter of the stack at the sampling location was found to be 18'-7 7/8"

a. Stack Configuration:

See Appendix A

b. Sampling Port Location:

See Appendix A

c. Sampling Point Position:

See Appendix A

5. Stack and Vent Description
(Ref. Item XII, "Intent To Test" Form)

One Combustion Engineering tangentially-fired Radiant Reheat Boiler discharges flue gas through two breechings into the stack. Attached to the outlet of the boiler is a Research-Cottrell electrostatic precipitator, having an estimated collection efficiency of 75% when burning No.6 residual fuel oil.

6. Operational Parameters
(Ref. Item XIII, "Intent To Test" Form)

Electric utility steam generator burning No.6 residual fuel oil having rated capacities as registered.

APPENDIX A
PARTICULATE TEST

V. SAMPLING METHODS

1. Port Location

The test port locations and the number of points sampled were calculated from guidelines in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. Enough points were used to assure accurate measurement of particulate emissions, temperature, and velocity over the cross-sectional area of each stack (See Figures 1-4).

2. Velocity and Temperature

Velocity was determined in accordance with Guidelines in Method 2 of the Federal Register. A preliminary velocity traverse was made to establish isokinetic sampling rates using EPA Method 5 sampling techniques (See Figure #6).

3. Flue Gas Analysis

Gas analysis for CO₂ and O₂ was conducted by UI using an Orsat apparatus. Readings for each test are reported in the Summary of Results.

4. Particulate Sampling Methods - EPA Method 5

The sampling apparatus consisted of a nine (9) foot probe on Unit 2 and a fifteen (15) foot probe on Unit 3, heated filter, four impingers, dry gas meter, vacuum pump, and calibrated orifice as shown in Figure 5. The stainless steel, button-hook type sampling nozzle (1), Type "S" pitot tube (2), and thermocouple (3), extended from the sampling end of the probe, which consisted of $\frac{1}{2}$ inch inside diameter medium-wall stainless steel tube with a ground steel joint on one end. The probe was logarithmically wound from the entrance end with 26-gauge nickel-chromium wire. During sampling, the wire was connected to a variable transformer to maintain a gas temperature of 250°F in the probe. The wire wound tube was wrapped with fiber glass tape and encased in a 1-inch-OD stainless steel tube for protection. The end of the steel tube that does not have the ball-joint protruding has a nut welded to it for connection to the stainless steel coupling used to attach the nozzle. The probe connects to a very coarse fritted glass filter holder (5) which holds a tared glass fiber filter. The filter holder was con-

tained in an electrically heated enclosed box (4) which is thermostatically maintained at a minimum temperature of 250°F to prevent water condensation. Attached to the heated box with tygon tubing was an ice bath (7) containing four impingers connected in series with vacuum hose. The first impinger (8) receives the gas stream from the filter. This impinger is of the Greenburg-Smith design modified by replacing the tip with a 1/2 inch ID glass tube extending to 0.5 inch from the bottom of the flask. This impinger was initially filled with 100 milliliters of distilled water. The second impinger (9) is a Greenburg-Smith impinger with tip, and also filled with 100 milliliters of distilled water. The third impinger (10) modified like the first, with no water. The fourth impinger (11) is also a Greenburg-Smith type modified like the first and contained 300 grams of dry indicating silica gel.

From the fourth impinger the effluent stream flows through a dial thermometer (12), a check valve (13); flexible rubber vacuum tubing (14); vacuum gauge (15); a valve (16); a leakless vacuum pump (17), rated at 4 cubic feet per minute at 0 inches of mercury gauge pressure and 0 cubic feet per minute at 26 inches of mercury gauge pressure, and connected in parallel with a bypass needle valve (18); and a dry gas meter rated at .1 cubic foot per revolution (19). A calibrated orifice (20) completes the train and was used to measure instantaneous meter flow rates. The three thermometers (12) are dial type with a range of 25° to 125°F. A fourth thermometer in the heated portion of the box has a range up to 500°F. The dual manometer (21) across the calibrated orifice is an inclined-vertical type graduated in hundredths of an inch of water from 0 to 1.0 inch and in tenths from .1 to 10 inches.

5. Test Procedure

Prior to the start of a test series for each stack, the pressure, temperature, and range of velocity pressures were determined during preliminary pitot tube and temperature traverse.

During each test the following readings were taken at each point:

1. Point Designation
2. Clock Time
3. Dry gas meter reading (CF)
4. Velocity head (ΔP in inches water)
5. Desired pressure drop across orifice (ΔH inches water)
6. Actual pressure drop across orifice (ΔH in inches water)
7. Dry gas temperature (°F) gas meter inlet
8. Dry gas temperature (°F) gas meter outlet.
9. Vacuum pump gauge reading (in. Hg).

10. Filter box temperature ($^{\circ}\text{F}$)
11. Dry gas temperature ($^{\circ}\text{F}$) at the discharge of last impinger
12. Stack temperature ($^{\circ}\text{F}$)

The relationship of ΔP reading with the ΔH reading is a function of the following variables:

1. Orifice calibration factor
2. Gas meter temperature
3. % moisture in the flue gas
4. Ratio of flue gas pressure to barometric pressure
5. Stack temperature
6. Sampling nozzle diameter

A nomograph was used to correlate all the above variables such that a direct relationship between ΔP and ΔH could be determined by the sampler within fifteen seconds and isokinetic conditions maintained throughout the test.

6. BASIC LABORATORY PROCEDURE

The following paragraph briefly describes the methods used in the laboratory to obtain the raw data used in the calculations of our results as reported in Section III and VI of this report.

The clean up is done in the field according to EPA test procedure. The filters were previously tare weighed and recorded at the laboratory. Upon return they are dried, cooled in a dessicator, then weighed on an analytical balance and the amount of particulate collected is the difference in the two weights. The particulate wash solution (taken from the train in front of the filter) is placed in a tared beaker, the wash solution is evaporated with an Infra-Red Heat Lamp and the beaker weighed again. The difference in weight is the weight of the particulate in the wash. This is combined with the filter catch as the weight of the sample.

The impinger condensate is measured for moisture determination.

CALIBRATION


The equipment used on this assignment was calibrated one week prior to field testing and re-calibrated upon equipment return after testing. York Research calibration is traceable to the National Bureau of Standards.



TEST TEAM

Robert J. Larkin
James R. Kittrell


Prepared By:


Robert J. Larkin
Test Engineer

Reviewed By:


Robert S. Epstein
Project Director


Approved By:


Roy S. Egddall
Manager Engineering Services




SAMPLING TRAIN

Figure No. 5



VELOCITY MEASUREMENT
APPARATUS
FIGURE # 6




STACK WALL

MANOMETER

PYROMETER

ORSAT



PLANT W. Harbor St.
 DATE 3/21/74
 SAMPLING LOCATION Stack 3
 SAMPLE TYPE Particulates
 RUN NUMBER 1
 OPERATOR R.T.L.
 AMBIENT TEMPERATURE 40
 BAROMETRIC PRESSURE 30.25
 STATIC PRESSURE (in. H₂O) 5.668
 FILTER NUMBER (s) 57-668

69 ml H₂O collected

FIELD DATA

SCHEMATIC OF TRAVERSE POINT LAYOUT:
 READ AND RECORD ALL DATA EVERY 5 MINUTES


PROBE LENGTH AND TYPE 26-15.5
 NOZZLE I.D. 3/16
 ASSUMED MOISTURE % 10
 SAMPLE BOX NUMBER 1578
 METER BOX NUMBER 188
 METER SH# 94
 C FACTOR -
 PROBE HEATER SETTING -
 HEATER BOX SETTING -
 REFERENCE DP 2.1

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (m ³ , H ₂)	VELOCITY HEAD (sq. in. H ₂ O)	ORIFICE PRESSURE DIFFERENTIAL (sq. in. H ₂ O)		STACK TEMPERATURE (T _s) °F	DRY GAS METER TEMPERATURE (T _m , in. °F)		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
				DESIGNED	ACTUAL		INLET	OUTLET			
E 1	1220	3.048	1.45	1.30	1.30	290	60	60	3	300	70
2	1235	8.00	1.35	1.31	1.31	290	60	64			
3	1230	10.448	1.15	1.03	1.03	290	72	64			
END	1235	10.448	1.50	1.34	1.34	290	60	60			
E 1	1243	10.448	1.25	1.12	1.12	290	61	60			
2	1248	13.80	1.25	1.12	1.12	290	70	62			
3	1253	16.04	1.20	1.08	1.08	290	60	60			
END	1255	16.04	1.50	1.34	1.34	290	60	60			
E 1	1311	19.000	1.45	1.30	1.30	290	58	57			
2	1316	22.30	1.45	1.30	1.30	290	60	55			
3	1321	24.91	1.15	1.03	1.03	290	60	55			
END	1324	27.500	1.15	1.03	1.03	290	43	42			
E 1	1344	22.510	1.50	1.34	1.34	290	46	44			
2	1349	30.44	1.50	1.34	1.34	290	48	43			
3	1354	33.51	1.30	1.15	1.15	290					
END	1404	36.564									

COMMENTS:

ES-011

REPORT NO. Y-8278-3



FIELD DATA

PLANT W. Harbor St
 DATE 2/23/74
 SAMPLING LOCATION Stack 3
 SAMPLE TYPE Particulate
 RUN NUMBER 3
 OPERATOR RST
 AMBIENT TEMPERATURE 45
 BAROMETRIC PRESSURE 30.5
 STATIC PRESSURE (P_s) 5
 FILTER NUMBER (S1) LE-669


70 m¹ H₂O
 collected

PROBE LENGTH AND TYPE 315" S.S.
 NOZZLE I.D. 2 1/8"
 ASSUMED MOISTURE % 10
 SAMPLE BOX NUMBER 1528
 METER BOX NUMBER 1528
 METER SN. 1528
 C FACTOR 1.1
 PROBE HEATER SETTING _____
 HEATH BOX SETTING _____
 REFERENCE SP 2.1

READ AND RECORD ALL DATA EVERY 5 MINUTES
 SCHEMATIC OF TRAVERSE POINT LAYOUT

TRAVERSE POINT NUMBER	SAMPLING TIME min	CLOCK TIME (24 hr CLOCAL)	GAS METER READING (V _m , ft ³)	VELOCITY HEAD (app. in. H ₂ O)	ORIFICE PRESSURE DIFFERENTIAL (2 in. in. H ₂ O)		STACK TEMPERATURE (T _s , °F)	DRY GAS METER TEMPERATURE		PUMP VACUUM (in. Hg)	SAMPLE BOX TEMPERATURE (°F)	SAMPLING TEMPERATURE (°F)
					DESIRED	ACTUAL		INLET (T _{m in} , °F)	OUTLET (T _{m out} , °F)			
E 1	1512		6.565	1.500	1.34	1.34	290	40	39	3	100	70
2	1532		4.44	1.45	1.30	1.30	290	50	43			
3	1537		12.66	1.20	1.08	1.08	290	51	54			
END	1533		15.511	1.50	1.34	1.34	290	50	52			
N 1	1539		15.511	1.40	1.24	1.24	290	52	47			
2	1544		18.28	1.20	1.08	1.08	290	54	46			
3	1549		21.74	1.20	1.08	1.08	290	54	46			
END	1554		24.322	1.35	1.12	1.12	290	45	45			
W 1	1604		24.322	1.40	1.24	1.24	290	57	46			
2	1609		32.81	1.40	1.24	1.24	290	53	46			
3	1614		30.42	1.10	1.08	1.08	290	53	46			
END	1619		33.248	1.40	1.24	1.24	290	46	44			
5 1	1625		33.248	1.35	1.12	1.12	290	50	46			
2	1633		35.46	1.35	1.12	1.12	290	53	47			
3	1638		39.18	1.10	1.08	1.08	290	53	47			
END	1643		41.912									

COMMENTS:



FIELD DATA

PLANT W. H. Huber St
 DATE 2/22/74
 SAMPLING LOCATION Stack 3
 SAMPLE TYPE Particulate
 RUN NUMBER 3
 OPERATOR PSL
 AMBIENT TEMPERATURE 45
 BAROMETRIC PRESSURE 30.60
 STATIC PRESSURE (P_s) 5
 FILTER NUMBER (F) E1-623

SD ml H₂O collected

PROBE LENGTH AND TYPE 24'-1 S.S.
 NOZZLE I.D. 1/8"
 ASSUMED MOISTURE % 10
 SAMPLE BOX NUMBER 1578
 METER BOX NUMBER 1578
 METER SH. 1.88
 C FACTOR 1.9
 PROBE HEATER SETTING -
 HEATER BOX SETTING -
 REFERENCE SD 1.1

SCHEMATIC OF TRAVERSE POINT LAYOUT
 READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER	SAMPLING TIME, min	CLOCK TIME (24 hr CLOCK)	GAS METER READING (V _m) (1)	VELOCITY HEAD (V _m) (2)	ORIFICE PRESSURE DIFFERENTIAL (3)(4) (in. H ₂ O)		STACK TEMPERATURE (T _s) (5) (°F)	DRY GAS METER TEMPERATURE (6)(7) (°F)		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
					DESIRED	ACTUAL		INLET (T _{m in}) (6)	OUTLET (T _{m out}) (7)			
SL	0918		23.220	1.50	1.34	1.34	240	50	50	3	300	20
2	0923		25.36	1.30	1.18	1.18	240	50	50			
3	0926		26.14	1.25	1.12	1.12	240	50	50			
EWD	0933		31.000	1.45	1.30	1.30	240	51	52			
EWD	0940		31.000	1.30	1.18	1.18	240	51	51			
W1	0945		34.16	1.35	1.13	1.13	240	51	51			
2	0945		32.10	1.35	1.13	1.13	240	51	51			
3	0950		40.08	1.45	1.30	1.30	240	54	52			
EWD	0955		40.08	1.30	1.18	1.18	240	56	52			
W1	1005		43.25	1.30	1.18	1.18	240	55	53			
2	1010		46.00	1.15	1.03	1.03	240	53	53			
3	1015		46.00	1.15	1.03	1.03	240	53	52			
EWD	1020		48.261	1.40	1.24	1.24	240	53	51			
EWD	1031		52.20	1.25	1.12	1.12	240	55	53			
E1	1036		55.00	1.30	1.08	1.08	240	57	53			
2	1041		57.843	1.30	1.08	1.08	240	57	53			
EWD	1046											

CONTINUED

York Research Corporation

Pitot Tube Calibration

ΔP_{std}	ΔP_s	$\frac{\Delta P_{std}}{\Delta P_s}$	F_s
.37	.50	.731	.860
.55	.75	.733	.856
.74	1.00	.740	.860
.92	1.25	.736	.858
1.12	1.50	.747	.864

$$F_s = \sqrt{\frac{\Delta P_{std}}{\Delta P_s}}$$

Pitot Tube # 15F

$F_s =$ 860

$F_{std} = 1.00$

Calibrated by CW/Elm

Date 12/4/73

nick Connects OK Valves OK

ars OK

t Meter OK

eters OK

cal Check - Amphenol OK

Gauge OK

neck at 27" hg. - 0 CFM

Check each item when checked and write in any remarks.

Calibration - Orifice and Meter

2-15-74 Box No. S-1578 P_b 30.42

CF _w	CF _d	T _w	IT _d	OT _d	T _d Avg.	Time t
5	5.27	58	87	78	84	13.12
5	5.24	58	93	78	85	9.48
10	10.62	58	77	77	87	13.42
10	10.48	57	98	74	86	9.62
10	10.55	57	97	71	84	7.87
10						

late Y & H₂ at man. 2.0

$$Y = \frac{CF_w P_b (T_d \text{ avg.} + 460)}{CF_d (P_b + 0.147)(T_w + 460)}$$

$$\Delta H_2 = \frac{0.0634 (T_w + 460)^2}{P_b (OT_d + 460) CF_w}$$

$$\Delta H_2 = \frac{0.0634 ((T_w + 460)t)^2}{(T_w + 460)}$$

Tolerances

Y = 0.99 - 1.00 - 1.01
 $\Delta H_2 = 1.6 - 1.84 - 2.1$

0.317 (Man. Orifice)

$$(T_w + 460) f^2$$

Man. Hg

$\Delta H_{@}$

P_b (OTD + 460)

CF_w

0.01585

$$(53 + 460) \frac{1}{2.17}$$

.5

1.179

$\Delta H_{@}$

$3c \sqrt{L} (78 + 460)$

5

0.0317

$$(58 + 460) \frac{1}{1.48}$$

1.0

1.87

$\Delta H_{@}$

$3c \sqrt{L} (78 + 460)$

5

0.0634

$$(58 + 460) \frac{1}{13.42}$$

2.0

1.88

$\Delta H_{@}$

$3c \sqrt{L} (77 + 460)$

10

0.1268

$$(57 + 460) \frac{1}{2.62}$$

4.0

1.93

$\Delta H_{@}$

$3c \sqrt{L} (74 + 460)$

10

0.1902

$$(57 + 460) \frac{1}{2.51}$$

6.0

1.96

$\Delta H_{@}$

$3c \sqrt{L} (71 + 460)$

10

0.2536

$$(57 + 460) \frac{1}{1.12}$$

8.0

8.0

CF_w P_b (T_D avg. + 460)

CF_D (P_b + $\frac{\text{Man. Orifice}}{13.6}$) (T_w + 460)

$$5 \times \frac{3c \sqrt{L}}{57.5} (78 + 460)$$

.5

$$5.27 \frac{3c \sqrt{L}}{57.5} (78 + 460) + 0.0368 (53 + 460)$$

1.0

$$5.27 \frac{3c \sqrt{L}}{30.4237} (78 + 460) + 0.0737 (58 + 460)$$

2.0

$$10 \times \frac{3c \sqrt{L}}{57.5} (77 + 460) + 0.147 (58 + 460)$$

4.0

$$10 \times \frac{3c \sqrt{L}}{57.5} (74 + 460) + 0.294 (57 + 460)$$



6.0

$$10 \times \frac{3c \sqrt{L}}{57.5} (71 + 460) + 0.431 (57 + 460)$$

8.0

$$10 \times \frac{3c \sqrt{L}}{57.5} (71 + 460) + 0.588 (57 + 460)$$

8.0




TRAVERSE POINT NO.	DISTANCE FROM WALL
3	9.9"
2	32.9"
1	66.0"

REVIEWED	THE UNITED ILLUMINATING CO.
	NEW HAVEN, CONN.
	STACK CONFIGURATION AND
	SAMPLING POINT LOCATION
	STACK NO. 3
	REIDG. POINT HARBOR STATION
DRAWN BY	P.L.O.
DATE	4-2-74
APPROVED BY	
DATE	4/2/74
SCALE	AS SHOWN
SPRING NO.	4/2/74-8

APPENDIX B
NITROGEN OXIDE TEST
FLUE GAS ANALYSIS

TEST NO. 1



Sample #1

Max

0.25

0.75

Sample #2

Max

0.25

0.75

9250
02750

Sample No
Test 1

02750

Sample 0
Test #1
02750

02750

4.2

7.2.5
COR 512

Calibrate
G. E. 1:35 PM
Test 1
Unit 3

Box
calibrate high end
350 PPM

Box
calibrate low end
50 PPM


2

zero check

35% = 210 PPM

Box

Form No. 100-1000



CO₂ x 28

N₂ x 51

O₂ x 25%

CO₂ x 51

Calibrate G.C.

zero check

Low Calibration 51 PPM
N₂

COUNTS PER MINUTE

MINUTES

COUNTS PER MINUTE

MINUTES

Feb. 21, 1974

380 13M Calibrate

Nox

zero
check

51 13M Calibrate

Nox

BRIDGEPORT HARBOR STATION

STACK NO 3

TEST NO 1

FEB 21, 1974

12512

025256

COX512

TEST NO. 2

Calibrate

N₂ 512

O₂ 256

CO₂ 512

Calibrate

O₂ 256

CO₂ 512

Sample #3
Test 3

N₂ 512

O₂ 256

CO₂ 512

Sample #2
Test 2

0.2x512

0.2x512

Sample #1
Test 2

0.2x25

0.2x512

0.2x512

0.2x512

Calibration
G. e. Test 2
4:15 PM

31.90 = 186 PPM

AUC = 189 PPM

NOx Sample 3:50 PM Tot 2

NOx Low end
50 PPM

Zero
check

NOx
High end
380 PPM

NOx
2500
check

3:50 PM

Test
Unit 3

BRIDGEPORT HARBOR STATION

STACK NO 3

TEST NO 2

FEB 21, 1974

TEST NO. 3

Barometer 29.26

amb. Temp 50°F


$N_2 \times 5/2$

$90.5 O_2 \times 2.56$


$99 CO_2 \times 5/2$

2nd CALIBRATION


NO CO




SAMPLE #3



SAMPLE #2



SAMPLE #1



$N_2 \times 512$

$O_2 \times 256$
91
 $CO_2 \times 512$
99

1st CALIBRATION
Test 3 Unit 3
10:30 AM Feb 22, 1974

PPM- 98

NOx Test 3 Unit 3
Sample 10:15 AM

2000

Zero

Low end cal.

50 PPM

BRIDGEPORT HARBOR STATION.

Nox

TEST NO. 3

UNIT # 3

FEB 22, 1974

APPENDIX C

BOILER OPERATING DATA

Unit # 3
 Bridgeport Harbor Station Test # 1
 Fuel flow readings corrected to
 60° F.

Time	1329	1335	1350	1405
Gross load	376.4 MW	376.4 MW	376.4 MW	375.7 MW
Net load (Gross)	171.8 MW	208.9 MW	367.6 MW	24.4 MW
Fuel flow (Accum)	12,490 ⁶ / _{hr}	15,160 ⁶ / _{hr}	22,276 ⁶ / _{hr}	17,500 17,500 ⁶ / _{hr}
F.W. Temp	458° F	459° F	459° F	459° F
F.W. Flow	2,619,000 ¹⁵ / _{hr}	2,600,800 ¹⁵ / _{hr}	2,600,000 ¹⁵ / _{hr}	2,545,700 ¹⁵ / _{hr}
Excess O ₂	2.93 %	2.94 %	2.99 %	2.87 %
Boiler Steam Press.	2370 PSIG	2365 PSIG	2374 PSIG	2366 PSIG
Steam Temp	994° F	993° F	994° F	991° F
Condenser Cooling in A	38.6° F	38.1° F	37.9° F	38.2° F
cooling out A	38.1° F	38.1° F	37.9° F	38.6° F
cooling in B	74.5° F	74.5° F	73.6° F	74.5° F
cooling out B	77.2° F	73.9° F	72.7° F	73.4° F
F.D. Disc #1	66° F	60° F	59° F	61° F
F.D. Disc #3	—	—	—	—
A.H. in A	105° F	105° F	103° F	105° F
" " B	118° F	118° F	118° F	118° F
A.H. out A	594° F	594° F	594° F	594° F
" " B	601° F	601° F	601° F	601° F
Gas in A	687° F	688° F	688° F	687° F
" " B	695° F	696° F	695° F	695° F
Gas out A	296° F	297° F	296° F	297° F
" " B	331° F	330° F	331° F	331° F
Cond. Flow	881,500 ¹⁵ / _{hr}	1,064,700 ¹⁵ / _{hr}	1,577,200 ¹⁵ / _{hr}	1,257,000 ¹⁵ / _{hr}
Throttle Steam Flow	1,122,200 ¹⁵ / _{hr}	1,362,500 ¹⁵ / _{hr}	2,001,600 ¹⁵ / _{hr}	1,603,000 ¹⁵ / _{hr}
W.H. S.H. Spray flow		76,930 ¹⁵ / _{hr}	77,240 ¹⁵ / _{hr}	77,720 ¹⁵ / _{hr}
Rit S.H. Spray Flow		106,410 ¹⁵ / _{hr}	106,530 ¹⁵ / _{hr}	106,600 ¹⁵ / _{hr}
		1,468,910 ¹⁵ / _{hr}	1,665,200 ¹⁵ / _{hr}	1,709,600 ¹⁵ / _{hr}
Hotwell A		89° F	88° F	90° F
Hotwell B		88° F	88° F	89° F
Barometer	30.12 @ 243'	30.12 @ 243'	30.12 @ 243'	30.12 @ 243'
Temp. Amb.	44° F	44° F	44° F	44° F
R.H. Press	490 PSIG	490 PSIG	490 PSIG	489.7 PSIG
R.H. Temp.	979° F	979° F	978° F	978° F

Unit #3
Bridgeport Harbor Station Test #1

Time	1420	1435	1450	1505
Gross load	373.5 MW	301.2 MW	293.3 MW	321.8 MW
Net load	122.0 MW	194.1 MW	270.9 MW	24.4 MW
Fuel flow	8,870 ^{Gal/hr}	13,900 ^{Gal/hr}	19,360 ^{Gal/hr}	1,800 ^{Gal/hr}
F.W. Temp	458°F	437°F	434°F	460°F
F.W. Flow	2,602,660 ^{lb/hr}	1,996,500 ^{lb/hr}	1,741,900 ^{lb/hr}	2,571,200 ^{lb/hr}
Excess O ₂	2.95%	3.07%	3.12%	3.24%
Boiler Steam Press.	2351 PSIG	2244 PSIG	2197 PSIG	2394 PSIG
Steam Temp.	998°F	1039°F	1014°F	996°F
Condenser Cooling in A	39.3°F	39.9°F	41.9°F	42.6°F
cooling out A	39.3°F	39.7°F	41.7°F	42.6°F
cooling in B	75.6°F	68.8°F	70.1°F	77.4°F
cooling out B	74.1°F	68.2°F	68.4°F	77.4°F
F.D. Disc A	61°F	63°F	64°F	68.4°F
F.D. Disc B	—	—	—	—
A.H. in A	105°F	113°F	114°F	104°F
" " B	119°F	126°F	126°F	130°F
A.H. out A	593°F	560°F	546°F	582°F
" " B	606°F	565°F	551°F	587°F
Gas in A	687°F	628°F	615°F	681°F
" " B	694°F	633°F	620°F	680°F
Gas out A	296°F	282°F	273°F	288°F
" " B	331°F	316°F	305°F	325°F
Cond. Flow	627,900 ^{lb/hr}	104,470 ^{lb/hr}	1,424,700 ^{lb/hr}	119,900 ^{lb/hr}
Throttle Steam Flow	800,900 ^{lb/hr}	125,420 ^{lb/hr}	1,714,200 ^{lb/hr}	1,588,000 ^{lb/hr}
L.A.S.H.	77,210 ^{lb/hr}			
Spray Flow	722,400 ^{lb/hr}			
R.H. S.H.	100,580 ^{lb/hr}	120,400 ^{lb/hr}	46,270 ^{lb/hr}	111,040 ^{lb/hr}
Spray Flow	1,285,500 ^{lb/hr}	1,285,500 ^{lb/hr}	462,900 ^{lb/hr}	1,115,400 ^{lb/hr}
Hotwell A	91°	80°F	81°F	92°F
Hotwell B	89°		81°F	92°F
Barometer	30.12 @ 243'	30.12 @ 243'	30.12 @ 243'	30.12 @ 243'
Temp. Hub	44°F	45°F	45°F	45°F
R.H. Press.	484 PSIG	373 PSIG	368 PSIG	496 PSIG
R.H. Temp	976°F	973°F	972°F	989°F

Bridgeport Harbor Station Test # 2

Time	1520	1535	1550	1605
Gross load	382.4 MW	379.5 MW	378.9 MW	375.4 MW
Net load	124.0 MW	211.9 MW	310.5 MW	25.4 MW
Fuel Flow	9,010 ^{Gal/hr}	15,320 ^{Gal/hr}	22,510 ^{Gal/hr}	1,780 ^{Gal/hr}
F.W. Temp	460°F	459°F	459°F	458°F
F.W. Flow	2,622,900 ^{lb/hr}	2,645,400 ^{lb/hr}	2,631,600 ^{lb/hr}	2,595,800 ^{lb/hr}
Excess O ₂	3.24%	5.24%	3.24%	3.24%
Boiler Steam Press	2415 PSI	2394 PSI	2393 PSI	2869 PSI
Steam Temp	1010°F	991°F	996°F	993°F
Condenser Cooling in A	43.6°F	43.1°F	43°F	45.1°F
cooling out A	105°F	106°F	108°F	109°F
cooling in B	42.8°F	43.1°F	43.2°F	45.3°F
cooling out B	78.7°F	80.2°F	80.1°F	81.1°F
F.D. Disc A	78.7°F	80.2°F	80.3°F	81.5°F
F.D. Disc B	61°F	61°F	64°F	63°F
A.H. in A	—	—	—	—
" " B	105°F	106°F	108°F	107°F
A.H. out A	121°F	122°F	122°F	120°F
" " B	591°F	594°F	595°F	593°F
Gas in A	598°F	602°F	602°F	600°F
" " B	686°F	685°F	688°F	684°F
Gas out A	696°F	698°F	698°F	694°F
" " B	296°F	298°F	300°F	298°F
Cond. Flow	336°F	334°F	334°F	331°F
Theoretical Steam Flow	6,240 ^{lb/hr}	1,049,700 ^{lb/hr}	1,551,900 ^{lb/hr}	125,150
L.M.S.H. Spray Flow	809,700 ^{lb/hr}	1,381,100 ^{lb/hr}	2,034,200 ^{lb/hr}	160,000 ^{lb/hr}
Rit S.H. Spray Flow			59,090 ^{lb/hr}	80,250 ^{lb/hr}
Hotwell A	95,740 ^{lb/hr}		95,740 ^{lb/hr}	94,900 ^{lb/hr}
Hotwell B	93°F	94°F	94°F	95°F
Barometer	93°F	94°F	94°F	94°F
Temp. Amb.	30.12 @ 243'	30.12 @ 243'	30.12 @ 243'	30.12 @ 243'
R.H. Press	45°F	45°F	45°F	45°F
R.H. Temp	499 PSI	495 PSI	495 PSI	490 PSI
	979°F	975°F	972°F	975°F

Unit #3
 Bridgeport Harbor Station Test #2
 Feb 21, 1974

Time	1620	1635	1650
Gross load	373.8 MW	374.4 MW	370.9 MW
Net load	123.0 MW	208.9 MW	305.6 MW
Fuel flow	8,880 Gal	15,090 Gal	22,130 Gal
F.W. Temp	458°F	458°F	457°F
F.W. Flow	2,595,200 ^{lb} / _{hr}	2,582,000 ^{lb} / _{hr}	2,563,000 ^{lb} / _{hr}
Excess O ₂	3.24%	3.24%	3.24%
Boiler Steam Press	2362 PSI	2362 PSI	2344 PSI
Steam Temp	994°F	995°F	997°F
Condenser Cooling in A	45.6°F	46.8°F	46.0°F
cooling out A	46.1°F	47.0°F	46.2°F
cooling in B	81.1°F	82.1°F	81.8°F
cooling out B	81.5°F	82.7°F	82.8°F
F.D. Disc A	64°F	64°F	61°F
F.D. Disc B	—	—	—
A.H. in A	108°F	108°F	109°F
" " B	121°F	121°F	122°F
A.H. out A	592°F	593°F	592°F
" " B	600°F	600°F	600°F
Gas in A	685°F	685°F	684°F
" " B	644°F	644°F	643°F
Gas out A	298°F	298°F	298°F
" " B	331°F	331°F	332°F
Cond. Flow	623,360 ^{lb} / _{hr}	1,057,800 ^{lb} / _{hr}	1,551,100 ^{lb} / _{hr}
Throttle Steam Flow	799,700 ^{lb} / _{hr}	1,357,800 ^{lb} / _{hr}	1,989,500 ^{lb} / _{hr}
L.H.S.H. Spray Flow	64,510 ^{lb} / _{hr}	71,260 ^{lb} / _{hr}	64,300 ^{lb} / _{hr}
R.H.S.H. Spray Flow	94,700 ^{lb} / _{hr}	74,810 ^{lb} / _{hr}	94,340 ^{lb} / _{hr}
Hotwell A	96°F	96°F	96°F
Hotwell B	96°F	96°F	96°F
Barometer	30.12 ⁰ 243	30.12 ⁰ 243	30.12 ⁰ 243
Temp Amb.	45°F	45°F	45°F
R.H. Press	488 PSI	488 PSI	484 PSI
R.H. Temp.	976°F	977°F	979°F

Unit #3
 Bridgeport Harbor Station Test #3
 Feb 22, 1974

Time	0924	0939	0954	1009
Gross load	378.9 MW	380.2 MW	380.2 MW	380.5 MW
Net load	149.3 MW	236.2 MW	335.8 MW	49.8 MW
Fuel flow	10,850 Gal	17,180 Gal	24,410 Gal	3,630 Gal
F.W. Temp	460° F	460° F	460° F	460° F
F.W. Flow	2,664,200 lb	2,666,800 lb	2,661,700 lb	2,651,200 lb
Excess O ₂	3.24%	3.24%	3.24%	3.24%
Boiler Steam Press.	2397 PSI	2405 PSI	2401 PSI	2407 PSI
Steam Temp.	996° F	989° F	988° F	996° F
Condenser Cooling in A	39.9° F	40.1° F	39.8° F	40.1° F
cooling out A	39.9° F	39.8° F	39.6° F	39.8° F
cooling in B	77.3° F	77.1° F	76.9° F	77.4° F
cooling out B	76.6° F	76.5° F	76.0° F	76.5° F
F.D. Dis A	69° F	70° F	70° F	70° F
F.D. Dis B	—	—	—	—
A.H. in A	111° F	112° F	112° F	112° F
" " B	127° F	127° F	128° F	128° F
A.H. out A	604° F	604° F	603° F	603° F
" " B	608° F	608° F	606° F	607° F
Gas in A	700° F	700° F	699° F	699° F
" " B	706° F	706° F	704° F	705° F
Gas out A	306° F	306° F	306° F	306° F
" " B	338° F	341° F	344° F	340° F
Cond. Flow	757,700 lb	1,208,400 lb	1,723,600 lb	256,900 lb
Throttle Steam Flow	97,610 lb	1,547,400 lb	2,203,200 lb	326,100 lb
L.M.S.H. Spray Flow	—	87,290 lb	87,300 lb	86,970 lb
R.H.S.H. Spray Flow	—	110,720 lb	110,810 lb	110,470 lb
Hotwell A	91° F	91° F	91° F	91° F
Hotwell B	90° F	90° F	90° F	90° F
Barometer	29.26 ²⁴³	29.26 ²⁴³	29.26 ²⁴³	29.26 ²⁴³
Temp. Hub.	50° F	50° F	50° F	50° F
R.H. Press	497 PSI	498 PSI	498 PSI	498 PSI
R.H. Temp.	974° F	973° F	971° F	972° F

Unit # 3
 Bridgeport Harbor Station Test # 3
 Feb 24, 1974

Time	1024	1039	1054	1109
Gross load	379.5 MW	380.2 MW	381.1 MW	380.5 MW
Net load	149.3 MW	236.2 MW	335.7 MW	49.8 MW
Fuel Flow	10,860 Gal	17,190 Gal	24,430 Gal	3,630 Gal
F.W. Temp	460°F	460°F	460°F	458°F
F.W. Flow	2,658,100 lb	2,660,300 lb	2,663,400 lb	2,655,800 lb
Excess O ₂	3.24%	3.24%	3.24%	3.24%
Boiler Steam Press.	2396 PSI	2400 PSI	2404 PSI	2401 PSI
Steam Temp.	989°F	989°F	988°F	988°F
Condenser Cooling in A	41.5°F	41.5°F	40.3°F	40.1°F
cooling out A	40.6°F	40.6°F	40.1°F	40.3°F
cooling in B	77.7°F	80.6°F	76.9°F	76.9°F
cooling out B	77.7°F	76.8°F	76.2°F	76.2°F
F.D. Disc A	71°F	71°F	71°F	72°F
F.D. Disc B	—	—	—	—
A.H. in A	112°F	109°F	112°F	113°F
" " B	128°F	125°F	128°F	129°F
A.H. out A	603°F	603°F	602°F	602°F
" " B	607°F	607°F	606°F	606°F
Gas in A	699°F	698°F	697°F	697°F
" " B	705°F	704°F	703°F	703°F
Gas out A	306°F	302°F	306°F	307°F
" " B	339°F	343°F	344°F	341°F
Cond. Flow	768,400 lb	1,215,900 lb	1,728,000 lb	258,100 lb
Throttle Steam Flow	980,200 lb	1,557,300 lb	2,205,100 lb	326,700 lb
Low S.H. Spray Flow	86,900 lbs	86,900 lbs	87,100 lbs	87,200 lbs
High S.H. Spray Flow	109,980 lb	110,470 lbs	110,540 lbs	110,470 lbs
Hotwell A	92°F	92°F	90°F	91°F
Hotwell B	91°F	90°F	90°F	90°F
Barometer	29.26 ⁰ 243'	29.26 ⁰ 243'	29.26 ⁰ 243'	29.26 ⁰ 243'
Temp. Amb.	50°F	50°F	50°F	50°F
R.H. Press	49.7 PSI	497 PSI	498 PSI	497 PSI
R.H. Temp.	972°F	972°F	972°F	972°F

APPENDIX D

SAMPLE CALCULATIONS

SAMPLE CALCULATIONS

NOTE: All equations used in these calculations are found in the Federal Register, Vol. 36, No. 247, dated December 23, 1971.

Calculations representative of Test #1.

1) Dry Gas Volume

$$\begin{aligned} V_{mstd} &= \left((17.71 \frac{^{\circ}R}{inHg}) \right) & V_m &= \left(\frac{(P_{bar} + \frac{\Delta H}{13.6})}{T_m} \right) & \text{eg.5-1} \\ &= \left(17.71 \frac{^{\circ}R}{inHg} \right) & & 34.52 \text{ ft}^3 \left(\frac{(30.12 \text{ in Hg} + \frac{1.217 \text{ in H}_2\text{O}}{13.6})}{517.8 \text{ R}} \right) \\ &= 35.46 \text{ ft}^3 \end{aligned}$$

2) Volume of Water Vapor

$$\begin{aligned} V_{wstd} &= \left((0.0474 \frac{FT^3}{M}) \right) & V_{lc} & & \text{eg.5-2} \\ &= \left((0.0474 \frac{FT^3}{M}) \right) & & 77.6 \text{ ml} \\ &= 3.68 \text{ FT}^3 \end{aligned}$$

3) Moisture Content

$$\begin{aligned} B_{ws} &= \frac{V_{wstd}}{V_{wstd} + V_{mstd}} \\ &= \frac{3.68 \text{ FT}^3}{3.68 \text{ FT}^3 + 35.67 \text{ FT}^3} \\ &= .0934 \times 100\% = 9.34\% \end{aligned}$$

4) Molecular Weight (dry)

$$\begin{aligned}
 M_d &= 0.44 (\% \text{ CO}_2) + 0.32 (\% \text{ O}_2) \\
 &\quad + 0.28 (\% \text{ N}_2) + 0.28 (\% \text{ CO}) \quad \text{eq. 3-2} \\
 &= 0.44 (10.72) + 0.32 (7.88) + 0.28 (81.40) \\
 &\quad + 0.28 (0.00) \\
 &= 30.03 \text{ lb/lb-mole}
 \end{aligned}$$

5) Molecular Weight (wet)

$$\begin{aligned}
 M_s &= M_d (1 - B_{ws}) + 18 B_{ws} \\
 &= 30.03 (1 - .0934) + 18 (.0934) \\
 &= 28.91 \text{ lb/lb-mole}
 \end{aligned}$$

6) Stack Gas Velocity

$$\begin{aligned}
 V_s &= K_p C_p \sqrt{\Delta P} \left(\frac{T_s}{P_s M_s} \right)^{\frac{1}{2}} \quad \text{eq. 2-2} \\
 &= (85.48) (.86) (1.161) \left(\frac{750}{30.08 \times 28.9} \right)^{\frac{1}{2}} \\
 &= 79.2 \text{ F.P.S.}
 \end{aligned}$$

7) Gas Volumetric Flow Rate, ACFM

$$\begin{aligned}
 \text{ACFM} &= V_s \times A_s \times 60 \text{ sec/min} \\
 &= 79.2 \times 273.36 \text{ FT}^2 \times 60 \text{ sec/min} \\
 &= 1,299,007 \text{ ACFM}
 \end{aligned}$$

8) Gas Volumetric Flow Rate, SCFM

$$\begin{aligned}
 Q_s &= 60 (1 - B_{ws}) V_s A_s \left(\frac{T_{std}}{T_s} \right) \left(\frac{P_s}{P_{std}} \right) \quad \text{eq. 2-3} \\
 &= 60 (1 - .0934) (79.2) (273.36) \left(\frac{530}{750} \right) \left(\frac{30.08}{29.92} \right) \\
 &= 836,782 \text{ SCFM}
 \end{aligned}$$

9) Gas Volumetric Flow Rate, lb/hr

$$\begin{aligned}
 W_s &= Q_s \times \frac{60 \text{ min}}{\text{hr}} \times \frac{M_d}{386 \text{ FT}^3} \\
 &= 836,782 \text{ SCFM} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{30.03 \text{ lb/lb-mole}}{386 \text{ FT}^3} \\
 &= 3,905,994 \text{ lb/hr}
 \end{aligned}$$

10) Particulate Concentrations, gr/SCF

$$\begin{aligned}
 c's &= \left(0.0154 \frac{\text{gr}}{\text{mg}} \right) \frac{M_n}{V_{mstd}} && \text{eg. 5-4} \\
 &= \left(0.0154 \frac{\text{gr}}{\text{mg}} \right) \frac{28.8 \text{ mg}}{35.46 \text{ FT}^3} \\
 &= .0124 \text{ gr/SCF}
 \end{aligned}$$

11) Particulate Concentrations, lb/FT³

$$\begin{aligned}
 C_s &= \left(\frac{1}{453600} \frac{\text{lb}}{\text{mg}} \right) \frac{M_n}{V_{mstd}} && \text{eg. 5-5} \\
 &= \left(\frac{1}{453600} \frac{\text{lb}}{\text{mg}} \right) \frac{28.8 \text{ mg}}{35.46 \text{ FT}^3} \\
 &= 1.78 \times 10^{-6} \text{ lb/SCF}
 \end{aligned}$$

12) Particulate Concentrations, lb/hr

$$\begin{aligned}
 C_w &= C_s Q_s \times \frac{60 \text{ min}}{\text{hr}} \\
 &= (1.78 \times 10^{-6} \text{ lb/SCF}) (836,782 \text{ SCFM}) \frac{60 \text{ min}}{\text{hr}} \\
 &= 89.37 \text{ lb/hr}
 \end{aligned}$$

13) Particulate Concentrations, lb/MBTU

$$\begin{aligned}
 E_r &= \frac{C_w}{\text{Heat Input}} \\
 &= \frac{89.37 \text{ lb/hr}}{4011.4 \times 10^6 \text{ BTU/hr}} \\
 &= .022 \text{ lb/MBTU}
 \end{aligned}$$

14) % Isokinetic Sampling

$$I = \frac{T_s \left(1.667 \frac{\text{min}}{\text{sec}} \right) \left(\frac{(0.00267) V_{lc} + \frac{V_m}{T_m} \left(P_{\text{bar}} + \frac{\Delta H}{13.6} \right)}{\Theta \quad V_s \quad P_s \quad A_n} \right)}{\text{eg. 5-6}}$$

$$I = \frac{750 (1.667)}{60 (79.20)} \left(\frac{(0.00267) (77.6) + \frac{34.52}{517.8} \left(30.12 + \frac{1.217}{13.6} \right)}{(30.08) (.00192)} \right) = 101.18\%$$

15) NO_x Concentrations, lb/hr

$$\begin{aligned} \text{lb/hr} &= \text{PPM} \times \frac{M_w \text{ NO}_x}{M_d} \times W_s \\ &= \frac{210}{10^6} \times \frac{46 \text{ lb/lb-mole}}{30.03 \text{ lb/lb-mole}} \times 3,905,994 \frac{\text{lb}}{\text{hr}} \\ &= 1256 \text{ lb/hr} \end{aligned}$$

16) NO_x Concentrations, lb/MBTU

$$\begin{aligned} \text{lb/MBTU} &= \frac{\text{lb/hr}}{\text{Heat Input}} \\ &= \frac{1256 \text{ lb/hr}}{4011.4 \times 10^6 \text{ BTU/hr}} \\ \text{lb/MBTU} &= \frac{.313 \text{ lb}}{10^6 \text{ BTU}} \end{aligned}$$

17) Stack Pressure (Absolute), in Hg

$$P_s = P_b + \frac{P_d}{13.6} = 30.12 + \frac{(-.5)}{13.6} = 30.08 \text{ in Hg}$$

18) Nozzle Area (FT²)

$$A_n = \pi D^2 / 4 = 0.785 \left(.1875 / 12 \right)^2 = 1.92 \times 10^{-4} \text{ Ft}^2$$

19) Stack Area (FT²)

$$A_s = \pi D^2 / 4 = 0.785 \left(18.6562 / 12 \right)^2 = 273.36 \text{ FT}^2$$

20) Heat Input, MBTU

$$\begin{aligned} \text{SP. Gr} \times 8.33 \text{ lb/gal} \times \text{BTU/gal} \times \text{gal /hr} \\ 0.90 \times 8.33 \times 19,149 \times 27,942 = 4011.4 \times 10^6 \text{ BTU/hr} \end{aligned}$$

21) Gas Density, lb/ft³

$$\begin{aligned} \text{Gas Density} &= \frac{\text{Mol wt gas (md)}}{386 \text{ FT}^3} \times \frac{T_{\text{std}}}{T_s} \times \frac{P_{\text{bar}}}{P_{\text{std}}} \\ &= \frac{30.03}{386} \times \frac{530^\circ \text{R}}{750} \times \frac{30.12}{29.92} = .055 \text{ lb/Ft}^3 \end{aligned}$$

THE UNITED ILLUMINATING COMPANY

SOURCE TESTING CALCULATION FORMS

Test No. BHS 3 No. Runs 3

Name of Firm The United Illuminating Company

Location of Plant 10 Henry Street, Bridgeport, Connecticut

Type of Plant Steam Electric Generating Station

Control Equipment Electrostatic Precipitator

Sampling Point Locations Stack

Pollutants Sampled Particulates, Nitrogen Oxide

Time of Particulate Test:

Run No. <u>1</u>	Date <u>2/21/74</u>	Begin <u>1220</u>	End <u>1404</u>
Run No. <u>2</u>	Date <u>2/21/74</u>	Begin <u>1517</u>	End <u>1643</u>
Run No. <u>3</u>	Date <u>2/22/74</u>	Begin <u>0918</u>	End <u>1046</u>

PARTICULATE EMISSION DATA

Run No.	1	2	3
$K_p = 85.48 \frac{ft}{sec} \left(\frac{lb.}{lb \text{ mole-}^{\circ}R} \right)^{1/2}$	85.48	85.48	85.48
$C_p =$ Pitot tube coefficient (calib.)	0.860	0.860	0.860
$\sqrt{\Delta P} =$ Average velocity head of stack gas, inches H ₂ O	1.161	1.143	1.142
$\bar{T}_s =$ Average stack temp., °R	750	750	750
$P_b =$ Barometric pressure, "Hg Abs.	30.12	30.12	29.26
$P_d =$ Gas duct pressure, "H ₂ O	-0.5	-0.5	-0.5
$P_s =$ Absolute stack gas pressure, inches Hg	30.08	30.08	29.22
$B_{ws} =$ % moisture in stack gas, by volume	9.34	9.45	7.05
$M_d =$ Molecular weight of stack gas, dry	30.03	30.17	30.23
$M_s =$ Molecular weight of stack gas	28.91	29.02	29.37

V_s = Stack gas velocity, F.P.S.	79.20	77.72	78.49	
% CO ₂	10.72	12.05	12.57	
% O ₂	7.88	6.32	5.57	
% CO	0.00	0.00	0.00	
% N ₂	81.40	81.63	81.86	
V_{lc} = Total volume of liquid collected in impingers and silica gel, ml.	77.6	82.0	57.8	
V_m = Volume of dry gas sampled at meter conditions, FT ³	34.52	35.35	35.62	
V_{std} = Volume of dry gas sampled at STP, FT ³	35.46	37.24	36.08	
T_m = Average dry gas meter temp., °R	517.8	507.8	513.1	
ΔH = Average pressure drop across orifice, inches H ₂ O	1.217	1.173	1.174	
θ = Total Sampling Time, min.	60	60	60	
D_n = Nozzle dia., inches	.1875	.1875	.1875	
A_n = Nozzle area, FT ²	.000192	.000192	.000192	
I = % of isokinetic sampling	101.18	107.78	103.70	
Q_s = Stack gas volume at STP (SCFM)	836,782	820,046	825,816	827,548
Q_a = Stack gas volume at stack conditions (ACFM)	1,299,007	1,274,732	1,287,362	1,287,034
W_s = Stack gas mass flow lbs/hr	3,905,994	3,832,971	3,880,479	3,873,148
M_p = Particulate-probe, washings, mg	-	-	-	-
M_f = Particulate-filter (mg)	-	-	-	-
M_n = Particulate-total (mg)	28.8	25.8	21.0	
$C's$ = Particulate Concentrations gr/scf	0.0124	0.0106	0.0089	0.0106
Q_w = Particulate total emission lb/hr	89.37	75.28	63.42	76.02
E_r = Particulate emission rate, lb/10 ⁶ BTU	0.0222	0.0193	0.0162	0.0192
C = NO _x concentrations, PPM	210	189	198	199
C_n = NO _x lb/10 ⁶ BTU	0.313	0.284	0.299	0.298

0AQP5-78-1
7615-II-I 260

FUEL
OIL COMBUSTION
AP-42 Section 1.3
Reference Number
24

4/93 Ref 21

Emission Test Report


Steel Point Station Stack No. 4

Steam Generator Nos. 19, 20, 21, 22


1921

The United Illuminating Company
Steel Point Station
43 East Main Street
Bridgeport, Connecticut
06608

Approved by:

E. W. Somerville 
Vice President, Engineering and Planning

Submitted by:

M. R. McCraven 
Director of Environmental Engineering

Emission Test Report

Steel Point Station Stack No. 4
Steam Generator Nos. 19, 20, 21, 22
(Ref. "Intent to Test" Form Number 730058)

Test Conducted By
The United Illuminating Company
Development and Test Laboratory
80 Temple Street
New Haven, Connecticut
06506.

United Illuminating Company Personnel Present

J. Sombati
J. Hotchkiss
J. Macknis

and by
York Research Corporation
One Research Drive
Stamford, Connecticut
06906

York Research Corporation Personnel Present

R. Epstein
J. Jasko

Prepared by:

J. S. Sombati *J. Sombati*
Development & Test Laboratory Supervisor

J. W. Hotchkiss *J. W. Hotchkiss*
Assistant Mechanical Engineer

Checked by:

J. F. Crowe *J. F. Crowe*
Chief Mechanical Engineer

Test Results

Steel Point Station Steam Generator
Nos. 19, 20, 21, 22

Test Conducted on
November 16 and 17, 1973

Prepared by _____

By _____ Test No. _____

Assistant _____

Introduction

Emission tests for particulates and nitrogen oxides were conducted as required by Connecticut State Law on The United Illuminating Company Steel Point Station Steam Generator Nos. 19, 20, 21, 22, stack No. 4, located in Bridgeport, Connecticut. Testing was conducted on November 16 and 17, 1973.

Particulate testing was performed in accordance with test methods and procedures as prescribed in the Federal Register, Vol. 36, No. 247, dated December 23, 1971. Testing was performed by York Research Corporation of Stamford, Connecticut, using a sampling train as described in Appendix A.

Nitrogen oxide emission testing was performed by the United Illuminating Company Development and Test Laboratory using a Dynascience Model P-101 NO_x Analyzer. Field data is included in Appendix B.

Tests were also conducted to determine stack gas velocity, moisture content, and flue-gas analysis. The procedures used in determining these various parameters, except for flue gas analysis, are those found in the above mentioned Federal Register. The stack flue gas was analyzed by using an Analytical Instrument Development Model 512 Portable Gas Chromatograph.

York Research Corporation was retained to perform particulate tests, together with a preliminary velocity traverse, moisture determination, and fuel oil analysis. The United Illuminating Company was responsible for the flue gas analysis, nitrogen oxide analysis, and for accumulating boiler operating data.

This test report includes the information required for Item Nos. III, IV, V, VI, VII, VIII, IX, X, XI, XII and XIII from the Department of Environmental Protection's Intent to Test form in compliance with the Department of Environmental Protection's new Source Test Guidelines and Procedures, (received April 3, 1973).

TABLE I

SUMMARY OF TEST RESULTS

STEAM GENERATOR NOS. 19, 20, 21, 22

STACK NO. 4

<u>Component</u>	<u>Sampling Duration</u>		<u>Number of Tests</u>	<u>Measured Concentrations</u>	<u>Method Employed to Determine Concentrations</u>
	<u>Minutes per point</u>	<u>Total Test Time</u>			
1) NO _X		15 min.	3	0.25 lb/10 ⁶ BTU	Dynascience Model P-101 NO _X Analyzer
2) Particulate	5	140 min.	3	0.11 lb/10 ⁶ BTU	Method 5*
3) Moisture	5	140 min.	3	5.2%	Method 4*
4) Gas Analysis		15 min.	3	47% Excess Air	A.I.D. Model 512 portable Gas Chromatograph
5) Velocity	1/2	15 min.	3	0.01" H ₂ O to 0.08" H ₂ O**	Method 2*

*Federal Register, Volume 36, No. 247, December 23, 1971

**Range of S-type Pitot - Tube Differential

TABLE II

SUMMARY OF RESULTS

STEAM GENERATOR NOS. 19, 20, 21, 22

STACK NO. 4

	<u>1</u>	<u>2</u>	<u>3</u>	<u>Average</u>
Test Date	11/16/73	11/17/73	11/17/73	
Stack Flow, ACFM	174,456	176,814	196,317	182,529
Stack Flow, SCFM	86,151	89,819	98,570	91,513
Stack Flow, lb/hr	398,526	413,121	455,363	422,337
% Excess O ₂ at Test Point	8.92	9.76	9.42	9.37
Particulate Emissions				
gr/SCF	0.027	0.018	0.052	0.032
lb/hr	20.0	14.0	44.3	26.1
lb/MBTU	0.07	0.06	0.19	0.11
Nitrogen Oxide Emission				
ppm	106.5	90	93	96.5
lb/hr	65.6	57.8	65.5	63.0
lb/MBTU	0.23	0.24	0.28	0.25

26.1 lb
 19.4 lb
 7.6 lb / 10³ gal
 10³ gal

TABLE III

AVERAGE BOILER OPERATING DATA FOR TEST PERIODS

STEAM GENERATOR NOS. 19, 20, 21, 22

STACK 4

	<u>1</u>	<u>2</u>	<u>3</u>
Test			
Date	11/16/73	11/17/73	11/17/73
Oil Flow (Total) gal/hr	1833	1642	1644
Heat Input (Total), MBTU/hr	290.8	237.1	237.4
Stack Gas Temperature °F	534.6	535.2	543.7
Gas Density, lb/ft ³	0.040	0.041	0.041

TABLE IV

FUEL OIL ANALYSIS

STEAM GENERATOR NOS. 19, 20, 21, 22

STACK NO. 4

Test	<u>1</u>	<u>2</u>	<u>3</u>
Date	11/16/73	11/17/73	11/17/73
	<u>Composition (% by Weight)</u>		
Carbon	85.43	85.86	85.86
Hydrogen	12.70	12.66	12.66
Nitrogen	<0.1	<0.1	<0.1
Ash	0.016	0.021	0.021
Sulfur	0.360	0.401	0.401
Specific Gravity	0.895	0.897	0.897
BTU/lb	21,276	19,328	19,328
BTU/gal	158,620	144,419	144,419

1. Sampling Train Information

(Rev. Item VIII, "Intent To Test" Form)

- a. Schematic Diagram and description of sampling train:

See Appendix A.

- b. Media type used to determine gas stream components:

1. NO_x: Dynascience Model P-101 NO_x Analyzer
2. Particulates: Tared glass fiber filter.
3. Flue Gas Analysis: Analytical Instrument Development Model 512 Portable Gas Chromatograph

- c. Sampling Probes:

1. Nitrogen Oxides: Stainless steel tube
2. Particulates: See Appendix A
3. Flue Gas Analysis: Stainless steel tube.

- d. Probe Cleaning Method:

See Appendix A

2. Field Data Sheets

(Ref. Item IX, "Intent To Test" Form)

See Appendices A, B, C, D.

3. Description of Operation

(Ref. Item X, "Intent To Test" Form)

The operation tested was Steel Point Station steam generator numbers 19, 20, 21, and 22, stack number 4, Registration Number St. Pt., 19-22, stack 4, having a total BTU/hr rating of 255.1 MBTU/hr (averaged over test period), burning No. 6 residual fuel oil at an average rate of 1706 gal/hr for all four boilers and having a gas flow of 182,589 ACFM average for the test period. See Table IV for fuel oil analysis.

4. Sampling Area Description
(Ref. Item XI, "Intent To Test" Form)

Emission sampling was performed in the stack 100 feet above the stack foundation (5 stack diameters above the breeching inlet and 2 stack diameters down from the top). Emission sampling was performed using four - 4" diameter sampling ports, spaced 90° apart on the stack circumference. A total of twenty eight sampling points (7 per sampling port) were used in the test for particulates. The inside diameter of the stack at the sampling location was found to be 15'-1" I.D.

a. Stack Configuration:

See Appendix A.

b. Sampling Port Location:

See Appendix A.

c. Sampling Point Position:

See Appendix A.

5. Stack and Vent Description
(Ref. Item XII, "Intent To Test" Form)

Four Babcock and Wilcox Three Drum Sterling Boilers discharge flue gas into a common breeching which enters the stack approximately 20 feet above the stack foundation. These boilers do not have any precipitators connected to the flue gas ducts.

6. Operational Parameters
(Ref. Item XIII, "Intent To Test" Form)

Electric utility steam generators burning No. 6 residual fuel oil having rated capacities as registered.

APPENDIX A

PARTICULATE TEST

V. SAMPLING METHODS

1. Port Location

The test port locations and the number of points samples were calculated from the guidelines in the Federal Register, Volume 36, Number 247, December 23, 1971. Enough points were used to assure accurate measurement of particulate emissions, temperature and velocity over the cross-sectional area of each stack. (See Figures 1 to 4.)

2. Velocity and Temperature

Velocity was determined by pitot tube in accordance with EPA Method 2. An "S"-Type Pitot Tube (2) and thermocouple (3) are rigidly attached to the sampling probe (See Figure 5). A preliminary velocity traverse was made to establish isokinetic sampling rates using EPA Method 5 sampling techniques.

3. Flue Gas Analysis

Gas analysis for CO₂ and O₂ was conducted by UI using an Orsat apparatus. Readings for each test are reported in the Summary of Results.

4. Particulate Sampling Methods - EPA Method 5

The sampling apparatus consisted of a nine (9) foot probe heated filter, four impingers, dry gas meter, vacuum pump, and calibrated orifice as shown in Figure 5. The stainless steel, button-hook type probe tip (1) was equipped with a 5/8 inch diameter fitting connected by a stainless steel coupling (2) with asbestos packing to the probe. The probe (3) consisted of 1/2 inch inside diameter medium-wall stainless steel tube with a ground steel joint on one end. The probe was logarithmically wound from the entrance end with 26-gauge nickel-chromium wire. During sampling, the wire was connected to a variable transformer to maintain a gas temperature of 300°F in the probe. The wire wound tube was wrapped with fiber glass tape and encased in a 1-inch-OD stainless steel tube for protection. The end of the steel tube that does not have the balljoint protruding has a nut welded to it for connection to the stainless steel coupling used to attach the nozzle. The probe connects to a very coarse fritted glass filter holder (4) which holds a tared glass fiber filter. The filter holder was contained in an electrically heated enclosed box (5) which is thermostatically maintained at 250-300°F to prevent water condensation. Attached to the heated box was an ice bath (7) containing four impingers connected in series with vacuum hose. The first impinger (8) receives the gas stream from

the filter. This impinger is of the Greenburg-Smith design modified by replacing the tip with a 1/2 inch ID glass tube extending to 0.5 inch from the bottom of the flask. This impinger was initially filled with 100 milliliters of distilled water. The second impinger (9) is a Greenburg-Smith impinger with tip, and also filled with 100 milliliters of distilled water. The third impinger modified like the first, with no water. The fourth impinger (11) is also a Greenburg-Smith type modified like the first and contained 300 grams of dry indicating silica gel.

From the fourth impinger (11) the effluent stream flows through a dial thermometer (12), a check valve (13); flexible rubber vacuum tubing (14); vacuum gauge (15); a valve (16); a leakless vacuum pump (17), rated at 4 cubic feet per minute at 0 inches of mercury gauge pressure and 0 cubic feet per minute at 26 inches of mercury gauge pressure, and connected in parallel with a bypass needle valve (18); and a dry gas meter rated at .1 cubic foot per revolution (19). A calibrated orifice (20) completes the train and was used to measure instantaneous meter flow rates. The three thermometers (12) are dial type with a range of 25° to 125°F. A fourth thermometer in the heated portion of the box has a range up to 500°F. The dual manometer (21) across the calibrated orifice is an inclined-vertical type graduated in hundredths of an inch of water from 0 to 1.0 inch and in tenths from 1 to 10 inches.

5. Test Procedure

Prior to the start of a test series for each stack, the pressure, temperature, and range of velocity pressures were determined during preliminary pitot tube and temperature traverse.

During each test the following readings were taken at each point:

1. Point Designation
2. Clock Time
3. Dry gas meter reading (CF)
4. Velocity head (ΔP in inches water)
5. Desired pressure drop across orifice (ΔH in inches of water)
6. Actual pressure drop across orifice (ΔH in inches of water)
7. Dry gas temperature (°F) gas meter inlet
8. Dry gas temperature (°F) gas meter outlet
9. Vacuum pump gauge reading (in. Hg)
10. Filter box temperature (°F).
11. Dry gas temperature (°F) at the discharge of last impinger.
12. Stack temperature (°F)

The relationship of ΔP reading with the ΔH reading is a function of the following variables:

1. Orifice calibration factor
2. Gas meter temperature
3. % moisture in the flue gas
4. Ratio of flue gas pressure to barometric pressure
5. Stack temperature
6. Sampling nozzle diameter

A nomograph was used to correlate all the above variables such that a direct relationship between ΔP and ΔH could be determined by the sampler within fifteen seconds and isokinetic conditions maintained throughout the test.

6. Basic Laboratory Procedure

The following paragraph briefly describes the methods used in the laboratory to obtain the raw data used in the calculations of our results as reported in Section III of this report.

The clean up is done in the field according to EPA test procedure. The filters were previously tare weighed and recorded at the laboratory. Upon return they are dried, cooled in a dessicator, then weighed on an analytical balance and the amount of particulate collected is the difference in the two weights. The particulate wash solution (taken from the train in front of the filter) is placed in a tared beaker, the wash solution is evaporated with an Infra-Red Heat Lamp and the beaker weighed again. The difference in weight is the weight of the particulate in the wash. This is combined with the filter catch as the weight of the sample.

The impinger condensate is measured for moisture determination.


7. Calibration of Sampling Equipment

The equipment used on this assignment was calibrated one week prior to field testing and recalibrated upon equipment return after testing. York Research calibration is traceable to the National Bureau of Standards.

TEST TEAM


Robert S. Epstein
John Jasko

Prepared By:



Robert J. Larkin
Test Engineer

Reviewed By:



Robert S. Epstein
Project Director

Approved By:

Roy S. Egdall
Manager-Engineering Services

York Research Corporation

Pitot Tube Calibration

ΔP_{std}	ΔP_s	$\frac{\Delta P_{std}}{\Delta P_s}$	F_s
.08	.11	.727	.853
.19	.27	.704	.839
.45	.66	.682	.826
.64	.91	.703	.839
.72	1.01	.713	.844

$$F_s = \sqrt{\frac{\Delta P_{std}}{\Delta P_s}}$$

Pitot Tube # 14

$F_s =$.84

$F_{std} = 1.00$

Calibrated by R. Jensen
Date 11/5/73

oil OK
 Quick Connects OK Valves OK
 ters OK
 st Meter _____
 meters OK
OK
 ical Check - Amphenol OK
OK
 n Gauge OK
 Check at 27" hg. - OK CF

al each item when checked and write in any remarks.

Calibration - Orifice and Meter

11/5/73 Box No. S 1563 Pb 29.9

ce	CF _w	CF _d	T _w	IT _d	OT _d	T _d Avg.	Time t
5	5	5.15	67	85	75	80	12.73
0	5	5.06	67	85.5	77.6	87.5	9.0.12
0	10	10.16	68	88.8	79.5	84.1	13.2
0	10	10.03	68	89.0	79.6	84.3	93.06
0	10	10.05	68	92.8	80.3	86.5	7.67
0	10						

ulate Y & H_a at man. 2.0

$$Y = \frac{CF_w P_b (T_d \text{ avg.} + 460)}{CF_d (P_b + 0.147 (T_w + 460))}$$

$$Y = \frac{0.0634 (T_w + 460)^2}{P_b (OT_d + 460) CF_w}$$

$$\Delta H_a = \frac{0.0634 ((T_w + 460)t)^2}{(P_b + 460)}$$

Tolerances

Y = 0.99 - 1.00 - 1.01
 Δ H_a = 1.6 - 1.84 - 2.1


Man. #	Man. #
0.317 (Man. Orifice)	1.78
$P_b (T_d + 460)$	0.5
CF_w	1.0
$(T_w + 460)^2$	1.90
0.01585	1.89
$29.9 (75 + 460)$	6.0
0.0317	8.0
$29.9 (77.6 + 460)$	
0.0634	
$29.9 (79.5 + 460)$	
0.1268	
$29.9 (79.6 + 460)$	
0.1902	
$29.9 (80.3 + 460)$	
0.2536	

Man. #	Man. #
0.5	1.0
1.0	2.0
2.0	4.0
4.0	6.0
6.0	8.0

$CF_w P_b (T_d \text{ avg.} + 460)$
 $CF_d P_b + \frac{\text{Man. Orifice}}{13.6} (T_w + 460)$
 $Y = 5 \times 29.9 (80 + 460)$
 $5.15 (29.9 + 0.0368) (67 + 460)$
 $5 \times 29.9 (81.5 + 460)$
 $5.06 (29.9 + 0.0737) (67 + 460)$
 $10 \times 29.9 (84.1 + 460)$
 $10.16 (29.9 + 0.147) (68 + 460)$
 $10 \times 29.9 (84.5 + 460)$
 $10.03 (29.9 + 0.294) (68 + 460)$
 $10 \times 29.9 (86.5 + 460)$
 $10.05 (29.9 + 0.431) (68 + 460)$
 $Y = \text{---} \times \text{---} (\text{---} + 460)$
 $Y = \text{---} (\text{---} + 0.588) (\text{---} + 460)$

FIELD DATA

PLANT UNITED ILLUMINATING STEEL POINT
 DATE 11-16-72
 SAMPLING LOCATION STACK #1
 SAMPLE TYPE DIAPHRAGM PLATE
 RUN NUMBER 1
 OPERATOR SS / RSE
 AMBIENT TEMPERATURE 60
 BAROMETRIC PRESSURE 30.31
 STATIC PRESSURE, (P_s) 1.01
 FILTER NUMBER (S) FL 228



PROBE LENGTH AND TYPE 100" SS
 NOZZLE I.D. .500
 ASSUMED MOISTURE % 10.0
 SAMPLE BOX NUMBER 5-1562
 METER BOX NUMBER 190
 METER # 43
 G FACTOR 250-300
 PROBE HEATER SETTING 250-300
 HEATER BOX SETTING 250-300
 REFERENCE # 054

SCHEMATIC OF TRAVERSE POINT LAYOUT

READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER	SAMPLING TIME, min	CLOCK TIME (24 hr CLOCK)	GAS METER READING (V _m), ft ³	VELOCITY HEAD (ΔP _s), in. H ₂ O	ORIFICE PRESSURE DIFFERENTIAL (ΔH), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
					DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F			
	0	1107	532.933									
A1	5	1112	537.97	.07	2.15	2.05	535	65	67	5	300	<70
2	10	1117	540.81	.03	1.05	1.05	540	73	65	4		
3	15	1122	545.98	.04	1.37	1.37	535	77	67	4		
4	20	1127	547.42	.05	1.67	1.67	530	82	67	5		
5	25	1132	550.34	.03	1.05	1.05	530	86	72	4		
6	30	1137	553.51	.02	0.70	0.70	530	87	77	3		
7	35	1142	554.410	.01	0.35	0.35	480	87	75	1.5		
B1	40	1206	558.24	.06	2.05	2.05	450	68	70	1.5	300	<70
2	45	1211	562.12	.06	2.05	2.05	445	75	70	1.5		
3	50	1216	566.09	.05	1.70	1.70	545	80	70	4.5		
4	55	1221	561.56	.07	2.35	2.35	540	81	73	5.5		
5	60	1226	573.13	.05	1.70	1.70	540	82	73	5		
6	65	1231	575.55	.02	0.70	0.70	540	82	73	3.5		
7	70	1236	577.226	.01	0.35	0.35	540	78	74	2.5		
C1	75	1265	583.03	.08	2.50	2.50	515	60	65	5.5	300	<70
2	80	1310	585.12	.08	2.50	2.50	515	69	65	6		
3	85	1315	590.10	.06	2.05	2.05	515	73	65	5.5		
4	90	1320	583.95	.06	2.05	2.05	500	77	66	5.5		
5	95	1325	587.25	.04	1.37	1.37	500	75	67	5		
6	100	1330	580.72	.04	1.37	1.37	535	73	67	4.5		
7	105	1335	583.122	.02	0.70	0.70	530	75	65	3.5		

ES-041

COMMENTS:




4-8278-1 TEST #2 STACK #4

TRAVERSE POINT NUMBER	SAMPLING TIME min	CLOCK TIME (24 hr CLOCK)	GAS METER READING (m ³ in 11")	VELOCITY HEAD (0.9 ft. in. H ₂ O)	ORIFICE PRESSURE DIFFERENTIAL (in. H ₂ O)		STACK TEMPERATURE (t _s) °F	DRY GAS METER TEMPERATURE (t _m) °F		PUMP VACUUM in Hg	SAMPLE BOX TEMPERATURE of	HYDRANT TEMPERATURE of
					DESIRED	ACTUAL		INLET	OUTLET			
			97.463				510	51	60	6.0	2500	< 70
A 1	105	1111	100.160	.06	2.50	2.50	500	60	60	6.5		
2	115	1115	105.62	.08	2.50	2.50	500	60	60	5.5		
3	120	1121	107.41	.06	2.05	2.05	500	61	60	5.5		
4	135	1126	115.12	.06	2.00	2.05	500	62	61	4.5		
5	150	1131	117.13	.07	1.35	1.35	500	62	62	5.0		
6	155	1135	120.66	.05	1.70	1.70	500	62	62	3.5		
7	170	1141	123.177	.02	0.70	0.70	480	62	61			

FIELD DATA

PROBE LENGTH AND TYPE 100" SS.
 NOZZLE I.D. .500 10.0
 ASSUMED MOISTURE, %
 SAMPLE BOX NUMBER S-1563
 METER BOX NUMBER 1.00
 METER SH. 278
 C FACTOR 250-300
 PROBE HEATER SETTING 250-300
 HEATER BOX SETTING 250-300
 REFERENCE AP .0574

PLANT UNITED ILLUM - STEEL POINT
 DATE 11-17-73
 SAMPLING LOCATION STACK #1
 SAMPLE TYPE PAUL PARTICULATE
 RUN NUMBER 3
 OPERATOR R.V. / R.S.
 AMBIENT TEMPERATURE 43.0
 BAROMETRIC PRESSURE 32.01
 STATIC PRESSURE, (P_s) 1.01
 FILTER NUMBER (s) FL-334





SCHMATIC OF TRAVERSE POINT LAYOUT
 READ AND RECORD ALL DATA EVERY 5 MINUTES

TRAVERSE POINT NUMBER	CLOCK TIME (24 hr CLOCK)	GAS METER READING (V _m), ft ³	VELOCITY HEAD (ΔP _v), in. H ₂ O	ORIFICE DIFFERENTIAL (ΔH), in. H ₂ O		STACK TEMPERATURE (T _s), °F	DRY GAS METER TEMPERATURE		PUMP VACUUM, in. Hg	SAMPLE BOX TEMPERATURE, °F	IMPINGER TEMPERATURE, °F
				DESIRED	ACTUAL		INLET (T _{m in}), °F	OUTLET (T _{m out}), °F			
	0	23.170									
A 1	5	23.05	.07	2.15	2.05	540	50	50	8.5	250°	<70°
2	10	32.00	.07	2.15	2.05	540	51	51	8.5		
3	15	35.33	.06	2.05	2.05	540	53	53	8.5		
4	20	31.13	.04	1.35	1.35	540	55	55	6.5		
5	25	12.36	.03	1.35	1.35	540	56	56	6.5		
6	30	45.36	.03	1.05	1.05	540	57	57	6.0		
7	35	35.37	.00								
B 1	35	47.65	.05	2.50	2.50	530	51	53	8.0	250°	<70°
2	40	51.35	.05	2.50	2.50	535	55	57	8.5		
3	45	58.81	.05	2.50	2.50	530	55	66	9.5		
4	50	63.81	.06	2.50	2.50	530	56	70	9.5		
5	55	67.35	.06	2.05	2.05	545	57	72	8.5		
6	60	14.31	.07	1.35	1.35	545	58	71	6.0		
7	65	72.107	.02	0.07	0.07	545	59	72	3.5		
C 1	70	77.38	.08	2.50	2.50	540	52	53	9.0	250°	<70°
2	75	81.67	.08	2.50	2.50	545	54	56	8.5		
3	80	85.71	.07	2.50	2.50	545	55	65	9.0		
4	85	27.57	.07	2.45	2.45	540	56	68	6.0		
5	90	51.82	.05	2.05	2.05	540	61	70	7.5		
6	95	44.0	.06	2.05	2.05	540	65	71	7.5		
7	100	101.711	.12	1.50	1.50	540	68	72	1.0		

ES-041

COMMENTS:



TRAVERSE POINT No.	DISTANCE FROM WALL
7	3.3"
6	10.4"
5	18.1"
4	26.7"
3	36.8"
2	49.2"
1	67.0"

THE UNITED ILLUMINATING CO.
 NEW HAVEN, CONN.
 STACK CONFIGURATION AND
 SAMPLING POINT LOCATION
 STACK No. 4
 STEEL POINT STATION

REVISIONS
 DATE 3-23-76
 DRAWN BY P.L.S.
 TRACED BY W.H.
 APPROVED BY W.H.
 SCALE NONE
 DRAWING NO. 21212-73

APPENDIX B

NITROGEN OXIDE TEST

FLUE GAS ANALYSIS

TEST NO. 1

NOX TEST 1
11/16/73

STEEL POINT
STACK 4

1235

1230

SPAN CHECK

1220

SAMPLE N @ 1215

70% = 420 ppm

02x512
02x512

sample # 2
stack # 4

02x512

02x512

sample # 4
stack # 4

02x512

Steel Point Station

stack No 4

Test No 1

11/16/73

ORSAT Test


02x512

02x512

02x512

Calibrate 12:45 PM

Nov. 16, 1973 steel pt



Calibrate 1.00 ppm

47

Sample K-3
stack 100

12X512

CO2 512


OUT 512

37.5
CO2 512

12X512

12X512

TEST NO. 2



1035 end

NOx Test ✓

1035

1030

SAMPLE IN @ 1025


NOx TEST 2

STEEL POINT
STACK 4


11-17-73

0
10
20
30
40
50
60
70
80
90
100


0
10
20
30
40
50
60
70
80
90
100




Sample # 2-1 Stack # 4



Steel Point Station
 Stack No 4.
 Test No 2
 11/17/73
 ORSAT Test.



10150 AM
 Calibrate
 Test # 2 # 4
 Stack # 4
 Nov 17, 1973
 3841 # 4



N₂X512

O₂X512

CO₂X512

Calibrate 11:20 AM

No Co
730

H₂X512

O₂X512

CO₂X512

Sample # 2-3 stock # 9

H₂X512

O₂X512

CO₂X512

TEST NO. 3

1:45 PM

Steel Point Station

Stack No 4.

Test No 3

11/17/73

NOx Test.


Sample in at 1:50

NOx Test 3

Steel Pt
Stack 4

11/17/73

1:45 PM



APPENDIX C

BOILER OPERATING DATA

Date Nov 16 1973

Stack Identification Number STP 19-22

Boiler Number 19-22

Plant Location STP 19-22

RA 29.1

TEST #1

Parameters	0997	1057	1242	1450	1505
Gross Load (MW)					
Net Load (MW)					
Fuel Flow (gal/hr)	27218	41928	45162	47307	47728
Steam Flow (lb/hr)					
Feed Water Flow (lb/hr)					
Air Flow (lb/hr)	4440	11445	4440	4440	4440
Excess Air (%)	1150	1115	470	470	470
Excess O ₂ (%)	375	370	370	370	365
Scot-Blowing	345	450	355	355	355
Boiler Inlet Feed Water Temp (OF)					
Boiler Exit Steam Press. (psig)	205	205	215	210	210
Boiler Exit Steam Temp (OF)					
Reheat Inlet Steam Press. (psig)	6.1	6.1	6.2	6.2	6.2
Reheat Inlet Steam Temp (OF)					
Reheat Exit Steam Press. (psig)					
Reheat Exit Steam Temp (OF)					

Date April 17, 19

Stack 4

Stack Identification Number

Boiler Number 19-20-21-22

Plant Location Steel Point

3010

TEST 2

Parameters	0707	0708	1147
Gross Load (MW)			
Net Load (MW)	78.220	71.257	76.546
Fuel Flow (gal/hr)			
Steam Flow (lb/hr)			
Feed-Water-Flow (lb/hr)	330	467	400
Air Flow	435	445	430
Excess Air (%)	11.40	11.50	11.5
Excess O2 (%)	1.20	1.10	1.15
Soot Blowing			
Boiler Inlet Feed Water Temp (°F)			
Boiler Exit Steam Press. (psig)	205	215	210
Boiler Exit Steam Temp (°F)			
Reheat-Inlet Steam Press. (psig)	7.3	7.3	7.1
Reheat-Inlet Steam Temp (°F)			
Reheat-Exit Steam Press. (psig)			
Reheat-Exit Steam Temp (°F)			

Date 1/17/17.1978

Stack Identification Number

19-20-21-22

TEST 3

Boiler Number

STEEL PART

Plant Location

Boiler # 299

Parameters	1226	1343	1519		
Gross Load (MW)					
Net Load (MW)	77611	79708	82350		
Fuel Flow (gal/hr)					
Steam Flow (lb/hr)					
Feed-Water-Flow (lb/hr)	490	460	405		
Air Flow	430	415	420		
Excess-Air (%)	455	455	450		
Excess-O ₂ (%)	315	315	315		
Soot-Blowing					
Boiler Inlet Feed Water Temp (°F)					
Boiler Exit Steam Press. (psig)	210	210	210		
Boiler Exit Steam Temp (°F)					
Reheat Inlet Steam Press. (psig)					
Reheat-Inlet-Steam Temp (°F)	7.1	7.2	7.1		
Reheat-Exit-Steam Press. (psig)					
Reheat-Exit-Steam Temp (°F)					

LP 108. DUCT

APPENDIX D

SAMPLE CALCULATIONS

SAMPLE CALCULATIONS

NOTE: All equations used in these calculations are found in the Federal Register, Vol. 36, No. 247, dated December 23, 1971.

Calculations representative of Test #1.

1. Dry Gas Volume

$$\begin{aligned} V_{mstd} &= \left(17.71 \frac{^{\circ}R}{\text{in.Hg.}} \right) V_m \left(\frac{P_{bar} + \frac{\Delta H}{13.6}}{T_m} \right) && \text{eq. 5-1} \\ &= \left(17.71 \frac{^{\circ}R}{\text{in.Hg.}} \right) 90.921 \text{ ft}^3 \left(\frac{29.31 \text{ In.Hg.} + \frac{1.609 \text{ in. H}_2\text{O}}{13.6}}{531.5 \text{ }^{\circ}R} \right) \\ &= 89.155 \text{ ft}^3 \end{aligned}$$

2. Volume of Water Vapor

$$\begin{aligned} V_{wstd} &= \left(0.0474 \frac{\text{ft}^3}{M} \right) V_{lc} && \text{eq. 5-2} \\ &= \left(0.0474 \frac{\text{ft}^3}{M} \right) 106.5 \text{ ml} \\ &= 5.048 \text{ ft}^3 \end{aligned}$$

3. Moisture Content

$$\begin{aligned} B_{ws} &= \frac{V_{wstd}}{V_{wstd} + V_{mstd}} \\ &= \frac{5.048 \text{ ft}^3}{5.048 \text{ ft}^3 + 89.155 \text{ ft}^3} \\ &= 0.0535 \times 100\% = 5.4\% \end{aligned}$$

4. Molecular Weight (dry)

$$M_d = 0.44 (\% \text{ CO}_2) + 0.32 (\% \text{ O}_2) + 0.28 (\% \text{ N}_2) + 0.28 (\% \text{ CO}) \quad \text{eq. 3-2}$$

$$= 0.44 (8.76) + 0.32 (8.92) + 0.28 (82.32) + 0.28 (0.00)$$

$$= 29.76 \text{ lb/lb-mole}$$

5. Molecular Weight (wet)

$$M_s = M_d (1 - B_{ws}) + 18 B_{ws}$$

$$= 29.76 (1 - .054) + 18 (.054)$$

$$= 29.12 \text{ lb/lb-mole}$$

6. Stack Gas Velocity

$$V_s = K_p C_p \sqrt{\Delta P} \left(\frac{T_s}{P_s \times M_s} \right)^{1/2} \quad \text{eq. 2-2}$$

$$= (85.48) (0.84) (0.210) \left(\frac{994.6}{29.31 \times 29.12} \right)^{1/2}$$

$$= 16.28 \text{ F.P.S.}$$

7. Gas Volumetric Flow Rate, ACFM

$$\text{ACFM} = V_s \times A_s \times 60 \text{ sec/min}$$

$$= 16.28 \times 178.6 \text{ ft}^2 \times 60 \text{ sec/min}$$

$$= 174,456 \text{ ACFM}$$

8. Gas Volumetric Flow Rate, SCFM

$$Q_s = 60 (1 - B_{ws}) V_s A_s \left(\frac{T_{std}}{T_s} \right) \left(\frac{P_s}{P_{std}} \right) \quad \text{eq. 2-3}$$

$$= 60 (1 - .054) (16.28) (178.6) \left(\frac{530}{994.6} \right) \left(\frac{29.31}{29.92} \right)$$

$$= 86,151 \text{ SCFM}$$

9. Gas Volumetric Flow Rate, lb/hr

$$\begin{aligned}
 W_s &= Q_s \times \frac{60 \text{ min}}{\text{hr}} \times \frac{M_d}{386 \text{ ft}^3} \\
 &= 86,151 \text{ SCFM} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{29.76 \text{ lb/lb-mole}}{386 \text{ ft}^3} \\
 &= 398,526 \text{ lb/hr}
 \end{aligned}$$

10. Particulate Concentrations, gr/SCF

$$\begin{aligned}
 C's &= \left(0.0154 \frac{\text{gr}}{\text{mg}} \right) \frac{M_n}{V_{mstd}} && \text{eq. 5-4} \\
 &= \left(0.0154 \frac{\text{gr}}{\text{mg}} \right) \frac{156.7 \text{ mg}}{89.155 \text{ ft}^3} \\
 &= 0.027 \text{ gr/SCF}
 \end{aligned}$$

11. Particulate Concentrations, lb/ft³

$$\begin{aligned}
 C_s &= \frac{\left(\frac{1}{453600} \frac{\text{lb}}{\text{mg}} \right) M_n}{V_{mstd}} && \text{eq. 5-5} \\
 &= \frac{\left(\frac{1}{453600} \frac{\text{lb}}{\text{mg}} \right) 156.7 \text{ mg}}{89.155 \text{ ft}^3} \\
 &= 3.87 \times 10^{-6} \text{ lb/SCF}
 \end{aligned}$$

12. Particulate Concentrations, lb/hr

$$\begin{aligned}
 C_w &= C_s Q_s \times \frac{60 \text{ min}}{\text{hr}} \\
 &= (3.87 \times 10^{-6} \text{ lb/SCF}) (86,151 \text{ SCFM}) \frac{60 \text{ min}}{\text{hr}} \\
 &= 20.00 \text{ lb/hr}
 \end{aligned}$$

13. Particulate Concentrations, lb/MBTU

$$\begin{aligned}
 E_r &= \frac{C_w}{\text{Heat Input}} \\
 &= \frac{20.00 \text{ lb/hr}}{290.8 \times 10^6 \text{ BTU/hr}} \\
 &= 0.069 \text{ lb/MBTU}
 \end{aligned}$$

14. % Isokinetic Sampling

$$\begin{aligned}
 I &= \frac{\bar{T}_s \left(1.667 \frac{\text{min}}{\text{sec}} \right) \left((0.00267) V_{lc} + \frac{V_m}{T_m} \left(P_{\text{bar}} + \frac{\Delta H}{13.6} \right) \right)}{\ominus V_s P_s A_n} \quad \text{eq. 5-6} \\
 &= \frac{994.6 (1.667) \left((0.00267) (106.5) + \frac{90.921}{531.5} \left(29.31 + \frac{1.609}{13.6} \right) \right)}{(135) (16.28) (29.31) (0.001363)} \\
 &= 100.4\%
 \end{aligned}$$

15. NO_x Concentrations, lb/hr

$$\begin{aligned}
 \text{lb/hr} &= \text{ppm} \times \frac{M_w (\text{NO}_2)}{M_d} \times W_s \\
 &= \frac{106.5}{10^6} \times \frac{46 \text{ lb/lb-mole}}{29.76 \text{ lb/lb-mole}} \times 398,526 \frac{\text{lb}}{\text{hr}} \\
 &= 65.6 \text{ lb/hr}
 \end{aligned}$$

16. NO_x Concentrations, lb/MBTU

$$\begin{aligned}
 \text{lb/MBTU} &= \frac{\text{lb/hr}}{\text{Heat Input}} \\
 &= \frac{65.6 \text{ lb/hr}}{290.8 \times 10^6 \text{ BTU/hr}} \\
 \text{lb/MBTU} &= \frac{0.226 \text{ lb}}{10^6 \text{ BTU}}
 \end{aligned}$$

17. Stack Pressure (Absolute), in.Hg.

$$P_s = P_b + \frac{P_d}{13.6} = 29.31 + \frac{(-0.01)}{13.6} = 29.31 \text{ in.Hg.}$$

18. Nozzle Area (ft²)

$$A_n = \pi D^2/4 = 0.785 (0.500/12)^2 = 13.63 \times 10^{-4} \text{ ft}^2$$

19. Stack Area (ft²)

$$A_s = \pi D^2/4 = 0.785 (181/12)^2 = 178.6 \text{ ft}^2$$

20. Heat Input, MBTU

Sp. Gr. x 8.33 lb/gal x BTU/lb x gal/hr

$$0.895 \times 8.33 \times 21,276 \times 1833 \text{ gal/hr} = 290.8 \text{ MBTU}$$

21. Gas Density, lb/ft³

$$\text{Gas Density} = \frac{\text{mol wt gas (md)}}{386 \text{ ft}^3} \times \frac{T_{\text{std}}}{T_s} \times \frac{P_{\text{bar}}}{P_{\text{std}}}$$

$$= \frac{29.76}{386} \times \frac{530^{\circ}\text{R}}{994.6} \times \frac{29.31}{29.92} = 0.040 \text{ lb/ft}^3$$

THE UNITED ILLUMINATING COMPANY

SOURCE TESTING CALCULATION FORMS

est No. Steel Point #4 No. Runs 3

ame of Firm The United Illuminating Company

ocation of Plant 43 East Main Street, Bridgeport, Connecticut

ype of Plant Steam Generating Station

ontrol Equipment None

ampling Point Locations Stack

ollutants Sampled Particulates, Nitrogen Oxides

Time of Particulate Test:

Run No. 1 Date 11/16/73 Begin 11:07 End 14:21

Run No. 2 Date 11/17/73 Begin 8:56 End 11:41

Run No. 3 Date 11/17/73 Begin 12:19 End 15:05

PARTICULATE EMISSION DATA

Run No.	1	2	3	
$K_p = 85.49 \frac{ft}{sec} \left(\frac{lb.}{lb \text{ mole-}^{\circ}R} \right)^{\frac{1}{2}}$	85.48	85.48	85.48	
$C_p = \text{Pitot tube coefficient (calib.)}$	0.84	0.84	0.84	
$\sqrt{VAP} = \text{Average velocity head of stack gas, inches H}_2\text{O}$	0.210	0.215	0.238	
$\bar{T}_s = \text{Average stack temp., }^{\circ}R$	994.6	995.2	1003.7	
$P_b = \text{Barometric pressure, "Hg Abs.}$	29.31	30.01	30.01	
$P_d = \text{Gas duct pressure, "H}_2\text{O}$	-0.01	-0.01	-0.01	
$P_s = \text{Absolute stack gas pressure, inches Hg}$	29.31	30.01	30.01	
$B_{ws} = \text{\% moisture in stack gas, by volume}$	5.4	4.9	5.2	
$M_d = \text{Molecular weight of stack gas, dry}$	29.76	29.59	29.72	
$M_s = \text{Molecular weight of stack gas}$	29.12	29.02	29.11	

Run NO.				
V_s = Stack gas velocity, F.P.S.	16.28	16.50	18.32	
% CO ₂	8.76	7.50	8.42	
% O ₂	8.92	9.76	9.42	
% CO	0.00	0.00	0.00	
% N ₂	82.32	82.74	82.16	
V_{lc} = Total volume of liquid collected in impingers and silica gel, ml.	106.5	106.0	121.5	
V_m = Volume of dry gas sampled at meter conditions, FT ³	90.921	95.978	101.812	
V_{std} = Volume of dry gas sampled at STP, FT ³	89.155	98.095	104.535	
T_m = Average dry gas meter temp., °R	531.5	522.2	520.2	
ΔH = Average pressure drop across orifice, inches H ₂ O	1.609	1.721	2.026	
θ = Total Sampling Time, min.	135	140	135	
D_n = Nozzle dia., inches	0.500	0.500	0.500	
A_n = Nozzle area, FT ²	13.63	13.63	13.63	
I = % of isokinetic sampling	100.4	102.2	103.0	
Q_s = Stack gas volume at STP (SCFM)	86,151	89,819	98,570	91,513
Q_a = Stack gas volume at stack conditions (ACFM)	174,456	176,814	196,317	182,529
W_s = Stack gas mass flow lbs/hr	398,526	413,121	455,363	422,337
M_p = Particulate-probe, washings, mg	-	-	-	
M_f = Particulate-filter (mg)	-	-	-	
M_n = Particulate-total (mg)	156.7	115.4	355.6	
$C's$ = Particulate Concentrations gr/scf	0.027	0.018	0.052	
C_w = Particulate total emission lb/hr	20.00	13.96	44.30	26.09
E_r = Particulate emission rate, lb/10 ⁶ BTU	0.069	0.059	0.187	0.105
C = NO _x concentrations, PPM	106.5	90	93	96.5
C_n = NO _x , lb/10 ⁶ BTU	0.226	0.244	0.276	0.249